

RAS J-66

In the Matter of Entergy (Pilgrim Nuclear Power Station)

Docket No. 50-293-LR Official Exhibit No. 36

OFFERED by: Applicant/Licensee (Inter) PilgrimWatch Ex 23

NRC Staff Other

IDENTIFIED on 4-10-08 Witness/Panel

Action Taken: ADMITTED REJECTED WITHDRAWN

Reported/Clark Thibault

Index | Site Map | FAQ | Facility Info | Reading Rm | New | Help | Glossary | Contact Us



Home > Electronic Reading Room > Document Collections > Reports Associated with Events > Event Notification Reports > 2007 > December 11

Event Notification Report for December 11, 2007

DOCKETED
UISNRC

U.S. Nuclear Regulatory Commission
Operations Center

April 15, 2008 (10:00am)

Event Reports For
12/10/2007 - 12/11/2007

OFFICE OF SECRETARY
RIII FMAKINGS AND
ADJUDICATIONS STAFF

** EVENT NUMBERS **

43832

TGP

Power Reactor	Event Number: 43832
Facility: PALISADES Region: 3 State: MI Unit: [1] [] [] RX Type: [1] CE NRC Notified By: TODD MULFORD HQ OPS Officer: JASON KOZAL	Notification Date: 12/10/2007 Notification Time: 22:21 [ET] Event Date: 12/10/2007 Event Time: 18:30 [EST] Last Update Date: 12/10/2007
Emergency Class: NON EMERGENCY 10 CFR Section: 50.72(b)(2)(xi) - OFFSITE NOTIFICATION	Person (Organization): JOHN MADERA (R3)

Unit	SCRAM Code	RX CRIT	Initial PWR	Initial RX Mode	Current PWR	Current RX Mode
1	N	Y	100	Power Operation	100	Power Operation

Event Text

NOTIFICATION TO OFFSITE AGENCIES DUE TO ELEVATED TRITIUM LEVELS

"Five new ground water monitoring wells were recently installed at Palisades Nuclear Plant in support of the Nuclear Energy institute (NEI) ground water initiative. The initial sampling of one of these wells displayed a level of tritium that triggered the communication protocol of the NEI initiative on ground water protection. On December 10, 2007, at 1830 hours, Entergy confirmed that the tritium concentration for this well was 22,000 picoCuries per liter (pCi/l). The threshold for initiating the communication protocol is 20,000 pCi/l (Offsite Dose Calculation Manual limit for drinking water). This well is located inside the owner controlled area and inside the protected area. This well is not a drinking water source. Entergy is continuing to investigate the source of tritium identified in this well. Samples from the remaining four wells are below minimum detectable activity levels. There is no indication that tritium has migrated off the Palisades site. The licensee plans to notify the State of Michigan, Van Buren County Office of Domestic Preparedness, City of South Haven, Covert Township, and the South Haven Charter Township.

"The licensee has notified the NRC Resident Inspector."

Temp = SECY-028

DS03