

RAS J-54

In the Matter of Entergy (Pilgrim Nuclear Power Station)
Docket No. 50-293-LR - Official Exhibit No. 24
OFFERED by: Applicant/Licensee Inter Pilgrim Watch Ex 11
NRC Staff _____ Other _____
IDENTIFIED on 4-10-08 Witness/Panel _____
Action Taken: ADMITTED REJECTED WITHDRAWN
Reporter/Clerk Thibault

June 5, 2007

UNITED STATES OF AMERICA
NUCLEAR REGULATORY COMMISSION

DOCKETED
USNRC

Before the Atomic Safety and Licensing Board

April 15, 2008 (10:00am)

OFFICE OF SECRETARY
RUI FMAKINGS AND
ADJUDICATIONS STAFF

In the Matter of)
)
Entergy Nuclear Generation Company and) Docket No. 50-293-LR
Entergy Nuclear Operations, Inc.) ASLBP No. 06-848-02-LR
)
(Pilgrim Nuclear Power Station))

**DECLARATION OF ALAN COX IN SUPPORT OF ENTERGY'S MOTION FOR
SUMMARY DISPOSITION OF PILGRIM WATCH CONTENTION 1**

Alan Cox states as follows under penalties of perjury:

⁶ The inlet SSW carbon steel piping that was replaced with titanium piping in order to prevent interior corrosion was never removed from the ground so the exterior coatings and surface of the original carbon steel SSW inlet piping were not examined.

Temp = SECY-028

DS03