

April 22, 2008

Ms. Andrea L. Sterdis  
Manager, Nuclear Licensing & Industry Affairs  
Nuclear Generation Development & Construction  
Tennessee Valley Authority  
1101 Market Street  
Chattanooga, Tennessee 37402-2801

SUBJECT: REQUEST FOR ADDITIONAL INFORMATION LETTER NO. 003 RELATED TO  
SRP SECTIONS 05.04.02.02 FOR THE BELLEFONTE UNITS 3 and 4  
COMBINED LICENSE APPLICATION

Dear Ms. Sterdis:

By letter dated September 30, 2007, as supplemented by letters dated November 2, 2007, January 8, 2008 and January 14, 2008, Tennessee Valley Authority (TVA) submitted its application to the U.S. Nuclear Regulatory Commission (NRC) for a combined license (COL) for two AP1000 advance passive pressurized water reactors pursuant to 10 CFR Part 52. The NRC staff is performing a detailed review of this application to enable the staff to reach a conclusion on the safety of the proposed application.

The NRC staff has identified that additional information is needed to continue portions of the review. The staff's request for additional information (RAI) is contained in the enclosure to this letter.

To support the review schedule, you are requested to respond within 45 days of the date of this letter. If changes are needed to the final safety analysis report, the staff requests that the RAI response include the proposed wording changes.

A. L. Sterdis

-2-

If you have any questions or comments concerning this matter, you may contact me at 301-415-6191 or you may contact Joseph Sebrosky, the lead project manager for the Bellefonte combined license at 301-415-1132.

Sincerely,

**/RA/**

Ravindra G. Joshi, Project Manager  
AP1000 Projects Branch 1  
Division of New Reactor Licensing  
Office of New Reactors

Docket Nos. 52-014  
52-015

Enclosure:  
Request for Additional Information

CC: see next page

A. L. Sterdis

-2-

If you have any questions or comments concerning this matter, you may contact me at 301-415-6191 or you may contact Joesph Sebrosky, the lead project manager for the Bellefonte combined license at 301-415-1132.

Sincerely,

**/RA/**

Ravindra G. Joshi, Project Manager  
AP1000 Projects Branch 1  
Division of New Reactor Licensing  
Office of New Reactors

Docket Nos. 52-014  
52-015  
eRAI Tracking No. 166

Enclosure:  
Request for Additional Information

Distribution:

Public	DTerao	BHughes
RidsNroDnrlNwe1	SCoffin	MComar
RidsNroLAKGoldstein	TSimms	AHodgdon
RidsOgcMailCenter	BAnderson	GMakar
RidsAcrsAcnwMailCenter	SSanders	
RidsRgn2MailCenter	JMazza	
JSebrosky	PMoulding	

ADAMS Accession No. ML081

NRO-002

OFFICE	CPIB/BC		NWE1/PM	OGC	NWE1/L-PM
NAME	DTerao*		RJoshi*	PMoulding*	JSebrosky*
DATE	4/14/08		4/21/08	4/22/08	4/22/08

\*Approval captured electronically in the electronic RAI system.

**OFFICIAL RECORD COPY**

**Request for Additional Information**  
**Bellefonte Units 3 and 4**  
**Tennessee Valley Authority**  
**Docket Nos.52-014 and 52-015**  
**SRP Section: 05.04.02.02- Steam Generator Program**  
**Application Section: 5.4.2.5**

**QUESTION from Component Integrity, Performance & Testing Branch 1**

05.04.02.02-1

According to SRP Section 5.4.2.2, the Steam Generator Program is an operational program that should be fully described, with implementation milestones listed in the appropriate table in Chapter 13 of the FSAR. Because Table 13.4-201 ("Operational Programs Required by NRC Regulations") of the COL application for Bellefonte Units 3 and 4 does not reference FSAR Section 5.4 or the Technical Specifications containing the implementation requirements for steam generator tube inspection, please discuss how the application ensures the Steam Generator Program is included as an operational program.

05.04.02.02-2

According to SRP Section 5.4.2.2, an acceptable steam generator inspection program will ensure that all tubes are inspected before being placed into service, using techniques that are expected to be used during subsequent inspections. Since this preservice inspection is not addressed by the proposed Technical Specifications, please discuss how TVA will ensure it is performed for Bellefonte Units 3 and 4.

Enclosure