

- (4) ENO pursuant to the Act and 10 CFR Parts 30, 40 and 70, to receive, possess, and use in amounts as required any byproduct, source or special nuclear material without restriction to chemical or physical form, for sample analysis or instrument calibration or associated with radioactive apparatus or components; Amdt. 203
11/27/00
- (5) ENO pursuant to the Act and 10 CFR Parts 30 and 70, to possess, but not separate, such byproduct and special nuclear materials as may be produced by the operation of the facility. Amdt. 203
11/27/00

C. This amended license shall be deemed to contain and is subject to the conditions specified in the following Commission regulations in 10 CFR Chapter I: Part 20, Section 30.34 of Part 30, Section 40.41 of Part 40, Sections 50.54 and 50.59 of Part 50, and Section 70.32 of Part 70; and is subject to all applicable provisions of the Act and to the rules, regulations, and orders of the Commission now or hereafter in effect; and is subject to the additional conditions specified or incorporated below:

(1) Maximum Power Level

ENO is authorized to operate the facility at steady state reactor core power levels not in excess of 3216 megawatts thermal (100% of rated power).

(2) Technical Specifications

The Technical Specifications contained in Appendices A and B, as revised through Amendment No. 236, are hereby incorporated in the License. ENO shall operate the facility in accordance with the Technical Specifications.

(3) (DELETED) Amdt. 205
2-27-01

(4) (DELETED) Amdt. 205
2-27-01

D. (DELETED) Amdt.46
2-16-83

E. (DELETED) Amdt.37
5-14-81

F. This amended license is also subject to appropriate conditions by the New York State Department of Environmental Conservation in its letter of May 2, 1975, to Consolidated Edison Company of New York, Inc., granting a Section 401 certification under the Federal Water Pollution Control Act Amendments of 1972.

Facility Operating License No. DPR-64
Appendix A – Technical Specifications

TABLE OF CONTENTS

3.4	REACTOR COOLANT SYSTEM (RCS)
3.4.1	RCS Pressure, Temperature, and Flow Departure from Nucleate Boiling (DNB) Limits
3.4.2	RCS Minimum Temperature for Criticality
3.4.3	RCS Pressure and Temperature (P/T) Limits
3.4.4	RCS Loops—MODES 1 and 2
3.4.5	RCS Loops—MODE 3
3.4.6	RCS Loops—MODE 4
3.4.7	RCS Loops—MODE 5, Loops Filled
3.4.8	RCS Loops—MODE 5, Loops Not Filled
3.4.9	Pressurizer
3.4.10	Pressurizer Safety Valves
3.4.11	Pressurizer Power Operated Relief Valves (PORVs)
3.4.12	Low Temperature Overpressure Protection (LTOP)
3.4.13	RCS Operational LEAKAGE
3.4.14	RCS Pressure Isolation Valve (PIV) Leakage
3.4.15	RCS Leakage Detection Instrumentation
3.4.16	RCS Specific Activity
3.4.17	Steam Generator (SG) Tube Integrity
3.5	EMERGENCY CORE COOLING SYSTEMS (ECCS)
3.5.1	Accumulators
3.5.2	ECCS—Operating
3.5.3	ECCS—Shutdown
3.5.4	Refueling Water Storage Tank (RWST)
3.6	CONTAINMENT SYSTEMS
3.6.1	Containment
3.6.2	Containment Air Locks
3.6.3	Containment Isolation Valves
3.6.4	Containment Pressure
3.6.5	Containment Air Temperature
3.6.6	Containment Spray System and Containment Fan Cooler System
3.6.7	Recirculation pH Control System
3.6.8	Not Used
3.6.9	Isolation Valve Seal Water (IVSW) System
3.6.10	Weld Channel and Penetration Pressurization System (WC & PPS)

(continued)

3.6 CONTAINMENT SYSTEMS

3.6.7 Recirculation pH Control System

LCO 3.6.7 The Recirculation pH Control System shall be OPERABLE.

APPLICABILITY: MODES 1, 2, 3, and 4.

ACTIONS

CONDITION	REQUIRED ACTION	COMPLETION TIME
A. Recirculation pH Control System inoperable.	A.1 Restore Recirculation pH Control System to OPERABLE status.	72 hours
B. Required Action and associated Completion Time not met.	B.1 Be in MODE 3.	6 hours
	<u>AND</u> B.2 Be in MODE 5.	84 hours

SURVEILLANCE REQUIREMENTS

SURVEILLANCE	FREQUENCY
SR 3.6.7.1 Perform a visual inspection of the eight sodium tetraborate storage baskets to verify each of the following: a. Each storage basket is in place and intact; and, b. Collectively contain \geq 8096 pounds (160 cubic feet) of sodium tetraborate decahydrate, or equivalent.	24 months