

June 16, 2008

Vice President, Operations  
Entergy Nuclear Operations  
Palisades Nuclear Plant  
27780 Blue Star Memorial Highway  
Covert, MD 49043-9530

SUBJECT: PALISADES NUCLEAR PLANT - CORRECTION TO AMENDMENT NO. 232 FOR  
REVISION TO TECHNICAL SPECIFICATION (TS) 5.5.7 INSERVICE TESTING  
PROGRAM (TAC NO. MD5713)

Dear Sir or Madam:

On April 15, 2008, the Nuclear Regulatory Commission issued Amendment No. 232 to Renewed Facility Operating License No. DPR-20 for the Palisades Nuclear Plant (Agencywide Documents Access and Management System (ADAMS) Accession No. ML080730011).

The amendment incorporates TS changes based on Nuclear Regulatory Commission (NRC)-approved TS Task Force (TSTF)-497-A, "Changes to Reflect Revision of 10 CFR 50.55a," Revision 0, as modified by NRC-approved TSTF-497, "Limit Inservice Testing Program [Surveillance Requirements] SR 3.0.2 Application to Frequencies of Two years or Less." Specifically, the amendment revises Palisades Nuclear Plant TS Section 5.5.7, "Inservice Testing Program," to update references to the American Society of Mechanical Engineers code and applicability of the provisions of SR 3.0.2.

Subsequently, the Amendment No. was inadvertently left off of License Page 3. Our revised License Page is enclosed with the Amendment No. We regret any inconvenience this may have caused. If you have any further concerns, please contact me at 301-415-8371.

Sincerely,

*/RA/*

Mahesh L. Chawla, Project Manager  
Plant Licensing Branch III-1  
Division of Operating Reactor Licensing  
Office of Nuclear Reactor Regulation

Docket No. 50-255

Enclosure:  
License Page 3

cc w/encl: See next page

Vice President, Operations  
Entergy Nuclear Operations  
Palisades Nuclear Plant  
27780 Blue Star Memorial Highway  
Covert, MD 49043-9530

June 16, 2008

SUBJECT: PALISADES NUCLEAR PLANT - CORRECTION TO AMENDMENT NO. 232 FOR REVISION TO TECHNICAL SPECIFICATION (TS) 5.5.7 INSERVICE TESTING PROGRAM (TAC NO. MD5713)

Dear Sir or Madam:

On April 15, 2008, the Nuclear Regulatory Commission issued Amendment No. 232 to Renewed Facility Operating License No. DPR-20 for the Palisades Nuclear Plant (Agencywide Documents Access and Management System (ADAMS) Accession No. ML080730011).

The amendment incorporates TS changes based on Nuclear Regulatory Commission (NRC)-approved TS Task Force (TSTF)-497-A, "Changes to Reflect Revision of 10 CFR 50.55a," Revision 0, as modified by NRC-approved TSTF-497, "Limit Inservice Testing Program [Surveillance Requirements] SR 3.0.2 Application to Frequencies of Two years or Less." Specifically, the amendment revises Palisades Nuclear Plant TS Section 5.5.7, "Inservice Testing Program," to update references to the American Society of Mechanical Engineers code and applicability of the provisions of SR 3.0.2.

Subsequently, the Amendment No. was inadvertently left off of License Page 3. Our revised License Page is enclosed with the Amendment No. We regret any inconvenience this may have caused. If you have any further concerns, please contact me at 301-415-8371.

Sincerely,

*/RA/*

Mahesh L. Chawla, Project Manager  
Plant Licensing Branch III-1  
Division of Operating Reactor Licensing  
Office of Nuclear Reactor Regulation

Docket No. 50-255

Enclosure:

License Page 3

cc w/encl: See next page

**DISTRIBUTION:**

PUBLIC LPL3-1 r/f RidsNrrDorlLpl3-1 RidsNrrPMMChawla  
RidsNrrLATHarris RidsOgcRp RidsAcrsAcnw&mMailcenter RidsNrrDorlDpr  
RidsNrrDirsltsb G. Hill, OIS RidsRgn3MailCenter

**ADAMS ACCESSION NUMBER: ML081150639**

OFFICE	NRR/LPL3-1/PM	NRR/LPL3-1/LA	NRR/LPL3-1/BC
NAME	MChawla	THarris	LJames
DATE	06/12/08	04/25/08	06/16/08

OFFICIAL RECORD COPY

Palisades Plant

cc:

Supervisor  
Covert Township  
P. O. Box 35  
Covert, MI 49043

Office of the Governor  
P. O. Box 30013  
Lansing, MI 48909

U.S. Nuclear Regulatory Commission  
Resident Inspector's Office  
Palisades Plant  
27782 Blue Star Memorial Highway  
Covert, MI 49043

Michigan Department  
of Environmental Quality  
Waste and Hazardous  
Materials Division  
Hazardous Waste and Radiological  
Protection Section  
Nuclear Facilities Unit  
Constitution Hall, Lower-Level North  
525 West Allegan Street  
P.O. Box 30241  
Lansing, MI 48909-7741

Michigan Department of Attorney General  
Special Litigation Division  
525 West Ottawa St.  
Sixth Floor, G. Mennen Williams Building  
Lansing, MI 48913

Senior Vice President  
Entergy Nuclear Operations  
P. O. Box 31995  
Jackson, MS 39286-1995

Vice President Oversight  
Entergy Nuclear Operations  
P. O. Box 31995  
Jackson, MS 39286-1995

Senior Manager, Nuclear Safety  
& Licensing  
Entergy Nuclear Operations  
P. O. Box 31995  
Jackson, MS 39286-1995

Senior Vice President and COO  
Entergy Nuclear Operations  
440 Hamilton Avenue  
White Plains, NY 10601

Assistant General Counsel  
Entergy Nuclear Operations  
440 Hamilton Avenue  
White Plains, NY 10601

Manager, Licensing  
Entergy Nuclear Operations  
Palisades Nuclear Plant  
27780 Blue Star Memorial Highway  
Covert, MI 49043-9530

- (1) Pursuant to Section 104b of the Act, as amended, and 10 CFR Part 50, "Licensing of Production and Utilization Facilities," (a) ENP to possess and use, and (b) ENO to possess, use and operate, the facility as a utilization facility at the designated location in Van Buren County, Michigan, in accordance with the procedures and limitation set forth in this license;
  - (2) ENO, pursuant to the Act and 10 CFR Parts 40 and 70, to receive, possess, and use source and special nuclear material as reactor fuel, in accordance with the limitations for storage and amounts required for reactor operation, as described in the Updated Final Safety Analysis Report, as supplemented and amended;
  - (3) ENO, pursuant to the Act and 10 CFR Parts 30, 40, and 70, to receive, possess, and use byproduct, source, and special nuclear material as sealed sources for reactor startup, reactor instrumentation, radiation monitoring equipment calibration, and fission detectors in amounts as required;
  - (4) ENO, pursuant to the Act and 10 CFR Parts 30, 40, and 70, to receive, possess, and use in amounts as required any byproduct, source, or special nuclear material for sample analysis or instrument calibration, or associated with radioactive apparatus or components; and
  - (5) ENO, pursuant to the Act and 10 CFR Parts 30, 40, and 70, to possess, but not separate, such byproduct and special nuclear materials as may be produced by the operations of the facility.
- C. This renewed operating license shall be deemed to contain and is subject to the conditions specified in the Commission's regulations in 10 CFR Chapter I and is subject to all applicable provisions of the Act; to the rules, regulations, and orders of the Commission now or hereafter in effect; and is subject to the additional conditions specified or incorporated below:
- (1) ENO is authorized to operate the facility at steady-state reactor core power levels not in excess of 2565.4 Megawatts thermal (100 percent rated power) in accordance with the conditions specified herein.
  - (2) The Technical Specifications contained in Appendix A, as revised through Amendment No. 232, and the Environmental Protection Plan contained in Appendix B are hereby incorporated in the license. ENO shall operate the facility in accordance with the Technical Specifications and the Environmental Protection Plan.
  - (3) ENO shall implement and maintain in effect all provisions of the approved fire protection program as described in the Final Safety Analysis Report for the facility and as approved in the SERs dated 09/01/78, 03/19/80, 02/10/81, 05/26/83, 07/12/85, 01/29/86, 12/03/87, and 05/19/89 and subject to the following provisions: