



Westinghouse Electric Company  
Nuclear Services  
P.O. Box 355  
Pittsburgh, Pennsylvania 15230-0355  
USA

U.S. Nuclear Regulatory Commission  
Document Control Desk  
Washington, DC 20555-0001

Direct tel: (412) 374-4643  
Direct fax: (412) 374-4011  
e-mail: greshaja@westinghouse.com

Our ref: LTR-NRC-08-19  
April 11, 2008

Subject: Response to NRC's Request for Sensitivity Studies Regarding Appendix A of Topical Report (TR) WCAP-16608-P, "Westinghouse Containment Analysis Methodology" (TAC No. MD2953) (Non-proprietary)

Enclosed are copies of the Non-Proprietary responses to NRC's Request for Sensitivity Studies Regarding Appendix A of Topical Report (TR) WCAP-16608-P, "Westinghouse Containment Analysis Methodology."

This submittal does not contain proprietary information and may be placed in the public domain.

Very truly yours,

A handwritten signature in black ink, appearing to read 'J. A. Gresham', written over a horizontal line.

J. A. Gresham, Manager  
Regulatory Compliance and Plant Licensing

Enclosures

cc: A. Mendiola, NRR  
R. Lobel, NRR  
J. Thompson, NRR

T007

Add copies have been  
sent to the PM

LRR

**Response to NRC's Request for Sensitivity Studies  
Regarding Appendix A of Topical Report (TR) WCAP-  
16608-P, "Westinghouse Containment Analysis  
Methodology"  
(TAC No. MD2953) (Non-Proprietary)**

Westinghouse Electric Company  
P.O. Box 355  
Pittsburgh, Pennsylvania 15230-0355

© 2008 Westinghouse Electric Company LLC  
All Rights Reserved

As part of their acceptance review for WCAP-16608, Appendix A, the NRC asked Westinghouse to determine the sensitivity to the condensation heat and mass transfer option with the generic GOTHIC BWR Mark I containment model. The sensitivity cases were run using the RSLB peak pressure and ECCS minimum backpressure models. The condensation heat and mass transfer option in each model was changed from DLM to DLM-FM for the sensitivity case.

Plots comparing the containment pressure, temperature, and suppression pool temperature responses with the two options are contained in the following pages. The model results are not very sensitive to the condensation heat and mass transfer option. We use the DLM option since it had been previously accepted by the NRC for PWR containment analyses.

### Test3 Drywell Pressure Comparison




Figure 1: RSLB Peak Pressure Case Comparison (Drywell Pressure)

### Test3 Wetwell Pressure Comparison




Figure 2: RSLB Peak Pressure Case Comparison (Wetwell Pressure)

### Test3 Drywell Vapor Temperature Comparison




Figure 3: RSLB Peak Pressure Case Comparison (Drywell Vapor Temperature)

### Test3 Wetwell Vapor Temperature Comparison




Figure 4: RSLB Peak Pressure Case Comparison (Wetwell Vapor Temperature)

### Test3 Wetwell Liquid Temperature Comparison




Figure 5: RSLB Peak Pressure Case Comparison (Suppression Pool Temperature)

### Case2zfix Drywell Pressure Comparison




Figure 6: ECCS Minimum Backpressure Case Comparison (Drywell Pressure)

### Case2zfix Wetwell Pressure Comparison




Figure 7: ECCS Minimum Backpressure Case Comparison (Wetwell Pressure)

### Case2zfix Drywell Vapor Temperature Comparison




Figure 8: ECCS Minimum Backpressure Case Comparison (Drywell Vapor Temperature)

### Case2zfix Wetwell Vapor Temperature Comparison




Figure 9: ECCS Minimum Backpressure Case Comparison (Wetwell Vapor Temperature)

### Case2zfix Wetwell Liquid Temperature Comparison




Figure 10: ECCS Minimum Backpressure Case Comparison (Suppression Pool Temperature)