

April 28, 2008

Mr. Gregory Gibson, Manager
Regulatory Affairs
STP Nuclear Operating Company
P. O. Box 289
Wadsworth, TX 77483

SUBJECT: REQUEST FOR ADDITIONAL INFORMATION LETTER NO. 10, REVISION 1,
RELATED TO THE SRP SECTION 02.03.03 FOR THE SOUTH TEXAS
COMBINED LICENSE APPLICATION

Dear Mr. Gibson:

By letter dated September 20, 2007, South Texas Project Nuclear Operating Company (STPNOC) submitted for approval a combined license application pursuant to 10 CFR Part 52. The U. S. Nuclear Regulatory Commission (NRC) staff is performing a detailed review of this application to enable the staff to reach a conclusion on the safety of the proposed application.

The NRC staff has identified that additional information is needed to continue portions of the review. The staff's request for additional information (RAI) is contained in the enclosure to this letter.

To support the review schedule, you are requested to respond within 45 days of the date of this letter. If changes are needed to the safety analysis report, the staff requests that the RAI response include the proposed wording changes.

Mr. Gregory Gibson

-2-

If you have any questions or comments concerning this matter, you may contact me at 301-415-1146 or Raj.Anand@nrc.gov, or you may contact George Wunder at 301-415-1494 or George.Wunder@nrc.gov.

Sincerely,

/RA/

Raj Anand, Project Manager
ESBWR/ABWR Projects Branch 2
Division of New Reactor Licensing
Office of New Reactors

Docket Nos. 52-012
52-013

eRAI Tracking No 144

Enclosure:
Request for Additional Information

cc: William Mookhoek

Mr. Gregory Gibson

-2-

If you have any questions or comments concerning this matter, you may contact me at 301-415-1146 or Raj.Anand@nrc.gov, or you may contact George Wunder at 301-415-1494 or George.Wunder@nrc.gov.

Sincerely,

/RA/

Raj Anand, Project Manager
ESBWR/ABWR Projects Branch 2
Division of New Reactor Licensing
Office of New Reactors

Docket Nos. 52-012
52-013

eRAI Tracking No 144

Enclosure:
Request for Additional Information

cc: William Mookhoek

Distribution:
PUBLIC
NGE 1/2 R/F
GWunder, NRO
BHarvey, NRO
SBrock, OGC
RidsNroDsraSbpb
RidsNroDnrlNge2

ADAMS Accession No. ML

NRO-002

OFFICE	SBPB/TR	SBPB/BC	NGE2/PM	OGC	NGE1/L-PM
NAME	BHarvey*	CCox*	RAnand*	SBrock*	GWunder*
DATE	4/9/08	4/9/08	4/28/08	4/12/08	4/15/08

* **Approval captured electronically in the electronic RAI system.**

OFFICIAL RECORD COPY

Request for Additional Information

South Texas Project Units 3 and 4
South Texas Project Nuclear Operating Co
Docket No. 52-012 and 52-013

SRP Section: 02.03.03 - Onsite Meteorological Measurements Programs
Application Section: 2.3S.3

QUESTION

02.03.03-3

FSAR Section 2.3S.3.4.1.2 compares stability class frequency distributions between the original onsite meteorological data set (1973-1977) and the current onsite meteorological data set (1997, 1999, and 2000). Please explain the 6% increase of onsite A stability class frequency from the original data set to the current data set as shown in FSAR Table 2.3S-20 (see Figure 1).