EXAMINATION OUTLINE SUBMITTAL AND COMMENTS FOR THE FERMI INITIAL EXAMINATION - JANUARY 2008

Joseph H. Plona Site Vice President

6400 N. Dixie Highway, Newport, MI 48166 Tel: 734.586.5910 Fax: 734.586.4172



October 16, 2007 NRC-07-0054

Mr. Hironori Peterson Chief, Operations Branch Division of Reactor Safety U. S. Nuclear Regulatory Commission Region III Suite 210 2443 Warrenville Road Lisle, Illinois 60532-4352

Dear Mr. Peterson:

Enclosed please find the proposed examination outline submitted to the NRC in preparation for the upcoming Fermi 2 Initial License Examination scheduled during the week of January 28, 2008:

- Examination Outline Quality Checklist (Form ES-201-2)
- Photocopies of Examination Security Agreements (Form ES-201-3)
- RO Administrative Topics Outline(s) (Form ES-301-1)
- SRO Administrative Topics Outline(s) (Form ES-301-1)
- RO Control Room / In-Plant Systems Outline (Form ES-301-2)
- SRO Upgrade Control Room / In-Plant Systems Outline (Form ES-301-2)
- SRO Instant Control Room/In-Plant Systems Outline (Form ES-301-2)
- Transient and Event Checklist (Form ES-301-5)
- Scenario Outlines (Form ES-D-1)
- RO BWR Examination Outline (Form ES-401-1)
- SRO BWR Examination Outline (Form ES-401-1)
- Generic K/A Outline (Form ES-401-3)
- Record of Rejected K/As (Form ES-401-4)

Hironori Peterson Chief, Operations Branch NRC-07-0054 October 16, 2007 Page 2

The examination outline was developed using the appropriate guidance contained in Revision 9, NUREG 1021, Supplement 1. These materials shall be withheld from public disclosure until after the examinations are complete.

We look forward to working with you and your examination team during the examination development and administration process. If you have any questions or comments regarding the contents of the items listed above, please contact Mr. Timothy P. Horan. General Supervisor, Operations Training at (734) 586-4961.

Sincerely,

Joseph Planc

Enclosure

cc: Chief, Reactor Operations Branch NRC Resident Office Document Control Desk Washington D. C.

Form ES-201-2

Facility	: Date of Examination:											
itom	Task Description		Initiai	s								
	Task Description a. Verify that the outline(s) fit(s) the appropriate model in accordance with ES-401											
1. W	a. Verify that the outline(s) fit(s) the appropriate model, in accordance with ES-401.	C.S	1nt	MF6								
R I T	b. Assess whether the outline was systematically and randomly prepared in accordance with Section D.1 of ES-401 and whether all K/A categories are appropriately sampled.											
T	c. Assess whether the outline over-emphasizes any systems, evolutions, or generic topics.	Ind	-18H	ME3								
E N	d. Assess whether the justifications for deselected or rejected K/A statements are appropriate.											
2. S	 a. Using Form ES-301-5, verify that the proposed scenario sets cover the required number of normal evolutions, instrument and component failures, technical specifications, and major transients. 	ß	<i>i</i> try	M83								
M U L A T	b. Assess whether there are enough scenario sets (and spares) to test the projected number and mix of applicants in accordance with the expected crew composition and rotation schedule without compromising exam integrity, and ensure that each applicant can be tested using at least one new or significantly modified scenario, that no scenarios are duplicated from the applicants' audit test(s), and that scenarios will not be repeated on subsequent days.	ß	<i>х</i> ^н	¥								
O R	c. To the extent possible, assess whether the outline(s) conform(s) with the qualitative and quantitative criteria specified on Form ES-301-4 and described in Appendix D.	F	,P#	MEB								
3. W / T	 a. Verify that the systems walk-through outline meets the criteria specified on Form ES-301-2: (1) the outline(s) contain(s) the required number of control room and in-plant tasks distributed among the safety functions as specified on the form (2) task repetition from the last two NRC examinations is within the limits specified on the form (3) no tasks are duplicated from the applicants' audit test(s) × (4) the number of new or modified tasks meets or exceeds the minimums specified on the form (5) the number of alternate path, low-power, emergency, and RCA tasks meet the criteria on the form. 	4	Trat	*								
	 b. Verify that the administrative outline meets the criteria specified on Form ES-301-1: (1) the tasks are distributed among the topics as specified on the form (2) at least one task is new or significantly modified (3) no more than one task is repeated from the last two NRC licensing examinations 	ß	.rplt	maz								
	c. Determine if there are enough different outlines to test the projected number and mix of applicants and ensure that no items are duplicated on subsequent days.	8	11214	MAG								
4.	 Assess whether plant-specific priorities (including PRA and IPE insights) are covered in the appropriate exam sections. 	G	ipu	m43								
G	b. Assess whether the 10 CFR 55.41/43 and 55.45 sampling is appropriate.	5	TP W	MGB								
Ň	c. Ensure that K/A importance ratings (except for plant-specific priorities) are at least 2.5.	4	7°4	mas								
E R	d. Check for duplication and overlap among exam sections.	5	TS W	INS								
A	e. Check the entire exam for balance of coverage.	3	19H	MAS								
	f. Assess whether the exam fits the appropriate job level (RO or SRO).	5	TPV	MAR								
a. Autt b. Faci c. NRC d. NRC	nor Repartie Repartie Printed Name/Signature ility Reviewer (*) Timothy 148 and A Standard A Stand	, cj., L	10/3	107 107 107 107								
Note:	Independent NRC reviewer initial items in Column "c"; chief examiner concurrence req Not applicable for NRC-prepared examination outlines	uired.										
	and the second s											

se Will verify no duplication of audit scenariosaduring onsite validation

ES-201, Page 26 of 28

Administrative Topics Outline

Form ES-301-1

Facility: <u>Fermi 2</u>		Date of Examination: 01/28/2008
Examination Level: RO 🛛 SI	RO 🗌	Operating Test Number: 2008-1
Administrative Topic (See Note)	Type Code*	Describe activity to be performed
Conduct of Operations	C,S,R,D	Perform Thermal Limit Verification (MAPRAT) 293009 Core Thermal Limits GENERIC 2.1.7 - Ability to evaluate plant performance and make operational judgments based on operating characteristics / reactor behavior / and instrument interpretation. RO 4.4 / SRO 4.7
Conduct of Operations	C,S,R,M	Complete and Communicate a Nuclear Plant Technical Data Form (Alert) GENERIC 2.4.39 - Knowledge of the RO's responsibilities in emergency plan implementation. RO 3.9 / SRO 3.8
Equipment Control	S,D	Perform 24.202.03, "HPCI System Piping Filled And Valve Position Verification" 206000 High Pressure Coolant Injection System GENERIC 2.2.12 - Knowledge of surveillance procedures. RO 3.7 / SRO 4.1
Radiation Control	C,S,R,D	Determine Dose Limit Will Be Exceeded and Initiate a Dose Extension. GENERIC 2.3.4 - Knowledge of radiation exposure limits and contamination control / including permissible levels in excess of those authorized. RO 3.2 / SRO 3.7
Emergency Plan		
NOTE: All items (5 total) are retaking only the adm	required for S inistrative top	SROs. RO applicants require only 4 items unless they are bics, when 5 are required.
* Type Codes & Criteria:	(C)ontro (D)irect (N)ew o (P)revio	l room, (S)imulator, or Class(R)oom from bank (≤ 3 for ROs; ≤ 4 for SROs & RO retakes) r (M)odified from bank (≥ 1) us 2 exams (≤ 1; randomly selected)

ES 301, Page 22 of 27

Administrative Topics Outline

Form ES-301-1

Facility: <u>Fermi 2</u>		Date of Examination: <u>1/28/2008</u>					
Examination Level: RO 🗌 SI	RO 🛛	Operating Test Number: <u>2008-1</u>					
Administrative Topic (See Note)	Type Code*	Describe activity to be performed					
Conduct of Operations	C,S,R,D	Perform Thermal Limit Verification (MAPRAT) 293009 Core Thermal Limits GENERIC 2.1.7 - Ability to evaluate plant performance and make operational judgments based on operating characteristics / reactor behavior / and instrument interpretation. RO 4.4 / SRO 4.7					
Conduct of Operations	C,R,S,P	Knowledge of Shift Staffing Requirements GENERIC 2.1.4 - Knowledge of individual licensed operator responsibilities related to shift staffing, such as medical requirements, "no-solo" operation, maintenance of active license status, 10CFR55, etc. RO 3.3 / SRO 3.8					
Equipment Control	S,D	Perform 24.202.03, "HPCI System Piping Filled And Valve Position Verification" 206000 High Pressure Coolant Injection System GENERIC 2.2.12 - Knowledge of surveillance procedures. RO 3.7 SRO 4.1					
Radiation Control	C,R,S,D	Determine Dose Limit and Complete a Dose Extension GENERIC 2.3.4 - Knowledge of radiation exposure limits under normal or emergency conditions. RO 3.2 / SRO 3.7					
Emergency Plan	C,S,R,M	Perform On-Site Protective Actions and Classification for Security Event (Alert) GENERIC 2.4.40 - Knowledge of the SRO's responsibilities in emergency plan implementation. RO 2.7 SRO 4.5					
NOTE: All items (5 total) are retaking only the adm	required for S inistrative top	SROs. RO applicants require only 4 items unless they are bics, when 5 are required.					
 * Type Codes & Criteria: (C)ontrol room, (S)imulator, or Class(R)oom (D)irect from bank (≤ 3 for ROs; ≤ 4 for SROs & RO retakes) (N)ew or (M)odified from bank (≥ 1) (P)revious 2 exams (≤ 1; randomly selected) 							

ES 301, Page 22 of 27

Control Room/In-Plant Systems Outline

Form ES-301-2

Facility: <u>Fermi 2</u>	Date of Examination: <u>1/28/2</u>	2008						
Exam Level: RO 🛛 SRO-I 🗌 SRO-U 🗌	Operating Test Number: 20	<u>08-1</u>						
Control Room Systems [@] (8 for RO); (7 for SRO-I); (2 or 3 for SRO-U, including 1 ESF)								
System / JPM Title	Type Code*	Safety Function						
 a. Shift Operating CRD Pumps 201001 Control Rod Drive Hydraulic System A4. Ability to manually operate and/or monitor in the control roo A4.01 CRD pumps RO 3.1 / SRO 3.1 	D,S om:	1						
 b. Manually Start the RCIC System 217000 Reactor Core Isolation Cooling System A4. Ability to manually operate and/or monitor in the control root A4.04 Manually initiated controls RO 3.6 / SRO 3.6 	D,S	2						
 c. Manually Initiate Low Low Set (No Fault) 239002 Relief/Safety Valves A4. Ability to manually operate and/or monitor in the control roo A4.01 SRV's RO 4.4 / SRO 4.4 	D,S	3						
 d. SOP Run of Core Spray System in Test Mode 209001 Low Pressure Core Spray System A2. Ability to (a) predict the impacts of the following on the LOV PRESSURE CORE SPRAY SYSTEM; and (b) based on those use procedures to correct, control, or mitigate the consequence abnormal conditions or operations: A2.06 Inadequate system flow RO 3.2 / SRO 3.2 	P,EN,D,A,S predictions, es of those	4						
 e. Restore a RWCU Pump After Oil Sample (Plant Hot) With S and Failure to Isolate 223002 Primary Containment Isolation System /Nuclear Stern Shut-Off A2. Ability to (a) predict the impacts of the following on the PRI CONTAINMENT ISOLATION SYSTEM/NUCLEAR STEAM SU SHUT-OFF; and (b) based on those predictions, use procedur control, or mitigate the consequences of those abnormal condition operations: A2.03 System logic failures RO 3.0 / SRO 3.3 	Eystem Leak N,S eam Supply IMARY JPPLY res to correct, tions or	5						
 f. Respond to Multiple Rod Drifts and RPS Failure 212000 Reactor Protection System A2. Ability to (a) predict the impacts of the following on the RE/ PROTECTION SYSTEM ; and (b) based on those predictions, procedures to correct, control, or mitigate the consequences of abnormal conditions or operations: 	D,A,S ACTOR use f those	7						

A2.16 Changing mode switch position RO 4.0 / SRO 4.1

g. Respond to Refuel Floor High Radiation 272000 Radiation Monitoring System		P,D,A,L,S	9
A2. Ability to (a) predict the impacts of the follo MONITORING SYSTEM; and (b) based on the procedures to correct, control, or mitigate the c abnormal conditions or operations:			
A2.12 Refuel floor handling accidents/operation			
h. Manually Initiate Div 1 Emergency Equipme 400000 Component Cooling Water Systems A4. Ability to manually operate and / or monitor A4.01 CCW indications and control BO.3.1/S	N,A,S	8	
In-Plant Systems [@] (3 for RO); (3 for SRO-I); (3	or 2 for SRO-U)		
 i. Shift In Service IAS Dryers 300000: Instrument Air System A2. Ability to (a) predict the impacts of the follo AIR SYSTEM and (b) based on those predictio control, or mitigate the consequences of those A2.01 Air dryer and filter malfunctions RO 2.9 / 	D,R	8	
j. Defeat ARI Logic Trips 216000: Nuclear Boiler Instrumentation Generic 2.4.34 Knowledge of RO tasks perfor room during emergency operations including sy implications. RO 4.2 / SRO 4.1	D,R,E	7	
 k. Place ESF Battery Charger in Service 263000: DC Electrical Distribution Generic 2.1.30 Ability to locate and operate controls. RO 4.4 / SRO 4.0 K1. Knowledge of the physical connections and between D.C. ELECTRICAL DISTRIBUTION a K1.02 Battery charger and battery RO 3.2 / SF 	D,R,	6	
All RO and SRO-I control room (and in-pla functions; all 5 SRO-U systems must serve overlap those tested in the control room.	ant) systems must be different and e different safety functions; in-plan	serve different s t systems and fu	afety inctions may
*Type Codes	Criteria for RO / S	RO-I / SRO-U	
(A)lternate path (C)ontrol room (D)irect from bank	/ 2-3 / <u>< 4</u> / > 1		
(E)mergency or abnormal in-plant (EN)gineered safety feature (L)ow-Power / Shutdown	/		
(P)revious 2 exams (R)CA (S)imulator	<u>≥</u> 2/ ≥2 ≤3/≤3/ ≥1/ ≥1	/ ≥ 1 ≤2 (randoml / ≥1	y selected)

ES-301, Page 23 of 27

Control Room/In-Plant Systems Outline

Form ES-301-2

Facility: <u>Fermi-2</u>	Date of Examination: 01/28	/2008
Exam Level: RO 🗌 SRO-I 🛛 SRO-U 🗌	Operating Test Number: 20	08-1
Control Room Systems [®] (8 for PO): (7 for SPO-I): (2 or 3 for SP		
		r
System / JPM Title	Type Code*	Safety Function
 a. Manually Start the RCIC System 217000 Reactor Core Isolation Cooling System A4. Ability to manually operate and/or monitor in the control roor 	D,S m:	2
A4.04 Manually Initiated controls RO 3.67 SRO 3.6		
 b. Manually Initiate Low Low Set (No Fault) 239002 Relief/Safety Valves 	D,S	3
A4. Ability to manually operate and/or monitor in the control roor A4.01 SRV's RO 4.4 / SRO 4.4	m:	
c. SOP Run of Core Spray System in Test Mode 209001 Low Pressure Core Spray System	P,EN,D,A,S	4
A2. Ability to (a) predict the impacts of the following on the LOW PRESSURE CORE SPRAY SYSTEM; and (b) based on those p use procedures to correct, control, or mitigate the consequences abnormal conditions or operations:	/ predictions, s of those	
A2.06 Inadequate system flow RO 3.2 / SRO 3.2		
d. Restore a RWCU Pump After Oil Sample (Plant Hot) With Sy and Failure to Isolate	stem Leak N,S	5
223002 Primary Containment Isolation System /Nuclear Stea Shut-Off	am Supply	
A2. Ability to (a) predict the impacts of the following on the PRIM CONTAINMENT ISOLATION SYSTEM/NUCLEAR STEAM SUF SHUT-OFF; and (b) based on those predictions, use procedure control, or mitigate the consequences of those abnormal condition	IARY PPLY s to correct, ons or	
operations:		
A2.03 System logic failures RO 3.0 / SRO 3.3		
e. Respond to Multiple Rod Drifts and RPS Failure	D,A,S	7
212000 Reactor Protection System		
A2. Ability to (a) predict the impacts of the following on the REAP PROTECTION SYSTEM; and (b) based on those predictions, u procedures to correct, control, or mitigate the consequences of t abnormal conditions or operations:	CTOR Ise those	
A2.16 Changing mode switch position RO 4.0 / SRO 4.1		

 f. Respond to Refuel Floor High Radiation 272000 Radiation Monitoring System A2. Ability to (a) predict the impacts of the following on the RADIATION MONITORING SYSTEM ; and (b) based on those predictions, use procedures to correct, control, or mitigate the consequences of those abnormal conditions or operations: A2.12 Refuel floor handling accidents/operations RO 3.3 / SRO 4.0 	P,D,A,L,S	9
 g. Manually Initiate Div 1 Emergency Equipment Cooling Water 400000 Component Cooling Water Systems (CCWS) A4. Ability to manually operate and / or monitor in the control room: A4.01 CCW indications and control .RO 3.1 / SRO 3.0 	N,A,S	8
h.		
In-Plant Systems [@] (3 for RO); (3 for SRO-I); (3 or 2 for SRO-U)		
 i. Shift In Service IAS Dryers 300000: Instrument Air System A2. Ability to (a) predict the impacts of the following on the INSTRUMENT AIR SYSTEM and (b) based on those predictions, use procedures to correct, control, or mitigate the consequences of those abnormal operation: A2.01 Air dryer and filter malfunctions RO 2.9 / SRO 2.8 	D,R	8
 j. Defeat ARI Logic Trips 216000: Nuclear Boiler Instrumentation Generic 2.4.34 Knowledge of RO tasks performed outside the main control room during emergency operations including system geography and system implications. RO 4.2 / SRO 4.1 	D,R,E	7
 k. Place ESF Battery Charger in Service 263000: DC Electrical Distribution Generic 2.1.30 Ability to locate and operate components, including local controls. RO 4.4 / SRO 4.0 K1. Knowledge of the physical connections and/or cause effect relationships between D.C. ELECTRICAL DISTRIBUTION and the following: K1.02 Battery charger and battery RO 3.2 / SRO 3.3 	D,R,	6
@ All RO and SRO-I control room (and in-plant) systems must be different and functions; all 5 SRO-U systems must serve different safety functions; in-plan overlap those tested in the control room.	serve different s t systems and fu	afety inctions may

*Type Codes	Criteria for RO / SRO-I / SRO-U
(A)Iternate path	4-6 / 4-6 / 2-3
(C)ontrol room	
(D)irect from bank	<u><</u> 9/ <u><</u> 8/ <u><</u> 4
(E)mergency or abnormal in-plant	<u>≥</u> 1/ <u>≥</u> 1 / <u>≥</u> 1
(EN)gineered safety feature	- / - / ≥ 1 (control room system)
(L)ow-Power / Shutdown	<u>≥</u> 1/ <u>≥</u> 1 / <u>≥</u> 1
(N)ew or (M)odified from bank including 1(A)	≥2/ ≥2 / ≥1
(P)revious 2 exams	\leq 3 / \leq 3 / \leq 2 (randomly selected)
(R)CA	<u>≥1/ ≥1 /≥</u> 1
(S)imulator	

ES-301, Page 23 of 27

Control Room/In-Plant Systems Outline

Form ES-301-2

Facility: <u>Fermi-2</u>	nination: <u>01/28/2008</u>		
Exam Level: RO 🗌 SRO-I 🗍 SRO-U 🛛	est Number: <u>20</u>	08-1	
Control Room Systems [@] (8 for RO); (7 for SRO-I); (2 or 3 for SF	RO-U, includin	g 1 ESF)	
System / JPM Title	Type Code*	Safety Function	
a. Temporary Removal and Restoration of SDC for I&C Surveill 205000 Shutdown Cooling System (RHR Shutdown Cooling	ances Mode)	N,EN,A,S	4
A4. Ability to manually operate and/or monitor in the			
control room:			
A4.01 SDC/RHR pumps RO 3.7 / SRO 3.7			
A4.03 SDC/RHR discharge valves RO 3.6 / SRO 3.5			
A4.05 Minimum flow valves RO 3.2 / SRO 3.2			
b. Respond to Refuel Floor High Radiation		PDALS	9
272000 Radiation Monitoring System		1,0,0,0,0	Ŭ
A2. Ability to (a) predict the impacts of the following on the RAD	IATION		
MONITORING SYSTEM ; and (b) based on those predictions, u	se		
procedures to correct, control, or mitigate the consequences of t	those	:	
A2.42 Refuel fleet bandling assidents/energtions RO.2.2 (SRO	4.0		
Az. 12 Reidel noor handling accidents/operations RO 3.37 SRO	4.0		
c. Manually Start the RCIC System		D,S	2
217000 Reactor Core Isolation Cooling System			
A4. Ability to manually operate and/or monitor in the control roor	m:		
A4.04 Manually initiated controls RO 3.6 / SRO 3.6			
In-Plant Systems [@] (3 for RO); (3 for SRO-I); (3 or 2 for SRO-U)			
i. Place ESF Battery Charger in Service		D.R	6
263000: DC Electrical Distribution			
Generic 2.1.30 Ability to locate and operate components, includ	ding local		
K1. Knowledge of the physical connections and/or cause effect	relationships		
between D.C. ELECTRICAL DISTRIBUTION and the following:	· · · · · · · · · · · · · · · · ·		
K1.02 Battery charger and battery RO 3.2 / SRO 3.3			
j. Defeat ARI Logic Trips		D.R.E	7
216000: Nuclear Boiler Instrumentation			
Generic 2.4.34 Knowledge of RO tasks performed outside the room during emergency operations including system geography implications. RO 4.2 / SRO 4.1	main control and system		
All RO and SRO-I control room (and in-plant) systems must b functions; all 5 SRO-U systems must serve different safety fu overlap those tested in the control room.	be different and nctions; in-plant	serve different s t systems and fu	afety nctions may

*Type Codes	Criteria for RO / SRO-I / SRO-U
(A)Iternate path	4-6 / 4-6 / 2-3
(C)ontrol room	
(D)irect from bank	<u>≤</u> 9/ <u>≤</u> 8 / <u>≤</u> 4
(E)mergency or abnormal in-plant	<u>≥</u> 1/ <u>≥</u> 1 / <u>≥</u> 1
(EN)gineered safety feature	$-/-/ \ge 1$ (control room system)
(L)ow-Power / Shutdown	<u>≥1/ ≥1 /≥1</u>
(N)ew or (M)odified from bank including 1(A)	<u>≥2/ ≥2/≥1</u>
(P)revious 2 exams	\leq 3 / \leq 3 / \leq 2 (randomly selected)
(R)CA	<u>≥1/ ≥1/≥</u> 1
(S)imulator	

ES-301, Page 23 of 27

Facility:	Fermi 2				Date of Exam: 1/28/2008													
			RO K/A Category Points											SRO-Only Points				
Tier	Group	К 1	K 2	К 3	К 4	K 5	К 6	A 1	A 2	A 3	A 4	G *	Total	A	2	G	×	Total
1. Emergency & Plant Evolutions	1	3	3	4				3	4			3	20	2	1	3		7
	2	1	1	1				1	1			2	7	2]		
	Tier Totals	4	4	5				4	5			5	27	6		4		10
	1	2	2	2	3	3	2	2	3	2	2	3	26	2		3	3	5
2. Plant	2	1	1	1	1	1	1	2	1	1	1	1	12	0	1	2		3
Systems	Tier Totals	3	3	3	4	4 3 4 4 3 3 4 38 3		3	5		8							
3. Generic Knowledge & Abilities			es	1		2		3		4		10	1	2	3	4	4	
Categories					2		3		2		3	10	1 2		2	2		

Note: 1. Ensure that at least two topics from every applicable K/A category are sampled within each tier of the RO and SRO-only outlines (i.e., except for one category in Tier 3 of the SRO-only outline, the "Tier Totals" in each K/A category shall not be less than two).

- 2. The point total for each group and tier in the proposed outline must match that specified in the table. The final point total for each group and tier may deviate by ±1 from that specified in the table based on NRC revisions. The final RO exam must total 75 points and the SRO-only exam must total 25 points.
- 3. Systems/evolutions within each group are identified on the associated outline; systems or evolutions that do not apply at the facility should be deleted and justified; operationally important, site-specific systems that are not included on the outline should be added. Refer to section D.1.b of ES-401, for guidance regarding elimination of inappropriate K/A statements.
- 4. Select topics from as many systems and evolutions as possible; sample every system or evolution in the group before selecting a second topic for any system or evolution.
- 5. Absent a plant specific priority, only those KAs having an importance rating (IR) of 2.5 or higher shall be selected. Use the RO and SRO ratings for the RO and SRO-only portions, respectively.
- 6. Select SRO topics for Tiers 1 and 2 from the shaded systems and K/A categories.
- 7.* The generic (G) K/As in Tiers 1 and 2 shall be selected from Section 2 of the K/A Catalog, but the topics must be relevant to the applicable evolution or system. Refer to Section D.1.b of ES-401 for the applicable K/A's
- 8. On the following pages, enter the K/A numbers, a brief description of each topic, the topics' importance ratings (IR) for the applicable license level, and the point totals (#) for each system and category. Enter the group and tier totals for each category in the table above. If fuel handling equipment is sampled in other than Category A2 or G* on the SRO-only exam, enter it on the left side of Column A2 for Tier 2, Group 2 (Note #1 does not apply). Use duplicate pages for RO and SRO-only exams.
- 9. For Tier 3, select topics from Section 2 of the K/A Catalog, and enter the K/A numbers, descriptions, IRs, and point totals (#) on Form ES-401-3. Limit SRO selections to K/As that are linked to 10CFR55.43

Form ES-401-1

ES-401 BWR Examination Outline Form ES-401-1 Emergency and Abnormal Plant Evolutions – Tier 1/Group 1 (RO / SRO)									
E/APE # / Name / Safety Function	К 1	К 2	к 3	A 1	A 2	G	K/A Topic(s)	IR	#
295004 Partial or Total Loss of DC Pwr / 6						x	2.2.25 - Knowledge of bases in technical specifications for limiting conditions for operations and safety limits.	4.2	76
295016 Control Room Abandonment / 7						X	2.1.30 - Conduct of Operations: Ability to locate and operate components, including local controls.	4.0	77
295024 High Drywell Pressure / 5					X		EA2.01 - Drywell pressure	4.4	78
295025 High Reactor Pressure / 3					x		EA2.06 - Ability to determine and/or interpret the following as they apply to HIGH REACTOR PRESSURE: Reactor water level	3.8	79
295030 Low Suppression Pool Water Level / 5					x		EA2.04 - Ability to determine and/or interpret the following as they apply to LOW SUPPRESSION POOL WATER LEVEL : Drywell/ suppression chamber differential pressure: Mark-I&II	3.7	80
295038 High Off-site Release Rate / 9					x		EA2.03 - Ability to determine and/or interpret the following as they apply to HIGH OFF-SITE RELEASE RATE : Radiation levels	4.3	81
600000 Plant Fire On-site / 8						x	2.4.41 - Knowledge of the emergency action level thresholds and classifications.	4.6	82
295001 Partial or Complete Loss of Forced Core Flow Circulation / 1 & 4			x				AK3.05 - Knowledge of the reasons for the following responses as they apply to PARTIAL OR COMPLETE LOSS OF FORCED CORE FLOW CIRCULATION : Reduced loop operating requirements: Plant-Specific	3.2	39
295003 Partial or Complete Loss of AC / 6	•••••				x		AA2.03 - Ability to determine and/or interpret the following as they apply to PARTIAL OR COMPLETE LOSS OF A.C. POWER : Battery status: Plant-Specific	3.2	40
295004 Partial or Total Loss of DC Pwr / 6					×		AA2.01 - Ability to determine and/or interpret the following as they apply to PARTIAL OR COMPLETE LOSS OF D.C. POWER : Cause of partial or complete loss of D.C. power	3.2	41
295005 Main Turbine Generator Trip / 3					x		AA2.05 - Ability to determine and/or interpret the following as they apply to MAIN TURBINE GENERATOR TRIP : Reactor power	3.8	42
295006 SCRAM / 1		x					AK2.07 - Knowledge of the interrelations between SCRAM and the following: Reactor pressure control	4.0	43
295016 Control Room Abandonment / 7			x				AK3.03 - Knowledge of the reasons for the following responses as they apply to CONTROL ROOM ABANDONMENT : Disabling control room controls	3.5	44
295018 Partial or Total Loss of CCW / 8			x				AK3.06 - Knowledge of the reasons for the following responses as they apply to PARTIAL OR COMPLETE LOSS OF COMPONENT COOLING WATER : Increasing cooling water flow to heat exchangers	3.3	45
295019 Partial or Total Loss of Inst. Air / 8					×		AA2.01 - Ability to determine and/or interpret the following as they apply to PARTIAL OR COMPLETE LOSS OF INSTRUMENT AIR : Instrument air system pressure	3.5	46
295021 Loss of Shutdown Cooling / 4		x					AK2.07 - Knowledge of the interrelations between LOSS OF SHUTDOWN COOLING and the following: Reactor recirculation	3.1	47

ES-401 BWR Examination Outline Form ES-401-1 Emergency and Abnormal Plant Evolutions – Tier 1/Group 1 (RO / SRO)									
E/APE # / Name / Safety Function	к 1	К 2	к 3	A 1	A 2	G	K/A Topic(s)	IR	#
295023 Refueling Accidents / 8	x						AK1.01 - Knowledge of the operational implications of the following concepts as they apply to REFUELING ACCIDENTS Radiation exposure hazards	3.6	48
295024 High Drywell Pressure / 5						X	2.1.27 - Conduct of Operations: Knowledge of system purpose and / or function.	3.9	49
295025 High Reactor Pressure / 3	x						EK1.04 - Knowledge of the operational implications of the following concepts as they apply to HIGH REACTOR PRESSURE : Decay heat generation	3.6	50
295026 Suppression Pool High Water Temp. / 5	x						EK1.02 - Knowledge of the operational implications of the following concepts as they apply to SUPPRESSION POOL HIGH WATER TEMPERATURE : Steam condensation	3.5	51
295031 Reactor Low Water Level / 2		x					EK2.03 - Knowledge of the interrelations between REACTOR LOW WATER LEVEL and the following: Low pressure core spray	4.2	52
295028 High Drywell Temperature / 5				x			EA1.01 - Ability to operate and/or monitor the following as they apply to HIGH DRYWELL TEMPERATURE: Drywell spray: Mark-I&II.	3.8	53
295030 Low Suppression Pool Water Level / 5				x			EA1.02 - Ability to operate and/or monitor the following as they apply to LOW SUPPRESSION POOL WATER LEVEL: RCIC: Plant-Specific	3.4	54
295037 SCRAM Condition Present and Power Above APRM Downscale or Unknown / 1						X	2.1.25 - Conduct of Operations: Ability to interpret reference materials, such as graphs, curves, tables, etc.	3.9	55
295038 High Off-site Release Rate / 9						x	2.1.32 - Conduct of Operations: Ability to explain and apply all system limits and precautions.	3.8	56
600000 Plant Fire On-site / 8			x				AK3.04 - Knowledge of the reasons for the following responses as they apply to PLANT FIRE ON SITE: Actions contained in the abnormal procedure for plant fire on site	2.8	57
700000 Generator Voltage and Electric Grid Disturbances				x			AA1.03 - Ability to operate and/or monitor the following as they apply to GENERATOR VOLTAGE AND ELECTRIC GRID DISTURBANCES: Voltage regulator controls.	3.8	58
K/A Category Totals:	3	3	4	3	8	6	Group Point Total:		20/7

Form ES-401-1

ES-401 BWR Examination Outline Form ES-401-1 Emergency and Abnormal Plant Evolutions – Tier 1/Group 2 (RO / SRO)									
E/APE # / Name / Safety Function	К 1	К 2	к 3	A 1	A 2	G	K/A Topic(s)	IR	#
295008 High Reactor Water Level / 2					x		AA2.02 - Ability to determine and/or interpret the following as they apply to HIGH REACTOR WATER LEVEL: Steam flow/feedflow mismatch	3.4	83
295012 High Drywell Temperature / 5						x	2.2.39 - Equipment Control: Knowledge of less than one hour technical specification action statements for systems.	4.5	84
295033 High Secondary Containment Area Radiation Levels / 9					X		EA2.02 - Ability to determine and/or interpret the following as they apply to HIGH SECONDARY CONTAINMENT AREA RADIATION LEVELS : Equipment operability	3.2	85
295007 High Reactor Pressure / 3	x						AK1.02 - Knowledge of the operational implications of the following concepts as they apply to HIGH REACTOR PRESSURE : Decay heat generation	3.1	59
295010 High Drywell Pressure / 5					×		AA2.06 - Ability to determine and/or interpret the following as they apply to HIGH DRYWELL PRESSURE : Drywell temperature	3.6	60
295012 High Drywell Temperature / 5				x			AA1.01 - Ability to operate and/or monitor the following as they apply to HIGH DRYWELL TEMPERATURE : Drywell ventilation system	3.5	61
295022 Loss of CRD Pumps / 1						X	2.4.18 - Emergency Procedures / Plan: Knowledge of the specific bases for EOPs.	3.3	62
295032 High Secondary Containment Area Temperature / 5			x				EK3.03 - Knowledge of the reasons for the following responses as they apply to HIGH SECONDARY CONTAINMENT AREA TEMPERATURE : Isolating affected systems	3.8	63
295033 High Secondary Containment Area Radiation Levels / 9						X	2.4.45 - Emergency Procedures / Plan: Ability to prioritize and interpret the significance of each annunciator or alarm.	4.1	64
295036 Secondary Containment High Sump/Area Water Level / 5		x					EK2.02 - Knowledge of the interrelations between SECONDARY CONTAINMENT HIGH SUMP/AREA WATER LEVEL and the following: Post-accident sampling system: Plant-Specific	2.6	65
K/A Category Totals:	1	1	1	1	3	3	Group Point Total:		7/3

ES-401 BWR Examination Outline F Plant Systems – Tier 2/Group 1 (RO / SRO)								Form ES-401-1						
System # / Name	к 1	к 2	к 3	к 4	к 5	К 6	A 1	A 2	A 3	A 4	G	K/A Topic(s)	IR	#
223002 PCIS/Nuclear Steam Supply Shutoff											×	2.1.23 - Conduct of Operations: Ability to perform specific system and integrated plant procedures during all modes of plant operation.	4.4	86
218000 ADS								*			an bernenden in den sterkenden. Bernenden in der sterkenden son	A2.06 - Ability to (a) predict the impacts of the following on the AUTOMATIC DEPRESSURIZATION SYSTEM; and (b) based on those predictions, use procedures to correct, control, or mitigate the consequences of those abnormal conditions or operations: ADS initiation signals present	4.3	87
215003 IRM											×	2.4.31 - Emergency Procedures / Plan: Knowledge of annunciator alarms, indications, or response procedures.	4.1	88
215005 APRM / LPRM								×				A2.10 - Ability to (a) predict the impacts of the following on the AVERAGE POWER RANGE MONITOR/LOCAL POWER RANGE MONITOR SYSTEM; and (b) based on those predictions, use procedures to correct, control, or mitigate the consequences of those abnormal conditions Changes in void concentration	2.9	89
262001 AC Electrical Distribution											X	 2.1.19 - Conduct of Operations: Ability to use plant computers to evaluate system or component status. 	3.8	90
203000 RHR/LPC1: Injection Mode	x											K1.01 - Knowledge of the physical connections and/or cause- effect relationships between RHR/LPCI: INJECTION MODE (PLANT SPECIFIC) and the following: Condensate storage and transfer system: Plant-Specific	2.8	1
205000 Shutdown Cooling							x					A1.01 - Ability to predict and/or monitor changes in parameters associated with operating the SHUTDOWN COOLING SYSTEM (RHR SHUTDOWN COOLING MODE) controls including: Heat exchanger cooling flow	3.3	2
206000 HPCI								X				A2.04 - Ability to (a) predict the impacts of the following on the HIGH PRESSURE COOLANT INJECTION SYSTEM; and (b) based on those predictions, use procedures to correct, control, or mitigate the consequences of those abnormal conditions or operations: A.C. failures: BWR-2,3,4	2.7	3
209001 LPCS			x									K3.03 - Knowledge of the effect that a loss or malfunction of the LOW PRESSURE CORE SPRAY SYSTEM will have on following: Emergency generators	2.9	4
211000 SLC	x											K1.02 - Knowledge of the physical connections and/or cause- effect relationships between STANDBY LIQUID CONTROL SYSTEM and the following: Core plate differential pressure indication	2.7	5
212000 RPS									x			A3.06 - Ability to monitor automatic operations of the REACTOR PROTECTION SYSTEM including: Main turbine trip: Plant-Specific	4.2	6

ES-401 BWR Examination Outline Plant Systems – Tier 2/Group 1 (RO / SRO)								Form ES-401-1						
System # / Name	к 1	К 2	к 3	K 4	К 5	к 6	A 1	A 2	A 3	A 4	G	K/A Topic(s)	IR	#
215003 IRM											X	2.4.31 Knowledge of annunciator alarms, indications, or response procedures.	4.2	7
215003 IRM		x										K2.01 - Knowledge of electrical power supplies to the following: IRM channels/detectors	2.5	8
215004 Source Range Monitor				x							는 가는 바깥 - 사람이라. 이 나는 것 이 한 화려 관련	K4.01 - Knowledge of SOURCE RANGE MONITOR (SRM) SYSTEM design feature(s) and/or interlocks which provide for the following: Rod withdrawal blocks	3.7	9
215005 APRM / LPRM					x							K5.04 - Knowledge of the operational implications of the following concepts as they apply to AVERAGE POWER RANGE MONITOR/LOCAL POWER RANGE MONITOR SYSTEM : LPRM detector location and core symmetry	2.9	10
217000 RCIC											×	2.2.44 - Equipment Control: Ability to interpret control room indications to verify the status and operation of a system, and understand how operator actions and directives affect plant and system conditions.	4.2	11
218000 ADS						x						K6.04 - Knowledge of the effect that a loss or malfunction of the following will have on the AUTOMATIC DEPRESSURIZATION SYSTEM : Air supply to ADS valves: Plant-Specific	3.6	12
223002 PCIS/Nuclear Steam Supply Shutoff										x		A4.06 - Ability to manually operate and/or monitor in the control room: Confirm initiation to completion	3.6	13
239002 SRVs						x						K6.05 - Knowledge of the effect that a loss or malfunction of the following will have on the RELIEF/SAFETY VALVES : Discharge line vacuum breaker	3.0	14
239002 SRVs					x							K5.04 - Knowledge of the operational implications of the following concepts as they apply to RELIEF/SAFETY VALVES : Tail pipe temperature monitoring	3.3	15
259002 Reactor Water Level Control								X				A2.05 - Ability to (a) predict the impacts of the following on the REACTOR WATER LEVEL CONTROL SYSTEM; and (b) based on those predictions, use procedures to correct, control, or mitigate the consequences of those abnormal conditions or operations: Loss of applicable plant air systems	3.2	16
261000 SGTS			x									K3.06 - Knowledge of the effect that a loss or malfunction of the STANDBY GAS TREATMENT SYSTEM will have on following: Primary containment oxygen content: Mark-I&II	3.0	17
261000 SGTS								×				A2.11 - Ability to (a) predict the impacts of the following on the STANDBY GAS TREATMENT SYSTEM; and (b) based on those predictions, use procedures to correct, control, or mitigate the consequences of those abnormal conditions or operations: High containment pressure	3.2	18

Form	ES-401-1

ES-401 BWR Examination Outline Form ES-401-1 Plant Systems – Tier 2/Group 1 (RO / SRO)							6-401-1							
System # / Name	к 1	К 2	к 3	к 4	К 5	К 6	A 1	A 2	A 3	A 4	G	K/A Topic(s)	IR	#
262001 AC Electrical Distribution					x							K5.01 - Knowledge of the operational implications of the following concepts as they apply to A.C. ELECTRICAL DISTRIBUTION: Principle involved with paralleling two A.C. sources	3,1	19
203000 RHR/LPCI: Injection Mode							x					A1.02 - Ability to predict and/or monitor changes in parameters associated with operating the RHR/LPCI: INJECTION 3.9 MODE (PLANT SPECIFIC) controls including: Reactor pressure		20
263000 DC Electrical Distribution										x		A4.01 - Ability to manually operate and/or monitor in the control room: Major breakers and control power fuses: Plant-Specific	3.3	21
263000 DC Electrical Distribution											×	2.4.35 - Emergency Procedures / Plan: Knowledge of local auxiliary operator tasks during emergency and the resultant operational effects.	3.8	22
264000 EDGs				x								K4.06 - Knowledge of EMERGENCY GENERATORS (DIESEL/JET) design feature(s) and/or interlocks which provide for the following: Governor control	2.6	23
300000 Instrument Air				x								K4.03 - Knowledge of (INSTRUMENT AIR SYSTEM) design feature(s) and or interlocks which provide for the following: Securing of IAS upon loss of cooling water	2.8	24
300000 Instrument Air									x			A3.02 - Ability to monitor automatic operations of the INSTRUMENT AIR SYSTEM including: Air temperature	2.9	25
400000 Component Cooling Water		X										K2.01 - Knowledge of electrical power supplies to the following: CCW pumps	2.9	26
K/A Category Totals:	2	2	2	3	3	2	2	5	2	2	6	Group Point Total:		26/5

ES-401 BWR Examination Outline Plant Systems – Tier 2/Group 2 (RO / SRO)								Dutline 0 2 (RO / SRO)	Form ES-401-					
System # / Name	К 1	к 2	К 3	K 4	К 5	6 6	A 1	A 2	A 3	A 4	G	K/A Topic(s)	IR	#
219000 RHR/LPCI: Torus/Pool Cooling Mode											X	2.4.11 - Knowledge of abnormal condition procedures.	4.2	91
223001 Primary Containment System and Auxiliaries											X	2.1.20 - Ability to interpret and execute procedure steps.	4.6	92
271000 Off-gas								X				A2.17 - Ability to (a) predict the impacts of the following on the OFFGAS SYSTEM; and (b) based on those predictions, use procedures to correct, control, or mitigate the consequences of those abnormal conditions or operations: Reactor power changes	3.1	93
201002 RMCS						×						K6.01 - Knowledge of the effect that a loss or malfunction of the following will have on the REACTOR MANUAL CONTROL SYSTEM : Select matrix power	2.5	27
204000 RWCU									x			A3.01 - Ability to monitor automatic operations of the REACTOR WATER CLEANUP SYSTEM including: System pressure downstream of the pressure regulating valve: LP-RWCU	3.3	28
214000 RPIS								×				A2.02 - Ability to (a) predict the impacts of the following on the ROD POSITION INFORMATION SYSTEM; and (b) based on those predictions, use procedures to correct, control, or mitigate the consequences of those abnormal conditions or operations: Reactor SCRAM	3.6	29
215001 Traversing In-core Probe				x								K4.01 - Knowledge of TRAVERSING IN-CORE PROBE design feature(s) and/or interlocks which provide for the following: Primary containment isolation: Mark-I&II(Not-BWR1)	3.4	30
215002 RBM					x							K5.01 - Knowledge of the operational implications of the following concepts as they apply to ROD BLOCK MONITOR SYSTEM : Trip reference selection: Plant-Specific	2.6	31
234000 Fuel Handling Equipment							x					A1.02 - Ability to predict and/or monitor changes in parameters associated with operating the FUEL HANDLING EQUIPMENT controls including: Refuel floor radiation levels/ airborne levels	3.3	32
201001 Control Rod Drive Hydraulic System							×					A1.07 - Ability to predict and/or monitor changes in parameters associated with operating the CONTROL ROD DRIVE HYDRAULIC SYSTEM controls including: Reactor water level	3.3	33
245000 Main Turbine Gen. / Aux.	x											K1.06 - Knowledge of the physical connections and/or cause- effect relationships between MAIN TURBINE GENERATOR AND AUXILIARY SYSTEMS and the following: Component cooling water systems	2.6	34
256000 Reactor Condensate			x									K3.02 - Knowledge of the effect that a loss or malfunction of the REACTOR CONDENSATE SYSTEM will have on following: CRD hydraulics system	3.2	35
271000 Off-gas										x		A4.03 - Ability to manually operate and/or monitor in the control room: System temperatures	2.8	36

Form ES-401-1

ES-401	BWR Examination Outline Form E Plant Systems – Tier 2/Group 2 (RO / SRO)													S-401-
System # / Name	К 1	к 2	К 3	К 4	K 5	к 6	A 1	A 2	A 3	A 4	G	K/A Topic(s)	IR	#
272000 Radiation Monitoring		x										K2.05 - Knowledge of electrical power supplies to the following: Reactor building ventilation monitors: Plant- Specific	2.6	37
288000 Plant Ventilation											X	2.2.40 - Equipment Control: Ability to apply technical specifications for a 3 system.	3.4	38
K/A Category Totals:	1	1	1	1	1	1	2	2	1	1	3	Group Point Total:		12/3

Generic Knowledge and Abilities Outline (Tier3)

Facility: Fermi-2		Date of Exam: 1/28/2008										
Category	K/A #	Topic	R	0	SRO-	Only						
	2.1.43	Ability to use procedures to determine the effects on reactivity of plant changes, such as RCS temperature. secondary plant, fuel depletion, etc.	IR	Q#	IR 4.3	Q# 94						
1.												
of Operations	2.1.41	Knowledge of the refueling process.	2.8	66								
	2.1.5	such as minimum crew complement, overtime limitations, etc.	2.9	67								
		· · · · · · · · · · · · · · · · · · ·										
	Subtotal			2		1						
	2.2.14	Knowledge of the process for controlling equipment		2	4.3	95						
	2.2.35	Ability to determine Technical Specification Mode of Operation.			4.5	96						
-												
2. Equipment	2.2.43	Knowledge of the process used to track inoperable alarms.	3.0	68								
Control	2.2.15	Ability to determine the expected plant configuration using design and configuration control	3.9	69								
		documentation, such as drawings, line-ups, tag-outs, etc.										
	2.2.40	Ability to apply technical specifications for a system.	3.4	70								
	Subtotal	· · · · · · · · · · · · · · · · · · ·		3		2						
	2.3.5	Ability to use radiation monitoring systems, such as fixed radiation monitors and alarms, portable survey instruments, personnel monitoring equipment, etc.			2.9	97						
	2.3.4	Knowledge of radiation exposure limits under normal or emergency conditions.			3.7	98						
3. Radiation Control	2.3.13	Knowledge of Radiological Safety Procedures pertaining to licensed operator duties, such as response to radiation monitor alarms, containment entry requirements, fuel handling responsibilities, access to locked high radiation areas, aligning filters, etc.	3.4	71								
	2.3.15	Knowledge of radiation monitoring systems, such as fixed radiation monitors and alarms, portable survey instruments, personnel monitoring equipment, etc.	2.9	72								
	Subtotal			2		2						

Generic Knowledge and Abilities Outline (Tier3)

Form ES-401-3

Category	K/A #	Topic	RO	SRO - Onl y	Cate gory	K/A #
2	2.4.20	Knowledge of operational implications of EOP warnings, cautions, and notes.			4.3	99
	2.4.23	Knowledge of the bases for prioritizing emergency procedure implementation during emergency operations.			4.4	100
4.						
Emergency Procedures /	2.4.1	Knowledge of EOP entry conditions and immediate action steps.	4.6	73		
Plan	2.4.27	Knowledge of "fire in the plant" procedures.	3.4	74		
	2.4.43	Knowledge of emergency communications systems and techniques.	3.2	75		
	Subtotal			3		2
Tier 3 Point Total	•			10		7

Facility	/: <u> </u>	ermi 2	Scenario No1 Op-Test No: _2008-1	٦									
Exami	ners: <u>M. Bielb</u>	<u>v</u>	Operators:										
	<u>B. Palag</u>	e li											
Initial (Conditions: IC-	18 MOL 75	5% Rx Power										
 Turnover: The plant has been operating for 103 days. Reactor Power is currently 75% of Rated Thermal Power with Control Rods at the 86% Rod Line following rod pattern adjustment. General Service Water Pump #4 is out of service for motor replacement with an expected return to service in 2 days. This shift will start the East Heater Feed Pump and raise Reactor Power to 85% of rated with Recirculation flow. Reactor Engineering will be ready in one hour to pull rods for another rod pattern adjustment. GOP 22.000.03, "Plant Operation 25% to 100% to 25%" (Rev 73) actions for power increase are complete through Step 4.2.17.1. NOTE: The crew's Pre-job Briefing for the reactor power increase is to be conducted prior to entering the simulator. (Suggested time 30 minutes prior to beginning the scenario.) 													
Event No.	Malf. No.	Event Type*	Event Description										
1.	N/A	N (BOP) N (SRO)	Start the Third HFP using SOP 23.107, "Reactor Feedwater and Condensate Systems", Section 5.5.										
2.	N/A	R (ATC) R (SRO)	Increase Reactor Power With Recirculation Flow per GOP 22.000.03,"Power Operation 25% To 100% To 25%".										
3.	B31RF0015	C (ATC) C (SRO)	RRMG "B" Walkaway Uncontrolled RRMG "B" Speed Change (>10%), crew trips the affected RRMG (Immediate Action per AOP 20.138.03, "Uncontrolled Recirc Flow Change"). Crew enters AOP 20.138.01, "Recirc Pump Trip", Condition C & D. NOTE: OPRMs are operable. CRS directs increased core monitoring for instability. He also directs increasing speed on the operating RRMG to raise core flow (>43%) and exit the Scram/Exit Region of the Power to Flow Map. CRS reviews TS 3.4.1.A, Recirc Loops Operating, 2 hours to declare loop inop and 4 hours to adjust RPS trip setpoints to single loop values.	0									
4.	E51MF0009	C (BOP) C (SRO)	Spurious RCIC Initiation Spurious start of RCIC, BOP verifies no valid actuation signal and trips RCIC when directed. CRS reviews TS 3.5.3.A, RCIC System, (Immediately verify HPCI operable and 14 day LCO).										
* (N)o	rmai, (R)eactiv	/ity, (I)nstr	rument, (C)omponent, (M)ajor										

Scenario Outline

Facility	:Fermi	2	Scenario No 1 Op-Test No: 2008-1									
Examir	ners: <u>M. Bielby</u> <u>C. Moore</u> <u>B. Palagi</u>		Operators:									
Initial C	conditions: <u>IC-1</u>	8, MOL, 75%	% Rx. Power.									
Event No.	Malf. No.	Event Type*	Event Description									
5.	R11MF0001 N20MF0023	M (All)	Loss of Div 2 Offsite Power / EDGs start / Loss of all Heater Feed Pumps, and Reactor Feed Pumps. Loss of all Div 2 Buses. EDGs 13 & 14 auto start and re- energize ESF buses only. CRS enters AOP 20.300.345kV, Mode Switch in SHUTDOWN, and performs AOP 20.000.21, "Reactor Scram". CRS enters EOP 29.100.01, "RPV Control", Sheet 1 (Level 3).									
6.	E41MF0009 E41MF0005	C (BOP) C (SRO)	HPCI Auto Start Failure HPCI fails to start on Level 2. The crew will identify and manually start HPCI using SOP 23.202, "HPCI System", Encl C. (Hard Card), but HPCI will isolate after about 1 min of operation.									
7.	N21MF0031 N21RF0019	C (BOP) C (SRO)	SBFW F001 Fails As Is BOP will start SBFW Pump A, for level control, and identify a F001 failure to open. When he depresses the valve's Open pushbutton the valve will lose power. The BOP will direct an operator to investigate and restore. NOTE: SBFW Pump A is the only available pump.									
8a.	B31MF0066	M (All)	Recirc Loop A Rupture LOCA - A Recirculation leak will cause High Drywell Pressure and level to decrease. EOP 29.100.01, RPV Control, Sheet 1 re-entry on high Drywell Pressure and EOP Primary Containment Control, Sheet 2 entry on High Drywell Pressure. The crew will start all available high pressure injection systems. (SLC and re-starts RCIC by resetting the Trip Throttle Valve due to spurious initiation still in 23.206, RCIC, Sect 7.1 or Encl B Hard Card) At ~100" RPV Water Level BOP reports water level cannot be maintained > TAF.									
* /\\\\\\\\\\\	mal (P)aastivi	ty /l)notri	CRS briefs crew for Emergency Depressurization.									
* (N)or	* (N)ormal, (R)eactivity, (I)nstrument, (C)omponent, (M)ajor											

Scenario Outline

Form ES-D-1

Facility: Fermi 2 Examiners: M. Bielby C. Moore B. Pilaggi			Scenario No1 Op-Test No: 2008-1 Operators:	
NOTE:	Continued from	page 2	<u>% RX. POwer.</u>	
Event No.	Malf. No.	Event Type*	Event Description	
8b	N/A	M (ALL)	AT TAF Emergency Depressurizes (EOP C-2) EOP 29.100.01, RF/ED/SC, Sheet 3 (CT). BOP opens 5 SRVs ADS preferred. Crew restores water level 173 – 214" with available High Pressure and Low Pressure ECCS Systems. (CT)	
9.	EOPRF0038	I (ATC) I (SRO)	Div 2 EECW Hi Drywell Pressure Lead Lifted. ATC verifies EECW actuation and isolation to the Drywell. Determines Div 2 EECW is not isolated, and isolates by closing the P4400-F606B. He then restores cooling to CRD.	
10.	N/A	N (ATC) N (SRO)	Crew sprays the Torus using SOP 23.205, "RHR System", Encl A. (Hard Card) Crew sprays the Drywell using SOP 23.205, "RHR System", Encl A. (Hard Card) (CT)	
* (N)ormal, (R)eactivity, (I)nstrument, (C)omponent, (M)ajor				

Scenario Outline

Facility	:Fe	ermi 2	Scenario No 2 Op-Test No: 2008-1		
Exami	ners: <u>M. Bielby</u>		Operators:		
	<u> </u>	!			
1					
	conditions: <u>IC-2</u>	<u>.0, MOL, 100</u>	<u>3% Rx. Power</u>		
Therma schedul to colled	er: <u>The plant ha</u> I Power. The So ed to be restore of routine vibratio	s been oper outh RBCCV d tomorrow. on data on D	Atting for 23 days. Reactor Power is 100% of Rated V Pump is out of service for motor replacement. It is Plans are to shift from Division 1 CCHVAC to Division 2 Division 2 CCHVAC equipment.		
NOTE:	The Pre-job Brie simulator. (Sugo	efing for the gested time (CCHVAC shift is to be conducted prior to entering the 30 minutes prior to beginning the scenario.)		
Event No.	Malf. No.	Event Type*	Event Description		
1.	N/A	N (BOP) N (SRO)	Crew shifts from Division 1 CCHVAC to Division 2 CCHVAC		
2.	C11MF0445	C (ATC) C (SRO)	Control Rod 26-15 Drifts IN CRS enters AOP 20.106.07, "Control Rod Drift" and determines TS 3.1.3.C, Control Rod Operability, (3 hrs to insert and 4 hrs to disarm). ATC inserts and directs disarming control rod 26-15.		
3.	C97MF1087 MF EBAORL _TCTVSP 1	C (BOP) C (SRO) Seismic System Event / Trouble Alarm 6D69 Crew monitors the plant and performs AOP Actions. CRS enters AOP 20.000.01, "Acts of Nature". BOP starts RHRSW MDCT Fans. When MDCT Fan B is started, it trips. CRS enters TS 3.7.2.B, Ultimate Heat Sink (UHS), (72 hr LCO).			
4. N61MF0003 M (ALL) East Condenser Air Leak CRS enters AOP 20.125.01, "Loss of Condenser Vacuum". BOP starts an additional SJAE and OG Ring Water C (ATC) BOP starts an additional SJAE and OG Ring Water Pump. R (ATC) R (ATC) ATC attempts Rapid Power Reduction, per SOP R (SRO) 23.623, Reactor Manual Control System, Section 9.7, and determines failure of Manual Runback. ATC takes individual manual control to reduce recirc speeds to 55-60% core flow.					
* (N)or	* (N)ormal, (R)eactivity, (I)nstrument, (C)omponent, (M)ajor				

Scenario Outline

Facility: Fermi 2 Examiners: M. Bielby C. Moore			Scenario No 2_ Op-Test No: 2008-1 Operators: 	
Event No.	Malf. No.	Event Type*	Event Description	
5.		M (ALL)	Reactor Scram Performs override action 20.125.01 and places Mode Switch in SHUTDOWN ≤ 2.5 psia. After Scram Reports, CRS enters EOP 29.100.01 RPV Control, Sheet 1 (Level 3) and directs entry into AOP 20.000.21, Reactor Scram. BOP controls water level 173 – 214 inches.	
6.	C97MF1087 B21MF0059 B21MF0060 B21MF0073	M (ALL) I (ALL)	Aftershock Seismic Event / Event Trouble Alarm (6D69) Loss of all level indication. Div 1 and Div 2 Level Instrument Reference Leg Ruptures. Flood up Level Indication fails upscale high. (Level 8 trip on Main Turbine, RFPs, HPCI, RCIC, and SBFW.) CRS enters (EOP C-4) EOP RPV Flooding, 29.100.01, Sheet 3. (Level cannot be determined) CRS enters EOP 29.100.01, Primary Containment Control, Sheet 2. (High Drywell Pressure)	
7.	B21MF0037	C (BOP) C (SRO)	When BOP is directed to open 5 SRVs, SRV "R" fails to open. BOP will select and open another SRV and report this to the CRS. (CT)	
8.	N/A	ALL	The crew floods to the Main Steam Lines using Feedwater, SBFW, and Low Pressure ECCS Systems. (CT)	
			· · · · · · · · · · · · · · · · · · · ·	
* (N)ormal, (R)eactivity, (I)nstrument, (C)omponent, (M)ajor				

Appendix D, 38 of 39

Scenario Outline

Form ES-D-1

Facility	/:Ferm	<u>ni 2</u>	Scenario No Op-Test No: 2008-1			
Examiners: M. Bielby Operators:						
:						
	<u>B. Palag</u>					
Initial (Conditions: <u>IC-</u>	<u>19, EOL, 1</u>	00% Rx. Power			
Turnov The pla Power v	Turnover: <u>The plant has been operating for 403 days</u> . <u>Reactor Power is currently 100% of Rated Thermal</u> <u>Power with Control Rods at the 86% Rod Line following rod pattern adjustment</u> . <u>The N. Turbine</u>					
a powe North T shift is	r supply failure a BCCW Pump fr also to perform	and a track om service 27.109.01,	ting LCO is written for it. The plan for the shift is to remove the for lubrication and outboard motor bearing replacement. The "Turbine Steam Valves Test. The crew will begin with the st because I&C support will not be available to perform the op-			
line val	ve position calib	ration on #	1 LPIV later in the shift.			
NOTE:	NOTE: The crew's Pre-job Briefing for the reactor power decrease and "Turbine Steam Valves Test" is to be conducted prior to entering the simulator. (Suggested time 30 minutes prior to beginning the scenario.)					
Event No.	Malf. No.	Event Type*	Event Description			
1.	N/A	N (BOP) N (SRO)	Crew shifts TBCCW Pumps due to scheduled maintenance on North TBCCW Pump.			
2.	N/A	R (ATC) R (SRO)	Lower reactor power to 93% with Recirculation Flow per GOP 22.000.03, "Power Operation 25% to 100% to 25%", in preparation to perform 27.109.01, Turbine Steam Valves Test.			
3.	N30MF0036	C (BOP) C (SRO)	Crew performs section 5.7 of 27.109.01. Tests LPSV #1 and closes LPIV #1 for on-line valve position calibration. When I&C reports complete BOP determines, #1 LPIV fails to re-open. Crew stops test, informs Ops Management, and System Engineer of problem.			
4.	Image: Second state in the second s					
* (N)o	* (N)ormal, (R)eactivity, (I)nstrument, (C)omponent, (M)ajor					

Scenario Outline

Form ES-D-1

Facility: Fermi 2 Scenario No3 Op-Test No: 2008-1			Scenario No3 Op-Test No: 2008-1	
Examiners: <u>M. Bielby</u>			Operators:	
<u>C. Moore</u> B. Palagi				
Initial C	anditional IC 1		% By Bower	
	Continued from	<u>9, EUL, 100</u> page 1	70 KX. POWEL	
Event	Malf	Event	Event	
No.	No.	Type*	Description	
5.	B21MF0029	C (BOP)	SRV G fails open.	
		C (SRO)	BOP takes immediate actions per AOP 20.000.25, "Failed Safety Relief Valve (SRV)", by depressing the open and closed pushbuttons repeatedly. The SRV will close.	
			The CRS reviews TS 3.4.3.A, SRVs (tracking LCO), TS 3.6.1.6.A, Low – Low Set Valves (14 day LCO), and TS 3.6.1.8, Suppression Chamber-to-Drywell Vacuum Breakers (SR 3.6.1.8.2, 12 hrs to perform the vacuum breaker test after a SRV discharge to Torus).	
			May direct removing fuses to prevent re-occurance per AOP 20.000.25, Enclosure A.	
6.	PO P603 _B087_1	C (ATC) C (SRO)	CRD Flow Control Valve drifts close. ATC observes and reports. SRO enters AOP 20.106.03, "CRD Flow Control Valve Failure", Condition A. ATC takes manual control, opens, and adjusts CRD Pressure.	
7.	N30MF0044	M (ALL)	Turbine Trips / Failure to Scram (ATWS)	
	C71MF0006 C11MF0001	C (ATC) C (SRO)	Failure to scram is reported and the crew enters the EOPs on Scram Condition with power > 3%. CRS directs actions from 29.100.01 Sheet 1A, RPV Control-ATWS. ATC performs FSQ 1-8 actions (unsuccessful) and BOP performs inhibit ADS, bypasses Drywell Pneumatics, and directs 29.ESP.11.	
8.	C41MF0003 C41MF0004	C (ATC) C (SRO)	Initial SLC Pump selected trips. When ATC is ordered to inject SLC. He informs CRS and starts second SLC Pump. SLC is successfully injected. (CT)	
9.	N/A	M (ALL)	BOP lowers water level and maintains 0 - 50" wr (EOP C-5, Level / Power Control)	
			ATC performs manual rod insertion (CT). When 29.ESP.10 (Defeat of ARI Logic Trips) is complete and ARI Trip Logic is reset, the scram discharge volume will drain (3D94 Clear). The ATC will perform the Scram-Reset-Scram section of 29.ESP.03, "Alternate Control Rod Insertion", which will insert all rods.	
* (N)ormal, (R)eactivity, (I)nstrument, (C)omponent, (M)ajor				

Facility	/:Fe	ermi 2	Scenario No. 4	Op-Test No : <u>2008-1</u>
Exami	ners: <u>M. Bielb</u> <u>C. Moor</u>	γ	Operators:	
	B. Palag	li		
Initial C	Conditions: <u>IC-2</u>	20, MOL, 10	00% Rx. Power	
Turnov current pattern on the c	er: <u>The plant h</u> ly 100% of Rate adjustment. Th center pump.	nas been op d Thermal F e plan for th	erating at 100% power for 400 o Power with Control Rods at the 8 he shift is to shift RBCCW Pump	lays. Reactor Power is 6% Rod Line following rod s for scheduled maintenance
NOTE:	The crew's Pre entering the sir	-job Briefing nulator. (Su	g for the reactor power increase ggested time 30 minutes prior to	is to be conducted prior to beginning the scenario.)
Event No.	Malf. No.	Event Type*	Eve Descr	ent iption
1.	N/A	N (BOP) N (SRO)	Shift RBCCW Pumps in accord Section 6.1	dance with SOP 23.127,
2.	B21MF0044	C (ATC) C (SRO)	Jet Pump 5/6 Failure ATC observes Recirc Loop Flo Pump failure. The crew enters Failure". The SRO evaluates T 3.3.1.1.F (6 hrs to Mode 2), TS 3.4.2.A (12 hrs to Mode 3). The inoperable and directs the ATC hydraulic instabilities.	w changes and diagnoses Jet AOP 20.138.02, "Jet Pump S 3.3.1.1.C (1 hr LCO), TS 3.4.1.A (2 hr LCO), and TS e CRS declares JP #5 C to monitor for thermal
3.	N21MF0029	R (ATC) R (SRO) C (BOP) C (SRO)	Spurious N. RFP Trip / RRS R Drains Crew enters AOP 20.107.01, " Feedwater Control". The crew SBFW and injects at 1200 gpn to lower reactor power to ≤ 650	unback / Loss of Heater Loss of Feedwater or verifies RR runs back, starts n, and inserts the Cram Array %. (~15% reactivity change)
4.	C51MF0198	I (ATC) I (SRO)	RBM B Fails High The crew bypasses RBM B pe Monitoring System", Section 5 inoperable and enters TS 3.3.2	r 23.607, "Rod Block .1. The CRS declares RBM B 2.1.A (24 hr LCO).
5a.	E41MF0007 EOPRF0022 E41MF0001 E41MF0008	C (BOP) C (SRO)	HPCI Steam Leak & E4150-F0 E4150-F600 Thermal Overload Fire Alarm in the HPCI Quad, f 20.000.22, "Plant Fires". When HIGH – HIGH EOP ENTRY ala 29.100.01, SC/RR, Sheet 5 du greater than Max Normal Oper	02 Failure to Auto Isolate / d the crew may enter AOP n 3D34, SEC CONTM TEMP arms the crew will enter EOP te to HPCI Area temperature rating (MNO) 148 °F
* (N)ormal, (R)eactivity, (I)nstrument, (C)omponent, (M)ajor				
Appendix D Scenario Outline Form ES-D-1				

Appendix D, 38 of 39

Facility Exami Initial (Facility: Fermi 2 Scenario No. 4 Op-Test No: 2008-1 Examiners: M. Bielby Operators:				
NOTE:	Continued fror	n page 1			
Event No.	Malf. No.	Event Type*	Event Description		
5b.			NOTE: 1D66, STEAM LEAK DETECTION AMBIENT TEMP HIGH alarms at ≥ 154 °F in HPCI area and an isolation signal is generated.		
			When BOP attempts to isolate and E4150-F002 will not close (failed as is) and when E4150-F600 valve close pushbutton is depressed or an isolation signal is received, the valve loses power. The leak cannot be isolated.		
6.	N/A	M (ALL)	Reactor Manual Scram (Mode Switch to Shutdown) Before the HPCI Area temperature reaches the Max Safe Operating Temperature (MSO) of 210 °F, the crew briefs and places the Mode Switch in Shutdown. (CT) When Scram Reports are complete the crew enters EOP 29.100.01, RPV Control, Sheet 1 (Level 3) and AOP		
			20.000.21, Reactor Scram.		
7.	B21MF0103 B21MF0015 B21MF0009 B21MF0054	C (BOP) C (SRO)	RB Steam Tunnel Leak / MSIVs Fail to Isolate Crew observes increasing temperature in RB Steam Tunnel on IPCS. Crew should attempt to isolate the steam leak, by closing the MSIVs, when the area temperature is \geq 160 °F (MNO), to isolate all systems discharging into the area. IF area temp is \geq 200 °F and the MSIVs are not closed, then the crew should close them due to the auto isolation failure. NOTE: MSL C MSIVs do not fully close		
8.	N/A	M (ALL)	When Area Temperatures are > MSO (210 °F) in 2 areas the EOP directs Emergency Depressurization, EOP 29.100.01 RPV Flood/ED, Sheet 3 (EOP Contingency 2).		
			CRS directs BOP to open 5 SRVs (ADS preferred) (CT) and while the plant is depressurizing the crew briefs water level restoration and control.		
9.	N/A		The crew restores and maintains water level 173 – 214".		
• (N)ormal, (R)eactivity, (I)nstrument, (C)omponent, (M)ajor					

Outline Review 10/30/07

001015	
COMANA	NU
COMMANE	

RESPONSE/RESOLUTION

WRITTEN EXAM:	
No comments.	
ADMIN JPMs:	
Suggestions: -On the RO and SRO ES 301-1 forms, assign / align common letter designators to the admin JPMs.	
SYSTEM JPMs:	
Suggestions: -On the RO and SRO-I;-U ES 301-2 forms, align similar JPMs to the same "letter designator" -Pick the 5 SRO-U from the SRO-I JPMs (created 1 new JPM).	
1. How did you select the JPMs from the previous 2 exams?	Licensee followed their process for randomly selecting exam material (submitted copy with outline).
2. The Emergency or Abnormal inplant JPM KAs have to come from the 295 KAs vice the Generic 2.4 section (SF 7, 216000, Defeat ARI Logic Trips).	Licensee will look to see if they can apply one of the 295 KAs to the existing JPM.
3. Delete the reference to Generic 2.1.30 from the system JPM, DC Electrical Distribution, 263000, on ES-301-2.	Agreed.
SCENARIOs:	
1. No "low power" scenario (ref: ES 301, D.5.c).	ES 301, D.5.c says "should." QA sheets, ES-301- 4 and -201-2 do not require a low power scenario. Have used low power scenarios on previous exams and minimum number of events that can be used (don't want to be predictable).
SCENARIO 1:	
1. Event 3, where should the RRMG walk-away occur to ensure entry into the scram/exit region?	If RRMG speed is 57%, will enter the prohibited region. Will coordinate with examiner directing events and practice during validation.
2. Event 4, are there enough verifiable actions for an evaluation of the BOP, or does he only depress the trip pushbutton? Need to look at taking more actions to achieve a better evaluation.	BOP should runback RCIC, then trip the pump. Will look at providing more actions (ie, injection valve not closing).
3. Event 7, if there is no success path for aligning SBFW A, how do we hold the BOP accountable if he decides not to investigate the SBFW A F001 failure, or does not identify it?	Will include manual startup of SLC and/or RCIC as part of the evaluation success path to achieve adequate RWL.

Outline Review 10/30/07

COMMENT	RESPONSE

5. Event 9, what are consequences of failing to isolate P44- F606B? Suppose ATC fails, or decides not to perform the action, how do we hold him accountable?	Failure to isolate Div 2 EECW could result in an inner system LOCA due to heating of water in DW that causes piping to rupture. Isolation is required by EOP for PCP Sheet 2.
6. Event 10, spraying the Torus and DW is not a "N" evolution. It is an action directed by the EOPs when specific plant conditions require the action.	Delete Event 10 as "N."
SCENARIO 2:	
 Event 2, why not have the rod drift out vice into, the core? What are the ATC verifiable actions? 	The selected rod is full out, so will select a partially inserted rod, and allow it to drift out. The operator will be required to fully insert rod. Power will exceed required power limit.
 Event 3, are there enough verifiable actions for an evaluation of the BOP? This is not a "C" because there are no actions to take in response to the fan trip. 	Will delete event as "C," but will leave in for a TS call.
 3. Event 4: -not a "M." -not a "C" because starting SJAE and OG Ring Water pump does not provide a success path, still lose vacuum. -sufficient verifiable BOP actions for an evaluation? How do we hold the BOP accountable if he decides not to start SJAE or OG RWP, or is unsuccessful? -why is ATC given credit for "C?" Only "R" for SRO and ATC. -may give "C" for failure of the RMCS? 	Need to break up event and clarify who is getting what credit. The "C" for ATC/SRO is for failure of the RRP Master Controller and taking individual manual control of RRPs (not starting the SJAE and OG RWP). The "R" is for the Rapid Power Reduction.
4. Event 6, this is "M-ALL" not "I-ALL," cannot restore level instrumentation, only take EOP directed actions for a flood.	Delete the "I-ALL."
SCENARIO 3:	
 Event 3, not a "C." BOP cannot take any verifiable actions, cannot restore operability, can only stop test and make notifications. 	Delete "C."
2. Event 7: -what is the "C" and subsequent verifiable actions? What is the success path (manually insert rods)? -can't get a "C" and "M" for the same event.	Clarify that "C" is failure of the normal scram function, and manual insertion of control rods is the success path.
3. Event 8, what are the verifiable ATC actions for an evaluation (ie, what is critieria for being unsat)?	Clarify the success criteria for starting the second SLC pump, ie, before BIT exceeds 110 degrees F.
SCENARIO 4:	

Outline Review 10/30/07

COMMENT	RESPONSE/RESOLUTION
	••••••••••••••••••••••••••••••••••••••
 Event 2, what audible cues does the ATC receive? Suppose ATC doesn't identify the failure (BOP or SRO may unless we pull them back somehow). 	High RWL on P-603. Need to verify during validation.
2. Event 3, SRO cannot get both "R" and "C" for same event.	SRO will only get "R."
 Event 5a and b, not a "C," because can't isolate HPCI steam leak. Don't have to take any action and get same result. Only provides a reason to scram. 	Delete "C."
4. Event 7, good chance BOP/SRO will not identify "failure of MSIVs to auto-isolate" if they manually close valves before exceeding 200 degrees F (would not get credit for "C."	Will leave in, but not depend on.