

PMBelCOL PEmails

From: Ravindra Joshi
Sent: Tuesday, April 29, 2008 9:35 AM
To: andrea sterdis; Eddie R Grant; Hastings, Peter S; Ray, Phillip M; rgrumbir@gmail.com
Cc: Joseph Sebrosky; PMBelCOL PEmails
Subject: RAI Letter No.4 related to SRP Section 5.3.3 for the Bellefonte Units 3 and 4
Attachments: ML0811408275.pdf

To All,
Attached is RAI letter No.4.

Ravi Joshi
Project Manager
NRO/DNRL/NWE1
US NRC
310-415-6191

Hearing Identifier: Bellefonte_COL_Public_EX
Email Number: 159

Mail Envelope Properties (CEEA97CC21430049B821E684512F6E5E6019972CCA)

Subject: RAI Letter No.4 related to SRP Section 5.3.3 for the Bellefonte Units 3 and 4
Sent Date: 4/29/2008 9:35:28 AM
Received Date: 4/29/2008 9:35:30 AM
From: Ravindra Joshi

Created By: Ravindra.Joshi@nrc.gov

Recipients:

"Joseph Sebrosky" <Joseph.Sebrosky@nrc.gov>
Tracking Status: None
"PMBelCOL PEmails" <PMBelCOL.PEmails@nrc.gov>
Tracking Status: None
"andrea sterdis" <alsterdis@tva.gov>
Tracking Status: None
"Eddie R Grant" <erg-xl@cox.net>
Tracking Status: None
"Hastings, Peter S" <pshastings@duke-energy.com>
Tracking Status: None
"Ray, Phillip M" <pmray@tva.gov>
Tracking Status: None
"rgrumbir@gmail.com" <rgrumbir@gmail.com>
Tracking Status: None

Post Office: HQCLSTR01.nrc.gov

Files	Size	Date & Time
MESSAGE	122	4/29/2008 9:35:30 AM
ML0811408275.pdf	90960	

Options

Priority: Standard
Return Notification: No
Reply Requested: No
Sensitivity: Normal
Expiration Date:
Recipients Received:

April 22, 2008

Ms. Andrea L. Sterdis
Manager, Nuclear Licensing & Industry Affairs
Nuclear Generation Development & Construction
Tennessee Valley Authority
1101 Market Street
Chattanooga, Tennessee 37402-2801

SUBJECT: REQUEST FOR ADDITIONAL INFORMATION LETTER NO. 004 RELATED TO
SRP SECTIONS 05.03.03 FOR THE BELLEFONTE UNITS 3 and 4 COMBINED
LICENSE APPLICATION

Dear Ms. Sterdis:

By letter dated September 30, 2007, as supplemented by letters dated November 2, 2007, January 8, 2008 and January 14, 2008, Tennessee Valley Authority (TVA) submitted its application to the U. S. Nuclear Regulatory Commission (NRC) for a combined license (COL) for two AP1000 advance passive pressurized water reactors pursuant to 10 CFR Part 52. The NRC staff is performing a detailed review of this application to enable the staff to reach a conclusion on the safety of the proposed application.

The NRC staff has identified that additional information is needed to continue portions of the review. The staff's request for additional information (RAI) is contained in the enclosure to this letter.

To support the review schedule, you are requested to respond within 45 days of the date of this letter. If changes are needed to the final safety analysis report, the staff requests that the RAI response include the proposed wording changes.

If you have any questions or comments concerning this matter, you may contact me at 301-415-6191 or you may contact Joseph Sebrosky, the lead project manager for the Bellefonte combined license at 301-415-1132.

Sincerely,

/RA/

Ravindra G. Joshi, Project Manager
AP1000 Projects Branch 1
Division of New Reactor Licensing
Office of New Reactors

Docket Nos. 52-014
52-015

Enclosure:
Request for Additional Information

CC: see next page

If you have any questions or comments concerning this matter, you may contact me at 301-415-6191 or you may contact Joesph Sebrosky, the lead project manager for the Bellefonte combined license at 301-415-1132.

Sincerely,

/RA/

Ravindra G. Joshi, Project Manager
 AP1000 Projects Branch 1
 Division of New Reactor Licensing
 Office of New Reactors

Docket Nos. 52-014
 52-015
 eRAI Tracking No. 104

Enclosure:
 Request for Additional Information

Distribution:

Public	DTERao	BHughes
RidsNroDnrlNwe1	SCoffin	MComar
RidsNroLAKGoldstein	TSimms	AHodgdon
RidsOgcMailCenter	BAnderson	NRay
RidsAcrsAcnwMailCenter	SSanders	
RidsRgn2MailCenter	JMazza	
JSebrosky	PMoulding	

ADAMS Accession No. ML081140827

NRO-002

OFFICE	CPIB/BC		NWE1/PM	OGC	NWE1/L-PM
NAME	DTERao*		RJoshi*	PMoulding*	JSebrosky*
DATE	4/08/08		4/21/08	4/22/08	4/22/08

*Approval captured electronically in the electronic RAI system.

OFFICIAL RECORD COPY

**Request for Additional Information
Bellefonte Units 3 and 4
Tennessee Valley Authority
Docket Nos.52-014 and 52-015
SRP Section: 05.03.03- Reactor Vessel Integrity
Application Section: 5.3.6.4.1**

QUESTION from Component Integrity, Performance & Testing Branch 1

05.03.03-1

The as-procured reactor vessel material properties would be available to the COL holder after the acceptance of the reactor vessel. In order to enable timely NRC review of the pressurized thermal shock (PTS) evaluation using the as-procured reactor vessel material properties, please describe whether a more specific and timely milestone for submitting the PTS evaluation to the NRC can be established. If so, please provide.

Enclosure