

June 4, 2008

Technical Specification Task Force (TSTF)  
11921 Rockville Pike, Suite 100  
Rockville, MD 20852

SUBJECT: REQUEST FOR ADDITIONAL INFORMATION REGARDING TSTF-500,  
REVISION 0, "DC ELECTRICAL REWRITE – UPDATE TO TSTF-360"  
(TAC NO. MD7221)

Dear Members of the TSTF,

By letter dated August 31, 2007 (Agencywide Documents Access and Management System (ADAMS) Accession No. ML072430830), as supplemented by letter dated March 11, 2008 (ADAMS Accession No. ML080710396), the Technical Specifications Task Force (TSTF) requested the NRC to review TSTF-500, Revision 0, "DC Electrical Rewrite – Update to TSTF-360."

The Nuclear Regulatory Commission (NRC) staff has reviewed the submittal and has determined that additional information is needed to complete its review. The specific questions are found in the enclosed Request for Additional Information (RAI). A response to this RAI is requested to be provided within 60 days.

Sincerely,

*/RA/*

Robert Elliott, Chief  
Technical Specifications Branch  
Division of Inspections & Regional Support  
Office of Nuclear Reactor Regulation

Enclosure:  
RAI

cc: See next page

June 4, 2008

Technical Specification Task Force (TSTF)  
11921 Rockville Pike, Suite 100  
Rockville, MD 20852

SUBJECT: REQUEST FOR ADDITIONAL INFORMATION REGARDING TSTF-500,  
REVISION 0, "DC ELECTRICAL REWRITE – UPDATE TO TSTF-360"  
(TAC NO. MD7221)

Dear Members of the TSTF,

By letter dated August 31, 2007 (Agencywide Documents Access and Management System (ADAMS) Accession No. ML072430830), as supplemented by letter dated March 11, 2008 (ADAMS Accession No. ML080710396), the Technical Specifications Task Force (TSTF) requested the NRC to review TSTF-500, Revision 0, "DC Electrical Rewrite – Update to TSTF-360."

The Nuclear Regulatory Commission (NRC) staff has reviewed the submittal and has determined that additional information is needed to complete its review. The specific questions are found in the enclosed Request for Additional Information (RAI). A response to this RAI is requested to be provided within 60 days.

Sincerely,

*/RA/*

Robert Elliott, Chief  
Technical Specifications Branch  
Division of Inspections & Regional Support  
Office of Nuclear Reactor Regulation

Enclosure:  
RAI

cc: See next page

DISTRIBUTION:

ITSB R/F      Nrr\_Dirs\_Itsb Distribution  
RWolfgang    RidsNrrDciCptb  
KParczewki   AKlett

RidsNrrDirs  
RidsNrrDeEeeb

RidsNrrDirsItsb  
RidsNrrDciCsgb

ADAMS Accession No.: ML0081210175

OFFICE	ITSB:DIRS	BC:ITSB:DIRS	BC:EEEB:DE
NAME	GWaig	RElliott	GWilson
DATE	04/30/2008	06/4/2008	04/30/2008

OFFICIAL RECORD COPY

Technical Specifications Task Force Mailing List

cc:

Technical Specifications Task Force  
11921 Rockville, Pike  
Suite 100  
Rockville, MD 20852  
[tstf@excelservices.com](mailto:tstf@excelservices.com)

Donald R. Hoffman  
EXCEL Services Corporation  
11921 Rockville Pike, Suite 100  
Rockville, MD 20852  
[donaldh@excelservices.com](mailto:donaldh@excelservices.com)

George G. Yates  
AmerenUE Callaway Plant  
Junction Hwy. CC and Hwy. O  
Mail Code CA-460  
P.O. Box 620  
Fulton, MO 65251  
[gyates@ameren.com](mailto:gyates@ameren.com)

Brian Mann  
EXCEL Services Corporation  
11921 Rockville Pike, Suite 100  
Rockville, MD 20852  
[brianm@excelservices.com](mailto:brianm@excelservices.com)

John Messina  
First Energy Nuclear Operating Company  
76 South Main Street  
Mail Sto: Akron-GO-14  
Akron, OH 44308  
[jmessina@firstenergycorp.com](mailto:jmessina@firstenergycorp.com)

Jim Kenny  
924 Liberty Street  
Emmaus, PA 18049  
[jken@ptd.net](mailto:jken@ptd.net)

David Bice  
Entergy  
N-GSB64  
Russellville, AR 72802  
[dbice@entergy.com](mailto:dbice@entergy.com)

Reene' V. Gambrell  
Duke Energy  
Mailcode: ON03RC  
7800 Rochester Highway  
Seneca, SC 29672  
[RVGambrell@duke-energy.com](mailto:RVGambrell@duke-energy.com)

## REQUEST FOR ADDITIONAL INFORMATION (RAI)

### TSTF-500, REVISION 0, "DC ELECTRICAL REWRITE – UPDATE TO TSTF-360"

1. On page 14 of the August 31, 2007, submittal, the applicant stated that the float current requirements are based on the float current indicative of a charged battery. Define the term 'charged battery'.
2. On page 17 of the August 31, 2007, submittal, the applicant stated that the [2] amp float current value is an indication that the battery is [95] percent charged. Show that the Technical Specification float current value provides an indication that the battery is fully capable of performing its specified safety function.
3. Describe the methodology for determining the design margin (e.g., 5%) that must be maintained in order to utilize float current monitoring as an indication of a battery's state-of-charge.
4. Describe how licensees will show that the float current limit for determining a battery's state-of-charge will remain valid for future replacement batteries.
5. Describe how electrical isolation will be maintained in accordance with Regulatory Guide 1.75, "Criteria for Independence of Electrical Safety Systems," between non-Class 1E and Class 1E circuits when an alternate means (i.e., non-Class 1E spare battery charger) is maintaining the charge on the Class 1E battery. If double isolation (e.g., two breakers in series, a breaker and a fuse, or a breaker supplied with a loss-of-offsite power signal) is not used, provide a detailed discussion on how a fault on the non-Class 1E electrical circuit will not propagate to the Class 1E electrical circuit.
6. On page 15 of the August 31, 2007, submittal, the TSTF stated that the minimum temperature necessary to support operability of the battery can vary depending on the available excess capacity of the associated battery. Describe the available excess capacity that is being credited.