Dominion Energy Kewaunee, Inc.
N490 Highway 42, Kewaunee, WI 54216-9511

Dominion®

APR 24 2008

ATTN: Document Control Desk
U. S. Nuclear Regulatory Commission
Washington, DC 20555-0001

Serial No. 08-0221
LIC/NW/RO
Docket No.: 50-305
License No.: DPR-43

DOMINION ENERGY KEWAUNEE, INC.
KEWAUNEE POWER STATION
2007 ANNUAL RADIOACTIVE EFFLUENT RELEASE REPORT

Enclosed is the Kewaunee Power Station (KPS) 2007 Annual Radioactive Effluent Release Report for January through December 2007. This report is submitted to meet the requirements of KPS Technical Specification 6.9.b.2 and 10 CFR 50.36a(a)(2).

If you have questions or require additional information, please feel free to contact Mr. Mike Hale at 920-388-8103.

Very truly yours,

Michael J. Wilson
Director Safety and Licensing

Commitments made by this letter: NONE

Enclosure

IE48

NRR

cc: Regional Administrator, Region III
U. S. Nuclear Regulatory Commission
2443 Warrenville Road
Suite 210
Lisle, IL 60532-4352

Ms. M. H. Chernoff
Senior Project Manager
U.S. Nuclear Regulatory Commission
One White Flint North, Mail Stop O8-H4A
11555 Rockville Pike
Rockville, MD 20852-2738

NRC Senior Resident Inspector
Kewaunee Power Station

Mr. W. A. Nestel
Institute of Nuclear Power Operations
700 Galleria Parkway
Atlanta, GA 30339

Mr. Don Hendrikse
WI Division of Public Health
Radiation Protection Section
Room 150
Madison, WI 53701-2659

Ms. Deborah Russo
American Nuclear Insurers
95 Glastonbury Blvd.
Glastonbury, CT 06033

Dominion®

2007 Annual Radioactive Effluent Release Report

Kewaunee Power Station

Dominion Energy Kewaunee, Inc.

DOCKET 50-305

KEWAUNEE POWER STATION

ANNUAL RADIOACTIVE EFFLUENT RELEASE REPORT

January 1 - December 31, 2007

Dominion Energy Kewaunee, Inc.
Kewaunee, Wisconsin

Table of Contents

Section	Description	
0.0	Summary	3
1.0	Introduction	3
1.1	Effluent Dose Limits	3
2.0	Gaseous Effluents	4
2.1	Lower Limits of Detection (LLD) for Gaseous Effluents	4
2.2	Gaseous Batch Release Statistics	6
2.3	Gaseous Effluent Data	6
	Table 2.1 Gaseous Effluents - Summation of all Releases	7
	Table 2.2 Gaseous Effluents	8
	Table 2.3A Gaseous Total of all Releases	10
	Table 2.3B Gaseous Release Continuous	18
	Table 2.3C Gaseous Release Batch	26
	Table 2.4 Dose From Gaseous Effluents	34
3.0	Liquid Effluents	36
3.1	Lower Limits of Detection (LLD) for Liquid Effluents	36
3.2	Liquid Batch Release Statistics	38
3.3	Liquid Effluent Data	38
	Table 3.1 Liquid Effluents - Summation of all Releases	39
	Table 3.2A Liquid Effluents - Batch Releases 1st Quarter	40
	Table 3.2B Liquid Effluents - Batch Releases 2nd Quarter	42
	Table 3.2C Liquid Effluents - Batch Releases 3rd Quarter	44
	Table 3.2D Liquid Effluents - Batch Releases 4th Quarter	46
	Table 3.3A Liquid Effluents - Continuous Releases 1st Quarter	48
	Table 3.3B Liquid Effluents - Continuous Releases 2nd Quarter	50
	Table 3.3C Liquid Effluents - Continuous Releases 3rd Quarter	52
	Table 3.3D Liquid Effluents - Continuous Releases 4th Quarter	54
	Table 3.4 Dose From Liquid Effluents	56
4.0	Unplanned Releases	58
5.0	Meteorological Data	58
6.0	Solid Waste Disposal	58
	Table 6.1 Solid Waste and Irradiated Fuel Shipments	59
7.0	Program Revisions	63
8.0	Reportable Occurrences	63

Appendix A Meteorological Data

0.0 SUMMARY

During 2007 all solid, liquid, and gaseous radioactive effluents from the Kewaunee Nuclear Plant were well below regulatory limits. For individual effluent streams , the quarterly limit most closely approached was:

GASEOUS:	Ingestion Pathway-Organ	Liver	
	Quarterly Limit (mRems)	7.5	
	Actual Dose (mRems)	0.00008958	(2nd Quarter)
	% of Specification	0.001194	
LIQUID:	Ingestion Pathway-Organ	Total Body	
	Quarterly Limit (mRems)	1.5	
	Actual Dose (mRems)	0.0007377	(2nd Quarter)
	% of Limit	0.04918	
SOLID:	No upper limit for solid radioactive waste applies.		
	Cubic Meters Shipped	1.72E+02 (6.08E+06 ft^3)	

1.0 INTRODUCTION

This report is being submitted in accordance with the requirements of Kewaunee Technical Specifications, Section 6.9.b.2 and the Offsite Dose Calculation Manual, Section 3/4.7. It includes data from all effluent releases made from January 1 - December 31, 2007. The report contains summaries of the gaseous and liquid releases made to the environment including the quantity, characterization, time duration and calculated radiation dose at the site boundary resulting from these releases. The report also includes a summation of solid waste disposal, revisions to the Process Control Program and the Offsite Dose Calculation Manual, and addresses the cumulative meteorological data. Values indicated as 0 (zero) in this report refer to actual values less than the detection limits. A table of these less than (LLD) values is identified in sections 2.1 and 3.1.

1.1 Effluent Dose Limits

Specifications are set to insure that offsite doses are maintained as low as reasonably achievable while still allowing for practical and dependable operation of the Kewaunee Plant.

The Kewaunee Offsite Dose Calculation Manual (ODCM) describes the methodology and parameters used in:

1.) The calculation of radioactive liquid and gaseous effluent monitoring instrumentation alarm/trip setpoints.

2.) The calculation of radioactive liquid and gaseous concentrations, dose rates and cumulative quarterly and annual doses. The ODCM methodology is acceptable for use in demonstrating compliance with 10 CFR 20.106; 10 CFR 50, Appendix I; and 40 CFR 190.

2.0 GASEOUS EFFLUENTS

2.1 Lower Limits of Detection (LLD) for Gaseous Effluents

Gaseous radioactive effluents are released in both the continuous mode and the batch mode. The auxiliary building stack is sampled continuously for particulates, halogens and Strontium by an "off-line" sample train. This stack is also grab-sampled daily for gaseous gamma emitters. Batch releases are sampled prior to release for principal gaseous and particulate gamma emitters, halogens and tritium.

The LLD's for gaseous radioanalyses, as listed in Table 4.4 of the Kewaunee ODCM are:

Analysis	LLD (μCi/ml)
Gaseous Gamma Emitters	1.00 E-04
Iodine 131	3.00 E-12
Particulate Gamma Emitters	1.00 E-11
Particulate Gross Alpha	1.00 E-11
Strontium 89, 90	1.00 E-11
Noble Gases, Gross Beta or Gamma	1.00 E-06

The nominal "a priori" LLD values are shown below.

Isotope	a priori LLD (μCi/ml)
a. Gaseous emissions:	
Kr-87	5.61E-08
Kr-88	1.02E-07
Xe-133	6.68E-08
Xe-133m	2.75E-07
Xe-135	2.99E-08
Xe-138	1.13E-07

b. Particulate emissions:

Mn-54	1.11E-13
Fe-59	2.27E-13
Co-58	2.28E-13
Co-60	3.57E-13
Zn-65	1.68E-13
Mo-99	2.73E-13
Cs-134	4.69E-13
Cs-137	1.68E-13
Ce-141	2.08E-13
Ce-144	1.24E-12

c. Other identifiable gamma emitters:

Ar-41	3.97E-10
Kr-85	8.63E-05
Kr-85m	4.62E-08
Kr-89	2.04E-06
Xe-127	4.20E-08
Xe-131m	1.82E-06
Xe-135m	1.90E-08
Xe-137	2.88E-07
I-131	1.32E-13

d. Composite particulate samples:

Sr-89	1 E-14
Sr-90	1 E-14
Gross Alpha	1.00 E-14

These "a priori" LLDs represent the capabilities of the counting systems in use, not an after the fact "a posteriori" limit for a particular measurement.

2.2 **Gaseous Batch Release Statistics**

The following is a summation of all gaseous batch releases made during 2007.

Number of batch releases.....52

Total time for all batch releases (min)..... 1,608,220.0

Maximum time for a batch release (min)..... 1,580,322.0

Average time for a batch release (min)..... 30,927.3

Minimum time for a batch release (min)..... 7.0

2.3 **Gaseous Effluent Data**

The following table 2.1 presents a quarterly summation of the total activity released and average release rates of four categories of gaseous effluents. Table 2.2 lists the quarterly sums of individual gaseous radionuclides released by continuous and batch modes. Table 2.3 is essentially the same data, but is presented as monthly summations. Table 2.4 presents the dose limits for gaseous effluents, and the calculated doses this year from gaseous effluents.

Table 2.1
Annual Radioactive Effluent Release Report 2007
Gaseous Effluents - Summation of all Releases

Fission and Activation Gases	1st Quarter	2nd Quarter	3rd Quarter	4th Quarter
Total Activity Released (Ci)	5.033E-003	1.889E-003	0.000E+000	7.245E-002
Average Release Rate (μCi/sec)	6.401E-004	2.403E-004	0.000E+000	9.214E-003
Iodines				
Total Activity Released (Ci)	0.000E+000	0.000E+000	0.000E+000	0.000E+000
Average Release Rate (μCi/sec)	0.000E+000	0.000E+000	0.000E+000	0.000E+000
Particulates				
Total Activity Released (Ci)	0.000E+000	0.000E+000	0.000E+000	0.000E+000
Average Release Rate (μCi/sec)	0.000E+000	0.000E+000	0.000E+000	0.000E+000
Gross Alpha Released (Ci)	0.000E+000	0.000E+000	0.000E+000	0.000E+000
Tritium				
Total Activity Released (Ci)	1.356E+000	4.240E+000	4.091E+000	2.545E+000
Average Release Rate (μCi/sec)	1.724E-001	5.393E-001	5.203E-001	3.237E-001

Table 2.2
Annual Radioactive Effluent Release Report 2007
Gaseous Effluents

Nuclides Released (Ci)
Continuous Mode

	1st Quarter	2nd Quarter	3rd Quarter	4th Quarter
Fission Gases				
Total	0.000E+000	0.000E+000	0.000E+000	0.000E+000
Iodines				
Total	0.000E+000	0.000E+000	0.000E+000	0.000E+000
Particulates				
Total	0.000E+000	0.000E+000	0.000E+000	0.000E+000

Table 2.2(cont)
Annual Radioactive Effluent Release Report 2007
Gaseous Effluents

Nuclides Released (Ci)
Batch Mode

Fission Gases				
Xe-133	4.962E-003	1.882E-003	0.000E+000	6.825E-002
Xe-133m	5.433E-005	0.000E+000	0.000E+000	1.460E-003
Xe-135	1.664E-005	7.623E-006	0.000E+000	2.739E-003
Total	5.033E-003	1.889E-003	0.000E+000	7.245E-002
Iodines				
Total	0.000E+000	0.000E+000	0.000E+000	0.000E+000
Particulates				
Total	0.000E+000	0.000E+000	0.000E+000	0.000E+000

Table 2.3A
Annual Radioactive Effluent Release Report 2007
1st Quarter Gaseous Release
Total of all Releases

Noble Gasses (Curies)

Isotope	January	February	March	Total
Xe-133	6.054E-004	8.370E-005	4.273E-003	4.962E-003
Xe-133m	0.000E+000	0.000E+000	5.433E-005	5.433E-005
Xe-135	0.000E+000	0.000E+000	1.664E-005	1.664E-005
Total	6.054E-004	8.370E-005	4.344E-003	5.033E-003

Particulates (Curies)

Isotope	January	February	March	Total
Total	0.000E+000	0.000E+000	0.000E+000	0.000E+000

Halogens (Curies)

Isotope	January	February	March	Total
Total	0.000E+000	0.000E+000	0.000E+000	0.000E+000

Table 2.3A (Con't)
Annual Radioactive Effluent Release Report 2007
1st Quarter Gaseous Release
Total of all Releases

Summary

	January	February	March	Total
Total Noble Gases (Ci)	6.054E-004	8.370E-005	4.344E-003	5.033E-003
Total Halogens (Ci)	0.000E+000	0.000E+000	0.000E+000	0.000E+000
Total Particulate Gross Beta-Gamma Half-Lives>8 Days (Ci)	0.000E+000	0.000E+000	0.000E+000	0.000E+000
Total Tritium (Ci)	9.563E-001	7.169E-003	3.922E-001	1.356E+000
Total Particulate Gross Alpha (Ci)	0.000E+000	0.000E+000	0.000E+000	0.000E+000

Table 2.3A (Con't)
Annual Radioactive Effluent Release Report 2007
2nd Quarter Gaseous Release
Total of all Releases

Noble Gasses (Curies)

Isotope	April	May	June	Total
Xe-133	1.750E-003	0.000E+000	1.317E-004	1.882E-003
Xe-135	7.623E-006	0.000E+000	0.000E+000	7.623E-006
Total	1.757E-003	0.000E+000	1.317E-004	1.889E-003

Particulates (Curies)

Isotope	April	May	June	Total
Total	0.000E+000	0.000E+000	0.000E+000	0.000E+000

Halogens (Curies)

Isotope	April	May	June	Total
Total	0.000E+000	0.000E+000	0.000E+000	0.000E+000

Table 2.3A (Con't)
Annual Radioactive Effluent Release Report 2007
2nd Quarter Gaseous Release
Total of all Releases

Summary

	April	May	June	Total
Total Noble Gases (Ci)	1.757E-003	0.000E+000	1.317E-004	1.889E-003
Total Halogens (Ci)	0.000E+000	0.000E+000	0.000E+000	0.000E+000
Total Particulate Gross Beta-Gamma Half-Lives>8 Days (Ci)	0.000E+000	0.000E+000	0.000E+000	0.000E+000
Total Tritium (Ci)	3.507E-001	7.086E-001	3.181E+000	4.240E+000
Total Particulate Gross Alpha (Ci)	0.000E+000	0.000E+000	0.000E+000	0.000E+000

Table 2.3A (con't)
Annual Radioactive Effluent Release Report 2007
3rd Quarter Gaseous Release
Total of all Releases

Noble Gasses (Curies)

Isotope	July	August	September	Total
Total	0.000E+000	0.000E+000	0.000E+000	0.000E+000

Particulates (Curies)

Isotope	July	August	September	Total
Total	0.000E+000	0.000E+000	0.000E+000	0.000E+000

Halogens (Curies)

Isotope	July	August	September	Total
Total	0.000E+000	0.000E+000	0.000E+000	0.000E+000

Table 2.3A (Con't)
Annual Radioactive Effluent Release Report 2007
3rd Quarter Gaseous Release
Total of all Releases

Summary

	July	August	September	Total
Total Noble Gases (Ci)	0.000E+000	0.000E+000	0.000E+000	0.000E+000
Total Halogens (Ci)	0.000E+000	0.000E+000	0.000E+000	0.000E+000
Total Particulate Gross Beta-Gamma Half-Lives>8 Days (Ci)	0.000E+000	0.000E+000	0.000E+000	0.000E+000
Total Tritium (Ci)	3.130E+000	9.450E-001	1.649E-002	4.091E+000
Total Particulate Gross Alpha (Ci)	0.000E+000	0.000E+000	0.000E+000	0.000E+000

Table 2.3A (Con't)
Annual Radioactive Effluent Release Report 2007
4th Quarter Gaseous Release
Total of all Releases

Noble Gasses (Curies)

Isotope	October	November	December	Total
Xe-133	6.825E-002	0.000E+000	0.000E+000	6.825E-002
Xe-133m	1.460E-003	0.000E+000	0.000E+000	1.460E-003
Xe-135	2.739E-003	0.000E+000	0.000E+000	2.739E-003
Total	7.245E-002	0.000E+000	0.000E+000	7.245E-002

Particulates (Curies)

Isotope	October	November	December	Total
Total	0.000E+000	0.000E+000	0.000E+000	0.000E+000

Halogens (Curies)

Isotope	October	November	December	Total
Total	0.000E+000	0.000E+000	0.000E+000	0.000E+000

Table 2.3A (Con't)
Annual Radioactive Effluent Release Report 2007
4th Quarter Gaseous Release
Total of all Releases

Summary

	October	November	December	Total
Total Noble Gases (Ci)	7.245E-002	0.000E+000	0.000E+000	7.245E-002
Total Halogens (Ci)	0.000E+000	0.000E+000	0.000E+000	0.000E+000
Total Particulate Gross Beta-Gamma Half-Lives>8 Days (Ci)	0.000E+000	0.000E+000	0.000E+000	0.000E+000
Total Tritium (Ci)	1.406E+000	6.959E-001	4.426E-001	2.545E+000
Total Particulate Gross Alpha (Ci)	0.000E+000	0.000E+000	0.000E+000	0.000E+000

Table 2.3B
Annual Radioactive Effluent Release Report 2007
1st Quarter Gaseous Release
Continuous Mode Only

Noble Gasses (Curies)

Isotope	January	February	March	Total
Total	0.000E+000	0.000E+000	0.000E+000	0.000E+000

Particulates (Curies)

Isotope	January	February	March	Total
Total	0.000E+000	0.000E+000	0.000E+000	0.000E+000

Halogens (Curies)

Isotope	January	February	March	Total
Total	0.000E+000	0.000E+000	0.000E+000	0.000E+000

Table 2.3B (Con't)
Annual Radioactive Effluent Release Report 2007
1st Quarter Gaseous Release
Continuous Mode Only

Summary

	January	February	March	Total
Total Noble Gases (Ci)	0.000E+000	0.000E+000	0.000E+000	0.000E+000
Total Halogens (Ci)	0.000E+000	0.000E+000	0.000E+000	0.000E+000
Total Particulate Gross Beta-Gamma Half-Lives>8 Days (Ci)	0.000E+000	0.000E+000	0.000E+000	0.000E+000
Total Tritium (Ci)	9.366E-001	0.000E+000	3.918E-001	1.328E+000
Total Particulate Gross Alpha (Ci)	0.000E+000	0.000E+000	0.000E+000	0.000E+000

Table 2.3B (Con't)
Annual Radioactive Effluent Release Report 2007
2nd Quarter Gaseous Release
Continuous Mode Only

Noble Gasses (Curies)

Isotope	April	May	June	Total
Total	0.000E+000	0.000E+000	0.000E+000	0.000E+000

Particulates (Curies)

Isotope	April	May	June	Total
Total	0.000E+000	0.000E+000	0.000E+000	0.000E+000

Halogens (Curies)

Isotope	April	May	June	Total
Total	0.000E+000	0.000E+000	0.000E+000	0.000E+000

Table 2.3B (Con't)
Annual Radioactive Effluent Release Report 2007
2nd Quarter Gaseous Release
Continuous Mode Only

Summary

	April	May	June	Total
Total Noble Gases (Ci)	0.000E+000	0.000E+000	0.000E+000	0.000E+000
Total Halogens (Ci)	0.000E+000	0.000E+000	0.000E+000	0.000E+000
Total Particulate Gross Beta-Gamma Half-Lives>8 Days (Ci)	0.000E+000	0.000E+000	0.000E+000	0.000E+000
Total Tritium (Ci)	3.414E-001	6.959E-001	3.172E+000	4.209E+000
Total Particulate Gross Alpha (Ci)	0.000E+000	0.000E+000	0.000E+000	0.000E+000

Table 2.3B (con't)
Annual Radioactive Effluent Release Report 2007
3rd Quarter Gaseous Release
Continuous Mode Only

Noble Gasses (Curies)

Isotope	July	August	September	Total
Total	0.000E+000	0.000E+000	0.000E+000	0.000E+000

Particulates (Curies)

Isotope	July	August	September	Total
Total	0.000E+000	0.000E+000	0.000E+000	0.000E+000

Halogens (Curies)

Isotope	July	August	September	Total
Total	0.000E+000	0.000E+000	0.000E+000	0.000E+000

Table 2.3B (Con't)
Annual Radioactive Effluent Release Report 2007
3rd Quarter Gaseous Release
Continuous Mode Only

Summary

	July	August	September	Total
Total Noble Gases (Ci)	0.000E+000	0.000E+000	0.000E+000	0.000E+000
Total Halogens (Ci)	0.000E+000	0.000E+000	0.000E+000	0.000E+000
Total Particulate Gross Beta-Gamma Half-Lives>8 Days (Ci)	0.000E+000	0.000E+000	0.000E+000	0.000E+000
Total Tritium (Ci)	3.125E+000	9.407E-001	1.114E-002	4.077E+000
Total Particulate Gross Alpha (Ci)	0.000E+000	0.000E+000	0.000E+000	0.000E+000

Table 2.3B (Con't)
Annual Radioactive Effluent Release Report 2007
4th Quarter Gaseous Release
Continuous Mode Only

Noble Gasses (Curies)

Isotope	October	November	December	Total
Total	0.000E+000	0.000E+000	0.000E+000	0.000E+000

Particulates (Curies)

Isotope	October	November	December	Total
Total	0.000E+000	0.000E+000	0.000E+000	0.000E+000

Halogens (Curies)

Isotope	October	November	December	Total
Total	0.000E+000	0.000E+000	0.000E+000	0.000E+000

Table 2.3B (Con't)
Annual Radioactive Effluent Release Report 2007
4th Quarter Gaseous Release
Continuous Mode Only

Summary

	October	November	December	Total
Total Noble Gases (Ci)	0.000E+000	0.000E+000	0.000E+000	0.000E+000
Total Halogens (Ci)	0.000E+000	0.000E+000	0.000E+000	0.000E+000
Total Particulate Gross Beta-Gamma Half-Lives>8 Days (Ci)	0.000E+000	0.000E+000	0.000E+000	0.000E+000
Total Tritium (Ci)	1.396E+000	6.923E-001	4.426E-001	2.531E+000
Total Particulate Gross Alpha (Ci)	0.000E+000	0.000E+000	0.000E+000	0.000E+000

Table 2.3C
Annual Radioactive Effluent Release Report 2007
1st Quarter Gaseous Release
Batch Mode Only

Noble Gasses (Curies)

Isotope	January	February	March	Total
Xe-133	6.054E-004	8.370E-005	4.273E-003	4.962E-003
Xe-133m	0.000E+000	0.000E+000	5.433E-005	5.433E-005
Xe-135	0.000E+000	0.000E+000	1.664E-005	1.664E-005
Total	6.054E-004	8.370E-005	4.344E-003	5.033E-003

Particulates (Curies)

Isotope	January	February	March	Total
Total	0.000E+000	0.000E+000	0.000E+000	0.000E+000

Halogens (Curies)

Isotope	January	February	March	Total
Total	0.000E+000	0.000E+000	0.000E+000	0.000E+000

Table 2.3C (Con't)
Annual Radioactive Effluent Release Report 2007
1st Quarter Gaseous Release
Batch Mode Only

Summary

	January	February	March	Total
Total Noble Gases (Ci)	6.054E-004	8.370E-005	4.344E-003	5.033E-003
Total Halogens (Ci)	0.000E+000	0.000E+000	0.000E+000	0.000E+000
Total Particulate Gross Beta-Gamma Half-Lives>8 Days (Ci)	0.000E+000	0.000E+000	0.000E+000	0.000E+000
Total Tritium (Ci)	1.969E-002	7.169E-003	3.231E-004	2.718E-002
Total Particulate Gross Alpha (Ci)	0.000E+000	0.000E+000	0.000E+000	0.000E+000

Table 2.3C (Con't)
Annual Radioactive Effluent Release Report 2007
2nd Quarter Gaseous Release
Batch Mode Only

Noble Gasses (Curies)

Isotope	April	May	June	Total
Xe-133	1.750E-003	0.000E+000	1.317E-004	1.882E-003
Xe-135	7.623E-006	0.000E+000	0.000E+000	7.623E-006
Total	1.757E-003	0.000E+000	1.317E-004	1.889E-003

Particulates (Curies)

Isotope	April	May	June	Total
Total	0.000E+000	0.000E+000	0.000E+000	0.000E+000

Halogens (Curies)

Isotope	April	May	June	Total
Total	0.000E+000	0.000E+000	0.000E+000	0.000E+000

Table 2.3C (Con't)
Annual Radioactive Effluent Release Report 2007
2nd Quarter Gaseous Release
Batch Mode Only

Summary

	April	May	June	Total
Total Noble Gases (Ci)	1.757E-003	0.000E+000	1.317E-004	1.889E-003
Total Halogens (Ci)	0.000E+000	0.000E+000	0.000E+000	0.000E+000
Total Particulate Gross Beta-Gamma Half-Lives>8 Days (Ci)	0.000E+000	0.000E+000	0.000E+000	0.000E+000
Total Tritium (Ci)	9.299E-003	1.275E-002	9.393E-003	3.145E-002
Total Particulate Gross Alpha (Ci)	0.000E+000	0.000E+000	0.000E+000	0.000E+000

Table 2.3C (con't)
Annual Radioactive Effluent Release Report 2007
3rd Quarter Gaseous Release
Batch Mode Only

Noble Gasses (Curies)

Isotope	July	August	September	Total
Total	0.000E+000	0.000E+000	0.000E+000	0.000E+000

Particulates (Curies)

Isotope	July	August	September	Total
Total	0.000E+000	0.000E+000	0.000E+000	0.000E+000

Halogens (Curies)

Isotope	July	August	September	Total
Total	0.000E+000	0.000E+000	0.000E+000	0.000E+000

Table 2.3C (Con't)
Annual Radioactive Effluent Release Report 2007
3rd Quarter Gaseous Release
Batch Mode Only

Summary

	July	August	September	Total
Total Noble Gases (Ci)	0.000E+000	0.000E+000	0.000E+000	0.000E+000
Total Halogens (Ci)	0.000E+000	0.000E+000	0.000E+000	0.000E+000
Total Particulate Gross Beta-Gamma Half-Lives>8 Days (Ci)	0.000E+000	0.000E+000	0.000E+000	0.000E+000
Total Tritium (Ci)	4.464E-003	4.231E-003	5.346E-003	1.404E-002
Total Particulate Gross Alpha (Ci)	0.000E+000	0.000E+000	0.000E+000	0.000E+000

Table 2.3C (Con't)
Annual Radioactive Effluent Release Report 2007
4th Quarter Gaseous Release
Batch Mode Only

Noble Gasses (Curies)

Isotope	October	November	December	Total
Xe-133	6.825E-002	0.000E+000	0.000E+000	6.825E-002
Xe-133m	1.460E-003	0.000E+000	0.000E+000	1.460E-003
Xe-135	2.739E-003	0.000E+000	0.000E+000	2.739E-003
Total	7.245E-002	0.000E+000	0.000E+000	7.245E-002

Particulates (Curies)

Isotope	October	November	December	Total
Total	0.000E+000	0.000E+000	0.000E+000	0.000E+000

Halogens (Curies)

Isotope	October	November	December	Total
Total	0.000E+000	0.000E+000	0.000E+000	0.000E+000

Table 2.3C (Con't)
Annual Radioactive Effluent Release Report 2007
4th Quarter Gaseous Release
Batch Mode Only

Summary

	October	November	December	Total
Total Noble Gases (Ci)	7.245E-002	0.000E+000	0.000E+000	7.245E-002
Total Halogens (Ci)	0.000E+000	0.000E+000	0.000E+000	0.000E+000
Total Particulate Gross Beta-Gamma Half-Lives>8 Days (Ci)	0.000E+000	0.000E+000	0.000E+000	0.000E+000
Total Tritium (Ci)	9.952E-003	3.635E-003	0.000E+000	1.359E-002
Total Particulate Gross Alpha (Ci)	0.000E+000	0.000E+000	0.000E+000	0.000E+000

Table 2.4
Annual Radioactive Effluent Release Report 2007
Dose From Gaseous Effluents

The offsite dose limits from radioactive materials in gaseous effluents are specified in Section 3/4.4 of the Kewaunee ODCM and can be summarized as follows:

Limit	Whole Body Gamma	Skin Beta	Organ
Quarterly	5.0 mRad	10.0 mRad	7.5 mRem
Annual	10.0 mRad	20.0 mRad	15.0 mRem

The total release of gaseous effluents during each quarter of 2007 was within limits. The following offsite doses were calculated using equations 2.7, 2.8, and 2.11 from the Kewaunee ODCM. Calculated offsite doses versus quarterly limits are shown below:

	1st Qtr	2nd Qtr	3rd Qtr	4th Qtr
1. Gamma-Whole Body				
Specification (mRads)	5.000E+000	5.000E+000	5.000E+000	5.000E+000
Actual Dose (mRads)	2.056E-007	7.747E-008	0.000E+000	3.404E-006
% of Specification	4.111E-006	1.549E-006	0.000E+000	6.808E-005
2. Beta-Skin				
Specification (mRads)	1.000E+001	1.000E+001	1.000E+001	1.000E+001
Actual Dose (mRads)	6.084E-007	2.276E-007	0.000E+000	9.193E-006
% of Specification	6.084E-006	2.276E-006	0.000E+000	9.193E-005
3. Ingestion Pathway-Organ				
Specification (mRems)	7.500E+000	7.500E+000	7.500E+000	7.500E+000
Actual Dose (mRems)	2.864E-005	8.958E-005	8.643E-005	5.376E-005
% of Specification	3.818E-004	1.194E-003	1.152E-003	7.168E-004
	Liver	Liver	Liver	Liver

Table 2.4 (Con't)
Annual Radioactive Effluent Release Report 2007
Dose From Gaseous Effluents

In addition, the cumulative annual offsite doses for the period January 1 - December 31, 2007 versus the ODCM annual limits were:

	Annual
1. Gamma-Whole Body	
Specification (mRads)	1.000E+001
Actual Dose (mRads)	3.687E-006
% of Specification	3.687E-005
2. Beta-Skin	
Specification (mRads)	2.000E+001
Actual Dose (mRads)	1.003E-005
% of Specification	5.015E-005
3. Ingestion Pathway-Organ	
Specification (mRems)	1.500E+001
Actual Dose (mRems)	2.584E-004
% of Specification	1.723E-003
Liver	

3.0 LIQUID EFFLUENTS

3.1 Lower Limits of Detection (LLD) for Liquid Effluents

Liquid radioactive effluents are released as both batch releases and continuous releases. Each batch is sampled prior to release and analyzed for gamma emitters and tritium. A fraction of each sample is retained for a monthly proportional composite which is then analyzed for Gross Alpha, Strontium 89, Strontium 90 and Iron 55.

The LLD's for liquid batch release radioanalyses, as listed in Table 4.3 of the Kewaunee Nuclear Power Plant Off-Site Dose Calculation Manual, are:

Analysis	LLD (µCi/ml)
Principal Gamma Emitters	1.00 E-06
Iodine 131	1.00 E-06
Tritium	1.00 E-05
Gross Alpha	5.00 E-07
Strontium 89, 90	5.00 E-08
Iron 55	1.00 E-06

The actual obtained "a priori" LLD values for batch releases are shown below.

Isotope	1st Quarter	2nd Quarter	3rd Quarter	4th Quarter	Average a priori LLD (µCi/ml)
Mn-54	1.11E-07	7.88E-10	7.88E-08	7.87E-10	4.79E-08
Fe-59	1.75E-09	1.75E-09	1.75E-07	1.75E-09	4.51E-08
Co-58	7.73E-10	8.64E-08	7.73E-10	7.73E-10	2.22E-08
Co-60	1.17E-09	1.48E-07	1.67E-09	1.16E-09	3.80E-08
Zn-65	1.98E-09	1.98E-07	2.79E-07	1.97E-09	1.20E-07
Mo-99	5.56E-09	5.56E-07	5.58E-09	5.59E-09	1.43E-07
Cs-134	6.13E-10	6.13E-08	6.13E-10	6.12E-10	1.58E-08
Cs-137	7.59E-10	7.59E-10	1.52E-07	7.54E-10	3.86E-08
Ce-141	3.97E-10	3.97E-10	3.97E-10	3.97E-10	3.97E-10
Ce-144	5.01E-07	5.49E-07	1.76E-09	1.76E-09	2.63E-07
I-131	6.56E-08	4.64E-08	6.57E-08	4.65E-09	4.56E-08
H-3	3.20E-06	2.96E-06	4.00E-06	3.53E-06	3.42E-06
Sr-89	1.40E-08	3.70E-08	1.40E-08	1.20E-08	1.93E-08
Sr-90	6.50E-09	9.00E-09	8.50E-09	8.30E-09	8.08E-09
Gross Alpha	5.10E-09	9.50E-09	8.70E-09	1.20E-08	8.83E-09
Fe-55	7.20E-07	7.10E-07	7.30E-07	7.10E-07	7.18E-07

Continuous liquid releases are grab sampled weekly and analyzed for principal gamma emitters. A fraction of each weekly sample is retained for a monthly proportional composite which is then analyzed for Tritium, Gross Alpha, Strontium 89, Strontium 90 and Iron 55.

The LLD's for liquid continuous release radioanalyses, as listed in Table 4.3 of the Kewaunee Nuclear Power Plant Off-Site Dose Calculation Manual, are:

Analysis	LLD (μCi/ml)
Principal Gamma Emitters	5.00 E-07
Iodine 131	1.00 E-06
Tritium	1.00 E-05
Gross Alpha	5.00 E-07
Strontium 89, 90	5.00 E-08
Iron 55	1.00 E-06

The actual obtained "a priori" LLD values for continuous releases are shown below.

Isotope	1st Quarter	2nd Quarter	3rd Quarter	4th Quarter	Average a priori LLD (μCi/ml)
Mn-54	1.31E-10	2.94E-08	2.75E-08	1.31E-10	1.43E-08
Fe-59	2.92E-10	3.51E-08	2.92E-08	2.92E-10	1.62E-08
Co-58	2.19E-08	2.14E-08	1.29E-10	1.28E-10	1.09E-08
Co-60	2.17E-08	1.94E-08	2.34E-08	1.94E-10	1.62E-08
Zn-65	4.66E-08	3.29E-08	3.29E-10	3.29E-10	2.00E-08
Mo-99	2.00E-07	4.60E-07	9.31E-10	3.74E-07	2.59E-07
Cs-134	1.02E-10	3.20E-08	3.09E-08	2.50E-08	2.20E-08
Cs-137	1.27E-10	2.19E-08	4.47E-08	3.75E-08	2.61E-08
Ce-141	5.01E-08	6.62E-11	3.03E-08	6.62E-11	2.01E-08
Ce-144	1.33E-07	2.50E-07	1.45E-07	1.56E-07	1.71E-07
I-131	7.74E-11	7.74E-11	7.74E-11	4.13E-08	1.04E-08
H-3	3.20E-06	2.96E-06	4.00E-06	3.53E-06	3.42E-06
Sr-89	1.40E-08	1.70E-08	1.70E-08	1.35E-08	1.54E-08
Sr-90	6.95E-09	8.55E-09	9.50E-08	8.15E-09	2.97E-08
Gross Alpha	5.15E-09	5.85E-09	5.55E-09	6.33E-09	5.72E-09
Fe-55	7.25E-07	6.60E-07	7.25E-07	7.15E-07	7.06E-07

3.2 **Liquid Batch Release Statistics**

The following is a summation of all liquid batch releases made during 2007.

Release Type	Number	Gallons Released
A SGBT Monitor Tk.	16	144,956
B SGBT Monitor Tk.	11	100,073
A CVC Monitor	9	59,990
B CVC Monitor	10	59,325
Both WCTs	2	3,300

Total time for all batch releases..... 21,905.0 Min.

Maximum time for a batch release..... 745.0 Min.

Minimum time for a batch release..... 50.0 Min.

Average time for a batch release..... 456.4 Min.

3.3 **Liquid Effluent Data**

The following Table 3.1 presents a quarterly summation of the total activity released and average concentration for all liquid effluents. It also presents the gross alpha activity released, volume of waste released and volume of dilution water used. Tables 3.2 and 3.3 are monthly summations of the same information in Table 3.1. Table 3.2 contains the quantity of the individual isotopes released to the unrestricted area for batch releases. Table 3.3 presents a monthly summation of gross radioactivity, tritium, gross alpha and isotopic activity for the secondary blowdown and leakage releases. It also presents the monthly total volume for these releases and dilution volumes. Table 3.4 presents the doses from liquid effluents for each quarter and the calculated doses this year from liquid effluents.

TABLE 3.1
Annual Radioactive Effluent Release Report 2007
Liquid Effluents - Summation of all Releases

	1st Qtr	2nd Qtr	3rd Qtr	4th Qtr
Fission and Activation Products				
Total Release Excluding H3 and Dissolved Gases (Ci)	8.534E-003	1.066E-002	2.862E-003	3.260E-003
0.000E+000				
Average Concentration (µCi/ml)	7.547E-011	5.002E-011	1.426E-011	1.682E-011
Tritium				
Total Release (Ci)	6.212E+001	4.161E+001	1.143E+001	1.240E+002
Average Concentration (µCi/ml)	5.493E-007	1.952E-007	5.695E-008	6.399E-007
% of Tech. Spec. Limit(3.0E-3 µCi/ml)	1.831E-002	6.507E-003	1.898E-003	2.133E-002
Dissolved Gases				
Total Release (Ci)	0.000E+000	0.000E+000	0.000E+000	0.000E+000
Average Concentration (µCi/ml)	0.000E+000	0.000E+000	0.000E+000	0.000E+000
% of Tech. Spec. Limit(2.0E-4 µCi/ml)	0.000E+000	0.000E+000	0.000E+000	0.000E+000
Gross Alpha Activity				
Total Release (Ci)	0.000E+000	0.000E+000	0.000E+000	0.000E+000
Volume of Waste Released				
Batch (liters)	5.011E+005	3.966E+005	9.976E+004	3.941E+005
Continuous (liters)	2.318E+007	1.816E+007	1.861E+007	2.007E+007
Total (liters)	2.368E+007	1.856E+007	1.871E+007	2.047E+007
Volume of Dilution Water				
Batch (liters)	6.495E+009	7.167E+009	2.382E+009	9.684E+009
Continuous (liters)	1.066E+011	2.060E+011	1.984E+011	1.841E+011
Total (liters)	1.131E+011	2.131E+011	2.008E+011	1.938E+011

TABLE 3.2A
Annual Radioactive Effluent Release Report 2007
Liquid Effluents - Batch Releases

	January	February	March	Total
Gross Radioactivity				
Total Release Excluding H3 and Dissolved Gases (Ci)	3.381E-003	3.539E-003	1.970E-003	8.891E-003
Avg. Conc. (μCi/ml)	1.878E-009	1.323E-009	9.749E-010	
Tritium				
Total Release (Ci)	4.026E+000	2.656E+001	4.664E+001	7.722E+001
Avg. Conc. (μCi/ml)	2.236E-006	9.929E-006	2.308E-005	
Dissolved Gases				
Total Release (Ci)	0.000E+000	0.000E+000	0.000E+000	0.000E+000
Avg. Conc. (μCi/ml)	0.000E+000	0.000E+000	0.000E+000	
Gross Alpha Activity				
Total Release (Ci)	0.000E+000	0.000E+000	0.000E+000	0.000E+000
Avg. Conc. (μCi/ml)	0.000E+000	0.000E+000	0.000E+000	
Volume of Waste Released				
(liters)	1.300E+005	2.020E+005	1.690E+005	5.011E+005
Volume of Dilution Water				
(liters)	1.800E+009	2.674E+009	2.020E+009	6.495E+009

TABLE 3.2A (Con't)
Annual Radioactive Effluent Release Report 2007
Liquid Effluents - Batch Releases

Isotope (Ci)	January	February	March	Total
Ag-110m	1.043E-005	1.581E-004	6.867E-005	2.371E-004
Alpha	0.000E+000	0.000E+000	0.000E+000	0.000E+000
Co-58	5.658E-004	6.108E-004	8.004E-005	1.257E-003
Co-60	8.951E-005	8.201E-004	2.487E-004	1.158E-003
Cs-136	0.000E+000	2.813E-005	0.000E+000	2.813E-005
Fe-55	1.079E-003	1.677E-003	1.548E-003	4.304E-003
Fe-59	0.000E+000	0.000E+000	0.000E+000	0.000E+000
H-3	4.026E+000	2.656E+001	4.664E+001	7.722E+001
Mn-54	0.000E+000	1.787E-004	2.479E-005	2.035E-004
Sb-125	1.636E-003	6.673E-005	0.000E+000	1.703E-003
Sr-89	0.000E+000	0.000E+000	0.000E+000	0.000E+000
Sr-90	0.000E+000	0.000E+000	0.000E+000	0.000E+000
Total	4.029E+000	2.656E+001	4.664E+001	7.723E+001

TABLE 3.2B
Annual Radioactive Effluent Release Report 2007
Liquid Effluents - Batch Releases

	April	May	June	Total
Gross Radioactivity				
Total Release Excluding H3 and Dissolved Gases (Ci)	3.166E-003	5.863E-003	1.277E-003	1.031E-002
Avg. Conc. (μCi/ml)	1.843E-009	1.367E-009	1.101E-009	
Tritium				
Total Release (Ci)	3.217E+000	1.552E+001	7.768E+000	2.651E+001
Avg. Conc. (μCi/ml)	1.873E-006	3.619E-006	6.698E-006	
Dissolved Gases				
Total Release (Ci)	0.000E+000	0.000E+000	0.000E+000	0.000E+000
Avg. Conc. (μCi/ml)	0.000E+000	0.000E+000	0.000E+000	
Gross Alpha Activity				
Total Release (Ci)	0.000E+000	0.000E+000	0.000E+000	0.000E+000
Avg. Conc. (μCi/ml)	0.000E+000	0.000E+000	0.000E+000	
Volume of Waste Released				
(liters)	1.403E+005	1.841E+005	7.221E+004	3.966E+005
Volume of Dilution Water				
(liters)	1.718E+009	4.289E+009	1.160E+009	7.167E+009

TABLE 3.2B (Con't)
Annual Radioactive Effluent Release Report 2007
Liquid Effluents - Batch Releases

Isotope (Ci)	April	May	June	Total
Ag-110m	2.283E-004	3.879E-004	4.214E-005	6.583E-004
Alpha	0.000E+000	0.000E+000	0.000E+000	0.000E+000
Co-58	2.396E-004	7.725E-004	8.010E-005	1.092E-003
Co-60	6.401E-004	1.930E-003	1.437E-004	2.714E-003
Cs-136	0.000E+000	0.000E+000	0.000E+000	0.000E+000
Fe-55	1.964E-003	2.578E-003	1.011E-003	5.553E-003
Fe-59	0.000E+000	0.000E+000	0.000E+000	0.000E+000
H-3	3.217E+000	1.552E+001	7.768E+000	2.651E+001
Mn-54	9.312E-005	1.945E-004	0.000E+000	2.876E-004
Sb-125	0.000E+000	0.000E+000	0.000E+000	0.000E+000
Sr-89	0.000E+000	0.000E+000	0.000E+000	0.000E+000
Sr-90	0.000E+000	0.000E+000	0.000E+000	0.000E+000
Total	3.220E+000	1.553E+001	7.769E+000	2.652E+001

TABLE 3.2C
Annual Radioactive Effluent Release Report 2007
Liquid Effluents - Batch Releases

	July	August	September	Total
Gross Radioactivity				
Total Release Excluding H3 and Dissolved Gases (Ci)	1.985E-003	8.778E-004	0.000E+000	2.862E-003
Avg. Conc. (μCi/ml)	1.313E-009	1.008E-009	N/A	
Tritium				
Total Release (Ci)	5.723E+000	5.712E+000	0.000E+000	1.143E+001
Avg. Conc. (μCi/ml)	3.788E-006	6.561E-006	N/A	
Dissolved Gases				
Total Release (Ci)	0.000E+000	0.000E+000	0.000E+000	0.000E+000
Avg. Conc. (μCi/ml)	0.000E+000	0.000E+000	N/A	
Gross Alpha Activity				
Total Release (Ci)	0.000E+000	0.000E+000	0.000E+000	0.000E+000
Avg. Conc. (μCi/ml)	0.000E+000	0.000E+000	N/A	
Volume of Waste Released				
(liters)	6.604E+004	3.372E+004	0.000E+000	9.976E+004
Volume of Dilution Water				
(liters)	1.511E+009	8.706E+008	0.000E+000	2.382E+009

TABLE 3.2C (Con't)
Annual Radioactive Effluent Release Report 2007
Liquid Effluents - Batch Releases

Isotope (Ci)	July	August	September	Total
Ag-110m	2.119E-004	4.572E-005	0.000E+000	2.576E-004
Alpha	0.000E+000	0.000E+000	0.000E+000	0.000E+000
Co-58	6.526E-005	2.153E-005	0.000E+000	8.679E-005
Co-60	3.532E-004	1.215E-004	0.000E+000	4.748E-004
Cs-136	0.000E+000	0.000E+000	0.000E+000	0.000E+000
Fe-55	1.321E-003	6.743E-004	0.000E+000	1.995E-003
Fe-59	0.000E+000	0.000E+000	0.000E+000	0.000E+000
H-3	5.723E+000	5.712E+000	0.000E+000	1.143E+001
Mn-54	3.342E-005	1.463E-005	0.000E+000	4.805E-005
Sb-125	0.000E+000	0.000E+000	0.000E+000	0.000E+000
Sr-89	0.000E+000	0.000E+000	0.000E+000	0.000E+000
Sr-90	0.000E+000	0.000E+000	0.000E+000	0.000E+000
Total	5.725E+000	5.713E+000	0.000E+000	1.144E+001

TABLE 3.2D
Annual Radioactive Effluent Release Report 2007
Liquid Effluents - Batch Releases

	October	November	December	Total
Gross Radioactivity				
Total Release Excluding H3 and Dissolved Gases (Ci)	2.074E-003	9.311E-004	2.545E-004	3.260E-003
Avg. Conc. (μCi/ml)	4.500E-010	2.359E-010	2.256E-010	
Tritium				
Total Release (Ci)	6.284E+001	5.655E+001	4.657E+000	1.240E+002
Avg. Conc. (μCi/ml)	1.363E-005	1.433E-005	4.128E-006	
Dissolved Gases				
Total Release (Ci)	0.000E+000	0.000E+000	0.000E+000	0.000E+000
Avg. Conc. (μCi/ml)	0.000E+000	0.000E+000	0.000E+000	
Gross Alpha Activity				
Total Release (Ci)	0.000E+000	0.000E+000	0.000E+000	0.000E+000
Avg. Conc. (μCi/ml)	0.000E+000	0.000E+000	0.000E+000	
Volume of Waste Released				
(liters)	2.143E+005	1.452E+005	3.462E+004	3.941E+005
Volume of Dilution Water				
(liters)	4.609E+009	3.947E+009	1.128E+009	9.684E+009

TABLE 3.2D (Con't)
Annual Radioactive Effluent Release Report 2007
Liquid Effluents - Batch Releases

Isotope (Ci)	October	November	December	Total
Ag-110m	1.274E-004	1.910E-005	0.000E+000	1.465E-004
Alpha	0.000E+000	0.000E+000	0.000E+000	0.000E+000
Co-58	1.493E-004	1.525E-005	9.192E-006	1.738E-004
Co-60	5.527E-004	5.717E-005	1.040E-005	6.203E-004
Cs-136	0.000E+000	0.000E+000	0.000E+000	0.000E+000
Fe-55	1.157E-003	7.839E-004	1.870E-004	2.128E-003
Fe-59	0.000E+000	1.147E-005	0.000E+000	1.147E-005
H-3	6.284E+001	5.655E+001	4.657E+000	1.240E+002
Mn-54	8.742E-005	5.236E-006	0.000E+000	9.265E-005
Sb-125	0.000E+000	3.891E-005	4.795E-005	8.686E-005
Sr-89	0.000E+000	0.000E+000	0.000E+000	0.000E+000
Sr-90	0.000E+000	0.000E+000	0.000E+000	0.000E+000
Total	6.284E+001	5.655E+001	4.657E+000	1.240E+002

TABLE 3.3A
Annual Radioactive Effluent Release Report 2007
Liquid Effluents - Continuous Releases

	January	February	March	Total
Gross Radioactivity				
Total Release Excluding H3 and Dissolved Gases (Ci)	0.000E+000	0.000E+000	0.000E+000	0.000E+000
Avg. Conc. (μCi/ml)	0.000E+000	0.000E+000	0.000E+000	
Tritium				
Total Release (Ci)	0.000E+000	0.000E+000	0.000E+000	0.000E+000
Avg. Conc. (μCi/ml)	0.000E+000	0.000E+000	0.000E+000	
Dissolved Gases				
Total Release (Ci)	0.000E+000	0.000E+000	0.000E+000	0.000E+000
Avg. Conc. (μCi/ml)	0.000E+000	0.000E+000	0.000E+000	
Gross Alpha Activity				
Total Release (Ci)	0.000E+000	0.000E+000	0.000E+000	0.000E+000
Avg. Conc. (μCi/ml)	0.000E+000	0.000E+000	0.000E+000	
Volume of Waste Released				
(liters)	7.504E+006	5.566E+006	1.011E+007	2.318E+007
Volume of Dilution Water				
(liters)	4.473E+010	3.017E+010	3.167E+010	1.066E+011

TABLE 3.3A (Con't)
Annual Radioactive Effluent Release Report 2007
Liquid Effluents - Continuous Releases

Isotope (Ci)	January	February	March	Total
Alpha	0.000E+000	0.000E+000	0.000E+000	0.000E+000
Fe-55	0.000E+000	0.000E+000	0.000E+000	0.000E+000
H-3	0.000E+000	0.000E+000	0.000E+000	0.000E+000
Sr-89	0.000E+000	0.000E+000	0.000E+000	0.000E+000
Sr-90	0.000E+000	0.000E+000	0.000E+000	0.000E+000
Total	0.000E+000	0.000E+000	0.000E+000	0.000E+000

TABLE 3.3B
Annual Radioactive Effluent Release Report 2007
Liquid Effluents - Continuous Releases

	April	May	June	Total
Gross Radioactivity				
Total Release Excluding H3 and Dissolved Gases (Ci)	0.000E+000	0.000E+000	0.000E+000	0.000E+000
Avg. Conc. (μCi/ml)	0.000E+000	0.000E+000	0.000E+000	
Tritium				
Total Release (Ci)	0.000E+000	0.000E+000	0.000E+000	0.000E+000
Avg. Conc. (μCi/ml)	0.000E+000	0.000E+000	0.000E+000	
Dissolved Gases				
Total Release (Ci)	0.000E+000	0.000E+000	0.000E+000	0.000E+000
Avg. Conc. (μCi/ml)	0.000E+000	0.000E+000	0.000E+000	
Gross Alpha Activity				
Total Release (Ci)	0.000E+000	0.000E+000	0.000E+000	0.000E+000
Avg. Conc. (μCi/ml)	0.000E+000	0.000E+000	0.000E+000	
Volume of Waste Released				
(liters)	6.546E+006	5.498E+006	6.120E+006	1.816E+007
Volume of Dilution Water				
(liters)	7.815E+010	6.656E+010	6.124E+010	2.060E+011

TABLE 3.3B (Con't)
Annual Radioactive Effluent Release Report 2007
Liquid Effluents - Continuous Releases

Isotope (Ci)	April	May	June	Total
Alpha	0.000E+000	0.000E+000	0.000E+000	0.000E+000
Fe-55	0.000E+000	0.000E+000	0.000E+000	0.000E+000
H-3	0.000E+000	0.000E+000	0.000E+000	0.000E+000
Sr-89	0.000E+000	0.000E+000	0.000E+000	0.000E+000
Sr-90	0.000E+000	0.000E+000	0.000E+000	0.000E+000
Total	0.000E+000	0.000E+000	0.000E+000	0.000E+000

TABLE 3.3C
Annual Radioactive Effluent Release Report 2007
Liquid Effluents - Continuous Releases

	July	August	September	Total
Gross Radioactivity				
Total Release Excluding H3 and Dissolved Gases (Ci)	0.000E+000	0.000E+000	0.000E+000	0.000E+000
Avg. Conc. (μCi/ml)	0.000E+000	0.000E+000	0.000E+000	
Tritium				
Total Release (Ci)	0.000E+000	0.000E+000	0.000E+000	0.000E+000
Avg. Conc. (μCi/ml)	0.000E+000	0.000E+000	0.000E+000	
Dissolved Gases				
Total Release (Ci)	0.000E+000	0.000E+000	0.000E+000	0.000E+000
Avg. Conc. (μCi/ml)	0.000E+000	0.000E+000	0.000E+000	
Gross Alpha Activity				
Total Release (Ci)	0.000E+000	0.000E+000	0.000E+000	0.000E+000
Avg. Conc. (μCi/ml)	0.000E+000	0.000E+000	0.000E+000	
Volume of Waste Released				
(liters)	8.329E+006	5.998E+006	4.288E+006	1.861E+007
Volume of Dilution Water				
(liters)	7.628E+010	6.132E+010	6.078E+010	1.984E+011

TABLE 3.3C (Con't)
Annual Radioactive Effluent Release Report 2007
Liquid Effluents - Continuous Releases

Isotope (Ci)	July	August	September	Total
Alpha	0.000E+000	0.000E+000	0.000E+000	0.000E+000
Fe-55	0.000E+000	0.000E+000	0.000E+000	0.000E+000
H-3	0.000E+000	0.000E+000	0.000E+000	0.000E+000
Sr-89	0.000E+000	0.000E+000	0.000E+000	0.000E+000
Sr-90	0.000E+000	0.000E+000	0.000E+000	0.000E+000
Total	0.000E+000	0.000E+000	0.000E+000	0.000E+000

TABLE 3.3D
Annual Radioactive Effluent Release Report 2007
Liquid Effluents - Continuous Releases

	October	November	December	Total
Gross Radioactivity				
Total Release Excluding H3 and Dissolved Gases (Ci)	0.000E+000	0.000E+000	0.000E+000	0.000E+000
Avg. Conc. (μCi/ml)	0.000E+000	0.000E+000	0.000E+000	
Tritium				
Total Release (Ci)	0.000E+000	0.000E+000	0.000E+000	0.000E+000
Avg. Conc. (μCi/ml)	0.000E+000	0.000E+000	0.000E+000	
Dissolved Gases				
Total Release (Ci)	0.000E+000	0.000E+000	0.000E+000	0.000E+000
Avg. Conc. (μCi/ml)	0.000E+000	0.000E+000	0.000E+000	
Gross Alpha Activity				
Total Release (Ci)	0.000E+000	0.000E+000	0.000E+000	0.000E+000
Avg. Conc. (μCi/ml)	0.000E+000	0.000E+000	0.000E+000	
Volume of Waste Released				
(liters)	7.994E+006	5.338E+006	6.739E+006	2.007E+007
Volume of Dilution Water				
(liters)	7.723E+010	6.124E+010	4.567E+010	1.841E+011

TABLE 3.3D (Con't)
Annual Radioactive Effluent Release Report 2007
Liquid Effluents - Continuous Releases

Isotope (Ci)	October	November	December	Total
Alpha	0.000E+000	0.000E+000	0.000E+000	0.000E+000
Fe-55	0.000E+000	0.000E+000	0.000E+000	0.000E+000
H-3	0.000E+000	0.000E+000	0.000E+000	0.000E+000
Sr-89	0.000E+000	0.000E+000	0.000E+000	0.000E+000
Sr-90	0.000E+000	0.000E+000	0.000E+000	0.000E+000
Total	0.000E+000	0.000E+000	0.000E+000	0.000E+000

Table 3.4
Annual Radioactive Effluent Report 2007
Dose From Liquid Effluents

The dose to a member of the public from total liquid radioactive releases for each quarter was below the ODCM limits of 1.5 mrems to the total body and less than or equal to 5 mrems to any organ. Additionally, the dose to a member of the public from total liquid radioactive releases for the year was below the ODCM limits of 3 mrems to the total body and less than or equal to 10 mrems to any organ.

Instantaneous release concentrations are limited by the individual radionuclide concentrations established in 10 CFR 20, Appendix B, for unrestricted areas. During the report period, none of the isotopes released exceed the concentrations specified in Appendix B. The following offsite doses were calculated using equation 1.5 from the Kewaunee ODCM.

Organ 1st Qtr Dose	Dose Total mRem	Quarterly Limit mRem	Percent of Limit
Total Body	2.865E-004	1.5	1.910E-02
Bone	7.026E-006	5.0	1.405E-04
Liver	2.903E-004	5.0	5.805E-03
Thyroid	2.792E-004	5.0	5.584E-03
Kidney	2.804E-004	5.0	5.607E-03
Lung	2.819E-004	5.0	5.638E-03
GI-LLI	3.440E-004	5.0	6.880E-03

Organ 2nd Qtr Dose	Dose Total mRem	Quarterly Limit mRem	Percent of Limit
Total Body	7.377E-004	1.5	4.918E-02
Bone	2.501E-005	5.0	5.001E-04
Liver	7.506E-004	5.0	1.501E-02
Thyroid	7.332E-004	5.0	1.466E-02
Kidney	7.332E-004	5.0	1.466E-02
Lung	7.428E-004	5.0	1.486E-02
GI-LLI	7.481E-004	5.0	1.496E-02

Table 3.4 (Con't)
Annual Radioactive Effluent Report 2007
Dose From Liquid Effluents

Organ 3rd Qtr Dose	Dose Total mRem	Quarterly Limit mRem	Percent of Limit
Total Body	4.763E-005	1.5	3.175E-03
Bone	1.455E-005	5.0	2.910E-04
Liver	5.547E-005	5.0	1.109E-03
Thyroid	4.166E-005	5.0	8.332E-04
Kidney	4.236E-005	5.0	8.472E-04
Lung	4.726E-005	5.0	9.453E-04
GI-LLI	8.281E-005	5.0	1.656E-03

Organ 4th Qtr Dose	Dose Total mRem	Quarterly Limit mRem	Percent of Limit
Total Body	4.740E-004	1.5	3.160E-02
Bone	1.700E-005	5.0	3.400E-04
Liver	4.845E-004	5.0	9.690E-03
Thyroid	4.656E-004	5.0	9.312E-03
Kidney	4.671E-004	5.0	9.341E-03
Lung	4.722E-004	5.0	9.445E-03
GI-LLI	5.284E-004	5.0	1.057E-02

Calculated Dose This Year

Organ	Dose Total mRem	Quarterly Limit mRem	Percent of Limit
Total Body	1.302E-003	3.0	4.341E-02
Bone	1.578E-004	10.0	1.578E-03
Liver	1.404E-003	10.0	1.404E-02
Thyroid	1.169E-003	10.0	1.169E-02
Kidney	1.224E-003	10.0	1.224E-02
Lung	1.228E-003	10.0	1.228E-02
GI-LLI	1.783E-003	10.0	1.783E-02

4.0 UNPLANNED RELEASES

No unplanned releases were made from the Kewaunee Plant during the report period.

5.0 METEOROLOGICAL DATA

See Appendix A for missing meteorological data and the joint frequency distribution tables.

6.0 SOLID WASTE DISPOSAL

Table 6.1 is a summation of solid wastes shipped during 2007. Presented are the types of wastes, major nuclide composition, disposition of the wastes. Table 6.1 contains the radionuclide content (curies) and percent abundance for each type of waste.

Table 6.1
Annual Radioactive Effluent Report 2007
Solid Waste and Irradiated Fuel Shipments

A. SOLID WASTE SHIPPED OFFSITE FOR BURIAL OR DISPOSAL

1. Type of Waste

	Ci	M^3
a. Resin	7.96E+01	1.07E+01
b. Dewatered Cloth Filters	3.83E+00	3.41E+00
c. DAW (compactible)	9.67E-02	3.08E+01
d. DAW (noncompactible)	5.13E-02	1.27E+02

Average Transuranics shipped (all shipments): 2.09E+00 nCi/g

2. Estimate of Major Nuclide by Composition

a. Resin

Nuclide	%	Ci
Mn54	2.95E-02	2.35E+00
Co57	1.14E-03	9.08E-02
Co58	1.22E-02	9.68E-01
Co60	1.56E-01	1.25E+01
Ag110m	1.39E-03	1.11E-01
Cs137	4.70E-03	3.75E-01
Sb125	1.43E-02	1.14E+00
Fe55	1.26E-01	1.01E+01
C14	7.80E-04	6.21E-02
Ni59	7.59E-03	6.04E-01
Nb94	9.97E-05	7.94E-03
TRU	1.35E-03	1.08E-01
Pu238	4.52E-07	3.60E-05
Pu241	1.35E-03	1.07E-01
Am241	1.64E-06	1.30E-04
Ni63	6.41E-01	5.10E+01
Sr90	6.04E-05	4.81E-03
Cm243	6.41E-07	5.11E-05
Pu239	4.52E-07	3.60E-05
Ce144	3.33E-03	2.65E-01

b. Dewatered Cloth Filters

Nuclide	%	Ci
Cr51	7.91E-09	3.03E-08
Mn54	2.52E-02	9.64E-02
Co58	1.18E-03	4.53E-03
Co60	1.99E-01	7.62E-01
Zr95	1.30E-05	4.98E-05
Nb95	4.83E-07	1.85E-06
Ag110m	5.33E-03	2.04E-02
Cs137	8.65E-05	3.31E-04
Sb125	1.10E-02	4.22E-02
Fe55	3.34E-01	1.28E+00
Fe59	1.48E-07	5.68E-07
C14	3.24E-05	1.24E-04
Tc99	2.72E-03	1.04E-02
TRU	3.91E-06	1.50E-05
Pu238	3.13E-06	1.20E-05
Am241	7.78E-07	2.98E-06
H3	1.47E-04	5.63E-04
Ni63	4.21E-01	1.61E+00
Zn65	2.35E-04	8.99E-04
U238	7.57E-07	2.90E-06
U233	1.20E-06	4.60E-06
Ce144	1.63E-04	6.25E-04

c. DAW (compactible)

Nuclide	%	Ci
Cr51	1.10E-03	1.06E-04
Mn54	3.33E-02	3.22E-03
Co57	8.59E-04	8.31E-05
Co58	1.65E-01	1.60E-02
Co60	1.14E-01	1.10E-02
Zr95	2.11E-03	2.04E-04
Nb95	2.45E-03	2.37E-04
Ag110m	5.04E-02	4.87E-03
Cs137	3.96E-03	3.83E-04
Sb125	8.29E-03	8.01E-04
Fe55	4.12E-01	3.99E-02
Fe59	3.48E-04	3.36E-05
C14	7.97E-03	7.71E-04
Tc99	9.24E-03	8.94E-04
TRU	2.83E-05	2.74E-06
Pu238	2.14E-05	2.07E-06
H3	7.74E-03	7.48E-04
Ni63	1.75E-01	1.69E-02
Zn65	1.74E-03	1.68E-04
Pu239	6.86E-06	6.63E-07
Ce144	5.19E-03	5.02E-04

d. DAW (noncompactible)

Nuclide	%	Ci
Cr51	1.65E-02	8.46E-04
Mn54	2.39E-02	1.23E-03
Co57	6.85E-04	3.51E-05
Co58	5.89E-01	3.02E-02
Co60	4.20E-02	2.16E-03
Zr95	8.65E-03	4.43E-04
Nb95	2.45E-02	1.26E-03
Ag110m	4.29E-02	2.20E-03
Cs137	1.30E-03	6.66E-05
Sb125	3.49E-03	1.79E-04
Fe55	1.74E-01	8.95E-03
Fe59	2.38E-03	1.22E-04
C14	2.54E-03	1.30E-04
Tc99	2.94E-03	1.51E-04
TRU	9.08E-06	4.66E-07
Pu238	6.90E-06	3.54E-07
H3	2.63E-03	1.35E-04
Ni63	5.61E-02	2.88E-03
Zn65	1.51E-03	7.73E-05
Pu239	2.19E-06	1.12E-07
Ce144	4.00E-03	2.05E-04

3. Solid Waste Disposition

DATE OF SHIPMENT	MODE OF TRANSPORTATION	DESTINATION
03/08/07	Hittman Transport	Studsvik Processing Facility, LLC Erwin, TN
03/28/07	Hittman Transport	Studsvik Processing Facility, LLC Erwin, TN
05/14/07	Hittman Transport	Studsvik Processing Facility, LLC Erwin, TN
06/07/07	Hittman Transport	Studsvik Processing Facility, LLC Erwin, TN
06/20/07	Hittman Transport	Duratek Services, Inc. Oak Ridge, TN
07/25/07	Hittman Transport	Duratek Services, Inc. Oak Ridge, TN
09/12/07	Hittman Transport	Envirocare of Utah, Inc. Clive, UT
12/11/07	Hittman Transport	Clive Disposal Facility Clive, UT

B. IRRADIATED FUEL SHIPMENTS

No irradiated fuel shipments were made from the Kewaunee Nuclear Power Plant during 2007.

7.0 PROGRAM REVISIONS

In accordance with Technical Specifications 6.18.b.3 and 6.19.a, the revisions to the Process Control Program, Offsite Dose Calculation Manual and radioactive waste treatment systems are listed below.

7.1 Offsite Dose Calculation Manual

The Offsite Dose Calculation Manual (ODCM) has not been revised during this report period.

7.2 Major Changes to the Radioactive Liquid, Gaseous and Solid Waste Treatment Systems

Major changes to the radioactive liquid, gaseous or solid waste systems are submitted in the annual Updated Final Safety Analysis Report consistent with Technical Specification 6.19.

8.0 REPORTABLE OCCURRENCES

None.

Appendix A

Kewaunee Power Station

2007 Meteorological Data

Missing Data

First Quarter: 16.25 hours
Second Quarter: 35.75 hours
Third Quarter: 699.0 hours
Fourth Quarter: 166.25 hours

Note: A total of 917.25 hours of data is missing or otherwise unavailable. This represents the availability of 89.529% of the data for the year.

FIRST QUARTER 2007
Total Hours Missing = 16.25 Total Hours = 2160

Stability Class A

Wind Direction

	CALM	1-3	4-7	8-12	13-18	19-24	>24	TOTAL
N	0	0	3.5	41.25	24.75	0	0	69.5
NNE	0	0	0.25	29	25.25	15	0.5	70
NE	0	0	4	26.75	7.75	0	0	38.5
ENE	0	0	2.75	5.25	9.25	0	0.25	17.5
E	0	0	4.5	2.25	19.75	19.25	2.25	48
ESE	0	0	3	12.75	19.25	1	0	36
SE	0	0	0.25	1.75	6.25	0	0	8.25
SSE	0	0	0.5	1.25	5.5	8.5	4.25	20
S	0	0	5.25	37.25	24	1.25	0.75	68.5
SSW	0	1.25	17.75	25.75	4.25	0	0	49
SW	0	1	4.25	26.5	18.5	0	0	50.25
WSW	0	0.25	8	28.5	5.75	0	0	42.5
W	0	0.25	9.5	69	40	0.25	0	119
WNW	0	0.5	10.5	31.25	23	4.25	0	69.5
NW	0	0.5	16	24	23.25	3.25	0	67
NNW	0	0	12.75	36.75	24.25	0	0	73.75
TOTAL	0	3.75	102.75	399.25	280.75	52.75	8	847.25

Stability Class B

Wind Direction

	CALM	1-3	4-7	8-12	13-18	19-24	>24	TOTAL
N	0	0	0	2.75	1	0	0	3.75
NNE	0	0	0	0.25	5.5	2.75	0	8.5
NE	0	0	0.25	1	0.5	0	0	1.75
ENE	0	0	0.25	1.5	0.25	0	0	2
E	0	0	0	1	0.25	0.5	0	1.75
ESE	0	0	1.25	1.5	0	0	0	2.75
SE	0	0	0	0	0	0	0	0
SSE	0	0	0	0.25	0.5	0	0	0.75
S	0	0	2	2.25	0	0	0	4.25
SSW	0	0	3.5	4.5	1.25	0	0	9.25
SW	0	0	0	2.25	2.25	0	0	4.5
WSW	0	0.25	2	5.75	2.5	0	0	10.5
W	0	0	3.5	14	10.5	0.5	0	28.5
WNW	0	0	0.75	3	0	0	0	3.75
NW	0	0	1.5	7.25	3	0	0	11.75
NNW	0	0	2.75	2.75	2	0	0	7.5
TOTAL	0	0.25	17.75	50	29.5	3.75	0	101.25

Stability Class C

Wind Direction

	CALM	1-3	4-7	8-12	13-18	19-24	>24	TOTAL
N	0	0	0.5	6	0.5	0	0	7
NNE	0	0	0	0.5	1	1	0	2.5
NE	0	0	0.25	1	0	0	0	1.25
ENE	0	0	0	0	0.75	0	0	0.75
E	0	0	0.5	1.75	0.25	0	0	2.5
ESE	0	0.25	0.5	1	0	0	0	1.75
SE	0	0	0	0.25	0	0	0	0.25
SSE	0	0	0	0	0.75	0	0	0.75
S	0	0	2	2.75	0	0	0	4.75
SSW	0	0	1.75	4.25	1	0	0	7
SW	0	0.25	0.5	3	1.5	0	0	5.25
WSW	0	0	0.25	7.5	1.5	0	0	9.25
W	0	0	3.75	22	8.25	0.5	0	34.5
WNW	0	0	0.5	5	0	0	0	5.5
NW	0	0.5	2.75	5.5	4.5	0	0	13.25
NNW	0	0	1.75	3.5	6	0	0	11.25
TOTAL	0	1	15	64	26	1.5	0	107.5

Stability Class D

Wind Direction

	CALM	1-3	4-7	8-12	13-18	19-24	>24	TOTAL
N	0	0.5	3.25	2.25	1	0	0	7
NNE	0	0	2.5	5	6.75	1	0	15.25
NE	0	0	0.75	2.75	0	0	0	3.5
ENE	0	0.5	0.5	1.5	0.75	0	0	3.25
E	0	0.5	2	0	0.75	0	0	3.25
ESE	0	0	4.75	0	0	0.25	0.5	5.5
SE	0	0	0	0.75	0	0.5	0	1.25
SSE	0	0.25	1.25	0.25	3	0	0	4.75
S	0	0.5	7.75	8.75	1	0	0	18
SSW	0	1	9.5	17.5	0.5	0	0	28.5
SW	0	0	8.5	7.25	4.25	0	0	20
WSW	0	0.25	3	13.5	5.5	0	0	22.25
W	0	0	21.5	30.75	29.25	0.25	0	81.75
WNW	0	0.25	8.75	16.75	0.75	0	0	26.5
NW	0	1.25	10.75	13.75	8.75	0	0	34.5
NNW	0	0.5	11.25	14.5	3.75	0	0	30
TOTAL	0	5.5	96	135.25	66	2	0.5	305.25

Stability Class E

Wind Direction

	CALM	1-3	4-7	8-12	13-18	19-24	>24	TOTAL
N	0	0.5	3.75	2	1	0	0	7.25
NNE	0	0	2.75	5.75	0.5	0	0	9
NE	0	0	5.5	4.5	0	0	0	10
ENE	0	1.25	3	5.25	0	0	0	9.5
E	0	0.75	2	0	0	0	0	2.75
ESE	0	1	2.75	0	0	0	0	3.75
SE	0	0	4.25	0.25	0.25	0	0	4.75
SSE	0	1	3.5	1.5	5	0	0	11
S	0	0.25	19	7	0	0	0	26.25
SSW	0	2	21	15.75	0	0	0	38.75
SW	0	2.5	17	9.75	7.25	0	0	36.5
WSW	0	1	20	18.5	11	0	0	50.5
W	0	1.25	23.75	54.25	9.75	0	0	89
WNW	0	0.5	14.75	32	1	0	0	48.25
NW	0	2	21.25	27.25	2.25	0	0	52.75
NNW	0	1.75	22.25	12.25	3	0	0	39.25
TOTAL	0	15.75	186.5	196	41	0	0	439.25

Stability Class F

Wind Direction

	CALM	1-3	4-7	8-12	13-18	19-24	>24	TOTAL
N	0	0	0.25	0	0	0	0	0.25
NNE	0	0	0.25	0	0	0	0	0.25
NE	0	0.75	1.5	2.75	0	0	0	5
ENE	0	0.25	0.25	1.5	0	0	0	2
E	0	0	0.75	0.75	0	0	0	1.5
ESE	0	0	1.75	0	0	0	0	1.75
SE	0	0.25	1.25	0	0	0	0	1.5
SSE	0	0.25	3.25	3	1.75	0	0	8.25
S	0	0.75	9.75	6.25	1	0	0	17.75
SSW	0	0.25	21	3.25	0	0	0	24.5
SW	0	0.75	15.5	2.5	3.25	0	0	22
WSW	0	0.25	17.5	3.5	4	0	0	25.25
W	0	1.25	15.25	7.75	0	0	0	24.25
WNW	0	0	6	13.5	0	0	0	19.5
NW	0	0	10.75	2.5	0	0	0	13.25
NNW	0	1	9.5	4.25	0	0	0	14.75
TOTAL	0	5.75	114.5	51.5	10	0	0	181.75

Stability Class G

Wind Direction

	CALM	1-3	4-7	8-12	13-18	19-24	>24	TOTAL
N	0	1	0.25	0.25	0	0	0	1.5
NNE	0	1	0.5	0.25	0	0	0	1.75
NE	0	0.25	4.75	3	0	0	0	8
ENE	0	0.75	0.75	1	0	0	0	2.5
E	0	1	2	1	0	0	0	4
ESE	0	0.25	1	0	0	0	0	1.25
SE	0	0.25	1	0	0	0	0	1.25
SSE	0	0.75	2.75	3.75	0.75	0	0.25	8.25
S	0	4.25	5	2.25	0	0	0	11.5
SSW	0	2.5	16	3	0.25	0	0	21.75
SW	0	1.25	8.5	2.5	0.5	0	0	12.75
WSW	0	0	15	10.5	2.25	0	0	27.75
W	0	0	8.5	20	0	0	0	28.5
WNW	0	1.25	4.5	3.25	0	0	0	9
NW	0	3	12.5	3.25	0	0	0	18.75
NNW	0	1	2	0	0	0	0	3
TOTAL	0	18.5	85	54	3.75	0	0.25	161.5

2nd QUARTER 2007
Total Hours Missing = 35.75 Total Hours = 2184

Stability Class A

Wind Direction

	CALM	1-3	4-7	8-12	13-18	19-24	>24	TOTAL
N	0	0.25	2	7.25	4.25	0	0	13.75
NNE	0	0	1.75	35.5	44.75	1	0	83
NE	0	0.25	5	10.5	0.75	5.75	0	22.25
ENE	0	0.25	2.5	2.5	3.25	3	0	11.5
E	0	0.5	8.75	8	7.25	2.25	0.5	27.25
ESE	0	0.5	7	6.25	0	0	0	13.75
SE	0	0	5.75	0.5	0	0	0	6.25
SSE	0	0	3	1.5	1.5	0	0	6
S	0	0.25	3.75	4.25	2.5	0	0	10.75
SSW	0	0	4	8.25	0.75	0	0	13
SW	0	0.25	1.25	3.5	0.25	1.5	0	6.75
WSW	0	0	0.5	1.75	0	0	0	2.25
W	0	0.5	0.5	1.75	7.5	1.25	0	11.5
WNW	0	0	0.75	9.25	11.75	6.25	0	28
NW	0	1	3.75	15	23.75	7.75	0	51.25
NNW	0	0.25	2.75	18	17	2.5	0	40.5
TOTAL	0	4	53	133.75	125.25	31.25	0.5	347.75

Stability Class B

Wind Direction

	CALM	1-3	4-7	8-12	13-18	19-24	>24	TOTAL
N	0	0	0	2	1	0	0	3
NNE	0	0	0	4.5	6.25	0	0	10.75
NE	0	0	0.5	1.5	0	0	0	2
ENE	0	0	1	0.5	0.25	0	0	1.75
E	0	0.25	1.25	0	0	0	0	1.5
ESE	0	0	1	0	0	0	0	1
SE	0	0.25	1.25	0	0	0	0	1.5
SSE	0	0	1.25	0	0.5	0	0	1.75
S	0	0	0.25	3.25	0.25	0	0	3.75
SSW	0	0.25	0.25	2.25	0	0	0	2.75
SW	0	0	1.25	0.25	0	0	0	1.5
WSW	0	0	0.25	0.5	2.5	0	0	3.25
W	0	0	0	0.25	3	0	0	3.25
WNW	0	0	0.5	0	1.75	0	0	2.25
NW	0	0	0.75	0.25	0.25	0	0	1.25
NNW	0	0.25	0.75	6.75	1	0	0	8.75
TOTAL	0	1	10.25	22	16.75	0	0	50

Stability Class C

Wind Direction

	CALM	1-3	4-7	8-12	13-18	19-24	>24	TOTAL
N	0	0	1.5	5.75	0	0	0	7.25
NNE	0	0	0.5	8.75	2.75	0	0	12
NE	0	0	2.75	3	0	0	0	5.75
ENE	0	0.25	0.25	0	0	0	0	0.5
E	0	0.25	2.75	0	0	0	0	3
ESE	0	0	0.5	0	0	0	0	0.5
SE	0	0.5	1.5	0.5	0	0	0	2.5
SSE	0	0.25	1.75	0	1.5	0	0	3.5
S	0	0	0.25	3.5	1.25	0	0	5
SSW	0	0.25	0	2	0	0	0	2.25
SW	0	0	0.25	0	2	0.25	0	2.5
WSW	0	0	0.75	0.25	1.5	0	0	2.5
W	0	0	0	0.5	3.75	0	0	4.25
WNW	0	0	0.5	1.25	1.75	0	0	3.5
NW	0	0.25	0.75	1.25	3.25	0	0	5.5
NNW	0	0	1.5	5.25	5.25	0	0	12
TOTAL	0	1.75	15.5	32	23	0.25	0	72.5

Stability Class D

Wind Direction

	CALM	1-3	4-7	8-12	13-18	19-24	>24	TOTAL
N	0	0.5	2.5	7.25	1.5	0	0	11.75
NNE	0	0.25	7.25	30.25	16	0	0	53.75
NE	0	0.75	8	11	0	0	0	19.75
ENE	0	0.5	4.25	6.5	0	0	0	11.25
E	0	1.75	5.75	1	0	0	0	8.5
ESE	0	0.5	9	0.25	0.25	0	0	10
SE	0	3	5.75	0.25	0.25	0	0	9.25
SSE	0	1.25	10.25	2.5	4	0	0	18
S	0	0.75	5	15.5	8.5	0.25	0	30
SSW	0	1	5	9.75	0	0	0	15.75
SW	0	0.25	3.25	2.25	5.5	0	0	11.25
WSW	0	0	1.75	7.75	1.25	0	0	10.75
W	0	0	2	10	12.75	0.25	0	25
WNW	0	0.25	3.5	3.25	0.25	0	0	7.25
NW	0	0.25	1	4	10.25	0	0	15.5
NNW	0	0.5	2.75	4.5	1.25	0	0	9
TOTAL	0	11.5	77	116	61.75	0.5	0	266.75

Stability Class E

Wind Direction

	CALM	1-3	4-7	8-12	13-18	19-24	>24	TOTAL
N	0	0.75	11.75	8.75	0.25	0	0	21.5
NNE	0	1.25	19.75	26.25	15	1.25	0	63.5
NE	0	2.5	20.5	13.5	0	0	0	36.5
ENE	0	2.5	13.5	4	0	0	0	20
E	0	3.75	11.25	0.25	0	0	0	15.25
ESE	0	1.5	15.5	2.5	0	0	0	19.5
SE	0	3	10.75	1.5	0	0	0	15.25
SSE	0	2	19.25	9.5	9.5	0.75	0	41
S	0	1	26	27.5	9	0.5	0	64
SSW	0	2.5	13	9.75	0	0	0	25.25
SW	0	0.5	9	3.25	4	0	0	16.75
WSW	0	0.5	4.5	9.25	1	0	0	15.25
W	0	1.25	10.25	11.75	3	0	0	26.25
WNW	0	1.25	8	3.5	0	0	0	12.75
NW	0	3	6.5	2.25	0.75	0	0	12.5
NNW	0	1	8.25	6.25	1.25	0	0	16.75
TOTAL	0	28.25	207.75	139.75	43.75	2.5	0	422

Stability Class F

Wind Direction

	CALM	1-3	4-7	8-12	13-18	19-24	>24	TOTAL
N	0	2.5	6.25	0.5	0	0	0	9.25
NNE	0	2	6.5	5	0	0	0	13.5
NE	0	6.75	18	3	0	0	0	27.75
ENE	0	1.5	9	1	0.25	0	0	11.75
E	0	4	12.25	3	0	0	0	19.25
ESE	0	4	7.25	0.5	0	0	0	11.75
SE	0	0.25	11.25	0.25	0	0	0	11.75
SSE	0	3.25	13	5	3.25	1.75	0	26.25
S	0	3.75	28.75	27.75	0.5	0	0	60.75
SSW	0	2.5	14.25	5.5	0	0	0	22.25
SW	0	3.75	5.25	3.25	0	0	0	12.25
WSW	0	2.5	4	1.25	0	0	0	7.75
W	0	0.75	6	2.25	0	0	0	9
WNW	0	1.5	4.75	0	0	0	0	6.25
NW	0	1.75	3	1.75	0	0	0	6.5
NNW	0	3.5	5.5	1.75	0.25	0	0	11
TOTAL	0	44.25	155	61.75	4.25	1.75	0	267

Stability Class G

Wind Direction

	CALM	1-3	4-7	8-12	13-18	19-24	>24	TOTAL
N	0	7	3.25	0.25	0	0	0	10.5
NNE	0.25	7	3	1.75	0	0	0	12
NE	0	10	26.25	3	0	0	0	39.25
ENE	0	8	14.25	0.5	1	0	0	23.75
E	0	7.75	19	1	2	0	0	29.75
ESE	0.25	8	14.25	1.5	0.25	0	0	24.25
SE	0	8.5	32	4.5	0	0	0	45
SSE	0	15	77	69.5	11.25	0	0	172.75
S	1	17.75	71.5	37.5	2.5	0	0	130.25
SSW	0	19.25	30.5	1.25	0.5	0	0	51.5
SW	0	19	23.5	1.25	0	0	0	43.75
WSW	0	11.5	35.5	1.25	0	0	0	48.25
W	0	10.75	21.75	0	0	0	0	32.5
WNW	0	9.25	6	2	0	0	0	17.25
NW	0	8	10.75	3.75	0	0	0	22.5
NNW	0	8.25	10.5	0.25	0	0	0	19
TOTAL	1.5	175	399	129.25	17.5	0	0	722.25

3rd QUARTER 2007
Total Hours Missing = 699.0 Total Hours = 2208

Stability Class A

Wind Direction

	CALM	1-3	4-7	8-12	13-18	19-24	>24	TOTAL
N	2	2.5	3.75	3.25	0.75	0	0	12.25
NNE	0.75	0.75	1.75	4	0	0	0	7.25
NE	1	1	1.75	0.25	0	0	0	4
ENE	0.5	0.75	1.5	0	0	0	0	2.75
E	0.5	0.5	0.75	0.75	2.5	0	0	5
ESE	0.5	2.5	0.25	2	7.5	0	0	12.75
SE	0.25	2.5	2.25	8.5	0.5	0	0	14
SSE	0.75	1.5	4.5	8.25	0.75	0	0.25	16
S	0.75	3.5	3.25	23.5	5	0	0	36
SSW	0	1	3.75	1	0	0	0	5.75
SW	0	2	1	2.5	0.5	0	0	6
WSW	0.75	2.5	1.75	3.75	0.25	0	0	9
W	0.25	3.25	0.75	1.25	0	0	0	5.5
WNW	0.5	2.25	2.25	1.75	0	0	0	6.75
NW	0	3.5	6.5	1.25	0	0	0	11.25
NNW	2	1.75	10.75	1.5	1.5	0	0	17.5
TOTAL	10.5	31.75	46.5	63.5	19.25	0	0.25	171.75

Stability Class B

Wind Direction

	CALM	1-3	4-7	8-12	13-18	19-24	>24	TOTAL
N	0	0	0.75	0.75	0	0	0	1.5
NNE	0	0	0.5	0.75	0	0	0	1.25
NE	0	0.25	1.5	0	0	0	0	1.75
ENE	0.25	0	0.5	0	0	0	0	0.75
E	0	0	0.25	0	0	0	0	0.25
ESE	0.25	0.5	0	0	0	0	0	0.75
SE	0.25	1	0	0	0	0	0	1.25
SSE	0.25	1	0.25	0.25	0.75	0	0	2.5
S	0	1.75	1.5	2.5	1	0	0	6.75
SSW	0	2.75	0.75	2	0	0	0	5.5
SW	0	0	0.25	0	0.5	0	0	0.75
WSW	0.75	0.5	0.25	1.25	0	0	0	2.75
W	0	1.75	0	0.5	0	0	0	2.25
WNW	0.5	0	0.75	1	0	0	0	2.25
NW	0	0.5	0.5	0.75	0	0	0	1.75
NNW	0.5	0.25	0.25	0.25	0.25	0	0	1.5
TOTAL	2.75	10.25	8	10	2.5	0	0	33.5

Stability Class C

Wind Direction

	CALM	1-3	4-7	8-12	13-18	19-24	>24	TOTAL
N	0.25	0.75	1.25	1	0	0	0	3.25
NNE	0	0.5	2	1.25	0	0	0	3.75
NE	0	0.25	1.75	0.5	0	0	0	2.5
ENE	0	0	1.75	0	0	0	0	1.75
E	0	0.25	0.75	0.25	0	0	0	1.25
ESE	0.25	0	0.25	0	0	0	0	0.5
SE	0	1.5	0	1	0	0	0	2.5
SSE	0	1.25	0.5	0.25	0.25	0	0	2.25
S	0	1.5	3.75	4	0.75	0	0	10
SSW	0.25	0.5	0.5	0.75	0	0	0	2
SW	0.75	0	0.5	0	0.5	0	0	1.75
WSW	1.75	0.5	1	1.25	0.5	0	0	5
W	0.5	0.75	0.25	2	0	0	0	3.5
WNW	1	0.75	0.75	5	0	0	0	7.5
NW	0	0.75	1	2	0	0	0	3.75
NNW	0.25	0.5	0.75	0.5	0.25	0	0	2.25
TOTAL	5	9.75	16.75	19.75	2.25	0	0	53.5

Stability Class D

Wind Direction

	CALM	1-3	4-7	8-12	13-18	19-24	>24	TOTAL
N	0.75	0.25	1.5	2.75	2	0	0	7.25
NNE	0	3.75	6.25	11.75	2.25	0	0	24
NE	0	0.5	2.75	5.25	0	0	0	8.5
ENE	0	2.5	1.25	0.5	0	0	0	4.25
E	0	2.5	2.5	0	0.75	0	0	5.75
ESE	1	3.25	3	0.5	0	0	0	7.75
SE	2	3.25	2.25	1	0	0	0	8.5
SSE	1.5	5.5	7.75	3	4.75	0	0	22.5
S	1.25	2.75	6	9.75	2.25	0.75	0	22.75
SSW	1.5	0.5	1.5	5	0	0	0	8.5
SW	0.5	0.75	2.25	2.25	0.25	0	0	6
WSW	4.25	1.5	3.5	4.75	2.25	0	0	16.25
W	2.5	2	5.75	6.5	1.25	0	0	18
WNW	2	3.25	13	19	10.25	0	0	47.5
NW	0	2.75	6.5	2	0.5	0	0	11.75
NNW	1.25	0.25	4.75	2.25	0.25	0	0	8.75
TOTAL	18.5	35.25	70.5	76.25	26.75	0.75	0	228

Stability Class E

Wind Direction

	CALM	1-3	4-7	8-12	13-18	19-24	>24	TOTAL
N	0	1.75	3.25	3.25	0.75	0	0	9
NNE	0.25	2	6	3.25	0.25	0	0	11.75
NE	0.25	2.5	10.5	0.5	0	0	0	13.75
ENE	0.25	4.5	4.5	0	0	0	0	9.25
E	0.25	3.5	2	0.25	0	0	0	6
ESE	1.5	1.25	4	0	0	0	0	6.75
SE	4	4.5	3	1	0	0	0	12.5
SSE	2.75	7.25	6.5	8	8	0	0	32.5
S	2.5	8.75	31.25	32.25	2.5	0.5	0	77.75
SSW	1	7	12.75	4.5	0	0	0	25.25
SW	1.5	1.5	10	6	0	0	0	19
WSW	3.5	1.75	5	6	4	0	0	20.25
W	2.25	3.25	10	15.5	2.25	0	0	33.25
WNW	2	4	15.5	10.25	1.5	0	0	33.25
NW	2.25	2.25	2.75	0.25	0.25	0	0	7.75
NNW	1.5	1.25	9.5	0.5	0	0	0	12.75
TOTAL	25.75	57	136.5	91.5	19.5	0.5	0	330.75

Stability Class F

Wind Direction

	CALM	1-3	4-7	8-12	13-18	19-24	>24	TOTAL
N	0.25	2.25	4.25	0.5	0	0	0	7.25
NNE	0.5	2.5	0.5	0	0	0	0	3.5
NE	0	8.25	1.5	0	0	0	0	9.75
ENE	0.25	4	2.5	0	0	0	0	6.75
E	0.75	3	2.25	0	0	0	0	6
ESE	0	3.5	4.5	0	0	0	0	8
SE	0.5	4.5	9.5	0	0	0	0	14.5
SSE	2	8.25	14	7.25	0.5	0	0	32
S	2.25	12.25	26	13.25	0.25	0	0	54
SSW	1	5.75	17.5	0.5	0	0	0	24.75
SW	1.75	4.75	9	1.25	0	0	0	16.75
WSW	1.75	3.75	14.5	0.75	0.5	0	0	21.25
W	2.75	2.75	14.75	10.75	0.25	0	0	31.25
WNW	0.75	2.25	11.75	1.5	0	0	0	16.25
NW	0	2.75	4.25	0	0	0	0	7
NNW	0.5	5	5.5	0	0	0	0	11
TOTAL	15	75.5	142.25	35.75	1.5	0	0	270

Stability Class G

Wind Direction

	CALM	1-3	4-7	8-12	13-18	19-24	>24	TOTAL
N	0.25	2.75	1	0	0	0	0	4
NNE	0	2	0	0	0	0	0	2
NE	0	7	3.25	0	0	0	0	10.25
ENE	0.25	4.25	2.25	0	0	0	0	6.75
E	0	3	2	0	0	0	0	5
ESE	0.5	3.75	1.5	0	0	0	0	5.75
SE	2	7	7.5	0.25	0	0	0	16.75
SSE	1.75	20.25	31	31	3.5	0	0	87.5
S	0.5	29.75	31.5	19.75	0	0	0	81.5
SSW	2.25	18.25	16	0.25	0	0	0	36.75
SW	0.75	10.75	15.5	0.75	0	0	0	27.75
WSW	1	6	36.5	0.5	0	0	0	44
W	0	2.25	30.75	0.5	0	0	0	33.5
WNW	0.75	3	13	0	0	0	0	16.75
NW	5.5	7.5	13.25	0.25	0	0	0	26.5
NNW	1.5	9.75	5.5	0	0	0	0	16.75
TOTAL	17	137.25	210.5	53.25	3.5	0	0	421.5

4th QUARTER 2007
Total Hours Missing = 166.25 Total Hours = 2208

Stability Class A

Wind Direction

	CALM	1-3	4-7	8-12	13-18	19-24	>24	TOTAL
N	0	0	2.5	11.75	18.25	0	0	32.5
NNE	0	0	2.75	5.5	12	1.75	0	22
NE	0	0	7.75	3.75	0	0	0	11.5
ENE	0	0	4	12.75	5.75	0	0	22.5
E	0	0	7.5	12.5	9	0	0	29
ESE	0	0.25	10.25	14.75	5.75	2.25	4	37.25
SE	0	0.5	3.25	1.5	5.5	2.75	4.25	17.75
SSE	0	0	3	9	11.25	6.75	6.25	36.25
S	0	0	12.75	60.25	12.25	1.75	0.25	87.25
SSW	0	0.5	19.5	24.75	6	0.25	0.25	51.25
SW	0	0	8.5	18.75	26	12.75	3.25	69.25
WSW	0	0.25	11	13	16.75	3.5	0	44.5
W	0	1	22.75	26	30.5	3	0	83.25
WNW	0	1	21.75	30.5	21.25	2.75	0	77.25
NW	0	1.25	14	24	12.25	7.25	0	58.75
NNW	0	0	11.25	28.75	28	1.25	0	69.25
TOTAL	0	4.75	162.5	297.5	220.5	46	18.25	749.5

Stability Class B

Wind Direction

	CALM	1-3	4-7	8-12	13-18	19-24	>24	TOTAL
N	0	0	0	3.25	0	0	0	3.25
NNE	0	0	0	0.25	3	1	0	4.25
NE	0	0	0.5	0	0	0	0	0.5
ENE	0	0	0.5	0.25	0.5	0	0	1.25
E	0	0.5	1	1	0	0	0	2.5
ESE	0	0	0	0.5	0	0	0	0.5
SE	0	0	0	0.25	0	1	0	1.25
SSE	0	0	0.25	0.5	2.75	0.75	1	5.25
S	0	0	3.75	1.75	2.25	0.5	0.5	8.75
SSW	0	0	3.25	3.75	0	0.25	0	7.25
SW	0	0	1.75	7	3.75	0	0.75	13.25
WSW	0	0.5	3.5	1.5	1.5	0	0	7
W	0	0	5.75	4.75	5.5	0	0	16
WNW	0	0.25	2.75	5.25	6.25	0.75	0	15.25
NW	0	0	7.75	5	0.25	0	0	13
NNW	0	0	1.25	5.75	4	0	0	11
TOTAL	0	1.25	32	40.75	29.75	4.25	2.25	110.25

Stability Class C

Wind Direction

	CALM	1-3	4-7	8-12	13-18	19-24	>24	TOTAL
N	0	0.75	0.75	1.25	0.75	0	0	3.5
NNE	0	0	0	0	0	1.5	0	1.5
NE	0	0	1.25	2	0	0	0	3.25
ENE	0	0	1	0.75	0.5	0	0	2.25
E	0	0	1.25	0.25	0	0	0	1.5
ESE	0	0	0.25	0.25	0	0	0	0.5
SE	0	0	0	0.75	0.5	0.75	0	2
SSE	0	0	0	1.25	3.25	0.75	1	6.25
S	0	0	2.5	3.5	1.25	0.25	0	7.5
SSW	0	0.25	2.25	1.5	0.5	0	0	4.5
SW	0	0	0.75	5	3.75	0	0	9.5
WSW	0	0.25	1.75	5.25	1.25	0.5	0	9
W	0	0.25	6.5	8.25	2.75	0.25	0	18
WNW	0	0.25	3.25	4.75	5.25	0.25	0	13.75
NW	0	0.5	0.75	2.25	0.75	0	0	4.25
NNW	0	0	0.75	4.75	5.5	0	0	11
TOTAL	0	2.25	23	41.75	26	4.25	1	98.25

Stability Class D

Wind Direction

	CALM	1-3	4-7	8-12	13-18	19-24	>24	TOTAL
N	0	0.25	1.75	5.5	1	0	0	8.5
NNE	0	0.5	0.5	0.75	1.75	0.25	0	3.75
NE	0	0	0.5	2.5	0	0	0	3
ENE	0	0.5	0.5	3.5	7.25	0	0	11.75
E	0	0	1	1.5	0.5	0	0	3
ESE	0	0	1.5	2.5	4	0.5	0	8.5
SE	0	0	0	1.5	7	3.25	0	11.75
SSE	0	0.25	0.75	2.25	9.5	3.25	0.75	16.75
S	0	0	9.25	13.75	1.75	0	0	24.75
SSW	0	1.75	20.75	7.75	1.75	0	0	32
SW	0	2.5	20.5	14	9.75	0	0	46.75
WSW	0	1	8.5	13.5	2	0	0	25
W	0	0.5	12.25	27.5	10.5	0	0	50.75
WNW	0	0.75	10.5	19.25	10.5	0.25	0	41.25
NW	0	0.75	11.25	19.75	11	0.25	0	43
NNW	0	0.25	5	22	3	0	0	30.25
TOTAL	0	9	104.5	157.5	81.25	7.75	0.75	360.75

Stability Class E

Wind Direction

	CALM	1-3	4-7	8-12	13-18	19-24	>24	TOTAL
N	0	0.5	2.25	9	0	0	0	11.75
NNE	0	0.5	3.25	0	0	0	0	3.75
NE	0	0.25	1.25	0	0	0	0	1.5
ENE	0	0.5	0.25	0	0	0	0	0.75
E	0	0	0.25	0	0.75	0	0	1
ESE	0	0.25	0.25	0	0.5	1.75	0.75	3.5
SE	0	0	0	5.5	2	0	0	7.5
SSE	0	0	4	9.75	5	0	0	18.75
S	0	0.75	13.5	17.25	0.75	0	0	32.25
SSW	0	3	39.5	15.75	0	0	0	58.25
SW	0	2.75	18.25	11.75	1.75	0	0	34.5
WSW	0	0.75	18.25	13.25	0	0	0	32.25
W	0	0.5	12	20.5	0.75	0	0	33.75
WNW	0	2.25	13	17.75	0.25	0	0	33.25
NW	0	1.5	13.25	12	0	0	0	26.75
NNW	0	0.5	8.75	5.5	0	0	0	14.75
TOTAL	0	14	148	138	11.75	1.75	0.75	314.25

Stability Class F

Wind Direction

	CALM	1-3	4-7	8-12	13-18	19-24	>24	TOTAL
N	0	0.75	1.25	0	0	0	0	2
NNE	0	0	0	0	0	0	0	0
NE	0	0	0	0	0	0	0	0
ENE	0	0	0	0	0	0	0	0
E	0	0	0	0	0	0	0	0
ESE	0	0	0	0	0	0	0	0
SE	0	0.25	0	1	0	0	0	1.25
SSE	0	0.5	4	8.5	0	0	0	13
S	0	1.25	6.5	2.25	0	0	0	10
SSW	0	0.5	17	1.25	0	0	0	18.75
SW	0	0.75	13.25	3.25	2	0	0.25	19.5
WSW	0	2.75	18.75	1.75	0	0	0	23.25
W	0	0.75	36.25	2.75	0	0	0	39.75
WNW	0	1.5	11.5	0.5	0	0	0	13.5
NW	0	1	11	0.25	0	0	0	12.25
NNW	0	0.5	7.75	0.25	0	0	0	8.5
TOTAL	0	10.5	127.25	21.75	2	0	0.25	161.75

Stability Class G

Wind Direction

	CALM	1-3	4-7	8-12	13-18	19-24	>24	TOTAL
N	0	1	0	0	0	0	0	1
NNE	0	0.75	0	0	0	0.25	0	1
NE	0	0.75	0	0	0	0	0	0.75
ENE	0	1.75	0	0	0	0	0	1.75
E	0	2	0	0	0	0	0	2
ESE	0	1.25	0	0	0	0	0	1.25
SE	0	1	1.25	0	0	0	0	2.25
SSE	0	4.25	11.75	9.75	0	0	0	25.75
S	0	6.5	13	4.25	0	0	0	23.75
SSW	0	7.5	19	1	0	0	0	27.5
SW	0	5	12.75	0.5	0	0	0	18.25
WSW	0	7.25	29.25	0	0	0	0	36.5
W	0	4.25	54.25	4	0	0	0	62.5
WNW	0	4.25	19.5	0.5	0	0	0	24.25
NW	0	4.75	8.25	0	0	0	0	13
NNW	0	2.25	3.25	0	0	0	0	5.5
TOTAL	0	54.5	172.25	20	0	0.25	0	247