

May 13, 2008

LICENSEE: Southern Nuclear Operating Company, Inc.

FACILITY: Vogtle Electric Generating Plant, Units 1 and 2

SUBJECT: SUMMARY OF TELEPHONE CONFERENCE CALL HELD ON APRIL 17, 2008, BETWEEN THE U.S. NUCLEAR REGULATORY COMMISSION AND SOUTHERN NUCLEAR OPERATING COMPANY, INC., CONCERNING REQUEST FOR ADDITIONAL INFORMATION PERTAINING TO THE VOGTLE ELECTRIC GENERATING PLANT, UNITS 1 AND 2, LICENSE RENEWAL APPLICATION

The U.S. Nuclear Regulatory and representatives of Southern Nuclear Operating Company, Inc., held a telephone conference call on April 17, 2008, to discuss and clarify the staff's request for additional information (RAI) concerning the Vogtle Electric Generating Plant, Units 1 and 2, license renewal application. The telephone conference call was useful in clarifying the intent of the staff's RAIs.

Enclosure 1 provides a listing of the participants. Enclosure 2 contains a summary of the discussions and a listing of the RAIs discussed with the applicant, including a brief description on the status of the items.

The applicant had an opportunity to comment on this summary.

/RA/

Donnie J. Ashley, Sr. Project Manager
Projects Branch 1
Division of License Renewal
Office of Nuclear Reactor Regulation

Docket Nos. 50-424 and 50-425

Enclosures:
As stated

cc w/encls: See next page

May 13, 2008

LICENSEE: Southern Nuclear Operating Company, Inc.

FACILITY: Vogtle Electric Generating Plant, Units 1 and 2

SUBJECT: SUMMARY OF TELEPHONE CONFERENCE CALL HELD ON APRIL 17, 2008, BETWEEN THE U.S. NUCLEAR REGULATORY COMMISSION AND SOUTHERN NUCLEAR OPERATING COMPANY, INC., CONCERNING REQUEST FOR ADDITIONAL INFORMATION PERTAINING TO THE VOGTLE ELECTRIC GENERATING PLANT, UNITS 1 AND 2, LICENSE RENEWAL APPLICATION

The U.S. Nuclear Regulatory Commission and representatives of Southern Nuclear Operating Company, Inc., held a telephone conference call on April 17, 2008, to discuss and clarify the staff's request for additional information (RAI) concerning the Vogtle Electric Generating Plant, Units 1 and 2, license renewal application. The telephone conference call was useful in clarifying the intent of the staff's RAIs.

Enclosure 1 provides a listing of the participants. Enclosure 2 contains a summary of the discussions and a listing of the RAIs discussed with the applicant, including a brief description on the status of the items.

The applicant had an opportunity to comment on this summary.

/RA/

Donnie J. Ashley, Sr. Project Manager
Projects Branch 1
Division of License Renewal
Office of Nuclear Reactor Regulation

Docket Nos. 50-424 and 50-425

Enclosures:
As stated

cc w/encls: See next page

DISTRIBUTION: See next page

ADAMS Accession No.: **ML081290027**

OFFICE	LA:DLR	PM:RPB1:DLR	BC:RPB1:DLR
NAME	IKing	DAshley	LLund
DATE	5/ 9 /08	5/ 9 /08	5/ 13 /08

OFFICIAL RECORD COPY

**TELEPHONE CONFERENCE CALL
VOGTLE ELECTRIC GENERATING PLANT, UNITS 1 AND 2
LICENSE RENEWAL APPLICATION**

**LIST OF PARTICIPANTS
APRIL 17, 2008**

PARTICIPANTS

Donnie Ashley
Edward Smith
Chalmer Myer
Louis Bohn

AFFILIATIONS

U.S. Nuclear Regulatory Commission (NRC)
NRC
Southern Nuclear Operating Company, Inc
SNOC

SUMMARY OF TELEPHONE CONFERENCE
VOGTLE ELECTRIC GENERATING PLANT, UNITS 1 AND 2
LICENSE RENEWAL APPLICATION

APRIL 17, 2008

The U.S. Nuclear Regulatory Commission (NRC or the staff) and representatives of Southern Nuclear Operating Company, Inc., held a telephone conference call on April 17, 2008, to discuss and clarify the applicant's responses to previous requests for additional information (RAI) concerning the Vogtle Electric Generating Plant (VEGP), Units 1 and 2, license renewal application (LRA).

These questions are focused on the scoping and screening section of the LRA.

In RAI 2.3.3.20-4, we requested that the applicant provide additional information explaining which tank vents on the LRA drawings do or do not have the tank vent screen component that is listed as item 36 in LRA Table 2.3.3.20. The applicant's response stated that "...Since the vents for both tanks provide the same function, it is assumed that screen covers were installed on the diesel fuel day tank vents as well." We will accept this response by stating that there are screen vents on the diesel fuel day tanks - thereby committing the applicant to having an aging management review for them. If it turns out that there are no screens, then the applicant should advise us and we will modify the response.

In RAI 2.3.3.23-3, we requested that the applicant provide additional information to verify that the continuation of pipeline 097-2 from LRA drawings 1X4LD179-2 and 2X4LD179-2 had been made to the correct drawings and locations and to provide the drawings. The applicant stated that the pipeline continues to P&ID AX4DB124-2 and shows the point where the license renewal boundary ends at the Auxiliary Building to Radwaste Transfer Tunnel Boundary. The applicant further stated that 1X4LD179-2 and 2X4LD179-2 "...should have been revised to include the Auxiliary Building to Radwaste Transfer Tunnel Boundary for clarity." Since 1X4LD179-2 and 2X4LD179-2 were not revised to show the boundary and AX4DB124-2 was not provided for our review, we are unable to confirm that there are no new component types within the boundary for which the drawing was not provided. The applicant confirmed that there are no new component types within the boundary discussed.

In RAI 2.3.4.4, we requested additional information justifying the boundary locations for line 153-10" at HV5103. The applicant's response referred to 1302-153-10" and 1302-010-10". There is some confusion regarding which line is being referred to. We can find no 1302-153-10". According to drawing 1(2)X4LD161-1, the line from HV5103 is 1305-153-10". The applicant stated that 1302-153-10" was mislabeled and should have been 1305-153-10".

Letter to Southern Nuclear from D. Ashley, dated May 13, 2008

DISTRIBUTION:

SUBJECT: SUMMARY OF TELEPHONE CONFERENCE CALL HELD ON APRIL 17, 2008,
BETWEEN THE U.S. NUCLEAR REGULATORY COMMISSION AND
SOUTHERN NUCLEAR OPERATING COMPANY, INC., CONCERNING
REQUEST FOR ADDITIONAL INFORMATION PERTAINING TO THE VOGTLE
ELECTRIC GENERATING PLANT, UNITS 1 AND 2, LICENSE RENEWAL
APPLICATION

HARD COPY:

DLR RF

E-MAIL:

PUBLIC

SSmith (srs3)

SDuraiswamy

RidsNrrDlr

RidsNrrDlrRIra

RidsNrrDlrRIrb

RidsNrrDlrRIrc

RidsNrrDlrReba

RidsNrrDlrRebb

RidsNrrDciCvib

RidsNrrDciCpnb

RidsNrrDraAfpb

RidsNrrDeEmcb

RidsNrrDeEeeb

RidsNrrDssSrxb

RidsNrrDssSbpb

RidsNrrDssScvb

RidsOgcMailCenter

DAshley

JPLeous

SLingam

CJulian, RII

GMcCoy, RII

Vogtle Electric Generating Plant,
Units 1 and 2

cc:

Mr. Tom E. Tynan
Vice President - Vogtle
Vogtle Electric Generating Plant
7821 River Road
Waynesboro, GA 30830

Mr. N. J. Stringfellow
Manager, Licensing
Southern Nuclear Operating Company, Inc.
P.O. Box 1295
Birmingham, AL 35201-1295

Mr. Jeffrey T. Gasser
Executive Vice President
Southern Nuclear Operating Company, Inc.
P.O. Box 1295
Birmingham, AL 35201-1295

Mr. Steven M. Jackson
Senior Engineer - Power Supply
Municipal Electric Authority of Georgia
1470 Riveredge Parkway, NW
Atlanta, GA 30328-4684

Mr. Reece McAlister
Executive Secretary
Georgia Public Service Commission
244 Washington Street, SW
Atlanta, GA 30334

Mr. Harold Reheis, Director
Department of Natural Resources
205 Butler Street, SE, Suite 1252
Atlanta, GA 30334

Attorney General
Law Department
132 Judicial Building
Atlanta, GA 30334

Mr. Laurence Bergen
Oglethorpe Power Corporation
2100 East Exchange Place
P.O. Box 1349
Tucker, GA 30085-1349

Arthur H. Domby, Esquire
Troutman Sanders
Nations Bank Plaza
600 Peachtree Street, NE
Suite 5200
Atlanta, GA 30308-2216

Resident Inspector
Vogtle Plant
8805 River Road
Waynesboro, GA 30830

Office of the County Commissioner
Burke County Commission
Waynesboro, GA 30830

Mr. Stanford M. Blanton, Esq.
Balch & Bingham, LLP
P.O. Box 306
Birmingham, AL 35201

Ms. Moanica M. Caston
Vice President and General Counsel
Southern Nuclear Operating Company, Inc.
40 Inverness Center Parkway
P.O. Box 1295
Birmingham, AL 35201-1295

Chalmer R. Myer
Southern Nuclear Operating Company, Inc.
40 Inverness Center Parkway
P.O. Box 1295
Birmingham, AL 35201-1295