

PMBelCOL PEmails

From: Tanya Simms
Sent: Friday, May 09, 2008 9:48 AM
To: rgrumbir@gmail.com; alsterdis@tva.gov; erg-xl@cox.net; pshastings@duke-energy.com; Ray, Phillip M
Cc: Joseph Sebrosky; PMBelCOL PEmails
Subject: RAI Letter No. 009 Related SRP Section 9.5.1 for Bellefonte Units 3 and 4
Attachments: BEL-RAI-LTR-009.pdf

To All,

Attached is RAI Letter No. 009 related SRP Section 9.5.1 for Bellefonte Units 3 and 4.

Tanya Simms
Project Manager
New Reactor Licensing
U.S. Nuclear Regulatory Commission
11555 Rockville Pike
Rockville, Maryland 20852-2738
301-415-1387
tanya.simms@nrc.gov

Hearing Identifier: Bellefonte_COL_Public_EX
Email Number: 166

Mail Envelope Properties (C4A4C9A16294FB4CBA5A36312D05FFAC034F72BBA3)

Subject: RAI Letter No. 009 Related SRP Section 9.5.1 for Bellefonte Units 3 and 4
Sent Date: 5/9/2008 9:47:30 AM
Received Date: 5/9/2008 9:47:32 AM
From: Tanya Simms

Created By: Tanya.Simms@nrc.gov

Recipients:

"Joseph Sebrosky" <Joseph.Sebrosky@nrc.gov>
Tracking Status: None
"PMBelCOL PEmails" <PMBelCOL.PEmails@nrc.gov>
Tracking Status: None
"rgrumbir@gmail.com" <rgrumbir@gmail.com>
Tracking Status: None
"alsterdis@tva.gov" <alsterdis@tva.gov>
Tracking Status: None
"erg-xl@cox.net" <erg-xl@cox.net>
Tracking Status: None
"pshastings@duke-energy.com" <pshastings@duke-energy.com>
Tracking Status: None
"Ray, Phillip M" <pmray@tva.gov>
Tracking Status: None

Post Office: HQCLSTR02.nrc.gov

Files	Size	Date & Time
MESSAGE	358	5/9/2008 9:47:32 AM
BEL-RAI-LTR-009.pdf	90758	

Options

Priority: Standard
Return Notification: No
Reply Requested: Yes
Sensitivity: Normal
Expiration Date:
Recipients Received:

May 8, 2008

Ms. Andrea L. Sterdis
Manager, Nuclear Licensing & Industry Affairs
Nuclear Generation Development & Construction
Tennessee Valley Authority
1101 Market Street
Chattanooga, Tennessee 37402-2801

SUBJECT: REQUEST FOR ADDITIONAL INFORMATION LETTER NO. 009 RELATED TO
SRP SECTION 09.05.01 FOR THE BELLEFONTE UNITS 3 and 4 COMBINED
LICENSE APPLICATION

Dear Ms. Sterdis:

By letter dated September 30, 2007, as supplemented by letters dated November 2, 2007, January 8, 2008 and January 14, 2008, Tennessee Valley Authority (TVA) submitted its application to the U. S. Nuclear Regulatory Commission (NRC) for a combined license (COL) for two AP1000 advance passive pressurized water reactors pursuant to 10 CFR Part 52. The NRC staff is performing a detailed review of this application to enable the staff to reach a conclusion on the safety of the proposed application.

The NRC staff has identified that additional information is needed to continue portions of the review. The staff's request for additional information (RAI) is contained in the enclosure to this letter.

To support the review schedule, you are requested to respond within 45 days of the date of this letter. If changes are needed to the final safety analysis report, the staff requests that the RAI response include the proposed wording changes.

If you have any questions or comments concerning this matter, you may contact me at 301-415-1387 or you may contact Joesph Sebrosky, the lead project manager for the Bellefonte combined license at 301-415-1132.

Sincerely,

/RA/

Tanya Simms, Project Manager
AP1000 Projects Branch 1
Division of New Reactor Licensing
Office of New Reactors

Docket Nos. 52-014
52-015

Enclosure:
Request for Additional Information

CC: see next page

If you have any questions or comments concerning this matter, you may contact me at 301-415-1387 or you may contact Joesph Sebrosky, the lead project manager for the Bellefonte combined license at 301-415-1132.

Sincerely,

/RA/

Tanya Simms, Project Manager
AP1000 Projects Branch 1
Division of New Reactor Licensing
Office of New Reactors

Docket Nos. 52-014
52-015
eRAI Tracking No. 94

Enclosure:
Request for Additional Information

Distribution:

Public	RRadlinski	BHughes
RidsNroDnrlNwe1	SCoffin	MComar
RidsNroLAKGoldstein	TSimms	AHodgdon
RidsOgcMailCenter	BAnderson	TDinh
RidsAcrsAcnwMailCenter	SSanders	
RidsRgn2MailCenter	JMazza	
JSebrosky	PMoulding	

ADAMS Accession No. ML081270253

NRO-002

OFFICE	SFPT/BC	NWE1/PM	OGC	NWE1/L-PM
NAME	RRadlinski *	TSimms*	PMoulding*	JSebrosky*
DATE	4/03/08	4/22/08	4/25/08	5/05/08

*Approval captured electronically in the electronic RAI system.

OFFICIAL RECORD COPY

**Request for Additional Information No. 94 Revision 0
Bellefonte Units 3 and 4
Tennessee Valley Authority
Docket No. 52-014 and 52-015
SRP Section: 09.05.01 - Fire Protection Program
Application Section: 9.5.1 - Fire Protection System**

QUESTION from Fire Protection Team (SFPT)

09.05.01-2

Final Fire Hazards and Safe Shutdown Analyses – The Bellefonte COLA states that the applicant shall implement applicable portions of the Fire Protection Program prior to initial fuel load. Please state when the final fire hazards and safe shutdown analyses will be completed, and confirm that those analyses will be included in the FSAR. Explain how those analyses will be performed and documented, especially the post-fire, safe-shutdown circuit analysis method, and describe how the applicant will ensure that the analyses reflect the as-purchased, as-built plant.