

With respect to the table of GDC 3 and 10CFR50.48(a) requirements:

50.48(a) (1)(iv) - Section 2.7 should be added in addition to referencing chapter 3 and 4.

50.48(a)(1)(iv) is a discussion of the plan which includes the engineering analysis with the other documentation.

50.48(a)(2)(i) The entire section 3.3 appears to be more applicable than limiting the discussion to only one subsection of 3.3.

50.48(a)(iii) Chapter 3 also includes means to limit fire damage (such as fire prevention), therefore section 3.3 and chapter 4 should be referenced here.

GDC 3, 2nd row, it is unclear why section 3.3.5.3 and 3.3.6 were excluded from here? Perhaps, a solution would be to change the applicable section to 3.3 and 3.11.4, referencing 3.3 will include all the subsections.

GDC 3, 3rd row, shouldn't only section 3.4 through 3.10 of chapter 3 be included here, in addition to Chapter 4?