

GNRO-2008/00035

May 13, 2008

U.S. Nuclear Regulatory Commission Washington, D.C. 20555-0001

- Attention: Document Control Desk
- Subject: Response to Request for Additional Information for Alternative No. VRR-GGNS-2007-02 from ASME OM Code 5-Year Test Interval for Main Steam Safety Relief Valves

Grand Gulf Nuclear Station, Unit 1 Docket No. 50-416 License No. NPF-29

- References: 1. Request for Alternative VRR-GGNS-2007-01 and VRR-GGNS-2007-02 Requests for Alternative from ASME OM Code 5-year Test Interval for Main Steam Safety Relief Valves, letter dated January 8, 2008, GNRO-2007/00076
 - Grand Gulf Nuclear Station, Unit 1 Request for Additional Information Regarding Request for Alternative No. VRR-GGNS-2007-02 From ASME OM Code 5-Year Test Interval for Main Steam Safety Relief Valves (Tac No. MD7758), letter dated March 14, 2008, GNRI-2008/00035

Dear Sir or Madam:

In Reference 1, Grand Gulf requested relief from American Society of Mechanical Engineers Operation and Maintenance Code (ASME OM Code), 2001 Edition through 2003 Appendix, "Code of Operation and Maintenance of Nuclear Power Plants," Subsection ISTC, Mandatory Appendix I. Relief Request No. VRR-GGNS-2007-02 requested to extend the 5-year test interval, on a one-time basis, for eleven Main Steam Safety Relief Valves (SRVs) for Grand Gulf Nuclear Station, Unit 1 (GGNS). In Reference 2, the NRC transmitted a Request for Additional Information to Grand Gulf concerning the requested relief. The responses to Reference 2 are provided in the enclosure to this letter. This letter was delayed from the original 30 days as allowed by the Grand Gulf NRC Project Manager. The responses in this letter are applicable to both Relief Requests VRR-GGNS-2007-01 and VRR-GGNS-2007-02 submitted in Reference 1. GNRO-2008/00035 Page 2

Entergy requests approval of Relief Request VRR-GGNS-2007-02 by July 11, 2008 to enable startup of GGNS Unit 1 following RF-16 in Fall of 2008, and continued operation until the seventeenth refueling outage (RF-17) and the eighteenth refueling outage (RF-18). RF-17 is currently scheduled to begin in Spring of 2010 and RF-18 is scheduled to begin in Winter of 2012.

This letter contains no commitments.

Should you have any questions regarding this submittal, please contact Michael Larson at (601) 437-6685.

Sincerely,

Mucho

Michael J. Larson Acting Licensing Manager

MJL:mjl

Enclosure: Response to NRC Request for Additional Information – VRR-GGNS-2007-02

CC:

| | NRC Senior Resident Inspector Grand Gulf Nuclear Station |
|---|---|
| | Port Gibson, MS 39150 |
| | U.S. Nuclear Regulatory Commission |
| l | ATTN: Mr. Elmo E. Collins, Jr. (w/2) |
| | 611 Ryan Plaza Drive, Suite 400 |
| | Arlington, TX 76011-4005 |
| | U. S. Nuclear Regulatory Commission |
| | ATTN: Mr. Jack N. Donohew, Jr., NRR/APRO/ DORL (w/2) |
| | ATTN: ADDRESSEE ONLY |
| | ATTN: U. S. Postal Delivery Address Only |
| | Mail Stop OWFN/O-8G14 |
| | Washington, DC 20555-0001 |

The NRC transmitted a Request for Additional Information in a letter (Reference 2) dated March 14, 2008 to Grand Gulf concerning the requested relief. The response to the NRC requests shown below.

NRC Request #1

Verify that Valves 1B21-F041K, 1B21-F041F, 1B21-F051F, 1B21-F051B, 1B21-F041D, and 1B21-F047D were refurbished to a like-new condition prior to being placed in storage and later installed in October 2005. Verify that Valves 1B21-F047L, 1B21-F041G, 1B21-F047G, 1B21-F051C, and 1B21-F047C were refurbished to a like-new condition prior to being placed in storage and later installed in March 2007.

Response

The table below lists the refurbishment work orders and the installation work orders as verification that the Main Steam Safety Relief Valves (SRVs), were refurbished to a like-new condition prior to being placed in storage and later installed in the plant. During the time between refurbishment and installation, the valves were stored in metal storage containers in an indoor Class "C" storage area in accordance with ANSI N45.2.2-1972, Packaging, Shipping, Receiving, Storage and Handling of Items for Nuclear Power Plants.

| Valve Location | Serial Number | Date Refurbished | Refurbishment Work Order # | Storage Duration | Date installed | Installation Work Order |
|----------------|---------------|---------------------|-------------------------------|------------------|-------------------|----------------------------|
| 1B21F041K | 160796 | 1/9/2004 | 50325284 | 21 months | 10/3/2005 | 41320 |
| 1B21F041F | 160836 | 1/9/2004 | 50325333 | 22 months | 10/3/2005 | 50983208 |
| 1B21F051F | 160831 | 1/9/2004 | 50325330 | 22 months | 10/3/2005 | 50983208 |
| 1B21F051B | 160844 | 1/9/2004 | 50325287 | 22 months | 10/3/2005 | 50983208 |
| 1B21F041D | 160838 | 1/9/2004 | 50325286 | 22 months | 10/3/2005 | 50983208 |
| 1B21F047D | 160808 | 1/9/2004 | 50325285 | 23 months | 10/3/2005 | 50983208 |
| 1B21F047L | 160825 | 1/25/2007 | 85663 | 2 months | 3/21/2007 | 51034868 |
| 1B21F041G | 160819 | 9/13/2005 | 44310 | 18 months | 3/21/2007 | 51034868 |
| 1B21F047G | 160804 | 9/15/2005 | 44320 | 18 months | 3/21/2007 | 51034868 |
| 1B21F051C | 160812 | 9/15/2005 | 44309 | 18 months | 3/21/2007 | 51034868 |
| 1B21F047C | 160803 | 9/20/2005 | 44306 | 18 months | 3/21/2007 | 51034868 |

NRC Request #2

Discuss if the controlled environment for the storage of Valves 1B21-F041K, 1B21-F041F, 1B21-F051F, 1B21-F051B, 1B21-F041D, 1B21-F047D, 1B21-F047L, 1B21-F041G, 1B21-F047G, 1B21-F051C, and 1B21-F047C was equipped to prevent condensation and corrosion.

Response

The valves in question are stored in an indoor Class C storage area in accordance with ANSI N45.2.2-1972, Packaging, Shipping, Receiving, Storage and Handling of Items for Nuclear Power Plants. Class C storage areas are defined as follows:

"Level C items shall be stored indoors or equivalent with all the provisions and requirements set forth in Level B items except that heat and temperature control is not required. Level B items shall be stored within a fire resistant, tear resistant, weathertight, and well ventilated building or equivalent enclosures...This area shall be situated and constructed so that it will not be subject to flooding; the floor shall be paved or equal, and well drained...Items shall be placed on shoring to permit circulation..."

For the valves in question, each valve is stored in metal container. The seating surfaces between the metal container and the base of the container has a rubber gasket material, which seals the container, therefore while in storage the SRVs are protected from moisture. There has not been any indication of condensation or corrosion based on the current practice to store the valves in a Level C storage area coupled with sealing the valves in metal containers.

NRC Request #3

Provide test results for Dikkers Model G-471 SRVs that were maintained in a controlled environment similar to the GGNS controlled environment for an extended period of time and setpoint tested prior to actual installation. As an alternative, discuss why the as-found set-pressure test results for Dikkers Model G-471 SRVs provided in a letter dated September 28, 2007 (Agency wide ADAMS Accession No. ML072740030) are applicable to the GGNS SRVs.

Response

Grand Gulf is not aware of a situation in which a Grand Gulf SRV has been stored for an extended period, greater that two operation cycles, prior to being installed in the plant without the valve being inspected and recertified. The standard practice at Grand Gulf is to refurbish and certify valves no more that 30 months prior to installation in the plant. The table below show the Grand Gulf actual test result for SRVs test from RF11 (April 2001) through RF15 (February 2007). The table documents the time the valve was previously tested, date valve installed, and the as found testing results. For 21 of the tests, the as found pressure was found to be within 1% of the as left set pressure. One valve in this group of 21, serial number 160837 testing during RF14 (September 2005), had 97 months between test. This valve's as found test result was within 1% of the valves as left set pressure. The test results, summarized in the table below, confirms that the storage of for Dikkers Model G-471 SRVs for an extended period of time has minimal impact upon the ability of the SRVs to satisfy the ASME as found acceptance criteria of plus or minus 3%, and thus does not reduce the level of quality or safety.

| Outage / | Valve | Valve | Date of | Date | Date of | Time | Correlation | As Found | PSIG | % above of |
|--------------------|-----------|------------------|-----------|-----------------------|------------------|-----------|-----------------|-------------|-----------------------|------------|
| Work Order | Location | Seriai Number | Test | Installed in Plant | As Found Test | Between | Set Pressure | lest Result | above or below set | below set |
| RE15 / | | Number | 1031 | | 1031 | 1031 | 1103010 | | 50.000 001 | |
| 51034868 | | | | | | | | | | |
| | 1B21F047L | 160823 | 2/27/2001 | 10/02/2002 | 3/25/2007 | 73 months | 1199.91 | 1189 | -10.91 | -0.91% |
| | 1B21F041G | 160800 | 9/11/2002 | 10/02/2002 | 3/25/2007 | 54 months | 1184.32 | 1204 | 19.68 | 1.66% |
| | 1B21F047G | 160826 | 2/27/2001 | 10/02/2002 | 3/25/2007 | 73 months | 1199.44 | 1177 | -22.44 | -1.87% |
| | 1B21F047C | 160824 | 9/15/2005 | 10/03/2005 | 3/25/2007 | 18 months | 1199.47 | 1209 | 9.53 | 0.80% |
| | 1B21F041C | 160795 | 9/14/2005 | 10/03/2005 | 3/25/2007 | 18 months | 1184.3 | 1189 | 4.7 | 0.40% |
| | 1B21F041A | 160816 | 7/15/2002 | 3/15/2004 | 3/27/2007 | 56 months | 1184.47 | 1183 | -1.47 | -0.12% |
| | 1B21F051A | 160809 | 7/15/2002 | 3/15/2004 | 3/27/2007 | 56 months | 1210.56 | 1219 | 8.44 | 0.70% |
| RF14 / 50983208 | | | | | | | | | | |
| | 1B21F041K | 160801 | 3/14/2001 | 5/03/2001 | 9/25/2005 | 54 months | 1183.96 | 1190 | 6.04 | 0.51% |
| | 1B21F051K | 160832 | 1/9/2004 | 3/15/2004 | 9/25/2005 | 20 months | 1209.35 | 1208 | -1.35 | -0.11% |
| | 1B21F041F | 160822 | 4/18/2001 | 5/03/2001 | 9/25/2005 | 53 months | 1183.98 | 1189 | 5.02 | 0.42% |
| | 1B21F051F | 160834 | 4/18/2001 | 5/03/2001 | 9/25/2005 | 53 months | 1209.33 | 1215 | 5.67 | 0.47% |
| | 1B21F041B | 160835 | 4/18/2001 | 5/03/2001 | 9/25/2005 | 53 months | 1183.92 | 1186 | 2.08 | 0.18% |
| | 1B21F051B | 160811 | 4/18/2001 | 5/03/2001 | 9/25/2005 | 53 months | 1209.47 | 1223 | 13.53 | 1.12% |

G080035

| Outage / | | Valve | Date of | Date | Date of | Time | Correlation | | PSIG | |
|-------------------------|-----------|--------|------------|--------------|-----------|-----------|-----------------------|--------------------|-----------|------------|
| Work | Valve | Serial | Previous | Installed in | As Found | Between | Set | As Found | above or | % above of |
| Order | Location | Number | Test | Plant | Test | Test | Pressure | Test Result | below set | below set |
| | 1B21F041D | 160837 | 8/4/1997 | 5/03/2001 | 9/25/2005 | 97 months | 1184.14 | 1174 | -10.14 | -0.86% |
| | 1B21F047D | 160825 | 3/30/1999 | 5/03/2001 | 9/25/2005 | 78 months | 1199.36 | 1157 | -42.36 | -3.53% |
| | 1B21F051C | 160830 | 9/18/2002 | 10/02/2002 | 9/25/2005 | 36 months | 1209.35 | 1196 | -13.35 | -1.10% |
| RF13/ 50336965 | | | | | | | | | | |
| | 1B21F041A | 160815 | 12/12/1997 | 12/04/1999 | 3/3/2004 | 75 months | 1184.63 | 1180 | -4.63 | -0.39% |
| | 1B21F041E | 160795 | 12/30/1997 | 12/04/1999 | 3/3/2004 | 75 months | 1184.71 | 1165 | -19.71 | -1.66% |
| | 1B21F047A | 160804 | 5/6/1999 | 12/04/1999 | 3/3/2004 | 58 months | 1199.97 | 1193 | -6.97 | -0.58% |
| | 1B21F047H | 160839 | 3/30/1999 | 12/04/1999 | 3/3/2004 | 60 months | 1199.93 | 1183 | -16.93 | -1.41% |
| | 1B21F051A | 160829 | 1/6/1998 | 12/04/1999 | 3/3/2004 | 74 months | 1210.12 | 1190 | -20.12 | -1.67% |
| | 1B21F051D | 160813 | 2/17/1999 | 12/04/1999 | 3/3/2004 | 61 months | 1210.03 | 1183 | -27.03 | -2.23% |
| RF12/ MAI311478 | | | | | | | | | | |
| | 1B21F041C | 160802 | 12/3/1997 | 5/08/1998 | 9/22/2002 | 57 months | 1184.69 | 1216 | 31.31 | 2.60% |
| | 1B21F047C | 160841 | 11/13/1997 | 5/08/1998 | 9/22/2002 | 58 months | 1199.79 | 1209 | 9.21 | 0.40% |
| | 1B21F051C | 160814 | 11/21/1997 | 5/08/1998 | 9/22/2002 | 58 months | 1210.03 | 1225 | 14.97 | 1.30% |
| | 1B21F047L | 160827 | 11/12/1997 | 5/08/1998 | 9/22/2002 | 58 months | 1199.83 | 1193 | -6.83 | -0.50% |
| | 1B21F047G | 160824 | 12/18/1997 | 5/08/1998 | 9/22/2002 | 57 months | 1199.89 | 1194 | -5.89 | -0.49% |
| | 1B21F041G | 160818 | 11/28/1997 | 5/08/1998 | 9/22/2002 | 58 months | 1184.49 | 1174 | -10.49 | -0.89% |
| RF11/ MAI287068 * | | | | | | | | | | |
| | | | | * | | | Steam Set Pressure | As-found Result | | |
| | 1B21F047D | 160840 | 5/1/1995 | 10/22/1996 | 4/30/2001 | 73 months | 1180 | 1207 | 27 | 2.29% |
| | 1B21F041D | 160817 | 5/11/1995 | 10/22/1996 | 4/30/2001 | 73 months | 1165 | 1172 | 7 | 0.60% |
| | 1B21F041K | 160800 | 5/18/1995 | 10/22/1996 | 4/30/2001 | 73 months | 1165 | 1166 | 1 | 0.09% |
| | 1B21F051K | 160830 | 5/16/1995 | 10/22/1996 | 4/30/2001 | 73 months | 1190 | 1202 | 12 | 1.00% |
| | 1B21F041F | 160821 | 5/5/1995 | 10/22/1996 | 4/30/2001 | 73 months | 1165 | 1175 | 10 | 0.86% |
| | 1B21F051F | 160809 | 5/15/1995 | 10/22/1996 | 4/30/2001 | 73 months | 1190 | 1200 | 10 | 0.84% |
| | 1B21F041B | 160816 | 5/17/1995 | 10/22/1996 | 4/30/2001 | 73 months | 1165 | 1180 | 15 | 1.29% |
| | 1B21F051B | 160810 | 5/15/1995 | 10/22/1996 | 4/30/2001 | 73 months | 1190 | 1209 | 19 | 1.60% |

Note: RF11 valves were set and tested by the use of steam, not nitrogen * See PO #NHS00370 for pressure see results