

Fort Calhoun Station P.O. Box 550 Fort Calhoun, NE 68023

> May 15, 2008 LIC-08-0066

U. S. Nuclear Regulatory Commission ATTN: Document Control Desk Washington, DC 20555-0001

Reference: Docket No. 50-285

SUBJECT: Fort Calhoun Station Unit No. 1 Request for Relief Pertaining to Liquid Penetrant Acceptance Criteria for Replacement Safety Injection and Refueling Water Tank (SIRWT) Outlet Header Level Control Valve (TAC No. MD8722)

Pursuant to the provision stated in 10 CFR 50.55a (a)(3)(i), the Omaha Public Power District (OPPD) requests relief from certain requirements of the American Society of Mechanical Engineers (ASME) Boiler and Pressure Vessel Code (BPVC), Section III, with regard to flaw acceptance criteria. This relief request applies to the Fisher Control valve procured as a replacement for the currently installed SIRWT Outlet Header Level Control Valve LCV-383-2.

Approval of this relief request is needed prior to Monday, May 19, 2008, in support of 2008 refueling outage activities. The current schedule for start up from this refueling outage (based upon successful resolution of this relief request) shows reactor criticality occurring on May 30, 2008.

The flaw tolerance analysis is ongoing and will be provided under a separate submittal.

The proposed duration is for one operating cycle. OPPD will be performing further evaluations and may request relief at a later date for permanent duration of the proposed alternative.

If you should have any additional questions regarding this submittal, please contact Mr. Tom Matthews at 402-533-6938.

Sincerely,

R. P. Clemens Division Manager Nuclear Engineering

Enclosure: 10 CFR 50.55a Relief Request

c: E. Collins, NRC Regional Administrator, Region IV (w/o Attachments)
 M. T. Markley, NRC Sr. Project Manager (w/o Attachments)
 J. D. Hanna, NRC Sr. Resident Inspector (w/o Attachments)

# 10 CFR 50.55a Relief Request Proposed Alternative in Accordance with 10 CFR 50.55a(a)(3)(i) --Alternative Provides Acceptable Level of Quality and Safety--

# 1. ASME CODE COMPONENT AFFECTED

This relief request involves one ASME Code Class 2 component; specifically, a proposed replacement valve for the currently installed LCV-383-2. This valve is one of two parallel Safety Injection and Refueling Water Tank (SIRWT) outlet header level control valves. The valve is a 20-inch, pressure class 150, butterfly valve with a pneumatic piston operator. It is maintained normally open as a supply isolation for the low pressure safety injection (LPSI), high pressure safety injection (HPSI) and containment spray (CS) pumps. It closes upon a safety injection recirculation actuation signal (RAS) to assist the downstream check valve in preventing backflow into the SIRWT. Replacement of the existing valve LCV-383-2 is necessary because it exhibited excess seat leakage testing during Technical Specification surveillance testing. Repair of the currently installed valve is not considered possible at this time because of the long lead time for obtaining replacement parts to refurbish the current valve. Therefore, two commercial grade replacement valves were procured for dedication as Safety Class 2.

## 2. APPLICABLE CODE EDITION AND ADDENDA

OPPD purchased this valve as a commercial grade item and is in the process of dedicating it from safety-related application. During the dedication process, the valve was rejected due to surface discontinuities discovered during the Liquid Penetrant (LP) Examination. As such, the replacement valve could not meet the requirements of ASME BPVC Section III, Division 1, Subsection NC-5350. Relief is being requested to accept the valve "As-Is" without repairing the surface discontinuities.

The valve is a Safety Class 2 component as defined in the Updated Final Safety Analysis Report (UFSAR), Appendix N "Reclassification of Systems." The applicable standard imposed for the valve's design is ANSI B16.34, "Valves - Flanged, Threaded and Welding End," 2004. From that standard, Appendix I, "Radiography Procedure and Acceptance Standards" and Appendix III, "Liquid Penetrant Procedure and Acceptance Standards" were imposed to make the valve equivalent in quality with respect to the design and inspection requirements from original plant construction for a valve in radioactive service. The proposed replacement valve is a (new) commercial grade valve which was procured by the Omaha Public Power District (OPPD) and inspected by a third party dedication vendor (Sigma), to ensure it meets the necessary quality requirements. The third party vendor has a quality assurance program which meets the requirements of 10 CFR 50 Appendix B.

As part of the dedication process, the vendor performed a dimensional (including wall thickness) verification, chemical (material) analysis on pressure retaining items and also performed the necessary non-destructive examinations (NDE) on pressure retaining items to ensure they meet the requirements. Hydrostatic testing of the body and seat were also performed. The applicable document prepared by the vendor is "Dedication of Butterfly Valves for Nuclear Safety Related Service". The OPPD purchase order (PO) for the valve

LIC-08-0066 Enclosure

(from the commercial supplier) is PO #120934. The OPPD contract number for the dedication services is #120818.

3. APPLICABLE CODE REQUIREMENT

An alternative to the acceptance criteria for the Liquid Penetrant Inspection acceptance criteria regarding rounded indications as stated in ANSI B16.34, 2004, Appendix III "Liquid Penetrant Procedure and Acceptance Standards" for the body casting is being proposed. The proposed alternative is the acceptance criteria (ref. Original Contract 762 Acceptance Criteria) from USAS B31.1, 1967 "Power Piping" for Liquid Penetrant Inspection. These acceptance criteria apply to the existing valve, which conforms to original plant construction requirements (Ref. OPPD Contract 762 Section H-10, "Control Valves").

The acceptance criteria for the LP examination from ANSI B16.34 Appendix III paragraph D2.1 "Castings" as defined in the dedication document is repeated as follows:

Maximum acceptable indications are as follows:

(a) Linear Indications:

(1) 0.3 in. long for materials up to 0.5 in. thick;

(2) 0.5 in. long for materials 0.5 in. to 1 in. thick;

(3) **0.7** in. long for materials over 1 in. thick.

For linear indications, the indications must be separated by a distance greater than the length of an acceptable indication. A linear indication is one with length in excess of 3 times the width.

(b) Rounded Indications:

(1) 0.3 in. diameter for materials up to 0.5 in. thick;

(2) 0.5 in. diameter for materials over 0.5 in. thick.

Four or more rounded indications in a line separated by 0.06 in. or less edge to edge are unacceptable. Rounded indications are those that are not defined as linear indications.

The acceptance criteria for the LP examination from USAS B31.1 1967, Section 136.5.3(d) states the following:

"All linear discontinuities and aligned penetrant indications revealed by the test shall be removed. Aligned penetrant indications are those in which the average of the center-to-center distances between any one indication and the two adjacent indications in any straight line is less than 3/16". All other discontinuities revealed on the surface need not be removed unless the discontinuities are also revealed by radiography, in which case the pertinent radiographic specification shall apply."

4. REASON FOR REQUEST

A timeline of events (Attachment 1) is provided explaining the exigent circumstances for this Relief Request.

During surveillance test SE-ST-SI-3005, LCV-383-1 and LCV-383-2 exhibited seat leakage outside the acceptance criteria as documented in condition reports (CRs) 2008-2919 and 2008-2920, respectively. Replacement valves were purchased as commercial grade, as defined by 10 CFR 21, and were to be dedicated (see Attachment 3 for Dedication Plan) to meet the requirements of ASME BPVC Section III Class 2 Components. During the dedication process, the valves failed to meet applicable inspection criteria due to surface discontinuities discovered during the LP Examination. As such, the replacement valves could not meet the requirements of ASME BPVC Section III, Division 1, Subsection NC-5350. Relief is being requested to accept one of the valves "As-Is" without repairing the surface discontinuities.

OPPD was successful in repairing the other valve (LCV-383-1).

5. PROPOSED ALTERNATIVE AND BASIS FOR USE

The valve procured as commercial grade item to be dedicated as a replacement was examined in accordance with the ANSI B16.34, 2004 criteria as referenced in the Dedication Plan (Attachment 2).

Radiography was performed on the body and disc in accordance with ASME B16.34, 2004, Appendix I "Radiography Procedure and Acceptance Standards". The body and disc met all RT acceptance criteria in Appendix I.

In addition, the valve was hydrostatically tested to 450 psig per the requirements of Section 7 of ASME B16.34, 2004, and met the acceptance criteria of Section 7.

When the PT exam was performed, in accordance with Appendix III, on the body and disc, several areas of the valve body presented indications which were outside of the acceptance criteria. However, the valve is an acceptable replacement based on the following:

- Integrity of the valve body has been demonstrated, through radiography and hydrostatic testing, in accordance with the requirements for ASME B16.34 Class 150 valve for operating conditions (350°F, 150 psig).
- The expected operating condition the valve will experience is significantly less than rated operating conditions for an ASME B16.34 Class 150 valve. The limiting conditions are 120°F and 60 psig. This statement is supported by the following:
  - The SIRWT (SI-5) is vented to atmosphere. Thus, the only pressure experienced at the valve is the result of water above the valve location and pressure related to the fluid velocity. The valve centerline is located at the 974'-6" elevation and the top of the SIRWT is at the 1004'-0" elevation (a difference of ~30 feet). Converted to psig, 30 ft = 13 psig at 39.2°F (4°C). Therefore, an operating pressure of 60 psig is conservative.
  - LCV-383-2 has a check valve (SI-139) installed downstream of its location. The effect of the check valve is that LCV-383-2 is isolated from directly experiencing the

temperatures associated with RAS. Thus, the only temperature the valve experiences is the 105°F maximum operating temperature of the SIRWT. Therefore, 120°F is a conservative normal operating temperature.

- Taking into consideration the expected operating pressure (60 psig), a minimum wall thickness calculation (Attachment 2) results in a minimum wall thickness of 0.124". The actual wall thickness measured during the dedication process was 1.18" (valve s/n 16988576). Therefore, the valve exceeds the required wall thickness for the intended application.
- The flaw tolerance analysis of the indications from the PT examination is in progress. Preliminary, non-QA'd results indicate any propagation of these flaws would not challenge the integrity of the valve body. When finalized, this flaw tolerance analysis will be provided under a separate submittal.

### 6. DURATION OF THE PROPOSED ALTERNATIVE

The proposed duration is for one operating cycle. OPPD will be performing further evaluations and may request relief at a later date for permanent duration of the proposed alternative.

Attachments:

- 1: Timeline of Events
- 2: Min Wall Thickness Calc
- 3: Dedication Plan
- 4: Dedication Package
- 5: Drawings (Isometric, P&ID, Valve Drawings (4))
- 6: Photos (9)
- 7: Fisher Bulletin

# Timeline for LCV-383-1 & LCV-383-2 Safety Injection Refueling Water Tank Outlet Header Level Control Valves

~

<u>Activity</u>	<u>Date</u>
1. 2008 Refueling Outage Begins	April 19, 2008
<ul> <li>Safety Injection System Leakage Test         <ul> <li>a. Surveillance Test SE-ST-SI-3005</li> <li>i. LCV-383-1 acceptance criteria exceeded</li> <li>ii. LCV-383-2 acceptance criteria exceeded</li> </ul> </li> </ul>	April 28, 2008 April 29, 2008
<ol> <li>Special Work Assignment Team Formed         <ul> <li>a. Resolve Seat leakage of valves</li> </ul> </li> </ol>	April 30, 2008
<ul> <li>4. Spare Parts Determination</li> <li>a. Two Seats in warehouse</li> <li>b. Valve disk, stem and pins ordered</li> <li>c. Only enough parts available to repair one valve</li> </ul>	May 1, 2008
<ul> <li>5. Two new Fisher valves ordered <ul> <li>a. Only commercial grade available</li> <li>b. Dedication plan developed</li> <li>c. Industry/Vendor search for safety related valves unsuccessful</li> <li>i. 14 – 16 week deliveries</li> </ul> </li> </ul>	May 2, 2008 ul
<ol> <li>Valve LCV-383-2 removed from pipe header &amp; inspected</li> <li>a. Seat and disk not repairable</li> </ol>	May 4, 2008
<ol> <li>Valve LCV-383-1 removed from pipe header &amp; inspected</li> <li>a. Valve repairable, best success for use of limited spare parts</li> </ol>	May 7, 2008
<ul> <li>8. New Fisher Valve's NDE at factory <ul> <li>a. Visual &amp; Radiography acceptable</li> <li>b. Dye Penetrant inspection <ul> <li>i. Body Wafer #1 discontinuities &amp; rejected</li> <li>ii. Body Wafer #2 discontinuities &amp; rejected</li> </ul> </li> </ul></li></ul>	May 10-11, 2008
9. Valve LCV-383-1 Repaired & Passes Seat Leakage Test	May 12, 2008
10. FCS Begins Engineering Evaluation of discontinuities	May 12, 2008
11. Determination NRC Relief Request Needed	May 14, 2008
12. Scheduled installation of Repaired LCV-383-1	May 16, 2008

13. Scheduled installation of New Valve LCV-383-2	May 16, 2008
14. FCS Submittal of Relief Request	May 15, 2008
15. Requested NRC Approval of Relief Request	May 19, 2008
16.2008 RFO Original Scheduled Breakers Closed	May 24, 2008
17.2008 RFO Reactor Criticality	May 30, 2008
18.2008 RFO Projected Breakers Closed	June 1, 2008

.

LIC-08-0066 Attachment 2	Minimum Wall Thickness Calculation per ASME BPVC Section II		
Internal Pressure Normal Operating $(P_N)$ [psi]	60	See Pressure Discussion Below	
Safety Factor	4		
Internal Pressure (P) [ps1]	240		
Nominal Outside Diameter (D) [in.]	23		
Inside Radius (R) [in.]	10.320		
Stress Intensity Limit (S) [psi]	20000		
Membrane Stress Intensity [ksi] @ -20° to 300°F Stress Intensity Factor	20.0 I	Table 2A, ASME BPVC Sec. II, Part D, Subpart 1 See Temperature Discussion Below Table NC-3217-1, ASME BPVC Sec. III, Div1 - NC	
Minimum Wall Thickness (t) [in.]	0.124	t = (P x R) ÷ (S - 0.5 x P) {ref. ASME BPVC Sec III, Div I, NC-3224.3(a)}	
Actual Measured Wall Thickness [in.]	1.180 1.160	Serial Number 16988576 [On-Site 15-May-2008] Serial Number 16988575	

#### Expected Normal Operating Pressure

The SIRWT (SI-5) is vent to atmosphere. Thus, the only pressure experience at the values is the result of water above the values location. The value are located at the 974'-6" elevation and the top of the SIRWT is at the 1004'-0" elevation (a difference of  $\sim$ 30 feet). Converted to psig, 30 ft = 13 psig at 39.2°F (4°C). Allowing for the maximum operating temperature of 105°F, this value could be less due less dense water. However, with all SI pumps (SI-1A/B, SI-2A/B/C  $\ddagger$  SI-3A/B/C) operating, each header can see flow approaching 9000 gpm which will induce approximately 10 psi in velocity pressure. Therefore, an operating pressure of 60 psig is conservative.

#### Expected Normal Operating Temperature

LCV-383-1/2 have check values installed downstream of their respective locations. The effect of these check values is that LCV-383-1/2 never see the temperatures associated with RAS. Thus, the only temperature the values experiences is the  $105^{\circ}F$  maximum operating temperature of the SWIRT. Therefore,  $120^{\circ}F$  is a conservative normal operating temperature.

#### Conclusion

A minimum wall thickness calculation indicates the valve would require a 0.124" minimum wall thickness for the expected operating pressure of 60 psig. This wall thickness incorporates a safety factor of 4 and is valid from -20°F to 300°F. The actual wall thickness measure by Sigma during the dedication process was 1.18" for the valve with serial number 16988576 which is currently on site. The wall thickness for the valve with serial number 16988575 was measured at 1.16". Thus, the valve has > 1" of additional material above what is required for the expected operating condition.

The radiography demonstrated the flaws were on the surface only and did not permeate into the body of the valve. Therefore, the valves have more than a sufficient amount of wall thickness to operate with an acceptable level of safety and quality.

# SIGMA SALES ORDER NO: 8904

CUSTOMER: OPPD-FORT CALHOUN

120818

PURCHASE ORDER NO.:

#### **Products**

QTY	LI#	CUSTOMER'S STOCK #	DESCRIPTION
		DIOCK //	
2	*	* .	VALVE, WAFER BUTTERFLY, 20", ASME B16.34 150# CLASS, ASTM A351 GRADE CF8M BODY AND DISC, POSI-SEAL
			FIGURE A31A

\* The valves being dedicated under this plan were purchased directly by the end user from the manufacturer.



Date: May 7, 2008

. . .. . . . .

# 1.0 **Purpose**

This plan establishes the requirements for performing the dedication activities of butterfly valves, commercial grade for use in nuclear facilities in safety related applications. This plan shall establish the requirements that will reasonably assure that the valves will perform their safety related function.

# 2.0 <u>Scope</u>

This plan is applicable to valves purchased commercial grade from the manufacturer's published catalog descriptions.

# 3.0 *Responsibilities*

- 3.1 The QA Manager is responsible for implementation for this plan and shall comply with the requirements of QAP-7 Dedication of Commercial Grade Items.
- 3.2 Vendors performing non-destructive examination and material verification services shall be qualified in accordance with the QA Manual section 6.
- 3.3 Suppliers of calibration services shall be qualified in accordance with the QA Manual Section 6.

# 4.0 *Commercial Grade Criteria*

4.1 An item is a commercial grade item if its critical characteristics can be verified during the dedication process. Butterfly valves purchased commercial from the manufacturer's published catalog description are commercial grade items as defined in 10CFR21.

## 5.0 Safety Function

5.1 The safety function of valves dedicated under this plan is pressure retention and isolation.

# 6.0 <u>Applicable Industry Standards</u>

- 6.1 ASME B16.34: Valves-Flanged, Threaded, and Welding End
- 6.2 MSS SP61: Pressure Testing of Steel Valves

## 7.0 Manufacturer's Commercial Publications

7.1 Posi-Seal Product Bulletin 21.1:A31A dated October 2005

# 8.0 Critical Characteristics/Acceptance Criteria

- 8.1 QAP-8 Attachment A "Receipt Inspection" provides assurance that the item is identifiable to the manufacturer's outline drawing (part number) and is not damaged.
- 8.2 Dimensional Verification provides assurance that the valve's critical dimensions meets the manufacturer's published literature.
- 8.3 Chemical Analysis of the pressure retaining components will provide assurance that the item meets the applicable ASTM specification for chemistry.
- 8.4 Non-Destructive Examination (RT and PT) of the pressure retaining components will provide assurance that defects in material and workmanship do not exist that would preclude the part from performing its design function (pressure retention).
- 8.5 Hydrostatic shell and pneumatic seat leak testing will provide assurance that the pressure retaining components (body and disc) will perform their safety function of pressure retention and isolation.

. . . .

 $(g_{ij}) \in \{i,j\} \in \mathbb{N}$ 

No.	Critical Characteristic	Basis	Acceptance Criteria
1	Receipt Inspection	Form	QAP-8 Attachment A
2	Configuration/ Dimensions • End to end • Height • Diameter (RO) • Bolt Circle • Weight • Minimum Wall	Fit, Form	5.0" ± (later) 26.0" ± (later) 23.0" ± (later) 25" ± (later) 368 lbs ± 10% 0.51"
3	Material Verification • Body, Disc	Form, Function	ASM A351 GRADE CF8M
4	NDE RT BODY & DISC 100% PT BODY & DISC: Machined surfaces	Function	ASME B16.34-2004 Appendix I ASME B16.34-2004 Appendix III
5	<ul> <li>Pressure Testing</li> <li>Hydrostatic Shell Test</li> <li>Pneumatic Seat Leak Test</li> </ul>	Function	ASME B16.34, (later) PSIG FOR MINUTES, ZERO LEAKAGE Manufacturer's Acceptance criteria. (later) PSIG FOR MINUTE, (later) LEAKAGE

a passa ng

# 9.0 Verification Inspection Plan

No.	Method	Instructions	RESULTS	VERIFIED BY
1	1	Verify acceptable QAP- 8 "Receipt Inspection". Record Heat Codes on Table A		
2	2	Verify acceptable critical dimensions. Record results on Table B.		
3	2	Verify acceptable Chemical Analysis for body and disc.		
4	2	Verify acceptable RT and PT examination results. Verify OPPD acceptance of RT & PT results		
5	2	Verify acceptable hydrostatic shell and seat leak test results.		

Method of Acceptance:

- 1. Special Tests and Inspections
- 2. Commercial Grade Survey of Suppliers
- 3. Source Verification
- 4. Acceptable Supplier/Item Performance

# Final Acceptance

By:

Date:

### 10.0 Plan Controls

- 10.1 All documentation generated as a result of this plan shall be identified with the dedication code for traceability.
- 10.2 All valves dedicated under this plan shall be stamped with the dedication code and serialized with successive numbers and be traceable to the documentation.
- 10.3 All measuring and test equipment used shall be calibrated and identified on the documentation.
- 10.4 Material acceptance of the body and disc shall be accomplished by review and acceptance of Chemical Analysis obtained by Optical Emission Spectrograph.
- 10.5 Valves that fail RT, PT or Chemical Analysis shall be rejected and an NCR written in accordance with QAP-2.
- 10.6 Hydrostatic testing shall be performed in accordance with the manufacturer's test procedure and shall comply with ANSI/ASME B16.34 and MSS-SP-61.
- 10.7 Valves that fail the hydrostatic shell test shall be rejected and an NCR written in accordance with QAP-2. Valves that fail the seat leak test may be reworked and retested.
- 10.8 Valves that successfully pass all the criteria set forth in this plan shall either be processed in accordance with QAP-10 "Sales Order Processing" or tagged with the commercial grade dedication code and stored in accordance with QAP-8 "Control of Nuclear Safety Related Components".

## 11.0 Documentation

11.1 All documentation generated as a result of this plan shall be identified with the dedication code and be controlled in accordance with QAP-5 "Document Control".

\

# DEDICATION PLAN Dedication of Butterfly Valves For Use In Nuclear Safety Related Applications Dedication Code: ND

# TABLE AMATERIAL TRACEABILITY RECORD

SERIAL NUMBER	HEAT CODES		
	BODY	DISC	
MD1			
MD2			

# **Table B Critical Dimensions**

Serial No.	End to End	Height	Diameter (RO)	Bolt Circle	Weight (lbs)	MIN WALL <sup>1</sup>
					331-405	.51
MD1						
MD2						

Dimensions are in inches.

'Record smallest measurement

Caliper No.:	Calibration Due Date:	

LIC-08-0066, Attachment 4

# QUALITY ASSURANCE DATA PACKAGE <u>TABLE OF CONTENTS</u>

SIGMA SALES ORDER NO: CUSTOMER: PURCHASE ORDER/CONTRACT NO.: 8904 OPPD-FORT CALHOUN Contract No.120818 Purchase Order No. 120934

#### **Products**

QTY	LI#	CUSTOMER'S	DESCRIPTION
		STOCK #	
1	1	00001302011	VALVE, WAFER BUTTERFLY, 20", ASME B16.34
			150# CLASS, ASTM A351 GRADE CF8M BODY AND
		-	DISC, POSI-SEAL FIGURE A31A

Shipment Date:

MAY 14, 2008

Document	Page Numbers	
Certificate of Conformance	1	
Hydrostatic Shell & Seat Leak Test Report	2	
Material Traceability Record	3	
PMI Report for Bodies & Discs	4	
RT for Bodies	5-8	
PT for the Bodies	9	
RT for the Discs	10-11	
PT for the Discs	12	
Dimensional Inspection Report with Minimum Wall	13	
OPPD Dedication Plan Approval from Glen Seier	14	
NCR 48 for PT of Bodies 15		
Acceptance of S/N 16988576 by Glen Seier 16		

Note: RT film was picked up at the manufacturer's facility by OPPD Tom Muff

# SIGMA, INC. 1295 HWY 62 <u>CHARLESTOWN IN 47111</u>

# **CERTIFICATE OF CONFORMANCE**

SIGMA SALES ORDER NO: CUSTOMER: PURCHASE ORDER/CONTRACT NO.: 8904 OPPD-FORT CALHOUN

Contract No.120818 Purchase Order No. 120934

#### **Products**

QTY	LI#	CUSTOMER'S	DESCRIPTION
		STOCK #	
1	1	00001302011	VALVE, WAFER BUTTERFLY, 20", ASME B16.34
			150# CLASS, ASIM ASSI GRADE CF8M BODY AND
			DISC, POSI-SEAL FIGURE ASTA, SERIAL NUMBER
		Í	16988576 (ND2)

SIGMA CERTIFIES THAT THE ITEMS LISTED ABOVE WERE PROCURED BY OPPD FORT CALHOUN AS COMMERCIAL GRADE ITEMS AND DEDICATED BY SIGMA AS A BASIC COMPONENT AS PROVIDED FOR IN 10CFR PART 21. THE DEDICATION PROCESS WAS CONDUCTED IN ACCORDANCE WITH SIGMA'S 10CFR50 APP. B QUALITY ASSURANCE PROGRAM REV. 7, DATED 3/09/2008.

SIGMA CERTIFIES THAT THE ITEM(S) SUPPLIED MEET THE REFERENCED PO REQUIREMENTS EXCEPT FOR THE FOLLOWING:

#### NCR 48 FOR UNACCEPTABLE PT EXAMINATION RESULTS APPLIES TO THIS VALVE AND FINAL DISPOSITION HAS NOT BEEN DETERMINED.

#### STORAGE LEVEL IS ANSI N45.2.2 LEVEL: C

NDE was verified by method 3, source surveillance, at CONAM. Surveillance records are not part of the Documentation Package and are on file at Sigma and available for inspection. All NDE Reports showing item identification as Wafer #1 and Disc #1 is valve serial number 16988575 (Dedication I.D. ND1). All NDE Reports showing item identification as Wafer #2 and Disc #2 is valve serial number 16988576 (Dedication I.D. ND2).

QUALITY ASSURANCE MANAGER:

Joseph a Bastone

 $( \mathcal{T} )$ 

DATE: 5/15/08

.\*.

# SIGMA, INC. 1295 HWY 62 CHARLESLTOWN, IN 47111

2

# HYDROSTATIC TEST REPORT

Test Procedure:	QAP-6 Rev. 4
Serial Nos.	16988576 (ND2) Reference: S08904
Description:	VALVE, WAFER BUTTERFLY, 20", 150#, ASTM A351, CF8M BODY AND DISC. SUPPLIED BY CUSTOMER
Test Criteria:	ASME/ANSI B16.34 MSS-SP61
Test Gauge No.	B407 @ INSTRUMENT AND VALVE SERVICES
Calibration Due Date:	09-11-08

Test Medium: WATER

Shell Test Pressure: (PSIG)	450				
Shell Test Duration:	10 MINUTES			•	
Acceptance Criteria:	Zero leakage				
Shell Test Results:	Passed			<b>***</b> ,	
Seat Test Pressure: (PSIG)	325				
Seat Test Duration:	2 MINUTES				
Acceptance Criteria: (ml/hr)	ZERO (0) LEAK	AGE			
Actual Seat Leakage:	S/N16988576				
(ml/hr)	0				
I certify that the abov	e results to be corr	ect and a	ccurate as	tested.	
Test Performed By:	INSTRUMENT A SERVICES	ND VAL	VE	Date: 05-14	1-08
Test Observed By:	STEVEN WELLS	S			

LIC-08-0066, Attachment 4

# DEDICATION PLAN Dedication of Butterfly Valves For Use In Nuclear Safety Related Applications Dedication Code: ND

÷.,

# TABLE A MATERIAL TRACEABILITY RECORD

SERIAL NUMBER	HEAT	CODES
	BODY	DISC
16988575	X651	¥3439
16988576	W114	¥4179
10,000,0	11 4 4 1	

۱





Inspection & Engineering Services, Inc.

A Member of MISTRAS Holdings Group

### Certificate of Positive Material Identification

Cust. Order #: (	G-11082		Work Ore	der #: 156	103			Date:	5/11/0	8		Page:	1	of 1
Customer.							1000	Purchas	e Order	Namb	ər:			an a state of the second s Second second
									te de la Constitución a s	Kasa	20040	)63035		and the second second second
Instrument & Va	ve Services	Company	L		nn			ttem De	scription			<u></u>	an a	a ser a segur da Ser a segur da segur
4320 West 166"			·			<u> </u>		Sector Sector	D	NSC & I	Sody,	vvater Ca	astings	ine din matter
Oak Forest, IL 604				·				Surface	Congitto		<u>. </u>	orm:	<u>, te</u> i	nperature:
Exam 8	ngoification	Endos			Dimo	oqueo		Partial	Machini	<u>19</u>	. U	asting	nteda	04 F
<u>کم (</u>	TM F 1476 -	97			96-MC-0	103 Rev 1					ACET	Client In	nto	An and the article of
PMI Fauinment					00 10 0				<u> </u>			Onent in		
Instrum	ent Manufaci	urer 👫			lodel Numb	AF	2.58	Serial	Number		S	tandardi)	ation Res	ulls
INNOV	K-Ray Techno	logies			XT-260		- 10 - <b>- 1</b> 09	1	034	<u> 662 (S</u>	MA	cceptable	Unacc	eptable
Nominal Alloy Sp	cification	1	<b>9</b>	CA	W M	6 I 🕺 N	h	Cu .	Nb		¥. [	Zran	ि ग ः	Co
Material Description:	N/S													
	N/S						<u></u>				1		<u> </u>	
Test Results (Per	centage of allo	ying eleme	nts listed):			1.000	House and			N 99 90 20 -				
Jiem.	Mata. ID.		<u> </u> €# 1		Marca)	MO		20	ND 20	star V	<u>i in a seconda se</u>	<u> </u>		60
Body, Wafer #1	316 /Duplex	66.92	20.41	9.42	2.38	0.86	1		<u> </u>					
#V165856X012				0.1		- 0.00							1	
	·													
Body, Wafer #2	316 /Duplex	67.06	20.04	9.48	2.41	1.00								
#V165856X012					ļ	L	ļ						<b>_</b>	
<u> </u>				<u> </u>	<u> </u>	<u> </u>	<u> </u>			ļ				
Dine 44	246	69 04	10.70	0.00	1-010-	1 00			·				+	
UISC #1	310	00.01	19.79	0.99	2.19	1.02	<u> </u>			<u> </u>				
#1033437012					<u>+</u>	· · · · · · · · · · · · · · · · · · ·				<u>+</u>				
Disc #2	316	68.36	19.84	9.04	2.20	0.56	+			1		- <b>.</b>	1	-1
#V169943X012														
						ŀ								
						A CONTRACTOR OF A			<u>A</u>		1.7 x x . 7 x		AND DE LE	an a
Additional Inform	nion: Castin		ANY SURVEY				(SPA)		1/	Gerales.		HOLE E		
		<u></u>			<u> </u>	7	$f_{a}$	\#	<u> </u>					
Name:	Richard Gei	rhard Jr	Sic	anature:		V V	$\mathcal{H}$	SA			D	ate:	5/1	1/08
					• • • • • • • • • • • • • • • •	Second Second		$\mathcal{O}^{\pm}$						Form; PMI 01/05
161 T	ower Drive / L	Init: E / Bur	r Ridge, IL	60527 - Pho	one: (630) 23	30-3400 - Fa	ax: (6:	30) 230-3	408 – Int	ernet: <u>†</u>	http://w	ww.conar	ninsp.com	
					Ð									

------

LIC-08-0066, Attachment 4

	-+					+			47		-+-		1			1
opeea	Ko	URK	8	ok A	A	-		1.00	4			Kodak T				
Canad		7"	x 17	۳ ج. •		+	4	1.5" K	x 17	"	_	4.5" x 10"				]
r'L: Steel	On	par	t se	irfa	ce	1	On	ряг	t sui	face	•	On part surface	1		· · · · · · · · · · · · · · · · · · ·	
'L: Steel		30	& 3	5		$\downarrow$			12			30				
		J.	.75	•		$\perp$			75"			1.50"				
			11'	•		1		.1	11"			.111"				
		3	mir	n			1	min	15	sec	_	10 min				
			117					1	11"		-	19"				
	I	r-19	2/1	60 c	:i		Ir	-19	2/6	0 ci		Ir-192 / 60 ci				
	V-	-1,	2,	3,	, 4		V-	•5,	6,	7, 1	8	V-9, 10				
							T	EC	HN	IQI	JE		SM	1. EDI	VELOP	
V- 10	1	_ √														
V-9	1	V														
V- 8	1	V										L	· · · · · · · · · · · · · · · · · · ·			
V -7	1	V											1915 - 1925 - 1915	an tradication a pro-	a 90 Marina Marina Marina ang Pangarang Pangarang Pangarang Pangarang Pangarang Pangarang Pangarang Pangarang Pan 1990 Marina Ma	
V- 6	1	V			1			-						* **** * ****		
V-5	1	V			-	$\square$		$\neg$				WA				
V-4	1	V		-	·						1					
Y-3	1	ti		1	1											
V-2	1	ţ		1	$\frac{1}{1}$											
V-1	VII.	Accep	Reject	GAS (A	T SAND	SHRINI	SHRJNI	SHRINI	SHRJNI	Hot Tca	Film Ar		1.			
Vicw	V OVERALL GRADE			2	(B)	<, T1 (CA)	C, T 2 (CB)	ς T3 (cc)	<, T4 (CD)	rs & Cracks	tifact		TYPICAL	SKET	СН	
							nrs	PO	TI2	101	N					
ME B16.3	\$4- 200	)4										ASM Append	lix I - E44	2004 6, E28	0]	
									Ac	cep	tanç	e Criteria:	F R16 24	2004		
Body,	waier											Condi		uai m	acining	
¥ 105856	XULZ	-	[V]2	ate	121	.: -		20	158		-	Proj-Code: Condi	in/5	- JC Hal M	$\frac{1}{2}$	.1
ient & Val	vė Ser	v., (			A	\dd	lres CF	s: 78N	43 4 F	20 MS	We	st 166 <sup>th</sup> St / Oa	k Forest,	IL 60	452	1
enerie gritte	-											Page:	1 of	1		
												Purcha	se Order #:	2004	063035	
Suite: D	i											Work (	Order #:	1561	)3	
												Date:		5/11	/08	
M≣									,			RA	DIOGRA	PHY	CASTING	
	Non         Suite: B         Suite: B         Nent & Val         V1658566         Body,         ME B16.3         View         View         V-1         V-2         V-3         V-4         V-5         V-6         V-7         V-8         V-9         V-10         Speed	Suite: B         Suite: B         Suite: B         Suite: B         V165856X012         Body, Wafer         ME B16.34- 200         View         No         V-1         V-2         V-3         V-6         V-7         V-8         V-9         V-10         View         View         View         View         View         View         View         View         View	No.       Suite: B         Suite: B       Suite: B         Vent & Valve Serv., 1       V165856X012         Body, Wafer       Body, Wafer         ME B16.34- 2004       ME         View       ME         View       ME         View       ME         Voice       ME         V-1       N         V-2       N         V-3       N         V-4       N         V-5       N         V-6       N         V-7       N         V-8       N         V-9       N         V-10       N         V-10       N         Index       Index         V-10       N         V-10       N         V-10       N         Index       N         V-10       N         N       N         V-10       N         N       N         N       N         N       N         N       N         N       N         N       N         N       N         N <td>None       Suite: B         Suite: B       Suite: B         Suite: B       Suite: B         View       Suite: Co         View       Suite: B         Wiew       Suite: B         Wiew       Suite: B         View       Suite: Steel         View       Suite: Steel         Speed       Kodak T</td> <td>No.       Suite: B         Suite: B       Suite: B         Ient &amp; Valve Serv., Co       V165856X012       Mate.         Body, Wafer       Body, Wafer         ME B16.34- 2004       Suite: B         View       View       Suite: C         View       Suite: C       Suite: C         View       Suite: Steel       Suite: Steel         Speed       Kodak T &amp; A</td> <td>Nome       Suite: B         Suite: B       Suite: B         Suite: B       Suite: B         Ment &amp; Valve Serv., Co       A         V165856X012       Material         Body, Wafer       Material         Wiew       Material         View       Material         Wafer       Wafer         Wiew       Material         Wafer       Wafer         Wiew       Material         View       Material         View       Material         V-1       1         V-2       1       1         V-3       1       1         V-4       1       1         V-7       1       1         V-8       1       1         V-9       1       1         V-10       1       1     &lt;</td> <td>Nome       Suite: B         Suite: B       Suite: B         Suite: B       Suite: Serv., Co       Add         V165856X012       Material.:       Body, Wafer         ME B16.34- 2004       Sevential.       Sevential.         View       Nove Sevential.       Sevential.       Sevential.         V-1       1       V       Nove Sevential.       Sevential.         V-2       1       V       Nove Sevential.       Nove Sevential.         V-3       1       V       Nove Sevential.       Nove Sevential.</td> <td>Num       Suite: B         Suite: B       Suite: B         Nent &amp; Valve Serv., Co       Address         V165856X012       Material.:       Cr         Body, Wafer       DIS         Wiew       Total of the serve of the serve</td> <td>Numerical Suite: B         Suite: B         Suite: B         View       Address: CF8M         V165856X012       Material: 20         DISPO         View       OP         VIE       VIE       VIE         VIE          &lt;th colspan="&lt;/td&gt;<td>Suite: B         Suite: B         V165856X012       Material.: 20B58         Body, Wafer         View       Disposit         View       Suite: B         View       Suite: C         View       Suite: B         View       Suite: C         View       Suite: B         View       Suite: C         View       Suite: C       Suite: C       Suite: C         V-1       1       V       1       V         V-2       1       V       1       V         V-3       1       V       1       V</td><td>Suite: B         Suite: B</td><td>Numerical Superior Superi</td><td>RA         Date:         Work (Custom Purcha         Page:         Nent &amp; Valve Serv., Co       Address: 4320 West 166<sup>th</sup> St / Oz         View Kok (Custom Purcha         VI65856X012       Material:       20B58       Proj-Code:         Body, Wafer       Condi         Acceptance Criteria:         ME B16.34- 2004       Speed         View Material:       20B58       Proj-Code:         Proj-Code:         Acceptance Criteria:         ME B16.34- 2004         USPOSITION         View Material:       20 (<math>0</math> (<math>0</math>) <math>1 + 1 + 1 + 1 + 1 + 1 + 1 + 1 + 1 + 1 </math></td><td>RADIOGRAL         Date:         Work Order #:         Customer Order #:         Page: 1 of         Nent &amp; Valve Serv., Co       Address: 4320 West 166<sup>th</sup> St / Oak Forest,         V165856X012       Material:       20B58       Proj-Code: N/S         Body, Wafer       Condition: Par         Acceptance Criteria:         ME B16.34- 2004         TYPICAL         View       TYPICAL         Vi</td><td>RADIOGRAPHY [         Suite: B         Vicw Valve Serv., Co       Address: 4320 West 166<sup>th</sup> St / Oak Forest, IL 60         Vicw Valve Serv., Co       Address: 4320 West 166<sup>th</sup> St / Oak Forest, IL 60         Vicw Valve Serv., Co       Address: 4320 West 166<sup>th</sup> St / Oak Forest, IL 60         Vicw Valve Serv., Co       Address: 4320 West 166<sup>th</sup> St / Oak Forest, IL 60         Vicw Valve Serv., Co       Address: 4320 West 166<sup>th</sup> St / Oak Forest, IL 60         DISPOSITION         TYPICAL SKET         Vicw Valve Serv., Co       Address: 4320 West 166<sup>th</sup> St / Oak Forest, IL 60         Vicw Valve Serv., Co       Address: 4320 West 166<sup>th</sup> St / Oak Forest, IL 60         Vicw Valve Serv., Co       Address: 4320 West 166<sup>th</sup> St / Oak Forest, IL 60         Vicw Valve Se</td><td>RADIOGRAPHY (CASTING)         Suite: B       Suite: S</td></td>	None       Suite: B         Suite: B       Suite: B         Suite: B       Suite: B         View       Suite: Co         View       Suite: B         Wiew       Suite: B         Wiew       Suite: B         View       Suite: Steel         View       Suite: Steel         Speed       Kodak T	No.       Suite: B         Suite: B       Suite: B         Ient & Valve Serv., Co       V165856X012       Mate.         Body, Wafer       Body, Wafer         ME B16.34- 2004       Suite: B         View       View       Suite: C         View       Suite: C       Suite: C         View       Suite: Steel       Suite: Steel         Speed       Kodak T & A	Nome       Suite: B         Suite: B       Suite: B         Suite: B       Suite: B         Ment & Valve Serv., Co       A         V165856X012       Material         Body, Wafer       Material         Wiew       Material         View       Material         Wafer       Wafer         Wiew       Material         Wafer       Wafer         Wiew       Material         View       Material         View       Material         V-1       1         V-2       1       1         V-3       1       1         V-4       1       1         V-7       1       1         V-8       1       1         V-9       1       1         V-10       1       1     <	Nome       Suite: B         Suite: B       Suite: B         Suite: B       Suite: Serv., Co       Add         V165856X012       Material.:       Body, Wafer         ME B16.34- 2004       Sevential.       Sevential.         View       Nove Sevential.       Sevential.       Sevential.         V-1       1       V       Nove Sevential.       Sevential.         V-2       1       V       Nove Sevential.       Nove Sevential.         V-3       1       V       Nove Sevential.       Nove Sevential.	Num       Suite: B         Suite: B       Suite: B         Nent & Valve Serv., Co       Address         V165856X012       Material.:       Cr         Body, Wafer       DIS         Wiew       Total of the serve	Numerical Suite: B         Suite: B         Suite: B         View       Address: CF8M         V165856X012       Material: 20         DISPO         View       OP         VIE       VIE       VIE         VIE          <th colspan="</td> <td>Suite: B         Suite: B         V165856X012       Material.: 20B58         Body, Wafer         View       Disposit         View       Suite: B         View       Suite: C         View       Suite: B         View       Suite: C         View       Suite: B         View       Suite: C         View       Suite: C       Suite: C       Suite: C         V-1       1       V       1       V         V-2       1       V       1       V         V-3       1       V       1       V</td> <td>Suite: B         Suite: B</td> <td>Numerical Superior Superi</td> <td>RA         Date:         Work (Custom Purcha         Page:         Nent &amp; Valve Serv., Co       Address: 4320 West 166<sup>th</sup> St / Oz         View Kok (Custom Purcha         VI65856X012       Material:       20B58       Proj-Code:         Body, Wafer       Condi         Acceptance Criteria:         ME B16.34- 2004       Speed         View Material:       20B58       Proj-Code:         Proj-Code:         Acceptance Criteria:         ME B16.34- 2004         USPOSITION         View Material:       20 (<math>0</math> (<math>0</math>) <math>1 + 1 + 1 + 1 + 1 + 1 + 1 + 1 + 1 + 1 </math></td> <td>RADIOGRAL         Date:         Work Order #:         Customer Order #:         Page: 1 of         Nent &amp; Valve Serv., Co       Address: 4320 West 166<sup>th</sup> St / Oak Forest,         V165856X012       Material:       20B58       Proj-Code: N/S         Body, Wafer       Condition: Par         Acceptance Criteria:         ME B16.34- 2004         TYPICAL         View       TYPICAL         Vi</td> <td>RADIOGRAPHY [         Suite: B         Vicw Valve Serv., Co       Address: 4320 West 166<sup>th</sup> St / Oak Forest, IL 60         Vicw Valve Serv., Co       Address: 4320 West 166<sup>th</sup> St / Oak Forest, IL 60         Vicw Valve Serv., Co       Address: 4320 West 166<sup>th</sup> St / Oak Forest, IL 60         Vicw Valve Serv., Co       Address: 4320 West 166<sup>th</sup> St / Oak Forest, IL 60         Vicw Valve Serv., Co       Address: 4320 West 166<sup>th</sup> St / Oak Forest, IL 60         DISPOSITION         TYPICAL SKET         Vicw Valve Serv., Co       Address: 4320 West 166<sup>th</sup> St / Oak Forest, IL 60         Vicw Valve Serv., Co       Address: 4320 West 166<sup>th</sup> St / Oak Forest, IL 60         Vicw Valve Serv., Co       Address: 4320 West 166<sup>th</sup> St / Oak Forest, IL 60         Vicw Valve Se</td> <td>RADIOGRAPHY (CASTING)         Suite: B       Suite: S</td>	Suite: B         V165856X012       Material.: 20B58         Body, Wafer         View       Disposit         View       Suite: B         View       Suite: C         View       Suite: B         View       Suite: C         View       Suite: B         View       Suite: C         View       Suite: C       Suite: C       Suite: C         V-1       1       V       1       V         V-2       1       V       1       V         V-3       1       V       1       V	Suite: B         Suite: B	Numerical Superior Superi	RA         Date:         Work (Custom Purcha         Page:         Nent & Valve Serv., Co       Address: 4320 West 166 <sup>th</sup> St / Oz         View Kok (Custom Purcha         VI65856X012       Material:       20B58       Proj-Code:         Body, Wafer       Condi         Acceptance Criteria:         ME B16.34- 2004       Speed         View Material:       20B58       Proj-Code:         Proj-Code:         Acceptance Criteria:         ME B16.34- 2004         USPOSITION         View Material:       20 ( $0$ ( $0$ ) $1 + 1 + 1 + 1 + 1 + 1 + 1 + 1 + 1 + 1 $	RADIOGRAL         Date:         Work Order #:         Customer Order #:         Page: 1 of         Nent & Valve Serv., Co       Address: 4320 West 166 <sup>th</sup> St / Oak Forest,         V165856X012       Material:       20B58       Proj-Code: N/S         Body, Wafer       Condition: Par         Acceptance Criteria:         ME B16.34- 2004         TYPICAL         View       TYPICAL         Vi	RADIOGRAPHY [         Suite: B         Vicw Valve Serv., Co       Address: 4320 West 166 <sup>th</sup> St / Oak Forest, IL 60         Vicw Valve Serv., Co       Address: 4320 West 166 <sup>th</sup> St / Oak Forest, IL 60         Vicw Valve Serv., Co       Address: 4320 West 166 <sup>th</sup> St / Oak Forest, IL 60         Vicw Valve Serv., Co       Address: 4320 West 166 <sup>th</sup> St / Oak Forest, IL 60         Vicw Valve Serv., Co       Address: 4320 West 166 <sup>th</sup> St / Oak Forest, IL 60         DISPOSITION         TYPICAL SKET         Vicw Valve Serv., Co       Address: 4320 West 166 <sup>th</sup> St / Oak Forest, IL 60         Vicw Valve Serv., Co       Address: 4320 West 166 <sup>th</sup> St / Oak Forest, IL 60         Vicw Valve Serv., Co       Address: 4320 West 166 <sup>th</sup> St / Oak Forest, IL 60         Vicw Valve Se	RADIOGRAPHY (CASTING)         Suite: B       Suite: S

ored wishes any warranty. Any flability is Buildes to the amount paid for the services at izue. All orders are append to Constitute Standard Torse and Conditions of Sale, which are available upon request

RI-1 9-8-00

1

5 NO.3

LIC-08-0066, A	Attachme	nt 4											CERT	IFICATE	OF I	NSPECTION
CONA	M 🗐												RAI	DIOGRAF	HY [	CASTING]
													Date:		5/11	/08
7081 Westview Avenue 5	inte: D												Work C	)rder #:	15610	)3
NUT HOU2DD, LL. 004/3	ţ	:											Custor	er Order #:	<u>G-1</u>	1082
10-339-0937 194X 1437													Purchas	se Order #:	2004	063035
ww.commisp.com		nic webser											Page: _	of	1	-
Customer: Instrum	ent & Val	ve Serv	r., (	Co	-	A	.dd	res	ร: จา <i>ม</i> ั	43	20 T	Wes	st 166 <sup>th</sup> St / Oa	k Forest, I	L 60	452
Item Part No.:#: _	V165856	X012		Ma	teri	al	:		201	B58		]	Ptoj-Code:	N/S	Se	rial #:
Casting Description:	Body,	Wafer											Condu	ion: Part	ial M	achining
Specification/Code:										Ac	cep	tanc	e Criteria:			
ASI	ME <b>B</b> 16.	34- 200	)4			-							ASM Appendix	E B16.34-2 I - E446, I	2004 E186, I	E280]
							I	DIS	PO	SIT	101	Y				
IDENTIEIC ATION	View	VERALL VDE					1 (CA)	2 (CB)	3 (CC)	4 (CD)	Cracks		T	YPICAL S	KET	СН
DEMINEATION	TILH	VIEW O' GRU	Accept	Reject	GAS (A)	SAND (B)	SHRINK, T	SHRINK, T	SHRINK, T	SHRINK, T	Hot Tears &	Film Artifac				
V165856X012 -1	V -11	1	$\checkmark$		1	1										
Body, Wafer	V-12	1	$$		1								1000 - 1000			
	V - 13	1	V			-1								ې د او کې د مېږو و د ولو د د د د د د د د د د د د د د د د		創業業計画
OTE:																
Composite View VII						†		+	-+				Spin 1	1920 - 5		TI is
ourposite view vii	<b> </b>	<b> </b>				-				_	-+					
or areas around boit			$\vdash$						-+		-+			a tha initiation and a state of the state of	2 8 4 4 4 8 5	
ioles.		ļ	$\square$				_	$\rightarrow$						¢.	W <sup>2</sup> John Column - St S = 12 V 1 1 2	
							_									
								T								
								TI	C	HN	IQI	UE		50M	NDI	YELOP
liews	2		V	-1	1				V	-12	?		V-13			
iotope / Curies		C	:o-6	0/1	6 ci			C	o-6(	071	6 ci		Co-60 / 16 ci			
.F.D.			2	23"					2	:3"			29*			
xposure Time			30	mi	D				30	mi	5		90 min	1		
ffective Focal Spot Size				84"				-	.1	84"			.184"	1		
CTUAL Thickness (S)			3.0"	- 4	.2"		1-	1	.25	" _ (	<b>;</b> "	$\neg$	4.2" - 5"			
enetrameter (s) Mat	L: Steel		30.	45.	50		1-		20	30. 4	0		60. 70			
enetr. Blocks (s) Mat	1: N/A				rfar			0 m		, - t e = -	-far-	-+	On nart eurface			<u>├──</u> ─────────
ilm Size (4)			147	× 1'	7"		<b>†</b> -'	1	14"	v 17		-				
ilm Sneed (c) MEC 14	Sneed	- n	47 5 F			7	-	 D 4	17 17	× 1 / 80	<u>n 7</u>	$\rightarrow$	/ XI/"			
na opeca jaj mr 6 / 2			<u> </u>	- 00,			+	<i>D</i> -:	<u>д</u> Г	- <i>3</i> 0,	U-1					
umper of Film Used		-		<u>د</u>	<u></u>		+-		_	<u>ح</u> م			2	<u>.</u>		
cadiographic Quality Lev	el		2-	- 21			<u>بر</u>	_	2-	- 2T			<u>/2-2T</u>			}
		τ				-						-			-	

RI

LIC-08-0066.	Attachme	nt 4														
	na É												CERI	TIFICATE	OF I	NSPECTION
CUNA													RA	DIOGRAI	'HY Į	UASTING]
17081 Westview Avenue	Suite: B												Date:	Ordar #1	<u>-5/11</u> 1561	/08
South Holland, IL. 6047	3	:											Custor	ner Order #	G.1	1082
708-339-0957 Fax: - 723	7										÷		Purcha	ise Order #:	2004	063035
www.conaminsp.com		:											Page:	1 of	1	
		1									-					-
Customer: Instruc	nent & Va	ve Ser	v., (	Co		A	١dc	lres	58:	43	20	We	st 166 <sup>th</sup> St / Oa	ak Forest, l	L 60	452
Item Part No.:#:	V165856	X012		M۵	iter	rial	:	CI	F8N 20	4 Fl B58	MS		Proj-Code:	N/S	Se	rial #: <u>-2</u>
Casting Description	: Body,	Wafer											Condi	tion: Par	tial M	achining
Specification/Code:		1								Ac	cep	tang	e Criteria:			
AS	SME B16.:	<b>34- 20</b> 0	04	,									ASM	E B16.34-	2004	
													Appen	dix I - E44	6, E2	30]
		<u>.</u>						DIS	SPC	)SII	10	N	in a shine of the second s			
	T	1	Τ	Γ	Γ						Γ		T			
		Ę					S	ଳ	6	â	υ			TYPICAL	SKET	НЭТ
		DE KA			ŀ		Q	Q,	ğ	ij	PE				SILLS I	Ch
IDENTIFICATION	View	2₹				<u>چ</u>	Ē	F	F	¥.	2	laci l	ZAAMIR MILES		r it sijne	
		A B B	Ept	Įž	ß	ő	X	ХX	X	ž	Car	And				
		>	20	Rej	SAS	NY.	HR	SHRU	SHR	HR	ĕ	E I				
VICERECVALA A				F	Ĕ	Ľ	-	-	Ľ	•,						
V 105850A012 -2	V-7	4			<b> </b>		2					<u> </u>				
Body, Waler	V-4				-	<u> </u>								· Andrewski - · ·		
	V- 3		V I		1	1	1									
	V-4		<u>۷</u>	<u> </u>	Į	1					<u> </u>					
	V- 5	1	<u>√</u>		ļ									C St. Start	, j	
	V- 6	1	$ $ $\vee$		1		_								કરે	
	V -7	1	V											· · · · ·		
	V- 8	1	$ $ $\checkmark$													
	V- 9	1	$ $ $\checkmark$		1											
	V- 10	1	V		1											ſ
		1						T	EC	HN	10	UE		SM	INSPT	NIEL OP
Views		V.	.1	2	3	4		v.	5	6	7	8	V-0 10	156959[C3		
lentone (Curies	~~~~		- 10	<u>~</u> ,	5	) T 	┾		. 10	<u>v</u> ,	* <b>9</b>	<u> </u>				
SED			1-12	117				11	r-17	117	0 01		10"			
Fynasiira Tima		<b>└- </b>	•	ي ي - 1 مير			+						19"			<b> </b>
Exposure time		<u> </u>	3	at 11	4		+	1	m)(	1 15	sec		10 min			ļ
Effective rocal Spot Size				[1]'			╉			11"			.111"			<b> </b>
ACTUAL Thickness (S)		<b></b>	1	.75"			+		•	75"			1.50"	·		<b> </b>
Penetrameter (s) Ma	t'L: Steel		30	å 3	55		$\downarrow$			12			30	<u> </u>		ļ
Penetr. Blocks (s) Ma	it'L: Steel	On	PAI	t sc	rfa	ce	╀	On	par	t su	rfac	e	On part surface			
Film Size (s)			7°	<b>x</b> 17	<b>7</b> "				<b>4.5</b> "	x 17	"		4.5" x 10"			
Film Speed (s) MFG /	Speed	Ko	dak	T	& A	A			Koc	lak	T		Kodak T			
Number of Film Used				8						4			2			
Radiographic Quality Lev	vel		2	- 27	r				2 -	- 4T			2 - 2T			
Technician : [Print]			1	Tecl	hŋjc	iΑ	[S	gna	ture	11	)	~	1	Level:	Date	:
Richard Ge	rhard Jr			1	R	X	1		. /	H		(	l = l	III	1	5/11/08
This render is not to be construed as a memory a	e unservery of the courts	on of the street						- C	-			<u> </u>				

1997

rendered without are parameter or marine or we composed to the services at sense. Common autocome to the services are endpected without are parameter or to any economic and the services at sense. The services are endpected without are marine or selection or constitution or constitution of Sale, which are available upon respect

 $\overline{\mathcal{O}}$ 

LIC-08-0066, A CONA 17081 Westview Avenue S South Holland, IL. 60473 708-339-0957 Fax: - 7237 www.conaminsp.com Customer: Instrum Item Part No.:#: Casting Description:	Attachmer M Suite: B ent & Val V165856 Body,	ve Serr X012 Wafer	v., (	Co Ma	ter	A ial		res CF	s: 78N 20]	43 1 Fi B58	20 MS	We	CERTIFICATE RADIOGRAP Date: Work Order #: Customer Order #: Purchase Order #: Page:1 of t 166 <sup>th</sup> St / Oak Forest, I Proj-Code:N/S Condition:Part	OF II HY [ 5/11 15610 G - 1 2004 1 L 60 Serial M	NSPECTION CASTING] /08 063035 - 452 mal #:2 achining
ASI	ME B16	4- 200	)4					ž			2		ASME B16.34- 2	004	
1103			•		7								Appendix I - E446, I	£186, I	E280]
							J	ois	PO	SIT	101	N			·
IDENTIFICATION	View	VIEW OVERALL GRADE	Accept	Reject	GAS (A)	SAND (B)	SHRINK, T1 (CA)	SHRINK, T 2 (CB)	SHRINK, T3 (CC)	SHRINK, T4 (CD)	Hot Tears & Cracks	Film Artifact	TYPICAL S	KET(	СН
V165856X012 -2	¥ -11	1	$\checkmark$		1	1									
NOTE: Composite View V11 for areas around bolt holes.	V - 13	1	<b>√</b>									· · ·			
								TI	CC)	ΗN	IQI	UE	SIVI	NOR	MELOP
Views	1		V	-1	l			-	V	-12	2		V-13		
Isotope / Curies		C	:0-6	0/1	6 ci	i		С	0-6	0/1	6 ci		Co-60 / 16 ci		
S.F.D.			2	23"					2	13"			29*		
Exposure Time	t		30	mi	n		_		30	mi	0	$\square$	90 min		
Effective Focal Spot Size			.1	84"			-		1.	84"			.184"		
ACTUAL Thickness (S)			3.0"	- 4.	2"		╇	1	1,25	" (	\$ <sup>19</sup>		4.2" - 5"		
renetrameter (s) Mat	L: Steel	+	30, 4	45, 5	80		-		z0, :	30, 4	HO 	-	60, 70		
Film Size (-)	'L: N/A		par 14"	τ su			+-'	Un .	par	t su	rfac	e	On part surface		
Film Sneed (s) MEC / S	ineed		14" 5 P	x 17 .40	<u> </u>	7	+	<b>D</b> 4	14" . F	x 17	n 4	+	7" x 17"		
Number of Film Hed	preu		, <b>r</b> .	3	U		+	U-3	), F	-50, 3	U~/		1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1		·
Radiogranhie Auslity 1 au	el		2 -	- 2T			+		2 -	- 2T			2 – 2T		
Technician : [Print] Richard Ger	hard Jr	_1	1	Fech	t		[Si	gnai 4	ture	le	(	<u>`</u>	Level:	Date	5/11/08

.

LIC-08-006 CON 17081 Westview Av South Holland, IL. (708) 339-0957 Fa www.conaminsp.cc	66, Attachmer AMM enue / Suite: B 60473 x#: -7237 pm	at 4		· ,		Da Wc Cu Pu Pag	CERTIFICA LIQUIE te: ork Order #: stomer Order cchase Order # ge:0	TE OF INS <b>PENET</b> 5/10/(156103) #: G - 110 #: 200406 f 1	PECTION RANT 98 182 13035
Customer: Inst	rument & Va	ve Services	Company	<u>/</u>	Locatio	n: <u>Conan</u>	1 & ES, In	c. / S. Holla	und, IL
Street Address:	4320 West 10	6th Street	(0.453		Contact	Stella	NIL CEDEC	¥013	
City: Oak Fores	t State:	<u>IL</u> Zip	00452		Pan No	/ nem No:	¥105850	AUI4	
Description:	body, water	·	<u></u>						م من
Fluorescent     Solvent Rem     Post Emulsif	ovable ied: 🗌 Hydroph	Water Wash	ohilic		A 🛛	led Visible Dy	e 🗌 Wate 🛛 Solve 🗌 Post	er Wash ent Removat Emulsified	ble
Post Emulsif	ied (High Sensit	ivity)				other:			
Specification/Code		Accepta	nce Criteria			Procedure		Test 7	emperature:
ASME I   ASTM	B16.34 E 165		ASME B	16.34 ix [[] ]		100	)-PT-001		65° F
Equipment /	Material Dat	a:					·		
	Manufac	turer		Туре		Batch N	umber(s)	Applic	ation Method
Cleaner:	Magna	Πυχ	S	$\frac{1}{KC-S}$		07E	16K	Spr	av / Wipe
Penetrant:	Magna	Aux	SK	L - SP1		04F	10K		Brush
Developer:	Magna	flux	Sh	(D – S2		07A	05K	Lig	ht Spray
Emulsifier:	N/A			N/A		N/	'A		N/A
Black Light:	Meter Model:	N/A		Serial	#:	N/A	Output:	N/A	µW/cm <sup>2</sup>
Visible Light	Meter Model:	DSE-100)	(	Serial	#: 169	910	Light Leve	el: > 100 Foc	ot Candles 🛛
Technique D Pre-Clean Time: 5 min	ata: utes	Dwell Tim	e: O minutes	-	Emulsi	fier Time: N/A	D	eveloper Tin 10 m	inutes
Temperature G	age: Serial #:	403-08	2-0774	Cal Du	e:	9/14/08	Water Pres	isure:	N/A
Test Material In	ifo: Type:	CF8M F	MS 20B58	Thickn	ess:	Various	Water Tem	perature:	N/A
Test Results: Visible- Solven	t Removable I	Quant bye Penetrar	ity Inspected at Inspectio	l: 2 n was p	Qua	ntity Accepted d on (2) – B	: 0 ody, Wafers	Quantity Rej Item #: V	ected: 2 165856X012
( Machined Fac	es only) with t	he following	g results:	SEE A	TTACH	ED PHOTOS F	OR SPECIFIC	C DEFECT L	OCATIONS
Body, Wafer #           a)         (1) pore was           b)         (4) areas of	<u>1 was rejected</u> as found on the g f concentrated po	for: asket seating : rosity were fo	surface that to bund to have	exceeded multiple	the .500" locations	diameter size r that exceed the	estriction for a	over .75" in the second	bickness. e criteria.
Body, Wafer # c) (2) pores w	2 was rejected ere found on the	for: nner I.D. sur	face that exc	eeded the	e .500° di	ameter size rest	riction for over	r .75" in thicl	kness.
NOTE: NO m	concentrated pol	int size disc	ontinuity	was not	ed in th	e ASME B16	(4) or more p 5.34 Standau	ores in a line rd.	criteria.
Technician [Print] Richar	d Gerhard Ji		Fechorician IS	ignafure)	R	SL	Level:	III Date	5/10/08

This report is not to construct as parately or varianty of the construction of the enternal black. Cleand induction cleands to do the optical and construct of the synthesis and the construction of the enternal black. Cleand inductions are backet to do the second black which are weaked without the second black.

9

LIC-08-0066,	Attachme	ent 4						÷				: :			
	88 <i>-</i>										CERT	IFICATE	OF II	NSPECTION	
CUNA											KAI Date:	JIUGRAP	пт (ч 5/11	/08	
7081 Westview Avenue	Suite: B										Work C	rder #:	15610	)3	-
outh Holland, IL. 60473											Custom	er Order #:	G - 1	1082	-
08-339-0957 Fax: - 7237											Purchas	e Order #:	2004	63035	-
ww.conaminsp.com			7. <b>H</b>						-	مببوسه	Page:	<u>1</u> of	1	•	
	- <b>-</b> -			٦.		۸ ما م			170 X	V.	et 166 <sup>th</sup> St / Oal	k Forest T	L 60	452	
Customer: Instrum	V160043	We Serv	, ( ., (	<u>_0</u> Mat	eria	nuu L	11655	316	520	N C	Proi-Code:	N/S	Sei	-1	-
Casting Description:	Disc	20" / (	- Cla	ss: 1	50				<u>v</u>	•	Condit	ion: Part	ial M	achining	
Casting Description		-					-	A	ccent	9776	e Criteria:				- 7
Specification/ Code:											ASMI	E B16.34-2	004		1
AS.	ME B16.3	34- 200	14							,	[ Appendi	x I - E446	/ E18	36 ]	
							DISF	OSI	TION	1					
and a standard stand	1			Π	Τ	Γ	IT	Γ	Π			VPICAL	SKET	СН	
		ALL				(Y	(f)	3 ê	ş				JILE		
IDENTIFICATION	View	ADE				Ē	Ĕ.		5	#					
		SR OR	=		₹ le	2	Ξľ	i y	53	nifac		Well and the			l
		VIE	le:	ie.	219	N N	RIN N		Ę	Υm					ł
			Ĭ	Ř	3	SHS	2	E HS	f	Ξ					ľ
DISC	V -1	1	V		1										
V169943X012 -1	V- 2	1	V		1							ta (15			
	V- 3	2	V		1 2	2									
	V-4	1	V		1					1	100 C			The field	
	V- 5	2	1		2]]										1 1
	V- 6	2	V		2 1					۷					
													anne stran	an a	
													,		
es. At substantiate cannot						TI	ECH	NIQ	UE			5 MINI	)E,Ŷł	LOP- 70° F	
Viewe			V-	-1, 2	2		۲	/-1,	2		V-3156				
11643			$(\mathbf{E})$	кр-	1)		_(I	Exp	-2)		· ····································		·		
Isotope / Curies		C	Co-6	0/10	i ci		Co	60 /	16 ci		Co-60 / 16 ci				
S.F.D.				21"				21"			21*				
Exposure Time			16	i min				20 m	in		20 min				
Effective Focal Spot Size			.1	84"				.184	n		.184"	·			
ACTUAL Thickness (S)			90"	- 3.	"		2.	5" - 3	3.7"		. <del>9</del> 0" - 3.7"				
Penetrameter (s) Ma	l'L: Steel	17,	20,	25, 3	0, 50			50, 6	0		17, 20, 25, 30, 50				
Penetr. Blocks (s) Ma	t'L: N/A	On	pai	rt sur	face		On p	art s	urface		On part surface				
Film Size (s)		<u> </u>	<b>7</b> "	x 17'	•		7	" x 1	7"		14" x 17"			ļ	
Film Speed (s) MFG /	Speed	Ko	dak	ТЗ	AA		K	dak	ÅÅ	$\downarrow$	AgfaD5, F-50, D7	1			1
Number of Film Used	•	↓1		4		_		2			12				]
Radiographic Quality Lev	/el		2	- 2T	n;			2-2	T	t	2-2T		- T =		4
Technician · [Print]		ł		Tech	licit	n: [S	ignati	irej	<ol> <li>1)</li> </ol>		$\setminus (I)$	Level:	) Date	:	

(0)

					-				_						_	
LIC-08-0066, A CONA 17081 Westview Avenue S South Holland, IL. 60473 708-339-0957 Fax: - 7237 avvvv.conaminsp.com	Attachme	nt 4											CERT RA Date: Work Custor Purcha Page:	DIOGRAN DIOGRAN Order #: ner Order #: ise Order #: 1 of	OF I PHY   5/11 1561 <u>G -</u> 2004 1	NSPECTION [CASTING] //08 03 11082 063035
Customer: Instrum	ent & Val	ve Ser	v., (	Co		A	dd	res	s:	43	20	We	st 166 <sup>th</sup> St / Oa	ak Forest, l	L 60	0452
Item Part No.:#:	V169943	X012		Ma	ter	ial.	:		3	16			Proj-Code:	N/S	Se	erial #: -2
Casting Description:	Disc	20" /	Cla	ss:	15(	)							Condi	tion: Par	tial M	achining
Specification/Code:		<u>}</u>								Ac	cep	tano	e Criteria:			
ASI	ME B16.	34- 200	)4										ASM [ Append	E B16.34- : ix I - E446	2004 5 / E1	86 ]
			_				-	DIS	PO	SIT	101	N				
	<b></b>		Т				Ń	T	Ť		Ň	<u>`</u>	1			
IDENTIFICATION	View	VIÊW OVERALL GRADE	Accept	Reject	GAS (A)	SAND (B)	SHRINK, T I (CA)	SHRINK, T2 (CB)	SHRINK, T3 (CC)	SHRINK, T 4 (CD)	Hot Tears & Cracks	Film Artifact		FYPICAL	SKE	ICH
DISC	V -1	1	V													
V169943X012 -2	V-2	1	V				-	-+	-							
and the second	V-3	1	V					-+	-+					• tion of the lines	5. P. S.	Register -
	V -4	i	J		1				-+					بې د د د د د د د د د د د د د د د د د د د		
	V-5	<u> </u>	j		Ĥ		-	-+	-							
	V- 6	1	1									1		and the second second		
	AP.4															
							ΓE	CH	(N)	IQI	JE			5 MIN	DEM	61 (6)P- 7/09 E
Views			V- (Ex	-1, (p-	2 -1)			0	V- Ex	•1, (р-	2 2)		V-3,4,5,6			
lsotope / Curies		(	Co-6	0/1	16 c	1		C	-60	0/1	6 ci		Co-60 / 16 ci			
S.F.D.			2	21"					2	.1"			21"			
Exposure Time			16	mi	n		$\downarrow$		20	min	1		20 min			
Effective Focal Spot Size			.1	84"					.1	84"			.184"			
ACTUAL Thickness (S)			.90"	- 3	.7"			2	.5"	- 3.	7"	_	.90" - 3.7"			
Penetrameter (s) Mat	'L: Steel	17,	20,	25,	30,	50			50	, 60			17, 20, 25, 30, 50			
Penetr. Blocks (s) Mat	'L: N/A	On	par	t su	rfa	ce		01	раг	t sui	rfact	•	On part surface			
Film Size (s)			7"	x 17	*				7" ;	k 17'	*		14" x 17"			
Film Speed (s) MFG / S	Speed	Ko	dak	T	& A	A		ĸ	ods	k A	A		AgfaD5, F-50, D7			
Number of Film Used				4						2			12			
Radlographic Quality Leve	el		2 .	- 27	ſ				2 -	- 2T			2 – 2T			
				T	mth	ion	I CH			11 .				1 and	In	

(1)

N
ure:
ure:
ure:
ure:
ure:
thod
<u>e</u>
*/ cm*
<b>47 garner</b> 900
A
<u>A</u>
<u> </u>
1/00

(12)

LIC-08-0066, Attachment 4

# DEDICATION PLAN Dedication of Butterfly Valves For Use In Nuclear Safety Related Applications Dedication Code: ND

# **Table B Critical Dimensions**

Serial No.	End to End	Height	Diameter (R)	Bolt Circle	Weight (lbs)	MIN WALL'
	4.98-5.02	26.25 maximum	22.50-23.50	24.98-25.02	331-405	.51
16988575 ND1	5.00	25,79	22.88	25.0	363	1.16
16988576 ND2	5.00	25.84	22.56	25.0	358	1.18

Dimensions are in inches.

'Record smallest measurement on body

Caliper No.:	Calibration Due Date	;
DC0089	12/31/2008	
FCD24A	5/8/09	
Verify By:	Thello	Date: 5-14-08



#### LIC-08-0066, Attachment 4

#### Joe Barbera

A SAN BASI'S OF A MASON INCOMES AND A SAN	
From:	SEIER, GLEN R [gseier@oppd.com]
Sent:	Wednesday, May 14, 2008 6:12 PM
To:	joe@sigmappc.com
Cc:	Adam Gartner; Bernard Saucier; Earl Sullivan; John DeWitt; NICOLE BRETEY; Peter Donaldson; Robert Bunz; Russell Cowley; Thomas Muff
Subject:	Dedication Plan for Fisher 20" Wafer Butterfly Valves

Attachments: Dedication Plan 8904.doc

Joe,

The attached dedication plan has been reviewed and found acceptable. Sigma may continue with the remaining dedication items.

Thank you.

Glen R. Seier Supervisor Procurement Engineering / Procurement Quality Fort Calhoun Station (402)533-6540 gseier@oppd.com

From: Joe Barbera [mailto:joe@sigmappc.com] Sent: Wednesday, May 14, 2008 5:04 PM To: SEIER, GLEN R Subject:

Joe Barbera

This e-mail contains Omaha Public Power District's confidential and proprietary information and is for u mail is not a contract offer, amendment, nor acceptance. If you are not the intended recipient you are no

5/14/2008

### SIGMA, INC. POWER PLANT COMPONENTS NONCONFORMANCE REPORT **NCR NO. 48**

#### Nonconforming Condition:

Unacceptable indications were discovered during PT examinations of (2) valve bodies for 20" Posi Seal Butterfly Valves, Model A31A. The acceptance criteria was ASME B16.34-2004 Appendix III, See Conam PT Report Work Order 156103 attached. Photo's of indications have been sent to Fort Calhoun.

References: SO8904, Dedication ND, OPPD POs 120934 & 120818

#### Item description:

Qty (2) 20" butterfly valve bodies, ASTM A351 Grade CF8M material, Valve serial numbers 16988575 and 16988576, heat codes W114 and X651

Initiator: Jouph a Bashene

Date: May 13, 2008

□reject

**Disposition:** 

□rework  $\Box$  use as is 🗆 repair Forward NCR to OPPD Fort Calhoun for disposition

Reportable in accordance with 10CFR Part 21? Yes: No: X

Q A Manager Jouph a Barton

President:

Date: May 13, 2008

Date:

Is corrective action required to prevent recurrence? Yes: No: Probable cause:

Action taken to prevent recurrence:

Action taken on items prior to discovery:

Final review and close-out:

Date: Q A Manager:

(/5)

#### LIC-08-0066, Attachment 4

#### Joe Barbera

From: SEIER, GLEN R [gseier@oppd.com]

- Sent: Wednosday, May 14, 2008 6:24 PM
- To: joe@sigmappc.com
- C.: DYER, JOSEPH L; COSTELLO, JAY P; CLAYTON, OWEN J; Adam Gartner, Bernard Saucier, Earl Sullivan; John DeWitt; NICOLE BRETEY; Peter Donaldson; Robert Bunz; Russell Cowley, Thomas Muff

1.0

Subject: INFO: Fort Calhoun Disposition of NCR 48

#### Joe,

REFERENCE:

Contract / Purchase Order Number: 120818 / 120934 Subject: Two (2) Fisher 20 Inch Posi Seal Butterfly Valves, Model A31A

Regarding Sigma NCR No. 48 related to unacceptable PT indications on two (2) 20 inch water butterfly valve bodies, Fort Calhoun provides the following direction.

Fort Calhoun has been unsuccessful in Code reconclisation of the PT indications noted on Conam PT inspection report dated 2/10/08
 Fort Calhoun has begun the process of getting code exemption from the NRC. This process continues.

Therefore, Sigma is authorized to Accept-As-Is and ship valve ND-2, S/N 16988576 with the identified but yet unresolved PT indications. This waiver to the dedication plan is only valid for the the PT nonconformance. All other dedication critical characteristics shall be completed satisfactory as defined in Dedication Plan "Dedication of Butterfty Valves For Use in Nuclear Safety Related Applications" Dedication Code: ND.

Valve ND-1, S/N 18988575 shall be held by Sigma until further direction (Accept-As-Is or repair by welding) is provided by Fort Calhoun.

Currently, the Fort Calhoun Purchasing System is unavailable. A Purchase Order 120934 revision was to be generated to capture the above disposition and direction regarding NCR 48 along with a clarification that the Sigma's dedication plan is to be provided in part or whole to parallel to the Fisher manufacturing efforts. The Purchase Order revision will be processed as soon as the Purchasing System is available. This email is to suffice as direction for Sigma until Purchase Order 120934 can be revised.

Glen R. Seier Supervisor Procurement Engineering / Procurement Quality Fort Cahoun Station (402)533-6540 geler@oppd.com

From: Joe Barbera (maito:joe@xigmappc.com) Sent: Wednesday, May 14, 2008 2:57 PM To: SEIER, GLEN R Subject: CORRECTED NCR

Glen:

Attached is the corrected NCR.

Joe Barbera

This c-mail contains Omaha Public Power District's confidential and proprietary information and is for use only by the intended recipient. Unless explicitly stated otherwise, i mail is not a contract offer, amendment, nor acceptance. If you are not the intended recipient you are notified that disclosing, copying, distributing or taking any action in reli

(16

5/14/2008

20 24 SERIAL N Fishe
20 24 USTORE ERIAL N
20 24 JUSTOHE
20 24 USTOME
20 24 USTORE
20 24
20
18
16
14
SIZE

LIC-08-0066 Attachment 5 (4 Drawings)



,







REF.DWGS. P&ID E-23866-210-130 ISO IC 205 V, D-4273 I

FORT CALH	IOUN STAT	CON
I.S.I. B	ISOMETRIC - <b>37</b>	2
DWG. FIGURE B	<u>-37, SH. 1</u>	
REV.SH. 21296	APVD	REV
FILE 23423		8



















Product Bulletin 21.1:A31A October 2005

# A31A Valve

# POSI-SEAL<sup>®</sup> Type A31A High-Performance Butterfly Valve

The POSI-SEAL® Type A31A High Performance Butterfly Valve (figure 1) provides outstanding performance under extreme pressure and temperature conditions. The Type A31A valve maintains tight shutoff and is available in a fire-tested version.

The Type A31A valve is available as either a flangeless (wafer style) design or as a single-flange (lugged) design. A keyed drive shaft combines with a variety of handlevers, handwheels, or pneumatic piston diaphragm actuators to make the Type A31A a reliable, high-performance butterfly valve for a variety of on-off applications in the various process industries.

The Type A31A valve can be supplied with one of several dynamic seals (figure 2) that can be used in a variety of demanding applications. With the appropriate seal selection and materials of construction, the pressure-assisted seal provides excellent shutoff against the full ANSI class pressure range for the specific valve type.

Unless otherwise noted, all NACE references are to NACE MR0175-2002.

#### Note

Neither Emerson<sup>®</sup>, Emerson Process Management, Fisher<sup>®</sup>, nor any of their affiliated entities assumes responsibility for the selection, use and maintenance of any product. Responsibility for the selection, use and maintenance of any product remains with the purchaser and end-user.



Figure 1. Type A31A Valve with Bettis<sup>®</sup> Actuator and DVC6020 Digital Valve Controller





www.Fisher.com

# A31A Valve

### Specifications

Valve Sizes<sup>(1)</sup>

■ 14-, ■ 16-, ■ 18-, ■ 20-, and ■ 24-inch

#### **Available Valve Configurations**

■ Flangeless (wafer) style or ■ single-flange (lugged) control valve with a one-piece valve body, a two-component seal/backup O-ring, and a keyed drive shaft

#### **End Connection Style**

■ Flangeless style or ■ single flange valve body designed to fit between raised-face mating flanges per ASME B16.5 Class 150 or 300

#### Valve Body Classification

Face-to-face dimensions are in compliance with MSS SP68 and API 609 standards; valve bodies are designed for installation between ASME B16.5 Class 150 or 300 raised-face flanges

#### Maximum Inlet Pressure/Temperature<sup>(2)</sup>

Consistent with ANSI Class ■ 150 and ■ 300 pressure/temperature ratings per ASME B16.34. Also, see figure 3 for additional information

#### **Available Seal Configurations**

See figure 2 and table 1

#### **Standard Construction Materials**

See table 1

#### **Disc Coating**

Hardcoating (also see table 1)

■Standard when used with NOVEX<sup>™</sup> seal or Phoenix III® seal.

#### Shaft Extension Lengths

None required for temperatures less than 343°C (650°F), 152.4 mm (6 inches) for temperatures from 343 to 538°C (650 to 1000°F), or 304.8 mm (12 inches) for temperatures above 538°C (1000°F)

#### Shutoff Classification per ANSI/FCI 70-2 and IEC 60534-4

Standard Soft Seal: Bidirectional bubble-tight shutoff

NOVEX Seal: Unidirectional shutoff Class V (preferred flow direction only<sup>(3)</sup>) Phoenix III Seal: Bidirectional bubble-tight Phoenix III Seal for Fire Tested Applications: Shutoff per FCI 70-2 Class VI. Fire Tested per API 607 Rev. 4. Contact your Fisher sales office for more information.

#### Flow Characteristic

Modified equal percentage

#### Flow Coefficients and Noise Levels

See the section titled Coefficients in this bulletin and Catalog 12

#### **Available Actuators**

Handlever, handwheel, or pneumatic piston

#### Disc Rotation

Clockwise (CW) to close

#### Valve Dimensions and Approximate Weights

See figures 6, 7, 8 and 9

#### Options

ENVIRO-SEAL® PTFE or graphite packing system provides improved sealing, guiding, and transmission of loading force to control liquid and gas emissions. See Bulletin 59.3:041 ENVIRO-SEAL Packing Systems for Rotary Valves for more information.

Cryogenic extension and seal provides service down to -234°C (-425°F). See Bulletin 21.1:Cryogenic-Rotary for more information.

The valve sizes listed in this bulletin refer to Nominal Pipe Size (NPS).
 The pressure/temperature limits in this bulletin (figure 3), and any application code or standard limitation, should not be exceeded.
 For optimum seal performance, the preferred valve orientation at shutoff is with the retaining ring downstream from the high pressure side of the valve.

### Features

#### • Economical Tight Shutoff—The

pressure-assisted seal design provides tight shutoff and permits the use of smaller, less expensive actuators in applications requiring full ASME B16.34 shutoff capabilities.

• Excellent Shutoff Integrity—Concentric rotation helps to ensure that the valve disc remains in the closed position in spite of line pressure surges or actuator failure.

• **True Bi-directional Shutoff Performance**— Valve design helps to ensure that the torque necessary to open and close the valve is the same regardless of the direction in which the differential pressure is applied.

• **Safety**—Shaft blowout protection is designed into the Type A31A valve (figure 4). The anti-blowout gland fits securely over the valve shaft which has been turned down to form a circumferential shoulder that contacts the anti-blowout gland.

• Ease of Maintenance—Interchangeability of all parts including shafts and discs simplifies service and reduces maintenance costs.

• Improved Environmental Capabilities — The optional ENVIRO-SEAL packing system is designed with improved sealing, guiding, and loading force transmission. The ENVIRO-SEAL packing system can control emissions to below the EPA (Environmental Protection Agency) limit of 500 ppm (parts per million) for valves.

• Reliable Flange Gasketing Surface—Seal retainer screws are located so there is no interference with the sealing function of either flat sheet or spiral wound line flange gaskets.

• **Easy Installation**—The valve body self-centers on the line flange bolts as a fast, accurate means of centering the valve in the pipeline.



T FOR OPTIMUM SEAL PERFORMANCE, THE PREFERRED VALVE ORIENTATION AT SHUTOFF IS WITH THE RETAINING BING DOWNSTREAM FROM THE HIGH PRESSURE SIDE OF THE VALVE.

Figure 2. Available Seal Configurations

# A31A Valve



.

C0759-2 / IL

4

Figure 3. Maximum Pressure/Temperature Ratings







Figure 5. Typical Valve Assembly

# A31A Valve

Table 1. Materials of Construction and Temperature Ratings

COMPONE	ENT AND MATERIAL OF CONSTRUCTION <sup>(1)</sup>	TEMPERAT	JRE RANGE		
		°C	°F		
Valve Body <sup>(2)</sup>					
Carbon steel (WCC or SA	A 517-70) <sup>(8)</sup>	-29 to 427	20 to 800		
CF8M (316 SST) ANSI C	lass 150 and 300	-198 to 538	-325 to 1000		
CF8M <sup>(3)</sup> FMS 20B16 a Fi	sher material standard (0.04% min carbon) Class 300	over 538 to 816	over 1000 to 1500		
Diee					
WCC carbon steel for size	zes 14 through 24-inch	-29 to 427	20 to 800		
CF8M (316 SST)		-198 to 538	-325 to 1000		
CF8M <sup>(3)</sup> FMS 20B16 a Fi	sher material standard (0.04% min carbon) Class 300	over 538 to 816	over 1000 to 1500		
Disc Coating					
CoCr-A (Alloy 6)		-198 to 916	-325 to 1500		
Hard Coating <sup>(7)</sup> (Standard	d with NOVEX or Phoenix III Seals)	-254 to 538	-425 to 1000		
Shaft		· · ·			
S20910 (Nitronic 50)		-198 to 538	-325 to 1000		
S17400 (17-4 pH 1025)		-73 to 427	-100 to 800		
S17400 (17-4 pH H1150N	۸)	-196 to 427	-320 to 800		
N07718 (Inconel 718)		-254 to 704	-425 to 1300		
N07750 (Inconel 750)		over 593 to 816	over 1100 to 1500		
Bearings <sup>(6)</sup>					
PEEK (standard)		-73 to 260	-100 to 500		
S31600(4)		-198 to 816	-325 to 1500		
B20006 (Alloy 6)		100 to 010	325 to 1500		
R30000 (Alloy 0)		-198 (0 810	-323 10 1500		
Bronze		-254 to 302	-425 to 575		
Packing			005 / 150		
PTFE Packing and PTFE	ENVIRO-SEAL Packing	-148 to 232	-325 to 450		
Graphite packing	aliais a suco dia	-198 to 916 -325 to 1500			
Graphite ENIVIRO_SEAL	Packing	-148 to 315	-325 to 600		
	Nitrile Realize O Bing	-29 to 93	-20 to 200		
	Neoprene Backup O-Ring	-43 to 149	-45 to 300		
	EPR Backup Q-Ring	-54 to 182	65 to 360		
	Fluoroelastomer Backup O-Ring	29 to 204	-20 to 400		
	PTFE Backup O-Ring	-73 to 204	-100 to 400		
	UHMWPE(5) Seal Ring (Class 150 Only)				
	Nitrile Backup O-Ring	-29 to 93	-20 to 200		
Seal Ring and Backup	Neoprene Backup O-Ring	-43 to 93	-45 to 200		
Ring	EPR Backup O-Ring	-54 to 93	-65 to 200		
	Fluoroelastomer Backup O-Ring	-29 to 93	-20 to 200		
	PTFE Backup O-Ring	-73 to 93	-100 to 200		
	Phoenix III and/or Fire Tested Construction				
	S31600 and PTFE Seal Ring with Nitrile Backup O-Ring	-40 to 149	-40 to 300		
	Neoprene Backup O-Ring	-54 to 149	65 to 300		
	EPR Backup O-Ring	62 to 204	-80 to 400		
	Fluoroelastomer Backup O-Ring	40 to 232	-40 to 450		
	NOVEX S31600 Seal <sup>(4)</sup> Ring (Class 150)	29 to 816	-20 to 1500		
Seal Ring	NOVEX S31600 Seal <sup>(4)</sup> Ring (Class 300)	-29 to 816	20 to 1500		
	NOVEX S21800 Seal <sup>(4)</sup> Ring (Class 300)	-29 to 816	-20 to 1500		
1. NACE trim constructions are a	available; consult your Fisher sales office.	·			

NACE trim constructions are available; consult your Fisher sales office.
 Special gasket relainer bolts are required for over 482°C (900°F)
 Special relaining nng screws for single flange valves over 538°C (1000°F)
 For a complete material description, contact your Fisher sales office.
 UHMWPE stands for ultra high molecular weight polyethytene.
 Special thrust bearings are required for high temp. applications over 343°C (650°F) (with 6 and 12-inch shaft extensions). Constructions with carbon steel valves and SST discs may require special thrust bearings are required for high temp. applications over 343°C (650°F) (with 6 and 12-inch shaft extensions). Constructions with carbon steel valves and SST discs may require special thrust bearings at temps. less than 343°C (650°F).
 The material for hard coating on the disc is either Hard Chrome Plating or Electroless Nickel Coating (ENC), depending upon availability.
 Cast or wrought/plate grades used interchangeably, depending on availability, unless specified by customer.

Valve Size, Inches	<b>A</b> (1)	D	E	G	к	M <sup>(2)</sup> Min. I.D.	R	S (Shaft Dia at Keyway)	Key SQ Size	т	U	Ŵ	Y	Approx Weight
	mm													kg
14	91.9	146	63.5	295	327	331	422	30.2	6.35	235	46.0	17.5		72
16	102	146	63.5	318	371	375	470	31.8	6.35	235	46.0	17.5	28.4	94
18	114	229	79.50	349	400	419	533	38.1	9.53	273	50.8	20.6	31.8	139
20	127	229	79.50	381	432	464	584	44.5	9.53	273	50.8	20.6	31.8	167
24	154	254	104.9	438	492	581	692	57.2	12.7	337	76.2	23.9	35.1	255
							Inche	s					_	Pounds
14	3.62	5.75	2.5	11.62	12.88	13.04	16.62	1-3/16	0.25	9.25	1.81	0.69		158
16	4.00	5.75	2.5	12.50	14.62	14.77	18.50	1-1/4	0.25	9.25	1.81	0.69	1.12	207
18	4.50	9.00	3.13	13.75	15.75	16.49	21.00	1-1/2	0.375	10.75	2.00	0.81	1.25	307
20	5.00	9.00	3.13	15.00	17.00	18.27	23.00	1-3/4	0.375	10.75	2.00	0.81	1.25	368
24	6.06	10.00	4.13	17.25	19.38	22.87	27.25	2-1/4	0.5	13.25	3.00	0.94	1.38	563
1. Face-to-face dimensions are in compliance with MSS SP68 and API 609 specifications. 2. Minimum I.D. is the minimum pipe or flange I.D. required for disc swing dearance.														

Table 2. Dimensions and Weights, Wafer Style Valves, ANSI Class 150



#### NOTE: THE KEYWAY IS SHOWN ON THIS SIDE OF THE SHAFT FOR REFERENCE PURPOSES ONLY.

Figure 6. Dimensions and Weights, Wafer Style Valves, ANSI Class 150 (also see table 2)

# A31A Valve

Valve Size, Inches	A <sup>(1)</sup>	D	E	G	к	M <sup>(2)</sup> Min. I.D.	R	S (Shaft Dia at Keyway)	Key SQ Size	т	U	w	Y	Approx Weight
	mm													
14	91.9	146	63.5	295	327	331	531	30.2	6.35	235	46.0	17.5		95
16	102	146	63.5	318	371	375	607	31.8	6.35	235	46.0	17.5		138
18	114	229	79.50	349	400	419	645	38.1	9.53	273	50.8	20.1		178
20	127	229	79.50	381	432	464	696	44.5	9.53	273	50.8	20.1		224
24	154	254	104.9	438	492	581	822	57.2	12.7	337	76.2	23.9		315
								Inches						Pounds
14	3.62	5.75	2.5	11.62	12.88	13.04	20.88	1-3/16	0.25	9.25	1.81	0.69	1-8 12 Holes	209
16	4.00	5.75	2.5	12.50	14.62	14.77	23.88	1-1/4	0.25	9.25	1.81	0.69	1-8 16 Holes	304
18	4.50	9.00	3.13	13.75	15.75	16.49	25.38	1-1/2	0.38	10.75	2.00	0.81	1-1/8-8 16 Holes	393
20	5.00	9.00	3.13	15.00	17.00	18.27	27.38	1-3/4	0.38	10.75	2.00	0.81	1-1/8-8 20 Holes	493
24	6.06	10.00	4.13	17.25	19.38	22.87	32.38	2-1/4	0.5	13.25	3.00	0.94	1-1/4-8 20 Holes	773
1. Face-to 2. Minimu	Face-to-face dimensions are in compliance with MSS SP68 and API 609 specifications.     Minimum 1.D. is the minimum pipe or flange I.D. required for <i>disc</i> swing clearance.													

Table 3. Dimensions and Weights, Single Flange Valves, ANSI Class 150



NOTE: THE KEYWAY IS SHOWN ON THIS SIDE OF THE SHAFT FOR REFERENCE PURPOSES ONLY.

Figure 7. Dimensions and Weights, Single Flange Valves, ANSI Class 150 (also see table 3)

## Installation

Recommended installation for the Type A31A valve is with the shaft upstream of the seal (retaining ring downstream from the high pressure side of the valve).

The standard soft seal offers bubble-tight, bidirectional shutoff. To meet the performance requirements of many of today's fire-tested requirements, a Phoenix III valve must be installed in the preferred valve orientation. The NOVEX seals are uni-directional and should be installed with the shaft upstream of the seal.

For assistance in selecting the appropriate combination of actuator action and open valve position, consult your Fisher sales office.

Dimensions and weights for wafer-style and single-flange valves are shown in figures 6, 7, 8 and 9.

Valve Size, Inches	<b>A</b> (1)	D	E	G	к	M <sup>(2)</sup> Min. I.D.	R	S (Shaft Dia at Keyway)	Key SQ Size	т	U	w	Y	Approx Weight
	mm													kg
14	117	229	79.50	319	364	304	437	44.5	9.53	273	50.8	20.6		121
16	133	229	79.50	353	397	346	498	44.5	9.53	273	50.8	20.6		183
18	149	254	104.9	384	419	389	556	57.2	12.7	337	76.2	23.9		227
20	159	273	124.0	416	483	442	605	69.9	15.88	337	76.2	23.9		364
24	181	273	124.0	483	546	523	716	69.9	15.88	337	76.2	23.9	• - •	469
		·						Inches		•				Pounds
14	4.62	9.00	3.13	12.56	14.31	11.98	17.19	1-3/4	0.375	10.75	2.00	0.81	1-1/8-8 4 Holes	266
16	5.25	9.00	3.13	13.88	15.62	13.63	19.62	1-3/4	0.375	10.75	2.00	0.81	1-1/4-8 4 Holes	403
18	5.88	10.00	4.13	15.12	16.50	15.32	21.88	2-1/4	0.5	13.25	3.00	0.94	1-1/4-8 4 Holes	500
20	6.25	10.75	4.88	16.38	19.00	17.40	23.81	2-3/4	0.625	13.25	3.00	0.94	1-1/4-8 4 Holes	802
24	7.12	11.75	4.88	19.00	21.50	20.59	28.19	2-3/4	0.625	13.25	3.00	0.94	1-1/2-8 4 Holes	1035
1. Face-to	1. Face-to-face dimensions are in compliance with MSS SP68 and API 609 specifications.													

Table 4. Dimensions and Weights, Wafer Style Valves, ANSI Class 300



NOTE: THE KEYWAY IS SHOWN ON THIS SIDE OF THE SHAFT FOR REFERENCE PURPOSES ONLY.

Figure 8. Dimensions and Weights, Wafer Style Valves, ANSI Class 300 (also see table 4)

Valve Size, Inches	A(1)	D	E	G	к	M <sup>(2)</sup> Min. I.D.	R	S (Shaft Dia at Keyway)	Key SQ Size	Т	U	w	Y	Approx Weight
	mm													
14	117	229	79.50	319	364	304	594	44.5	9.53	273	50.8	20.6		227
16	133	229	79.50	353	397	346	657	44.5	9.53	273	50.8	20.6		294
18	149	254	104.9	384	419	389	721	57.2	12.7	337	76.2	23.9		402
20	159	273	124.0	416	483	442	784	69.9	15.88	337	76.2	23.9		544
24	181	292	124.0	483	546	523	924	69.9	15.88	337	76.2	23.9		821
								Inches						Pounds
14	4.62	9.00	3.13	12.56	14.31	11.98	23.38	1-3/4	0.375	10.75	2.00	0.81	1-1/8-8 16 Holes	500
16	5.25	9.00	3.13	13.88	15.62	13.63	25.88	1-3/4	0.375	10.75	2.00	0.81	1-1/4-8 20 Holes	649
18	5.88	10.00	4.13	15.12	16.50	15.32	28.38	2-1/4	0.5	13.25	3.00	0.94	1-1/4-8 24 Holes	886
20	6.25	10.75	4.88	16.38	19.00	17.40	30.88	2-3/4	0.625	13.25	3.00	0.94	1-1/4-8 24 Holes	1200
24	7.12	11.50	4.88	19.00	21.50	20.59	36.38	2-3/4	0.625	13.25	3.00	0.94	1-1/2-8 24 Holes	1810
1. Face-to 2. Minimu	o-face dim m I.D. is t	ensions ar he minimu	re in comp im pipe or	liance with flange I.D	MSS SP	68 and API 609 for disc swing c	specificati learance.	ions.					*	

Table 5. Dimensions and Weights, Single Flange Valves, ANSI Class 300





Figure 9. Dimensions and Weights, Single Flange Valves, ANSI Class 300 (also see table 5)

# Coefficients

Table 6	Class	150	Reverse Flow
iable 0.	01033	100,	Neverse LIUW

0	Valve	/alve Valve Rotation, Degrees										
Coefficients	Size, Inches	10	20	30	40	50	60	70	80	90		
Cv		95	316	695	1200	1900	2840	3980	5120	6320		
K <sub>v</sub>		82.2	273	601	1038	1643	2457	3443	4429	5467		
F <sub>d</sub>	14	0.090	0.17	0.26	0.34	0.42	0.49	0.57	0.64	0.70		
FL		0.77	0.79	0.81	0.81	0.78	0.73	0.68	0.60	0.52		
X <sub>T</sub>		0.50	0.53	0.55	0.55	0.51	0.45	0.39	0.30	0.23		
Cv		129	430	946	1640	2580	3870	5420	6970	8600		
K <sub>v</sub>		112	372	818	1419	2232	3348	4688	6029	7439		
Fd	16	0.090	0.17	0.26	0.34	0.42	0.49	0.57	0.64	0.70		
FL		0.77	0.79	0.81	0.81	0.78	0.73	0.68	0.60	0.52		
X <sub>T</sub>		0.50	0.53	0.55	0.55	0.51	0.45	0.39	0.30	0.23		
Cv		166	553	1220	2100	3320	4970	6960	8950	11,050		
K <sub>v</sub>		144	478	1055	1817	2872	4299	6020	7742	9558		
Fd	18	0.090	0.17	0.26	0.34	0.42	0.49	0.57	0.64	0.70		
FL		0.77	0.79	0.81	0.81	0.78	0.73	0.68	0.60	0.52		
X <sub>T</sub>		0.50	0.53	0.55	0.55	0.51	0.45	0.39	0.30	0.23		
Cv		208	692	1520	2630	4160	6230	8730	11,220	13,850		
Kv		180	599	1315	2275	3598	5389	7551	9705	11,980		
F <sub>d</sub>	20	0.090	0.17	0.26	0.34	0.42	0.49	0.57	0.64	0.70		
FL		0.77	0.79	0.81	0.81	0.78	0.73	0.68	0.60	0.52		
X <sub>T</sub>		0.50	0.53	0.55	0.55	0.51	0.45	0.39	0.30	0.23		
Cv		322	1080	2370	4080	6450	9670	13,540	17,410	21,500		
κ <sub>ν</sub>		277	9 <b>3</b> 4	2050	3529	5579	8365	11,712	15,060	18,598		
F <sub>d</sub>	24	0.090	0.17	0.26	0.34	0.42	0.49	0.57	0.64	0.70		
FL		0.77	0.79	0.81	0.81	0.78	0.73	0.68	0.60	0.52		
XT	•	0.50	0.53	0.55	0.55	0.51	0.45	0.39	0. <b>3</b> 0	0.23		

Coefficients	Valve Size, Inches	Valve Rotation, Degrees								
		10	20	30	40	50	60	70	80	90
Cv	14	136	341	704	1200	1860	2680	3450	4050	4550
κ <sub>ν</sub>		118	295	609	1038	1609	2318	2984	3503	3936
F <sub>d</sub>		0.090	0.17	0.26	0.34	0.42	0.49	0.57	0.64	0.70
FL		0.78	0.81	0.81	0.79	0.75	0.69	0.62	0.56	0.52
X <sub>T</sub>		0.51	0.55	0.55	0.53	0.47	0.40	0.33	0.26	0.23
Cv	16	169	422	873	1490	2310	3320	4280	5010	5630
κ <sub>ν</sub>		146	365	755	1289	1998	2872	3702	4334	4870
Fd		0.090	0.17	0.26	0.34	0.42	0.49	0.57	0.64	0.70
FL		0.78	0.81	0.81	0.79	0.75	0.69	0.62	0.56	0.52
X <sub>T</sub>		0.51	0.55	0.55	0.53	0.47	0.40	0.33	0.26	0.23
Cv	18	247	617	1280	2180	3370	4860	6260	7330	8230
κ <sub>ν</sub>		214	534	1107	1886	2915	4204	5415	6340	7119
Fd		0.090	0.17	0.26	0.34	0.42	0.49	0.57	0.64	0.70
FL		0.78	0.81	0.81	0.79	0.75	0.69	0.62	0.56	0.52
X <sub>T</sub>		0.51	0.55	0.55	0.53	0.47	0.40	0.33	0.26	0.23
Cv	20	286	714	1480	2520	3910	5620	7240	8480	9530
K <sub>v</sub>		247	618	1280	2180	3382	4861	6263	7335	8243
Fd		0.090	0.17	0.26	0.34	0.42	0.49	0.57	0.64	0.70
FL		0.78	0.81	0.81	0.79	0.75	0.69	0.62	0.56	0.52
X <sub>T</sub>		0.51	0.55	0.55	0.53	0.47	0.40	0.33	0.26	0.23
Cv	24	375	938	1940	3320	5130	7380	9510	11,140	12,510
κ <sub>ν</sub>		324	811	1678	2872	4437	6384	8226	9636	10,821
F <sub>d</sub>		0.090	0.17	0.26	0.34	0.42	0.49	0.57	0.64	0.70
FL		0.78	0.81	0.81	0.79	0.75	0.69	0.62	0.56	0.52
X <sub>T</sub>		0.51	0.55	0.55	0.53	0.47	0.40	0.33	0.26	0.23

#### Note

Neither Emerson, Emerson Process Management, Fisher, nor any of their affiliated entities assumes responsibility for the selection, use and maintenance of any product. Responsibility for the selection, use and maintenance of any product remains with the purchaser and end-user.

Bettis, POSI-SEAL, NOVEX, Phoenix III, ENVIRO-SEAL and Fisher are marks owned by Fisher Controls International LLC, a member of the Emerson Process Management business division of Emerson Electric Co. Emerson and the Emerson logo are trademarks and service marks of Emerson Electric Co. All other marks are the property of their respective owners. This product may be covered by one or more of the following patents: 5,535,986; 4,744,572; 5,129,625; 5,131,666 and 5,542,681 or under pending patents.

The contents of this publication are presented for informational purposes only, and while every effort has been made to ensure their accuracy, they are not to be construed as warranties or guarantees, express or implied, regarding the products or services described herein or their use or applicability. We reserve the right to modify or improve the designs or specifications of such products at any time without notice.

Neither Emerson, Emerson Process Management, Fisher, nor any of their affiliated entities assumes responsibility for the selection, use and maintenance of any product. Responsibility for the selection, use and maintenance of any product remains with the purchaser and end-user.

**Emerson Process Management** 

Fisher Marshalltown, Iowa 50158 USA Cernay 68700 France Sao Paulo 05424 Brazil Singapore 128461

www.Fisher.com



©Fisher Controls International LLC 1991, 2005; All Rights Reserved Printed in USA