

Start: 2/4/2008 Schedule Period: 28 DAYS
Critical: 2/7/2008 5:00:00 PM Previous Complete: 12/30/2007
Work Order: 0251080204 PM: 0251 Description: PERFORM 24.202.03 HPCI SYSTEM
Work Group: OPS System Tie: E4100 PIPING FILLED AND VALVE

Required Mode: 1 2 3 Recommended Mode: 1 2 3

RAD PROTECTION REVIEW

Required: Y RWP Number: _____
Alara Review: Y N ID: _____ Date: _____
RP Reviewer: _____

JOB START

Tag Attribute: NP No Protection RWP Number: _____
Pmt for WO#'s: _____ LCO#: _____
Lead Person: _____ ID: _____ Date: _____
FSS: _____ ID: _____ Date: _____
SF: _____ ID: _____ Date/Time: _____

LEAD PERSON REVIEW

Discrepancies/Resolutions Listed [] Yes [] No No. of Personnel: _____
Total Dose Received: _____ Hours to Complete: _____
Jobs Complete: _____ ID: _____ Date/Time: _____

SM REVIEW

_____ :All Job Acceptance Criteria Met
_____ :A Portion Of Job Acceptance Criteria Met - Explain
_____ :Job Acceptance Criteria Not Met - Explain

SM: _____ ID: _____ Date: _____

DESIGNATED REVIEWERS

ISI Reviewer: ISI Designate Requested: N Date: _____
Reviewer 1: Mark Bergman ID: 00100609 Requested: N Date: _____
Reviewer 2: ID: Requested: N Date: _____
Reviewer 3: ID: Requested: Date: _____

JOB INSTRUCTION

10 PERFORM ENTIRE PROCEDURE

JOB PERFORMANCE MEASURE
NRC EXAM 2008

JPM Title Perform 24.202.03, "HPCI System Piping Filled and Valve Position Verification" (BANK)	No.: 08-A-001 Revision: 0 Page 1
--	--

Preferred Evaluation Method:

Perform Walkthrough _____ Discuss _____
Plant _____ Simulator Classroom _____

System:

E4100 – High Pressure Coolant Injection System

Task:



References: Required (R) / Available (A)

24.202.03, " HPCI System Piping Filled And Valve Position Verification" (R)

Tools and Equipment Required:

Surveillance Performance Form (SPF) signed on to reflect job started.

Initial Conditions:

- You are the Control Room NSO.
- The plant is operating at 100% CTP.

Initiating Cue(s):

- You are to perform 24.202.03, "HPCI System Piping Filled And Valve Position Verification", Section 5.1 (Control Room Portion).
- All prerequisites are met.
- The surveillance was started and is being turned over to you.
- Steps 4.1 and 4.2 are complete and signed.

Note: Examinee may identify out-of-position valves prior to reaching procedural steps requiring verification. If necessary, Examiner may cue trainee at any point that, as CRS, you have directed another operator to initiate corrective actions for the condition, and direct Examinee to complete the surveillance.

Terminating Cue(s):

Surveillance 24.202.03, " HPCI System Piping Filled And Valve Position Verification", Section 5.1 is complete.

Task Standard:

Perform 24.202.03, " HPCI System Piping Filled And Valve Position Verification", Section 5.1 (Control Room Portion).

JOB PERFORMANCE MEASURE
NRC EXAM 2008

JPM Title Perform 24.202.03, "HPCI System Piping Filled and Valve Position Verification" (BANK)	No.: 08-A-001 Revision: 0 Page 2
---	--

Licensed Operator Exam Information (required for NRC exams)

Safety Function:

2 – Reactor Water Inventory Control

K/A Reference: (from NUREG 1123)

K/A SYSTEM: 206000 - High Pressure Coolant Injection System
K/A STATEMENT:
2.2 Equipment Control
2.2.14 Knowledge of the process for controlling equipment configuration or status. 3.9 / 4.3

Maintenance Rule Safety Classification:

E4100-01

Maintenance Rule Risk Significant? (Yes or No)

Yes

JOB PERFORMANCE MEASURE
NRC EXAM 2008

JPM Title Perform 24.202.03, "HPCI System Piping Filled and Valve Position Verification" (BANK)	No.: 08-A-001 Revision: 0 Page 3
---	--

PERFORMANCE EVALUATION

Start Time _____

ELEMENT	STANDARD
PREREQUISITES: None	
CUE: Provide Examinee with CUE SHEET. Hand Examinee a CONTROLLED copy of 24.202.03, HPCI SYSTEM PIPING FILLED AND VALVE POSITION VERIFICATION with a signed SPF.	
NOTE: Examinee should verify SPF is signed on properly and procedure is controlled. The examinee will sign on the surveillance (second page in the Lead Person Change Block.	
1. Place or verify E41-K615, HPCI Pump Flow Controller, in Auto and set at 5250 gpm ("S" Display).	1. Controller is verified in Auto at 5250 gpm. Initial block is signed.
2. Verify horizontal output bar graph on E41-K615, HPCI Pump Flow Controller, is at 100%.	2. Controller is verified at 100%. Initial block is signed.
3. If Annunciator 2D56, HPCI STEAM SUPPLY PRESSURE LOW, is clear, verify: <ul style="list-style-type: none"> • E4150-F002, HPCI Stm Sply Inbd Iso Vlv, OPEN • E4150-F600, HPCI Stm Sply Otbd Iso Byp Vlv, OPEN 	3. 2D56 is verified clear, and E4150-F002 and E4150-F600 are verified OPEN. Initial block is signed.
4. If Annunciator 2D56, HPCI STEAM SUPPLY PRESSURE LOW, is in alarm, verify: <ul style="list-style-type: none"> • E4150-F002, HPCI Stm Sply Inbd Iso Vlv, CLOSED • E4150-F600, HPCI Stm Sply Otbd Iso Byp Vlv, CLOSED 	4. 2D56 is verified Not in alarm. "N/A" is placed in Initial block.

JOB PERFORMANCE MEASURE
NRC EXAM 2008

JPM Title Perform 24.202.03, "HPCI System Piping Filled and Valve Position Verification" (BANK)	No.: 08-A-001 Revision: 0 Page 4
--	--

ELEMENT	STANDARD
<p>* 5. Verify:</p> <ul style="list-style-type: none"> • E4150-F003, HPCI Stm Sply Otbd Iso Vlv, CLOSED • E41-F011, HPCI/RCIC Test Iso/Press Control Valve, CLOSED • E41-F011, HPCI/RCIC Test Iso/Press Control Valve, Selector switch in ISOLATE • E4100-F068, HPCI Turb Stm Control Vlv, CLOSED • E4100-F067, HPCI Turb Stm Stop Vlv, CLOSED • E4150-F001, HPCI Turb Stm Sply Iso Vlv, CLOSED • E4150-F004, HPCI CST Suct Iso Vlv, OPEN • E4150-F007, HPCI Pump Disch Otbd Iso Vlv, OPEN • E4150-F006, HPCI Pump Disch Inbd Iso Vlv, CLOSED • E4150-F042, HPCI Torus Suct Inbd Iso Vlv, CLOSED • E4150-F041, HPCI Torus Suct Otbd Iso Vlv, CLOSED • E4150-F021, HPCI Turb Stop Ck Vlv, OPEN • E4150-F012, HPCI Pump Min Flow Vlv, CLOSED • E4150-F059, HPCI Oil Clr Clg Water Iso Vlv, CLOSED • E4150-F022, HPCI Turb Exh Pot Drain Stop Check Vlv, OPEN 	<p>* 5. Examinee identifies mispositioned valves. Step 5.1.5 is NOT met and should NOT be initialed.</p> <p style="padding-left: 40px;">NOTE 1 or something to that effect should be entered in the Initials block</p>
<p>*6. CRS must be notified of failure of the following valves to meet Acceptance Criteria:</p> <ul style="list-style-type: none"> • E4150-F004, HPCI CST Suct Iso Vlv, is CLOSED. • E4150-F042, HPCI Torus Suct Inbd Iso Vlv, is OPEN. • E4150-F041, HPCI Torus Suct Otbd Iso Vlv, is OPEN. 	<p>*6 CRS is notified of the failure of step 5.1.5 to meet the acceptance criteria.</p>
<p>NOTE: Examinee may perform the next step after step 9.</p>	
<p>*7. Examinee will note surveillance discrepancies in the Discrepancy Section of the SPF.</p>	<p>*7 Discrepancies are noted in the Discrepancy Section of the SPF.</p>
<p>CUE: Inform Examinee that a CARD will be written, and direct him/her to complete the remainder of Section 5.1. Do not reposition any valves. Another Operator will realign HPCI Suction per SOP 23.202. (Require operator to complete surveillance close-out.)</p>	

JOB PERFORMANCE MEASURE
NRC EXAM 2008

JPM Title Perform 24.202.03, "HPCI System Piping Filled and Valve Position Verification" (BANK)	No.: 08-A-001 Revision: 0 Page 5
---	--

ELEMENT	STANDARD
NOTE: Examinee should continue on and properly document discrepancies.	
8. Verify: <ul style="list-style-type: none"> • E4150-F008, HPCI Test Line Iso Vlv, CLOSED • E4150-F075, HPCI Exh Vac Bkr Otbd Iso Vlv, OPEN • E4150-F079, HPCI Exh Vac Bkr Inbd Iso Vlv, OPEN 	8. Valves are verified in proper positions and initial block is signed.
* 9. Fill in and sign Record of Test Personnel.	* 9. Record of Test Personnel is filled in and signed.
NOTE: Examinee may place NOTE 1 and reason below Record of Test Personnel.	
CUE: End JPM when Performed block is signed.	

_____ SATISFACTORY

_____ UNSATISFACTORY

Stop Time _____

* **Critical Step**

JOB PERFORMANCE MEASURE
NRC EXAM 2008

JPM Title Perform 24.202.03, "HPCI System Piping Filled and Valve Position Verification" (BANK)	No.: 08-A-001 Revision: 0 Page 6
---	--

Evaluator Notes:

This JPM should be performed in the simulator control room.

ENSURE ALL INDUSTRIAL AND PERSONNEL SAFETY PRACTICES ARE USED AND ENFORCED AT ALL TIMES.

Generic Notes and Cues:

CMC switches will turn RED and amperage will increase when the switch is rotated to the start position started. The current should initially be five to seven times the normal running amps with the ammeter flashing. As counter EMF is developed, the amperage will lower to the normal running amperage and the ammeter will no longer flash. CMC switches will turn GREEN when the pumps are stopped and amperage will decrease to zero.

Ex.: Pump start: "Switch has been rotated to the start position, red light is lit, green light is out, amperage initially pegs out high, and is now indicating X amps."

Pump stop: "Switch has been rotated to the stop position, green light is lit, red light is out, amperage indicates 0 amps."

Remotely operated valve position is determined with open and close indicating lights. A RED light only would indicate that the valve is open. A GREEN light only would indicate that the valve is closed. Dual indication would indicate that the valve is in some intermediate position.

Manual valves are checked in the closed direction (MOP02 and MOP05). Valve stem position may aid in valve position determination, but cannot be used as Independent Verification (MOP02).

Ex.: Verify valve closed: "Valve handwheel indicates no valve movement in the clockwise direction."

Verify valve open: "Valve handwheel has been rotated slightly in the clockwise direction and returned to the original positions."

Closing a valve: "Valve handwheel has been rotated in the fully clockwise direction until no additional valve movement. Valve stem is down."

Opening a valve: "Valve handwheel has been rotated in the fully counterclockwise direction until no additional valve movement, valve stem is out."

Controllers have an Auto light that is GREEN when selected and AMBER (YELLOW) when Manual is selected. When in Manual, the open and closed pushbuttons control the parameter to be changed by adjusting position or speed. When the deviation meter is nulled, then the process can be shifted to Auto to allow the desired setpoint to control the process.

System Specific Notes and Cues:

None

Task Performance and Cues:

The Elements of this JPM are step by step in accordance with the procedure. The Standard is that the procedure is performed as written. The Cues are as listed above for indication or as each step is completed the appropriate information is reported to the examinee. Notify Examinee that time compression may be used for activities performed outside of the Control Room.

Critical Steps:

Critical Tasks are identified by asterisk (*) and **bolded** steps on the cover sheet. Verify that the latest revision of the procedure is used and critical tasks are correctly identified.

JOB PERFORMANCE MEASURE
NRC EXAM 2008

JPM Title Perform 24.202.03, "HPCI System Piping Filled and Valve Position Verification" (BANK)	No.: 08-A-001 Revision: 0 Page 7
---	--

FOLLOW-UP DOCUMENTATION QUESTIONS

Reason for follow-up question(s):

Question:

Reference:

Response:

Question:

Reference

Response:

JOB PERFORMANCE MEASURE
NRC EXAM 2008

JPM Title Perform 24.202.03, "HPCI System Piping Filled and Valve Position Verification" (BANK)	No.: 08-A-001 Revision: 0 Page 8
---	--

Simulator Setup

IC#:

Any power IC

Malfunctions:

Number	Title	Value	Delay	Ramp
None				

Remote Functions:

Number	Title	Value	Delay	Ramp
None				

Override Functions:

Number	Title	Value	Delay	Ramp
None				

Special Instructions:

1. Align HPCI Suction valves to CST.
 - E4150-F004, HPCI CST Suct Iso Vlv, CLOSED.
 - E4150-F042, HPCI Torus Suct Inbd Iso Vlv, OPEN.
 - E4150-F041, HPCI Torus Suct Otbd Iso Vlv, OPEN.
2. Surveillance Performance Form (SPF) as part of initial Cue.

Initial Conditions:

- You are the CRNSO.
- The plant is operating at 100% CTP.

Initiating Cue(s):

- You are to perform 24.202.03, "HPCI System Piping Filled And Valve Position Verification", Section 5.1 (Control Room Portion).
- All prerequisites are met.
- The surveillance was started and is being turned over to you.
- Steps 4.1 and 4.2 are complete and signed.

TRAINING USE ONLY

FERMI	CYCLE 12	INSTRUMENT READINGS/STATUS					
		CALIBRATED LPRM READINGS					
57 D	20.0	26.5	26.3	22.3			
C	23.8	32.2	31.1	29.2			
B	26.0	38.8	40.0	35.3			
A	23.3	41.5	39.0	37.5			
49 D	20.7	27.9	30.1	30.3	29.7	24.7	
C	25.8	40.6	40.7	38.7	39.6	25.8	
B	28.9	49.3	49.8	53.9	50.6	43.7	
A	27.4P	58.9	56.9	63.8	62.1	52.3	
41 D	26.2	29.7	31.9	34.2	30.2	28.8	22.5
C	35.9	39.5	42.4	40.5	40.2	38.7	30.2
B	46.8	48.9	53.2	52.8	53.2	50.5	36.6
A	64.8	55.0	53.7	52.7	60.6	63.4	39.4
33 D	28.1	32.0	35.9	34.5	35.5	31.4M	25.3
C	40.2	42.8	41.1	42.5	41.8	43.3	36.3
B	50.7	53.7	50.4	50.3	53.4	55.0	43.2
A	69.7	56.9	50.7	58.9	53.7	43.4	41.0
25 D	28.4	31.7	34.7	35.4	31.3	28.9	25.6
C	39.1	43.0	44.6	40.9	41.5	38.8	32.6
B	51.1	53.1	56.7	52.0	52.9	51.1	39.5
A	66.0	51.2	56.4	50.8	57.7	51.2	44.1
17 D	22.1	30.7	31.8C	32.9	29.4	26.9	19.4
C	31.2	41.7	43.7	44.0	38.4	39.3	23.7
B	40.1	53.4	54.3	54.6	49.4	49.8	26.0
A	51.7	61.6	49.6	54.8	58.5	61.5	24.6
09 D		23.6	28.9	29.5	26.8	21.1	
C		39.3	39.6	41.6	38.6	25.5	
B		42.4	50.6	51.4	47.6	28.8	
A		51.6	64.7	66.3	63.0	28.0	
	08	16	24	32	40	48	56

SEQUENCE NO 11
 TODAY 09:00 CALCULATED
 TODAY 09:01 PRINTED
 CASE IS FMLD1050609105759
 LPRM SHAPE - FULL CORE

FAILED SENSORS
 LPRM (0 SIGNALS FAILED)
 LPRM (0 PANACEA REJECTED)
 OTHER SENSORS (0 TOTAL)
 SUB RODS
 NONE

T = T I P RUN RECOMMENDED
 C = MFLCPR LOCATION
 M = MAPRAT LOCATION
 D = MFLPD LOCATION
 P = PCRAT LOCATION
 * = MULTIPLE LIMIT

CORE SUMMARY

CORE POWER	100 %	CALC SUB FLOW	94.1%	DP MEAS PSI	13.681
CORE FLOW	92.3 %	OPER SUB FLOW	-1.0%	DP CALC PSI	18.836
LOAD LINE	104.9 %	FLOW BASIS	MEAS	FEEDWTR FLOW MLB/HR	14.81

APRM CALIBRATION

	1	2	3	4
READING	99.9	99.9	99.8	99.9
AGAF	1.001	1.001	1.002	1.001
APRM - %CTP	-0.1	-0.1	-0.2	-0.1

TIP RUNS RECOMMENDED
 STRINGS : NONE

JOB PERFORMANCE MEASURE
NRC EXAM 2008

JPM Title Perform Thermal Limit Verification (MAPRAT)	No.: 08-A-002 Revision: 2 Page 1
--	--

Preferred Evaluation Method:

Perform Walkthrough _____ Discuss _____
Plant Simulator Classroom

System:

N/A

Task:

02A0006026 - Perform Shiftly, Daily, Weekly, and Situation Required Performance Evaluations.

References: Required (R) / Available (A)

24.000.02, "Shiftly, Daily and Weekly Required Surveillances", Attachment 2 (p. 19 of 24) (R)

Tools and Equipment Required:

3DM Edit Printout

Initial Conditions:

- You are the Patrol NSO.
- The STA has indicated that 3DM limits are reflective of the status of the MSR and BPVs.
- There has been no TAU change. This is the latest 3DM edit.

Initiating Cue(s):

The CRS directs you to complete 24.000.02, Attachment 2, the Shiftly/Daily Mode 1,2,3 – Control Room Step 16, Core Thermal Limit Verification.

Terminating Cue(s):

Surveillance is complete (RO).
Appropriate TS and limiting time identified (SRO).

Task Standard:

Perform Core Thermal Limit verification in accordance with 24.000.02 Attachment 2 (Step 16)

Licensed Operator Exam Information (required for NRC exams)

Safety Function:

N/A

K/A Reference: (from NUREG 1123)

K/A SYSTEM: 293009 - Core Thermal Limits

K/A STATEMENT:

GENERIC 2.1.7 - Ability to evaluate plant performance and make operational judgments based on operating characteristics / reactor behavior / and instrument interpretation. **RO 4.4 / SRO 4.7**

Maintenance Rule Safety Classification:

N/A

Maintenance Rule Risk Significant? (Yes or No)

N/A

JOB PERFORMANCE MEASURE
NRC EXAM 2008

JPM Title Perform Thermal Limit Verification (MAPRAT)	No.: 08-A-002 Revision: 2 Page 2
--	--

JOB PERFORMANCE MEASURE
NRC EXAM 2008

JPM Title Perform Thermal Limit Verification (MAPRAT)	No.: 08-A-002 Revision: 2 Page 3
--	--

PERFORMANCE EVALUATION

Start Time _____

ELEMENT	STANDARD
PREREQUISITES: None	
CUE: Provide Examinee with CUE SHEET. Hand a copy of 24.000.02 and 3DM edit to the Examinee. State all communications will be directed to the appropriate individual(s) and you will respond.	
1. Verify LPRMs are not failed (except for Bypassed LPRMs) and no other sensors are failed which affect the Heat Balance	1. Verifies there are no failed LPRMs or other sensors shown on the 3DM edit.
2. Verify Flow basis is "MEAS"	2. Verifies Flow basis is "MEAS".
3. If failed sensors exist (other than Bypassed or PANACEA-rejected LPRMs) or the flow basis is not "MEAS," consult with the STA/SNE for appropriate action before continuing.	3. Verifies no other failed sensors exist on the 3DM edit.
4. Place a check in items a and b when the review is satisfactory or when discrepancies are resolved and logged by the STA/SNE.	4. Checks blocks "a" and "b". The review is satisfactory.
5. Record Calculated Date and Time (items c and d) of the Core Monitor Periodic Log and verify complete in last 24 hours	5. Records Date and Time and verify complete within the last 24 hours
6. Record the listed parameters (items e – h) as they appear on the Core Monitor Periodic Log	6. Records CTP and Thermal Limit values.
CUE: Acknowledge report that TS is not met.	
* 7. Identifies that MAPRAT is > 1.0	* 7. Notifies CRS that TS is not being met. Thermal Limits are being exceeded.
* 8. Initial block.	* 8. Initials should NOT be signed as Acceptance Criteria is NOT met. Candidate should place a Circled Number in the INITIALS BLOCK.
9. Candidate places a Numbered Note in the REMARKS Section	9. Numbered Note is placed in REMARKS Section. (IE: Note 1 - Step 16.b MAPRAT > 1.0 SM/CRS/RE notified.)
*10. Identify the appropriate TS and limiting time. (SRO only)	*10. Reports that TS 3.2.1 APLHGR Condition A.1 is not met and must be restored within 2 hours.

JOB PERFORMANCE MEASURE
NRC EXAM 2008

JPM Title Perform Thermal Limit Verification (MAPRAT)	No.: 08-A-002 Revision: 2 Page 4
--	--

CUE: End JPM when surveillance is complete (RO) and TS and limiting time is identified (SRO).

_____ SATISFACTORY

_____ UNSATISFACTORY

Stop Time _____

*** Critical Step**

JOB PERFORMANCE MEASURE
NRC EXAM 2008

JPM Title Perform Thermal Limit Verification (MAPRAT)	No.: 08-A-002 Revision: 2 Page 5
--	--

Evaluator Notes:

This JPM may be performed in the plant, simulator, or classroom.
Obtain a current 3DM printout.

ENSURE ALL INDUSTRIAL AND PERSONNEL SAFETY PRACTICES ARE USED AND ENFORCED AT ALL TIMES.

Generic Notes and Cues:

CMC switches will turn RED and amperage will increase when the switch is rotated to the start position started. The current should initially be five to seven times the normal running amps with the ammeter flashing. As counter EMF is developed, the amperage will lower to the normal running amperage and the ammeter will no longer flash. CMC switches will turn GREEN when the pumps are stopped and amperage will decrease to zero.

Ex.: Pump start: "Switch has been rotated to the start position, red light is lit, green light is out, amperage initially pegs out high, and is now indicating X amps."

Pump stop: "Switch has been rotated to the stop position, green light is lit, red light is out, amperage indicates 0 amps."

Remotely operated valve position is determined with open and close indicating lights. A RED light only would indicate that the valve is open. A GREEN light only would indicate that the valve is closed. Dual indication would indicate that the valve is in some intermediate position.

Manual valves are checked in the closed direction (MOP02 and MOP05). Valve stem position may aid in valve position determination, but cannot be used as Independent Verification (MOP02).

Ex.: Verify valve closed: "Valve handwheel indicates no valve movement in the clockwise direction."

Verify valve open: "Valve handwheel has been rotated slightly in the clockwise direction and returned to the original positions."

Closing a valve: "Valve handwheel has been rotated in the fully clockwise direction until no additional valve movement. Valve stem is down."

Opening a valve: "Valve handwheel has been rotated in the fully counterclockwise direction until no additional valve movement, valve stem is out."

Controllers have an Auto light that is GREEN when selected and AMBER (YELLOW) when Manual is selected. When in Manual, the open and closed pushbuttons control the parameter to be changed by adjusting position or speed. When the deviation meter is nulled, then the process can be shifted to Auto to allow the desired setpoint to control the process.

System Specific Notes and Cues:

NONE

Task Performance and Cues:

The Elements of this JPM are step by step in accordance with the procedure. The Standard is that the procedure is performed as written. The Cues are as listed above for indication or as each step is completed the appropriate information is reported to the examinee. Notify Examinee that time compression may be used for activities performed outside of the Control Room.

Critical Steps:

Critical Tasks are identified by asterisk (*) and **bolded** steps on the cover sheet. Verify that the latest revision of the procedure is used and critical tasks are correctly identified.

JOB PERFORMANCE MEASURE
NRC EXAM 2008

JPM Title Perform Thermal Limit Verification (MAPRAT)	No.: 08-A-002 Revision: 2 Page 6
--	--

FOLLOW-UP DOCUMENTATION QUESTIONS

Reason for follow-up question(s):

Question:

Reference:

Response:

Question:

Reference

Response:

JOB PERFORMANCE MEASURE
NRC EXAM 2008

JPM Title Perform Thermal Limit Verification (MAPRAT)	No.: 08-A-002 Revision: 2 Page 7
--	--

Simulator Setup

IC#:

N/A

Malfunctions:

Number	Title	Value	Delay	Ramp
N/A				

Remote Functions:

Number	Title	Value	Delay	Ramp
N/A				

Override Functions:

Number	Title	Value	Delay	Ramp
N/A				

Special Instructions:

N/A

Cue Sheet

Initial Conditions:

- You are the Patrol NSO.
- The STA has indicated that 3DM limits are reflective of the status of the MSR and BPVs.
- There has been no TAU change. This is the latest 3DM edit.

Initiating Cue(s):

The CRS directs you to complete 24.000.02, Attachment 2, the Shifty/Daily Mode 1,2,3 – Control Room Step 16, Core Thermal Limit Verification.

AUTHORIZATION TO EXCEED DOSE CONTROL THRESHOLDS FORM

PART 3: APPROVAL (APPROPRIATE APPROVING AUTHORITY)

A) Approval Signature:

Individual's Section Head:

_____ Date: _____
print/sign

Radiation Protection Manager:

_____ Date: _____
print/sign

Plant Manager:

_____ Date: _____
print/sign

Vice President, Nuclear Generation:

NA

_____ Date: _____
print/sign

Comments/Controls

PART 4: INPUT (RADIOLOGICAL HEALTH)

A) RPMS Input/Update By:

_____ Date: _____
print/sign

B) RPMS Verified By:

_____ Date: _____
print/sign

C) FACS Input/Update By:

_____ Date: _____
print/sign

D) FACS Verified By:

_____ Date: _____
print/sign

E) Radiation Protection Operations Notification:

_____ Date: _____
print/sign


**Fermi 2-Radiation Protection
Radiological Survey**



Detroit Edison
FOR TRAINING USE ONLY

Area(s) RB-2 N. RWCU Pump Room	RWP. No. 08-1003 08-1010	Continuous coverage Survey Posted	Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> Yes/No
Purpose Open G3300-F013A	Date Today	HWC 85 SCFM	
Survey by (Print/Sign) Kevin Schultz / <i>Kevin Schultz</i>	Time 0800	Reactor Power 100 %	Surveyor's Dose 100 mrem

Location	Contamination (dpm/100cm ²)	
	Beta/gamma	Alpha
2 See Map	1K	N/A
3 See Map	4K	N/A
4 See Map	5K	N/A
5 See Map	16,285	< 20
6 See Map	2K	N/A
7 See Map	80K	N/A



NORTH REACTOR WATER CLEAN-UP PUMP ROOM R-2-8A

Unless otherwise noted, all dose rate readings are in the following units: Gamma (mR/hr), Beta (mRad/hr), Neutron (mrem/hr).
All smears not listed are <500dpm/100cm²

Instruments		
Type	Serial No.	Cal. Due
R50-50E	C524 H	6/08
LO 177	81612	6/08
LB 5100	70915	9/08

Air Sample No. N/A	Results N/A	Uci/ml N/A	DAC N/A
Reviewed by <i>Wayne Rutenberg</i>	Date Today		

SHIFT ASSIGNMENTS

DATE: Today

	Nights	Days	
SM	<u>Almes</u>	<u>Hemmele</u>	<u> </u>
CRS	<u>Simone</u>	<u>Crane</u>	<u> </u>
CRNSO	<u>McAllister</u>	<u>Kirchner</u>	<u> </u>
COP H11-P603	<u>Teifer</u>	<u>Conroy</u>	<u> </u>
Patrol	<u>**Leist</u>	<u>**Pearce</u>	<u> </u>
Shift Foreman	<u>O'Hern</u>	<u> </u>	<u> </u>
Other	<u> </u>	<u> </u>	<u> </u>
Turbine Bldg	<u>*Koss</u>	<u>*F. Brown</u>	<u> </u>
Reactor Bldg	<u>* Woods</u>	<u>* Hughes</u>	<u> </u>
Outside/Fermi 1	<u>Eisenmann</u>	<u>Ward</u>	<u> </u>
Radwaste Op-Assigned	<u>#Toward</u>	<u># J. Brown</u>	<u> </u>
Radwaste Op-Shift	<u> </u>	<u> </u>	<u> </u>
Other	<u>*Johnson</u>	<u>*Brda</u>	<u> </u>
	<u>*Smith</u>	<u>S. Ness</u>	<u> </u>
	<u> </u>	<u>* FP - Grodi</u>	<u> </u>
	<u> </u>	<u> </u>	<u> </u>
	<u> </u>	<u> </u>	<u> </u>
	<u>* </u>	<u>* </u>	<u> </u>

* Fire Brigade Member ** Fire Brigade Leader # CR Communicator

JOB PERFORMANCE MEASURE
NRC EXAM 2008

Job Position RO	No. 08-A-003	Revision 1
JPM Title Determine Dose Limit will be Exceeded and Initiate a Dose Extension (BANK)	Duration 20 minutes	Page COVER SHEET

Examinee: _____ SRO / RO / NO / STA

Evaluator: _____

JPM Type: **Normal** / Alternate Path / Time Critical

Evaluation Method: **Perform** / Walkthrough / Discuss Start Time _____

(Circle method used) Plant / **Simulator** / **Classroom** Stop Time _____

Total Time: _____

PERFORMANCE EVALUATION SUMMARY							
Element	S	U	Comments	Element	S	U	Comments
* 1.							
* 2.							
3.							
4.							
* 5.							
* 6.							
7.							
8.							

_____ SATISFACTORY _____ UNSATISFACTORY

OVERALL EVALUATOR COMMENTS:

Evaluator Signature / Date: _____ / _____

JOB PERFORMANCE MEASURE
NRC EXAM 2008

JPM Title Determine Dose Limit will be Exceeded and Initiate a Dose Extension	No.: 08-A-003 Revision: 1 Page 1
--	--

Preferred Evaluation Method:

Perform Walkthrough Discuss
Plant Simulator Classroom

System:

N/A

Task:

13808 - Initiate request for personnel dose extensions.

References: Required (R) / Available (A)

MRP 12, "Authorization To Exceed Dose Control Thresholds" (R)
"Training Only" Survey Map for RWCU room (R)

Tools and Equipment Required:

MRP12001, "Authorization To Exceed Dose Control Thresholds Form"

Initial Conditions:

- You are the Patrol NSO.
- The Shift is trying to restore the N RWCU Pump after a seal replacement.
- G33F013A, North RWCU Pump Discharge Isolation Valve will not open.

Initiating Cue(s):

- You must enter the RWCU pump room to perform an investigation of valve G33F013A, North RWCU Pump Discharge Isolation Valve and open the valve.
- The estimated time necessary to perform the inspection is 6 minutes. The job duration is too short to install, additional engineering controls to reduce dose.
- The situation is **NOT** an emergency but there is no other on shift person, with lower dose, knowledge, and expertise to performing the inspection.
- RP reports your accumulated dose for the year is 753 mR.
- Perform the necessary requirements to allow this entry to occur.

Terminating Cue(s):

MRP12001 Part 1 is complete.

Task Standard:

MRP12001 Part 1 is complete in accordance with MRP 12.

JOB PERFORMANCE MEASURE
NRC EXAM 2008

JPM Title Determine Dose Limit will be Exceeded and Initiate a Dose Extension	No.: 08-A-003 Revision: 1 Page 2
---	--

Licensed Operator Exam Information (required for NRC exams)

Safety Function:

N/A

K/A Reference: (from NUREG 1123)

K/A SYSTEM: GENERIC 2.3 – Radiation Control
K/A STATEMENT:
2.3.4 Knowledge of radiation exposure limits under normal or emergency conditions
. 3.2 / 3.7

Maintenance Rule Safety Classification:

N/A

Maintenance Rule Risk Significant? (Yes or No)

N/A

JOB PERFORMANCE MEASURE
NRC EXAM 2008

JPM Title Determine Dose Limit will be Exceeded and Initiate a Dose Extension	No.: 08-A-003 Revision: 1 Page 3
--	--

PERFORMANCE EVALUATION

Start Time _____

ELEMENT	STANDARD
CUE: Provide Examinee with CUE SHEET and copy of survey map of N. RWCU pump room.	
* 1. Determine radiation dose in work area.	* 1. Determines radiation level in the area of the valve is 6 Rem/hr.
NOTE: Fermi Admin Guideline = 1 REM/yr TEDE.	
* 2. Calculate dose to determine if dose extension is necessary.	* 2. Dose = 6/60 hr * 6 Rem/hr = 600 mrem. 600 mrem + 753 mrem = 1353 mrem or 1.353 Rem
CUE: Provide examinee the copy of MRP12001. If necessary, direct examinee to complete "Individual" and "Requestor" actions per MRP12. (Examiner may elect to not require SSN.)	
3. Obtain Procedure MRP 12 and form MRP12001.	3. Obtains procedure and form.
4. Complete part 1A of form MRP 12001.	4. Enters correct information.
CUE: Act as Radiation Protection to recommend a new dose limit of 1500 mrem.	
* 5. Complete part 1B of MRP 12001.	* 5. Enters: <ul style="list-style-type: none"> • Checks Fermi 2 Administrative Dose Guideline • Checks TEDE • Accumulated Dose: 753 mrem • Current Guideline Limit: 1,000 mrem/yr • Requested Dose Level: 1500 mrem
* 6. Complete part 1C	6. Enters – "options to lower dose or use another worker were considered and were impractical" (or any similar explanation consistent with intent).
7. Sign part 1D.	* 7. Examinee signs part 1D.
CUE: Act as RP Supervision and accept form from Examinee for processing.	
8. Complete Part E and route form to RP.	8. Examinee signs 1E.
CUE: End JPM when MRP12001 Part 1 is complete.	

_____ SATISFACTORY

_____ UNSATISFACTORY

Stop Time _____ * Critical Step

JOB PERFORMANCE MEASURE
NRC EXAM 2008

JPM Title Determine Dose Limit will be Exceeded and Initiate a Dose Extension	No.: 08-A-003 Revision: 1 Page 4
---	--

Evaluator Notes:

This JPM should be performed in the simulator control room or classroom.

ENSURE ALL INDUSTRIAL AND PERSONNEL SAFETY PRACTICES ARE USED AND ENFORCED AT ALL TIMES.

Generic Notes and Cues:

CMC switches will turn RED and amperage will increase when the switch is rotated to the start position started. The current should initially be five to seven times the normal running amps with the ammeter flashing. As counter EMF is developed, the amperage will lower to the normal running amperage and the ammeter will no longer flash. CMC switches will turn GREEN when the pumps are stopped and amperage will decrease to zero.

Ex.: Pump start: "Switch has been rotated to the start position, red light is lit, green light is out, amperage initially pegs out high, and is now indicating X amps."

Pump stop: "Switch has been rotated to the stop position, green light is lit, red light is out, amperage indicates 0 amps."

Remotely operated valve position is determined with open and close indicating lights. A RED light only would indicate that the valve is open. A GREEN light only would indicate that the valve is closed. Dual indication would indicate that the valve is in some intermediate position.

Manual valves are checked in the closed direction (MOP02 and MOP05). Valve stem position may aid in valve position determination, but cannot be used as Independent Verification (MOP02).

Ex.: Verify valve closed: "Valve handwheel indicates no valve movement in the clockwise direction."

Verify valve open: "Valve handwheel has been rotated slightly in the clockwise direction and returned to the original positions."

Closing a valve: "Valve handwheel has been rotated in the fully clockwise direction until no additional valve movement. Valve stem is down."

Opening a valve: "Valve handwheel has been rotated in the fully counterclockwise direction until no additional valve movement, valve stem is out."

Controllers have an Auto light that is GREEN when selected and AMBER (YELLOW) when Manual is selected. When in Manual, the open and closed pushbuttons control the parameter to be changed by adjusting position or speed. When the deviation meter is nulled, then the process can be shifted to Auto to allow the desired setpoint to control the process.

System Specific Notes and Cues:

None

Task Performance and Cues:

The Elements of this JPM are step by step in accordance with the procedure. The Standard is that the procedure is performed as written. The Cues are as listed above for indication or as each step is completed the appropriate information is reported to the examinee. Notify Examinee that time compression may be used for activities performed outside of the Control Room.

Critical Steps:

Critical Tasks are identified by asterisk (*) and **bolded** steps on the cover sheet. Verify that the latest revision of the procedure is used and critical tasks are correctly identified.

JOB PERFORMANCE MEASURE
NRC EXAM 2008

JPM Title Determine Dose Limit will be Exceeded and Initiate a Dose Extension	No.: 08-A-003 Revision: 1 Page 5
---	--

FOLLOW-UP DOCUMENTATION QUESTIONS

Reason for follow-up question(s):

Question:

Reference:

Response:

Question:

Reference

Response:

JOB PERFORMANCE MEASURE
NRC EXAM 2008

JPM Title Determine Dose Limit will be Exceeded and Initiate a Dose Extension	No.: 08-A-003 Revision: 1 Page 6
---	--

Simulator Setup

IC#:

N/A

Malfunctions:

Number	Title	Value	Delay	Ramp
N/A				

Remote Functions:

Number	Title	Value	Delay	Ramp
N/A				

Override Functions:

Number	Title	Value	Delay	Ramp
N/A				

Special Instructions:

N/A

Cue Sheet

Initial Conditions:

- You are the Patrol NSO.
- The Shift is trying to restore the N RWCU Pump after a seal replacement.
- G33F013A, North RWCU Pump Discharge Isolation Valve will not open.

Initiating Cue(s):

- You must enter the RWCU pump room to perform an investigation of valve G33F013A, North RWCU Pump Discharge Isolation Valve and open the valve.
- The estimated time necessary to perform the inspection is 6 minutes. The job duration is too short to install, additional engineering controls to reduce dose.
- The situation is NOT an emergency but there is no other on shift person, with lower dose, knowledge, and expertise to performing the inspection.
- RP reports your accumulated dose for the year is 753 mR.
- Perform the necessary requirements to allow this entry to occur.

JOB PERFORMANCE MEASURE
NRC EXAM 2008

JPM Title Determine Shift Staffing Requirements	No.: 08-A-005 Revision: 0 Page 1
--	--

Preferred Evaluation Method:

Perform Walkthrough _____ Discuss _____
Plant _____ Simulator Classroom

System:

N/A

Task:

01A0001078 - Take action on receiving a report that the Relief Individual is not fully capable of performing assigned duties.

References: Required (R) / Available (A)

MOP03 (A)

Tools and Equipment Required:

None

Initial Conditions:

- You are the CRS.
- The time is 1000 Sunday morning with the plant operating at 100% power.

Initiating Cue(s):

- Frank Brown has just informed you that he is leaving immediately due to a personal emergency.
- He has given a turnover to S. Ness, who has just recently completed his proficiency watches as Turbine Building Rounds but is not current on Fire Brigade qualification.
- You are to identify the staffing adjustments that need to be made, recommendations for call-outs, and time constraints.
- Vocalize your thought process and report when you have completed the task.

Terminating Cue(s):

Call-out is made for another NO who is qualified as a Fire Brigade member within 2 hours.

Task Standard:

Shift staffing adjusted and actions taken to meet minimum shift staffing within the time constraints.

JOB PERFORMANCE MEASURE
NRC EXAM 2008

JPM Title Determine Shift Staffing Requirements	No.: 08-A-005 Revision: 0 Page 2
--	--

Licensed Operator Exam Information (required for NRC exams)

Safety Function:

N/A

K/A Reference: (from NUREG 1123)

K/A SYSTEM: GENERICS 2.1 – Conduct of Operations
K/A STATEMENT:
2.1.4 Knowledge of individual licensed operator responsibilities related to shift staffing, such as medical requirements, “no-solo” operation, maintenance of active license status, 10CFR55, etc.3.3 / 3.8

Maintenance Rule Safety Classification:

N/A

Maintenance Rule Risk Significant? (Yes or No)

N/A

JOB PERFORMANCE MEASURE
NRC EXAM 2008

JPM Title Determine Shift Staffing Requirements	No.: 08-A-005 Revision: 0 Page 3
--	--

PERFORMANCE EVALUATION

Start Time _____

ELEMENT	STANDARD
CUE: Provide the examinee the Cue Sheet. Hand the examinee a copy of the attached Shift Assignment sheet if asked for.	
* 1. Obtain a copy of the current Shift Assignments sheet to determine the status of shift staffing.	* 1. Identifies that F. Brown was filling a required Fire Brigade position in addition to TB Rounds.
* 2. Identify the time requirements to have minimum staffing positions filled.	* 2. Identifies that minimum staffing must be filled within 2 hours per MOP03.
CUE: Report as the RO that Scott Harter has been called in to replace Frank Brown as the TB Rounds as well as the Fire Brigade member and will report within 45 minutes.	
* 3. Initiate the process for call-out to fill the Fire Brigade member position.	* 3. Directs an RO to initiate a call-out for the needed individual.
CUE: End JPM when call-out is made for another NO who is qualified as a Fire Brigade member.	

_____ SATISFACTORY

_____ UNSATISFACTORY

Stop Time _____

* **Critical Step**

JOB PERFORMANCE MEASURE
NRC EXAM 2008

JPM Title Determine Shift Staffing Requirements	No.: 08-A-005 Revision: 0 Page 4
--	--

Evaluator Notes:

This JPM may be performed anywhere the examinee has access to conduct manuals.

ENSURE ALL INDUSTRIAL AND PERSONNEL SAFETY PRACTICES ARE USED AND ENFORCED AT ALL TIMES.

Generic Notes and Cues:

CMC switches will turn RED and amperage will increase when the switch is rotated to the start position started. The current should initially be five to seven times the normal running amps with the ammeter flashing. As counter EMF is developed, the amperage will lower to the normal running amperage and the ammeter will no longer flash. CMC switches will turn GREEN when the pumps are stopped and amperage will decrease to zero.

Ex.: Pump start: "Switch has been rotated to the start position, red light is lit, green light is out, amperage initially pegs out high, and is now indicating X amps."

Pump stop: "Switch has been rotated to the stop position, green light is lit, red light is out, amperage indicates 0 amps."

Remotely operated valve position is determined with open and close indicating lights. A RED light only would indicate that the valve is open. A GREEN light only would indicate that the valve is closed. Dual indication would indicate that the valve is in some intermediate position.

Manual valves are checked in the closed direction (MOP02 and MOP05). Valve stem position may aid in valve position determination, but cannot be used as Independent Verification (MOP02).

Ex.: Verify valve closed: "Valve handwheel indicates no valve movement in the clockwise direction."

Verify valve open: "Valve handwheel has been rotated slightly in the clockwise direction and returned to the original positions."

Closing a valve: "Valve handwheel has been rotated in the fully clockwise direction until no additional valve movement. Valve stem is down."

Opening a valve: "Valve handwheel has been rotated in the fully counterclockwise direction until no additional valve movement, valve stem is out."

Controllers have an Auto light that is GREEN when selected and AMBER (YELLOW) when Manual is selected. When in Manual, the open and closed pushbuttons control the parameter to be changed by adjusting position or speed. When the deviation meter is nulled, then the process can be shifted to Auto to allow the desired setpoint to control the process.

System Specific Notes and Cues:

None

Task Performance and Cues:

The Elements of this JPM are step by step in accordance with the procedure. The Standard is that the procedure is performed as written. The Cues are as listed above for indication or as each step is completed the appropriate information is reported to the examinee. Notify Examinee that time compression may be used for activities performed outside of the Control Room.

Critical Steps:

Critical Tasks are identified by asterisk (*) and **bolded** steps on the cover sheet. Verify that the latest revision of the procedure is used and critical tasks are correctly identified.

JOB PERFORMANCE MEASURE
NRC EXAM 2008

JPM Title Determine Shift Staffing Requirements	No.: 08-A-005 Revision: 0 Page 5
--	--

FOLLOW-UP DOCUMENTATION QUESTIONS

Reason for follow-up question(s):

Question:

Reference:

Response:

Question:

Reference

Response:

JOB PERFORMANCE MEASURE
NRC EXAM 2008

JPM Title Determine Shift Staffing Requirements	No.: 08-A-005 Revision: 0 Page 6
--	--

Simulator Setup

IC#:

N/A

Malfunctions:

Number	Title	Value	Delay	Ramp
N/A				

Remote Functions:

Number	Title	Value	Delay	Ramp
N/A				

Override Functions:

Number	Title	Value	Delay	Ramp
N/A				

Special Instructions:

N/A

Cue Sheet

Initial Conditions:

- You are the CRS.
- The time is 1000 Sunday morning with the plant operating at 100% power.

Initiating Cue(s):

- Frank Brown has just informed you that he is leaving immediately due to a personal emergency.
- He has given a turnover to S. Ness, who has just recently completed his proficiency watches as Turbine Building Rounds but is not current on Fire Brigade qualification.
- You are to identify the staffing adjustments that need to be made, recommendations for call-outs, and time constraints.
- Vocalize your thought process and report when you have completed the task.

(For Training Use ONLY)

NUCLEAR PLANT EVENT TECHNICAL DATA FORM

Actual Event

Drill

Plant Contact Information	
Nuclear Power Plant: <u>Fermi 2</u>	<div style="border: 1px solid black; width: 100px; height: 40px; margin: 0 auto;"></div> Plant Message Number
Plant Communicator: _____	
Calling From: <input type="checkbox"/> Control Room <input type="checkbox"/> TSC <input type="checkbox"/> EOF <input type="checkbox"/> Other _____	
Call Back Telephone Number: 313 256-4_____	
Meteorological Data	
NOTE: The IPCS "Straight Line Plume Plot" is the preferred source. <input type="checkbox"/> See attached Event Notification Form	
Wind Direction (degrees): From _____ to _____	Wind Speed (MPH): _____
Stability Class: _____	Precipitation: <input type="checkbox"/> Yes <input type="checkbox"/> No
Reactor Information	
Is the reactor shut down? <input type="checkbox"/> Yes Time of shutdown: _____	<input type="checkbox"/> No
Plant Status/Additional Information	
Release/Offsite Dose Data: <input type="checkbox"/> N/A OR <input type="checkbox"/> See Page 2 (If N/A, do not send Page 2)	

Approved: _____
Signature
Print Name
Date
Time

Notifications	Time Contacted	Name	Telephone No. or Select Auto-Dial
Monroe County Sheriff			<input type="checkbox"/> Auto-Dial
Wayne County Sheriff			<input type="checkbox"/> Auto-Dial
Michigan State Police			<input type="checkbox"/> Auto-Dial
NRC Operations Center			
Nuclear Information			

(FOR Training Use ONLY)

NUCLEAR PLANT EVENT TECHNICAL DATA FORM

Release/Offsite Dose Data																																							
			<div style="border: 1px solid black; width: 100px; height: 40px; margin: 0 auto;"></div> Plant Message Number																																				
Release Pathway: <input type="checkbox"/> Airborne <input type="checkbox"/> Waterborne		<table border="1" style="width: 100%; border-collapse: collapse;"> <thead> <tr> <th colspan="2" style="text-align: center;">Release Rates</th> </tr> </thead> <tbody> <tr> <td>Noble Gas (Ci/sec)</td> <td></td> </tr> <tr> <td>Equivalent I - 131 (Ci/sec)</td> <td></td> </tr> <tr> <td>Particulate (Ci/sec)</td> <td style="text-align: center;">N/A</td> </tr> </tbody> </table>		Release Rates		Noble Gas (Ci/sec)		Equivalent I - 131 (Ci/sec)		Particulate (Ci/sec)	N/A																												
Release Rates																																							
Noble Gas (Ci/sec)																																							
Equivalent I - 131 (Ci/sec)																																							
Particulate (Ci/sec)	N/A																																						
Projected Release Duration (Hrs): _____																																							
<input type="checkbox"/> Actual <input type="checkbox"/> Potential	Time of Calculation: _____																																						
Based On: <input type="checkbox"/> Monitor (in plant) <input type="checkbox"/> Sample (in plant) <input type="checkbox"/> Back Calculation of Field Data																																							
<input type="checkbox"/> Other: _____																																							
<table border="1" style="width: 100%; border-collapse: collapse;"> <thead> <tr> <th colspan="3" style="text-align: center;">Calculated Dose Rates</th> </tr> <tr> <th style="width: 30%;">Distance</th> <th style="width: 30%;">TEDE (mrem/hr)</th> <th style="width: 40%;">Thyroid CDE (mrem/hr)</th> </tr> </thead> <tbody> <tr><td>Site Boundary</td><td></td><td></td></tr> <tr><td>2 Miles</td><td></td><td></td></tr> <tr><td>5 Miles</td><td></td><td></td></tr> <tr><td>10 Miles</td><td></td><td></td></tr> </tbody> </table>		Calculated Dose Rates			Distance	TEDE (mrem/hr)	Thyroid CDE (mrem/hr)	Site Boundary			2 Miles			5 Miles			10 Miles			<table border="1" style="width: 100%; border-collapse: collapse;"> <thead> <tr> <th colspan="3" style="text-align: center;">Projected Dose</th> </tr> <tr> <th style="width: 30%;">Distance</th> <th style="width: 30%;">TEDE (mrem)</th> <th style="width: 40%;">Thyroid CDE (mrem)</th> </tr> </thead> <tbody> <tr><td>Site Boundary</td><td></td><td></td></tr> <tr><td>2 Miles</td><td></td><td></td></tr> <tr><td>5 Miles</td><td></td><td></td></tr> <tr><td>10 Miles</td><td></td><td></td></tr> </tbody> </table>		Projected Dose			Distance	TEDE (mrem)	Thyroid CDE (mrem)	Site Boundary			2 Miles			5 Miles			10 Miles		
Calculated Dose Rates																																							
Distance	TEDE (mrem/hr)	Thyroid CDE (mrem/hr)																																					
Site Boundary																																							
2 Miles																																							
5 Miles																																							
10 Miles																																							
Projected Dose																																							
Distance	TEDE (mrem)	Thyroid CDE (mrem)																																					
Site Boundary																																							
2 Miles																																							
5 Miles																																							
10 Miles																																							
<input type="checkbox"/> Not Available																																							
Measured Offsite Radiation Levels																																							
Distance	Time	Highest Reading (mR/hr)	Iodine Cartridge (net CPM)	Sector																																			
Site Boundary																																							
Miles																																							
Miles																																							
Miles																																							

AUTHORIZATION TO EXCEED DOSE CONTROL THRESHOLDS FORM

PART 3: APPROVAL (APPROPRIATE APPROVING AUTHORITY)

A) Approval Signature:

Individual's Section Head:

_____ Date: _____
print/sign

Radiation Protection Manager:

_____ Date: _____
print/sign

Plant Manager:

_____ Date: _____
print/sign

Vice President, Nuclear Generation:

NA

_____ Date: _____
print/sign

Comments/Controls

PART 4: INPUT (RADIOLOGICAL HEALTH)

A) RPMS Input/Update By:

_____ Date: _____
print/sign

B) RPMS Verified By:

_____ Date: _____
print/sign

C) FACS Input/Update By:

_____ Date: _____
print/sign

D) FACS Verified By:

_____ Date: _____
print/sign

E) Radiation Protection Operations Notification:

_____ Date: _____
print/sign


**Fermi 2-Radiation Protection
Radiological Survey**



Detroit Edison

Area(s) RB-2 N. RWCU Pump Room	RWP No. 08-1003 08-1010	Continuous coverage Survey Posted Yes (No) Yes (No)
Purpose Open G3300-F013A	Date Today	HWC 85 SCFM
Survey by (Print/Sign) Kevin Schultz / <i>Kevin Schultz</i>	Time 0800	Reactor Power 100 % Surveyor's Dose 100 mrem

Location		Contamination (dpm/100cm ²)	
		Beta/gamma	Alpha
2	See Map	1K	N/A
3	See Map	4K	N/A
4	See Map	5K	N/A
5	See Map	16,285	< 20
6	See Map	2K	N/A
7	See Map	80K	N/A



NORTH REACTOR WATER CLEAN-UP PUMP ROOM

R-2-8A

Unless otherwise noted, all dose rate readings are in the following units: Gamma (mR/hr), Beta (mRad/hr), Neutron (mrem/hr).

All smears not listed are <500dpm/100cm²

Instruments		
Type	Serial No.	Cal. Due
R50-50E	C524 H	6/08
LO 177	81612	6/08
LB 5100	70915	9/08

Air Sample No. N/A	Results N/A Uci/ml N/A DAC
--------------------	----------------------------

Reviewed by *Wayne Ruteberg* Date *Today*

JOB PERFORMANCE MEASURE
NRC EXAM 2008

Job Position RO	No. 08-A-004	Revision 0
JPM Title Complete and Communicate the Nuclear Plant Technical Data Form (MODIFIED)	Duration 20 minutes	Page COVER SHEET

Examinee: _____ SRO / RO / NO / STA

Evaluator: _____

JPM Type: **Normal** / Alternate Path / Time Critical

Evaluation Method: **Perform** / Walkthrough / Discuss Start Time _____

(Circle method used) Plant / **Simulator** / Classroom Stop Time _____

Total Time: _____

PERFORMANCE EVALUATION SUMMARY							
Element	S	U	Comments	Element	S	U	Comments
* 1.							
2.							
* 3.							
* 4.							
5.							
* 6.							
7.							
8.							
9.							

_____ SATISFACTORY

_____ UNSATISFACTORY

OVERALL EVALUATOR COMMENTS:

Evaluator Signature / Date: _____ / _____

JOB PERFORMANCE MEASURE
NRC EXAM 2008

JPM Title Complete and Communicate the Nuclear Plant Technical Data Form	No.: 08-A-004 Revision: 0 Page 1
--	--

Preferred Evaluation Method:

Perform Walkthrough _____ Discuss _____
Plant _____ Simulator Classroom

System:

N/A

Task:

References: Required (R) / Available (A)

EP-290, "Emergency Notifications" (R)

Tools and Equipment Required:

EP-290002, "Nuclear Plant Technical Data Form", JETFORM or Hard Copy at STA desk. (R)
IPCS "Meteorological Overview" screen printout (O)

Initial Conditions:

- This is **NOT** a drill.
- The Emergency Director has declared a Site Area Emergency (FS1) due to event in progress resulting in loss of reactor coolant fission product barrier and potential loss of fuel clad fission product barrier.
- The Reactor has been shutdown. (Today at current clock time)
- CHRRMs readings have increased.
- Currently the plant is degrading based on a fire having started in the EDG 11 room. Offsite Fire Assistance has been requested.
- All safety systems are currently available with HPCI maintaining RPV level.
- Onsite Assembly and Accountability has been completed.
- The Dose Assessment is not available.
- Offsite Protective action recommendations are not required.
- The State EOC is **NOT** functional.

NOTE: The examinee may request information from the evaluator in accordance with Enclosure B of EP-290. Be prepared to respond to requests, which will typically be that additional information is not yet available.

Initiating Cue(s):

- You are the Control Room Emergency Communicator.
- The Initial Notification is complete and numbered Message 1.
- Fill out the required information for the Follow up Notification (TDF).
- Present the form to the Emergency Director for approval.
- Make the required periodic update to Offsite Authority Telephone Notifications.
- This task is **NOT** time critical.

JOB PERFORMANCE MEASURE
NRC EXAM 2008

JPM Title Complete and Communicate the Nuclear Plant Technical Data Form	No.: 08-A-004 Revision: 0 Page 2
--	--

Terminating Cue(s):

Technical Data Form has been turned in for approval to the Emergency Director. If required by the examiner, offsite notifications are complete. **Examiner may stop task at any time following ED signature.**

Task Standard:

All steps required should be completed within 30 minutes, including:

- Form EP-290002, Technical Data Form, completed with accurately transcribed technical information consistent with the provided sample standard.
- Emergency Director Approval (signature) of the notification form.
- Completion of telephone notifications to Offsite Authorities (if asked for by Examiner).

Licensed Operator Exam Information (required for NRC exams)

Safety Function:

N/A

K/A Reference: (from NUREG 1123)

K/A SYSTEM: GENERIC 2.4 – Emergency Procedures / Plans
K/A STATEMENT:
2.4.39 Knowledge of the RO's responsibilities in emergency plan implementation. 3.9 / 3.8

Maintenance Rule Safety Classification:

N/A

Maintenance Rule Risk Significant? (Yes or No)

N/A

JOB PERFORMANCE MEASURE
NRC EXAM 2008

JPM Title Complete and Communicate the Nuclear Plant Technical Data Form	No.: 08-A-004 Revision: 0 Page 3
--	--

PERFORMANCE EVALUATION

Start Time _____

ELEMENT	STANDARD
PREREQUISITES: None	
CUE: Present Examinee with CUE SHEET.	
NOTE: The examinee may request information from the evaluator in accordance with Enclosure B of EP-290. Be prepared to respond to requests, which will typically be that additional information is not yet available.	
* 1. Fill in Actual Event or Drill on the top of the Plant Event Technical Data Form	* 1. Actual Event is checked.
2. Enters Name, Checks calling from Control Room, Plant Message Number and STA Desk Telephone Number.	2. Enters Name, Checks Control Room, enters Message 2 and 771 to complete phone number.
NOTE: Applicable data on IPCS Meteorological Data screen may be recognized by Blue-Green colored outline around data on screen.	
* 3. Enters Meteorological Data.	* 3. Enters: (Data obtained from IPCS terminal) 10M Wind Direction actual reading 10M Wind Speed (mph) actual reading Stability class actual reading Precipitation actual reading
* 4. Enters Reactor Information.	* 4. Checks Rx Shutdown – Yes Adds comments similar to sample that will convey: <ul style="list-style-type: none"> • Loss/Potential Loss of 2 FPBs • Degrading conditions • Offsite fire assistance has been requested.
5. Enter Release/Offsite Dose Data.	5. N/A – Dose Assessment is not available.
CUE: Examiner should sign as ED.	
6. Obtains Emergency Director Signature.	6. Emergency Director signs.
NOTE: Completion of Notifications (making simulated phone calls)	
* 7. Notifies the Monroe County Sheriff by calling 734-243-7070 or Auto dial	* 7. Monroe County Sheriff notified
* 8. Notifies the Wayne County Sheriff by calling 734-942-3600	* 8. Wayne County Sheriff notified
* 9. Notifies the Michigan State Police by calling 517-336-6100	* 9. Michigan State Police notified

JOB PERFORMANCE MEASURE
NRC EXAM 2008

JPM Title Complete and Communicate the Nuclear Plant Technical Data Form	No.: 08-A-004 Revision: 0 Page 4
--	--

ELEMENT	STANDARD
CUE: End JPM when Technical Data Form has been turned in for approval to the Emergency Director. If required by the examiner, offsite notifications are complete.	

_____ SATISFACTORY

_____ UNSATISFACTORY

Stop Time _____

* **Critical Step**

JOB PERFORMANCE MEASURE
NRC EXAM 2008

JPM Title Complete and Communicate the Nuclear Plant Technical Data Form	No.: 08-A-004 Revision: 0 Page 5
--	--

Evaluator Notes:

This JPM should be performed in the simulator control room but, can be done in a classroom with IPCS available to obtain data. Alternatively, the provided printout of the "Meteorological Overview" screen may be presented to the Examinee.

Additional Notes

- Telephone number is usually the STA's (communicators desk x4771)
- Plant message number is the sequential number of the message (continued from previous message).
- Initiating condition/ description comes from EP-101 Enclosure A.
- Meteorological data is obtained from the 10 meter MET TOWER screen of IPCS. It may also be obtained from the RERP Web page when IPCS is unavailable.
- Protective action recommendations are only provided for a General Emergency and IAW EP-545.

A sample completed notification form is provided for comparison. The examinee may request event information from the evaluator in accordance with the Enclosures B of EP- 290. Be prepared to respond to requests, which will typically be that additional information is not yet available.

ENSURE ALL INDUSTRIAL AND PERSONNEL SAFETY PRACTICES ARE USED AND ENFORCED AT ALL TIMES.

Generic Notes and Cues:

CMC switches will turn RED and amperage will increase when the switch is rotated to the start position started. The current should initially be five to seven times the normal running amps with the ammeter flashing. As counter EMF is developed, the amperage will lower to the normal running amperage and the ammeter will no longer flash. CMC switches will turn GREEN when the pumps are stopped and amperage will decrease to zero.

Ex.: Pump start: "Switch has been rotated to the start position, red light is lit, green light is out, amperage initially pegs out high, and is now indicating X amps."

Pump stop: "Switch has been rotated to the stop position, green light is lit, red light is out, amperage indicates 0 amps."

Remotely operated valve position is determined with open and close indicating lights. A RED light only would indicate that the valve is open. A GREEN light only would indicate that the valve is closed. Dual indication would indicate that the valve is in some intermediate position.

Manual valves are checked in the closed direction (MOP02 and MOP05). Valve stem position may aid in valve position determination, but cannot be used as Independent Verification (MOP02).

Ex.: Verify valve closed: "Valve handwheel indicates no valve movement in the clockwise direction."

Verify valve open: "Valve handwheel has been rotated slightly in the clockwise direction and returned to the original positions."

Closing a valve: "Valve handwheel has been rotated in the fully clockwise direction until no additional valve movement. Valve stem is down."

Opening a valve: "Valve handwheel has been rotated in the fully counterclockwise direction until no additional valve movement, valve stem is out."

Controllers have an Auto light that is GREEN when selected and AMBER (YELLOW) when Manual is selected. When in Manual, the open and closed pushbuttons control the parameter to be changed by adjusting position or speed. When the deviation meter is nulled, then the process can be shifted to Auto to allow the desired setpoint to control the process.

System Specific Notes and Cues:

None

JOB PERFORMANCE MEASURE
NRC EXAM 2008

JPM Title Complete and Communicate the Nuclear Plant Technical Data Form	No.: 08-A-004 Revision: 0 Page 6
--	--

Task Performance and Cues:

The Elements of this JPM are step by step in accordance with the procedure. The Standard is that the procedure is performed as written. The Cues are as listed above for indication or as each step is completed the appropriate information is reported to the examinee. Notify Examinee that time compression may be used for activities performed outside of the Control Room.

Critical Steps:

Critical Tasks are identified by asterisk (*) and **bolded** steps on the cover sheet. Verify that the latest revision of the procedure is used and critical tasks are correctly identified.

JOB PERFORMANCE MEASURE
NRC EXAM 2008

JPM Title Complete and Communicate the Nuclear Plant Technical Data Form	No.: 08-A-004 Revision: 0 Page 7
--	--

FOLLOW-UP DOCUMENTATION QUESTIONS

Reason for follow-up question(s):

Question:

Reference:

Response:

Question:

Reference

Response:

JOB PERFORMANCE MEASURE
NRC EXAM 2008

JPM Title Complete and Communicate the Nuclear Plant Technical Data Form	No.: 08-A-004 Revision: 0 Page 8
--	--

Simulator Setup

IC#:

N/A

Malfunctions:

Number	Title	Value	Delay	Ramp
N/A				

Remote Functions:

Number	Title	Value	Delay	Ramp
N/A				

Override Functions:

Number	Title	Value	Delay	Ramp
N/A				

Special Instructions:

IPCS data available in Simulator. MET information is only required data.

Cue Sheet

Initial Conditions:

- This is **NOT** a drill.
- The Emergency Director has declared a Site Area Emergency (FS1) due to event in progress resulting in loss of reactor coolant fission product barrier and potential loss of fuel clad fission product barrier.
- The Reactor has been shutdown.
- CHRRMs readings have increased.
- Currently the plant is degrading based on a fire having started in the EDG 11 room. Offsite Fire Assistance has been requested.
- All safety systems are currently available with HPCI maintaining RPV level.
- Onsite Assembly and Accountability has been completed.
- The Dose Assessment is not available.
- Offsite Protective action recommendations are not required.
- The State EOC is **NOT** functional.

Initiating Cue(s):

- You are the Control Room Emergency Communicator.
- The Initial Notification is complete and numbered Message 1.
- Fill out the required information for the Follow up Notification (TDF).
- Present the form to the Emergency Director for approval.
- Make the required periodic update to Offsite Authority Telephone Notifications.
- This task is **NOT** time critical.

JOB PERFORMANCE MEASURE
NRC EXAM 2008

JPM Title Determine Dose Limit Complete a Dose Extension	No.: 08-A-006 Revision: 0 Page 1
---	--

Preferred Evaluation Method:

Perform Walkthrough _____ Discuss _____
Plant _____ Simulator Classroom

System:

N/A

Task:

13808 - Initiate request for personnel dose extensions.

References: Required (R) / Available (A)

MRP 12, "Authorization To Exceed Dose Control Thresholds" (R)
Training RWP for RWCU room (A)

Tools and Equipment Required:

MRP12001, "Authorization To Exceed Dose Control Thresholds Form"

Initial Conditions:

- You are the CRS.
- The Shift is trying to restore the N RWCU Pump after a seal replacement. G33F013A, North RWCU Pump Discharge Isolation Valve will not open.
- The Patrol NSO must enter the N RWCU pump room to perform an investigation and open G33F013A, North RWCU Pump Discharge Isolation Valve.
- The estimated time necessary to perform the inspection is 6 minutes. The job duration is too short to install additional engineering controls to reduce dose.

Initiating Cue(s):

- The Patrol NSO (Charles Smith) total exposure for the year is 753 mrem.
- The situation is **NOT** an emergency but there is no other on shift person, with lower dose, knowledge, and expertise to performing the inspection.
- Perform the necessary requirements to allow this entry to occur.

Terminating Cue(s):

MRP12001 Part 1 is complete.

Task Standard:

Authorization to exceed Fermi 2 Administrative Guidelines is obtained in accordance with MRP 12.

JOB PERFORMANCE MEASURE
NRC EXAM 2008

JPM Title Determine Dose Limit Complete a Dose Extension	No.: 08-A-006 Revision: 0 Page 2
---	--

Licensed Operator Exam Information (required for NRC exams)

Safety Function:

N/A

K/A Reference: (from NUREG 1123)

K/A SYSTEM: GENERIC 2.3 – Radiation Control

K/A STATEMENT:

2.3.4 Knowledge of radiation exposure limits under normal or emergency conditions.

3.2 / 3.7

Maintenance Rule Safety Classification:

N/A

Maintenance Rule Risk Significant? (Yes or No)

N/A

JOB PERFORMANCE MEASURE
NRC EXAM 2008

JPM Title Determine Dose Limit Complete a Dose Extension	No.: 08-A-006 Revision: 0 Page 3
---	--

PERFORMANCE EVALUATION

Start Time _____

ELEMENT	STANDARD
CUE: Provide Examinee with CUE SHEET and copy of RWP for RWCU pump room.	
* 1. Determine radiation dose in work area.	* 1. Determines radiation level in the area of the valve is 6 Rem/hr.
CUE: RP reports Charles Smith's accumulated dose this year is 753 mR.	
NOTE: Fermi Admin Guideline = 1 REM/yr TEDE.	
* 2. Calculate dose to determine if dose extension is necessary.	* 2. Dose = 6/60 hr * 6 Rem/hr = 600 mrem. 600 mrem + 753 mrem = 1353 mrem or 1.353 Rem
CUE: After examinee finds form, provide examinee the copy of MRP12001.	
3. Obtain Procedure MRP 12 and form MRP12001.	3. Obtains procedure and form.
CUE: Charles Smith is the NSO, and his SSN is 111-11-1111.	
4. Complete part 1A of form MRP 12001.	4. Enters correct information.
CUE: If desired, act as Radiation Protection to recommend a new dose limit of 1500 mrem.	
* 5. Complete part 1B of MRP 12001.	* 5. Enters: <ul style="list-style-type: none"> • Checks Fermi 2 Administrative Dose Guideline • Checks TEDE • Accumulated Dose: 753 mrem • Current Guideline Limit: 1,000 mrem/yr • Requested Dose Level: 1500 mrem
* 6. Complete part 1C	* 6. Enters – "No other individual available with lower dose, exposure time too short for other practical dose reduction methods" (or any similar explanation consistent with intent).
CUE: When requested by the Examinee, acknowledge the extension request by completing part 1D.	
7. Request NSO sign part 1D.	7. Examiner signs part 1D for Charles Smith.
8. Complete Part E.	8. Examinee signs 1E.
CUE: Act as Radiological Health personnel and accept form.	
CUE: Acting as Radiological Health, complete Part 2 of Form MRP12001 as follows:	
<p>A. Check "Yes"</p> <p>B. Enter age as "32" years</p> <p>C. Enter dose of "4.235" rem</p> <p>D. Enter "Individual's dose records updated"</p> <p>E. Sign and date</p>	
CUE: Tell Examinee that part 2 of MRP 12001 is complete, and return the form to Examinee.	

JOB PERFORMANCE MEASURE
NRC EXAM 2008

JPM Title Determine Dose Limit Complete a Dose Extension	No.: 08-A-006 Revision: 0 Page 4
---	--

ELEMENT	STANDARD
9. Route form to Radiological Health.	9. Routes form to Radiological Health.
CUE: Act as each specified individual and sign as requested.	
NOTE: If the Examinee obtains the Site VP signature, make an exam comment because this is only required to exceed 80% of the Fed Limit.	
10. Obtain appropriate approvals as required by MRP12 Enclosure B.	10. Obtain approvals from: <ul style="list-style-type: none"> • Operations Manager • Radiation Protection Manager • Plant Manager
CUE: End JPM when MRP12001 Part 1 is complete.	

_____ SATISFACTORY

_____ UNSATISFACTORY

Stop Time _____

*** Critical Step**

JOB PERFORMANCE MEASURE
NRC EXAM 2008

JPM Title Determine Dose Limit Complete a Dose Extension	No.: 08-A-006 Revision: 0 Page 5
---	--

Evaluator Notes:

This JPM should be performed in the simulator control room or classroom.

ENSURE ALL INDUSTRIAL AND PERSONNEL SAFETY PRACTICES ARE USED AND ENFORCED AT ALL TIMES.

Generic Notes and Cues:

CMC switches will turn RED and amperage will increase when the switch is rotated to the start position started. The current should initially be five to seven times the normal running amps with the ammeter flashing. As counter EMF is developed, the amperage will lower to the normal running amperage and the ammeter will no longer flash. CMC switches will turn GREEN when the pumps are stopped and amperage will decrease to zero.

Ex.: Pump start: "Switch has been rotated to the start position, red light is lit, green light is out, amperage initially pegs out high, and is now indicating X amps."

Pump stop: "Switch has been rotated to the stop position, green light is lit, red light is out, amperage indicates 0 amps."

Remotely operated valve position is determined with open and close indicating lights. A RED light only would indicate that the valve is open. A GREEN light only would indicate that the valve is closed. Dual indication would indicate that the valve is in some intermediate position.

Manual valves are checked in the closed direction (MOP02 and MOP05). Valve stem position may aid in valve position determination, but cannot be used as Independent Verification (MOP02).

Ex.: Verify valve closed: "Valve handwheel indicates no valve movement in the clockwise direction."

Verify valve open: "Valve handwheel has been rotated slightly in the clockwise direction and returned to the original positions."

Closing a valve: "Valve handwheel has been rotated in the fully clockwise direction until no additional valve movement. Valve stem is down."

Opening a valve: "Valve handwheel has been rotated in the fully counterclockwise direction until no additional valve movement, valve stem is out."

Controllers have an Auto light that is GREEN when selected and AMBER (YELLOW) when Manual is selected. When in Manual, the open and closed pushbuttons control the parameter to be changed by adjusting position or speed. When the deviation meter is nulled, then the process can be shifted to Auto to allow the desired setpoint to control the process.

System Specific Notes and Cues:

None

Task Performance and Cues:

The Elements of this JPM are step by step in accordance with the procedure. The Standard is that the procedure is performed as written. The Cues are as listed above for indication or as each step is completed the appropriate information is reported to the examinee. Notify Examinee that time compression may be used for activities performed outside of the Control Room.

Critical Steps:

Critical Tasks are identified by asterisk (*) and **bolded** steps on the cover sheet. Verify that the latest revision of the procedure is used and critical tasks are correctly identified.

JOB PERFORMANCE MEASURE
NRC EXAM 2008

JPM Title Determine Dose Limit Complete a Dose Extension	No.: 08-A-006 Revision: 0 Page 6
---	--

FOLLOW-UP DOCUMENTATION QUESTIONS

Reason for follow-up question(s):

Question:

Reference:

Response:

Question:

Reference

Response:

JOB PERFORMANCE MEASURE
NRC EXAM 2008

JPM Title Determine Dose Limit Complete a Dose Extension	No.: 08-A-006 Revision: 0 Page 7
---	--

Simulator Setup

IC#:

N/A

Malfunctions:

Number	Title	Value	Delay	Ramp
N/A				

Remote Functions:

Number	Title	Value	Delay	Ramp
N/A				

Override Functions:

Number	Title	Value	Delay	Ramp
N/A				

Special Instructions:

N/A

Cue Sheet

Initial Conditions:

- You are the CRS.
- The Shift is trying to restore the N RWCU Pump after a seal replacement. G33F013A, North RWCU Pump Discharge Isolation Valve will not open.
- The Patrol NSO must enter the N RWCU pump room to perform an investigation of a G33F013A, North RWCU Pump Discharge Isolation Valve.
- Current Dose Rate in the area of the inspection has been measured at 6,000 mrem/hr.
- The estimated time necessary to perform the inspection is 6 minutes. The job duration is too short to install additional engineering controls.

Initiating Cue(s):

- The Patrol NSO (Charles Smith) total exposure for the year is 753 mrem TEDE.
- The situation is **NOT** an emergency but there is no other on shift person, with lower dose, knowledge, and expertise to performing the inspection.
- Perform the necessary requirements to allow this entry to occur.

JOB PERFORMANCE MEASURE
NRC EXAM 2008

Job Position SRO	No. 08-A-007	Revision 0
JPM Title On-Site Protective Actions and Classification for Security Event (MODIFIED)	Duration 15 minutes	Page COVER SHEET

Examinee: _____ SRO / RO / NO / STA

Evaluator: _____

JPM Type: **Normal** / Alternate Path / **Time Critical**

Evaluation Method: **Perform** / Walkthrough / Discuss Start Time _____

(Circle method used) Plant / **Simulator** / **Classroom** Stop Time _____

Total Time: _____

PERFORMANCE EVALUATION SUMMARY							
Element	S	U	Comments	Element	S	U	Comments
* 1.							
* 2.							
* 3.							

_____ SATISFACTORY

_____ UNSATISFACTORY

OVERALL EVALUATOR COMMENTS:

Evaluator Signature / Date: _____ / _____

JOB PERFORMANCE MEASURE
NRC EXAM 2008

JPM Title On-Site Protective Actions and Classification for Security Event	No.: 08-A-007 Revision: 0 Page 1
--	--

Preferred Evaluation Method:

Perform Walkthrough _____ Discuss _____
Plant _____ Simulator Classroom

System:

N/A

Task:

01A0005099 - Direct and Supervise the Shift Team During Abnormal Operations

References: Required (R) / Available (A)

EP-530, "Assembly, Accountability & Onsite Protective Actions" (R)

EP-101, "Classification Of Emergencies" (R)

Tools and Equipment Required:

None

Initial Conditions:

- This JPM is time critical.
- You are the Shift Manager.
- The Reactor is shutdown.
- Reactor level and pressure are being controlled in normal bands.
- No other EOP entry conditions exist.
- The CRS is executing the Hostile Threat AOP. (Have copy available for candidate)

Initiating Cue(s):

- A Hostile Attack is in progress from an unknown group of approximately 5 to 10 armed individuals.
- These individuals have attacked the EF2 Drive Gate House and obtained entry into the Owner Controlled Area. They are on the 120 KV Mat.
- Perform on-site protective actions and classify the event.

Terminating Cue(s):

An ALERT has been declared by the Emergency Director.

Task Standard:

Determine On-Site Protective actions for a Security Threat per EP-530, and Classify the event per EP-101.

JOB PERFORMANCE MEASURE
NRC EXAM 2008

JPM Title On-Site Protective Actions and Classification for Security Event	No.: 08-A-007 Revision: 0 Page 2
--	--

Licensed Operator Exam Information (required for NRC exams)

Safety Function:

N/A

K/A Reference: (from NUREG 1123)

K/A SYSTEM: GENERIC 2.4 – Emergency Procedures / Plan
K/A STATEMENT:
2.4.40 Knowledge of the SRO's responsibilities in emergency plan implementation..... 2.7 / 4.5

Maintenance Rule Safety Classification:

N/A

Maintenance Rule Risk Significant? (Yes or No)

N/A

JOB PERFORMANCE MEASURE
NRC EXAM 2008

JPM Title On-Site Protective Actions and Classification for Security Event	No.: 08-A-007 Revision: 0 Page 3
--	--

PERFORMANCE EVALUATION

Start Time _____

ELEMENT	STANDARD
PREREQUISITES: None	
CUE: Present Examinee with CUE SHEET.	
NOTE: Examinee should use EP-530 Enclosure B, and execute steps for Hostile Threat in progress.	
* 1. Sound the Plant Area Alarm.	* 1. Sounds the Plant Area Alarm.
* 2. Make the following announcement using Hi-Com override: "Attention all personnel. There is a hostile attack in progress on the Fermi 2 site. All personnel take cover immediately!" Repeat the announcement.	* 2. Makes the announcement.
* 3. Declare an ALERT – HA8, Security Event in a Plant Protected Area.	* 3. Declares an ALERT.
CUE: End JPM when an ALERT has been declared by the Emergency Director.	

_____ SATISFACTORY

_____ UNSATISFACTORY

Stop Time _____

* **Critical Step**

JOB PERFORMANCE MEASURE
NRC EXAM 2008

JPM Title On-Site Protective Actions and Classification for Security Event	No.: 08-A-007 Revision: 0 Page 4
--	--

Evaluator Notes:

This JPM should be performed in the simulator control room.

ENSURE ALL INDUSTRIAL AND PERSONNEL SAFETY PRACTICES ARE USED AND ENFORCED AT ALL TIMES.

Generic Notes and Cues:

CMC switches will turn RED and amperage will increase when the switch is rotated to the start position started. The current should initially be five to seven times the normal running amps with the ammeter flashing. As counter EMF is developed, the amperage will lower to the normal running amperage and the ammeter will no longer flash. CMC switches will turn GREEN when the pumps are stopped and amperage will decrease to zero.

Ex.: Pump start: "Switch has been rotated to the start position, red light is lit, green light is out, amperage initially pegs out high, and is now indicating X amps."

Pump stop: "Switch has been rotated to the stop position, green light is lit, red light is out, amperage indicates 0 amps."

Remotely operated valve position is determined with open and close indicating lights. A RED light only would indicate that the valve is open. A GREEN light only would indicate that the valve is closed. Dual indication would indicate that the valve is in some intermediate position.

Manual valves are checked in the closed direction (MOP02 and MOP05). Valve stem position may aid in valve position determination, but cannot be used as Independent Verification (MOP02).

Ex.: Verify valve closed: "Valve handwheel indicates no valve movement in the clockwise direction."

Verify valve open: "Valve handwheel has been rotated slightly in the clockwise direction and returned to the original positions."

Closing a valve: "Valve handwheel has been rotated in the fully clockwise direction until no additional valve movement. Valve stem is down."

Opening a valve: "Valve handwheel has been rotated in the fully counterclockwise direction until no additional valve movement, valve stem is out."

Controllers have an Auto light that is GREEN when selected and AMBER (YELLOW) when Manual is selected. When in Manual, the open and closed pushbuttons control the parameter to be changed by adjusting position or speed. When the deviation meter is nulled, then the process can be shifted to Auto to allow the desired setpoint to control the process.

System Specific Notes and Cues:

None

Task Performance and Cues:

The Elements of this JPM are step by step in accordance with the procedure. The Standard is that the procedure is performed as written. The Cues are as listed above for indication or as each step is completed the appropriate information is reported to the examinee. Notify Examinee that time compression may be used for activities performed outside of the Control Room.

Critical Steps:

Critical Tasks are identified by asterisk (*) and **bolded** steps on the cover sheet. Verify that the latest revision of the procedure is used and critical tasks are correctly identified.

JOB PERFORMANCE MEASURE
NRC EXAM 2008

JPM Title On-Site Protective Actions and Classification for Security Event	No.: 08-A-007 Revision: 0 Page 5
--	--

FOLLOW-UP DOCUMENTATION QUESTIONS

Reason for follow-up question(s):

Question:

Reference:

Response:

Question:

Reference

Response:

JOB PERFORMANCE MEASURE
NRC EXAM 2008

JPM Title On-Site Protective Actions and Classification for Security Event	No.: 08-A-007 Revision: 0 Page 6
--	--

Simulator Setup

IC#:

N/A

Malfunctions:

Number	Title	Value	Delay	Ramp
N/A				

Remote Functions:

Number	Title	Value	Delay	Ramp
N/A				

Override Functions:

Number	Title	Value	Delay	Ramp
N/A				

Special Instructions:

N/A

Cue Sheet

Initial Conditions:

- This JPM is time critical.
- You are the Shift Manager.
- The Reactor is shutdown.
- Reactor level and pressure are being controlled in normal bands.
- No other EOP entry conditions exist.
- The CRS is executing the Hostile Threat AOP.

Initiating Cue(s):

- A Hostile Attack is in progress from an unknown group of approximately 5 to 10 armed individuals.
- These individuals have attacked the EF2 Drive Gate House and obtained entry into the Owner Controlled Area. They are on the 120 KV Mat.
- Perform on-site protective actions and classify the event.