

John Carlin
Site Vice President

R.E. Ginna Nuclear Power Plant, LLC
1503 Lake Road
Ontario, New York 14519-9364
585.771.5200
585.771.3943 Fax
John.carlin@constellation.com



May 12, 2008

U. S. Nuclear Regulatory Commission
Washington, DC 20555


ATTENTION: Document Control Desk

SUBJECT: **R.E. Ginna Nuclear Power Plant**
Docket No. 50-244
Annual Radioactive Effluent Release and Radiological Environmental
Operating Reports

Ladies and Gentlemen:

R. E. Ginna Nuclear Power Plant, LLC is pleased to submit the enclosed Annual Radioactive Effluent Release and Annual Radiological Environmental Operating Reports, prepared in accordance with Technical Specification Section 5.6.3 and Technical Specification 5.6.2, respectively.

Should you have questions regarding the enclosed documents, please contact Tom Harding at (585) 771-3384.

Very truly yours,

John Carlin

Enclosures: Annual Radioactive Effluent Release Report
Annual Radiological Environmental Operating Report

cc: S. J. Collins, NRC
D. V. Pickett, NRC
Resident Inspector, NRC

1001963

IE48
IE25
NRR

State Emergency Management Office
Building #2, First Sublevel
State Campus
Albany, NY 12226-5000
Attn: Jay Dunkleberger

NYS Department of Public Service
3 Empire State Plaza, 10th Floor
Albany, NY 12223
Attn: Paul Eddy

American Nuclear Insurers
95 Glastonbury, Blvd.
Glastonbury, CT 06033
Attn: Thomas Wolff

INPO
700 Galleria Parkway
Atlanta, GA 30339-5957

2007

ANNUAL RADIOACTIVE EFFLUENT RELEASE REPORT

R. E. GINNA NUCLEAR POWER PLANT

DOCKET NO. 50-244

TABLE OF CONTENTS

1.0	INTRODUCTION	4
2.0	SUPPLEMENTAL INFORMATION.....	4
2.1	<u>Regulatory Limits</u>	4
2.2	<u>Effluent Air and Water Concentrations</u>	6
2.3	<u>Release Rate Limits</u>	6
2.4	<u>Measurements and Approximations of Total Radioactivity</u>	6
2.5	<u>Batch Releases</u>	7
2.6	<u>Abnormal Releases</u>	7
3.0	SUMMARY OF GASEOUS RADIOACTIVE EFFLUENTS	8
4.0	SUMMARY OF LIQUID RADIOACTIVE EFFLUENTS	8
5.0	SOLID WASTE	8
6.0	LOWER LIMIT OF DETECTION	8
7.0	RADIOLOGICAL IMPACT.....	9
8.0	METEOROLOGICAL DATA	10
9.0	LAND USE CENSUS CHANGES.....	10
10.0	CHANGES TO THE OFFSITE DOSE CALCULATION MANUAL.....	10
11.0	CHANGES TO THE PROCESS CONTROL PROGRAM.....	10
12.0	MAJOR CHANGES TO THE RADWASTE TREATMENT SYSTEMS	10
13.0	INOPERABLE MONITORS.....	10
14.0	GROUNDWATER SAMPLING RESULTS.....	10
15.0	CHANGES TO PREVIOUS ANNUAL EFFLUENT OPERATING REPORTS.....	10

LIST OF TABLES

Table 1A Gaseous Effluents - Summation of all Releases	11
Table 2A Liquid Effluents - Summation of all Releases.....	13
Table 1B Gaseous Effluents - Continuous and Batch Releases	15
Table 2B Liquid Effluents - Continuous and Batch Releases.....	17
Table 3 Solid Waste and Irradiated Fuel Shipments.....	19
Table 4A Radiation Dose to Nearest Individual Receptor from Gaseous Releases	20
Table 4B Radiation Dose to Nearest Individual Receptor from Liquid Releases.....	24
Table 5 Groundwater Sampling Results.....	25

1.0 INTRODUCTION

This Annual Radioactive Effluent Release Report is for the R. E. Ginna Nuclear Power Plant and is submitted in accordance with the requirements of Technical Specification Section 5.6.3. The report covers the period from January 1, 2007 through December 31, 2007.

This report includes a summary of the quantities of radioactive gaseous and liquid effluents and solid waste released from the plant presented in the format outlined in Appendix B of Regulatory Guide 1.21, Revision 1, June 1974.

All gaseous and liquid effluents discharged during this reporting period were in compliance with the limits of the R. E. Ginna Technical Specifications as defined in the Offsite Dose Calculation Manual (ODCM).

2.0 SUPPLEMENTAL INFORMATION

2.1 Regulatory Limits

The ODCM limits applicable to the release of radioactive material in liquid and gaseous effluents are:

2.1.1 Fission and Activation Gases

The instantaneous dose rate, as calculated in the ODCM, due to noble gases released in gaseous effluents from the site shall be limited to a release rate which would yield ≤ 500 mrem/yr to the total body and ≤ 3000 mrem/yr to the skin if allowed to continue for a full year.

The air dose, as calculated in the ODCM, due to noble gases released in gaseous effluents from the site shall be limited to the following:

- (i) During any calendar quarter to ≤ 5 mrad for gamma radiation and to ≤ 10 mrad for beta radiation.
- (ii) During any calendar year to ≤ 10 mrad for gamma radiation and to ≤ 20 mrad for beta radiation.

2.1.2 Radioiodine, Tritium, and Particulates

The instantaneous dose rate, as calculated in the ODCM, due to radioactive materials released in gaseous effluents from the site as radioiodines, radioactive materials in particulate form, and radionuclides other than noble gases with half-lives greater than 8 days shall be limited to a release rate which would yield ≤ 1500 mrem/yr to any organ if allowed to continue for a full year.

The dose to an individual, as calculated in the ODCM, from radioiodine, radioactive materials in particulate form, and radionuclides other than noble gases with half-lives greater than 8 days released with gaseous effluents from the site shall be limited to the following:

- (i) During any calendar quarter to ≤ 7.5 mrem to any organ.
- (ii) During any calendar year to ≤ 15 mrem to any organ.

2.1.3 Liquid Effluents

The release of radioactive liquid effluents shall be such that the concentration in the circulating water discharge does not exceed the limits specified in accordance with Appendix B, Table II, Column 2 and notes thereto of 10 CFR 20, as explained in Section 1 of the ODCM. For dissolved or entrained noble gases the total activity due to dissolved or entrained noble gases shall not exceed $2E-04$ uCi/ml.

The dose or dose committed to an individual as calculated in the ODCM from radioactive materials in liquid effluents released to unrestricted areas shall be limited:

- (i) During any calendar quarter to < 1.5 mrem to the total body and to < 5 mrem to any organ, and
- (ii) During any calendar year to < 3 mrem to the total body and to < 10 mrem to any organ.

2.2 Effluent Air and Water Concentrations

- 2.2.1 For gaseous effluents, effluent concentration limits are not directly used in release rate calculations since the applicable limits are stated in terms of dose rate at the unrestricted area boundary, in accordance with Technical Specification 5.5.4.g.
- 2.2.2 For liquid effluents, ten times the effluent concentration values specified in 10 CFR 20, Appendix B, Table II, Column 2, are used to calculate release rates and permissible concentrations at the unrestricted area boundary as permitted by Technical Specification 5.5.4.b. A value of $2E-04$ uCi/ml is used as the ECL for dissolved and entrained noble gases in liquid effluents.

2.3 Release Rate Limits

The release rate limits for fission and activation gases from the R. E. Ginna Nuclear Power Plant are not based on the average energy of the radionuclide mixture in gaseous effluents; therefore, this value is not applicable. However the 2007 average beta/gamma energy of the radionuclide mixture in fission and activation gases released from Ginna is available for review upon request.

2.4 Measurements and Approximations of Total Radioactivity

Gamma spectroscopy was the primary analysis method used to determine the radionuclide composition and concentration of gaseous and liquid effluents. Composite samples were analyzed for Sr-89, Sr-90, and Fe-55 by a contract laboratory. Tritium and alpha were performed using liquid scintillation and gas flow proportional counting respectively.

The total radioactivity in effluent releases was determined from the measured concentration of each radionuclide present and the total volume of effluents released.

2.5 Batch Releases

2.5.1 Liquid

1. Number of batch releases:	1.17 E+02
2. Total time period for batch releases:	1.06 E+06 min
3. Maximum time period for a batch release:	4.47 E+04 min
4. Average time period for batch releases:	9.06 E+03 min
5. Minimum time period for a batch release:	8.00 E+00 min
6. Average blowdown (LPM) during periods of effluent release into the discharge canal:	4.34 E+02 lpm

2.5.2 Gaseous

1. Number of batch releases:	4.50 E+01
2. Total time period for batch releases:	5.30 E+05 min
3. Maximum time period for a batch release:	4.46 E+04 min
4. Average time period for batch releases:	1.18 E+04 min
5. Minimum time period for a batch release:	2.60 E+01 min

2.6 Abnormal Releases

There were no abnormal or unplanned releases in 2007. Examples of ventilation system deficiencies that could result in small quantities of air exiting controlled areas by pathways other than monitored vent exhaust have been documented by the corrective action process. Sampling did not result in any measured radioactivity. Gaseous release permit methodology is conservative against small deviations in flow direction, if activity were present.

3.0 SUMMARY OF GASEOUS RADIOACTIVE EFFLUENTS

The quantities of radioactive material released in gaseous effluents are summarized in Tables 1A and 1B. Plant Vent and Containment Vent releases are modeled as mixed mode and Air Ejector is modeled as ground level release. In 2005, Ginna revised gaseous release procedures to remove the unrealistically conservative step of including sample activity that was less than the Minimum Detectable Activity, MDA, (which is the calculated *a posteriori* LLD for each sample counted), as if it were actually a measured value. This conservatism had been included in procedures years ago to account for sample purges and valve leakage which have since been demonstrated to be dramatically lower than the conservative estimate. Any leaks or purges with measurable activity are now included in release permits by integration of Radiation Monitoring System (RMS) data. This change has resulted in lower total reported activity in gaseous effluents for 2007 as compared to years prior to 2005.

4.0 SUMMARY OF LIQUID RADIOACTIVE EFFLUENTS

The quantities of radioactive material released in liquid effluents are summarized in Tables 2A and 2B.

5.0 SOLID WASTE

The quantities of radioactive material released in shipments of solid waste transported from the site during the reporting period are summarized in Table 3. Principal nuclides were determined by gamma spectroscopy and non-gamma emitters were calculated from scaling factors determined by an independent laboratory from representative samples of that waste type. The majority of Dry Active Waste is processed utilizing an off-site processor who reduces the volume and then sends the waste for burial.

6.0 LOWER LIMIT OF DETECTION

The required Lower Limit of Detection, (LLD), as defined in the ODCM, was met for all samples used in reporting effluent releases for 2007.

All samples also met the *a posteriori* Minimum Detectable Activity (MDA).

7.0 RADIOLOGICAL IMPACT

An assessment of doses to the maximally exposed individual from gaseous and liquid effluents was performed for locations representing the maximum calculated dose in occupied sectors. Meteorological sectors from WNW through ENE are entirely over Lake Ontario. In all cases, doses were well below Technical Specification limits as defined in the ODCM. Doses were assessed based upon historical meteorological conditions considering the noble gas exposure, inhalation, ground plane exposure, and ingestion pathways. The ingestion pathways considered were the fruit, vegetable, fish, drinking water, goat's milk, cow's milk, and cow meat pathways. Results of this assessment are presented in Tables 4A and 4B. Since September 11, 2001, Ginna Security has been augmented by full-time presence of the New York State Police and the New York National Guard. These personnel have posts within the site boundary. For this reason, the exposure and uptake pathways for 2007 are calculated using meteorological dispersion and deposition parameters at onsite posts, as well as at the site boundary.

7.1 Total Dose

40 CFR 190 limits the total dose to members of the public due to radiation and radioactivity from uranium fuel cycle sources to:

<25 mrem total body or any organ and;
<75 mrem thyroid for a calendar year.

Using the maximum exposure and uptake pathways, the maximum liquid pathways, and the direct radiation measurements onsite in the vicinity of the National Guard outpost, yield the following dose summaries to the maximally exposed individual member of the public onsite.

2.60E+00 mrem total body (2.60E+00 mrem direct radiation plus 4.81E-03 mrem all other pathways).
4.86E-03 mrem GI-LLI (maximum organ dose).

Using the maximum exposure and uptake pathways, the maximum liquid pathways, and the direct radiation measurements at the site boundary, yield the following dose summaries to the hypothetical maximally exposed individual member of the public offsite. This dose conservatively bounds any real member of the public.

6.00E+00 mrem total body (6.00E+00 mrem direct radiation plus 4.81E-03 mrem all other pathways).
4.86E-03 mrem GI-LLI (maximum organ dose).

8.0 METEOROLOGICAL DATA

The annual summary of hourly meteorological data collected during 2007 is not included with this report, but can be made available at the R. E. Ginna Nuclear Power Plant.

9.0 LAND USE CENSUS CHANGES

There were no changes in critical receptor location for dose calculations during the reporting period. There were no large changes in land use within 5 miles of the plant. Additional new homes are being built at consistent rate compared to past years.

10.0 CHANGES TO THE OFFSITE DOSE CALCULATION MANUAL

There were no changes to the ODCM during the reporting period.

11.0 CHANGES TO THE PROCESS CONTROL PROGRAM

There were no changes to the Process Control Program during the reporting period.

12.0 MAJOR CHANGES TO THE RADWASTE TREATMENT SYSTEMS

There were no major changes to the Radwaste Treatment Systems during the reporting period.

13.0 INOPERABLE MONITORS

No gaseous effluent monitors were inoperable for greater than 7 days in 2007.

14.0 GROUNDWATER SAMPLING RESULTS

No inadvertent releases to groundwater occurred during 2007. Sample results are included in Table 5.

15.0 CHANGES TO PREVIOUS ANNUAL EFFLUENT OPERATING REPORTS

None

R. E. Ginna Nuclear Power Plant

Table 1A

EFFLUENT AND WASTE DISPOSAL ANNUAL REPORT
GASEOUS EFFLUENTS - SUMMATION OF ALL RELEASES
 January – June 2007

	Unit	Quarter 1 st	Quarter 2 nd	Est. Total Error, %
A. Fission & Activation Gases				
1. Total release	Ci	1.82E-01	4.32E-01	1.50E+01
2. Average release rate for period	uCi/sec	2.34E-02	5.50E-02	
3. Percent of Technical Specification limit	%	3.71E-05	8.73E-05	
B. Iodines				
1. Total iodine-131	Ci			
2. Average release rate for period	uCi/sec			
3. Percent of Technical Specification limit	%			
C. Particulates				
1. Particulates with half-lives > 8 days	Ci			
2. Average release rate for period	uCi/sec			
3. Percent of Technical Specification limit	%			
4. Gross alpha radioactivity	Ci			
D. Tritium				
1. Total release	Ci	7.39E+00	7.47E+00	9.20E+00
2. Average release rate for period	uCi/sec	9.50E-01	9.49E-01	
3. Percent of Technical Specification limit	%	1.12E-04	1.12E-04	

Note: Isotopes for which no value is given were not identified in applicable releases.

R. E. Ginna Nuclear Power Plant

Table 1A

EFFLUENT AND WASTE DISPOSAL ANNUAL REPORT
GASEOUS EFFLUENTS - SUMMATION OF ALL RELEASES
 July – December 2007

	Unit	Quarter 3 rd	Quarter 4 th	Est. Total Error, %
A. Fission & Activation Gases				
1. Total release	Ci	2.89E-01	3.03E-01	1.50E+01
2. Average release rate for period	uCi/sec	3.63E-02	3.81E-02	
3. Percent of Technical Specification limit	%	5.76E-05	6.05E-05	
B. Iodines				
1. Total iodine-131	Ci			
2. Average release rate for period	uCi/sec			
3. Percent of Technical Specification limit	%			
C. Particulates				
1. Particulates with half-lives > 8 days	Ci			
2. Average release rate for period	uCi/sec			
3. Percent of Technical Specification limit	%			
4. Gross alpha radioactivity	Ci			
D. Tritium				
1. Total release	Ci	7.29E+00	5.80E+00	9.20E+00
2. Average release rate for period	uCi/sec	9.17E-01	7.30E-01	
3. Percent of Technical Specification limit	%	1.08E-04	8.59E-05	

Note: Isotopes for which no value is given were not identified in applicable releases.

R. E. Ginna Nuclear Power Plant

Table 2A

EFFLUENT AND WASTE DISPOSAL ANNUAL REPORT

LIQUID EFFLUENTS - SUMMATION OF ALL RELEASES

January - June 2007

	Unit	Quarter 1 st	Quarter 2 nd	Est. Total Error, %
A. Fission & Activation Products				
1. Total release (not including tritium, gases, alpha)	Ci	5.65E-03	9.24E-03	9.90E+00
2. Average diluted concentration during period	uCi/ml	1.30E-11	1.82E-11	
3. Percent of applicable limit	%	4.45E-12	3.80E-12	
B. Tritium				
1. Total release	Ci	2.73E+01	1.85E+02	9.20E+00
2. Average diluted concentration during period	uCi/ml	6.31E-08	3.64E-07	
3. Percent of applicable limit	%	3.16E-01	1.82E+00	
C. Dissolved and entrained gases				
1. Total release	Ci		1.37E-04	9.90E+00
2. Average diluted concentration during period	uCi/ml		2.70E-13	
3. Percent of applicable limit	%		1.35E-07	
D. Gross alpha radioactivity				
1. Total release	Ci			
E. Volume of waste released (prior to dilution)				
	Liters	9.04E+07	9.55E+07	
F. Volume of dilution water used during period				
	Liters	4.34E+11	5.07E+11	

Note: Isotopes for which no value is given were not identified in applicable releases.

R. E. Ginna Nuclear Power Plant

Table 2A

EFFLUENT AND WASTE DISPOSAL ANNUAL REPORT

LIQUID EFFLUENTS - SUMMATION OF ALL RELEASES

July - December 2007

	Unit	Quarter 3 rd	Quarter 4 th	Est. Total Error, %
A. Fission & Activation Products				
1. Total release (not including tritium, gases, alpha)	Ci	7.02E-03	8.72E-05	9.90E+00
2. Average diluted concentration during period	uCi/ml	1.37E-11	1.78E-13	
3. Percent of applicable limit	%	3.74E-12	9.38E-13	
B. Tritium				
1. Total release	Ci	1.63E+02	3.89E+01	9.20E+00
2. Average diluted concentration during period	uCi/ml	3.19E-07	7.93E-08	
3. Percent of applicable limit	%	1.60E+00	3.97E-01	
C. Dissolved and entrained gases				
1. Total release	Ci	3.36E-05		9.90E+00
2. Average diluted concentration during period	uCi/ml	6.55E-14		
3. Percent of applicable limit	%	3.27E-08		
D. Gross alpha radioactivity				
1. Total release	Ci			
E. Volume of waste released (prior to dilution)				
	Liters	9.66E+07	1.01E+08	
F. Volume of dilution water used during period				
	Liters	5.12E+11	4.91E+11	

Note: Isotopes for which no value is given were not identified in applicable releases.

R. E. Ginna Nuclear Power Plant

Table 1B

EFFLUENT AND WASTE DISPOSAL ANNUAL REPORT

GASEOUS EFFLUENTS – CONTINUOUS AND BATCH RELEASES
January – June 2007

Nuclides released	Unit	Continuous Mode		Batch Mode	
		Quarter 1 st	Quarter 2 nd	Quarter 1 st	Quarter 2 nd
1. Fission Gases					
Argon-41	Ci			7.10E-02	6.93E-02
Krypton-85	Ci				
Krypton-85m	Ci				
Krypton-87	Ci				
Krypton-88	Ci				
Xenon-131m	Ci				9.84E-04
Xenon-133	Ci			1.10E-01	3.59E-01
Xenon-133m	Ci				4.33E-04
Xenon-135	Ci			8.23E-04	2.07E-03
Xenon-135m	Ci				
Xenon-138	Ci				
Others (specify)	Ci				
Xenon-135	Ci				
	Ci				
	Ci				
Total for period	Ci	0.00E+00	0.00E+00	1.82E-01	4.30E-01
2. Iodines					
Iodine-131	Ci				
Iodine-132	Ci				
Iodine-133	Ci				
Total for period	Ci	0.00E+00	0.00E+00	0.00E+00	0.00E+00
3. Particulates					
Strontium-89	Ci				
Strontium-90	Ci				
Cesium-134	Ci				
Cesium-137	Ci				
Niobium-95	Ci				
Cobalt-58	Ci				
Cobalt-60	Ci				
Others (specify)	Ci				
Total for period	Ci	0.00E+00	0.00E+00	0.00E+00	0.00E+00

Note: Isotopes for which no value is given were not identified in applicable releases.

R. E. Ginna Nuclear Power Plant

Table 1B

EFFLUENT AND WASTE DISPOSAL ANNUAL REPORT

GASEOUS EFFLUENTS – CONTINUOUS AND BATCH RELEASES

July – December 2007

Nuclides released	Unit	Continuous Mode		Batch Mode	
		Quarter 3 rd	Quarter 4 th	Quarter 3 rd	Quarter 4 th
1. Fission Gases					
Argon-41	Ci			7.20E-02	7.36E-02
Krypton-85	Ci				
Krypton-85m	Ci				
Krypton-87	Ci				
Krypton-88	Ci				
Xenon-131m	Ci				
Xenon-133	Ci			2.15E-01	2.28E-01
Xenon-133m	Ci				
Xenon-135	Ci			1.71E-03	1.77E-03
Xenon-135m	Ci				
Xenon-138	Ci				
Others (specify)	Ci				
	Ci				
	Ci				
	Ci				
Total for period	Ci	0.00E+00	0.00E+00	2.89E-01	3.03E-01
2. Iodines					
Iodine-131	Ci				
Iodine-132	Ci				
Iodine-133	Ci				
Total for period	Ci	0.00E+00	0.00E+00	0.00E+00	0.00E+00
3. Particulates					
Strontium-89	Ci				
Strontium-90	Ci				
Cesium-134	Ci				
Cesium-137	Ci				
Niobium-95	Ci				
Cobalt-58	Ci				
Cobalt-60	Ci				
Zirconium-95	Ci				
Total for period	Ci	0.00E+00	0.00E+00	0.00E+00	0.00E+00

Note: Isotopes for which no value is given were not identified in applicable releases.

R. E. Ginna Nuclear Power Plant

Table 2B

EFFLUENT AND WASTE DISPOSAL ANNUAL REPORT

LIQUID EFFLUENTS – CONTINUOUS AND BATCH RELEASES

January – June 2007

Nuclides released	Unit	Continuous Mode		Batch Mode	
		Quarter	Quarter	Quarter	Quarter
		1 st	2 nd	1 st	2 nd
Nuclide					
Chromium-51	Ci				
Manganese-54	Ci				
Iron-55	Ci				
Cobalt-57	Ci				
Cobalt-58	Ci			3.96E-04	3.09E-04
Iron-59	Ci				
Cobalt-60	Ci			2.64E-05	5.01E-05
Zinc-65	Ci				
Stronium-89	Ci				
Stronium-90	Ci				
Niobium-95	Ci			6.13E-06	
Zirconium-95	Ci				
Molybdenum-99	Ci				
Silver-110m	Ci				
Antimony-122	Ci				
Antimony-124	Ci				
Antimony-125	Ci				1.98E-05
Iodine-131	Ci				
Iodine-132	Ci				
Tellurium-132	Ci				
Cesium-134	Ci				
Iodine-135	Ci				
Cesium-136	Ci				
Cesium-137	Ci				
Barium/Lanthanum-140	Ci				
Cerium-141	Ci				
Tellurium-123m	Ci			4.07E-05	5.74E-05
Tellurium-125m	Ci			5.18E-03	8.80E-03
Total for period	Ci	0.00E+00	0.00E+00	5.65E-03	9.24E-03
Xenon-133	Ci				1.37E-04
Xenon-135	Ci				

Note: Isotopes for which no value is given were not identified in applicable releases.

R. E. Ginna Nuclear Power Plant

Table 2B

EFFLUENT AND WASTE DISPOSAL ANNUAL REPORT

LIQUID EFFLUENTS – CONTINUOUS AND BATCH RELEASES

July – December 2007

Nuclides released	Unit	Continuous Mode		Batch Mode	
		Quarter 3 rd	Quarter 4 th	Quarter 3 rd	Quarter 4 th
Nuclide					
Chromium-51	Ci				
Manganese-54	Ci				
Iron-55	Ci				
Cobalt-57	Ci				
Cobalt-58	Ci			9.78E-05	3.57E-05
Iron-59	Ci				
Cobalt-60	Ci			4.88E-05	5.15E-05
Zinc-65	Ci				
Strontium-89	Ci				
Strontium-90	Ci				
Niobium-95	Ci				
Zirconium-95	Ci				
Molybdenum-99	Ci				
Silver-110m	Ci				
Antimony-122	Ci				
Antimony-124	Ci				
Antimony-125	Ci				
Iodine-131	Ci				
Iodine-132	Ci				1.42E-04
Tellurium-132	Ci				1.64E-04
Cesium-134	Ci				
Iodine-135	Ci				
Cesium-136	Ci				
Cesium-137	Ci				
Barium/Lanthanum-140	Ci				
Cerium-141	Ci				
Tellurium-123m	Ci			3.22E-05	
Tellurium-125m	Ci			6.85E-03	
Total for period	Ci	0.00E+00	0.00E+00	7.03E-03	8.72E-05
Xenon-133	Ci			3.36E-05	
Xenon-135	Ci				

Note: Isotopes for which no value is given were not identified in applicable releases.

Table 3
EFFLUENT AND WASTE DISPOSAL ANNUAL REPORT
SOLID WASTE AND IRRADIATED FUEL SHIPMENTS
 January 1, 2007 - December 31, 2007

A. SOLID WASTE SHIPPED OFFSITE FOR BURIAL OR DISPOSAL - (Not irradiated fuel)

1. Type of waste	Unit	12 month period	Est. total Error %
a. Spent resins, filter sludges, evaporator bottoms, etc.	m ³	8.42E+01	7.00E+00
	Ci	8.21E+01	1.40E+01
b. Dry compressible waste, contaminated equip, etc.	m ³	2.19E+02	7.00E+00
	Ci	2.39E-02	1.40E+01
c. Irradiated components, control rods, etc.	m ³	None	N/A
	Ci		
d. Other: Condensate Cooler	m ³	8.72E+00	7.00E+00
	Ci	1.42E-03	1.40E+01

2. Estimate of major nuclide composition (by type of waste)								
a.			b.			d. (None)		
Co-58	%	1.30E-01	Fe-55	%	2.54E+01	Co-60	%	3.66E+01
Ni-63	%	7.12E+01	Co-58	%	1.49E+01	Ni-63	%	5.84E+01
Co-60	%	1.19E+01	Ni-63	%	2.54E+01	Ag-110m	%	5.00E-01
Cs-137	%	3.85E+00	Cr-51	%	2.07E+00	Cs-137	%	2.50E+00
Fe-55	%	1.10E+01	Co-60	%	2.35E+01	Ce-144	%	2.00E+00
Sb-125	%	3.90E-01	Zr-95	%	7.90E-01		%	
Ce-144	%	3.00E-02	Ag-110m	%	1.71E+00		%	
Mn-54	%	3.50E-01	Cs-137	%	2.02E+00		%	
Ag-110m	%	3.00E-03	Sb-125	%	8.30E-01		%	
H-3	%	1.50E-01	H-3	%	7.90E-01		%	
Total		9.90E+01	Total		9.74E+01	Total		1.00E+02

3. Solid Waste Disposition		
Number of Shipments	Mode of Transportation	Destination
1.00E+00	Sole Use Truck	Barnwell, SC
4.00E+00	Sole Use Truck	Duratek, TN
2.00E+00	Sole Use Truck	Studsvik, TN
1.00E+00	Sole Use Truck	Toxco, TN

B. IRRADIATED FUEL SHIPMENTS (Disposition)

Number of Shipments	Mode of Transportation	Destination
None	N/A	N/A

R. E. Ginna Nuclear Power Plant

Table 4A
Radiation Dose to Maximum Individual Receptor
First Quarter 2007
(Units in rem)

	All	All	Adult	Teen	Child	Infant
	Noble Gas	Noble Gas	Thyroid	Thyroid	Thyroid	Thyroid
	Air Gamma	Air Beta				
N	1.90E-09	9.51E-10				
NNE	1.59E-09	7.97E-10				
NE	1.84E-09	9.19E-10				
ENE	2.33E-09	1.17E-09				
E	4.24E-09	2.12E-09	2.06E-07	2.26E-07	3.10E-07	1.35E-07
ESE	5.40E-09	2.70E-09	2.63E-07	2.87E-07	3.94E-07	1.72E-07
SE	3.27E-09	1.63E-09	1.59E-07	1.74E-07	2.39E-07	1.04E-07
SSE	1.35E-09	6.73E-10	6.55E-08	7.16E-08	9.84E-08	4.28E-08
S	2.36E-09	1.18E-09	1.15E-07	1.25E-07	1.72E-07	7.49E-08
SSW	2.36E-09	1.18E-09	1.15E-07	1.25E-07	1.72E-07	7.49E-08
SW	2.36E-09	1.18E-09	1.15E-07	1.25E-07	1.72E-07	7.49E-08
WSW	2.51E-09	1.26E-09	1.22E-07	1.33E-07	1.83E-07	7.99E-08
W	1.60E-09	7.99E-10	7.77E-08	8.49E-08	1.17E-07	5.08E-08
WNW	1.35E-10	6.75E-11				
NW	4.42E-10	2.21E-10				
NNW	1.38E-09	6.92E-10				
Maximum	5.40E-09	2.70E-09	2.626E-07	2.869E-07	3.944E-07	1.718E-07

R. E. Ginna Nuclear Power Plant

Table 4A
Radiation Dose to Maximum Individual Receptor
Second Quarter 2007
(Units in rem)

	All	All	Adult	Teen	Child	Infant
	Noble Gas	Noble Gas	Thyroid	Thyroid	Thyroid	Thyroid
	Air Gamma	Air Beta				
N	2.11E-09	1.66E-09				
NNE	1.76E-09	1.39E-09				
NE	2.03E-09	1.60E-09				
ENE	2.58E-09	2.04E-09				
E	4.70E-09	3.70E-09	2.08E-07	2.28E-07	3.14E-07	1.37E-07
ESE	5.98E-09	4.71E-09	2.65E-07	2.90E-07	3.99E-07	1.74E-07
SE	3.62E-09	2.85E-09	1.60E-07	1.76E-07	2.41E-07	1.05E-07
SSE	1.49E-09	1.17E-09	6.61E-08	7.24E-08	9.96E-08	4.34E-08
S	2.61E-09	2.05E-09	1.16E-07	1.27E-07	1.74E-07	7.60E-08
SSW	2.61E-09	2.05E-09	1.16E-07	1.27E-07	1.74E-07	7.60E-08
SW	2.61E-09	2.05E-09	1.16E-07	1.27E-07	1.74E-07	7.60E-08
WSW	2.78E-09	2.19E-09	1.23E-07	1.35E-07	1.86E-07	8.10E-08
W	1.77E-09	1.39E-09	7.84E-08	8.59E-08	1.18E-07	5.15E-08
WNW	1.50E-10	1.18E-10				
NW	4.90E-10	3.86E-10				
NNW	1.53E-09	1.21E-09				
Maximum	5.98E-09	4.71E-09	2.65E-07	2.90E-07	3.99E-07	1.74E-07

R. E. Ginna Nuclear Power Plant

Table 4A
Radiation Dose to Maximum Individual Receptor
Third Quarter 2007
(Units in rem)

	All	All	Adult	Teen	Child	Infant
	Noble Gas	Noble Gas	Thyroid	Thyroid	Thyroid	Thyroid
	Air Gamma	Air Beta				
N	2.03E-09	1.26E-09				
NNE	1.70E-09	1.06E-09				
NE	1.96E-09	1.22E-09				
ENE	2.49E-09	1.55E-09				
E	4.54E-09	2.82E-09	2.03E-07	2.22E-07	3.06E-07	1.34E-07
ESE	5.77E-09	3.59E-09	2.59E-07	2.83E-07	3.89E-07	1.70E-07
SE	3.49E-09	2.17E-09	1.57E-07	1.71E-07	2.35E-07	1.03E-07
SSE	1.44E-09	8.95E-10	6.46E-08	7.06E-08	9.71E-08	4.25E-08
S	2.52E-09	1.57E-09	1.13E-07	1.23E-07	1.70E-07	7.43E-08
SSW	2.52E-09	1.57E-09	1.13E-07	1.23E-07	1.70E-07	7.43E-08
SW	2.52E-09	1.57E-09	1.13E-07	1.23E-07	1.70E-07	7.43E-08
WSW	2.68E-09	1.67E-09	1.20E-07	1.32E-07	1.81E-07	7.92E-08
W	1.71E-09	1.06E-09	7.66E-08	8.37E-08	1.15E-07	5.04E-08
WNW	1.44E-10	8.98E-11				
NW	4.73E-10	2.94E-10				
NNW	1.48E-09	9.20E-10				
Maximum	5.77E-09	3.59E-09	2.59E-07	2.83E-07	3.89E-07	1.70E-07

R. E. Ginna Nuclear Power Plant

Table 4A
Radiation Dose to Maximum Individual Receptor
Fourth Quarter 2007
(Units in rem)

	All	All	Adult	Teen	Child	Infant
	Noble Gas	Noble Gas	Thyroid	Thyroid	Thyroid	Thyroid
	Air Gamma	Air Beta				
N	2.09E-09	1.31E-09				
NNE	1.75E-09	1.10E-09				
NE	2.01E-09	1.27E-09				
ENE	2.56E-09	1.61E-09				
E	4.65E-09	2.93E-09	1.62E-07	1.77E-07	2.43E-07	1.06E-07
ESE	5.92E-09	3.73E-09	2.06E-07	2.26E-07	3.10E-07	1.35E-07
SE	3.58E-09	2.26E-09	1.25E-07	1.37E-07	1.87E-07	8.16E-08
SSE	1.48E-09	9.30E-10	5.14E-08	5.63E-08	7.72E-08	3.36E-08
S	2.58E-09	1.63E-09	8.98E-08	9.85E-08	1.35E-07	5.88E-08
SSW	2.58E-09	1.63E-09	8.98E-08	9.85E-08	1.35E-07	5.88E-08
SW	2.58E-09	1.63E-09	8.98E-08	9.85E-08	1.35E-07	5.88E-08
WSW	2.75E-09	1.73E-09	9.57E-08	1.05E-07	1.44E-07	6.27E-08
W	1.75E-09	1.10E-09	6.09E-08	6.68E-08	9.16E-08	3.99E-08
WNW	1.48E-10	9.33E-11				
NW	4.85E-10	3.05E-10				
NNW	1.52E-09	9.56E-10				
Maximum	5.92E-09	3.73E-09	2.06E-07	2.26E-07	3.10E-07	1.35E-07

R. E. Ginna Nuclear Power Plant

Table 4B
 Radiation Dose to Maximum Individual Receptor
 From Liquid Release
 2007
 (Units in rem)

	Adult	Teen	Child	Infant
First Quarter				
Total Body	1.86E-07	1.32E-07	2.48E-07	2.40E-07
GI-LLI	2.35E-07	1.70E-07	2.64E-07	2.41E-07
Thyroid	1.88E-07	1.34E-07	2.51E-07	2.40E-07
Second Quarter				
Total Body	1.08E-06	7.65E-07	1.44E-06	1.40E-06
GI-LLI	1.14E-06	8.10E-07	1.46E-06	1.40E-06
Thyroid	1.08E-06	7.65E-07	1.44E-06	1.40E-06
Third Quarter				
Total Body	9.55E-07	6.75E-07	1.27E-06	1.23E-06
GI-LLI	1.00E-06	7.10E-07	1.29E-06	1.24E-06
Thyroid	9.55E-07	6.75E-07	1.28E-06	1.23E-06
Fourth Quarter				
Total Body	2.37E-07	1.67E-07	3.15E-07	3.06E-07
GI-LLI	2.37E-07	1.67E-07	3.15E-07	3.06E-07
Thyroid	2.37E-07	1.67E-07	3.15E-07	3.06E-07

R. E. Ginna Nuclear Power Plant

Groundwater Sampling Results

Table 5

LOCATION	DATE SAMPLED	Tritium pCi/L
Groundwater by Butler Bldg.	01/16/07	*
Groundwater by Butler Bldg.	02/07/07	*
Groundwater by Butler Bldg.	03/29/07	*
Groundwater by Butler Bldg.	04/26/07	*
Groundwater by Butler Bldg.	05/31/07	*
Groundwater by Butler Bldg.	06/26/07	*
Groundwater by Butler Bldg.	07/31/07	*
Groundwater by Butler Bldg.	08/15/07	*
Groundwater by Butler Bldg.	09/25/07	*
Groundwater by Butler Bldg.	10/28/07	*
Groundwater by Butler Bldg.	11/29/07	*
Groundwater by Butler Bldg.	12/20/07	*
Groundwater IFFSI work	08/15/07	*
Groundwater SE of CSB	01/16/07	*
Groundwater SE of CSB	02/02/07	*
Groundwater SE of CSB	03/29/07	*
Groundwater SE of CSB	04/26/07	*
Groundwater SE of CSB	05/31/07	*
Groundwater SE of CSB	06/26/07	*
Groundwater SE of CSB	07/31/07	*
Groundwater SE of CSB	08/15/07	*
Groundwater SE of CSB	09/26/07	*
Groundwater SE of CSB	10/28/07	*
Groundwater SE of CSB	11/29/07	*
Groundwater SE of CSB	12/20/07	*
Pond	01/16/07	*
Pond	03/29/07	*
Pond	04/26/07	*
Pond	05/08/07	*
Pond	05/31/07	*
Pond	08/15/07	*
Pond	10/28/07	*
Screen House West	01/16/07	*
Screen House West	03/29/07	*
Screen House West	04/26/07	*
Screen House West	05/31/07	*
Screen House West	06/26/07	*
Screen House West	07/31/07	*
Screen House West	08/15/07	*
Screen House West	09/25/07	*
Screen House West	10/28/07	*
Screen House West	11/29/07	*

* All results are <500 pCi/L unless otherwise shown

R. E. Ginna Nuclear Power Plant

Groundwater Sampling Results

Table 5 continued

LOCATION	DATE SAMPLED	Tritium pCi/L
Storm Drain F	01/16/07	*
Storm Drain F	02/02/07	*
Storm Drain F	03/29/07	*
Storm Drain F	04/26/07	*
Storm Drain F	05/31/07	*
Storm Drain F	06/26/07	*
Storm Drain F	07/31/07	*
Storm Drain F	08/15/07	*
Storm Drain F	09/25/07	*
Storm Drain F	10/28/07	*
Storm Drain F	11/29/07	*
Storm Drain F	12/20/07	*
Storm Drain G	01/16/07	*
Storm Drain G	03/29/07	*
Storm Drain G	04/26/07	*
Storm Drain G	05/31/07	*
Storm Drain G	06/26/07	*
Storm Drain G	07/31/07	*
Storm Drain G	08/15/07	*
Storm Drain G	09/25/07	*
Storm Drain G	10/28/07	*
Storm Drain G	11/29/07	*
Storm Drain G	12/20/07	*
Storm Drain H	01/16/07	*
Storm Drain H	02/02/07	*
Storm Drain H	03/29/07	*
Storm Drain H	04/26/07	*
Storm Drain H	09/26/07	*
Storm Drain H	11/29/07	*
Storm Drain H	12/20/07	*
Storm Drain I	01/16/07	*
Storm Drain I	03/29/07	*
Storm Drain I	04/26/07	*
Storm Drain I	05/31/07	*
Storm Drain I	06/26/07	*
Storm Drain I	07/31/07	*
Storm Drain I	08/15/07	*
Storm Drain I	09/25/07	*
Storm Drain I	10/28/07	*
Storm Drain I	11/29/07	*
Storm Drain I	12/20/07	*

* All results are <500 pCi/L unless otherwise shown


R. E. Ginna Nuclear Power Plant

Groundwater Sampling Results

Table 5 continued

LOCATION	DATE SAMPLED	Tritium pCi/L
Groundwater AVT M. 17'	01/16/07	*
Groundwater AVT M. 17'	02/02/07	*
Groundwater AVT M. 17'	03/29/07	*
Groundwater AVT M. 17'	04/26/07	*
Groundwater AVT M. 17'	05/31/07	*
Groundwater AVT M. 17'	06/26/07	*
Groundwater AVT M. 17'	07/31/07	*
Groundwater AVT M. 17'	08/15/07	*
Groundwater AVT M. 17'	09/25/07	*
Groundwater AVT M. 17'	10/28/07	*
Groundwater AVT M. 17'	11/29/07	*
Groundwater AVT M. 17'	12/20/07	*
Groundwater AVT N. 6'	01/16/07	*
Groundwater AVT N. 6'	02/02/07	*
Groundwater AVT N. 6'	03/29/07	*
Groundwater AVT N. 6'	04/26/07	*
Groundwater AVT N. 6'	05/31/07	*
Groundwater AVT N. 6'	06/26/07	*
Groundwater AVT N. 6'	07/31/07	*
Groundwater AVT N. 6'	08/15/07	*
Groundwater AVT N. 6'	09/25/07	*
Groundwater AVT N. 6'	10/28/07	*
Groundwater AVT N. 6'	11/29/07	*
Groundwater AVT N. 6'	12/20/07	*
Groundwater AVT S. 13'	01/16/07	*
Groundwater AVT S. 13'	02/02/07	*
Groundwater AVT S. 13'	03/29/07	*
Groundwater AVT S. 13'	04/26/07	*
Groundwater AVT S. 13'	05/31/07	*
Groundwater AVT S. 13'	06/26/07	*
Groundwater AVT S. 13'	07/31/07	*
Groundwater AVT S. 13'	08/15/07	*
Groundwater AVT S. 13'	09/25/07	*
Groundwater AVT S. 13'	10/28/07	*
Groundwater AVT S. 13'	11/29/07	*

* All results are <500 pCi/L unless otherwise shown



Constellation Energy[®]
Nuclear Generation Group

**ANNUAL RADIOLOGICAL
ENVIRONMENTAL OPERATING
REPORT: JANUARY 1, 2007 –
DECEMBER 31, 2007**

MAY 2008



Prepared For:

R.E. Ginna Nuclear Power Plant

1503 Lake Road
Ontario, New York 14519

TABLE OF CONTENTS

	Page
I. SUMMARY	1
II. R. E. GINNA NUCLEAR POWER PLANT RADIOLOGICAL ENVIRONMENTAL MONITORING PROGRAM.....	2
II.A. INTRODUCTION.....	2
II.B. PROGRAM.....	2
II.B.1 Objectives	2
II.B.2 Sample Collection.....	2
II.B.3 Data Interpretation	3
II.B.4 Program Exceptions	3
II.C. RESULTS AND DISCUSSIONS	3
II.C.1 Aquatic Environment.....	4
II.C.1.a Surface and Drinking Water	4
II.C.1.b Aquatic Organisms.....	5
II.C.1.c Shoreline Sediment	5
II.C.2 Atmospheric Environment.....	5
II.C.2.a Air Particulate Filters.....	6
II.C.2.b Air Iodine	6
II.C.3 Terrestrial Environment.....	6
II.C.3.a Vegetation.....	6
II.C.3.b Milk.....	7
II.C.4 Direct Radiation.....	7
II.C.5 Monitoring Wells.....	8
II.D. CONCLUSION.....	8
III. REFERENCES	13
APPENDIX A REMP SAMPLE LOCATIONS.....	14
APPENDIX B REMP ANALYTICAL RESULTS.....	23
APPENDIX C QUALITY ASSURANCE PROGRAM.....	46
APPENDIX D LAND USE SURVEY.....	61

LIST OF FIGURES

Figure	Title	Page
A-1	MAP OF NEW YORK STATE AND LAKE ONTARIO SHOWING LOCATION OF THE R. E. GINNA NUCLEAR POWER PLANT	19
A-2	ONSITE SAMPLE LOCATIONS	20
A-3	OFFSITE SAMPLE LOCATIONS (TLDS AND MILK FARMS WITHIN 5 MILES)	21
A-4	WATER SAMPLE, MILK FARMS AND TLD LOCATIONS	22

LIST OF TABLES

Table	Title	Page
1	SYNOPSIS OF R.E. GINNA NUCLEAR POWER PLANT RADIOLOGICAL ENVIRONMENTAL MONITORING PROGRAM.....	9
2	ANNUAL SUMMARY OF RADIOACTIVITY IN THE ENVIRONS OF THE R.E. GINNA NUCLEAR POWER PLANT RADIOLOGICAL ENVIRONMENTAL MONITORING PROGRAM.....	10
A-1	LOCATIONS OF ENVIRONMENTAL SAMPLING STATIONS FOR THE R.E. GINNA NUCLEAR POWER PLANT	16
B-1	CONCENTRATION OF TRITIUM, GAMMA EMITTERS AND GROSS BETA IN SURFACE AND DRINKING WATER.....	25
B-2	CONCENTRATION OF GAMMA EMITTERS IN THE FLESH OF EDIBLE FISH.....	27
B-3	CONCENTRATION OF GAMMA EMITTERS IN SEDIMENT	28
B-4	CONCENTRATION OF IODINE-131 IN FILTERED AIR (CHARCOAL CARTRIDGES)	29
B-5	CONCENTRATION OF BETA EMITTERS IN AIR PARTICULATES – ONSITE SAMPLES	31
B-6	CONCENTRATION OF BETA EMITTERS IN AIR PARTICULATES – OFFSITE SAMPLES	33
B-7	CONCENTRATION OF GAMMA EMITTERS IN AIR PARTICULATES	35
B-8	CONCENTRATION OF GAMMA EMITTERS IN VEGETATION SAMPLES.....	36
B-9	CONCENTRATION OF GAMMA EMITTERS (INCLUDING I-131) IN MILK	37
B-10	TYPICAL MDA RANGES FOR GAMMA SPECTROMETRY	38
B-11	TYPICAL LLDS FOR GAMMA SPECTROMETRY	39
B-12	DIRECT RADIATION	40
B-13	GROUNDWATER MONITORING WELLS	43

C-1	RESULTS OF PARTICIPATION IN CROSS CHECK PROGRAMS.....	48
C-2	RESULTS OF QUALITY ASSURANCE PROGRAM.....	51
C-3	TELEDYNE BROWN ENGINEERING'S TYPICAL MDAS FOR GAMMA SPECTROMETRY	60

I. SUMMARY

The Annual Radiological Environmental Operating Report is published in accordance with Section 5.0 of the Offsite Dose Calculation Manual, (ODCM). This report describes the Radiological Environmental Monitoring Program, (REMP), and its implementation as required by the ODCM.

The REMP is implemented to measure radioactivity in the aquatic and terrestrial pathways. The aquatic pathways include Lake Ontario fish, Lake Ontario water, and Deer Creek water. Measurement results of the samples representing these pathways contained only natural background radiation or low concentrations of Cesium-137 resulting from past atmospheric nuclear weapons testing. Terrestrial pathways monitored included airborne particulate and radioiodine, milk, food products, and direct radiation. Analysis of terrestrial pathways demonstrated no detectable increase in radiation levels as a result of plant operation. The 2007 results were consistent with data for the past five years and exhibited no adverse trends.

The analytical results from the 2007 Radiological Environmental Monitoring program demonstrate that the operation of the R.E. Ginna Nuclear Power Plant had no measurable radiological impact on the environment. The results also demonstrate that operation of the plant did not result in a measurable radiation dose to the general population above natural background levels.

During 2007, 1289 samples were collected for analysis by gross beta counting and/or gamma spectroscopy. These included 60 water samples, 17 fish samples, 6 sediment samples, 4 cladophera samples, 312 air iodine samples, 672 air particulates samples, 36 milk samples, 26 food products samples, and 156 thermoluminescent dosimeter measurements. During 2007 there were three deviations from the sampling schedule for air samples, one deviation from the sampling schedule for milk samples, and one deviation from the sampling schedule for surface water samples. In addition a set of samples were delayed in delivery to the laboratory due to a mistake by the shipping vendor. All deviations were documented in the Corrective Action Program. The minimum number of samples required in the ODCM (Ref. 2) was collected for all pathways.

Samples were collected by R. E. Ginna Nuclear Power Plant's Chemistry personnel and analyzed by the Constellation Energy Ft. Smallwood Environmental Laboratory. A summary of the content of the REMP and the results of all the data collected for indicator and control locations are provided in Tables 1 and 2.

II. R. E. GINNA NUCLEAR POWER PLANT RADIOLOGICAL ENVIRONMENTAL MONITORING PROGRAM

II.A. INTRODUCTION

The R. E. Ginna Nuclear Power Plant (Ginna) is an operating nuclear generating facility consisting of one pressurized water reactor. Unit 1 achieved criticality on September 1969 and commenced commercial operation in July 1970. The location of the plant in relation to local metropolitan areas is depicted in Appendix A, Figure A-1.

Results of the monitoring program for the pre-operational and previous operational periods through 2006 have been reported in a series of documents.

Results of the monitoring program for the current operational period are included in this report. The report presents the content of the REMP (Table 1), the sampling locations (Appendix A), the summary of the analytical results (Table 2), a compilation of the analytical data (Appendix B), the results of the Quality Assurance Program (Appendix C), and the results of the Land Use Survey (Appendix D). Interpretation of the data and conclusions are presented in the body of the report.

The environmental surveillance data collected during this reporting period were compared with that generated in previous periods whenever possible to evaluate the environmental radiological impact of the R. E. Ginna Nuclear Power Plant.

II.B. PROGRAM

II.B.1 Objectives

The objectives of the REMP for the R.E. Ginna Nuclear Power Plant are:

- a. Measure and evaluate the effects of plant operation on the environment.
- b. Monitor background radiation levels in the environs of the Ginna site.
- c. Demonstrate compliance with the environmental conditions and requirements of applicable state and federal regulations, including the ODCM and 40 CFR 190.
- d. Provide information by which the general public can evaluate environmental aspects of the operation of the R.E. Ginna Nuclear Power Plant.

II.B.2 Sample Collection

The locations of the individual sampling stations are listed in Table A-1 and shown in Figures A-2 and A-3. All samples were collected by contractors to, or personnel of Constellation Energy according to Ginna procedures.

II.B.3 Data Interpretation

Many results in environmental monitoring occur at or below the minimum detectable activity (MDA). In this report, all results below the relevant MDA are reported as being "less than" the MDA value. Typical MDA values are listed in Table B-10.

II.B.4 Program Exceptions

Six items reportable in the Annual Environmental Radiological Operating Report under procedure CHA-RETS-VARIATION were reported as follows:

1. Possible damage to environmental air sample #8 from striking filter housing with paintbrush during painting of sample shed on 5/1/07. Analysis showed no deviation from expected result.
2. Circulating Water Outlet water sampler was found out of service on 5/15/07. Compensatory grab samples were taken in accordance with the instructions of the ODCM.
3. Particulate filter on environmental air sampler #12 was damaged during annual pump changeout on 6/4/07 and was replaced.
4. Milk samples taken on 7/10/07 degraded during shipment due to ineffective preservation. Samples were retaken 7/16/07.
5. Environmental air sampler #11 found off 8/13/07. Reset with no subsequent indications of problem. Sample period was 60.1 hours.
6. Milk samples and air samples taken the week of 8/6/07 were lost in shipment by the vendor. Compensatory milk samples were collected and sent 8/14/07. Missing air samples were found by the vendor and resent to the environmental laboratory.

II.C. RESULTS AND DISCUSSIONS

All the environmental samples collected during the year were analyzed using Constellation Energy laboratory procedures (Ref. 3). The analytical results for this reporting period are presented in Appendix B and are also summarized in Table 2. For discussion, the analytical results are divided into four categories. The categories are the Aquatic Environment, the Atmospheric Environment, the Terrestrial Environment, and Direct Radiation. These categories are further divided into subcategories according to sample type (e.g., Circulating Water, Aquatic Organisms, etc., for the Aquatic Environment).

II.C.1 Aquatic Environment

The aquatic environment surrounding the plant was monitored by analyzing samples of surface and drinking water, aquatic organisms, and shoreline sediment. These samples were obtained from various sampling locations on Lake Ontario and Deer Creek near the plant.

II.C.1.a Surface and Drinking Water

Samples are collected weekly from Lake Ontario, upstream (Monroe County Water Authority - Shoremont) and downstream (Ontario Water District Plant - OWD), composited monthly, and analyzed for gross beta activity (Table B-1). There was no statistically significant difference between the upstream and downstream sample concentrations. The 2007 averages were 2.00 pCi/liter and 2.28 pCi/liter for the upstream and downstream samples respectively. Gamma isotopic analysis of the monthly composite samples showed no statistically significant difference in activity between the upstream and downstream samples.

Gross beta peaks of up to 10 pCi/liter can occur when the lake is stirred up by wind and the weekly sample includes large quantities of suspended silt.

Weekly samples are taken from the plant circulating water intake (Circ In) and discharge canal (Circ Out), and composited monthly. The 2007 averages were 2.14 pCi/liter and 2.11 pCi/liter for the intake and discharge canal respectively. These are essentially the same as the upstream and downstream values as they fall within the ± 1 sigma error band and range of the measurement.

Results for all water beta analyses are listed in Table B-1.

Samples of the creek which crosses the site are collected and analyzed monthly. Deer Creek gross beta values are typically higher than other surface water samples due to Radon progeny in the soils from which the creek recharges and over which the creek flows.

Gamma isotopic analysis including I-131 is performed on each monthly composite sample. These are listed in Table B-1 and are separated by source of sample. No anomalous results were noted. The analysis allows the determination of Iodine-131 activity of <1 pCi/liter. Any positive counts and the 1 sigma error are reported. During 2007, no sample results indicated I-131 activity.

Tritium analysis was performed on all water samples on a monthly basis. Composites are made from the weekly samples and a portion filtered to remove interferences for analysis by beta scintillation. During 2007, no sample results indicated tritium activity. Tritium data is provided in Table B-1.

II.C.1.b Aquatic Organisms

Indicator fish are caught in the vicinity of the R.E. Ginna Nuclear Power Plant and analyzed for radioactivity from liquid effluent releases from the plant. The fish are filleted to represent that portion which would normally be eaten. Additional fish are caught more than 15 miles away to be used as control samples and are prepared in the same manner.

Four different species of fish are analyzed during each half-year from the indicator and background locations if they are available. There was no statistically significant difference in the traces of radioactivity of the fish caught between the indicator and control locations.

Fish are caught by R. E. Ginna Nuclear Power Plant environmental staff and are analyzed by gamma spectroscopy after being held for periods of less than one week to keep the LLD value for the shorter half-life isotopes realistic. Detection limits could also be affected by small mass samples, (< 2000 grams), in some species. Gamma isotopic concentrations (pCi/kilogram wet) are provided in Table B-2.

II.C.1.c Shoreline Sediment

Samples of shoreline sediment are taken upstream (Monroe County Water Authority - Shoremont) and downstream (Ontario Water District) of R. E. Ginna Nuclear Power Plant.

Results of the gamma isotopic analysis for sediment are included in Table B-3, along with benthic sediment and cladophera from Lake Ontario. Positive indication of Iodine-131 was found in cladophera samples taken at Ginna. The corrective action process was used to verify that positive indication of Iodine-131 was also found in cladophera samples taken upstream, outside of the influence of Ginna, and results were verified by the New York State Department of Environmental Conservation. The apparent cause of this radioactivity in the cladophera is the common nuclear medicine Iodine-131 treatments and subsequent pathway to Lake Ontario via sanitary sewage releases in nearby communities. Cladophera had been included in the Ginna REMP as a supplemental sample due to its extremely high bioaccumulation factor for iodine.

II.C.2 Atmospheric Environment

Radioactive particles in air are collected by drawing approximately one SCFM through a two inch diameter particulate filter. The volume of air sampled is measured by a dry gas meter and corrected for the pressure drop across the filter. The filters are changed weekly and allowed to decay for three days prior to counting to eliminate most of the natural radioactivity such as the short half-life decay products of radon. The decay period is used to give a more sensitive measurement of long-lived man-made radioactivity.

A ring of 6 sampling stations is located on the plant site from 160 to 420 meters from the reactor centerline near the point of the maximum annual average ground level concentration, 1 more is located on-site at 690 meters, and 2 others offsite at approximately 7 miles. In addition, there are 3 sampling stations located approximately 7 to 16 miles from the site that serve as control stations. See Figure A-2 and Figure A-4.

II.C.2.a Air Particulate Filters

Based on weekly comparisons, there was no statistical difference between the Control and Indicator radioactive particulate concentrations. The averages for the control samples were 0.020 pCi/m³, and the averages for the indicators were 0.020 pCi/m³ for the period of January to December 2007. Maximum weekly concentrations for each station were less than 0.034 pCi/m³.

The major airborne species released from the plant are noble gases and tritium. Most of this activity is released in a gaseous form, however, some of the particulate activity is due to short lived noble gas decay products.

Tables B-5 is a list of gross beta analysis values for the on-site sample stations. Table B-6 is a list of gross beta analysis values for the off-site sampler stations.

The particulate filters from each sampling location were saved and a 13 week composite was made. A gamma isotopic analysis was performed for each sampling location and corrected for decay. One sample indicated a positive result for Cs-137 a factor of 35 times lower than the required limit of detection. This result is consistent with background levels of this long-lived radionuclide released in historical atmospheric weapons tests. The results of these analyses are listed in Table B-7.

II.C.2.b Air Iodine

Radioiodine cartridges are placed at six locations. These cartridges are changed and analyzed each week. No positive analytical results were found on any sample. A list of values for these cartridges is given in Table B-4.

II.C.3 Terrestrial Environment

Crops are grown on the plant property in a location with a highest off-site meteorological deposition parameter, and samples of the produce are collected at harvest time for analysis. Control samples are purchased from farms greater than ten miles from the plant, (e.g. Gro-Moore Farm Market in Henrietta, New York).

II.C.3.a Vegetation

There was no indication in the samples of any activity other than naturally occurring radionuclides and trace levels of Cesium-137 consistent with background levels.

Gamma isotopic data is given in Table B-8.

II.C.3.b Milk

There was one indicator dairy herd located within five miles from the plant on 1/1/07. Milk samples are collected monthly during November through May from the indicator farm and biweekly during June through October. A control farm sample is taken for each monthly sample and once during each biweekly period. The milk is analyzed for Iodine-131 and also analyzed by gamma spectroscopy for major fission products.

All positive counts and the ± 1 sigma error are reported. During 2007, no samples indicated Iodine-131 activity that exceeded the LLD for the analysis. One sample from the control farm indicated trace Cesium-137 activity consistent with background levels.

Table B-9 is a listing of all samples collected during 2007 with analytical results.

II.C.4 Direct Radiation

Thermoluminescent dosimeters (TLDs) or Optically Stimulated Luminescent Dosimeters (OSLs) with a sensitivity of 5 millirem/quarter are placed as part of the environmental monitoring program. Thirty-nine TLD/OSL badges are currently placed in four rings around the plant. These rings range from less than 1000 feet to 15 miles and have been dispersed to give indications in each of the nine land based sectors around the plant should an excessive release occur from the plant. Badges are changed and read after approximately 3 months exposure.

TLD/OSL locations #7 and #13 are influenced by close proximity to radioactive equipment storage areas and will normally read slightly higher than other locations. For the year of 2007 on-site exposure ranged between 9.9 – 14.3 mrem/quarter, with an average exposure of 12.5 mrem/quarter and off-site exposure ranged between 9.8 – 15.4 mrem/quarter with an average exposure of 11.4 mrem/quarter.

40 CFR 190 requires that the annual dose equivalent not exceed 25 millirem to the whole body of any member of the public. Using the annual average of control TLD/OSL stations as background at 43.7 millirem, and the highest site boundary TLD/OSL annual reading, leads to 6.0 millirem direct radiation dose to the hypothetical maximally exposed member of the public, off-site.

Table B-12 gives TLD/OSL readings for each quarter.

II.C.5 Monitoring Wells

In accordance with R. E. Ginna Nuclear Power Plant's Chemistry procedures, environmental groundwater monitoring wells are sampled monthly. There are 3 indicator wells, one of which is screened at 3 depths to include groundwater from top of the water table down to bedrock. One well is located upgradient from the reactor containment building and serves as a local control sample point. Additionally, surface water samples from storm drains and the transformer retention pond are sampled monthly when water is present. These samples are analyzed for tritium to a detection limit of 500 pCi/L. In 2007, no radioactivity was detected in any groundwater sample or storm drain sample. Results of the groundwater monitoring well sampling are presented in Table B-13.

II.D. CONCLUSION

It is concluded that operation of the R. E. Ginna Nuclear Power Plant produced radioactivity and ambient radiation levels significantly below the limits of the ODCM and 40 CFR 190. Additionally, there was no significant buildup of plant-related radionuclides in the environment due to the operations of R. E. Ginna Nuclear Power Plant.

Table 1

Synopsis of R.E. Ginna Nuclear Power Plant Radiological Environmental Monitoring Program

Sample Type	Sampling Frequency ¹	Number of Locations	Number Collected	Analysis	Analysis Frequency ¹	Number Analyzed
Aquatic Environment						
Drinking Water	MC	2	24	Gamma	M	24
				Gross Beta	M	24
				Tritium	M	24
Surface Water	MC	3	36	Gamma	M	36
				Gross Beta	M	36
				Tritium	M	36
Fish ²	SA	4	17	Gamma	SA	17
Sediment	SA	4	6	Gamma	SA	6
Cladophera	A	3	4	Gamma	A	4
Atmospheric Environment						
Air Iodine ³	W	6	312	Gamma	W	312
Air Particulates ⁴	W	12	624	Gross Beta	W	624
	Q	12	48	Gamma	Q	48
Direct Radiation						
Ambient Radiation	Q	39	156	TLD	Q	156
Terrestrial Environment						
Food Products ⁵	A	11	26	Gamma	A	26
Milk	BW (June thru October)	2	22	Gamma	BW	22
	M (November thru May)	2	14	Gamma	M	14

¹ W=Weekly, BW=biweekly (15 days), M=Monthly (31 days), Q=Quarterly (92 days), SA=Semiannual, A=Annual, C= Composite

² Twice during fishing season including at least four species

³ The collection device contains activated charcoal

⁴ Beta counting is performed ≥ 24 hours following filter change. Gamma spectroscopy performed on quarterly composite of weekly samples.

⁵ Annually during growing season. Samples include grapes, apples, cabbage, tomatoes, green leafy vegetables, cucumbers, raspberries, and squash.

Table 2

Annual Summary of Radioactivity in the Environs of the Ginna Nuclear Power Plant

Medium or Pathway Sampled (Unit of Measurement)	Type and Total Number of Analyses Performed	Lower Limit of Detection (LLD)	Indicator Locations Mean (F)/Range ¹	Location with Highest Annual Mean Name/Distance & Direction ²	Highest Annual Mean (F)/Range ¹	Control Locations Mean (F)/Range ¹
Aquatic Environment						
Drinking Water (pCi/L)	Gross Beta 24	0.60	2.28(12/12) (1.32 – 2.73)	Ontario Water District	2.28(12/12) (1.32 – 2.73)	2.06(12/12) (1.15 – 2.48)
	Cs-137 24	2.30	2.82(1/12)	2.2 km ENE Ontario Water District Station 15 2.2 km ENE	2.82(1/12)	³
Surface Water (pCi/L)	Gross Beta 36	0.60	2.92(36/36) (0.88 – 8.41)	Deer Creek	4.51(12/12) (1.90 – 8.41)	2.06(12/12) (1.15 – 2.48)
	Cs-137 36	2.80	4.23 (1/36)	Circulating Water Out 0.1 km NNE	4.23(1/12)	³
Fish	Cs-137 17	17	43(1/10)	North Indicator	43(1/10)	³
Sediment Shoreline Sediment	Cs-137 5	58	0(4/4)	³	0(4/4)	³
Benthic Sediment	Cs-137 1	58	0(4/4)	³	0(4/4)	³

Table 2 (Continued)

Annual Summary of Radioactivity in the Environs of the Ginna Nuclear Power Plant

Medium or Pathway Sampled (Unit of Measurement)	Type and Total Number of Analyses Performed	Lower Limit of Detection (LLD)	Indicator Locations Mean (F)/Range ¹	Location with Highest Annual Mean Name/Distance & Direction ²	Highest Annual Mean (F)/Range ¹	Control Locations Mean (F)/Range ¹
Cladophera (pCi/kg)	I-131 4	19	41(3/3) (22-53)	Lake Ontario Discharge	53(1/3)	22(1/1)
	Cs-137 4	26	21(1/1)	Slater Creek	21(1/1)	21(1/1)
Atmospheric Environment						
Air Iodine	I-131	1.9	0 (312/312)	³	0 (312/312)	³
Air Particulates (10 ⁻² pCi/m ³)	Gross Beta 624	0.5	1.94(468/468) (0.72 – 3.55)	Substation 13 Station 13 1.4 km SSW	2.04(52/52) (0.81 – 3.55)	2.02(156/156) (0.80 – 3.55)
	Cs-137 28	0.03	0.0249(2/28) (0.0205-0.0292)	Creek Bridge Station 5 0.1 km SSE	0.0292(1/4)	0.0288(1/20)
Direct Radiation						
Ambient Radiation (mR/91 days)	Dosimeters 156	--	11.6 (360/360) (9.9 – 15.4)	West Fence Line Station 7 0.22 km WSW	13.6(12/12) (12.9 – 14.3)	10.9(108/108) (9.8 – 12.3)
Terrestrial Environmental						
Food Products (pCi/kg)	Cs-137 26	10.3	22(1/2)	ESE Garden	22(1/2)	³
Milk	Cs-137 36	2.9	3.5 (1/18)	Farm C	3.5 (1/18)	3.5 (1/18)

Table 2 (Continued)

Annual Summary of Radioactivity in the Environs of the Ginna Nuclear Power Plant

Notes:

¹ Mean and range based upon detectable measurements only. Fraction (F) of detectable measurements at specified location is indicated in parentheses

² From the center point of the containment building

³ There was no detectable activity at the control or indicator location

III. REFERENCES

- (1) R. E. Ginna Nuclear Power Plant, Nos. DPR-18, Technical Specification 5.6.2; Annual Radiological Environmental Operating Report.
- (2) Offsite Dose Calculation Manual for the R. E. Ginna Nuclear Power Plant, Revision 20, Effective Date: March 29, 2005.
- (3) Constellation Energy Laboratory Procedures Manual, General Services Department.
- (4) Constellation Energy, "Land Use Survey Around R. E. Ginna Nuclear Power Plant, September 2007."

APPENDIX A

REMP Sample Locations

Summary of Appendix A Content

Appendix A contains information concerning the environmental samples which were collected during this operating period. Sample locations and specific information about individual locations for the Ginna are given in Table A-1. Figure A-1 shows the location of the R. E. Ginna Nuclear Power Plant in relation to New York State and Lake Ontario. Figures A-2, A-3, and A-4 show the locations of the power plant sampling sites in relation to the plant site at different degrees of detail.

**APPENDIX A – REMP SAMPLE LOCATIONS
TABLE OF CONTENTS**

Table	Title	Page
A-1	LOCATIONS OF ENVIRONMENTAL SAMPLING STATIONS FOR THE GINNA NUCLEAR POWER PLANT	16

Figure	Title	Page
A-1	MAP OF NEW YORK STATE AND LAKE ONTARIO SHOWING LOCATION OF THE R. E. GINNA NUCLEAR POWER PLANT	19
A-2	ONSITE SAMPLE LOCATIONS	20
A-3	OFFSITE SAMPLE LOCATIONS (TLDS AND MILK FARMS WITHIN 5 MILES)....	21
A-4	WATER SAMPLE, MILK FARMS AND TLD LOCATIONS	22

TABLE A-1
Locations of Environmental Sampling Stations
for the R. E. Ginna Nuclear Plant

Station	Description	Distance		Direction
		Meters	Miles	Sector
Air Samplers				
2	Manor House Yard	320	0.2	E
3	East Field	420	0.3	ESE
4	Training Center Parking Lot	250	0.2	SE
5	Creek Bridge	160	0.1	SSE
6	Main Parking Lot	225	0.1	SW
7	West Fence Line	220	0.1	WSW
8	Seabreeze	19200	11.9	WSW
9	Webster	11400	7.1	SW
10	Walworth	13100	8.1	S
11	Williamson	11500	7.1	ESE
12	Sodus Point	25100	15.6	E
13	Substation 13	690	0.4	SSW
Direct Radiation				
2	Onsite-Manor House Yard	320	0.2	E
3	Onsite-In field approximately 200 ft SE of station #2	420	0.3	ESE
4	Onsite-Training Center yard driveway circle	250	0.2	SE
5	Onsite-Between creek and plant entry road	160	0.1	SSE
6	Onsite-SW side of plant parking lot	225	0.1	SW
7	Onsite-utility pole along West plant fence	220	0.1	WSW
8	Topper Drive-Irondequoit, Seabreeze Substation #51	19200	11.9	WSW
9	Phillips Road-Webster, intersection with Highway #104, Substation #74	11400	7.1	SW
10	Atlantic Avenue-Walworth, Substation #230	13100	8.1	S
11	W. Main Street-Williamson, Substation #207	11500	7.1	ESE
12	12 Seaman Avenue-Sodus Point-Off Lake Road by Sewer district, Substation #209	25100	15.6	E
13	At corner of plant-controlled area fence and dogleg to West	230	0.1	WNW
14	NW corner of field along lake shore	770	0.5	WNW
15	Field access road, west of orchard, approximately 3000' West of plant	850	0.5	W
16	SW Corner of orchard, approximately 3000' West of plant, approximately 200' North of Lake Road	900	0.6	WSW
17	Utility pole in orchard, approximately 75" North of Lake Road	500	0.3	SSW
18	Substation 13A fence, North Side	650	0.4	SSW
19	On NW corner of house 100' East of plant access road	400	0.2	S
20	Approximately 150' West of Ontario Center Road and approximately 170' South of Lake Road	680	0.4	SSE

Station	Description	Distance		Direction
		Meters	Miles	Sector
21	North side of Lake Road, approximately 200' East of Ontario Center Road	600	0.4	SE
22	North side of Lake Road, SE, property corner	810	0.5	SE
23	East property line, midway between Lake Road and Lake shore	680	0.4	ESE
24	Lake shore near NE corner of property	630	0.4	E
25	Substation #73, Klem Road, adjacent to 897 Klem Road	14350	8.9	WSW
26	Service Center, Plank Road, West of 250	14800	9.2	SW
27	Atlantic Avenue at Knollwood Drive utility pole, North side of road	14700	9.1	SSW
28	Substation #193, Marion, behind Stanton Ag. Service, North Main Street	17700	11.0	SE
29	Substation #208, Town Line Road (CR-118), 1000' North of Route 104	13800	8.6	ESE
30	District Office, Sodus, on pole, West side of bldg	20500	12.7	ESE
31	Lake Road, pole 20' North of road, 500' East of Salt Road	7280	4.5	W
32	Woodard Road at County Line Road, pole @ Northwest corner.	6850	4.2	WSW
33	County Line Road at RR tracks, pole approximately 100' East along tracks	7950	4.9	SW
34	Pole at Route 104, Lincoln Road, SW Corner.	6850	4.2	SSW
35	Transmission Right of Way, North of Clevenger Road on pole.	7600	4.7	SSW
36	Substation #205, Route 104, East of Ontario Center Road, North side of fence.	5650	3.5	S
37	Rail Road Avenue, pole at 2048	6000	3.7	SSE
38	Fisher Road at RR Tracks, pole East of road	7070	4.4	SE
39	Seeley Road, Pole South side 100' West of intersection with Stony Lonesome Road	6630	4.1	ESE
40	Lake Road at Stoney Lonesome Road, pole at SE corner	6630	4.1	E
Fish				
	Lake Ontario Discharge Plume	2200	1.4	ENE
	Russell Station	25600	15.9	W
Produce (Vegetation)				
Indicator and background samples of lettuce, apples, tomatoes, and cabbage are collected from gardens grown on company property and purchased from farms >10 miles from the plant.				
Water				
	Shoremont/MCWA	27160	16.9	W
	Ontario Water District	2200	1.4	ENE
	Circ Water Intake	420	0.3	N
	Circ Water Discharge	130	0.1	NNE
	Deer Creek	260	0.2	ESE

Station	Description	Distance		Direction
		Meters	Miles	Sector
Sediment				
	Lake Ontario Discharge Plume	2200	1.4	ENE
	Russell Station	25600	15.9	W
Milk				
	Farm A	8270	5.1	ESE
	Farm C (Control)	21000	13.0	SE

FIGURE A-1

Map of New York State and Lake Ontario Showing Location of R. E. Ginna Nuclear Power Plant




FIGURE A-2
Onsite Sample Locations




FIGURE A-3

Offsite Sample Locations (TLDs and milk farms within 5 miles)





FIGURE A-4
Water Sample, Milk Farms and TLD Locations



APPENDIX B

REMP Analytical Results

Summary of Appendix B Content

Appendix B is a presentation of the analytical results for the R. E. Ginna Nuclear Power Plant radiological environmental monitoring programs.

APPENDIX B
TABLE OF CONTENTS - REMP ANALYTICAL RESULTS

Table	Title	Page
B-1	CONCENTRATION OF TRITIUM, GAMMA EMITTERS AND GROSS BETA IN SURFACE AND DRINKING WATER.....	25
B-2	CONCENTRATION OF GAMMA EMITTERS IN THE FLESH OF EDIBLE FISH.....	27
B-3	CONCENTRATION OF GAMMA EMITTERS IN SEDIMENT	28
B-4	CONCENTRATION OF IODINE-131 IN FILTERED AIR (CHARCOAL CARTRIDGES)	29
B-5	CONCENTRATION OF BETA EMITTERS IN AIR PARTICULATES – ONSITE SAMPLES	31
B-6	CONCENTRATION OF BETA EMITTERS IN AIR PARTICULATES – OFFSITE SAMPLES	33
B-7	CONCENTRATION OF GAMMA EMITTERS IN AIR PARTICULATES	35
B-8	CONCENTRATION OF GAMMA EMITTERS IN VEGETATION SAMPLES.....	36
B-9	CONCENTRATION OF GAMMA EMITTERS (INCLUDING I-131) IN MILK.....	37
B-10	TYPICAL MDA RANGES FOR GAMMA SPECTROMETRY	38
B-11	TYPICAL LLDS FOR GAMMA SPECTROMETRY.....	39
B-12	DIRECT RADIATION	40
B-13	GROUNDWATER MONITORING WELLS	43

Table B-1

Concentration of Tritium, Gamma Emitters and Gross Beta in Surface and Drinking Water
(Results in units of pCi/L $\pm 2\sigma$)

Location	Sample Date	H-3	Gamma Emitters	Gross Beta
Monroe County Water Shoremont (MCWA)	01/30/2007	*	*	1.15 \pm 0.28
	02/26/2007	*	*	2.39 \pm 0.55
	04/02/2007	*	*	2.14 \pm 0.55
	04/30/2007	*	*	2.31 \pm 0.50
	06/04/2007	*	*	2.15 \pm 0.52
	07/02/2007	*	*	2.02 \pm 0.50
	07/30/2007	*	*	1.94 \pm 0.53
	08/28/2007	*	*	1.70 \pm 0.50
	10/02/2007	*	*	1.98 \pm 0.53
	10/30/2007	*	*	2.44 \pm 0.52
	11/27/2007	*	*	2.48 \pm 0.54
	12/26/2007	*	*	1.27 \pm 0.50
	Ontario Water District (OWD)	01/30/2007	*	*
02/26/2007		*	*	2.13 \pm 0.54
04/02/2007		*	*	2.23 \pm 0.55
04/30/2007		*	*	2.60 \pm 0.52
06/04/2007		*	*	2.54 \pm 0.54
07/02/2007		*	2.82 \pm 1.68 (Cs-137)	2.52 \pm 0.53
07/30/2007		*	*	2.24 \pm 0.55
08/28/2007		*	*	2.13 \pm 0.53
10/02/2007		*	*	1.79 \pm 0.52
10/30/2007		*	*	2.73 \pm 0.55
11/27/2007		*	*	2.47 \pm 0.53
12/26/2007		*	*	2.65 \pm 0.57
Circulating Water Inlet (Circ In)		01/30/2007	*	*
	02/26/2007	*	*	2.65 \pm 0.57
	04/02/2007	*	*	2.06 \pm 0.55
	04/30/2007	*	*	2.63 \pm 0.53
	06/04/2007	*	*	1.86 \pm 0.49
	07/02/2007	*	*	1.99 \pm 0.50
	07/30/2007	*	*	1.18 \pm 0.53
	08/28/2007	*	*	2.16 \pm 0.53
	10/02/2007	*	*	1.91 \pm 0.52
	10/30/2007	*	*	2.50 \pm 0.54
	11/27/2007	*	*	2.77 \pm 0.56
	12/26/2007	*	*	3.03 \pm 0.59

*All Non-Natural Gamma Emitters, including I-131, and tritium <MDA.

Table B-1 (Continued)

Concentration of Tritium, Gamma Emitters and Gross Beta in Surface and Drinking Water
(Results in units of pCi/L \pm 2 σ)

Location	Sample Date	H-3	Gamma Emitters	Gross Beta
Circulating Water Outlet (Circ Out)	01/30/2007	*	*	1.26 \pm 0.29
	02/26/2007	*	*	2.80 \pm 0.58
	04/02/2007	*	*	2.17 \pm 0.55
	04/30/2007	*	*	3.03 \pm 0.52
	06/04/2007	*	*	1.95 \pm 0.50
	07/02/2007	*	*	2.38 \pm 0.52
	07/30/2007	*	*	1.63 \pm 0.51
	08/28/2007	*	*	2.03 \pm 0.52
	10/02/2007	*	*	1.30 \pm 0.50
	10/30/2007	*	*	2.54 \pm 0.54
	11/27/2007	*	4.23 \pm 2.42 (Cs-137)	2.43 \pm 0.53
	12/26/2007	*	*	1.82 \pm 0.53
Deer Creek	01/16/2007	*	*	1.90 \pm 0.34
	02/27/2007	*	*	3.61 \pm 0.75
	03/19/2007	*	*	3.22 \pm 0.67
	04/23/2007	*	*	3.65 \pm 0.62
	05/14/2007	*	*	2.88 \pm 0.63
	06/18/2007	*	*	4.12 \pm 0.66
	07/16/2007	*	*	8.03 \pm 0.83
	08/13/2007	*	*	4.81 \pm 0.79
	09/10/2007	*	*	2.64 \pm 0.65
	10/16/2007	*	*	6.55 \pm 0.94
	11/05/2007	*	*	8.41 \pm 1.26
	12/11/2007	*	*	4.35 \pm 0.75

* All Non-Natural Gamma Emitters, including I-131, and tritium < MDA.

Table B-2

Concentration of Gamma Emitters in the Flesh of Edible Fish
(Results in units of pCi/kg (wet) $\pm 2\sigma$)

Location	Sample Date	Fish Type	Gamma Emitters
North Indicator	1/11/2007	Burbot	43±19 (Cs-137)
	1/17/2007	Lake Trout	*
	1/17/2007	Smallmouth Bass	*
	1/24/2007	White Sucker	*
	3/07/2007	Smallmouth Bass	*
	11/21/2007	Lake Trout	*
	11/21/2007	White Sucker	*
	11/28/2007	Brown Trout	*
	11/29/2007	Smallmouth Bass	*
	Russel Station (Control)	5/02/2007	Smallmouth Bass
Sandy Creek – Hamlin (Control)	4/25/2007	Rainbow Trout	*
	6/7/2007	Bowfin	*
	6/7/2007	Northern Pike	*
	9/25/2007	Largemouth Bass	*
	9/25/2007	Chinook Salmon	*
	9/25/2007	Northern Pike	*
Greece (Control)	12/13/2006	Lake Trout	*

*All Non-Natural Gamma Emitters <MDA

Table B-3

Concentration of Gamma Emitters in Sediment
(Results in units of pCi/kg (wet) $\pm 2\sigma$)

Description	Sample Date	Gamma Emitters
Shoreline Sediment		
- East (Manor House)	6/7/2007	*
- East (Bear Creek)	6/14/2007	*
	9/04/2007	*
- Greece (Control)	6/7/2007	*
	9/04/2007	*
Benthic Sediment		
- North	5/30/2007	*
Cladophera		
- East (Manor House)	8/20/2007	53 \pm 15 (I-131)
	9/5/2007	48 \pm 24 (I-131)
- Slater Creek (Control)	9/5/2007	22 \pm 9 (I-131)
	9/5/2007	21 \pm 10 (Cs-137)
- Webster Park	9/5/2007	*

* All Non-Natural Gamma Emitters <MDA

Table B-4

Concentration of Iodine-131 in Filtered Air (Charcoal Cartridges)
(Results in units of 10^{-2} pCi/m³ ± 2σ)

Start Date	Stop Date	Station #2 (I) Manor House Yard	Station #4 (I) Training Center Parking Lot	Station #7 (I) West Fence Line	Station #8 (C) Seabreeze ¹	Station #9 (I) Webster	Station #11 (I) Williamson
1/01/2007	1/08/2007	*	*	*	*	*	*
1/08/2007	1/15/2007	*	*	*	*	*	*
1/15/2007	1/23/2007	*	*	*	*	*	*
1/23/2007	1/29/2007	*	*	*	*	*	*
1/29/2007	2/05/2007	*	*	*	*	*	*
2/05/2007	2/12/2007	*	*	*	*	*	*
2/12/2007	2/19/2007	*	*	*	*	*	*
2/19/2007	2/26/2007	*	*	*	*	*	*
2/26/2007	3/05/2007	*	*	*	*	*	*
3/05/2007	3/12/2007	*	*	*	*	*	*
3/12/2007	3/19/2007	*	*	*	*	*	*
3/19/2007	3/26/2007	*	*	*	*	*	*
3/26/2007	4/02/2007	*	*	*	*	*	*
4/02/2007	4/09/2007	*	*	*	*	*	*
4/09/2007	4/16/2007	*	*	*	*	*	*
4/16/2007	4/23/2007	*	*	*	*	*	*
4/23/2007	4/30/2007	*	*	*	*	*	*
4/30/2007	5/07/2007	*	*	*	*	*	*
5/07/2007	5/14/2007	*	*	*	*	*	*
5/14/2007	5/21/2007	*	*	*	*	*	*
5/21/2007	5/28/2007	*	*	*	*	*	*
5/28/2007	6/04/2007	*	*	*	*	*	*
6/04/2007	6/11/2007	*	*	*	*	*	*
6/11/2007	6/18/2007	*	*	*	*	*	*
6/18/2007	6/25/2007	*	*	*	*	*	*
6/25/2007	7/02/2007	*	*	*	*	*	*

¹ Control Location

* <MDA (I-131)

Table B-4 (Continued)

Concentration of Iodine-131 in Filtered Air (Charcoal Cartridges)
(Results in units of 10^{-2} pCi/m³ ± 2σ)

Start Date	Stop Date	Station #2 (I) Manor House Yard	Station #4 (I) Training Center Parking Lot	Station #7 (I) West Fence Line	Station #8 (C) Seabreeze ¹	Station #9 (I) Webster	Station #11 (I) Williamson
7/02/2007	7/09/2007	*	*	*	*	*	*
7/09/2007	7/16/2007	*	*	*	*	*	*
7/16/2007	7/23/2007	*	*	*	*	*	*
7/23/2007	7/30/2007	*	*	*	*	*	*
7/30/2007	8/06/2007	*	*	*	*	*	*
8/7/2007	8/13/2007	*	*	*	*	*	*
8/13/2007	8/20/2007	*	*	*	*	*	*
8/20/2007	8/27/2007	*	*	*	*	*	*
8/27/2007	9/03/2007	*	*	*	*	*	*
9/03/2007	9/10/2007	*	*	*	*	*	*
9/10/2007	9/17/2007	*	*	*	*	*	*
9/17/2007	9/24/2007	*	*	*	*	*	*
9/24/2007	10/01/2007	*	*	*	*	*	*
10/01/2007	10/08/2007	*	*	*	*	*	*
10/08/2007	10/15/2007	*	*	*	*	*	*
10/15/2007	10/22/2007	*	*	*	*	*	*
10/23/2007	10/29/2007	*	*	*	*	*	*
10/29/2007	11/05/2007	*	*	*	*	*	*
11/05/2007	11/12/2007	*	*	*	*	*	*
11/12/2007	11/19/2007	*	*	*	*	*	*
11/19/2007	11/26/2007	*	*	*	*	*	*
11/26/2007	12/03/2007	*	*	*	*	*	*
12/03/2007	12/10/2007	*	*	*	*	*	*
12/10/2007	12/17/2007	*	*	*	*	*	*
12/17/2007	12/24/2007	*	*	*	*	*	*
12/24/2007	12/31/2007	*	*	*	*	*	*

¹ Control Location

* <MDA (I-131)

Table B-5

Concentration of Beta Emitters in Air Particulates – Onsite Samples
(Results in pCi/m³ ± 2σ Uncertainty)

START DATE	STOP DATE	Station #2 (I) Manor House Yard	Station #3 (I) East Field	Station #4 (I) Training Center Parking Lot	Station #5 (I) Creek Bridge	Station #6 (I) Main Parking Lot	Station #7 (I) West Fence Line	Station #13 (I) Substation 13
01/01/07	01/08/07	0.0135 ± 0.0011	0.0144 ± 0.0012	0.0144 ± 0.0012	0.0153 ± 0.0014	0.0137 ± 0.0011	0.0157 ± 0.0012	0.0145 ± 0.0014
01/08/07	01/15/07	0.0140 ± 0.0010	0.0152 ± 0.0011	0.0145 ± 0.0011	0.0158 ± 0.0013	0.0148 ± 0.0011	0.0155 ± 0.0011	0.0138 ± 0.0013
01/15/07	01/23/07	0.0183 ± 0.0010	0.0135 ± 0.0009	0.0178 ± 0.0011	0.0209 ± 0.0013	0.0193 ± 0.0011	0.0195 ± 0.0012	0.0193 ± 0.0014
01/23/07	01/29/07	0.0194 ± 0.0012	0.0195 ± 0.0013	0.0199 ± 0.0013	0.0217 ± 0.0015	0.0208 ± 0.0012	0.0233 ± 0.0013	0.0186 ± 0.0013
01/29/07	02/05/07	0.0197 ± 0.0012	0.0207 ± 0.0012	0.0206 ± 0.0013	0.0233 ± 0.0015	0.0194 ± 0.0012	0.0207 ± 0.0013	0.0211 ± 0.0015
02/05/07	02/12/07	0.0161 ± 0.0011	0.0160 ± 0.0011	0.0151 ± 0.0011	0.0181 ± 0.0013	0.0138 ± 0.0010	0.0152 ± 0.0011	0.0167 ± 0.0013
02/12/07	02/19/07	0.0193 ± 0.0011	0.0188 ± 0.0012	0.0194 ± 0.0012	0.0209 ± 0.0014	0.0171 ± 0.0011	0.0195 ± 0.0012	0.0198 ± 0.0014
02/19/07	02/26/07	0.0166 ± 0.0011	0.0150 ± 0.0011	0.0144 ± 0.0011	0.0177 ± 0.0013	0.0166 ± 0.0011	0.0177 ± 0.0012	0.0153 ± 0.0013
02/26/07	03/05/07	0.0130 ± 0.0010	0.0131 ± 0.0010	0.0127 ± 0.0010	0.0128 ± 0.0012	0.0134 ± 0.0010	0.0131 ± 0.0011	0.0130 ± 0.0012
03/05/07	03/12/07	0.0211 ± 0.0012	0.0220 ± 0.0012	0.0195 ± 0.0012	0.0242 ± 0.0015	0.0211 ± 0.0011	0.0207 ± 0.0013	0.0216 ± 0.0013
03/12/07	03/19/07	0.0196 ± 0.0012	0.0199 ± 0.0012	0.0203 ± 0.0012	0.0212 ± 0.0014	0.0199 ± 0.0013	0.0217 ± 0.0013	0.0211 ± 0.0016
03/19/07	03/26/07	0.0180 ± 0.0010	0.0179 ± 0.0011	0.0184 ± 0.0011	0.0192 ± 0.0012	0.0189 ± 0.0011	0.0201 ± 0.0012	0.0157 ± 0.0012
03/27/07	04/02/07	0.0161 ± 0.0012	0.0162 ± 0.0012	0.0164 ± 0.0012	0.0187 ± 0.0015	0.0155 ± 0.0011	0.0178 ± 0.0012	0.0153 ± 0.0014
04/02/07	04/09/07	0.0075 ± 0.0008	0.0072 ± 0.0008	0.0076 ± 0.0009	0.0090 ± 0.0011	0.0082 ± 0.0008	0.0078 ± 0.0009	0.0081 ± 0.0011
04/09/07	04/16/07	0.0103 ± 0.0009	0.0108 ± 0.0010	0.0111 ± 0.0010	0.0126 ± 0.0012	0.0098 ± 0.0009	0.0120 ± 0.0011	0.0108 ± 0.0011
04/16/07	04/23/07	0.0169 ± 0.0011	0.0166 ± 0.0011	0.0158 ± 0.0011	0.0169 ± 0.0013	0.0163 ± 0.0011	0.0180 ± 0.0012	0.0173 ± 0.0014
04/23/07	04/30/07	0.0120 ± 0.0010	0.0116 ± 0.0010	0.0114 ± 0.0010	0.0127 ± 0.0012	0.0108 ± 0.0010	0.0124 ± 0.0011	0.0101 ± 0.0012
04/30/07	05/07/07	0.0127 ± 0.0010	0.0123 ± 0.0010	0.0124 ± 0.0011	0.0125 ± 0.0012	0.0122 ± 0.0010	0.0139 ± 0.0012	0.0116 ± 0.0012
05/07/07	05/14/07	0.0198 ± 0.0012	0.0191 ± 0.0012	0.0198 ± 0.0013	0.0157 ± 0.0011	0.0193 ± 0.0012	0.0197 ± 0.0013	0.0188 ± 0.0014
05/14/07	05/21/07	0.0160 ± 0.0011	0.0177 ± 0.0012	0.0165 ± 0.0012	0.0164 ± 0.0011	0.0174 ± 0.0012	0.0182 ± 0.0013	0.0171 ± 0.0014
05/21/07	05/28/07	0.0206 ± 0.0011	0.0219 ± 0.0012	0.0207 ± 0.0012	0.0195 ± 0.0011	0.0202 ± 0.0011	0.0230 ± 0.0012	0.0227 ± 0.0014
05/28/07	06/04/07	0.0255 ± 0.0014	0.0260 ± 0.0015	0.0234 ± 0.0014	0.0246 ± 0.0014	0.0264 ± 0.0015	0.0298 ± 0.0017	0.0273 ± 0.0018
06/04/07	06/11/07	0.0123 ± 0.0010	0.0115 ± 0.0010	0.0118 ± 0.0011	0.0120 ± 0.0010	0.0118 ± 0.0010	0.0142 ± 0.0012	0.0130 ± 0.0012
06/11/07	06/18/07	0.0181 ± 0.0012	0.0188 ± 0.0012	0.0180 ± 0.0013	0.0183 ± 0.0012	0.0168 ± 0.0012	0.0196 ± 0.0014	0.0207 ± 0.0014
06/18/07	06/25/07	0.0146 ± 0.0011	0.0151 ± 0.0011	0.0142 ± 0.0011	0.0153 ± 0.0010	0.0144 ± 0.0010	0.0159 ± 0.0012	0.0158 ± 0.0013
06/25/07	07/02/07	0.0192 ± 0.0012	0.0191 ± 0.0012	0.0207 ± 0.0013	0.0193 ± 0.0013	0.0189 ± 0.0012	0.0219 ± 0.0014	0.0227 ± 0.0015
1st 6-Month Summary								
Maximum		0.0255 ± 0.0014	0.0260 ± 0.0015	0.0234 ± 0.0014	0.0246 ± 0.0015	0.0264 ± 0.0015	0.0298 ± 0.0017	0.0273 ± 0.0018
Average		0.0165	0.0165	0.0164	0.0175	0.0164	0.0180	0.0170
Minimum		0.0075 ± 0.0008	0.0072 ± 0.0008	0.0076 ± 0.0009	0.0090 ± 0.0010	0.0082 ± 0.0008	0.0078 ± 0.0009	0.0081 ± 0.0011

Table B-5 (Continued)
(Results in pCi/m³ ± 2σ Uncertainty)

START DATE	STOP DATE	Station #2 (I) Manor House Yard	Station #3 (I) East Field	Station #4 (I) Training Center Parking Lot	Station #5 (I) Creek Bridge	Station #6 (I) Main Parking Lot	Station #7 (I) West Fence Line	Station #13 (I) Substation 13
7/2/2007	7/9/2007	0.0223 ± 0.0013	0.0227 ± 0.0013	0.0223 ± 0.0014	0.0227 ± 0.0013	0.0225 ± 0.0013	0.0230 ± 0.0014	0.0234 ± 0.0015
7/9/2007	7/16/2007	0.0203 ± 0.0013	0.0193 ± 0.0012	0.0200 ± 0.0013	0.0194 ± 0.0012	0.0214 ± 0.0014	0.0213 ± 0.0014	0.0213 ± 0.0013
7/16/2007	7/23/2007	0.0230 ± 0.0013	0.0231 ± 0.0013	0.0210 ± 0.0013	0.0206 ± 0.0012	0.0252 ± 0.0014	0.0218 ± 0.0013	0.0236 ± 0.0015
7/23/2007	7/30/2007	0.0218 ± 0.0014	0.0223 ± 0.0013	0.0232 ± 0.0014	0.0230 ± 0.0013	0.0244 ± 0.0017	0.0236 ± 0.0016	0.0245 ± 0.0017
8/6/2007	8/13/2007	0.0240 ± 0.0014	0.0189 ± 0.0012	0.0227 ± 0.0013	0.0229 ± 0.0013	0.0259 ± 0.0015	0.0233 ± 0.0014	0.0248 ± 0.0014
7/30/2007	8/6/2007	0.0263 ± 0.0014	0.0284 ± 0.0015	0.0264 ± 0.0015	0.0265 ± 0.0014	0.0273 ± 0.0016	0.0280 ± 0.0015	0.0295 ± 0.0017
8/13/2007	8/20/2007	0.0116 ± 0.0010	0.0110 ± 0.0010	0.0132 ± 0.0011	0.0128 ± 0.0010	0.0155 ± 0.0012	0.0128 ± 0.0011	0.0159 ± 0.0014
8/20/2007	8/27/2007	0.0145 ± 0.0011	0.0110 ± 0.0010	0.0144 ± 0.0011	0.0144 ± 0.0011	0.0156 ± 0.0012	0.0150 ± 0.0012	0.0161 ± 0.0013
8/27/2007	9/3/2007	0.0232 ± 0.0012	0.0169 ± 0.0011	0.0216 ± 0.0012	0.0219 ± 0.0012	0.0225 ± 0.0013	0.0228 ± 0.0013	0.0236 ± 0.0014
9/3/2007	9/10/2007	0.0228 ± 0.0014	0.0191 ± 0.0014	0.0242 ± 0.0015	0.0231 ± 0.0014	0.0266 ± 0.0017	0.0264 ± 0.0016	0.0270 ± 0.0017
9/10/2007	9/17/2007	0.0152 ± 0.0012	0.0119 ± 0.0011	0.0141 ± 0.0012	0.0144 ± 0.0011	0.0136 ± 0.0012	0.0138 ± 0.0012	0.0138 ± 0.0012
9/17/2007	9/24/2007	0.0277 ± 0.0014	0.0226 ± 0.0013	0.0263 ± 0.0014	0.0284 ± 0.0014	0.0298 ± 0.0016	0.0306 ± 0.0016	0.0317 ± 0.0017
9/24/2007	10/1/2007	0.0195 ± 0.0013	0.0167 ± 0.0012	0.0214 ± 0.0014	0.0198 ± 0.0012	0.0202 ± 0.0014	0.0195 ± 0.0014	0.0229 ± 0.0015
10/1/2007	10/8/2007	0.0286 ± 0.0015	0.0231 ± 0.0014	0.0317 ± 0.0016	0.0304 ± 0.0015	0.0328 ± 0.0017	0.0308 ± 0.0016	0.0355 ± 0.0018
10/8/2007	10/15/2007	0.0121 ± 0.0011	0.0095 ± 0.0011	0.0111 ± 0.0011	0.0126 ± 0.0010	0.0118 ± 0.0012	0.0110 ± 0.0011	0.0124 ± 0.0012
10/15/2007	10/22/2007	0.0296 ± 0.0015	0.0243 ± 0.0014	0.0283 ± 0.0015	0.0315 ± 0.0015	0.0337 ± 0.0017	0.0316 ± 0.0016	0.0352 ± 0.0018
10/22/2007	10/29/2007	0.0155 ± 0.0012	0.0145 ± 0.0012	0.0169 ± 0.0012	0.0184 ± 0.0012	0.0179 ± 0.0013	0.0172 ± 0.0013	0.0183 ± 0.0014
10/29/2007	11/5/2007	0.0223 ± 0.0014	0.0183 ± 0.0013	0.0244 ± 0.0014	0.0249 ± 0.0013	0.0236 ± 0.0015	0.0243 ± 0.0015	0.0265 ± 0.0016
11/5/2007	11/12/2007	0.0187 ± 0.0012	0.0159 ± 0.0012	0.0201 ± 0.0013	0.0200 ± 0.0012	0.0201 ± 0.0013	0.0204 ± 0.0013	0.0208 ± 0.0014
11/12/2007	11/19/2007	0.0207 ± 0.0013	0.0164 ± 0.0011	0.0218 ± 0.0013	0.0220 ± 0.0012	0.0222 ± 0.0014	0.0219 ± 0.0013	0.0220 ± 0.0014
11/19/2007	11/26/2007	0.0159 ± 0.0012	0.0129 ± 0.0011	0.0167 ± 0.0012	0.0172 ± 0.0011	0.0165 ± 0.0012	0.0176 ± 0.0013	0.0179 ± 0.0014
11/26/2007	12/3/2007	0.0245 ± 0.0013	0.0198 ± 0.0012	0.0246 ± 0.0013	0.0242 ± 0.0012	0.0253 ± 0.0014	0.0256 ± 0.0014	0.0273 ± 0.0015
12/3/2007	12/10/2007	0.0187 ± 0.0011	0.0157 ± 0.0010	0.0180 ± 0.0011	0.0186 ± 0.0010	0.0205 ± 0.0012	0.0185 ± 0.0011	0.0210 ± 0.0013
12/10/2007	12/17/2007	0.0249 ± 0.0013	0.0210 ± 0.0013	0.0254 ± 0.0014	0.0251 ± 0.0013	0.0264 ± 0.0015	0.0263 ± 0.0014	0.0276 ± 0.0015
12/17/2007	12/24/2007	0.0278 ± 0.0014	0.0232 ± 0.0013	0.0279 ± 0.0014	0.0269 ± 0.0013	0.0282 ± 0.0014	0.0295 ± 0.0014	0.0329 ± 0.0016
12/24/2007	12/31/2007	0.0264 ± 0.0013	0.0228 ± 0.0013	0.0271 ± 0.0014	0.0272 ± 0.0013	0.0296 ± 0.0015	0.0285 ± 0.0014	0.0305 ± 0.0016
2nd 6-Month Summary								
Maximum		0.0296 ± 0.0015	0.0284 ± 0.0015	0.0317 ± 0.0016	0.0315 ± 0.0015	0.0337 ± 0.0027	0.0316 ± 0.0016	0.0355 ± 0.0018
Average		0.0215	0.0185	0.0217	0.0219	0.0230	0.0225	0.0241
Minimum		0.0116 ± 0.0010	0.0095 ± 0.0010	0.0111 ± 0.0011	0.0126 ± 0.0010	0.0118 ± 0.0012	0.0110 ± 0.0011	0.0124 ± 0.0012
12-Month Summary								
Maximum		0.0296 ± 0.0015	0.0284 ± 0.0015	0.0317 ± 0.0016	0.0315 ± 0.0015	0.0337 ± 0.0027	0.0316 ± 0.0017	0.0355 ± 0.0018
Average		0.0190	0.0175	0.0191	0.0197	0.0197	0.0202	0.0205
Minimum		0.0075 ± 0.0008	0.0072 ± 0.0008	0.0076 ± 0.0009	0.0090 ± 0.0010	0.0082 ± 0.0008	0.0078 ± 0.0009	0.0081 ± 0.0011

Table B-6

Concentration of Beta Emitters in Air Particulates – Offsite Samples
Results in pCi/m³ ± 2sigma Uncertainty

START DATE	STOP DATE	Station #8 (C) Seabreeze	Station #9 (I) Webster	Station #10 (C) Walworth	Station #11 (I) Williamson	Station #12 (C) Sodus Point
01/01/07	01/08/07	0.0162 ± 0.0018	0.0144 ± 0.0012	0.0162 ± 0.0012	0.0154 ± 0.0020	0.0154 ± 0.0013
01/08/07	01/15/07	0.0155 ± 0.0017	0.0139 ± 0.0011	0.0139 ± 0.0011	0.0139 ± 0.0019	0.0167 ± 0.0011
01/15/07	01/23/07	0.0183 ± 0.0017	0.0167 ± 0.0012	0.0177 ± 0.0012	0.0202 ± 0.0019	0.0251 ± 0.0014
01/23/07	01/29/07	0.0174 ± 0.0017	0.0147 ± 0.0011	0.0187 ± 0.0012	0.0212 ± 0.0023	0.0225 ± 0.0014
01/29/07	02/05/07	0.0201 ± 0.0018	0.0196 ± 0.0013	0.0206 ± 0.0012	0.0191 ± 0.0020	0.0228 ± 0.0013
02/05/07	02/12/07	0.0172 ± 0.0018	0.0153 ± 0.0012	0.0166 ± 0.0011	0.0166 ± 0.0020	0.0172 ± 0.0012
02/12/07	02/19/07	0.0181 ± 0.0016	0.0173 ± 0.0011	0.0184 ± 0.0011	0.0208 ± 0.0020	0.0208 ± 0.0012
02/19/07	02/26/07	0.0170 ± 0.0018	0.0143 ± 0.0012	0.0163 ± 0.0012	0.0177 ± 0.0020	0.0175 ± 0.0012
02/26/07	03/05/07	0.0160 ± 0.0017	0.0124 ± 0.0011	0.0125 ± 0.0010	0.0135 ± 0.0019	0.0133 ± 0.0011
03/05/07	03/12/07	0.0230 ± 0.0019	0.0190 ± 0.0013	0.0219 ± 0.0013	0.0217 ± 0.0020	0.0235 ± 0.0013
03/12/07	03/19/07	0.0214 ± 0.0018	0.0191 ± 0.0013	0.0212 ± 0.0013	0.0213 ± 0.0023	0.0238 ± 0.0015
03/19/07	03/26/07	0.0199 ± 0.0016	0.0143 ± 0.0010	0.0186 ± 0.0011	0.0172 ± 0.0018	0.0180 ± 0.0011
03/27/07	04/02/07	0.0183 ± 0.0020	0.0163 ± 0.0013	0.0186 ± 0.0013	0.0160 ± 0.0022	0.0164 ± 0.0013
04/02/07	04/09/07	0.0080 ± 0.0014	0.0081 ± 0.0010	0.0081 ± 0.0009	0.0080 ± 0.0017	0.0092 ± 0.0010
04/09/07	04/16/07	0.0128 ± 0.0016	0.0112 ± 0.0010	0.0106 ± 0.0009	0.0102 ± 0.0017	0.0103 ± 0.0010
04/16/07	04/23/07	0.0176 ± 0.0017	0.0163 ± 0.0012	0.0165 ± 0.0011	0.0172 ± 0.0020	0.0171 ± 0.0012
04/23/07	04/30/07	0.0120 ± 0.0016	0.0116 ± 0.0011	0.0117 ± 0.0010	0.0110 ± 0.0018	0.0121 ± 0.0011
04/30/07	05/07/07	0.0145 ± 0.0016	0.0119 ± 0.0011	0.0134 ± 0.0011	0.0130 ± 0.0019	0.0145 ± 0.0012
05/07/07	05/14/07	0.0239 ± 0.0020	0.0213 ± 0.0014	0.0221 ± 0.0013	0.0219 ± 0.0014	0.0203 ± 0.0013
05/14/07	05/21/07	0.0209 ± 0.0017	0.0231 ± 0.0014	0.0231 ± 0.0013	0.0179 ± 0.0012	0.0167 ± 0.0012
05/21/07	05/28/07	0.0238 ± 0.0020	0.0237 ± 0.0015	0.0228 ± 0.0013	0.0228 ± 0.0012	0.0204 ± 0.0012
05/28/07	06/04/07	0.0316 ± 0.0024	0.0289 ± 0.0017	0.0300 ± 0.0016	0.0302 ± 0.0016	0.0281 ± 0.0016
06/04/07	06/11/07	0.0162 ± 0.0018	0.0126 ± 0.0012	0.0139 ± 0.0011	0.0132 ± 0.0011	0.0118 ± 0.0018
06/11/07	06/18/07	0.0198 ± 0.0018	0.0189 ± 0.0014	0.0207 ± 0.0013	0.0187 ± 0.0013	0.0202 ± 0.0022
06/18/07	06/25/07	0.0157 ± 0.0017	0.0153 ± 0.0013	0.0161 ± 0.0012	0.0150 ± 0.0012	0.0160 ± 0.0020
06/25/07	07/02/07	0.0236 ± 0.0019	0.0219 ± 0.0014	0.0214 ± 0.0013	0.0222 ± 0.0013	0.0212 ± 0.0021
1st 6-Month Summary						
Maximum		0.0316 ± 0.0024	0.0289 ± 0.0017	0.0300 ± 0.0016	0.0302 ± 0.0023	0.0281 ± 0.0022
Average		0.0184	0.0166	0.0178	0.0175	0.0181
Minimum		0.0080 ± 0.0014	0.0081 ± 0.0010	0.0081 ± 0.0009	0.0080 ± 0.0011	0.0092 ± 0.0010

Table B-6 (Continued)

Concentration of Beta Emitters in Air Particulates – Offsite Samples
(Results in pCi/m³ ± 2σ Uncertainty)

START DATE	STOP DATE	Station #8 (C) Seabreeze	Station #9 (I) Webster	Station #10 (C) Walworth	Station #11 (I) Williamson	Station #12 (C) Sodus Point
7/2/2007	7/9/2007	0.0247 ± 0.0020	0.0230 ± 0.0015	0.0233 ± 0.0014	0.0232 ± 0.0014	0.0229 ± 0.0022
7/9/2007	7/16/2007	0.0197 ± 0.0017	0.0204 ± 0.0013	0.0226 ± 0.0013	0.0195 ± 0.0013	0.0210 ± 0.0022
7/16/2007	7/23/2007	0.0223 ± 0.0021	0.0222 ± 0.0016	0.0229 ± 0.0013	0.0219 ± 0.0012	0.0215 ± 0.0020
7/23/2007	7/30/2007	0.0262 ± 0.0021	0.0231 ± 0.0015	0.0239 ± 0.0015	0.0228 ± 0.0015	0.0237 ± 0.0025
8/6/2007	8/13/2007	0.0241 ± 0.0014	0.0238 ± 0.0015	0.0227 ± 0.0013	0.0355 ± 0.0030	0.0227 ± 0.0020
7/30/2007	8/6/2007	0.0305 ± 0.0022	0.0272 ± 0.0016	0.0287 ± 0.0015	0.0297 ± 0.0015	0.0293 ± 0.0024
8/13/2007	8/20/2007	0.0146 ± 0.0011	0.0144 ± 0.0012	0.0133 ± 0.0011	0.0133 ± 0.0011	0.0164 ± 0.0022
8/20/2007	8/27/2007	0.0150 ± 0.0011	0.0156 ± 0.0013	0.0153 ± 0.0011	0.0157 ± 0.0011	0.0166 ± 0.0018
8/27/2007	9/3/2007	0.0231 ± 0.0012	0.0231 ± 0.0014	0.0232 ± 0.0013	0.0248 ± 0.0014	0.0244 ± 0.0022
9/3/2007	9/10/2007	0.0237 ± 0.0014	0.0274 ± 0.0017	0.0263 ± 0.0016	0.0269 ± 0.0016	0.0262 ± 0.0026
9/10/2007	9/17/2007	0.0141 ± 0.0011	0.0150 ± 0.0013	0.0146 ± 0.0011	0.0145 ± 0.0011	0.0147 ± 0.0020
9/17/2007	9/24/2007	0.0281 ± 0.0014	0.0303 ± 0.0017	0.0291 ± 0.0015	0.0312 ± 0.0015	0.0304 ± 0.0025
9/24/2007	10/1/2007	0.0205 ± 0.0013	0.0208 ± 0.0015	0.0216 ± 0.0014	0.0230 ± 0.0013	0.0213 ± 0.0021
10/1/2007	10/8/2007	0.0321 ± 0.0015	0.0324 ± 0.0017	0.0302 ± 0.0015	0.0326 ± 0.0017	0.0352 ± 0.0028
10/8/2007	10/15/2007	0.0153 ± 0.0011	0.0176 ± 0.0013	0.0165 ± 0.0011	0.0114 ± 0.0011	0.0097 ± 0.0020
10/15/2007	10/22/2007	0.0336 ± 0.0015	0.0349 ± 0.0018	0.0320 ± 0.0016	0.0331 ± 0.0015	0.0306 ± 0.0023
10/22/2007	10/29/2007	0.0131 ± 0.0012	0.0148 ± 0.0014	0.0144 ± 0.0013	0.0141 ± 0.0012	0.0139 ± 0.0022
10/29/2007	11/5/2007	0.0233 ± 0.0013	0.0239 ± 0.0015	0.0250 ± 0.0014	0.0258 ± 0.0014	0.0262 ± 0.0024
11/5/2007	11/12/2007	0.0190 ± 0.0012	0.0195 ± 0.0014	0.0185 ± 0.0012	0.0198 ± 0.0013	0.0185 ± 0.0021
11/12/2007	11/19/2007	0.0218 ± 0.0012	0.0207 ± 0.0014	0.0225 ± 0.0013	0.0228 ± 0.0013	0.0216 ± 0.0021
11/19/2007	11/26/2007	0.0175 ± 0.0012	0.0161 ± 0.0013	0.0151 ± 0.0012	0.0150 ± 0.0012	0.0154 ± 0.0021
11/26/2007	12/3/2007	0.0232 ± 0.0013	0.0221 ± 0.0014	0.0208 ± 0.0012	0.0243 ± 0.0013	0.0244 ± 0.0022
12/3/2007	12/10/2007	0.0185 ± 0.0011	0.0177 ± 0.0012	0.0215 ± 0.0012	0.0189 ± 0.0011	0.0203 ± 0.0019
12/10/2007	12/17/2007	0.0194 ± 0.0011	0.0227 ± 0.0015	0.0277 ± 0.0015	0.0248 ± 0.0014	0.0254 ± 0.0023
12/17/2007	12/24/2007	0.0237 ± 0.0012	0.0264 ± 0.0014	0.0278 ± 0.0013	0.0292 ± 0.0013	0.0270 ± 0.0022
12/24/2007	12/31/2007	0.0289 ± 0.0014	0.0246 ± 0.0014	0.0292 ± 0.0014	0.0290 ± 0.0014	0.0290 ± 0.0023
2nd 6-Month Summary						
Maximum		0.0336 ± 0.0022	0.0349 ± 0.0018	0.0320 ± 0.0016	0.0355 ± 0.0030	0.0352 ± 0.0028
Average		0.0221	0.0223	0.0226	0.0232	0.0226
Minimum		0.0131 ± 0.0011	0.0144 ± 0.0012	0.0133 ± 0.0011	0.0114 ± 0.0011	0.0097 ± 0.0018
12-Month Summary						
Maximum		0.0336 ± 0.0024	0.0349 ± 0.0018	0.0320 ± 0.0016	0.0355 ± 0.0030	0.0352 ± 0.0028
Average		0.0203	0.0195	0.0202	0.0204	0.0204
Minimum		0.0080 ± 0.0011	0.0081 ± 0.0010	0.0081 ± 0.0009	0.0080 ± 0.0011	0.0092 ± 0.0010

Table B-7

Concentration of Gamma Emitters in Air Particulates
(Results in units of $10^{-3}\text{pCi/m}^3 \pm 2\sigma$)

Location	First Quarter	Second Quarter	Third Quarter	Fourth Quarter
Station #2 Manor House Yard	*	*	*	*
Station #3 East Field	*	*	*	*
Station #4 Training Center Parking Lot	*	*	*	*
Station #5 Creek Bridge	Cs-137 0.292±0.187	*	*	*
Station #6 Main Parking Lot	*	*	*	*
Station #7 West Fence Line	*	*	*	*
Station #8 Seabreeze	*	*	*	*
Station #9 Webster	*	*	*	*
Station #10 Walworth	*	*	*	*
Station #11 Williamson	*	*	*	*
Station #12 Sodus Point	*	*	*	*
Station #13 Substation 13	*	*	*	*

* All Non-Natural Gamma Emitters <MDA

Table B-8

Concentration of Gamma Emitters in Vegetation Samples
(Results in units of pCi/kg (wet) $\pm 2\sigma$)

Location	Sample Date	Sample Type	Gamma Emitters
South East Garden	09/19/2007	Grapes	*
	09/19/2007	Apples	*
East South East Garden	07/16/2007	Raspberries	*
	07/16/2007	Squash	*
	07/30/2007	Cucumbers	*
	07/30/2007	Green Leafy Vegetables	*
	09/04/2007	Cabbage	*
	09/04/2007	Tomatoes	22 \pm 8 (Cs-137)
Brockport (Control)	08/11/2007	Green Leafy Vegetables	*
	09/26/2007	Cabbage	*
Lyndonville (Control)	08/11/2007	Raspberries	*
South Southeast Garden	07/24/2007	Green Leafy Vegetables	*
	08/14/2007	Cucumbers	*
	09/04/2007	Cabbage	*
	09/04/2007	Tomatoes	*
	09/19/2007	Apples	*
South	09/19/2007	Apples	*
South West	09/19/2007	Apples	*
West	09/19/2007	Apples	*
South South West	09/19/2007	Apples	*
West South West	09/19/2007	Apples	*
Hilton (Control)	08/07/2007	Tomatoes	*
	08/07/2007	Squash	*
	08/07/2007	Cucumbers	*
	09/20/2007	Grapes	*
	09/20/2007	Apples	*

* All Non-Natural Gamma Emitters <MDA

Table B-9

Concentration of Gamma Emitters (including I-131) in Milk
(Results in units of pCi/Liter $\pm 2\sigma$)

Location	Sample Date	Gamma Emitters
FARM A	01/08/07	*
	02/19/07	*
	03/12/07	*
	04/17/07	*
	05/08/07	*
	06/13/07	*
	06/26/07	*
	07/16/07	*
	07/24/07	*
	08/13/07	*
	08/21/07	*
	09/04/07	*
	09/17/07	*
	10/01/07	*
10/15/07	*	
10/29/07	*	
11/12/07	*	
12/10/07	*	
FARM C	01/08/07	*
	02/19/07	*
	03/12/07	*
	04/17/07	*
	05/08/07	*
	06/13/07	*
	06/26/07	*
	07/16/07	*
	07/24/07	*
	08/13/07	*
	08/21/07	*
	09/04/07	*
	09/17/07	*
	10/01/07	3.6 \pm 1.89 (Cs-137)
10/15/07	*	
10/29/07	*	
11/12/07	*	
12/10/07	*	

* All Non-Natural Gamma Emitters <MDA

Table B-10

Typical MDA Ranges for Gamma Spectrometry

Selected Nuclides	Water pCi/l	Fish pCi/Kg	Sediment pCi/Kg	Particulate 10 ⁻³ pCi/m ³	Vegetation pCi/Kg	Milk pCi/l
H-3	223 -- 779	--	--	--	--	--
Na-22	4 – 10	27 – 51	47 – 160	0.4 – 1.0	21 – 68	6 – 13
Cr-51	28 – 77	237 – 777	353 – 1380	14 – 27	143 – 380	31 – 61
Mn-54	4 – 8	20-39	39 – 118	0.5 – 0.9	15 – 56	5 – 10
Co-58	4 – 9	33 – 50	47 – 156	0.8 – 1.6	20 – 54	5 – 10
Fe-59	8 – 11	69 – 191	118-436	3 – 6	45 – 144	11 – 24
Co-60	4 – 9	24 – 47	49 – 144	0.5 – 1.0	21 – 70	5 – 12
Zn-65	8 – 21	53 – 95	102 – 365	3 – 3	45 – 166	12 – 25
Nb-95	4 – 11	39 – 100	53 – 222	2 – 3	23 – 61	5 – 9
Zr-95	6 – 16	47 – 94	75 – 259	1 – 3	34 – 102	8 – 16
Ru-106	34 – 71	185 – 267	319 – 922	4 – 6	149 – 440	37 – 75
Ag-110m	3 – 8	20 – 31	37 – 142	0.4 – 0.8	16 – 52	4 – 8
Te-129m	42 – 119	364 – 1170	538 – 2280	19 – 33	246 – 674	50 – 98
I-131	4 – 29**	100 – 12200	122 – 1300	161 – 827*	21 – 479	4 – 9***
Cs-134	3 – 7	18 – 27	33 – 117	0.4 – 0.7	14 – 51	4 – 8
Cs-137	4 – 8	21 – 32	39 – 125	0.3 – 0.7	18 – 57	5 – 10
Ba-140	6 – 29	59 – 2250	103 – 916	33 – 87	29 – 137	6 – 14
La-140	6 – 29	59 – 2250	103 – 916	33 – 87	29 – 137	6 – 14
Ce-144	18 – 39	61 – 80	140 – 413	1 – 2	64 – 195	20 – 43

* The MDA range for I-131 measured on a charcoal cartridge is typically 6.3×10^{-3} to 2.3×10^{-2} pCi/m³

** The MDA range for I-131 measured in drinking water is typically 0.5 to 1.1 pCi/L

***The MDA range for I-131 measured in milk is typically 0.6 to 0.9 pCi/L

Table B-11

Typical LLDs for Gamma Spectrometry

Selected Nuclides	Water pCi/l	Fish pCi/Kg	Sediment pCi/Kg	Particulate* 10 ⁻³ pCi/m ³	Vegetation pCi/Kg	Milk pCi/l
Na-22	4.1	24	59	3.7	29	6
Cr-51	26	120	327	16	144	30
Mn-54	3.8	20	49	2.8	24	5
Co-58	3.9	20	36	2.8	19	5
Fs-59	7.8	45	103	2.8	50	11
Co-60	4.4	24	60	2.7	26	6
Zn-65	7.9	54	141	7.0	57	12
Nb-95	4.2	18	60	2.4	24	4
Zr-95	6.5	35	79	5.0	43	8
Ru-106	35	172	458	25	196	39
Ag-110m	3.6	15	42	2.2	21	4
Tc-129m	4.1	170	551	27	248	50
I-131	3.2*	13	41	1.9**	19	4*
Cs-134	3.3	17	44	2.4	20	4
Cs-137	3.9	17	58	2.8	26	5
Ba-140	4.8	19	67	3.9	33	5
La-140	4.8	19	67	3.9	33	5
Ce-144	17	58	191	8.9	81	20

* The LLD for I-131 measured in drinking water and milk is 0.5 pCi/L

**The LLD for I-131 measured on charcoal filter is 9.4×10^{-3} pCi/m³

Table B-12

Direct Radiation
(Results in Units of mR/90 days $\pm 2\sigma$)

Station	Location	First Quarter	Second Quarter	Third Quarter	Fourth Quarter
2	Onsite-Manor House Yard	12.1 \pm 3.0	11.8 \pm 3.0	13.2 \pm 3.3	13.0 \pm 3.3
3	Onsite-In field approximately 200 ft SE of station #2	11.9 \pm 3.0	11.9 \pm 3.0	13.8 \pm 3.5	13.4 \pm 3.4
4	Onsite-Training Center yard driveway circle	12.4 \pm 3.1	12.4 \pm 3.1	13.4 \pm 3.4	13.4 \pm 3.4
5	Onsite-Between creek and plant entry road	12.9 \pm 3.2	12.7 \pm 3.2	13.9 \pm 3.5	13.7 \pm 3.5
6	Onsite-SW side of plant parking lot	10.1 \pm 2.6	10.1 \pm 2.5	9.9 \pm 2.5	10.2 \pm 2.6
7	Onsite-utility pole along West plant fence	12.9 \pm 3.3	14.3 \pm 3.6	14.0 \pm 3.5	13.0 \pm 3.3
8	Topper Drive-Irondequoit, Seabreeze Substation #51	11.1 \pm 2.8	10.8 \pm 2.7	11.5 \pm 2.9	11.2 \pm 2.8
9	Phillips Road-Webster, intersection with Highway #104, Substation #74	10.5 \pm 2.6	10.8 \pm 2.7	11.4 \pm 2.9	11.4 \pm 2.9
10	Atlantic Avenue-Walworth, Substation #230	10.1 \pm 2.5	9.8 \pm 2.5	10.6 \pm 2.7	10.3 \pm 2.6
11	W. Main Street-Williamson, Substation #207	10.5 \pm 2.6	10.6 \pm 2.7	10.3 \pm 2.6	11.0 \pm 2.8
12	12 Seaman Avenue-Sodus Point-Off Lake Road by Sewer district, Substation #209	10.5 \pm 2.7	11.5 \pm 2.9	11.6 \pm 2.9	12.1 \pm 3.0
13	At corner of plant-controlled area fence and dogleg to West	11.9 \pm 3.0	12.2 \pm 3.1	13.3 \pm 3.3	12.6 \pm 3.2
14	NW corner of field along lake shore	11.1 \pm 2.8	11.9 \pm 3.0	12.9 \pm 3.2	12.5 \pm 3.1
15	Field access road, west of orchard, approximately 3000' West of plant	11.8 \pm 3.0	12.7 \pm 3.2	13.4 \pm 3.4	13.1 \pm 3.3

Table B-12 (Continued)

Direct Radiation
(Results in Units of mR/90 days \pm 2 σ)

Station	Location	First Quarter	Second Quarter	Third Quarter	Fourth Quarter
16	SW Corner of orchard, approximately 3000' West of plant, approximately 200' North of Lake Road	11.4 \pm 2.9	12.1 \pm 3.0	13.3 \pm 3.3	12.9 \pm 3.3
17	Utility pole in orchard, approximately 75' North of Lake Road	11.1 \pm 2.8	11.7 \pm 2.9	12.4 \pm 3.1	12.4 \pm 3.1
18	Approximately 30' North of NE corner of Substation 13A fence	10.0 \pm 2.5	10.0 \pm 2.5	10.3 \pm 2.6	10.4 \pm 2.6
19	On NW corner of house 100' East of plant access road	10.7 \pm 2.7	10.3 \pm 2.6	10.5 \pm 2.6	10.7 \pm 2.7
20	Approximately 150' West of Ontario Center Road and approximately 170' South of Lake Road	11.6 \pm 2.9	11.8 \pm 3.0	12.5 \pm 3.2	12.6 \pm 3.2
21	North side of Lake Road, approximately 200' East of Ontario Center Road	10.9 \pm 2.8	11.2 \pm 2.8	12.0 \pm 3.0	12.2 \pm 3.1
22	North side of Lake Road, SE, property owner	10.9 \pm 2.7	11.1 \pm 2.8	11.4 \pm 2.9	10.9 \pm 2.8
23	East property line, midway between Lake Road and Lake shore	10.8 \pm 2.7	12.2 \pm 3.1	13.1 \pm 3.3	12.9 \pm 3.2
24	Lake shore near NE corner of property	11.8 \pm 3.0	12.4 \pm 3.1	12.8 \pm 3.2	12.9 \pm 3.3
25 ¹	Substation #73, Klem Road, adjacent to 897 Klem Road	10.3 \pm 2.6	10.4 \pm 2.6	10.7 \pm 2.7	10.7 \pm 2.0
26 ¹	Service Center, Plank Road, West of 250	10.6 \pm 2.7	11.0 \pm 2.8	11.4 \pm 2.9	11.1 \pm 2.7
27 ¹	Atlantic Avenue at Knollwood Drive utility pole, North side of road	10.5 \pm 2.6	11.5 \pm 2.9	12.3 \pm 3.1	11.7 \pm 3.0

Table B-12 (Continued)

Direct Radiation
(Results in Units of mR/90 days $\pm 2\sigma$)

28	Substation #193, Marion, behind Stanton Ag. Service, North Main Street	10.0 \pm 2.5	11.1 \pm 2.8	11.2 \pm 2.8	10.8 \pm 2.7
29	Substation #208, Town Line Road (CR-118), 1000' North of Route 104	10.4 \pm 2.6	10.6 \pm 2.7	11.2 \pm 2.8	11.0 \pm 2.8
30	District Office, Sodus, on pole, West side of bldg.	11.3 \pm 2.9	10.7 \pm 2.7	11.2 \pm 2.8	10.7 \pm 2.7
31	Lake Road, pole 20' North of road, 500' East of Salt Road	11.2 \pm 2.8	12.5 \pm 3.2	13.2 \pm 3.3	12.0 \pm 3.0
32	Woodard Road at County Line Road, pole @ BW corner	10.4 \pm 2.6	10.2 \pm 2.6	10.8 \pm 2.7	10.8 \pm 2.7
33	County Line Road at RR tracks, pole approximately 100' East along tracks	10.5 \pm 2.6	10.8 \pm 2.7	10.5 \pm 2.6	10.8 \pm 2.7
34	Lincoln Road, pole midway between Ridge Road and Route 104	12.2 \pm 3.1	12.8 \pm 3.2	13.2 \pm 3.3	13.2 \pm 3.3
35	Transmission Right of Way, North of Clevenger Road on pole	11.3 \pm 2.8	12.7 \pm 3.2	13.8 \pm 3.5	15.4 \pm 3.9
36	Substation #205, Route 104, East of Ontario Center Road, North side of fence	10.7 \pm 2.7	10.7 \pm 2.7	11.4 \pm 2.9	11.3 \pm 2.8
37	Rail Road Avenue, pole at 2048	10.1 \pm 2.6	10.4 \pm 2.6	10.5 \pm 2.7	10.1 \pm 2.5
38	Fisher Road at RR Tracks, pole East of road	11.5 \pm 2.9	12.1 \pm 3.1	12.5 \pm 3.1	11.5 \pm 2.9
39	Seeley Road, Pole South side 100' West of intersection with Stony Lonesome Road	11.0 \pm 2.8	12.5 \pm 3.2	12.9 \pm 3.3	11.8 \pm 3.0
40	Lake Road at Stoney Lonesome Road, pole at SE corner	10.6 \pm 2.7	11.4 \pm 2.9	10.5 \pm 2.7	11.0 \pm 2.8

¹ Control Location

Table B-13

Groundwater Monitoring Wells

Location	Depth to Water (ft)	Sample Date	Tritium	
Groundwater AVT M. 17'	3.5	1/16/07	*	
	3.6	2/2/07	*	
	1.8	3/29/07	*	
	3.3	4/26/07	*	
	4.4	5/31/07	*	
	4.4	6/26/07	*	
	4.9	7/31/07	*	
	4.9	8/15/07	*	
	4.9	9/25/07	*	
	(1)	10/28/07	*	
	2.0	11/29/07	*	
	4.9	12/20/07	*	
Groundwater AVT N. 6'	3.2'	1/16/07	*	
	3.3'	2/2/07	*	
	1.6'	3/29/07	*	
	3.2'	4/26/07	*	
	4.3'	5/31/07	*	
	4.7' (recount)	6/26/07	*	
	4.7'	7/31/07	*	
	5.0'	8/15/07	*	
	4.6'	9/25/07	*	
	(1)	10/28/07	*	
	1.6'	11/29/07	*	
	3.9'	12/20/07	*	
	Groundwater AVT S. 13'	3.2'	1/16/07	*
		3.0'	2/2/07	*
1.0'		3/29/07	*	
3.0'		4/26/07	*	
4.0'		5/31/07	*	
4.3'		6/26/07	*	
4.4'		7/31/07	*	
4.9'		8/15/07	*	
4.6'		9/25/07	*	
(1)		10/28/07	*	
1.3'		11/29/07	*	
5.2'		12/20/07	*	

Table B-13 (Continued)

Groundwater Monitoring Wells

Location	Depth to Water (ft)	Sample Date	Tritium
Groundwater by Butler Bldg.	7.4'	1/16/07	*
	7.7'	2/7/07	*
	6.4'	3/29/07	*
	7.0'	4/26/07	*
	7.6'	5/31/07	*
	8.6'	6/26/07	*
	10.5'	7/31/07	*
	12.6'	8/15/07	*
	15.6'	9/25/07	*
	(1)	10/28/07	*
	13.6'	11/29/07	*
	12.8'	12/20/07	*
	Groundwater SE of CSB	17.1'	1/16/07
17.4'		2/2/07	*
14.2'		3/29/07	*
15.8'		4/26/07	*
17.6'		5/31/07	*
17.9'		6/26/07	*
17.4'		7/31/07	*
18.4'		8/15/07	*
18.3'		9/26/07	*
(1)		10/28/07	*
16.3'		11/29/07	*
16.6'		12/20/07	*
Pond			1/16/07
		3/29/07	*
		4/26/07	*
	Prior to drain	5/8/07	*
		5/31/07	*
		8/15/07	*
		10/28/07	*
Screen House West	6.0'	1/16/07	*
	6.0'	3/29/07	*
	6.2'	4/26/07	*
	6.4'	5/31/07	*
	6.2'	6/26/07	*
	12.3'	7/31/07	*
	12.7'	8/15/07	*
	9.7'	9/25/07	*
	(1)	10/28/07	*
12.0'	11/29/07	*	

Table B-13 (Continued)

Groundwater Monitoring Wells

Location	Depth to Water (ft)	Sample Date	Tritium
Storm Drain F		1/16/07	*
		2/2/07	*
		3/29/07	*
		4/26/07	*
		5/31/07	*
		6/26/07	*
		7/31/07	*
		8/15/07	*
		9/25/07	*
		10/28/07	*
		11/29/07	*
		12/20/07	*
Storm Drain G		1/16/07	*
		3/29/07	*
		4/26/07	*
		5/31/07	*
		6/26/07	*
		7/31/07	*
		8/15/07	*
		9/25/07	*
		10/28/07	*
		11/29/07	*
		12/20/07	*
	Storm Drain H		1/16/07
		2/2/07	*
		3/29/07	*
		4/26/07	*
		9/26/07	*
		11/29/07	*
		12/20/07	*
Storm Drain I		1/16/07	*
		3/29/07	*
		4/26/07	*
		5/31/07	*
		6/26/07	*
		7/31/07	*
		8/15/07	*
		9/25/07	*
		10/28/07	*
		11/29/07	*
	12/20/07	*	

* – Analytical results less than MDA
(1) – Depth to water information not collected.

APPENDIX C

Quality Assurance Program

Summary of Appendix C Content:

Appendix C presents a summary of Constellation Energy laboratory's quality assurance program, including the following:

- Table C-1 compiles the results of the Constellation Energy Laboratory's participation in an intercomparison program with Environmental Resource Associates (ERA), located in Arvada, Colorado and Analytics, Inc. located in Atlanta, Georgia.
- Table C-2 compiles the results of the Constellation Energy Laboratory's participation in a split sample program with Teledyne Brown Engineering located in Knoxville, Tennessee.
- Table C-3 lists typical MDAs achieved by Teledyne Brown for Gamma Spectroscopy.

All the Constellation Energy Laboratory's results contained in Table C-1 generally agree with the intercomparison laboratory's results within the range of $\pm 2 \sigma$ of each other. In addition, all the sets of intercomparison results in the table are in full agreement when they were further evaluated using the NRC Resolution Test Criteria¹. The uncertainties for the Constellation Energy Laboratory's results and Analytics' results are $\pm 2\sigma$ while the ERA laboratory's uncertainty is based on USEPA guidelines².

All the results contained in Table C-2 agree within the range of $\pm 2 \sigma$ of each other with their respective Constellation Energy Laboratory original, replicate and/or Teledyne Brown Engineering's split laboratory samples, except for the comparisons of five samples involving Cs-137 results: an air filter composite sample from A3 collected 5/15/2007; a soil sample from SFA4 collected 5/31/2007; a shoreline sample from Wb1 collected 5/31/2007; a vegetation sample form Ib1 collected 7/23/2007; and a vegetation sample from SFb3 collected 12/18/2007. In all five cases low levels of Cs-137 were observed in only one of the results of the comparison set and not observed in the other two. These minor discrepancies, occurring very close to or below the analyses MDA's, are most probably due to counting statistical fluctuations and/or the non-homogeneous nature of the sample-splitting process. Other samples whose nature generally precludes sample splitting are marked "***" in the Split Analysis column.

¹ NRC Inspection Manual, Inspection Procedure 84750, March 15, 1994

² National Standards for Water Proficiency Testing Studies Criteria Document, December 1998

TABLE OF CONTENTS - ANALYTICAL RESULTS

Table	Title	Page
C-1	RESULTS OF PARTICIPATION IN CROSS CHECK PROGRAMS.....	48
C-2	RESULTS OF QUALITY ASSURANCE PROGRAM.....	51
C-3	TELEDYNE BROWN ENGINEERING'S TYPICAL MDAS FOR GAMMA SPECTROMETRY	60

TABLE C-1
Results of Participation in Cross Check Programs

Sample Date	Sample Type and Units	Isotope Observed	Reported Laboratory ¹ Results ¹	Cross Check Lab Results ¹
1/08/07	Water-pCi/L	Ba-133	90±10	91±15
		Co-60	104±9	101±9
		Cs-134	83±7	89±9
		Cs-137	233±15	231±20
		Zn-65	381±33	350±60
3/22/07	Milk-pCi/L	I-131	85±29	85±3
		Cs-134	99±13	112±4
		Cs-137	249±28	234±8
		Ce-141	309±28	297±10
		Cr-51	227±109	245±8
		Mn-54	197±27	182±6
		Co-58	106±22	100±3
		Fe-59	111±30	106±4
		Co-60	162±17	152±5
		Zn-65	1075±80	1000±33
3/22/07	Charcoal Cartridge-pCi	I-131	80±5	70±2
3/22/07	Water-pCi/L	Gross β	99±5	100±3
4/09/07	Water-pCi/L	I-131	19±7	19±5
6/14/07	Water-pCi	Gross β	147±2	148±5
6/14/07	Water-pCi/L	Cs-134	172±7	194±6
		Cs-137	138±11	135±5
		Ce-141	145±36	160±5
		Co-58	171±15	159±5
		Fe-59	145±26	134±4
		Cr-51	489±191	411±14
		Co-60	202±8	191±6
		Mn-54	144±10	133±4
		Zn-65	283±23	268±9
		Cs-137	112±11	110±6
Zn-65	194±24	200±19		

¹ See discussion at the beginning of the Appendix.

Table C-1 (Continued)

Sample Date	Sample Type and Units	Isotope Observed	Reported Laboratory Results¹	Cross Check Lab Results¹
6/14/07	Filter-pCi/filter	Ce-141	121±24	114±4
		Cr-51	286±130	293±10
		Cs-134	118±6	138±5
		Cs-137	100±8	97±3
		Mn-54	108±9	95±3
		Fe-59	103±29	95±3
		Zn-65	230±22	191±6
		Co-60	143±8	136±5
		Co-58	122±14	113±4
7/06/07	Water-pCi/L	Ba-133	19±7	19±9
		Cs-134	67±6	69±9
		Cs-137	64±9	61±9
		Zn-65	113±15	55±9
		Co-60	34±5	34±8
7/06/07	Water-pCi/L	Gross β	7.6±0.4	11.5±9.0
9/13/07	Filter-pCi/filter	Gross β	82±2	87±1
9/18/07	Filter-pCi/filter	Am-241	31±22	21±8
		Cs-134	859±22	922±208
		Cs-137	916±23	831±269
		Co-60	562±14	505±126
		Zn-65	1554±51	1290±500
10/06/07	Water-pCi/L	I-131	29±2	29±5
12/06/07	Charcoal	I-131	79±5	74±2

¹ See discussion at the beginning of the Appendix

Table C-1 (Continued)
Results of Participation in Cross Check Programs

Sample Date	Sample Type and Units	Isotope Observed	Reported Laboratory' Results¹	Cross Check Lab Results¹
12/06/07	Milk-pCi/L	Cs-137	181±17	166±6
		Co-58	190±16	174±6
		Mn-54	208±16	190±6
		Fe-59	172±19	148±5
		Zn-65	264±30	234±8
		Co-60	224±13	211±8
12/06/07	Filter-pCi/filter	Ce-141	143±7	117±4
		Cr-51	535±60	425±14
		Cs-134	96±6	114±4
		Cs-137	148±10	138±5
		Co-58	152±12	144±5
		Mn-54	180±12	157±6
		Fe-59	148±14	123±4
		Zn-65	238±30	194±6
Co-60	190±10	175±6		

¹ See discussion at the beginning of the Appendix

TABLE C-2

Results of Quality Assurance Program

Sample Type And Location	Sample Date	Type of Analysis	Original Analysis	Replicate Analysis (10 ⁻² pCi/m ³)	Split Analysis
Air Iodine-A1	2/05/07	I-131	<MDA	<MDA	**
Air Iodine-A2	2/05/07	I-131	<MDA	<MDA	**
Air Iodine-A3	1/08/07	I-131	<MDA	<MDA	**
Air Iodine-A4	1/08/07	I-131	<MDA	<MDA	**
Air Filter -A1	1/08/07	Beta	0.7±0.1	0.8±0.1	**
Air Filter -A2	1/08/07	Beta	1.0±0.2	1.0±0.2	**
Air Filter -A3	1/08/07	Beta	0.7±0.1	0.7±0.1	**
Air Filter -A4	1/08/07	Beta	1.0±0.2	1.0±0.2	**
Air Filter -A5	1/08/07	Beta	0.9±0.1	0.9±0.1	**
Air Filter -SFA1	1/08/07	Beta	0.8±0.1	0.9±0.1	**
Air Filter -SFA2	1/08/07	Beta	1.0±0.1	0.9±0.1	**
Air Filter -SFA3	1/08/07	Beta	1.1±0.1	1.1±0.1	**
Air Filter -SFA4	1/08/07	Beta	1.0±0.2	0.9±0.1	**
Air Filter-A1	2/05/07	Beta	2.5±0.2	2.5±0.2	**
Air Filter-A2	2/05/07	Beta	2.5±0.2	2.4±0.2	**
Air Filter-A3	2/05/07	Beta	2.4±0.2	2.3±0.2	**
Air Filter-A4	2/05/07	Beta	2.7±0.3	2.9±0.2	**
Air Filter-A5	2/05/07	Beta	2.3±0.2	2.6±0.2	**
Air Filter-SFA1	2/05/07	Beta	2.6±0.2	2.7±0.2	**
Air Filter-SFA2	2/05/07	Beta	2.6±0.2	2.5±0.2	**
Air Filter-SFA3	2/05/07	Beta	2.4±0.2	2.6±0.2	**
Air Filter-SFA4	2/05/07	Beta	2.7±0.2	2.5±0.2	**
Bay Water-Wa2	2/28/07	Gamma	<MDA	<MDA	
Air Filter-A1	3/05/07	Beta	1.1±0.2	1.2±0.2	

**The nature of these samples precluded splitting them with an independent laboratory.

TABLE C-2 (Continued)

Results of Quality Assurance Program

Sample Type And Location	Sample Date	Type of Analysis	Original Analysis	Replicate Analysis (10 ⁻² pCi/m ³)	Split Analysis
Air Filter-A2	3/05/07	Beta	1.4±0.2	1.4±0.2	**
Air Filter-A3	3/05/07	Beta	1.2±0.2	1.1±0.2	**
Air Filter-A4	3/05/07	Beta	1.5±0.2	1.5±0.2	**
Air Filter-A5	3/05/07	Beta	1.0±0.1	1.0±0.1	**
Air Filter-SFA1	3/05/07	Beta	1.1±0.1	1.1±0.1	**
Air Filter-SFA2	3/05/07	Beta	1.0±0.1	1.2±0.2	**
Air Filter-SFA3	3/05/07	Beta	1.1±0.1	1.1±0.2	**
Air Filter-SFA4	3/05/07	Beta	1.5±0.2	1.4±0.2	**
(10 ⁻² pCi/m ³)					
Air Iodine-A3	3/05/07	I-131	<MDA	<MDA	**
Air Iodine-A4	3/05/07	I-131	<MDA	<MDA	**
(pCi/Kg)					
Oysters-Ia3	3/28/07	Gamma	<MDA	<MDA	<MDA
(pCi/L)					
Bay Water-Wa2	4/27/07	Cs-137	2±2	2±2	MDA
(10 ⁻² pCi/m ³)					
Air Filter-A1	4/09/07	Beta	1.2±0.2	1.3±0.2	**
Air Filter-A2	4/09/07	Beta	1.3±0.2	1.2±0.2	**
Air Filter-A3	4/09/07	Beta	1.5±0.2	1.6±0.2	**
Air Filter-A4	4/09/07	Beta	2.2±0.3	2.4±0.3	**
Air Filter-A5	4/09/07	Beta	1.4±0.2	1.2±0.2	**
Air Filter-SFA1	4/09/07	Beta	1.6±0.2	1.6±0.2	**
Air Filter-SFA2	4/09/07	Beta	1.3±0.2	1.5±0.2	**
Air Filter-SFA3	4/09/07	Beta	1.4±0.2	1.2±0.2	**
Air Filter-SFA4	4/09/07	Beta	1.3±0.2	1.4±0.2	**
(10 ⁻² pCi/m ³)					
Air Iodine-A1	4/09/07	I-131	<MDA	<MDA	**
Air Iodine-A2	4/09/07	I-131	<MDA	<MDA	**

**The nature of these samples precluded splitting them with an independent laboratory.

TABLE C-2 (Continued)

Results of Quality Assurance Program

Sample Type And Location	Sample Date	Type of Analysis	Original Analysis	Replicate Analysis (10 ⁻² pCi/m ³)	Split Analysis
Air Filters-A1	5/15/07	Gamma	<MDA	<MDA	<MDA
Air Filters-A2	5/15/07	Be-7	<MDA	<MDA	<MDA
Air Filters-A3	5/15/07	Cs-137	<MDA	2±1	<MDA
Air Filters-A4	5/15/07	Gamma	<MDA	<MDA	<MDA
Air Filters-A5	5/15/07	Gamma	<MDA	<MDA	<MDA
Air Filters-SFA1	5/15/07	Gamma	<MDA	<MDA	<MDA
Air Filters-SFA2	5/15/07	Gamma	<MDA	<MDA	<MDA
Air Filters-SFA3	5/15/07	Gamma	<MDA	<MDA	<MDA
Air Filters-SFA4	5/15/07	Gamma	<MDA	<MDA	<MDA
				(10 ⁻² pCi/m ³)	
Air Iodine-A3	5/07/07	I-131	<MDA	<MDA	**
Air Iodine-A4	5/07/07	I-131	<MDA	<MDA	**
				(10 ⁻² pCi/m ³)	
Air Filter-A1	5/07/07	Beta	1.5±0.2	1.3±0.2	**
Air Filter-A2	5/07/07	Beta	1.2±0.1	1.1±0.1	**
Air Filter-A3	5/07/07	Beta	1.4±0.2	1.1±0.2	**
Air Filter-A4	5/07/07	Beta	0.9±0.2	1.0±0.2	**
Air Filter-A5	5/07/07	Beta	3.1±0.3	2.6±0.3	**
Air Filter-SFA1	5/07/07	Beta	1.3±0.2	1.0±0.1	**
Air Filter-SFA2	5/07/07	Beta	1.2±0.1	1.1±0.1	**
Air Filter-SFA3	5/07/07	Beta	1.0±0.1	1.0±0.1	**
Air Filter-SFA4	5/07/07	Beta	1.1±0.1	1.0±0.1	**
				(pCi/Kg)	
Soil-SFS3	5/31/07	Cs-137	563±103	672±1013	708±99
Soil-SFS4	5/31/07	Cs-137	<MDA	<MDA	101±32
				(pCi/Kg)	
Vegetation-SFb3	5/31/07	Gamma	<MDA	<MDA	<MDA
Vegetation-SFb4	5/31/07	Gamma	<MDA	<MDA	<MDA

**The nature of these samples precluded splitting them with an independent laboratory.

TABLE C-2 (Continued)

Results of Quality Assurance Program

Sample Type And Location	Sample Date	Type of Analysis	Original Analysis	Replicate Analysis (10 ⁻² pCi/m ³)	Split Analysis
Shoreline-Wb1	5/31/07	Gamma	<MDA	<MDA	336±344
(10⁻² pCi/m³)					
Air Iodine-SFA2	6/04/07	I-131	<MDA	<MDA	**
Air Iodine-SFA3	6/04/07	I-131	<MDA	<MDA	**
(10⁻² pCi/m³)					
Air Filter-A1	6/04/07	Beta	2.0±0.2	2.1±0.2	**
Air Filter-A2	6/04/07	Beta	1.8±0.2	1.7±0.2	**
Air Filter-A3	6/04/07	Beta	1.8±0.2	1.9±0.2	**
Air Filter-A4	6/04/07	Beta	2.0±0.2	2.2±0.2	**
Air Filter-A5	6/04/07	Beta	2.0±0.2	2.2±0.2	**
Air Filter-SFA1	6/04/07	Beta	1.7±0.2	1.7±0.2	**
Air Filter-SFA2	6/04/07	Beta	1.8±0.2	1.9±0.2	**
Air Filter-SFA3	6/04/07	Beta	1.7±0.2	2.0±0.2	**
Air Filter-SFA4	6/04/07	Beta	1.9±0.2	1.8±0.2	**
(mR/90 Days)					
DR05	6/29/07	TLD	11.15±0.97	11.94±1.49	**
DR06	6/29/07	TLD	9.58±0.58	10.06±1.32	**
DR07	6/29/07	TLD	11.13±0.56	11.72±1.17	**
DR08	6/29/07	TLD	14.01±1.23	14.60±0.71	**
DR09	6/29/07	TLD	10.62±0.79	10.94±1.58	**
DR10	6/29/07	TLD	9.91±0.70	10.56±0.65	**
DR11	6/29/07	TLD	10.68±0.45	10.96±1.42	**
SFDR14	6/29/07	TLD	21.47±2.54	24.08±1.47	**
SFDR15	6/29/07	TLD	20.42±3.30	23.38±5.16	**
DR29	6/29/07	TLD	21.49±1.87	14.11±1.99	**
DR31	6/29/07	TLD	14.88±2.17	15.26±1.32	**

**The nature of these samples precluded splitting them with an independent laboratory.

TABLE C-2 (Continued)

Results of Quality Assurance Program

Sample Type And Location	Sample Date	Type of Analysis	Original Analysis	Replicate Analysis (10 ⁻² pCi/m ³)	Split Analysis
Air Filter-A1	7/09/07	Beta	1.8±0.2	2.0±0.2	**
Air Filter-A2	7/09/07	Beta	1.3±0.2	1.2±0.2	**
Air Filter-A3	7/09/07	Beta	1.3±0.2	1.3±0.2	**
Air Filter-A4	7/09/07	Beta	1.8±0.2	2.0±0.2	**
Air Filter-A5	7/09/07	Beta	1.7±0.2	1.7±0.2	**
Air Filter-SFA1	7/09/07	Beta	1.7±0.2	1.6±0.2	**
Air Filter-SFA2	7/09/07	Beta	1.8±0.2	1.8±0.2	**
Air Filter-SFA3	7/09/07	Beta	1.8±0.2	1.8±0.2	**
Air Filter-SFA4	7/09/07	Beta	1.9±0.2	1.8±0.2	**
(10 ⁻² pCi/m ³)					
Air Iodine-A3	7/09/07	I-131	<MDA	<MDA	**
Air Iodine-A4	7/09/07	I-131	<MDA	<MDA	**
(pCi /kg)					
Vegetation-Ib1	7/23/07	Cs-137	<MDA	18±11	<MDA
Vegetation-Ib3	7/23/07	Gamma	<MDA	<MDA	<MDA
Vegetation-Ib4	7/23/07	Gamma	<MDA	<MDA	<MDA
Vegetation-Ib5	7/23/07	Gamma	<MDA	<MDA	<MDA
Vegetation-Ib6	7/23/07	Gamma	<MDA	<MDA	<MDA
Vegetation-Ib7	7/23/07	Gamma	<MDA	<MDA	<MDA
Vegetation-Ib8	7/23/07	Gamma	<MDA	<MDA	<MDA
Vegetation-Ib9	7/23/07	Gamma	<MDA	<MDA	<MDA
(10 ⁻² pCi/m ³)					
Air Filter-A1	8/06/07	Beta	2.8±0.3	2.7±0.3	**
Air Filter-A2	8/06/07	Beta	2.2±0.2	2.3±0.2	**
Air Filter-A3	8/06/07	Beta	2.6±0.2	2.2±0.2	**
Air Filter-A4	8/06/07	Beta	2.0±0.2	2.1±0.2	**
Air Filter-A5	8/06/07	Beta	2.7±0.2	2.5±0.2	**
Air Filter-SFA1	8/06/07	Beta	2.7±0.2	2.4±0.2	**
Air Filter-SFA2	8/06/07	Beta	2.8±0.2	2.6±0.2	**
Air Filter-SFA3	8/06/07	Beta	2.3±0.2	2.1±0.2	**
Air Filter-SFA4	8/06/07	Beta	2.9±0.2	2.7±0.2	**

**The nature of these samples precluded splitting them with an independent laboratory.

TABLE C-2 (Continued)

Results of Quality Assurance Program

Sample Type And Location	Sample Date	Type of Analysis	Original Analysis	Replicate Analysis (10 ⁻² pCi/m ³)	Split Analysis
Air Iodine-A1	8/06/07	I-131	<MDA	<MDA	**
Air Iodine-A2	8/06/07	I-131	<MDA	<MDA	**
(pCi/kg)					
Fish-Ia1	8/22/07	Cs-137	7±9	9±10	<MDA
Oysters-Ia3	8/22/07	Gamma	<MDA	<MDA	<MDA
(pCi/L)					
Bay Water-Wa1	8/31/07	Gamma	<MDA	<MDA	<MDA
(pCi/kg)					
Vegetation-Ib4	8/13/07	Gamma	<MDA	<MDA	<MDA
Vegetation-Ib6	8/13/07	Gamma	<MDA	<MDA	<MDA
(10⁻² pCi/m³)					
Air Iodine-A3	9/10/07	I-131	<MDA	<MDA	**
Air Iodine-A4	9/10/07	I-131	<MDA	<MDA	**
(10⁻² pCi/m³)					
Air Filter-A1	9/10/07	Beta	2.7±0.3	2.5±0.3	**
Air Filter-A2	9/10/07	Beta	2.0±0.2	2.0±0.2	**
Air Filter-A3	9/10/07	Beta	1.9±0.2	2.1±0.2	**
Air Filter-A4	9/10/07	Beta	2.0±0.2	2.2±0.2	**
Air Filter-A5	9/10/07	Beta	2.2±0.3	2.1±0.2	**
Air Filter-SFA1	9/10/07	Beta	2.3±0.3	2.2±0.3	**
Air Filter-SFA2	9/10/07	Beta	2.4±0.3	2.5±0.3	**
Air Filter-SFA3	9/10/07	Beta	2.2±0.2	2.2±0.2	**
Air Filter-SFA4	9/10/07	Beta	2.1±0.2	2.2±0.3	**
(10⁻³ pCi/m³)					
Air Filters-A1	10/15/07	Gamma	<MDA	<MDA	<MDA
Air Filters-A2	10/15/07	Gamma	<MDA	<MDA	<MDA
Air Filters-A3	10/15/07	Gamma	<MDA	<MDA	<MDA

**The nature of these samples precluded splitting them with an independent laboratory.

TABLE C-2 (Continued)

Results of Quality Assurance Program

Sample Type And Location	Sample Date	Type of Analysis	Original Analysis	Replicate Analysis (10 ⁻³ pCi/m ³)	Split Analysis
Air Filters-A4	10/15/07	Gamma	<MDA	<MDA	<MDA
Air Filters-A5	10/15/07	Gamma	<MDA	<MDA	<MDA
Air Filters-SFA1	10/15/07	Gamma	<MDA	<MDA	<MDA
Air Filters-SFA2	10/15/07	Gamma	<MDA	<MDA	<MDA
Air Filters-SFA3	10/15/07	Gamma	<MDA	<MDA	<MDA
Air Filters-SFA4	10/15/07	Gamma	<MDA	<MDA	<MDA
(10 ⁻² pCi/m ³)					
Air Iodine-A1	10/08/07	I-131	<MDA	<MDA	**
Air Iodine-A2	10/08/07	I-131	<MDA	<MDA	**
(10 ⁻² pCi/m ³)					
Air Filter-A1	10/08/07	Beta	3.1±0.3	3.3±0.3	**
Air Filter-A2	10/08/07	Beta	2.0±0.2	2.1±0.2	**
Air Filter-A3	10/08/07	Beta	3.3±0.3	3.4±0.3	**
Air Filter-A4	10/08/07	Beta	2.1±0.2	2.1±0.2	**
Air Filter-A5	10/08/07	Beta	2.2±0.2	2.4±0.2	**
Air Filter-SFA1	10/08/07	Beta	2.3±0.2	2.6±0.2	**
Air Filter-SFA2	10/08/07	Beta	2.5±0.2	2.3±0.2	**
Air Filter-SFA3	10/08/07	Beta	2.3±0.2	2.6±0.2	**
Air Filter-SFA4	10/08/07	Beta	2.3±0.2	2.5±0.2	**
(10 ⁻² pCi/m ³)					
Air Filter-A1	11/05/07	Beta	1.9±0.2	2.0±0.2	**
Air Filter-A2	11/05/07	Beta	2.0±0.2	2.0±0.2	**
Air Filter-A3	11/05/07	Beta	1.7±0.2	1.9±0.2	**
Air Filter-A4	11/05/07	Beta	2.1±0.2	2.2±0.2	**
Air Filter-A5	11/05/07	Beta	2.3±0.2	2.2±0.2	**
Air Filter-SFA1	11/05/07	Beta	2.3±0.2	2.4±0.2	**
Air Filter-SFA2	11/05/07	Beta	2.2±0.2	2.2±0.2	**
Air Filter-SFA3	11/05/07	Beta	2.4±0.2	2.4±0.2	**
Air Filter-SFA4	11/05/07	Beta	2.4±0.2	2.2±0.2	**

**The nature of these samples precluded splitting them with an independent laboratory.

TABLE C-2 (Continued)

Results of Quality Assurance Program					
Sample Type And Location	Sample Date	Type of Analysis	Original Analysis	Replicate Analysis (10^{-2} pCi/m ³)	Split Analysis
Air Iodine-A3	11/05/07	I-131	<MDA	<MDA	**
Air Iodine-A5	11/05/07	I-131	<MDA	<MDA	**
(pCi/L)					
Bay Water-Wa2	11/30/07	Gamma	<MDA	<MDA	<MDA
(10 ⁻² pCi/m ³)					
Air Filter-A1	12/10/07	Beta	1.9±0.2	1.7±0.2	**
Air Filter-A2	12/10/07	Beta	1.5±0.2	1.6±0.2	**
Air Filter-A3	12/10/07	Beta	1.7±0.2	1.6±0.2	**
Air Filter-A4	12/10/07	Beta	1.8±0.2	2.1±0.2	**
Air Filter-A5	12/10/07	Beta	1.9±0.2	1.8±0.2	**
Air Filter-SFA1	12/10/07	Beta	1.7±0.2	1.5±0.2	**
Air Filter-SFA2	12/10/07	Beta	2.0±0.2	2.1±0.2	**
Air Filter-SFA3	12/10/07	Beta	2.0±0.2	1.9±0.2	**
Air Filter-SFA4	12/10/07	Beta	1.9±0.2	1.8±0.2	**
(10 ⁻² pCi/m ³)					
Air Iodine-A1	12/10/07	I-131	<MDA	<MDA	**
Air Iodine-A2	12/10/07	I-131	<MDA	<MDA	**
(pCi/Kg)					
Soil-SFS2	12/18/07	Cs-137	103±39	131±46	99±71
Soil-SFS3	12/18/07	Cs-137	502±91	565±91	565±91
(pCi/Kg)					
Vegetation-SFb2	12/18/07	Gamma	<MDA	<MDA	<MDA
Vegetation-SFb3	12/18/07	Cs-137	27±24	<MDA	<MDA

**The nature of these samples precluded splitting them with an independent laboratory.

TABLE C-2 (Continued)

Results of Quality Assurance Program

Sample Type And Location	Sample Date	Type of Analysis	Original Analysis	Replicate Analysis (mR/90	Split Analysis
DR05	01/03/08	TLD	13.39±1.34	11.79±1.17	**
DR06	01/03/08	TLD	11.02±1.06	10.28±1.02	**
DR07	01/03/08	TLD	11.26±1.37	10.15±1.22	**
DR08	01/03/08	TLD	16.04±1.68	15.27±0.99	**
DR09	01/03/08	TLD	12.29±0.45	11.66±0.69	**
DR10	01/03/08	TLD	11.60±1.19	11.09±0.81	**
DR11	01/03/08	TLD	11.88±2.32	11.18±1.12	**
SFDR14	01/03/08	TLD	17.90±3.71	17.28±2.55	**
SFDR15	01/03/08	TLD	20.18±3.71	20.83±2.71	**
DR29	01/03/08	TLD	16.30±2.17	15.39±1.05	**
DR31	01/03/08	TLD	16.91±1.74	15.66±1.07	**

**The nature of these samples precluded splitting them with an independent laboratory.

TABLE C-3

Teledyne Brown Engineering's Typical MDAs for Gamma Spectrometry

Selected Nuclides	Bay Water pCi/l	Fish pCi/kg	Shellfish pCi/kg	Sediment pCi/kg	Vegetation pCi/kg	Particulates 10 ⁻³ pCi/m ³
H-3	175	--	--	--	--	--
Na-22	1	8	3	12	6	5
Cr-51	12	105	4	104	50	63
Mn-54	1	9	3	12	5	4
Co-58	1	9	4	9	4	5
Fe-59	3	28	9	24	10	12
Co-60	1	9	4	12	5	6
Zn-65	2	20	8	25	10	9
Nb-95	1	12	7	14	6	9
Zr-95	2	18	8	20	9	9
Ru-106	9	75	30	90	41	40
Ag-110m	1	10	10	10	5	4
Te-129m	16	131	60	162	79	95
I-131	4	65	30	35	22	74
Cs-134	1	8	4	10	5	4
Cs-137	1	9	4	10	5	4
BaLa-140	3	32	15	25	14	36
Ce-144	7	40	16	54	26	18

APPENDIX D

Land Use Survey

Summary of Appendix D Content:

Appendix D contains the results of a Land Use Survey conducted around R. E. Ginna Nuclear Power Plant during this operating period. A table listing the raw data of this survey and a discussion of the results are included in this appendix.

Land Use Survey

Discussion

A Land Use Survey was conducted to identify the location of the nearest milk animal, the nearest residence, and the nearest garden greater than 50 square meters in each of the nine sectors within a 5-mile radius of the power plant. A detailed description of the Land Use Survey is given in a separate document (Ref. 4). The position of the nearest residence and garden and animals producing milk for human consumption in each sector is provided in Table D-1.

Table D-1
Land Use Survey Distances

Sector	Distance to Nearest Residence	Distance to Nearest Garden	Distance to Milk Producing Animals
E	1260 m	N/A	N/A
ESE	1050 m	Onsite Garden	N/A
SE	610 m	N/A	8270 m
SSE	660 m	Onsite Supplemental Garden	N/A
S	1560 m	N/A	N/A
SSW	760 m	N/A	N/A
SW	660 m	N/A	N/A
WSW	1350 m	N/A	N/A
W	1160 m	N/A	N/A

The closest residence is situated in the SE sector (610 meter from the power plant), the nearest garden is in the SSE sector (660 meters), and the nearest milk producing animals was in the SE sector (8,270 meters).

Changes from Previous Years:

The following land use changes have occurred over the within a 5-mile radius of the power plant:

- Development of single family homes continues at a pace consistent with prior years.
- Interviews with area farmers indicate that the number of acres farmed will continue to decrease.
- No new agricultural land use was noted.
- No new food producing facilities were noted.

Milk Animal Locations:

The milk animal location with a 5-mile radius of the power plant are as follows:

- Eaton Farm -- 6747 Salmon Creek Road, Williamson, NY
- No new milk producing animals were identified in the 2007 Census.