TASK TITLE: Perform Shutdown Margin Calculation

JPM No.: R-103

Task No.: R-RK-005

Objective No.: 4.C.GP-03

EXAMINEE: _____

EVALUATOR: _____

PASSED _____ this JPM. The Examinee: FAILED

CRITICAL ELEMENTS: (*) 3, 4, 5, 6 45 minutes CRITICAL TIME: **EVALUATION METHOD:**

> X PERFORM SIMULATE

| REV: | 20070301 |
|----------|----------|
| K/A No.: | 2.1.25 |
| K/A IMP: | 2.8/3.1 |

RO

DATE:

TIME STARTED: TIME FINISHED: JPM TIME: MINUTES APPROX COMPLETION TIME: 20 MINUTES

LOCATION:

X IN PLANT SIMULATOR

GENERAL REFERENCES:

- 1. 2BwOSR 3.1.1.1-2, UNIT TWO SHUTDOWN MARGIN SURVEILLANCE DURING **OPERATION**, Rev. 1.
- 2. BwCB-2, BRAIDWOOD CURVE BOOK, UNIT 2.
- 3. CORE OPERATING LIMITS REPORT (COLR) FOR BRAIDWOOD UNIT 2 CYCLE 13.

MATERIALS:

- 1. Copy of 2BwOSR 3.1.1.1-2, Rev. 1.
- 2. Copy of BwCB-2.
- Copy of Braidwood Technical Requirements Manual (TRM) 3.

TASK STANDARDS:

- 1. Correctly determine total rod worth due to rods.
- 2. Correctly determine actual reactivity available due to rods.
- 3. Correctly determine current power defect.
- 4. Correctly determine shutdown margin is unacceptable for current plant conditions within 45 minutes.

TASK CONDITIONS:

1. This is a time critical JPM.

- 2. You are an extra NSO.
- 3. Unit 2 is at 100% power with the following conditions:
 - Control Bank D is at 215 steps, Unit 2 burn up is 6,500 EFPH, RCS Tave is 581°F and RCS a. Boron concentration is 950 ppm from a sample obtained one hour ago.
 - 15 minutes ago, control rods D-4 and M12 were determined to be inoperable and b. immovable. The QNE has been informed.

INITIATING CUES:

The Unit 2 Unit Supervisor has directed you to perform 2BwOSR 3.1.1.1-2, UNIT TWO SHUTDOWN MARGIN SURVEILLANCE DURING OPERATION, in accordance with Tech Spec 1. 3.1.4. Condition A.

CUE: Hand examinee copy of 2BwOSR 3.1.1.1-2.

2. Inform the Unit 2 Unit Supervisor when you have completed 2BwOSR 3.1.1.1-2.

| | PERFORMANCE STEP | STANDARD | CIRCLE APPLICABLE |
|----|--|--|-----------------------------------|
| | EVALUATOR NOTE: JPM may be | performed in plant or in classr | oom. |
| 1. | Refer to 2BwOSR 3.1.1.1-2: NOTE: Critical Time begins when examinee understands initiating cue and accepts responsibility for task performance. Record critical time start time: CUE: All Prerequisites, Precautions, Limitations and Actions are met. | Refer to 2BwOSR 3.1.1.1-2: | SAT UNSAT N/A <u>Comments:</u> |
| 2. | Record Present Conditions: (step F.1) | Determine and record the following from initiating cue: Date and Time: <u>Current</u> <u>Date and Time</u> Core Average Burnup: <u>6,500 EFPH</u> Core Average Temperature: <u>581°F</u> Power Level: <u>100%</u> Present Boron Concentration: <u>950 ppm</u> | SAT UNSAT N/A <u>Comments:</u> |

| | PERFORMANCE STEP | STANDARD | CIRCLE APPLICABLE |
|-----|---|--|----------------------------|
| *3. | Determine total worth due to rods (step F.2) | Determine and record total worth due to rods by | SAT UNSAT N/A Comments: |
| | CUE: When examinee locates curve book, provide the attached curves. NOTE: Examinee may refer to BwCB-2, Figure 2c for an expanded scale of Figure 2 control bank D rod worth. | Record control bank position: <u>Bank D @ 215</u> <u>steps</u> (from initiating cue). Determine and record control bank D inserted worth by performing the following: | <u></u> |
| | NOTE: Examinee must refer to correct figure and burn up range. BwCB-2, Figures 2 & 2c are for Hot Full Power and Figures 2a and 2d are for Hot Zero Power. From initiating cue, Unit 2 is at 100% power. NOTE: Record Examinee Value of control bank D inserted worth: (10 pcm ± 10 pcm) NOTE: Record Examinee Value of control bank D total worth: (3329.4 pcm) NOTE: Record Examinee Value of control bank D available worth: (3319.4 pcm ± 10 pcm) | Refer to BwCB-2, Figure 2 for burn up range of 4,850.1 – 7544.6 EFPH. Record control bank D inserted worth: <u>10 pcm</u> <u>± 10 pcm</u>. Determine and record total available control bank worth by performing the following: Refer to BwCB-2, Table 4-1 for control bank worth for burn up range of 4850.1 - 9449.4 EFPH. Determine control bank total worth: <u>3329.4</u> pcm. Subtract control bank D inserted worth from control bank total worth: <u>3329.4 pcm –</u> <u>10 pcm (± 10 pcm) =</u> <u>3319.4 pcm (± 10 pcm)</u>. Determine and record total worth due to rods by performing the following: Refer to BwCB-2, Table 4-1 for shutdown bank | |
| | NOTE: Record Examinee Value of shutdown bank total worth: | 4-1 for shutdown bank worth for burn up range of 4850.1 - 9449.4 EFPH. Determine shutdown | |
| | (3458.5 pcm) | Determine shutdown bank total worth: <u>3458.5 pcm.</u> Determine total rod worth | |
| | NOTE: Record Examinee Value of total rod worth: (6777.9 pcm ± 10 pcm) | by performing the following: Add shutdown bank total worth to available control bank worth: <u>3458.5 pcm + 3319.4</u> <u>pcm (± 10 pcm) =</u> <u>6777.9 pcm (+ 10 pcm)</u> | |
| | | <u> </u> | |

| | PERFORMANCE STEP | STANDARD | CIRCLE APPLICABLE |
|-----|---|---|-----------------------------------|
| *4. | Determine actual reactivity available due to rods (step F.3) NOTE: Record Examinee Value of number of immovable and/or untrippable control rods: | Determine and record actual reactivity due to rods by performing the following: Record the number of immovable and/or untrippable control rods: <u>2</u> (from initiating cue) | SAT UNSAT N/A <u>Comments:</u> |
| | (2) | Determine and record highest stuck rod worth by performing the following: | |
| | NOTE: Record Examinee Value of highest stuck rod worth: | Refer to BwCB-2, Table 4-1 for highest stuck rod worth for burn up range of 4850.1 - 9449.4 EFPH. | |
| | (966.5 pcm) | Determine and record highest stuck rod worth: <u>966.5 pcm</u>. | |
| | NOTE: Record Examinee Value of immovable/untrippable rod worth: (4000 pcm) NOTE: Record Examinee Value of actual reactivity available due to rods: | Determine immovable/untrippable rod worth by performing the following: Multiply the number of immovable or untrippable control rods by 2000pcm: <u>2 X 2000</u> pcm = 4000 pcm. Determine actual reactivity available due to rods by performing the following: Subtract immovable/untrippable rod worth and highest stuck rod worth from | |
| | (1811.4 pcm ± 10 pcm) | total rod worth: <u>6777.9</u> <u>pcm (± 10 pcm) – 4000</u> <u>pcm – 966.5 pcm =</u> <u>1811.4 pcm (± 10 pcm).</u> | |

| | PERFORMANCE STEP | STANDARD | CIRCLE APPLICABLE |
|-----|---|--|-----------------------------------|
| *5. | Determine current Power Defect | Determine and record the current power defect for boron concentration and power level by performing the following: | SAT UNSAT N/A <u>Comments:</u> |
| | NOTE: Record Examinee Value of power defect: (-1725 <u>+</u> 50 if Fig 17A used, -1733 if Table 2-1 used) | Refer to BwCB-2, Figure 17A for power defect for burn up range of 4850 - 9449.4 EFPH. Determine and record power defect: -<u>1725 ±</u> 50 pcm. OR Refer to BwCB-2, Table 2-1 for power defect for burn up range of 6466.8 EFPH. Determine and record power defect: -<u>1733</u> | |
| | | pcm. | |

| | PERFORMANCE STEP | STANDARD | CIRCLE APPLICABLE |
|-----|---|--|----------------------------|
| *6. | Perform Shutdown Margin Verification | VERIFY Shutdown Margin by performing the following: | SAT UNSAT N/A Comments: |
| | NOTE: Record Examinee Value of available shutdown margin: | Add total corrected rod worth to power defect: <u>1811.4 pcm (± 10 pcm) + -</u> <u>1725 (± 50 pcm). = 86.4</u> pcm (± 60 pcm) | |
| | (86.4 pcm ± 60 pcm) NOTE: Record Examinee Value of minimum required shutdown margin: (1300 pcm) | Refer to TRM for Unit 2 COLR. Determine and record the Shutdown Margin Limit for Modes 1 and 2 from the COLR: <u>1.3% ∆k/k x 1000</u> | |
| | 86.4 pcm ± 60 pcm < 1300 pcm NOTE: Critical Time ends when examinee completes surveillance or reports unacceptable shutdown margin. | pcm/% Δk/k = 1300 pcm. Determine the available shutdown reactivity is less than the minimum required Shutdown Margin Limit: <u>86.4 pcm (± 60 pcm). <</u> <u>1300 pcm</u> Inform US shutdown margin is unaccentable | |
| | Record time that examinee reports unacceptable shutdown margin or completes surveillance: | Inform US 2BwOSR 3.1.1.1-2 is complete. | |
| | | | |
| | (end time) (start time) ≤ 45 minutes. | | |
| | CUE: As US, acknowledge report of inadequate shutdown margin and/or completion of 2BwOSR 3.1.1.1-2. | | |

RECORD STOP TIME:

TASK CONDITIONS:

- 1. This is a time critical JPM.
- 2. You are an extra NSO.
- 3. **Unit 2** is at 100% power with the following conditions:
 - a. Control Bank D is at 215 steps, Unit 2 burn up is 6,500 EFPH, RCS Tave is 581°F and RCS Boron concentration is 950 ppm from a sample obtained one hour ago.
 - b. 15 minutes ago, control rods D-4 and M-12 were determined to be inoperable and immovable. The QNE has been informed.

- 1. The Unit 2 Unit Supervisor has directed you to perform 2BwOSR 3.1.1.1-2, UNIT TWO SHUTDOWN MARGIN SURVEILLANCE DURING OPERATION, in accordance with Tech Spec 3.1.4. Condition A.
- 2. Inform the Unit 2 Unit Supervisor when you have completed 2BwOSR 3.1.1.1-2.

TASK TITLE: Review Shutdown Margin Calculation

JPM No.: S-107

Task No.: S-AM-123

Objective No.: 8E.AM-123

EXAMINEE: _____

EVALUATOR: _____

PASSED _____ this JPM. The Examinee: FAILED

CRITICAL ELEMENTS: (*) 4, 6, 7 CRITICAL TIME: 45 minutes **EVALUATION METHOD:**

X PERFORM

| REV: | 20070301 |
|----------|----------|
| K/A No.: | 2.1.33 |
| K/A IMP: | 4.0 |

SRO

DATE:

TIME STARTED: _____ TIME FINISHED: JPM TIME: MINUTES APPROX COMPLETION TIME: 30 MINUTES

LOCATION:

SIMULATE

X IN PLANT SIMULATOR

GENERAL REFERENCES:

- 1. 2BwOSR 3.1.1.1-2, UNIT TWO SHUTDOWN MARGIN SURVEILLANCE DURING **OPERATION**, Rev. 1.
- 2. BwCB-2, BRAIDWOOD CURVE BOOK, UNIT 2.
- 3. CORE OPERATING LIMITS REPORT (COLR) FOR BRAIDWOOD UNIT 2 CYCLE 13.

MATERIALS:

- 1. Copy of completed 2BwOSR 3.1.1.1-2, Rev. 1.
- 2. Copy of BwCB-2.
- Copy of Braidwood Technical Requirements Manual (TRM) 3.

TASK STANDARDS:

- 1. Determine actual reactivity due to rods incorrectly calculated.
- 2. Determine shutdown margin incorrectly performed.
- 3. Determine shutdown margin is unacceptable for current plant conditions within 45 minutes.
- 4. Determine boration required to be initiated within 1 hour of discovery of stuck control rod.
- Determine plant shutdown to MODE 3 required to be completed within 6 hours of discovery of 5. stuck control rod.

TASK CONDITIONS:

1. This is a time critical JPM.

- 2. You are the Unit 2 Unit Supervisor.
- 3. Unit 2 is at 100% power with the following conditions:
 - Control Bank D is at 215 steps, Unit 2 burn up is 6,500 EFPH, RCS Tave is 581°F and RCS a. Boron concentration is 950 ppm from a sample obtained one hour ago.
 - 15 minutes ago, control rods D-4 and M12 were determined to be inoperable and b. immovable. The QNE has been informed.

- The Unit 2 Assist NSO has completed 2BwOSR 3.1.1.1-2, UNIT TWO SHUTDOWN MARGIN 1. SURVEILLANCE DURING OPERATION.
- 2. The Shift Manager has directed you to perform the supervisory review of 2BwOSR 3.1.1.1-2.
- 3. Inform the Shift Manager when you have completed the review of 2BwOSR 3.1.1.1-2.

| | PERFORMANCE STEP | STANDARD | CIRCLE APPLICABLE |
|----|--|---|-----------------------------------|
| | EVALUATOR NOTE: JPM may be | performed in plant or in classr | oom. |
| 1. | Refer to 2BwOSR 3.1.1.1-2 NOTE: Critical Time begins when examinee understands initiating cue and accepts responsibility for task performance. Record critical time start time: | Refer to 2BwOSR 3.1.1.1-2 | SAT UNSAT N/A <u>Comments:</u> |
| 2. | Review Present Conditions: (step F.1) | Review Present Conditions: (from initiating cue) Date and Time: <u>Current</u> <u>Date and Time</u> Core Average Burnup: <u>6,500 EFPH</u> Core Average Temperature: <u>581°F</u> Power Level: <u>100%</u> Present Boron Concentration: <u>950 ppm</u> | SAT UNSAT N/A <u>Comments:</u> |

| | PERFORMANCE STEP | STANDARD | CIRCLE APPLICABLE |
|----|--|---|-----------------------------------|
| 3. | Review total worth due to rods: (step F.2) | Review total worth due to rods:Verify control bank_ | SAT UNSAT N/A <u>Comments:</u> |
| | CUE: When examinee locates curve book, provide the attached curves. | position: <u>Bank D @ 215</u> <u>steps</u> (from initiating cue). | |
| | NOTE: Examinee may refer to | Verify control bank D inserted worth: | |
| | BwCB-2, Figure 2c for an expanded scale of Figure 2 control bank D rod worth. | Refer to BwCB-2, Figure 2 for burn up range of 4,850.1 – 7544.6 EFPH. | |
| | | Verify control bank D inserted worth correct: <u>10 pcm</u>. | |
| | | Verify total available control bank worth: | |
| | | Refer to BwCB-2, Table 4-1 for control bank worth for burn up range of 4850.1 - 9449.4 EFPH. | |
| | | Verify control bank total worth: <u>3329.4 pcm</u>. | |
| | | Subtract control bank D inserted worth from control bank total worth: <u>3329.4 pcm –</u> <u>10 pcm = 3319.4 pcm</u>. | |
| | | Verify total worth due to rods: | |
| | | Refer to BwCB-2, Table 4-1 for shutdown bank worth for burn up range of 4850.1 - 9449.4 EFPH. | |
| | | Verify shutdown bank total worth: <u>3458.5</u> <u>pcm.</u> | |
| | | Verify total rod worth: | |
| | | Add shutdown bank total worth to available control bank worth: <u>3458.5 pcm + 3319.4</u> <u>pcm = 6777.9 pcm.</u> | |

| *4. Review actual reactivity available due to rods: (step F.3) Review actual reactivity due to rods: Verify the number of immovable and/or untrippable control rods: 2 (from initiating cue) Verify highest stuck rod worth: | N/A |
|--|-----|
| worth: | |
| CUE: When examinee discovers incorrect highest stuck rod worth has been recorded, instruct examinee to correct error and proceed with surveillance review. Refer to BwCB-2, Table 4-1 for highest stuck rod worth for burn up range of 4850.1 - 9449.4 EFPH. Determine incorrect highest stuck rod worth stuck rod worth | |
| NOTE: Record Examinee Value of highest stuck rod worth: • Inform NSO of incorrect rod worth entry. (966.5 pcm) • Verify immovable/untrippable rod worth: | |
| CUE: When examinee discovers incorrect reactivity available due to rods (from previously recorded in step F.3.b), instruct examinee to correct error and proceed with surveillance review. NOTE: Record Examinee Value of actual reactivity available due to rods: (1811.4 pcm) | |

| | PERFORMANCE STEP | STANDARD | CIRCLE APPLICABLE |
|-----|--|--|-----------------------------------|
| 5. | Determine current Power Defect: (step F.4) | Verify current power defect for boron concentration and power level: Refer to BwCB-2, Figure 17A for power defect for burn up range of 4850 - 9449.4 EFPH. OR Refer to BwCB-2, Table 2-1 for power defect for burn up range of 6466.8 EFPH. Verify power defect: <u>-1733 pcm.</u> | SAT UNSAT N/A <u>Comments:</u> |
| *6. | Verify Shutdown Margin: (step F.5)CUE:When examinee discovers incorrect available shutdown margin, instruct examinee to correct error and proceed with | Verify shutdown margin: Add total corrected rod worth to power defect: 1811.4 pcm + -1733. = 78.4 pcm. Determine shutdown margin calculation incorrectly performed (power defect value incorrectly added to total corrected rod worth instead of subtracted due to negative value to power defect). Inform NSO of incorrect available shutdown margin entry. Enter correct available shutdown margin: <u>78.4</u> <u>pcm.</u> Refer to TRM for Unit 2 COLR. Verify shutdown margin limit for Modes 1 and 2 from the COLR: <u>-1.3%</u> <u>Ak/k x 1000 pcm/%Ak/k = 1300 pcm.</u> Determine the available shutdown margin limit: <u>78.4 pcm < 1300 pcm</u> Inform Shift Manager 2BwOSR 3.1.1.1-2 is complete and acceptance criteria is not met. | SAT UNSAT N/A Comments: |
| | | | 1 |

| | PERFORMANCE STEP | STANDARD | CIRCLE APPLICABLE |
|-----|---|---|-----------------------------------|
| *7. | Determine Tech Spec requirements. NOTE: If examinee determines shutdown margin is inadequate, provide the following cue: CUE: Shift Manager directs you to review Tech Specs for applicability with current plant conditions. NOTE: Critical Time ends when examinee determines boration must be initiated. Record time that examinee determines boration required: Critical time = (end time) (start time) ≤ 45 minutes. CUE: As Shift Manager, acknowledge report of Tech Spec entry conditions and applicability. | Perform the following: Determine Tech Spec 3.1.4, Condition A.1.2 applies for inadequate shutdown margin in mode 1 (initiate boration within 1 hour of discovery of stuck rods) Determine Tech Spec 3.1.4, Condition A.2 applies for inadequate shutdown margin in mode 1 (be in MODE 3 within 6 hours of discovery of stuck rods) Notify Shift Manager of Tech Spec entry conditions and applicability. | SAT UNSAT N/A <u>Comments:</u> |

RECORD STOP TIME: _____

TASK CONDITIONS:

- 1. This is a time critical JPM.
- 2. You are the Unit 2 Unit Supervisor.
- 3. Unit 2 is at 100% power with the following conditions:
 - a. Control Bank D is at 215 steps, Unit 2 burn up is 6,500 EFPH, RCS Tave is 581°F and RCS Boron concentration is 950 ppm from a sample obtained one hour ago.
 - b. 15 minutes ago, control rods D-4 and M12 were determined to be inoperable and immovable. The QNE has been informed.

- 1. The Unit 2 Assist NSO has completed 2BwOSR 3.1.1.1-2, UNIT TWO SHUTDOWN MARGIN SURVEILLANCE DURING OPERATION.
- 2. The Shift Manager has directed you to perform the supervisory review of 2BwOSR 3.1.1.1-2.
- 3. Inform the Shift Manager when you have completed the review of 2BwOSR 3.1.1.1-2.

TASK TITLE: Perform Mode 5 Shiftly and Daily Operating Surveillance

JPM No.: R-107

Task No.: R-AM-064

Objective No.: 4.C.AM-03

EXAMINEE:

EVALUATOR: _____

The Examinee: PASSED _____ this JPM. FAILED _____

CRITICAL ELEMENTS: (*) 2, 8, 9 CRITICAL TIME: N/A EVALUATION METHOD:

X PERFORM

SIMULATE

REV:20070301K/A No.:2.1.18K/A IMP:2.9/3.0

RO SRO (Circle One)

DATE:

TIME STARTED: _____ TIME FINISHED: _____ JPM TIME: _____ MINUTES APPROX COMPLETION TIME: 30 MINUTES

LOCATION:

___ IN PLANT

X SIMULATOR

GENERAL REFERENCES:

1. 1BwOSR 0.1-5, UNIT ONE MODE 5 SHIFTLY AND DAILY OPERATING SURVEILLANCE, Rev. 9.

MATERIALS:

- 1. Copy of partially completed 1BwOSR 0.1-5.
- 2. Red ink pen for annotating out of spec readings.

TASK STANDARDS:

- 1. Determine 1A SI Pump is not correctly aligned for current plant conditions.
- 2. Determine VCT level channel is failed low.
- 3. Determine BDPS is inoperable.

TASK CONDITIONS:

- 1. You are the Unit 1 NSO.
- 2. Unit 1 is in Mode 5.
- 3. 1BwGP 100-1, PLANT HEATUP, is in progress.
- 4. BOTH RH trains are operable.
- 5. The SHIFT TWO portion of 1BwOSR 0.1-5, MODE 5, SHIFTLY AND DAILY OPERATING SURVEILLANCE, is in progress.
- 6. Another NSO has completed 1BwOSR 0.1-5, data sheets D-2 thru D-4 and D-12 thru D-15. The NSO has also partially completed data sheets D-8 thru D-10.

INITIATING CUES:

1. The Unit 1 Unit Supervisor directs you to complete the SHIFT TWO portion of 1BwOSR 0.1-5 by performing the incomplete items on data sheets D-5 thru D-11.

CUE: Hand examinee copy of 1BwOSR 0.1-5.

- 2. Another NSO will monitor the remainder of the Main Control Board panels and address alarms as necessary.
- Inform the Unit 1 Unit Supervisor when you have completed 1BwOSR 0.1-5 data sheets D-5 thru D-11.

| | PERFORMANCE STEP | | STANDARD | CIRCLE APPLICABLE | | |
|----|---|---|--|-----------------------------------|--|--|
| 1. | Refer to 1 | BwOSR 0.1-5: | Refer to 1BwOSR 0.1-5: | SAT UNSAT N/A | | |
| | CUE: A P a | II Prerequisites, recautions, Limitations nd Actions are met. | | <u>Comments:</u> | | |
| | CUE: If e: 0 (i | asked, provide xaminee copy of BwOSR 0.1-5 pages 1-7 nstructions section) | | | | |
| *2 | Determine 1A SI Pump is not properly aligned: (Data Sheet D- 5) | | Perform the following at 1PM05J: Check Pressurizer level channels. Determine Pressurizer level is > 5%. (≈ 28%) Check YES box on Data Sheat D 5 | SAT UNSAT N/A <u>Comments:</u> | | |
| | CUE: If b | asked, 1A SI pump preaker is racked in. | Data Sheet D-5. Perform the following at 1PM06J: Determine 1A SI Pump status 1A SI pump breaker is racked in. 1A SI pump C/S is in NAT. 1A SI pump is aligned for cold leg injection. | | | |
| | CUE: If n ti fi | asked, there are no nanual valves closed in he 1A SI pump lowpath. | 1A SI pump is capable of injecting to the RCS cold legs. Notify Unit Supervisor 1A SI Pump is not in correct alignment. | | | |
| | CUE: If asked, 1B SI pump breaker is racked out. | | Check 1B SI Pump status: 1B SI pump breaker is R/O. | | | |
| | CUE: A a 1 iii 3 a N S | As Unit Supervisor, acknowledge report of A SI pump alignment, nform examinee LCO 8.4.12 (LTOP) will be addressed and another NSO will realign the 1A SI pump. | Perform the following at 1PM05J: Check 1A CV pump status: 1A CV pump is operating. Check 1B CV pump status: 1B CV pump breaker is R/O. Determines Data Sheet D-6 is not required to be performed with PZR level > 5%. Record SI and CV Pump status on Data Sheet D-5. | | | |

| | PERFORMANCE STEP | STANDARD | CIRCLE APPLICABLE | | |
|----|--|--|-----------------------------------|--|--|
| 3. | Check RH Pump discharge flow: (Data Sheet D-7) | Perform the following at 1PM06J: Check 1A RH Pump Discharge Flow on 1FI-618. Record 1A RH Pump Flow on Data Sheet D-7. | SAT UNSAT N/A <u>Comments:</u> | | |
| 4. | Check RCS Temperature: (Data Sheet D-7) | Perform the following at 1PM05J: Check Cold Leg 1A-1D WR Temperature Indicators: 1TI-413B (170°F - 180°F) 1TI-423B (170°F - 180°F) 1TI-433B (170°F - 180°F) 1TI-443B (170°F - 180°F) 1TI-443B (170°F - 180°F) Record RCS Cold Leg temperatures on Data Sheet D-7. Perform the following at 1PM05J and 1PM6J: Determine lowest RCS temperature indication from RCS loops and operating RH train. (≈ 175°F) Record lowest RCS temperature on Data Sheet D-7. | SAT UNSAT N/A Comments: | | |
| 5. | Check RCS level: (Data Sheet D- 8) NOTE: Reduced inventory exists if Reactor Vessel level is ≤ 397' (< 0% PZR level or approximately 55% RVLIS plenum level). | Perform the following at 1PM05J: Determine RCS NOT in reduced inventory PZR level ≈ 28% RVLIS Head and Plenum 100% Check NO box on Data Sheet D-8. | SAT UNSAT N/A <u>Comments:</u> | | |
| 6. | Check Source Range Instrumentation. (Data Sheet D-9) | Perform the following at 1PM05J: Check Source Range indications: 1NI-31A (≈ 10 cps) 1NI-32A (≈ 10 cps) Determine Source Range indications responding properly. Check YES boxes on Data Sheet D-9. | SAT UNSAT N/A <u>Comments:</u> | | |

| | PERFORMANCE STEP | STANDARD | CIRCLE APPLICABLE | | |
|----|--|--|-----------------------------------|--|--|
| 7. | Check RCS Loops: (Data Sheet D- 10) | Perform the following at 1PM05J: Check RCP Status: Determine 1D RCP is running. Check 1D box on Data Sheet D-10. Check Loop Stop Valves open: RCS flow indication. ESF Isolation Valve light box on 1PM06J. Check loops 1A – 1D HL and CL boxes on Data Sheet D-10. | SAT UNSAT N/A Comments: | | |
| *8 | Determine VCT level channel is inoperable: (Data Sheet D-11) CUE: As Unit Supervisor, acknowledge report of 1LR-185 failure. | Perform the following at 1PM05J: Check VCT Level 1LI-112 (≈ 54%) 1LR-185 (0%) Determine 1LR-185 is failed low. Record VCT level on Data Sheet D-11. Check YES box next to 1LI-112 on Data Sheet D-11. Check NO box next to 1LR-185 on Data Sheet D-11. Check NO box next to 1LR-185 on Data Sheet D-11. Notify Unit Supervisor VCT Level Channel 1LR-185 is failed. | SAT UNSAT N/A <u>Comments:</u> | | |

| | PERFORMANCE STEP | STANDARD | CIRCLE APPLICABLE |
|-----|--|---|-----------------------------------|
| *9. | Determine BDPS is inoperable: (Data Sheet D-11) | Perform the following at 1PM05J: | SAT UNSAT N/A <u>Comments:</u> |
| *9. | Determine BDPS is inoperable: (Data Sheet D-11) CUE: As Unit Supervisor, acknowledge report of BDPS inoperability and inform examinee LCO 3.3.9 will be addressed. | Perform the following at 1PM05J: Check BDPS Channel Selector Switches. Determine BDPS Channel Selector Switches are BOTH in NORMAL. Check YES boxes on Data Sheet D-11. Verify BDPS Operability Determine < 2 VCT level channels operable. Notify Unit Supervisor BDPS is NOT operable Determine BDPS Channel Selector Switches are BOTH in NORMAL. Check NORMAL box on Data Sheet D-11. Determine one RCP running Check ≥ 1 box on Data Sheet D-11. Determine all 8 LSIVs are OPEN | SAT UNSAT N/A <u>Comments:</u> |
| | | Check 8 box on Data Sheet D-11. | |

RECORD STOP TIME:

SIMULATOR SETUP INSTRUCTIONS

- Verify/perform TQ-BR-201-0113, BRAIDWOOD TRAINING DEPARTMENT SIMULATOR EXAMINATION SECURITY ACTIONS CHECKLIST.
- Establish the conditions of IC-3.
- Complete items on Simulator Ready for Training Checklist.
- Place simulator in RUN.
- Place Wide Range Iconics and RCS Heat up limitations on 1PM05J CRTs.
- Turn on scaler timer and verify audible SR counts.
- Provide examinees with red pen for circling out of spec readings.
- Energize SVAG valves by performing the following:
 - Place 480v feed to Bus 131X1A/X2A C/S to CLOSE
 - Place 480v feed to Bus 132X2A/X4A C/S to CLOSE
- Open 1SI8835, SI Pumps to Cold Legs Isolation Valve
- Place 1A SI Pump in NAT.
- Place C/O cards on 1B CV Pump C/S and 1B SI Pump C/S.
- Turn over or remove energized SVAG valve placards.
- Insert **IMF CV17 0** to fail VCT Level Channel 1LT-185 LOW.
- Depressurize the SI Accumulators by performing the following:
 - Set monitor item SIMN2ACC[1] = 0
 - Set monitor item SIMN2ACC[2] = 0
 - Set monitor item SIMN2ACC[3] = 0
 - Set monitor item **SIMN2ACC[4] = 0**
- AT CONCLUSION OF JPM PERFORMANCE(S), PERFORM THE FOLLOWING:
 - VERIFY/REMOVE C/O CARDS FROM 1B CV PUMP C/S
 - VERIFY/REMOVE C/O CARDS FROM 1B SI PUMP
 - VERIFY/RESTORE SVAG VALVE PLACARDS

JOB PERFORMANCE MEASURE

TASK CONDITIONS:

- 1. You are the Unit 1 NSO.
- 2. Unit 1 is in Mode 5.
- 3. 1BwGP 100-1, PLANT HEATUP, is in progress.
- 4. BOTH RH trains are operable.
- 5. The SHIFT TWO portion of 1BwOSR 0.1-5, MODE 5, SHIFTLY AND DAILY OPERATING SURVEILLANCE, is in progress.
- 6. Another NSO has completed 1BwOSR 0.1-5, data sheets D-2 thru D-4 and D-12 thru D-15. The NSO has also partially completed data sheets D-8 thru D-10.

- 1. The Unit 1 Unit Supervisor directs you to complete the SHIFT TWO portion of 1BwOSR 0.1-5 by performing the incomplete items on data sheets D-5 thru D-11.
- 2. Another NSO will monitor the remainder of the Main Control Board panels and address alarms as necessary.
- 3. Inform the Unit 1 Unit Supervisor when you have completed 1BwOSR 0.1-5 data sheets D-5 thru D-11.

| TASK TITLE: | Hang Worke | r Tagout (1A FW P | Pump) | | |
|---------------|---------------------------------|----------------------------------|----------------------|-------------------|--------------------------------|
| JPM No.: | R-201 | | | REV: | 20070301 |
| Task No.: | R-AP-017 | | | K/A No.: | 2.2.13 |
| Objective No. | : 4C.AP-04 | | | K/A IMP: | 3.6 |
| EXAMINEE: | | | | RO | |
| EVALUATOR | : | | | DATE: | |
| The Examine | e: PAS | SED this JP | M. | TIME STAR | TED: |
| | FAIL | ED | | TIME FINIS | HED: |
| | | | | JPM TIME: | MINUTES |
| CRITICAL EL | EMENTS: | (*) 2, 3, 4a, 4b, | 5a | APPROX CO | MPLETION TIME: 40 MINUTES |
| CRITICAL TIN | ME: | NA | | | |
| EVALUATION | METHOD: | | | LOCATION: | |
| | <u>X</u> PERFO | RM | | IN PLAN | IT |
| | SIMULA | TE | | X SIMUL | ATOR |
| GENERAL RE | EFERENCES | : | | | |
| 1. | OP-AA-109- | 101, CLEARANCE | AND TAGGING, | Rev. 1. | |
| MATERIALS: | | | | | |
| 1. | Copy of part | ially completed Wo | orker Tagout Form | | |
| 2. | Worker Tage | out cards. | | | |
| 3. | Copy of Fee | dwater System pri | nts. | | |
| 4. | Copy of OP- | AA-109-101, Rev. | 1. | | |
| TASK STAND | DARDS: | | | | |
| 1. | Determine w card on 1A F | rong component is W pump. | s listed on Worker | Tagout (WTO) | checklist prior to hanging WTO |
| 2. | Determine th cards on 1A | ne sequence of iso FW pump. | lation points for 1A | FW pump is ir | ncorrect prior to hanging WTO |
| 3. | Correctly po | sition 1A FW pump | components for \ | NTO. | |
| 4. | Correctly se | quence hanging of | WTO. | | |
| TASK CONDI | TIONS: | | | | |
| 1. | You are the | Unit 1 Assist NSO. | | | |
| INITIATING C | CUES: | | | | |
| 1. | The Unit 1 U on the 1A F | Init Supervisor has N Pump. | directed you to re | view and hang | Worker Tagout (WTO) P07-100 |
| | CUE: Hand | l examinee copy o | of Worker Tagout | form. | |
| 2. | Equipment of in the field to | perators have bee assist you. | n briefed and have | e a field copy of | f the WTO and are standing by |
| 3. | Another NSC as necessar | O will monitor the re y. | emainder of the M | ain Control Boa | ard panels and address alarms |
| 4. | Inform the U | Init 1 Unit Supervis | or when you have | completed the | Worker Tagout. |

RECORD START TIME: _____

| | PERFORMANCE STEP | STANDARD | CIRCLE APPLICABLE | | | | | | | |
|-----|---|---|---|--|--|--|--|--|--|--|
| 1. | Refer to Worker Tagout Form Hang/Lift Section: CUE: If asked, provide examinee copy of OP- AA-109-101 | Refer to Worker Tagout (WTO) Form Hang/Lift Section: Review WTO Hang/Lift Section. Review Special Instructions. | SAT UNSAT N/A <u>Comments:</u> | | | | | | | |
| | EVALUATOR NOTE: The examin step 3) prior to determining the co discover both errors simultaneou critical tasks 2 & 3. | ee may determine the clearance sec omponent is incorrect (JPM step 2) Isly. The examinee must identify bo | quence is incorrect (JPM , or the examinee may oth errors to complete | | | | | | | |
| | EVALUATOR NOTE: The JPM contains corrected Worker Tagout checklist to be given to the examinee after the errors are identified. If the examinee first determines the incorrect component is listed on the Worker Tagout checklist prior to determining the incorrect sequence is listed, provide examines JPM page 7 | | | | | | | | | |
| | If the examinee first determines to checklist, provide examinee JPM | he incorrect sequence is listed, provi page 8. | he Worker Tagout | | | | | | | |
| | When the examinee has determin the Worker Tagout checklist, prov | ed BOTH the incorrect component vide examinee JPM page 9. | and sequence is listed on | | | | | | | |
| *2 | Determine the incorrect component is listed on the WTO: CUE: Acknowledge as Unit Supervisor and inform examinee the checklist | Determine the incorrect component is listed on the WTO: 2A FW pump C/S is listed on checklist and card instead of 1A FW pump. Notify Unit Supervisor of | SAT UNSAT N/A <u>Comments:</u> | | | | | | | |
| | and card will be corrected. CUE: Hand examinee corrected worker tagout and correct card (1FW01PA C/S) in accordance with the evaluator note above. | component error. | | | | | | | | |
| *3. | Determine the clearance sequence for 1A FW Pump is incorrect. CUE: Acknowledge as Unit Supervisor and inform examinee the checklist will be corrected. CUE: Hand examinee corrected | Determine the clearance hang sequence for 1A FW Pump is incorrect: Clearance hang is sequenced in lift order. Notify Unit Supervisor of sequencing error. | SAT UNSAT N/A <u>Comments:</u> | | | | | | | |
| | accordance with the evaluator note above. | | | | | | | | | |

| | PERFORMANCE STEP | STANDARD | CIRCLE APPLICABLE |
|------|---|--|-----------------------------------|
| *4a. | Hang WTO on 1A FW Pump C/S: | Perform the following at 1PM04J: Place 1FW01PA, FW Pump 1A, C/S to PULL OUT. Hang WTO card on 1FW01PA C/S. Place initials in HUNG BY block. | SAT UNSAT N/A <u>Comments:</u> |
| *4b | Hang WTO on 1A FW Pump Aux Oil Pump C/S: | Perform the following at 1PM04J: Place 1FW01PA-B, FW Pump 1A Aux Oil Pump, C/S to PULL OUT. Hang WTO card on 1FW01PA- B C/S. Place initials in HUNG BY block. | SAT UNSAT N/A <u>Comments:</u> |
| *5a. | Hang WTO on 1A FW Pump Discharge Valve: | Perform the following at 1PM04J: Place 1FW002A, FW Pump 1A Discharge Valve, C/S to CLOSE. Hang WTO card on 1FW002A C/S. Place initials in HUNG BY block. | SAT UNSAT N/A <u>Comments:</u> |
| 5b. | Hang WTO on 1A FW Pump Recirc Valve | Perform the following at 1PM04J: Hang WTO card on 1FW012A C/S. Place initials in HUNG BY block. | SAT UNSAT N/A <u>Comments:</u> |

| | PERFORMANCE STEP | STANDARD | CIRCLE APPLICABLE | | |
|----|--|---|---|--|--|
| 6. | Hang WTO on 1A FW Pump breakers: CUE: In plant WTO steps being performed by Doe (initials DD). CUE: 1A FW Pump Break RACKED OUT and V card is hung. CUE: 1A FW Pump Aux C Pump Breaker is Of and WTO card is hu CUE: 1A FW Pump Motor Heater breaker is O and WTO card is hu CUE: 1A FW Pump Motor Heater breaker is O and WTO card is hu NOTE: Contact simulator operator to deenerge 1FW002A breaker a provide the followin cue: CUE: 1FW002A breaker is and WTO card is hu | Perform the following: Dispatch Equipment Operators • R/O 1A FW pump breaker. • Turn off 1A FW Pump Aux O Pump Breaker. • Turn off 1A FW Pump Moto Heater Breaker. • Turn off 1FW002A, 1A FW Pump Discharge Valve, Breaker. • Hang WTO cards on FW Pump Breakers. • Hang WTO cards on FW Pump Breakers. • Place NLOs initials/examine initials in HUNG BY block. | SAT UNSAT N/A to: <u>Comments:</u> Oil r | | |
| 7. | Hang WTO on 1A FW Pump valves: CUE: 1FW027A is closed WTO card is hung. | Perform the following: Dispatch Equipment Operators to: Close 1FW027A, FW Pump 1A Recirc Valve Manual Isolation Valve Hang WTO card on 1FW027A. Place NLOs initials/examinee's initials in HUNG BY block. | SAT UNSAT N/A Comments: | | |
| 8. | Inform Unit Supervisor 1A FW Pump WTO is complete. CUE: As Unit Supervisor, acknowledge repor | Perform the following: Inform Unit Supervisor 1A FW Pump WTO is complete. | SAT UNSAT N/A <u>Comments:</u> | | |

RECORD STOP TIME:

SIMULATOR SETUP INSTRUCTIONS

- Verify/perform TQ-BR-201-0113, BRAIDWOOD TRAINING DEPARTMENT SIMULATOR EXAMINATION SECURITY ACTIONS CHECKLIST.
- Establish the conditions of IC 21, 100% power, steady state, equilibrium xenon.
- Complete items on Simulator Ready for Training Checklist.
- Place simulator in RUN.
- Verify 1A FW pump is available.
- When examinee dispatches NLO to deenergize 1FW002A, perform the following:
 - Insert **IRF ED091C OFF** to deenergize 1FW002A.

JOB PERFORMANCE MEASURE

TASK CONDITIONS:

1. You are the Unit 1 Assist NSO.

- 1. The Unit 1 Unit Supervisor has directed you to review and hang Worker Tagout (WTO) P07-100 on the 1A FW Pump.
- 2. Equipment operators have been briefed and have a field copy of the WTO and are standing by in the field to assist you.
- 3. Another NSO will monitor the remainder of the Main Control Board panels and address alarms as necessary.
- 4. Inform the Unit 1 Unit Supervisor when you have completed the Worker Tagout.

| ATTA | CHMEN | IT 14 P | ART 1 |
|------|-------|---------|-------|
| | ••••• | | |

WTO Form Hang/Lift Section

Page 1 of 1

| Fage 1 01 1 | | | | | | | | | | |
|--|---|-------------|----------|------------|------------------|-----------------|------------|-----------------|-----------|--------------|
| Exceptional WTO: | | | | 1 | Mode De | pendent: | | | | |
| Condition Depende | nt: 🗌 | | | F | Productio | on Risk: | | | | |
| WORKER TAGOUT# PO7-100 JOB DESCRIPTION: CHANGE 1A MAIN FEEDWATER PUMP OIL | | | | | | | | | | |
| WORKING DEPARTMENT: <u>MMD</u> W/O OR W/R: <u>12345</u> EQUIP. TAG# <u>1FW01PA</u> | | | | | | | | | | |
| COMPONENT DESCRIPTION: 1A MAIN FEEDWATER PUMP | | | | | | | | | | |
| FIRST APPROVAL: | | | | | | | | | | |
| SECOND APPROVAL: | SECOND APPROVAL: Mike Operator DATE/TIME: Today/8 minutes ago | | | | | | | | | |
| WTO AUTHORIZATION: _Joe S | upervis | sor | | DATE | /TIME <u>Too</u> | lay/2 minut | tes ago | | | |
| SPECIAL INSTRUCTIONS: | YES | : 🖂 | NO: | | IF YES SE | E ATTACH | MENT 14 | 4 PART 2) | | |
| EQUIP. TAG/EQUIPMENT NAME | SEQ | TAG TYPE | POSITION | HUNG BY | VERIF. BY | SFTY. VERIF. | RTS SEQ | RTS POSITION | RTS BY | VERIF. BY |
| 1FW027A FW PUMP 1A RECIRC VALVE MANUAL ISOL VLV (401 K-11 +20') | 1 | RD | CLOSED | | N/A | | 1 | OPEN | | N/A |
| 1FW002A BKR FW PUMP 1A DSCH VLV BKR (133Z2 G3) | 2 | RD | OFF | | N/A | | 2 | ON | | N/A |
| 1FW01PA BKR FW PUMP 1A BKR (BUS 156 CUB 4) | 2 | RD | R/O | | N/A | | 2 | R/TEST | | N/A |
| 1FW01PA-B BKR FW PUMP 1A AUX OIL PUMP BKR (134Z2 CUB F1) | 2 | RD | OFF | | N/A | | 2 | ON | | N/A |
| 1FW01PA-A BKR FW PP 1A MOTOR HTR BKR (134Z2 G4) | 2 | RD | OFF | | N/A | | 2 | ON | | N/A |
| 1FW01PA C/S FW PUMP 1A C/S (1PM04J) | 3 | CD | PTL | | N/A | | 3 | NAT | | N/A |
| 1FW01PA-B C/S FW PUMP 1A AUX OIL PUMP C/S (1PM04J) | 3 | CD | PTL | | N/A | | 3 | NAT | | N/A |
| 1FW002A C/S FW PUMP 1A DISCH VALVE C/S (1PM04J) | 3 | CD | NAC | | N/A | | 3 | NAO | | N/A |
| 1FW012A C/S FW PUMP 1A RECIRC VALVE C/S (1PM04J) | 3 | CI | INFO | | N/A | | 3 | CLOSED | | N/A |
| WTO PLACED: | DATE/TIME: | | | | | | | | | |
| WTL COMPLETED WORK STAP | | | | DATE/T | IME: | | | | | |
| WTO FINAL CLEAR: WORK CREWMEMBER RELEASE: | | | | | | | | | | |
| WTO CLEARED: | | | | | | D | ATE/TIM | E: | | |
| (COPIES MAY BE MADE OF THIS FORM FOR ADDITIONAL ISOLATION POINTS) | | | | | | | | | | |

ATTACHMENT 14 PART 1 WTO Form Hang/Lift Section

Page 1 of 1

Exceptional WTO:

SECOND APPROVAL: Mike Operator

Mode Dependent:

Condition Dependent:

Production Risk:

WORKER TAGOUT# **P07-100** JOB DESCRIPTION: **CHANGE 1A MAIN FEEDWATER PUMP OIL**

WORKING DEPARTMENT: MMD W/O OR W/R: 12345 EQUIP. TAG# 1FW01PA

COMPONENT DESCRIPTION: 1A MAIN FEEDWATER PUMP

DATE/TIME: *Today/10 minutes ago*

___ DATE/TIME: <u>Today/8 minutes ago</u>

WTO AUTHORIZATION: <u>Joe Supervisor</u> DATE/TIME <u>Today/2 minutes ago</u>

NO:

SPECIAL INSTRUCTIONS:

YES:

(IF YES SEE ATTACHMENT 14 PART 2)

| EQUIP. TAG/EQUIPMENT NAME | SEQ | TAG TYPE | POSITION | HUNG BY | VERIF. BY | SFTY. VERIF. | RTS SEQ | RTS POSITION | RTS BY | VERIF. BY |
|---|-----|-------------|----------|------------|--------------|-----------------|------------|-----------------|-----------|--------------|
| 2FW01PA C/S FW PUMP 2A C/S (2PM04J) | 1 | CD | PTL | | N/A | | 5 | NAT | | N/A |
| 1FW01PA-B C/S FW PUMP 1A AUX OIL PUMP C/S (1PM04J) | 1 | CD | PTL | | N/A | | 4 | NAT | | N/A |
| 1FW002A C/S FW PUMP 1A DISCH VALVE C/S (1PM04J) | 2 | CD | NAC | | N/A | | 3 | NAO | | N/A |
| 1FW012A C/S FW PUMP 1A RECIRC VALVE C/S (1PM04J) | 2 | CI | INFO | | N/A | | 3 | CLOSED | | N/A |
| 1FW01PA BKR FW PUMP 1A BKR (BUS 156 CUB 4) | 3 | RD | R/O | | N/A | | 2 | R/TEST | | N/A |
| 1FW01PA-B BKR FW PUMP 1A AUX OIL PUMP BKR (134Z2 CUB F1) | 3 | RD | OFF | | N/A | | 2 | ON | | N/A |
| 1FW01PA-A BKR FW PP 1A MOTOR HTR BKR (134Z2 G4) | 3 | RD | OFF | | N/A | | 2 | ON | | N/A |
| 1FW002A BKR FW PUMP 1A DSCH VLV BKR (133Z2 G3) | 3 | RD | OFF | | N/A | | 2 | ON | | N/A |
| 1FW027A FW PUMP 1A RECIRC VALVE MANUAL ISOL VLV (401 K-11 +20') | 4 | RD | CLOSED | | N/A | | 1 | OPEN | | N/A |

| WTO PLACED: | DATE/TIME: | |
|---|------------|--|
| WTL COMPLETED WORK START: | DATE/TIME: | |
| WTO FINAL CLEAR: WORK CREWMEMBER RELEASE: | DATE/TIME: | |
| WTO CLEARED: | DATE/TIME: | |

(COPIES MAY BE MADE OF THIS FORM FOR ADDITIONAL ISOLATION POINTS)

| ATTACHMENT 14 PART 1 | | | | | | | | | | |
|---|---|------------------|-------------|-----------------|------------------|-----------------|------------|-----------------|-----------|--------------|
| WTO Form Hang/Lift Section | | | | | | | | | | |
| Page 1 of 1 | | | | | | | | | | |
| Exceptional WTO: Mode Dependent: | | | | | | | | | | |
| Condition Dependent: Production Risk: | | | | | | | | | | |
| WORKER TAGOUT# <u>PO7-100</u> | WORKER TAGOUT# P07-100 JOB DESCRIPTION: CHANGE 1A MAIN FEEDWATER PUMP OIL | | | | | | | | | |
| WORKING DEPARTMENT: MMD | W/O C |)R W/R: <u>1</u> | 12345 EQUIP | . TAG# <u>1</u> | W01PA | | | | | |
| COMPONENT DESCRIPTION: 1/ | A MAIN | FEEDW/ | ATER PUMP | | | | | | | |
| FIRST APPROVAL: | | | | DATE/TIN | IE: <u>Today</u> | /10 minute | es ago | | | |
| SECOND APPROVAL: <u>Mike O</u> | perator | | | DATE/TI | ME: <u>Toda</u> | y/8 minut | es ago | | | |
| WTO AUTHORIZATION: | Iperviso | or | | _ DATE/1 | TIME <u>Toda</u> | ay/2 minut | tes ago | | | |
| SPECIAL INSTRUCTIONS: | YES: | \boxtimes | NO: | (IF | YES SEE | E ATTACH | MENT 14 | 4 PART 2) | | |
| EQUIP. TAG/EQUIPMENT NAME | SEQ | TAG TYPE | POSITION | HUNG BY | VERIF. BY | SFTY. VERIF. | RTS SEQ | RTS POSITION | RTS BY | VERIF. BY |
| 1FW01PA C/S FW PUMP 1A C/S (1PM04J) | 1 | CD | PTL | | N/A | | 5 | NAT | | N/A |
| 1FW01PA-B C/S FW PUMP 1A AUX OIL PUMP C/S (1PM04J) | 1 | CD | PTL | | N/A | | 4 | NAT | | N/A |
| 1FW002A C/S FW PUMP 1A DISCH VALVE C/S (1PM04J) | 2 | CD | NAC | | N/A | | 3 | NAO | | N/A |
| 1FW012A C/S FW PUMP 1A RECIRC VALVE C/S (1PM04J) | 2 | CI | INFO | | N/A | | 3 | CLOSED | | N/A |
| 1FW01PA BKR FW PUMP 1A BKR (BUS 156 CUB 4) | 3 | RD | R/O | | N/A | | 2 | R/TEST | | N/A |
| 1FW01PA-B BKR FW PUMP 1A AUX OIL PUMP BKR (134Z2 CUB F1) | 3 | RD | OFF | | N/A | | 2 | ON | | N/A |
| 1FW01PA-A BKR FW PP 1A MOTOR HTR BKR (134Z2 G4) | 3 | RD | OFF | | N/A | | 2 | ON | | N/A |
| 1FW002A BKR FW PUMP 1A DSCH VLV BKR (133Z2 G3) | 3 | RD | OFF | | N/A | | 2 | ON | | N/A |
| 1FW027A FW PUMP 1A RECIRC VALVE MANUAL ISOL VLV (401 K-11 +20') | 4 | RD | CLOSED | | N/A | | 1 | OPEN | | N/A |
| WTO PLACED: | | | | | | | DATE/TI | ME: | | |
| WTL COMPLETED WORK START: DATE/TIME: | | | | | | | | | | |

WTO FINAL CLEAR: WORK CREWMEMBER RELEASE: _____ DATE/TIME: _____

WTO CLEARED: ____

(COPIES MAY BE MADE OF THIS FORM FOR ADDITIONAL ISOLATION POINTS)

_____ DATE/TIME: _____

TASK TITLE:Initiate a LCOAR for 1A SI PumpJPM No.:S-201Task No.:S-AM-073

Objective No.: 8E.AM-120

EXAMINEE:

EVALUATOR: _____

The Examinee: PASSED _____ this JPM. FAILED _____

CRITICAL ELEMENTS: (*) 3, 5, 6 CRITICAL TIME: NA EVALUATION METHOD:

> X PERFORM SIMULATE

REV: 20070301 K/A No.: 2.2.23 K/A IMP: 3.8

SRO

DATE:_____

TIME STARTED: _____ TIME FINISHED: _____ JPM TIME: _____ MINUTES APPROX COMPLETION TIME: 10 MINUTES

LOCATION:

__ IN PLANT

X SIMULATOR

GENERAL REFERENCES:

1. 1BwOL 3.5.2, LCOAR – ECCS OPERATING, Rev 5.

2. 1BwVSR 5.5.8.SI.1, ASME SURVEILLANCE REQUIREMENTS FOR THE 1A SI PUMP, Rev. 5. MATERIALS:

1. Copy of 1BwOL 3.5.2, Rev 5.

2. Completed copy of 1BwVSR 5.5.8.SI.1, Rev. 5.

- TASK STANDARDS:
 - 1. Perform safety function determination for 1A SI pump inoperability.
 - 2. Initiate LCOAR for 1A SI pump inoperability.

TASK CONDITIONS:

- 1. You are the Unit 1 Unit Supervisor.
- 2. Both units at power.
- The Engineering staff has notified you that the 1A SI pump has failed surveillance 1BwVSR 5.5.8.SI.1, ASME SURVEILLANCE REQUIREMENTS FOR THE 1A SI PUMP, 10 minutes ago due to high pump vibration.
- 4. IR # 123456 has been written.
- 5. No other inoperable equipment exists on either Unit.

INITIATING CUES:

1. The Shift Manager (Jon Doe) directs you to initiate 1BwOL 3.5.2, LCOAR – ECCS OPERATING, for the 1A SI Pump.

CUE: Hand examinee copy of 1BwOL 3.5.2.

2. Inform the Shift Manager when you have initiated 1BwOL 3.5.2.

RECORD START TIME:

| | PERFORMANCE STEP | STANDARD | CIRCLE APPLICABLE |
|-----|---|---|-----------------------------------|
| 1. | Refer to 1BwOL 3.5.2 NOTE: If examinee requests to review 1BwVSR 5.5.8.SI.1, provide the attached copy. | Refer to 1BwOL 3.5.2 | SAT UNSAT N/A <u>Comments:</u> |
| | EVALUATOR NOTE: JPM steps 2 | – 4 can be performed in any or | der. |
| 2. | Enter present mode and initiating event in Section A of 1BwOL 3.5.2: | Enter present mode and initiating event in Section A of 1BwOL 3.5.2: Present Mode: <u>1</u> Initiating Event: <u>Failure of 1BwVSR 5.5.8.SI.1 due to high pump vibrations.</u> | SAT UNSAT N/A <u>Comments:</u> |
| *3. | Perform Safety Function Determination (step B.1) | Refer to Loss of Safety Function (LOSF) Evaluation, step B.1 (page 2): Determine NO support system or supported system on Train B ECCS is inoperable (from initiating cue) Check box <u>1A</u>: No – No LOSF exists. On page 1, perform the following: SAFETY FUNCTION DETERMINATION PERFORMED? <u>YES</u>. Initial next to YES box. DOES THIS INOPERABILITY INVALIDATE ANY PREVIOUS SFD? <u>NO</u> | SAT UNSAT N/A <u>Comments:</u> |

| | PERFORMANCE STEP | STANDARD | CIRCLE APPLICABLE |
|-----|--|--|-----------------------------------|
| 4. | Complete section A, Notification of 1BwOL 3.5.2 NOTE: Underlined phrases or words to that effect are acceptable. CUE: If examinee asks, curre Shift Manager is Jon Doe. CUE: If examinee asks, a clearance order is beir prepared, but has not been completed yet. CUE: Sign NSO signature as Joe Operator | Complete Section A. Notification, of 1BwOL 3.5.2: Name of Shift Manager notified: Jon Doe Time Date: (notification time and today's date) Was an IR written: Yes, 123456 Related WRs: None Related C/O(s): No SRO Signature: Examinee's signature) Unit NSO signature: (Unit NSO name signed by examiner) | SAT UNSAT N/A <u>Comments:</u> |
| *5. | Complete LCOAR Index ECCS Operating | On page 5 of 1BwOL 3.5.2, sign and date Condition A line and refer to page 6: Examinee's signature Today's date | SAT UNSAT N/A <u>Comments:</u> |
| *6. | Initiate LCOAR 1BwOL 3.5.2 CUE: If asked, another SRO will enter this LCOAR entry into the LCOAR data base. | On page 6 of 1BwOL 3.5.2, enter time, date and signature in Condition column: 10 minutes ago time Today's date Examinee's signature | SAT UNSAT N/A <u>Comments:</u> |

RECORD STOP TIME: _____

SIMULATOR SETUP INSTRUCTIONS

- Verify/perform TQ-BR-201-0113, BRAIDWOOD TRAINING DEPARTMENT SIMULATOR EXAMINATION SECURITY ACTIONS CHECKLIST.
- Establish the conditions of IC-21, BOL 100% Power, Steady State, Equilibrium Xenon.
- Complete items on Simulator Ready for Training Checklist.
- Place simulator in RUN.
- Verify 1A SI pump not running.

JOB PERFORMANCE MEASURE

TASK CONDITIONS:

- 1. You are the Unit 1 Unit Supervisor.
- 2. Both units are at power.
- The Engineering staff has notified you that the 1A SI pump has failed surveillance 1BwVSR 5.5.8.SI.1, ASME SURVEILLANCE REQUIREMENTS FOR THE 1A SI PUMP, <u>10 minutes ago</u> due to high pump vibration.
- 4. IR # 123456 has been written.
- 5. No other inoperable equipment exists on either Unit.

- 1. The Shift Manager (Jon Doe) directs you to initiate 1BwOL 3.5.2, LCOAR ECCS OPERATING, for the 1A SI Pump.
- 2. Inform the Shift Manager when you have initiated 1BwOL 3.5.2.

TASK TITLE:Determine Radiological Conditions and Entry Requirements for 1A RH Hx RoomJPM Number:R-303Rev.20070301

Task No.: R-HP-001 Objective No.: 4E.HP-01

EXAMINEE:

EVALUATOR: _____

The Examinee: PASSED _____ this JPM. FAILED _____

Critical Elements: (*) 2, 3, 4, 5 Critical Time: N/A

EVALUATION METHOD:

X PERFORM SIMULATE Rev.20070301K/A No.:2.3.10K/A Imp.:2.9/3.3

RO SRO (Circle One)

DATE:_____

TIME STARTED: _____ TIME FINISHED: _____ JPM TIME: _____ MINUTES Approx. Completion Time: 15 MINUTES

LOCATION:

__ IN PLANT

X_SIMULATOR

GENERAL REFERENCES:

- 1. A-364-3-D, Unit 1 1A RH HX Room Survey Map
- 2. RP-AA-300, RADIOLOGICAL SURVEY PROGRAM, Rev. 2.
- 3. RP-AA-376, RADIOLOGICAL POSTINGS, LABELING, AND MARKINGS, Rev. 2.
- 4. RP-AA-460, CONTROLS FOR HIGH AND VERY HIGH RADIATION AREAS, Rev. 12.

MATERIALS:

- 1. Copy of A-364-3-D, Unit 1 1A RH HX Room Survey Map.
- 2. Copy of RP-AA-460, CONTROLS FOR HIGH AND VERY HIGH RADIATION AREAS, Rev. 12.

TASK STANDARDS:

- 1. Determine dose rates for 1A RH HX Room.
- 2. Determine required briefing prior to entering 1A RH HX Room.

TASK CONDITIONS:

- 1. Unit 1 is in Mode 5.
- 2. You are the Unit 1 Assist NSO.
- 3. You have been directed to access the 1A RH HX Room to check the position of the Instrument Air Isolation Valve for 1RH606, 1A RH HX Flow Control Valve.
- 4. You have previously reviewed and signed the applicable RWP(s) for access to the 1A RH HX Room.

5. Your have previously acquired the required dosimetry for access to the 1A RH HX Room.

- 1. Using the attached survey map of the 1A RH HX Room, determine the following for the 1A RH HX Room:
 - a. Highest dose rate on contact from accessible radiation sources.
 - b. Highest dose rate at 30 cm from accessible radiation sources.
 - c. Highest general area dose rate.
 - d. RP briefing (if any) required for room entry.

| | PERFORMANCE STEP | STANDARD | CIRCLE APPLICABLE |
|-----|---|---|--|
| | EVALUATOR NOTE: The examine | ee may perform the following JF | PM steps in any order. |
| | EVALUATOR NOTE: If examinee performance of JPM, provide exam. 1. RP-AA-300, RADIOLOGICAL 2. RP-AA-376, RADIOLOGICAL 3. RP-AA-460, CONTROLS FOR | request copy of the procedures minee with applicable attached SURVEY PROGRAM POSTINGS, LABELING, AND M/ HIGH AND VERY HIGH RADIAT | i listed below during copy. ARKINGS TON AREAS |
| 1. | Refer to Survey Map A-364-3-D. CUE: Provide examinee attached copies of RP- AA-460 and 1A RH HX Survey Map. | Refer to Survey Map A-364-3- D. | SAT UNSAT N/A <u>Comments:</u> |
| *2. | Determine highest dose rate on contact from accessible radiation sources. | Perform the following: Review Survey Map A-364- 3-D. Determine highest dose rate on contact from accessible radiation sources to be 170 mrem/hr (on 1A RH HX) | SAT UNSAT N/A <u>Comments:</u> |
| *3 | Determine highest dose rate at 30 cm from accessible radiation sources. | Perform the following: Review Survey Map A-364- 3-D. Determine highest dose rate at 30 cm from accessible radiation sources to be 90 mrem/hr (on 1A RH HX) | SAT UNSAT N/A <u>Comments:</u> |
| *4 | Determine highest general area dose rate. | Perform the following: Review Survey Map A-364- 3-D. Determine highest general area dose rate to be 80 mrem/hr. | SAT UNSAT N/A <u>Comments:</u> |

| | PERFORMANCE STEP | STANDARD | CIRCLE APPLICABLE |
|-----|-----------------------------------|---|-------------------|
| *5. | Determine High Rad Area RP | Perform the following: | SAT UNSAT N/A |
| | Briefing required for room entry. | Review Survey Map A-364- 3-D. | Comments: |
| | | Determine High Rad Area RP Briefing required for room entry from posting noted at room entrance (A with square around it. | |

RECORD STOP TIME: _____

JOB PERFORMANCE MEASURE

TASK CONDITIONS:

- 1. Unit 1 is in Mode 5.
- 2. You are the Unit 1 Assist NSO.
- 3. You have been directed to access the 1A RH HX Room to check the position of the Instrument Air Isolation Valve for 1RH606, 1A RH HX Flow Control Valve.
- 4. You have previously reviewed and signed the applicable RWP(s) for access to the 1A RH HX Room.
- 5. Your have previously acquired the required dosimetry for access to the 1A RH HX Room.

- 2. Using the attached survey map of the 1A RH HX Room, determine the following for the 1A RH HX Room:
 - a. Highest dose rate on contact from accessible radiation sources.
 - b. Highest dose rate at 30 cm from accessible radiation sources.
 - c. Highest general area dose rate.
 - d. RP briefing (if any) required for room entry.

TASK TITLE: Prepare and Approve Nuclear Accident Reporting System Form

| JPM No.: | S-400 |
|-----------|----------|
| Task No.: | S-ZP-001 |

Objective No.: 8F.ZP-001

EXAMINEE:

EVALUATOR: _____

The Examinee: PASSED _____ this JPM. FAILED _____

CRITICAL ELEMENTS:(*) 3, 5, 6, 8CRITICAL TIME:15 minutes.EVALUATION METHOD:

X PERFORM SIMULATE

| DATE: | | |
|-------|--|--|

TIME STARTED: _____ TIME FINISHED:_____ JPM TIME:_____ MINUTES APPROX COMPLETION TIME: 13 MINUTES

20070301

2.4.40

2.3/4.0

LOCATION:

REV:

SRO

K/A No.:

K/A IMP:

IN PLANT

X SIMULATOR

GENERAL REFERENCES:

- 1. EP-MW-114-100, MIDWEST REGION OFFSITE NOTIFICATIONS, Rev. 5
- 2. EP-MW-114-100-F-01, NUCLEAR ACCIDENT REPORTING SYSTEM (NARS) FORM, Rev. B.
- 3. EP-AA-114-F-01, Rev. B, RELEASE IN PROGRESS DETERMINATION GUIDE.

MATERIALS:

- 1. Copy of EP-MW-114-100, Rev. 5.
- 2. Copy of EP-MW-114-100-F-01, Rev. B.
- 3. Copy of EP-AA-114-F-01, Rev. B.

TASK STANDARDS:

- 1. Correctly determine Unit 1 release status.
- 2. Correctly complete NARS Form.
- 3. Approve NARS Form for transmittal within 15 minutes.

TASK CONDITIONS:

1. This is a Time Critical JPM.

- 2. You are the Shift Emergency Director.
- 3. A 600 gpm tube rupture has occurred on the 1A SG.
- 4. Three safety valves are stuck open on 1A SG.
- 5. 1BwEP-0, REACTOR TRIP OR SAFETY INJECTION, is in progress at step 20.
- 6. The accident in progress has just been classified as a Site Area Emergency, FS1, due to a loss of the RCS and Containment fission product barriers. (Assume classification time is start time of JPM).

INITIATING CUES:

1. The Emergency Plan requires that you <u>PREPARE AND APPROVE</u> the <u>INITIAL</u> Nuclear Accident Reporting System (NARS) Form for transmittal in accordance with EP-MW-114-100, MIDWEST REGION OFFSITE NOTIFICATIONS.

CUE: Hand examinee copy of EP-MW-114-100 and EP-MW-114-100-F-01.

- 2. Another operations person will transmit the NARS form once it is prepared and approved.
- 3. Hand the NARS Form to your evaluator once you have prepared and approved the NARS Form.

| | PERFORMANCE STEP | STANDARD | CIRCLE APPLICABLE |
|-----|---|--|-----------------------------------|
| 1. | Refer to EP-MW-114-100. NOTE: JPM page 7 contains a key of a correctly completed NARS form. NOTE: Critical Time begins when examinee understands initiating cue and accepts responsibility for task performance. Record critical time start time: | Refer to EP-MW-114-100. | SAT UNSAT N/A <u>Comments:</u> |
| 2. | Complete blocks 1 & 2:. | Complete blocks 1 & 2 by entering the information in bold font below: UTILITY MESSAGE NO.: 1 STATE MESSAGE NO. N/A STATUS: [1B] DRILL/EXERCISE STATION: [2A] BRAIDWOOD | SAT UNSAT N/A <u>Comments:</u> |
| *3. | Complete blocks 3 & 4: | Complete blocks 3 & 4 by checking the boxes and entering the information in bold font below: • ONSITE CONDITION: [3C] SITE AREA EMERGENCY • ACCIDENT CLASSIFIED: • TIME: JPM start time • DATE: Today's Date. • EAL#: FS1. • ACCIDENT TERMINATED: Time and Date: N/A. | SAT UNSAT N/A <u>Comments:</u> |

| | PERFORMANCE STEP | STANDARD | CIRCLE APPLICABLE |
|-----|---|--|--|
| *5. | Complete blocks 5 & 6: CUE: If asked, provide attached copy of EP-AA- 114-F-01, RELEASE IN PROGRESS DETERMINATION GUIDE. | Complete blocks 5 & 6 by performing the following: Determine release is occurring. Refer to EP-AA-114-F-01, RELEASE IN PROGRESS DETERMINATION GUIDE. SGTR w/open MS safety valves is release path. Check the boxes in bold font below: RELEASE STATUS: [5B] OCCURRING. TYPE OF RELEASE: [6B] GASEOUS | SAT UNSAT N/A <u>Comments:</u> |
| | EVALUATOR NOTE: When record wind speed in miles per hour, met correctly entered. | ding wind speed in the next step ters per second, or both. At lea | o, the examinee may enter st one wind speed must be |
| *6. | Complete blocks 7 & 8: | Complete blocks 7 & 8 by performing the following: Record actual data from PPDS or 0PM01J: Enter the information in bold font below WIND DIRECTION: 270 ± 30 WIND SPEED: [8A] 4.5 m/s ± 2 m/s. AND/OR [8B] 10 mph ± 5 mph | SAT UNSAT N/A <u>Comments:</u> |
| 7. | Complete blocks 9 & 10: | Complete blocks 3 & 4 by checking the boxes and entering the information in bold font below: • RECOMMENDED ACTIONS: [9A] NONE • ADDITIONAL INFORMATION: None | SAT UNSAT N/A <u>Comments:</u> |

| | PERFORMANCE STEP | STANDARD | | | CIRCLE APPLICABLE | | |
|-----|--|----------|--|--------------|-------------------|-----|--|
| *8. | Approve the NARS Form: | | Approve the NARS Form | SAT | UNSAT | N/A | |
| | NOTE: If examinee asks for verification of NARS form. | | following: | <u>Com</u> ı | <u>ments:</u> | | |
| | provide the following cue: | | Obtain verification | | | | |
| | CUE: Verification has been provided by SRO Jon Doe. | | Sign the Approved by line. | | | | |
| | NOTE: Critical Time ends when | | | | | | |
| | examinee approves NARS form and hand it to | | | | | | |
| | the evaluator for | | | | | | |
| | transmittal. | | | | | | |
| | Record critical time stop time: | | | | | | |
| | | | | | | | |
| | | | | | | | |
| | | | | | | | |
| | | | | | | | |
| | (end time) (start time) | | | | | | |
| | | | | | | | |
| | ≤ 15 minutes. | | | | | | |

RECORD STOP TIME:

SIMULATOR SETUP INSTRUCTIONS

- Verify/perform TQ-BR-201-0113, BRAIDWOOD TRAINING DEPARTMENT SIMULATOR EXAMINATION SECURITY ACTIONS CHECKLIST.
- Establish the conditions of IC 21, 100% power, steady state, equilibrium xenon.
 OR -
- Other IC if being performed concurrently with other JPMs. (JPM is not IC dependent)
- Complete items on Simulator Ready for Training Checklist.
- Place simulator in RUN.
- Insert the following remote functions to set wind direction at 270 degrees, and the wind speed at 10 mph:
 - Insert IRF EP03 10 to set 34' wind speed to 10 mph
 - Insert IRF **EP04 270** to set 34' wind direction to 270 degrees
 - Insert IRF EP11 12 to set 204' wind speed to 12 mph
 - Insert IRF EP12 272 to set 204' wind direction to 272 degrees

TASK CONDITIONS:

- 1. This is a Time Critical JPM.
- 2. You are the Shift Emergency Director.
- 3. A 600 gpm tube rupture has occurred on the 1A SG
- 4. Three safety valves are stuck open on 1A SG.
- 5. 1BwEP-0, REACTOR TRIP OR SAFETY INJECTION, is in progress at step 20.
- 6. The accident in progress has just been classified as a Site Area Emergency, FS1, due to a loss of the RCS and Containment fission product barriers. (Assume classification time is start time of JPM).

- 1. The Emergency Plan requires that you <u>PREPARE AND APPROVE</u> the <u>INITIAL</u> Nuclear Accident Reporting System (NARS) Form for transmittal in accordance with EP-MW-114-100, MIDWEST REGION OFFSITE NOTIFICATIONS.
- 2. Another operations person will transmit the NARS form once it is prepared and approved.
- 3. Hand the NARS Form to your evaluator once you have prepared and approved the NARS Form.

| | KEY – DO NOT GIVE TO EXAMINEE |
|-----|--|
| UTI | LITY MESSAGE NO. <u>1</u> STATE MESSAGE NO. <u>N/A</u> |
| 1. | <u>STATUS</u> 2. <u>STATION</u> |
| | [A] ACTUAL [X] BRAIDWOOD [C] CLINTON [E] LASALLE [G] ZION |
| | [X] DRILL/EXERCISE [B] BYRON [D] DRESDEN [F] QUAD CITIES |
| 3. | ONSITE CONDITION 4. ACCIDENT CLASSIFIED ACCIDENT TERMINATED |
| | [A] UNUSUAL EVENT TIME (3[A-E]): <u>JPM start time</u> TIME (3[F]): <u>N/A</u> |
| | [B] ALERI DATE (3[A-E]): <u>Today</u> DATE (3[F]): <u>N/A</u> |
| | [A] SHE AREA EMERGENCY EAL#: <u>FS1</u> |
| | IEI RECOVERY |
| | [F] TERMINATED |
| 5. | RELEASE STATUS 6. TYPE OF RELEASE 7. WIND DIR 8. WIND SPEED |
| | [A] NONE \leftarrow [A] NOT APPLICABLE 270 ± 30 [X] METERS/SEC.: 4.5 ± 2 |
| | [X] OCCURRING \leftarrow [X] GASEOUS (DEGREES FROM) [X] MILES/HR.: 10 ± 5 |
| _ | [C] TERMINATED ← ↓ → [C] LIQUID |
| 9. | RECOMMENDED ACTIONS |
| | UTILITY RECOMMENDATION |
| | (GE Only) |
| | [B] SHELTER ILLINOIS SUB-AREAS: |
| | AND ADVISE REMAINDER OF THE EPZ TO MONITOR LOCAL RADIO STATIONS |
| | [C] SHELTER IOWA SUB-AREAS: |
| | IDI EVACUATE ILLINOIS SUB-AREAS: |
| | AND ADVISE REMAINDER OF THE EPZ TO MONITOR LOCAL RADIO STATIONS |
| | [E] EVACUATE IOWA SUB-AREAS: |
| | AND ADVISE REMAINDER OF THE EPZ TO MONITOR LOCAL RADIO STATIONS |
| | STATE RECOMMENDATION |
| | |
| | [G] SHELLER SUB-AREAS. |
| | III RECOMMEND POTASSIUM IODIDE (KI) PER PROCEDURES |
| | [J] COMMENCE RETURN OF PUBLIC |
| | [K] OTHER |
| 10. | ADDITIONAL INFORMATION <u>"NONE"</u> |

| Verified With: Jon Doe | | | Approved By: Candida | tes Signature |
|------------------------|------------|-------------------------------------|-----------------------------|---------------|
| 11. | | TRANSMITTED BY: <u>TIME/DATE</u> | NAME | PHONE NUMBER |
| [A | A] EXELON: | | | |
| [B | B] STATE: | | | |
| [C | COUNTY: | | | |
| 12. | F | RECEIVED BY: <u>TIME/DATE</u> | <u>NAME</u> | ORGANIZATION |

KEY – DO NOT GIVE TO EXAMINEE