

Ngola Otto

From: Ngola Otto
Sent: Thursday, May 15, 2008 9:16 AM
To: 'us-apwr-rai@mhi.co.jp'
Subject: US-APWR DCD Draft RAI Number 138
Attachments: RAI 138_Draft.doc

Please see draft RAI # 138 attached.

Thank you

Ngola Otto
New Reactor Licensing
U.S. Nuclear Regulatory Commission
11555 Rockville Pike
Rockville, MD 20852-2739
301.415.6695
ngola.otto@nrc.gov

Request for Additional Information No. 138 Revision 0

US-APWR Design Certification

Mitsubishi Heavy Industries

Docket No. 52-021

SRP Section: 14.02 - Initial Plant Test Program - Design Certification and New License Applicants

Application Section: 14.2 Initial Plant Test Program

QUESTIONS

14.02-***

The following information in the application needs to be revised: 1. The issue date of RG 1.68.2, Revision 1, listed in Table 14.2-2 of Tier 2 of the DCD should be 07/1978, not April, 1978. 2. The issue date of RG 1.206 listed in Table 14.2-2 of Tier 2 of the DCD should be 06/2007, not May 2007. 3. The title of RG 1.9, Revision 4, listed in Table 14.2-2 of Tier 2 of the DCD should be "Application and Testing of Safety-Related Diesel Generators in Nuclear Power Plants," not "Selection, Design, and Qualification of Diesel-Generator Units Used as Onsite Electric Power Systems at Nuclear Power Plants." 4. Table 14.2-2 of Tier 2 of the DCD lists Revision 1 of RG 1.37, "Quality Assurance Requirements for Cleaning of Fluid Systems and Associated Components of Water-Cooled Nuclear Power Plants." However, Table 1.9.1-1 of the DCD notes that the RG is "Not Applicable." "RG applies to a site-specific operational program."