

SAFETY INSPECTION REPORT AND COMPLIANCE INSPECTION

1. LICENSEE/LOCATION INSPECTED: <i>HARRISON POWER STATION P.O. Box 600 HAYWOOD, NV 26366</i>		2. NRC/REGIONAL OFFICE U.S. Nuclear Regulatory Commission Region I, 475 Allendale Road King of Prussia, Pennsylvania 19406-1415	
REPORT Nos <i>2008-001</i>			
3. DOCKET NUMBER(S) <i>030-33129</i>	4. LICENSE NUMBER(S) <i>47-25244-D</i>	5. DATE(S) OF INSPECTION <i>MARCH 20, 2008</i>	

LICENSEE:

The inspection was an examination of the activities conducted under your license as they relate to radiation safety and to compliance with the Nuclear Regulatory Commission (NRC) rules and regulations and the conditions of your license. The inspection consisted of selective examinations of procedures and representative records, interviews with personnel, and observations by the inspector. The inspection findings are as follows:

- 1. Based on the inspection findings, no violations were identified.
- 2. Previous violation(s) closed.
- 3. The violation(s), specifically described to you by the inspector as non-cited violations, are not being cited because they were self-identified, non-repetitive, and corrective action was or is being taken, and the remaining criteria in the NRC Enforcement Policy, NUREG-1600, to exercise discretion, were satisfied.
- Non-Cited Violation(s) was/were discussed involving the following requirement(s) and Corrective Action(s):

- 4. During this inspection certain of your activities, as described below and/or attached, were in violation of NRC requirements and are being cited. This form is a NOTICE OF VIOLATION, which may be subject to posting in accordance with 10 CFR 19.11.
 - 1. FAILURE TO CONDUCT AN ANNUAL REVIEW OF THE RADIATION SAFETY PROGRAM AS REQUIRED BY 10CFR 20.1101(c)*
 - 2. FAILURE TO CONDUCT LEAK TESTS OF THE DEVICES AT INTERVAL AS SPECIFIED BY LICENSE CONDITION 13.A. LAST TESTS WERE DONE 05-20-02*

Both items will be corrected within thirty (30) days. WJG/leson

Licensee's Statement of Corrective Actions for Item 4, above.

I hereby state that, within 30 days, the actions described by me to the inspector will be taken to correct the violations identified. This statement of corrective actions is made in accordance with the requirements of 10 CFR 2.201 (corrective steps already taken, corrective steps which will be taken, date when full compliance will be achieved). I understand that no further written response to NRC will be required, unless specifically requested.

Title	Printed Name	Signature	Date
LICENSEE'S REPRESENTATIVE	<i>William J Glessner Manager Engineering</i>	<i>William J Glessner</i>	<i>3/20/08</i>
NRC INSPECTOR	<i>RICHARD H. LADON</i>	<i>Richard H. Ladon</i>	<i>03-20-08</i>

SUNSI Review Completed By: *IRA/R. H. LADON*

Public

Non-Sensitive