

Official Transcript of Proceedings
NUCLEAR REGULATORY COMMISSION

Title: Advisory Committee on Reactor Safeguards
Plant License Renewal Subcommittee

Docket Number: (n/a)

PROCESS USING ADAMS
TEMPLATE: ACRS/ACNW-005
SUNSI REVIEW COMPLETE

Location: Rockville, Maryland

Date: Wednesday, May 7, 2008

Work Order No.: NRC-2184

Pages 1-145

NEAL R. GROSS AND CO., INC.
Court Reporters and Transcribers
1323 Rhode Island Avenue, N.W.
Washington, D.C. 20005
(202) 234-4433

RECEIVED
MAY 15 2008

TRO4

DISCLAIMER

UNITED STATES NUCLEAR REGULATORY COMMISSION'S
ADVISORY COMMITTEE ON REACTOR SAFEGUARDS

May 7, 2008

The contents of this transcript of the proceeding of the United States Nuclear Regulatory Commission Advisory Committee on Reactor Safeguards, taken on May 7, 2008, as reported herein, is a record of the discussions recorded at the meeting held on the above date.

This transcript has not been reviewed, corrected and edited and it may contain inaccuracies.

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25
26
27

UNITED STATES OF AMERICA
NUCLEAR REGULATORY COMMISSION

+ + + + +

ADVISORY COMMITTEE ON REACTOR SAFEGUARDS
(ACRS)

+ + + + +

SUBCOMMITTEE ON PLANT LICENSE RENEWAL

+ + + + +

WEDNESDAY

MAY 7, 2008

+ + + + +

ROCKVILLE, MARYLAND

+ + + + +

The Subcommittee met at the Nuclear Regulatory Commission, Two White Flint North, Room T2B3, 11545 Rockville Pike, at 10:30 a.m., Dr. John Stetkar, Chairman, presiding.

COMMITTEE MEMBERS:

- JOHN STETKAR, Chairman
- MARIO V. BONACA, Member
- WILLIAM J. SHACK, Member
- JOHN D. SIEBER, Member
- OTTO L. MAYNARD, Member
- SAID ABDEL-KHALIK, Member

CONSULTANTS TO THE SUBCOMMITTEE:

- JOHN J. BARTON

NEAL R. GROSS
COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 NRC STAFF PRESENT:

2 PETER WEN, Cognizant Staff Engineer

3 SAMSON LEE

4 LOUISE LUND

5 CAUDLE JULIAN

6 ROBERT HSU

7 KEN CHANG

8 ALSO PRESENT:

9 CHRIS BURTON

10 JOHN CAVES

11 ROGER STEWART

12 CHRIS MALLNER

13 BOB REYNOLDS

14 MIKE HEATH

15 MIKE FLETCHER

16

17

18

19

20

21

22

23

24

25

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

TABLE OF CONTENTS

1	2	PAGE
	<u>AGENDA ITEM/TOPIC:</u>	
3	Opening Remarks	4
4	J. Stetkar, ACRS	
5	Staff Introductions	5
6	Dr. Samson Lee, NRR	
7	CP&L - HNP Renewal Application	
8	Introductions	6
9	Operating History/Background	7
10	Improvements	10
11	Scoping Discussion	19
12	Application of GALL	20
13	Commitment Process	25
14	Unresolved Issues/Open Item	26
15	Confirmatory Items	31
16	Question/Answer period	34
17	Lunch Break	79
18	Continued Question/Answer period	79
19	NRC Staff Presentation SER Overview	
20	Introductions/Overview	99
21	Scoping and Screening Results	101
22	Onsite Inspection Results	119
23	NRC Audit (AMP and AMR)	135
24	Time Limited Aging Analyses	141
25	Subcommittee Discussion	158

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
 1323 RHODE ISLAND AVE., N.W.
 WASHINGTON, D.C. 20005-3701

P-R-O-C-E-E-D-N-G-S

(10:29 a.m.)

1
2
3 CHAIR STETKAR: The meeting will not come
4 to order. This is a meeting of the Plant License
5 Renewal Subcommittee. My name is John Stetkar. I'm
6 Chairman of the Shearon Harris Plant License Renewal
7 Subcommittee. ACRS Members in attendance are Otto
8 Maynard, Jack Sieber, Bill Shack, Mario Bonaca, Said
9 Abdel-Khalik, and our consultant, John Barton.

10 Peter Wen of the ACRS staff is the
11 cognizant staff engineer for this meeting.

12 The purpose of this meeting is to review
13 the license renewal application for the Shearon Harris
14 Nuclear Plant, the Draft Safety Evaluation Report and
15 associated documents. We will hear presentations from
16 representatives of the Office of Nuclear Reactor
17 Regulation and the applicant, Carolina Power & Light.
18 The Subcommittee will gather information, analyze
19 relevant issues and facts, and formulate proposed
20 positions and actions as appropriate for deliberation
21 by the full committee.

22 The rules for participation in today's
23 meeting were announced as part of the notice of this
24 meeting previously published in the Federal Register
25 on April 15th, 2008. We have received no written

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 comments or requests for time to make oral statements
2 from members of the public regarding today's meeting.

3 A transcript of the meeting is being kept
4 and will be made available as stated in the Federal
5 Register notice. Therefore, we request that
6 participants in this meeting use the microphones
7 located throughout the meeting room when addressing
8 the subcommittee. Participants should first identify
9 themselves and speak with sufficient clarity and
10 volume so that they can be readily heard.

11 We'll now proceed with the meeting and I
12 call upon Dr. Sam Lee of the Office of Nuclear Reactor
13 Regulation to introduce the presenters.

14 MR. LEE: Thank you very much. Good
15 morning. This is Samson Lee. I'm the Acting Division
16 Director for the Division of License Renewal NRR, and
17 on my left is Louise Lund. She's the Project Branch
18 Chief. On my right is Maurice Heath. He's the
19 Project Manager for the Shearon Harris Safety
20 Evaluation Report. And I also have Caudle Julian from
21 Region II. He's the Team Leader. He'll be part of
22 the presentation. I have Dr. Ken Chang. He's the
23 Engineering Branch Chief, and he'll be discussing some
24 of the technical details.

25 And also I have other technical staff that

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 are in the audience that can help answer questions.
2 And I would also like to acknowledge Peter Wen, the
3 ACRS staff member who actually coordinated the
4 presentation.

5 And with that, the Applicant, Carolina
6 Power & Light is going to start the presentation. And
7 Chris Burton, the Director of Site Operations, you can
8 start.

9 MR. BURTON: Thank you. Good morning. My
10 name is Chris Burton. I'm the Director of Site
11 Operations at the Shearon Harris site. It's a
12 pleasure to be hear this morning. With me this
13 morning are four members of the team that have
14 association with this license renewal application --
15 Christ Mallner, part of the license renewal team and
16 the mechanical engineering portion, Roger Stewart
17 who's the manager for our fleet of license renewal
18 overall, John Caves who's a member of my staff at the
19 Harris site and technical services in the engineering
20 group -- present to you this morning. We have several
21 additional people that are available to answer
22 questions if possible, if we're not able to.

23 This morning Mr. Stewart and I primarily
24 will present information on plant background, a short
25 description of the site, some of the improvements that

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 have been made over the course of the first 20 years
2 of operation of the Harris unit, the scoping of
3 license renewal, generic aging, lessons learned,
4 discussion, commitments associated with our
5 application, open item discussion and then any
6 confirmatory items.

7 In 1971, Carolina Power & Light, now known
8 as Progress Energy, announced plans for construction
9 of the Harris units. In 1978, a construction permit
10 was issued. In 1986, the license was issued and in
11 May 1987, commercial operation began, or October 2026
12 will be the expiration date for the current license
13 for the Shearon Harris unit.

14 Just a little bit about the Harris site
15 and the reactor design. The NSSS is a Westinghouse 3-
16 PWR. The architect engineer is EBASCO, 990 megawatts
17 electrical, 2900 megawatts thermal. We operate on an
18 18-month refueling cycle, have a large site area
19 encompassing a large lake, a cooling lake, and we use
20 a cooling tower and that lake for our ultimate heat
21 sink.

22 Just a note about the ownership of the
23 output of the unit. Progress Energy or Carolina Power
24 & Light owns 84 percent of the output. We do have a
25 co-owner. North Carolina Eastern Municipal Power

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 Agency owns 16 percent of our output and participate
2 pretty actively in reviews of our performance and our
3 daily operations.

4 MR. BARTON: Construction management was
5 who? Was it also a EBASCO?

6 MR. BURTON: Yes, sir. Is that correct,
7 Roger?

8 MR. STEWART: No. It was -- excuse me.
9 I apologize -- Daniels.

10 MR. BARTON: Okay.

11 MR. STEWART: Actually, at the time
12 Carolina Power & Light did the construction
13 management, we had the construction management team
14 and Daniels was the --

15 MR. BARTON: Was the contractor?

16 MR. STEWART: Yes, sir.

17 MR. BARTON: Got you. Okay. Thank you.

18 MR. SIEBER: Where is the makeup water for
19 the lake come from?

20 MR. BURTON: It comes from the Cape Fear
21 river. Really, it comes from -- that's how we fill
22 the lake. We now have runoff that comes into the
23 lake.

24 MR. SIEBER: Is runoff enough to keep the
25 lake at operating conditions?

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MR. BURTON: David?

2 MR. COLLETT: I'm Dave Collett from the
3 Harris staff. The lake is fed from creeks,
4 approximately four creeks.

5 MR. SIEBER: Well, the question was is
6 that enough to provide you --

7 MR. BURTON: Yes, it is.

8 MR. SIEBER: -- with normal and emergency
9 operation, or do you have some pump house someplace?

10 MR. BURTON: We also have an auxiliary
11 reservoir that we keep full that's independent and
12 available to use for emergency cooling water. The
13 lake, the rainwater, and the runoff from the creeks is
14 sufficient. As we went through a period of very dry
15 weather last year, we still had sufficient margin in
16 that lake to operate the plant without question. We
17 never tabled at five or six months, capacity-wise, of
18 having to question our ultimate heat sink capability.

19 MR. SIEBER: Do you have tech spec
20 restrictions on the lake condition, like level comfort
21 or --

22 MR. BURTON: Yes, sir, we do.

23 MR. SIEBER: Thank you.

24 MR. BURTON: Okay. Just a little bit
25 about some of the improvements we've made in recent

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealgross.com

1 years. We did replace our steam generators
2 preemptively in 2001. The condition of those steam
3 generators was not such they required replacement, but
4 based on the materials, the tubing, we chose to do it
5 at that time for the long-term health of the plant.
6 At the same time in that outage, we performed a power
7 uprate, a 4.5% power uprate of the Harris Plant and
8 also did a T-ave or a T-hot recovery. Wee had derated
9 our hot light temperature to preserve steam generator
10 tube integrity over the few years prior to the
11 replacement. So we regained some megawatt output in
12 that activity.

13 In the last refueling outage completed in
14 the fall of 2007, we mitigated the pressurizer Alloy
15 600 issue, number of welds on pressurizer spray, code
16 safety lines and the surge line itself, conducted
17 reactor vessel head inspections per MRP 139
18 expectations, and we also enlarged our containment
19 sump capacity approximately 275 square feet to
20 approximately 3,000 square feet of containment sump
21 capability and have completed that work.

22 MEMBER SHACK: Now when you recovered that
23 T-hot, is that going to increase the temperature of
24 your vessel head, too?

25 MR. BURTON: Yes.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MR. SIEBER: Yes, sir, it did.

2 MR. SIEBER: Yes, T-ave went up. Those
3 were model 51 steam generators originally?

4 MR. BURTON: They were D-4s.

5 MR. SIEBER: D's, oh, okay. I understand
6 why you replaced them. And what's in there now?

7 MR. BURTON: D-75s.

8 MR. SIEBER: Okay.

9 MEMBER MAYNARD: On your pressurizer weld
10 overlays, did you do any inspections before the
11 overlay or just do the overlay?

12 MR. BURTON: We went straight to
13 mitigation, sir.

14 Several things I want to share with the
15 Subcommittee on our future improvements I think would
16 be of interest, potentially germane. We are in the
17 midst of a transition to NFPA-805. We are one of the
18 two pilot fleets in doing that along with the Duke
19 fleet, and we are well on our way. We expect to
20 submit a license request to NRC in the next 60 days
21 which will outline what we're going to do in risk
22 space in an NFPA-805 for fire protection.

23 We also have installed a digital control
24 platform for the site, and we have some applications,
25 some nonsafety-related applications already running on

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 that digital control system to improve our
2 familiarity, our maintenance ability with digital
3 controls, and we're certainly watching other people in
4 the industry for the application of additional systems
5 on the digital control platform. So that's a big
6 effort for us as well.

7 And we do have several smaller power
8 uprates on the books for the next couple of outages.
9 We will do the LEFN or the Appendix K, the uncertainty
10 recapture uprate. We'll install some of the equipment
11 in our next outage and then we will go through the
12 actual licensing effort and take advantage of that in
13 a following outage. So we're two cycles away. We
14 will also be upgrading our low pressure and high
15 pressure turbines, rewinding our generator and will be
16 doing some work on our coolant system.

17 So all of those things have some fairly
18 small but still important megawatts regains there.
19 And those are the key items that we're working on from
20 a plant standpoint to continue to make the plant
21 better, more reliable and safer.

22 MR. BARTON: When you add all your
23 uprates, how much total percentage have you added to
24 the plant, originally licensed?

25 MR. BURTON: Including the ones that we

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 conducted in 2001, the one where we did the steam
2 generator replacement and a T-ave or just the ones in
3 the future, sir?

4 MR. BARTON: The one in the future.

5 MR. CAVES: It's about -- we expect about
6 1.6 for the measurement uncertainty uprate, and we
7 still don't have a final answer in terms of how much
8 we're going to be able to get out of the generator
9 rewind.

10 MR. BARTON: Okay.

11 MR. BURTON: It could be anywhere between
12 8 and 20 associated with those turbines non-deadly the
13 rewind, but the uncertainty recapture should be
14 somewhere between 1 and 2% of our rate right now.

15 MR. SIEBER: Also, what's T-hot now?

16 MR. CAVES: I'm not sure about T-hot.
17 Five eighty-eight is the T-cold.

18 MR. COLLETT: I'd have to figure it out,
19 the -- somewhere on the quarter of 620 --

20 MR. SIEBER: Six twenty?

21 MR. COLLETT: -- the full power T-ave is
22 588.8.

23 MR. BURTON: We can get confirmation that
24 and answer that after a break if that's acceptable,
25 sir.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MR. CAVES: I would like to -- one of the
2 things we had talked about earlier -- you had some
3 questions about lake level. You know, since we're
4 talking about future improvements, just for the
5 standpoint of completeness, we have submitted the
6 licensed amendment request to allow another
7 approximately 15 feet of lake level. You know, right
8 now I don't remember the exact number --

9 MR. SIEBER: It's even less feet?

10 MR. COLLETT: Yes, so we can go 15 feet
11 deeper than we are right now.

12 MR. SIEBER: What's that tell me about
13 your water supply?

14 MR. BURTON: Well, as I was talking about
15 before --

16 MR. SIEBER: If you feel you need that?

17 MR. BURTON: Well, as we were going
18 through what we considered to be a regional drought we
19 were within five months of reaching the tech spec
20 required low level in that lake which is, I believe,
21 215 feet, as I recall. And so as a precautionary
22 measure, we looked at all the options including taking
23 the plant offline at the appropriate time to determine
24 how are we going to react if the drought persisted.
25 Now the drought did not persist. The lake is

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 currently full but we pursued taking some of the what
2 we felt was the available calculational basis and
3 examining it and determining, based on our pump
4 suction from that lake, did we have enough margin to
5 have a lower tech spec limit on that lake. And as it
6 worked out, we did. There's significant margin there.

7 MR. SIEBER: And the concern is the MPSH
8 on your --

9 MR. BURTON: Yes, Ohio Emergency Service
10 water pumps. Yes, sir.

11 MEMBER MAYNARD: Is your lake -- do you
12 have like an ultimate heat sink? What's the safety-
13 related part of the lake versus -- is the whole lake
14 safety-related or?

15 MR. CAVES: What we have is we've got the
16 main lake and we've got the main lake and we've got
17 what we call the auxiliary reservoir. Both are
18 required by our current tech specs, and -- but the
19 auxiliary reservoir is the especially safety-related
20 piece.

21 CHAIR STETKAR: What feeds the auxiliary
22 reservoir?

23 MR. CAVES: They're bot fed from same
24 creeks.

25 CHAIR STETKAR: Okay. It's just an

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 overflow something from the main, the auxiliary.

2 MR. STEWART: If you think of it as two
3 impoundments, you've got the main reservoir and the
4 auxiliary reservoir is a separate impoundment.
5 They're both seismic category one water structures,
6 and both required per our licensing basis. But if
7 something would happen to the main reservoir, the aux
8 reservoir is still available.

9 CHAIR STETKAR: ESW return, though, is to
10 the main reservoir through some, if I was reading it
11 correctly, through a torturous path or something like
12 that to enhance cooling?

13 MR. COLLETT: If I may add, the emergency
14 service water returns to the auxiliary reservoir.

15 CHAIR STETKAR: To the auxiliary
16 reservoir.

17 MR. COLLETT: Yes. And the auxiliary
18 reservoir overflows to the main reservoir, so it's
19 possible to keep the auxiliary reservoir by pumping
20 from the main reservoir to the auxiliary reservoir.
21 And I think it's also important to note that the
22 reservoir is full now.

23 MEMBER MAYNARD: Roughly, what's the size
24 of the lake, the reservoir we're looking at here,
25 surface area?

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MR. BURTON: I will get that information
2 for you by right after lunch if that's acceptable?

3 MR. SIEBER: Yes, or acres.

4 MR. BARTON: Three hundred and forty acres
5 or something --

6 MR. BURTON: I'd rather give you exact --

7 MR. SIEBER: It was real big. It was less
8 than a square mile. So the reservoir is receiving the
9 discharge, so that is going to be a lot warmer than
10 the main lake?

11 MR. BURTON: That's only when emergency
12 service water --

13 MR. SIEBER: That's right.

14 MR. BURTON: -- is running.

15 MR. SIEBER: Okay. And that's your
16 ultimate heat sink, too? Okay.

17 MR. BURTON: Okay. At this point, I would
18 introduce Roger Stewart again, our manager of license
19 renewal, to go through some of the rest of the agenda
20 items form our sampling. Roger?

21 MR. STEWART: Good morning. First, we'll
22 talk about scoping. When we did our scoping, our
23 sources of information included the equipment database
24 and from the equipment database, we can get a listing
25 of the systems and the components and the component

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 plant locations that also includes quality class
2 information. We also looked at the FSAR. We looked
3 at our Design Basis Documents. We looked at current
4 licensing information. And we also looked at the
5 maintenance rule database.

6 We did our scoping on a system level, and
7 one of the starting points that we used is we used the
8 component classifications within a system to identify
9 system as something that's potentially in-scope for
10 licensing renewal, so if it had something that looked
11 like it might be an (a)(1) or an (a)(2) or an (a)(3),
12 we through and evaluated that system as potentially
13 being in-scope for license renewal. The way we
14 identified our structures is once we had gone through
15 and identified the systems that were in scope, we
16 looked at the structure to see what they contained and
17 brought those into scope accordingly.

18 Relative to application of generic aging
19 lessons learned, relative to GALL consistency, if you
20 look at standard notes A through D, we were 89%
21 consistent with GALL. As we did our aging management
22 reviews, we relied on 40 aging management programs.
23 Twenty-eight of those were existing programs, 19
24 requiring enhancements. There were 12 new aging
25 management programs credited. We did take exceptions

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 in 14 aging management programs of GALL, and we had
2 one site-specific aging management program. That's
3 oil-filled cable testing program.

4 MEMBER SHACK: Just a question on that.
5 There's a comment in the SCR on your fact program that
6 you had leakage in carbon steel pipes without
7 catastrophic failures, but when did those occur in the
8 context of your FAC program?

9 MR. STEWART: I will have to get back to
10 you on that. I don't recall offhand.

11 MR. CAVES: Yes. We've had some minor
12 leaks. Our -- I don't recall the exact reference that
13 you're referring to.

14 MEMBER SHACK: It's just there's a comment
15 in the SCR that you've had leakage in carbon steel
16 pipage, through-wall leakage but no catastrophic fail
17 -- and it wasn't even clear to me -- it was in the
18 context of the FAC program, but I don't know whether
19 the through-wall leakage was FAC or something else.

20 MR. CAVES: I don't recall any FAC
21 failures but I'll double check and get back to you on
22 that. The leaks that we've had in the carbon sealed
23 piping are primarily in the service water system.

24 MEMBER SHACK: Okay. And --

25 MR. CAVES: Okay. But I'll --

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MEMBER SHACK: -- I was just --

2 MR. CAVES: -- double check and see if
3 there's something else associated with FAC.

4 MR. SIEBER: Yes, it would be good if you,
5 while you're checking on when, if you could check on
6 the size of the line, material composition, how you
7 repaired it, what implications they had to the
8 application of CheckWorks otherwise.

9 MR. CAVES: Okay, sure.

10 MEMBER SHACK: That was just another
11 curious thing is your application never mentions
12 CheckWorks, but I assume that you actually use
13 CheckWorks?

14 MR. CAVES: We do.

15 MR. SIEBER: Right.

16 MEMBER SHACK: I wasn't sure whether the
17 document had some back door thing that you could use
18 instead. You reference the EPRI document, but you
19 never say CheckWorks anywhere in the 1600 pages, so --

20 MR. CAVES: That's true. Our utilization
21 of the CheckWorks program is actually expanding. You
22 know, we have not taken full advantage of it in the
23 past, and we do have plans in place and actually have
24 it implemented now. But at the time the amendment was
25 submitted, it's possible that we didn't have full

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 implementation.

2 MEMBER SHACK: Okay. Just another aging
3 management program, too. It's the thermal aging of
4 the cast stainless steel. I was trying to figure out
5 what was actually in this, because every time I came
6 to a stainless steel component, you reference the
7 letter from Chris Grimes that gave you an exemption
8 that said it wasn't embrittled. What actually -- what
9 components are actually in this aging management
10 program that, you know, will embrittle?

11 MR. MALLNER: Okay. My name's Chris
12 Mallner. The only component that was part of the
13 program was the -- well, part of the review was the
14 pressurizer spray head. And for the pressurizer spray
15 head, we pulled the CMCs for that component, did the
16 evaluation according to the methodology in the Grimes
17 letter and determined that it wasn't susceptible to
18 thermal aging.

19 MEMBER SHACK: It wasn't?

20 MR. MALLNER: It was not. That's why we
21 don't have a program. We did the evaluation
22 beforehand. The program itself, normally, the first
23 thing you do is do a susceptibility evaluation and
24 then determine required inspections. In this case, we
25 did the susceptibility evaluations while we were in

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 the process of doing the AMRs and had already
2 dispositioned it.

3 MEMBER SHACK: Okay. So all your cast
4 stainless components are rendered unsusceptible by
5 those criteria?

6 MR. MALLNER: As far as the -- for the
7 pressurizer spray head, we did a specific evaluation.
8 The reactor cooling loop elbows also made of case were
9 also determined not to be susceptible. Now we've
10 evaluated those as part of the leak before break
11 evaluation. We took into consideration the material
12 properties. We came to the conclusion that thermal
13 aging -- it was not susceptible per the Grimes letter,
14 even though they do show some thermal aging over the
15 full 60 years, but not to the level that's required by
16 the Grimes letter to put it into program. But they
17 were also evaluated, like I said, as part of the leak-
18 before-break evaluation.

19 MEMBER SHACK: But again, just as part of
20 the license renewal, you will look at every cast
21 component and decide whether it has to be in a thermal
22 aging program or not?

23 MR. MALLNER: That's -- well, we've
24 already done that.

25 MEMBER SHACK: You've already done that.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 MR. MALLNER: And that's why we don't
2 actually have a program. We have an installation
3 where we've done the evaluations already and we've
4 already determined that those components that would
5 have been -- could have potentially been in the
6 program as defined in GALL, the M12 program, that ends
7 up being a null set.

8 MEMBER SHACK: A null set. Okay. That's
9 why I couldn't find any compounds?

10 MR. MALLNER: That's correct.

11 MR. STEWART: Relative to commitments for
12 license renewal, to date Harris has made 37
13 commitments in support license renewal. And if you
14 looked at the application of the SER, it was 35. When
15 we talk about confirmatory items, we've made two
16 additional commitments since the SER was issued in
17 response to the confirmatory items. So that's how
18 come we have a count of 37.

19 These commitments are tracked by the
20 Progress Energy commitment tracking process. That's
21 a corporate process that we use at all of our nuclear
22 stations.

23 As we made a commitment in license
24 renewal, we develop an implementation plan which is
25 some guidance to take whatever the words are in the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 commitments and try to give some idea to the engineer
2 or whoever may be implementing it as to okay, here's
3 what you really need to do. And in those commitments
4 we are working with the plant now, some of them will
5 be implemented early. Some of them, obviously, will
6 have to go on, like if we go to some of the one-time
7 inspection stuff, you don't do those until the last
8 ten years. The plan is all open commitments will be
9 assigned to some on the plant staff, private closure
10 of the license renewal project.

11 Now I want to discuss the open item.
12 First off, I'll give you some background. Here's
13 mitigation of a main steamline break includes
14 redundant isolation of the feedwater lines. And
15 isolation of the feedwater is accomplished by closure
16 of the feedwater isolation valves, and these are
17 accredited containment isolation valves with backup
18 closure feedwater-regulating valves and bypass valves.

19 On here is the feedwater isolation valves
20 or the containment isolation valves, so they are
21 safety-related, and they're located in the reactor
22 auxiliary building. We identified these as being in
23 scope for license renewal in accordance with 10 CFR
24 54.4(a)(1).

25 The feedwater regulating valves and bypass

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 vales are nonsafety-related, and they're located in
2 the turbine building and were identified as being in-
3 scope for license renewal per the criteria of 10 CFR
4 54.4(a)(2).

5 And to give you an idea of what we're
6 talking about is the -- if Chris will show you the
7 isolation valves that are in green? And relative to
8 safety class designation on the piping, it runs up to
9 the check valve that's upstream of the isolation
10 valves. And you can see that the check valve and the
11 isolation valves are contained in the reactor
12 auxiliary building.

13 And next we'll move to the turbine
14 building, and in yellow, you can see the regulating
15 valve and the bypass valves. And the thing that I'd
16 like you to keep in mind on our turbine building for
17 the Harris plant, it's an open turbine building, and
18 it's a non-seismic Category 1 structure. Now there is
19 -- underneath the building, there's a service water
20 tunnel that's a seismic Category 1 structure that
21 takes the service water from the reactor auxiliary
22 building toward the diesel generator building, but the
23 turbine building itself is open and not safety-
24 related.

25 MR. SIEBER: Typically, feedwater

1 regulating valves and bypass valves are not leak type
2 and are not counted as containment isolation valves?
3 Is that the case here?

4 MR. STEWART: Yes.

5 MR. SIEBER: So you only have one set of
6 containment isolation valves on the steam side?

7 MR. STEWART: That's correct. If I look
8 at what we --

9 MR. SIEBER: Yes. A lot of plants have
10 shutoff valves inside and outside. This plant does
11 not.

12 MR. STEWART: That's correct.

13 MEMBER MAYNARD: You take no credit for
14 the check valves?

15 MR. STEWART: Let me confirm that and get
16 back to you.

17 MR. SIEBER: Well --

18 MR. STEWART: I don't believe we do but I
19 need to confirm that.

20 MR. SIEBER: In an accident condition, the
21 check valve is not going to do --

22 MR. STEWART: The check valve would work
23 from pressure coming from the containment but it
24 wouldn't stop the feedwater --

25 MR. SIEBER: Right.

1 MR. STEWART: -- and --

2 CHAIR STETKAR: It would be protection
3 against a break in the turbine building but not a
4 break at the steam generator building?

5 MR. MALLNER: Ready?

6 MR. STEWART: Yes, sir. Specifically, the
7 open item, and this is from the SCRs, the staff's
8 position remains that the main feedwater regulating
9 valves and bypass valves, by definition, fulfill a
10 safety-related function. Therefore, they should be
11 included in the scope of license renewal under 10 CFR
12 50.4(a)(1). In addition, the function to provide main
13 feedwater isolation should be included in the scope
14 under 10 CFR 54.4(a)(1) for Section 2.3.4.6 to include
15 main feedwater isolation valves and the regulating and
16 bypass valves.

17 To discuss the open item further, the
18 original SER for Harris -- this is NUREG-1038, and it's
19 dated November 1983 -- recognizes that the feedwater
20 regulating valves and bypass valves are non-nuclear
21 safety and that they do provide a backup isolation
22 function to mitigate a main seam line break. In
23 addition, if you look at the NRC Guidance in the
24 Standard Review Plan -- that's NUREG-0800, both
25 Revision 2 which is 1981 version and Revision 3 which

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 was updated in 2007 -- they recognize that for a main
2 steamline event, you can credit -- under certain
3 conditions, you can credit nonsafety-related equipment
4 for this backup isolation.

5 In addition, this design that we have is
6 consistent with the Westinghouse standard information
7 package that was released at the time we did the plan.
8 That's all the discussion I have on the opinion item.
9 We'll go onto the confirmatory items.

10 The first confirmatory item relates to
11 elastomers an thermoplastic components that were
12 discussed in the main steam and power conversion
13 system. The staff questions the specifics of the
14 inspection method, our use of the External Surfaces
15 Monitoring Program acceptance criteria and the GALL
16 applicability for this application.

17 Since then we've talked to staff and we
18 submitted a response by amending the license renewal
19 application to provide that the condensate storage
20 tank goes into the internal inspection aging
21 management program. And by the way, we had replaced
22 that diaphragm in 1994, and the last inspection that
23 we did was in 2006. So we do have an APM where we
24 basically do go in and inspect it, so we're moving it
25 that direction.

1 Relative to the other elastomeric and
2 thermoplastic components, we made a commitment that
3 will replace those prior to the period of extend
4 operation. We'll add those to periodic maintenance
5 program and replace those on as-needed basis.

6 CHAIR STETKAR: What -- would you give a
7 brief summary of the types of applications of these
8 other elastomeric and thermoplastic --

9 MR. STEWART: Yes, sir. The main steam
10 power-operated relief valves, there were some
11 hydraulic grinds associated with the actuator, and
12 there's also a breather cap on the hydraulic system.
13 We had some sample lines on the secondary sampling
14 system, and we had an instrument air hose on the --
15 providing instrument air to the feed reg valve
16 actuator. Those are the elastomeric components other
17 than the condensates storage tank diaphragm.

18 CHAIR STETKAR: Thank you.

19 MEMBER MAYNARD: ON your condensate
20 storage tank, do you one or two?

21 MR. STEWART: One.

22 MEMBER MAYNARD: One. Is it safety-
23 related or not safety-related?

24 MR. STEWART: Safety-related.

25 MEMBER MAYNARD: Okay.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MR. STEWART: The second confirmatory item
2 relates to the TLAA section, and there's two parts to
3 it. The first part deals with the operational
4 transients. And for Harris, if you remember back with
5 some of the bulletins and stuff, we were looking at
6 insurge and outsurge and thermal stratification on the
7 pressurizer surge lines. And the staff expressed a
8 concern that we had not updated the design speculation
9 to reflect these redefined transients. All the
10 analyses that we did in going forth for the license
11 renewal and the previous analyses that we had done
12 when we did the steam generator replacement power rate
13 were consistent with the transients, but we had not
14 revised the design specifications.

15 So we have since responded to that by
16 amending the application to include a commitment to
17 update the design specification and that update is in
18 progress now. The commitment says we'll do it prior
19 to the period of extended operation. We'll have it
20 done before the summer.

21 The part two relates to disposition of
22 some of the Environmentally-Assisted Fatigue Analysis,
23 whether we had used projections, i.e., the method II
24 or we were going to manage it with the Fatigue
25 Monitoring program which is the III, and the staff

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 requested that we make it clear in our FSAR supplement
2 which method we were using. Since then we have
3 responded by amending the application to indicate
4 which components we were using for the method 10 CFR
5 54.21(c)(1)(ii)(r)(iii), and that should resolve that
6 item.

7 That's all I have. Do you have any
8 questions?

9 MEMBER BONACA: You're doing the one-time
10 inspection or small-bore piping?

11 MR. STEWART: Yes, sir.

12 MEMBER BONACA: I do not understand
13 clearly your -- how do you collect your sample of
14 piping for the inspection? Will it be based on
15 susceptible locations or will it be based on risk
16 informed --

17 MR. STEWART: We're using several
18 locations to try to identify the most susceptible
19 locations and we'll do a sample from those.

20 MEMBER BONACA: Okay. So you're really
21 staying with the -- you're really looking for
22 susceptibility --

23 MR. STEWART: Yes, sir.

24 MEMBER BONACA: -- and then see if you
25 have any, you know, conditions like that. Okay.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MEMBER ABDEL-KHALIK: Who's the
2 manufacturer of your emergency diesels?

3 MR. STEWART: Do you have that?

4 MEMBER ABDEL-KHALIK: Can you still obtain
5 spare parts for those diesels?

6 MR. BURTON: Yes, we do. We have not had
7 any problems that I'm aware of, sir.

8 MR. CAVES: We are implementing some
9 upgrades. You know, for instance, as some of the
10 components become obsolete, we're replacing them with
11 a design change upgraded component.

12 MEMBER ABDEL-KHALIK: Okay, for example --

13 MR. CAVES: Yes, for --

14 MR. CAVES: -- would be a good example of
15 that?

16 MR. CAVES: And we've got it planned, for
17 instance, to do that during the upcoming outage.

18 MEMBER MAYNARD: On that picture, could
19 you just kind of identify those bodies of water, what
20 --- their function, not their name.

21 MR. STEWART: Okay. This is the main
22 intake structure and this is from the auxiliary
23 reservoir, so this is the aux intake structure. This
24 is the discharge structure over here. This is our
25 cooling tower obviously, but you can't see it on this,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 but there, I'm guessing it's a 30 or 40-foot elevation
2 difference between the water level here and the water
3 level here -- I mean between the main dam and the aux
4 reservoir.

5 MEMBER MAYNARD: So that's the aux
6 reservoir --

7 MR. STEWART: This is -- we call it aux
8 intake structure. The aux reservoir is impounded on
9 this side. If you had a larger picture, if I thought
10 I could have --

11 MEMBER MAYNARD: Okay. So that's a
12 continuous body of water around the bottom there?

13 MR. BURTON: Yes, sir, wrapped around.

14 MEMBER MAYNARD: And where would the main
15 --

16 MR. BURTON: Off the bottom of the
17 picture, sir.

18 MEMBER MAYNARD: Off the bottom.

19 MR. BURTON: Yes, sir.

20 MEMBER MAYNARD: You do not see any part
21 of it or --

22 MR. BURTON: Well, you see a finger of it
23 that comes up, supplies the normal intake right there.
24 That's an extension of the main reservoir. The
25 reservoir itself would be below the picture that

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1. you're currently seeing.

2. MEMBER MAYNARD: Okay.

3. CHAIR STETKAR: You have to identify
4. yourself.

5. MR. FLETCHER: My name is Mike Fletcher.
6. I work with Progress Energy License Renewal Team. The
7. lake was originally sized for four units, and only one
8. was eventually built.

9. MR. STEWART: To clarify that, the plan
10. was for four units. The lake would have been a little
11. higher elevation to go for four units, but the site
12. was sized for four units. We just didn't fill the
13. reservoir quite as high as we would if we had four.

14. MR. CAVES: Yes. If we had built the
15. four, the lake level would have been about 30 feet
16. higher than it is right now.

17. CHAIR STETKAR: I had a couple of
18. questions on your heat exchanger performance
19. monitoring. You've taken exception to flow
20. temperature pressure monitoring for performance for a
21. number of heat exchangers. I came across a curious
22. statement, if I can find it here. It says an
23. engineering evaluation concluded that factors inherent
24. in the testing process make the test results too
25. unreliable to be used for operability determinations

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 whereas a basis for an inspection program -- that's
2 with respect to monitoring flows and temperatures.

3 There's a list of heat exchanges but the
4 ones I was more curious about were the component
5 cooling water heat exchangers and the fuel pool heat
6 exchangers, because that statement is used for both of
7 those. I was trying to think about what factors
8 inherent in the testing process would make it
9 difficult to evaluate flows and temperatures.

10 MR. MALLNER: Okay. This is Chris
11 Mallner. I'll take that question. Part of the
12 problem of doing heat exhcanger testing is getting
13 enough heat load on your heat exchangers where the
14 fouling factor doesn't overly influence the results.
15 Obviously, the CCW heat exchanger and the spent fuel
16 pool heat exchangers are designed for accident-level
17 heat loads which are much greater than their normal
18 heat loads, so we currently don't have a way of
19 getting that amount of heat load into the heat
20 exchangers to come up with a test where you get a big
21 enough delta-T to make a good evaluation of whether or
22 not you're having a problem with the heat exchanger in
23 that case.

24 CHAIR STETKAR: What about CCW heat
25 exchangers, though, when you shut down for refueling?

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 You should have a fairly decent load on them when you
2 line up RHR, don't you?

3 MR. MALLNER: It's fairly decent but I
4 still don't think it's going to be high enough. Now
5 we relied on -- when we're doing license renewal,
6 evaluations had been done previously by the plant, and
7 we had taken those evaluations to heart when we did
8 the license renewal evaluations. So we thought it
9 would be better to do other things than try to come up
10 with a performance test that we didn't feel confident
11 would actually give us any information that was
12 worthwhile, especially like I said, for the spent fuel
13 pools, Harris has tremendously large spent fuel
14 because it was originally designed for four units, and
15 we've put two sets of heat exchangers in service now
16 because we had a spent fuel pool expansion project
17 about ten years ago. So to try to get a significant
18 amount of heat load on those heat exchangers will be
19 problematic.

20 The other thing is that when you look at
21 the water -- for example, if there's spent fuel heat
22 exchanges, you have essentially clean water on both
23 sides, and we don't expect to get significant amounts
24 of fouling on those heat exchanger tubes. So we
25 discuss things like we have alarms on the pool

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 temperatures and things like that, so if we notice a
2 rise in pool temperatures, then we would take
3 corrective actions to go back and investigate why the
4 pool temperature would be going up when those heat
5 exchangers are in service.

6 CHAIR STETKAR: You mentioned those
7 alarms. What is the alarm temperature for high --
8 what do you normally run at and what's the alarm
9 temperature for high temperature in the fuel pool?

10 MR. MALLNER: I want to say I think the
11 alarm temperature is 140 degrees, but I'd have to go
12 back and verify that. As far as the normal operating
13 temperature of the pools, John, can you help me with
14 that?

15 MR. CAVES: Yes, typically, we adjust the
16 spent fuel cooling to maintain between 90 and maybe
17 104, 103 degrees. You know, it does change. It's a
18 manual operation to put the spent fuel pool cooling in
19 operation and simply monitor the temperatures as they
20 --

21 MEMBER BONACA: On the buried piping and
22 tanks program, you don't have any tanks, buried tanks
23 on site or do you? They are not in the program?

24 MR. STEWART: No. The closest thing to a
25 buried tank would be the diesel fuel storage, but it's

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 a concrete -- it's a blowdown structure that's
2 concrete and steel-lined. It doesn't fall under the
3 program.

4 MR. MALLNER: That's a vault.

5 MR. STEWART: It's a vault.

6 MR. MALLNER: And the security diesel has
7 a tank, but it's a plastic tank that's inside another
8 tank for the security diesel. But that doesn't meet
9 the definition of the type of tank that would go in
10 that program, because it's a special application. So
11 it really is not a direct burden tank.

12 MEMBER BONACA: I don't remember. Do you
13 take any exceptions from GALL as far as this program?

14 MR. MALLNER: I would have to look at the
15 application. I don't remember off the top of my head.

16 MEMBER BONACA: You agree to perform at
17 least one inspection in ten years, either an
18 opportunistic inspection or if you don't get any in
19 ten years, you would then look for an inspection if I
20 remember.

21 MR. MALLNER: Yes, I'm pretty sure that we
22 felt the current industry practice, which is --

23 MR. STEWART: We did not take any
24 exceptions to the program.

25 MR. MALLNER: Right, no exceptions. And

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 we would do opportunistic inspections when the lines
2 are uncovered, but no more than ten years --

3 MEMBER ABDEL-KHALIK: Did I understand you
4 correctly that your component cooling water heat
5 exchangers are somewhat oversized?

6 MR. CAVES: Oversized for a normal
7 operation.

8 MEMBER ABDEL-KHALIK: Okay. How well do
9 you control the letdown temperature?

10 MR. CAVES: Dave, do you want to handle
11 that. Dave Collett, our licensing supervisor, is head
12 of shift supervisors in the control room, so.

13 MR. COLLETT: It's automatically
14 controlled iwth a temperature control valve.

15 MEMBER ABDEL-KHALIK: You can maintain it
16 within the control bank?

17 MR. BURTON: Yes.

18 MR. COLLETT: Yes.

19 MR. BURTON: There is no operational
20 challenges.

21 MEMBER ABDEL-KHALIK: There are no, with
22 regard to control of letdown temperatures or any
23 reactivity implications with regard to ability to
24 control letdown temperature?

25 MR. COLLETT: That's correct. We have no

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 operational temperature control problems whatsoever.

2 MEMBER ABDEL-KHALIK: Okay. Thank you.

3 MR. SIEBER: You have a regenerative heat
4 exchanger which is --

5 MR. COLLETT: Yes.

6 MEMBER BONACA: Yes. I had a question
7 regarding your plant-specific PRA. Do you have an
8 estimation of CDF for the plant?

9 MR. CAVES: It's on the order of 10 to the
10 minus 6.

11 MEMBER SHACK: It's 9.24 times 10 to the
12 minus 6.

13 (Off the record comments.)

14 MEMBER MAYNARD: Your head -- you
15 mentioned this in your application -- you had
16 inspected in 2007. I take it you didn't find any
17 significant issues with your head?

18 MR. CAVES: That's correct.

19 MEMBER MAYNARD: The other part of that is
20 on the scale from a materials and service standpoint,
21 your's is considered to be one of the lower
22 susceptible heads to the degradation?

23 MR. CAVES: That's correct.

24 MEMBER SHACK: Even after you've raised T-
25 hot --

1 MR. CAVES: That's right.

2 MEMBER ABDEL-KHALIK: Now when T-hot is
3 raised, is it raised to the original design value --

4 MR. CAVES: That's what we do.

5 MEMBER ABDEL-KHALIK: -- which was
6 reduced, I guess, when you had degradation --

7 MR. CAVES: We covered it --

8 MEMBER ABDEL-KHALIK: -- in steam
9 generator?

10 MR. CAVES: That's correct.

11 MEMBER MAYNARD: But with some of your
12 future power uprates -- of course, you're looking
13 pretty small -- are you looking at increasing T-hot or
14 are you -- whatever you get additional out of the
15 turbine is not going to matter, but your instrument
16 assurance and others need to know that you're going to
17 be running your reactor power a little bit higher,
18 right?

19 MR. BURTON: Yes, actually slightly
20 higher. Yes, sir.

21 MR. CAVES: Yes. We haven't gone far
22 enough with the design to be able to answer that
23 question.

24 MEMBER MAYNARD: And it would be a very
25 small amount and it's just -- philosophically looking,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 are you going to continue raising T-hot, or would you
2 look at going to a reduced T-ave?

3 MR. SIEBER: Six twenty is pretty hot.

4 MR. CAVES: It's premature for us to be
5 able to answer that.

6 CHAIR STETKAR: Since Mario opened the
7 question, I feel obliged to follow-up on one thing.
8 I noticed in your masonry walls inspection program,
9 one of the criteria for identifying the masonry walls
10 that you mention is risk significance. So I got
11 curious about that and I looked back at the PRA, and
12 I noticed that the seismic part of the risk assessment
13 was done only according to the EPRI seismic margins.
14 So there's been no quantification of seismic risk.

15 There are some arguments that say well,
16 everybody knows th the fire risk is dominant so we'll
17 assume that the fire risk is 85% of the total risk
18 from other external events which sounds rather
19 specious, at best. I was curious what type of -- if
20 risk insights are used for classifying your masonry
21 walls for inspection, what are they since you don't
22 have a seismic risk ranking on a consistent risk basis
23 for those walls? In other words, you can't go to your
24 PRA and say this particular wall has this risk
25 importance because indeed those walls are not in your

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 PRA. You can't actually measure their contribution to
2 risk.

3 MR. MALLNER: will turn it over Bob
4 Reynolds. He was the civil lead for the application.

5 MR. REYNOLDS: Yes. Bob Reynolds, the
6 civil lead. We had a question on that based on the
7 wording in the GALL as to which. I think it was more
8 related to how often do we inspect the walls, you
9 know, which ones do we prioritize first and things,
10 and we came up with -- the answer that we gave was is
11 that we -- mainly, it's by safety-related. In other
12 words, if it's a safety-related structure with masonry
13 walls, safety-related walls, then we would look at
14 those perhaps more frequently than we would some of
15 the others. We set a frequency on some of the
16 buildings that have masonry walls in them that are
17 more -- that are at various year whereas some of the
18 nonsafety-related structures are like at ten years or
19 nine years. So that was the way we addressed that.
20 It was basically more on the fact whether it was
21 safety-related or nonsafety-related --

22 CHAIR STETKAR: So it's just a pass/fail
23 criterion rather than a risk --

24 MR. REYNOLDS: Yes, sir.

25 CHAIR STETKAR: -- because if you read the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 walls -- if you read the words, you're led to believe
2 that it's kind of a risk ranking type base.

3 MR. REYNOLDS: It was nothing to do with
4 the risk ranking at all, sir.

5 CHAIR STETKAR: Thank you.

6 MR. SIEBER: I take it a wall is a
7 structural member as opposed to a partition which is
8 nonstructural but separates a structure into cubicles?

9 MR. REYNOLDS: We have some walls at
10 Harris that are fire protection-related walls in the
11 fuel handling building, and those are in-scope of
12 license renewal, and those are being included in the
13 inspections as well as we had a structure even that
14 was a nonsafety-related structure that had equipment
15 that was in the scope of license renewal and say for
16 SBO or for protection or some other reason, that wall
17 also would be in-scope of license renewal, and those
18 were inspected as well.

19 MR. SIEBER: Okay. Thanks.

20 MR. BARTON: You have an AMP that covers
21 inaccessible medium voltage cables not subject to
22 50.45 EQ requirements, and in there it states manholes
23 will be inspected for ore accumulation and drained as
24 needed, and this inspection program will be based on
25 field data and not to exceed two years. Now do you

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 have a program in place now that inspects manholes?

2 MR. STEWART: Yes, we do.

3 MR. BARTON: And what is covered under --

4 MR. STEWART: It's part of -- there's Pms
5 where we do -- it's quarterly or semi-quarterly drain
6 down of the manway. Then separate, we do an
7 inspection of them as part of the structure monitoring
8 program. And I believe that's currently on a nine-
9 year frequency.

10 MR. SIEBER: Do you ordinarily find water
11 in the vaults below the manholes?

12 MR. CAVES: It's not infrequent to find
13 water.

14 MR. SIEBER: It's not infrequent. So you
15 do find it --

16 MR. CAVES: We do find it occasionally.

17 MR. SIEBER: -- quite a bit?

18 CHAIR STETKAR: There was -- if I
19 remember, the NRC Regional Inspection Team apparently
20 audited inspections of two of those manholes, and
21 there was water in them.

22 MR. HEATH: This is Mike Heath. We do do
23 those inspections on a quarterly basis. We do find
24 water. The water is not up to the level of the cable.

25 MR. SIEBER: You say the water is not up

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 to the level of the cables?

2 MR. HEATH: That's correct. The water is
3 -- we have not found -- we do not find water above the
4 cable level.

5 CHAIR STETKAR: You said quarterly, you
6 actually inspect. Is that only the safety-related
7 manholes or all manholes?

8 MR. STEWART: The production manager that
9 we do the -- it's not the inspections basically to
10 open the manholes and drain them. It's quarterly on
11 the nonsafety and I think semi-quarterly on the safety
12 -- I'll confirm those frequencies.

13 CHAIR STETKAR: I didn't find those. I
14 was curious about that frequency.

15 MEMBER MAYNARD: Can you just give us a
16 feeling? You say you normally find water in there or
17 it's not unusual to find water but it's not up to the
18 cable. Relatively speaking, you know, are we looking
19 at six feet with the water being a foot below it. or
20 are we looking at an inch or two of water with four,
21 five feet of clearance? I'm just trying to get a feel
22 for whether it's something that the water's getting
23 close to it or whether it's --

24 MR. HEATH: To my understanding, it's not
25 a significant amount of water. In other words, it's

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 not -- we're not nearly up to the cables but we do
2 find water in there. And we do pump that out. From
3 my understanding of it, it's not an issue at the
4 plant.

5 MR. CAVES: Yes, it can be more than a
6 couple of inches. You know, it can be a foot or so,
7 but we've still quite a bit of margin.

8 MEMBER MAYNARD: Just quantify a little
9 bit quite a bit. Are we --

10 MR. CAVES: To get that specific, I'll get
11 an answer and bring it --

12 MEMBER MAYNARD: I don't have it by the
13 inch or the foot, but I mean --

14 MR. BARTON: Relatively speaking --

15 MEMBER MAYNARD: -- relatively speaking,
16 you know, if we got two feet of water in there, and we
17 got quite a bit of clearance, quite a bit of clearance
18 to you might mean four, five inches, and quite a bit
19 of clearance to me may mean four or five feet.

20 MR. CAVES: Yes, it's on your four and
21 five feet, but I'll confirm that.

22 MEMBER MAYNARD: Okay.

23 CHAIR STETKAR: Are the results from these
24 inspections, whether they're quarter or semi-
25 quarterly, are they recorded and trended, does

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 somebody look at that information?

2 MR. CAVES: System engineers monitor that.

3 CHAIR STETKAR: So they have a historical
4 trending or historical monitoring of what the level
5 was --

6 MR. CAVES: It doesn't go back 20 years.
7 It's a program that we, you know, increased the rigor,
8 you know, in that monitoring program a couple of years
9 back. Okay? But over the last, you know, three or
10 four years, we do have good information --

11 MR. SIEBER: You're doing a quarterly,
12 it's going to go up and down.

13 MR. STEWART: Caudle, would you like to
14 speak to that? This was a particular question that
15 Mr. Julian had when he was on site, so he can --

16 MR. JULIAN: During our inspections, we
17 did look into what they were doing with the manholes,
18 and they do have a quarterly PM to go out and measure
19 the level of water that they find in there. And they
20 were -- looked to us like the water was well below the
21 cable height. We did ask them to pull open one of the
22 manholes, and they're actually vaults, kind of, then
23 look in there and it was a very small amount of water
24 in that one vault that we'd looked at. And the cable
25 distance, my memory fails also, but I'm talking three

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 feet or so it seems like from the highest water level
2 they had reported to the cable we were looking at.

3 When we asked about trending, at that
4 time, they did not have trending. That's one of the
5 issues that we talked about in our inspection report
6 is that the workers were dutifully writing the data
7 down, but it wasn't going anywhere. So they responded
8 by getting a system engineer who's responsible for
9 that, routed the information. He started a trending
10 program , in fact, I think, in reaction to our
11 discussions with him. So now I have faith that they
12 are indeed trending it, recognizing, of course, the --
13 trying to recognize the particular manholes might have
14 problems. You know, containing you only had water
15 again and again.

16 MEMBER ABDEL-KHALIK: What's the main
17 source of the water?

18 MR. BURTON: Rainwater.

19 MEMBER ABDEL-KHALIK: Rainwater and it's
20 just sort of gradually draining into these vaults
21 through the manholes?

22 MR. BURTON: Yes.

23 CHAIR STETKAR: DO you have a sense --
24 does it come in through the manholes or --

25 MR. BURTON: Yes.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 CHAIR STETKAR: -- or it's not groundwater
2 seeping through the cable canals and the ducts and
3 stuff?

4 MR. BURTON: You know, it could come in
5 and drain through the cable ducts and get down into
6 the manhole because it's a low point.

7 MR. SIEBER: Well, you know you have a
8 flow path all the time from the manhole. You'd have
9 to rupture or break the conduit box or the piping in
10 order to get water in from that standpoint. The
11 interesting thing is that where the manholes are is
12 where the splices usually are. And so if you think if
13 you have qualified cable, it's -- the important thing
14 is whether you have a qualified splice or not.

15 MR. JULIAN: We did observe that Harris'
16 layout, their cable vaults that they have are large,
17 big concrete cavities, and after they've pulled them
18 periodically to inspect them, they go back and seal
19 them. So they do attempt to keep rainwater out of the
20 things, but I guess that sealant probably ages with
21 time. But the layout then, I think, from the vaults
22 is -- my memory is that it's, you know, sealed conduit
23 that runs underground.

24 CHAIR STETKAR: That's what I was going to
25 ask. Isn't sealed conduit out? Or are they just

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 concrete -- I've seen a lot of different things. Some
2 people just have concrete ducts with, you know, cable
3 raceways, and other people have actual sealed conduit
4 as you go out.

5 MR. STEWART: We better check that to give
6 you --

7 MR. JULIAN: Because some of the concrete
8 ducts, you can get ground water, you know, in the
9 ducts, and it just sort of goes down the sluice if
10 it's cracked.

11 MR. BURTON: I'm not sure that we know and
12 we will find out through that answer.

13 CHAIR STETKAR: Where are -- you know,
14 since you have the nice picture of the site up there,
15 are these -- the underground cables that we're talking
16 about, are they throughout the site or are they for
17 only a few particular functions?

18 MR. JULIAN: Primarily, cabling, in my
19 memory, has to run for the auxiliary building to the
20 diesel building. Is that --

21 MR. STEWART: The diesel building is right
22 here, and the auxiliary building is here. The other
23 place that we would go is back to the screening
24 structure here which are these, along this place where
25 we'd have safety-related type cable.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 CHAIR STETKAR: Where are your ESW pumps
2 physically located?

3 MR. STEWART: In this (indicating)
4 structure right here.

5 CHAIR STETKAR: They're in the intake
6 structure itself?

7 MR. STEWART: Yes, sir.

8 MR. CAVES: And are motor-driven fire
9 pumps are in the same location.

10 MR. JULIAN: So those are the cable runs,
11 primarily the long run down to the intake structure
12 for safety-related application. And the ones we
13 looked at were the cable vaults on the cabling that's
14 going from the auxiliary building to the diesel
15 building. Those are the ones we selected.

16 CHAIR STETKAR: Those are the ones that
17 you actually --

18 MR. JULIAN: We selected to look into and
19 we thought that the condition of them was good. It
20 looked like, from marks in there, they if they had
21 water accumulating in there, it's rather low. And we
22 didn't see evidence, certainly, that there is
23 recurring flooding. We don't think water ever gets up
24 to the cables in those --

25 CHAIR STETKAR: Thank you.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MEMBER BONACA: You said in your
2 presentation that the aging evaluations were 89%
3 consistently GALL. But also, you stated that there
4 are 14 aging monitoring programs take one or more
5 exceptions to GALL. Would you characterize a little?
6 You know, for example, is it most of it is to do with
7 different ASME --

8 MR. STEWART: I took a quick look back at
9 it and more than half of them are due to either ASME
10 code addition or revision of EPRI guidelines or in one
11 of them on the steam generator tube integrity is the
12 revision of NEI 97-06. The majority of them are just
13 a different addition or revision of the reference
14 document.

15 MEMBER BONACA: So you don't feel that
16 there is real departure from GALL? I mean they're
17 just variation or rule changes?

18 MR. MALLNER: The --

19 MEMBER BONACA: I'm trying to understand
20 because we have seen a trend in later applications
21 where there'd be more and more exceptions to GALL.
22 And GALL, when it was issued, was really almost a
23 contract between the industry and the NSC. So I just
24 -- I'm curious to know what's driving the exceptions.
25 Some of them are just convenience in a sense that you

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 already have a program in place, you feel is
2 appropriate and adequate the way it is, and you don't
3 want to change that, but you don't have fundamental
4 disagreement with GALL.

5 MR. MALLNER: This is Chris Mallner again.
6 I would say the answer to that question is no. It's
7 basically in trying to apply the requirements in the
8 GALL aging management program at your particular site.
9 I mean a good example is the Brunell hardness testing
10 of the selective leaching program.

11 MEMBER BONACA: Yes.

12 MR. MALLNER: You know, that one has been
13 -- an exception has come up for almost all the
14 applicant's, and we're always trying to figure out
15 what's the best way to accomplish of the selective
16 leaching program to find what we need to do. And
17 we're just looking for an alternative to -- because
18 that Brunell hardness testing could be problematic
19 where you can do -- can you get to the actual
20 component that you suspect. So those are the type of
21 things. And we've tried to communicate this back to
22 the staff in the reviews, that when GALL is updated --
23 I'm sure they're working on it now -- that we'll try
24 to get a better way to try to convene at a point where
25 we can have less exceptions in the program space.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 MEMBER BONACA: Good.

2 MR. STEWART: And in addition, the one --
3 I'm just looking -- I have some of the exceptions in
4 front of me, but fuel oil chemistry, we took exception
5 or exceptions. We had additional scope items that
6 weren't covered in GALL. So we -- I mean it was an
7 exception to the program. Chris mentioned the
8 selective leaching. On the one-time inspection of
9 Class 1 small-bore pipe, we took the exception that we
10 would not do a volumetric examination of the small
11 socket welds. And then on the electrical cable
12 connections, we took the exception that the
13 connections that we're looking at are the external
14 connections, not the ones that are contained inside of
15 a panel, and those are the exceptions other than the
16 code addenda are.

17 MEMBER BONACA: Okay. Thank you.

18 CHAIR STETKAR: You mentioned socket
19 welds. I think in the discussion, it said there are
20 socket welds in some safety-significant systems, I
21 think, is the way it said. Do you happen to -- what
22 are those systems since you won't be examining those
23 welds? Do you know which systems those -- that they
24 point to?

25 MR. STEWART: I don't.

1 CHAIR STETKAR: I've forgotten the exact
2 words and it's too difficult for me to find my notes
3 on it, but the term was small-bore socket welds do
4 exist in, I believe it was, safety-significant
5 systems, which had me curious as what systems they
6 were.

7 MR. STEWART: I don't know the specifics
8 but I --

9 CHAIR STETKAR: I don't think it said
10 safety-related. If -- find my notes here.

11 MR. STEWART: We do have some small-bore
12 socket welds in our RSI program, and my recollection
13 for license renewal is what we committed to. There is
14 not a substantial number of them, but we do a visual
15 exam of all of them each outage. I'll confirm that
16 and we'll get back to you in terms of --

17 MEMBER SHACK: Yes, each refueling outage.

18 MR. STEWART: And my recollection is
19 there's not a substantial number of those, but we
20 committed to do a visual of each -- of all of them
21 each outage. And these are the -- I believe these are
22 the Class 1 ones, and so the systems, if it's Class 1,
23 it's got to be reactor coolant --

24 MR. CAVES: Or an extension.

25 MR. STEWART: -- or extension thereof.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 CHAIR STETKAR: My notes on this, and
2 they're just sketchy, said there are socket welds in
3 locations that are classified as high safety-
4 significance from your risk-informed ISI program if
5 that points you to some reference document.

6 MR. STEWART: We'll get back to you.

7 CHAIR STETKAR: Sure. Where are your
8 containment spray valve chambers located? I noticed
9 when you were talking about containment liner and so
10 forth corrosion problems that there had been some
11 repeated evidence of corrosion in those containment
12 spray -- they're categorized as containment spray
13 valve chambers. And I was curious where they're
14 located and why are they more susceptible to corrosion
15 than some, you know, other locations that you've
16 examined?

17 MR. STEWART: The chambers themselves are
18 -- it's in the reactor auxiliary building just outside
19 of containment, very lowest elevation. I think it's
20 190 feet elevation. And I'm not familiar enough with
21 the corrosion to discuss the specifics on that.

22 MR. REYNOLDS: I don't remember all the
23 details -- Bob Reynolds of Progress Energy -- these
24 chambers are in the scope of IWE, and they are
25 inspected on the frequency of, you know, the IWE

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 frequency. And there has been some flaking and some
2 loss of coating and things on those valve chambers
3 outside and inside. And they have had some -- they
4 are looked at and they are repaired each time. I
5 don't think it's -- I don't -- as I recall, it is not
6 a generic problem with them. It's just some localized
7 problems in each of the -- in those chambers.

8 CHAIR STETKAR: Okay.

9 MR. REYNOLDS: Does that answer your
10 question or?

11 MR. SIEBER: Yes. I was just curious
12 whether there was any -- you've answered as long as
13 you don't believe it's a generic problem whether its
14 not water or condensation because of their location,
15 if they are out in the auxiliary building.

16 MR. REYNOLDS: They are located in the
17 auxiliary building and the chambers themselves are
18 partially embedded in the reactor building wall, I
19 guess you -- containment wall. And actually, when I
20 was -- when they did some of the inspections, they
21 think they even damaged some of it when they were
22 trying to do the repairs on the other, and it was just
23 -- it was fairly minor. But there have been -- it has
24 occurred several times, and they -- it's not a --
25 think -- what's the word -- it's not a -- it's not

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 like one of the problems that -- they do look at it,
2 but it's not a continuous problem. The last outage,
3 there was very little problem --

4 MEMBER ABDEL-KHALIK: Are those chambers
5 considered a part of the containment?

6 MR. REYNOLDS: Yes, sir, they're part --
7 we consider them part of the containment.

8 MEMBER ABDEL-KHALIK: So how frequently do
9 you open them to see whether or not there's water in
10 there or corrosion in there?

11 MR. REYNOLDS: From my understanding,
12 they're looked at on a five-year basis.

13 MEMBER ABDEL-KHALIK: So you can't open
14 these on line?

15 MR. REYNOLDS: No.

16 MEMBER ABDEL-KHALIK: No.

17 MR. REYNOLDS: It would be during a
18 refueling outage, yes, sir, or an outage.

19 MEMBER ABDEL-KHALIK: And what is the
20 extent of the corrosion of these chambers?

21 MR. REYNOLDS: It's surface corrosion.

22 CHAIR STETKAR: There wasn't any
23 indication of severe corrosion. I was just curious
24 because they've done several inspections, and this --
25 that item, in their operating experience, seemed to

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 come up repeatedly. But there wasn't any indication
2 of severity, you know, severe condition. It's just
3 curious why, because of their environment or --

4 MEMBER ABDEL-KHALIK: Is there a leakage
5 to the valve stems inside those chambers or what?
6 What is the source of water that causes the corrosion?

7 MR. REYNOLDS: I'm not sure I can answer
8 that off the top of my head. It may be the plant has
9 some idea better than I do on that, but I can go back
10 and ask the question.

11 CHAIR STETKAR: Those lines are stagnant.
12 They're the containment spray injection lines.

13 MR. REYNOLDS: That's correct.

14 MR. BURTON: And they're not in an unusual
15 environment of any kind. They're in the same --

16 CHAIR STETKAR: That's why I was curious
17 about --

18 MR. BURTON: They're not down on the
19 floor.

20 CHAIR STETKAR: No, no.

21 MR. BURTON: I mean they're huge but --

22 MR. SIEBER: But it's important because
23 part of containment boundary and, you know, it's the
24 same effect as having your liner corroding in the
25 upper part of containment. It's a pathway to the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 outside. So you do a ten-year containment pressure
2 test, right?

3 MR. REYNOLDS: Yes. These tanks are
4 included as part of the Appendix J program and the IWE
5 programs as well.

6 MR. SIEBER: Okay. So if it leaked, you
7 would at least know it every ten years?

8 MR. REYNOLDS: That's correct.

9 MR. BURTON: We'll try and get some
10 characterization of --

11 MEMBER ABDEL-KHALIK: Have you done a root
12 cause analysis of the cause of the corrosion?

13 MR. CAVES: I'd be surprised. I do not
14 believe we've done a root cause analysis on that.

15 MR. SIEBER: You probably would be hard-
16 pressed to do that because it's underground. If the
17 corrosion's on the outside of the liner, had to come
18 through the concrete.

19 CHAIR STETKAR: These are -- if the -- I
20 used to work at Zion and if they're anything like ours
21 was, they're below grade, but you can look at them.
22 They're out in the open.

23 MR. REYNOLDS: You can look at the
24 exterior --

25 CHAIR STETKAR: Exterior --

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MR. REYNOLDS: -- surface of it and it's
2 observable in the bottom of the reactor auxiliary
3 building, yes, sir. And --

4 MR. SIEBER: Okay. Ours are really under
5 --

6 CHAIR STETKAR: No, this is -- they're
7 below grade, but you can see -- you can touch the
8 exterior of these things.

9 MR. STEWART: You can take -- you can
10 actually go inside. You can take off the manhole
11 cover and go inside as well.

12 MEMBER MAYNARD: I would just like to have
13 a brief discussion with the fatigue analysis and with
14 the issues that have come up with several of the other
15 plants that it's my understanding for your fatigue
16 analysis, you're using a different program than what
17 Vermont Yankee, Wolf Creek and some of the others have
18 used, so you're not susceptible, I guess, to some of
19 the same issues that had come up. Can you just
20 confirm that a little bit or briefly --

21 MR. STEWART: Yes, we can. Would you like
22 to hear it from us or would you like to hear it from
23 Dr. Chang?

24 MEMBER MAYNARD: Well, either one. I just
25 want to get a little bit of discussion on the record,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 and if staff's going to address that, that'll be fine.
2 I just -- since it is an issue, I think it's something
3 that we need to have a discussion either this
4 afternoon or a little bit on.

5 MR. MALLNER: This is Mallner again. I
6 can talk about that a little bit. Westinghouse did
7 our evaluations for us for license renewal, and they
8 typically used ANSI software to do the evaluations,
9 and they used their WESTMS software also. Their WESTM
10 software uses all six components of stress. We were
11 asked during the audit to provide a benchmark of
12 WESTMS versus the ANSI analysis to show that we were
13 getting the same results we provided, that the
14 reviewers were satisfied that we were okay as far as
15 the software we were using, and the issue that applies
16 to the other plants, which is the concept of virtual
17 single stress to represent all the stresses in that
18 particular location don't apply to us.

19 CHAIR STETKAR: That's fine and we can
20 hear from the staff later.

21 MR. LEE: This is Samson Lee. The staff
22 will go over that also in case you still have
23 questions.

24 MEMBER MAYNARD: I just wanted to get some
25 discussion on the record on that.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 CHAIR STETKAR: I notice that you've
2 established the boundary between your -- the boundary
3 for inspection program for your offsite power supplies
4 as including the circuit breakers out in the
5 switchyard and everything in from that. Who owns the
6 circuit breakers? Is it yours?

7 MR. CAVES: Yes, sir.

8 CHAIR STETKAR: Okay. You own it. You
9 control all of the equipment out there? You operate
10 the equipment from the control room or from -- you
11 operate the establishment.

12 MR. BARTON: Doesn't the transmission
13 department have some culpability here someplace?

14 MR. STEWART: Progress Energy owns the
15 plant, the switchyard, the transmission. There is an
16 interface agreement between the plant and the
17 transmission department in terms of how they do work
18 in the switchyard. That's controlled by an interface
19 agreement and the control room, and the plant has say
20 on what they do. So they don't go in and do things
21 without the plant knowing.

22 CHAIR STETKAR: But you're all the same
23 company?

24 MR. STEWART: Yes, we are the same
25 company.

1 CHAIR STETKAR: Okay.

2 MR. BARTON: They own the oil fuel high
3 voltage cables out in the switchyard, right? That's
4 what I got out of the literature someplace. And
5 you're going to have an aging management program on
6 those cables. Who will actually implement that
7 program, the transmission department under your
8 overview, or how is that going to work on this
9 interface agreement?

10 MR. STEWART: I don't know if worked the
11 specifics out on that yet. We talked -- my
12 recollection is we've talked with the system engineer
13 and transmission and come up with some proposed
14 methodology, but we have not worked out the specifics
15 yet.

16 MR. CAVES: I'm very confident it'll be
17 the transmission department that actually does the
18 maintenance under the watchful oversight of what we
19 call the PTAC, the plant system engineer that's
20 responsible for --

21 MR. BARTON: Okay. Understand.

22 MR. SIEBER: You need to be careful
23 because transmission departments, in general, don't go
24 through the paperwork and sign-offs and everything,
25 that you need to document what's going on. I think

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 they do the work okay. On the other hand, they are
2 not paper oriented.

3 MR. CAVES: Right. And we've actually had
4 significant efforts over the last several years
5 increasing the interaction between our staff and
6 transmission issues like that, compliance with
7 procedures --

8 MR. SIEBER: So the plant is really only
9 responsible for manning the output breakers and its
10 auxiliary transformers and the main unit transformer.
11 Everything else belongs to transmission.

12 MR. CAVES: But we still assume our own
13 responsibility for that. You know, we don't delegate
14 that responsibility. We describe it as 200%
15 accountability at that interface.

16 MEMBER BONACA: You're running an 18-month
17 cycle you said. Is it a low leakage core?

18 MR. CAVES: Yes, it is.

19 MEMBER BONACA: Okay.

20 MEMBER SHACK: Why? You seem to have
21 ample margin to diffuse --

22 MEMBER BONACA: Yes, that's why I was
23 asking that question.

24 MR. SIEBER: Yes, but they don't have AB
25 (phonetic) margin. They have margin in the core.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 CHAIR STETKAR: One last question, from
2 me, anyway since, amazingly enough, we're running well
3 ahead of schedule. Do you have any comments on your
4 plans to resolve the open issue? You describe the
5 issue quite well to us. I think we understand what
6 the issue is. Is there progress being made on it?

7 MR. STEWART: There is progress being
8 made. We've been in discussions with the staff, and
9 we have a path to resolution.

10 MEMBER BONACA: Okay. The issue does not
11 affect the scope. I mean still it's components are
12 in-scope.

13 And so the issue has to do with ancient
14 history. I mean --

15 CHAIR STETKAR: Well it's whether they're
16 in-scope under (a)(1) or (a)(2) is the issue, and the
17 fact that they're in a non-seismically qualified open
18 to the environment building is the problem.

19 MEMBER MAYNARD: I think this probably has
20 generic imprint. Is there something unique about
21 Shearon Harris? Actually, a lot of Westinghouse
22 plants' feed reg valves are not safety-related.

23 MR. STEWART: That's correct.

24 MEMBER MAYNARD: So I think this is
25 probably more a generic issue to Shearon Harris.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MR. STEWART: That's right.

2 MEMBER BONACA: It goes back to the
3 original categorization and so it's more of an issue
4 of defining and understanding of how the plant was
5 licensed than an issue affecting, really, license
6 renewal scope. I mean --

7 MEMBER MAYNARD: Yes. I had a number of
8 questions for the staff on this, because I felt that
9 this was a generic item about any Westinghouse --

10 CHAIR STETKAR: I was just curious, from
11 your perspective, whether this is a real sticking
12 point or --

13 MR. STEWART: From our perspective, we
14 have a path to resolution.

15 CHAIR STETKAR: Okay. If nothing else, I
16 guess before we close, I'll just go around the table
17 just to make sure that there aren't any lingering
18 items. We typically do this at the end of the
19 afternoon also. Jack, do you have anything for them?

20 MR. SIEBER: So far, nothing.

21 CHAIR STETKAR: John?

22 MR. BARTON: I don't have anything major.
23 I have a question on the refueling water storage tank.
24 It's an enclosure, like could accumulate raw water
25 undefined, maybe rain water, whatever else. You have

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 an aging management program that you're proposing a
2 one-time inspection. Does this include inspecting
3 tank bottom or something? I don't understand how the
4 tank is maybe sealed from water in the enclosure
5 getting underneath it or whatever, so I don't
6 understand what you're one-time inspection program on
7 that refueling water storage tank and system.

8 MR. STEWART: Let me explain the
9 configuration of the tank. The tank is an outdoor
10 tank, and there's an enclosure around the tank. The
11 tank sits on a concrete platform inside the enclosure,
12 and the concrete platform is approximately six inches
13 high.

14 MR. BARTON: Okay.

15 MR. STEWART: There is capability of
16 draining the enclosure. However, for environmental
17 considerations, we do not drain the enclosure without
18 sampling it. And what we typically do is monitor
19 during operator rounds. If we get a rainstorm or
20 something, you will accumulate water in there. If the
21 operators see water accumulating, they will get it
22 drained down but not until we sample the water and
23 make sure that we can discharge it.

24 So what we're talking about is there -- is
25 you can accumulate water that might come over that.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 It's not a normal occurrence.

2 MR. BARTON: But it could happen?

3 MR. STEWART: It could happen and in terms
4 of the proposed inspection program, recognizing that
5 it's a stainless steel tank and it's potentially --
6 it's raw water, there are some potential corrosion
7 mechanisms, and we are going to look for those.

8 MR. BARTON: Okay.

9 MR. CAVES: Just a clarification. When we
10 talk about an enclosure, it's enclosed on the sides
11 but not on the --

12 MR. BARTON: I understand. It's in a
13 concrete kind of box. I got you. I understand what
14 you're talking about.

15 CHAIR STETKAR: You mentioned operators.
16 Do the operators go in there once a day, once a shift,
17 once a month? How frequently does someone look in
18 there? You said they look at it when it rains but --

19 MR. COLLETT: It's on the normal rounds so
20 it's at least once per day.

21 CHAIR STETKAR: Once per day. Okay.

22 MR. COLLETT: And they look in there and
23 specifically look for standing water.

24 CHAIR STETKAR: Okay.

25 MR. BARTON: That's it.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 CHAIR STETKAR: Bill?

2 MEMBER SHACK: No.

3 CHAIR STETKAR: Mario?

4 MEMBER BONACA: No issues.

5 CHAIR STETKAR: Okay. This is amazing.

6 We'll close this session and reconvene at 1:30.

7 (Whereupon, off the record at 11:50 a.m.,

8 and back on the record at 1:29 p.m.)

9 CHAIR STETKAR: Okay. I guess we're back
10 in session. This afternoon, we're going to hear a
11 presentation from the staff on the SER, but first, I
12 understand that applicant has some answers to a few
13 questions, I guess, that were raised this morning, so
14 I'll turn it over to Progress Energy.

15 MR. CAVES: This is John Caves.
16 Appreciate the opportunity to do some research, get
17 the answers to your questions. The first thing is we
18 talked this morning about the lake level, and I wanted
19 to clarify that the license amendment request that
20 we've got submitted to the Nuclear Regulatory
21 Commission is to change the lake level from our
22 current tech spec limit of 215 feet to the originally
23 licensed level of 206 feet.

24 Back in the late 90's, as a result of net
25 positive suction head concerns with the emergency

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealgross.com

1 service water pump, we'd actually increased the
2 minimum lake level. Now we have subsequently upgraded
3 those pumps, put in different design pumps and,
4 therefore, went back to the originally licensed 206
5 feet. So I just wanted to clarify that.

6 Also, related to the lakes, the question
7 was what is the size of the main lake, and that's
8 4,000 acres, so that's several square miles. The aux
9 reservoir is 317 acres. So the main reservoir is
10 huge. The aux reservoir is 317.

11 There was a question about the T-hot,
12 operating T-hot for the plant. The design T-hot right
13 now is 621 degrees Fahrenheit. There is a slight
14 variation from loop to loop depending on, you know,
15 actual heat transfer characteristics across the
16 various three steam generators. But 621 degrees
17 Fahrenheit is the design T-hot, and we normally
18 operate right in that general area.

19 As I go through, if you need any
20 additional clarification, just stop me. Okay? The
21 next question was related to FAC, flow-accelerated
22 corrosion. Over the last ten years, Harris has
23 experienced six through-wall leaks in piping that's
24 monitored for FAC. In all of those cases, it's been
25 small-bore carbon steel piping, and small-bore is

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 defined as three inches or less in our program. And
2 the primary degradation mechanism is actually erosion
3 that's causing the degradation. FAC is present but
4 it's not the primary contributor to these particular
5 degradations that we've discovered.

6 When we found those cases, they had been
7 repaired and replacement is with FAC-resistant
8 material. Typically, it's chrome-moly. Sometimes we
9 use stainless steel or Incanel. Okay? But, you know,
10 the original findings occur in carbon steel piping,
11 small-bore and replaced with FAC-resistant material.
12 Okay?

13 MEMBER BONACA: Is the small-bore piping
14 the one that is a subject of one-time inspection?

15 MR. CAVES: NO, this is this not.

16 MR. STEWART: No, this is not that. No,
17 this would be on a secondary side.

18 MR. CAVES: This is all -- in fact, the
19 primary system that does experience this is the
20 extraction steam system.

21 We talked a little bit about CheckWorks,
22 and CheckWorks is normally not used, is not
23 recommended by EPRI to be used for the small-bore
24 piping. We do use it for the large-bore, three inches
25 or greater. We do not use it for the small-bore

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 piping.

2 Okay. Any other questions about flow
3 accelerator corrosion?

4 MR. SIEBER: What do you use for small-
5 bore piping?

6 MR. CAVES: Actually, it's operating
7 experience. We use measurements, you know, to some
8 extent, but even the measurements we found to be
9 unreliable, because there can be times when you, you
10 know, find adequate wall thickness in one area, and it
11 turns out that, you know, some number of pipe
12 diameters downstream of a control valve or something
13 like that, you can find more susceptible areas.

14 MR. SIEBER: So you'd have eddy's that
15 form in these pipes?

16 MR. CAVES: Yes. So because --

17 MR. SIEBER: -- the hands -- in general,
18 the number of pipe barriers through-wall leaks that
19 you find is going to be in small-bore piping?

20 MR. CAVES: In the --

21 MR. SIEBER: Now you can't kill anybody,
22 I don't think, with small-bore piping unless they're
23 up close, but you can damage equipment or make
24 equipment inoperable in a cubicle, so you need to pay
25 attention to the small-bore piping.

1 MR. CAVES: Yes. We're absolutely paying
2 attention to it, and we have got an aggressive
3 program, you know, continuing to move in that
4 direction. Your counsel is well taken.

5 Anything else on the flow accelerator
6 corrosion questions?

7 Okay. Another question that came up is do
8 we credit the check valves in the feed line for
9 containment isolation. And the answer is no, the
10 framework isolation valve is the only valve that we
11 credit for containment isolation in the main feed
12 system.

13 MR. SIEBER: How do you deal with single
14 failures?

15 MR. CAVES: I believe that what we've got
16 is because the system is normally filled and normally
17 flowing, I believe that that meets the requirements.

18 MR. SIEBER: I don't think so.

19 MR. CAVES: Closed system inside
20 containment.

21 MR. SIEBER: I don't think so. We'll let
22 the staff --

23 CHAIR STETKAR: I'm sure they'll come up -
24 -

25 MR. SIEBER: Yes, I can just keep saying

1 I don't think so.

2 MEMBER MAYNARD: Well, I don't think it's
3 need -- it's not applicable for probably the accident
4 of concern. There's other accidents where it is, so
5 I think it depends on which accident you're looking at
6 there.

7 MR. CAVES: Gotcha.

8 MR. SIEBER: Well, the problem is, as I
9 see it, is using a feed reg valve and its bypass as an
10 isolation valve is probably not good, because they
11 always leak through. On the other hand, I think
12 you're supposed to be single failure-proof which means
13 takes two valves to do that. The check valve in this
14 configuration won't do it.

15 MR. CAVES: Right.

16 MR. SIEBER: The staff can tell us more
17 about that when it's their turn.

18 MR. CAVES: Okay. There was a question
19 about the alarm set point for the spent fuel pool high
20 temperature alarm. And the alarm set point is 105
21 degrees, so we -- the low temperature alarm was 80 --
22 I believe eight-five. So we control between 85 and
23 105. The design temperature is higher than the 105,
24 but we don't have that number, you know, right now.
25 If you need that number, we can find it for you.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 The next question was related to the
2 manholes and cabling. The manholes that we have are
3 typically ten feet from the manhole cover down to the
4 floor. The cables normally start about three feet
5 above the floor. And what we found, there's 180
6 manholes that are on the site. And of those, we've
7 got them categorized as nonsafety-related, safety-
8 related, and for the safety-related, whether it's
9 energized or not energized.

10 If the cable is normally energized, we
11 inspect the manholes every 45 days. That would be
12 typical of the cable that goes out to the emergency
13 service water pumps and the structure.

14 The cables that are not normally
15 energized, such as the cables to the emergency diesel
16 generator, those manholes are inspected on a quarterly
17 basis.

18 There's six manholes that we frequently
19 find water levels in the neighborhood of three to four
20 feet deep. So we mention that, normally, the cables
21 start about three feet off the ground. So we've got
22 six manholes that we do find routinely, you know, at
23 or close to the surface of the water. It's certainly
24 not appropriate to say that those cables are always
25 dry. All right? So that is, you know, the condition

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 at the Harris Plant.

2 The majority of the manholes, the typical
3 level is less than 30 inches. Some are in the 2 to 3
4 inches every time we look. Some are normally about 2
5 feet to 2-1/2 feet. Okay, but that gives you a feel
6 for the distribution of what we find when we do the
7 inspections for water in these manholes.

8 CHAIR STETKAR: These -- let me make sure
9 I understand. You said that your -- if the cables are
10 normally energized, you check them once every 45 days,
11 and if they're normally de-energized, the manhole is
12 checked quarterly. Is that only for the safety-
13 related cables?

14 MR. CAVES: I apologize. I don't have
15 that answer.

16 CHAIR STETKAR: Okay.

17 MR. CAVES: I think it's primarily safety-
18 related, but I can't answer it for sure.

19 CHAIR STETKAR: We're curious because some
20 of the -- the AMP for the medium-voltage cables that
21 aren't included under the quality assurance
22 requirements, I'm not sure how they span safety-
23 related -- they're probably nonsafety-related cables,
24 so I was curious to how frequently you inspect those
25 manholes.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MR. CAVES: Yes. I'll have to get back to
2 you on that. I apologize.

3 CHAIR STETKAR: Okay. Thanks.

4 MEMBER ABDEL-KHALIK: Did I hear you
5 correctly that you said there are six manholes where
6 you frequently find water and the level of the water
7 is three to four feet from the bottom?

8 MR. CAVES: That's correct.

9 MEMBER ABDEL-KHALIK: So that the cabling
10 is --

11 MR. CAVES: May be --

12 MEMBER ABDEL-KHALIK: submerged?

13 MR. CAVES: -- under water.

14 MEMBER ABDEL-KHALIK: Are all these cables
15 de-energized normally or ---

16 MR. CAVES: No.

17 MEMBER ABDEL-KHALIK: -- some of them are
18 normally energized?

19 MR. CAVES: Some are normally energized.
20 Some are normally de-energized.

21 MEMBER ABDEL-KHALIK: Any problems with
22 the cables that are normally energized when these
23 walls flood?

24 MR. BARTON: Have you had any failures in
25 any of those cables?

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 MR. CAVES: We have had some failures of
2 a line going out to the motor-driven fire pump. We
3 had that a couple cycles ago. We are in the process
4 of implementing a cable monitoring program, but that's
5 not fully developed at this time. The testing
6 methodology that we're using for that is Tan-Delta
7 testing, and we're in the start phase of that
8 monitoring program.

9 MR. BARTON: I would ask you then what are
10 you doing about trying to eliminate that amount of
11 water in that area, because those cables are going to
12 be energized at times, and they're going to be
13 submerged. So what are you doing about eliminating
14 the water? The water is the problem.

15 MR. CAVES: That's correct. We asked that
16 ourselves that same question over lunch. I don't have
17 an answer for you at this point.

18 MEMBER ABDEL-KHALIK: Has this problem
19 been observed from day one?

20 MR. CAVES: Yes, it has.

21 MR. BARTON: It's only a 20-year-old
22 problem.

23 MR. CAVES: The cables are designed for
24 the moist environment, okay, and --

25 MEMBER ABDEL-KHALIK: But not submerged

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 environment.

2 MR. CAVES: Well, you know, that's where
3 the submerge -- the cable definition of submerged --
4 you know, rated for a submerged environment is
5 actually used for cables like -- that are buried -- or
6 not buried but transatlantic cables, so there's not
7 really a classification, as I understand it, for
8 cables in this particular environment. But this
9 environment's not abnormal for these types of cables.
10 But cable manufacturers, you know, recommend
11 monitoring. We've got that process being started, yet
12 there is potential degradation associated with that.
13 And what we have to do is we have to monitor for that
14 degradation.

15 MEMBER MAYNARD: I think it's fair to say,
16 at least from my perspective, that at the full
17 committee meeting, we'll probably want to explore this
18 a little bit more as to what you're doing to eliminate
19 the water or what your plans or justification for
20 leaving it there.

21 MR. CAVES: Sure. We'll be prepared for
22 that. Okay. At this point, any other questions about
23 the cabling? I think I'd like to turn it over to
24 Chris Mallner then for the next questions.

25 MR. MALLNER: Yes. The next question was

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 what systems contain the Class 1 small-bore socket
2 welds and about how many are there. There's
3 approximately 150 small-bore socket welds that will be
4 within the scope of the inspection of one-time small-
5 bore piping. They're in the Reactor Coolant System,
6 Safety Injection System, CBCS System, and the RHR
7 System. And currently, those things are pressure-
8 tested. They get a VT-2. Every time you come out of
9 an outage, you do the pressure test. And we'll do
10 visual inspections on those. That's currently what
11 we're doing with those right now. But that's
12 basically the population, about 150 socket welds are
13 in that program.

14 MEMBER ABDEL-KHALIK: If I may go back to
15 the manhole water issue. Could you give us an idea
16 what other systems may be affected by the cabling in
17 those six manholes that you've observed frequently
18 water accumulation?

19 MR. CAVES: Yes. The engineer that I
20 talked to didn't have that information over lunch, so
21 I'll have to get back to you on that. And that can be
22 something we follow-up on when we bring it back to the
23 ACRS --

24 MEMBER ABDEL-KHALIK: Okay.

25 MR. CAVES: -- you know, which systems are

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 potentially affected by that.

2 MEMBER ABDEL-KHALIK: All right.

3 MEMBER SHACK: Have you had any history of
4 those socket weld failures in those systems?

5 MR. MALLNER: I don't have that
6 information. I can't answer specifically.

7 CHAIR STETKAR: You mentioned CBCS is your
8 high head safety injection system in this plant?

9 MR. MALLNER: Yes.

10 MR. SIEBER: Now these are vents and
11 drains for the most part?

12 MR. MALLNER: There are some. I mean we
13 have some -- there are some generic small-bore lines
14 that are attached for vents, drains, valve leak-offs,
15 things like that, but obviously, that's not all of
16 them.

17 MR. SIEBER: It sounds like a number that
18 I would attribute to just the Reactor Coolant System
19 as far as socket welds.

20 MR. MALLNER: Well, for example, for RHR,
21 there's only two. So the great majority are part of
22 the Reactor Coolant System, but again, you're going to
23 have some offshoot into CBCS and in SI for the same
24 reason.

25 MR. SIEBER: I remember a number like for

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 a 3-loop plant, 167. They're almost all vents and
2 drains or instrument lines or impulse lines.

3 MR. MALLNER: Right.

4 MR. SIEBER: The big trick on those is
5 when you weld them up to pull them out a little bit
6 before you weld it so that the gap isn't closed until
7 you heat it up, and then --

8 MR. MALLNER: Crack the weld.

9 MR. SIEBER: Crack the weld when the --

10 MR. MALLNER: And anything else on the
11 population of socket welds?

12 (No response.)

13 MR. MALLNER: The other item we had -- I'm
14 going to turn over to Bob Reynolds -- concerned the
15 containment spray valve chambers, and Bob has the
16 information on that.

17 MR. REYNOLDS: Okay, I'm Bob Reynolds, and
18 I would like to say that this was a question -- really
19 a question we also got on the whole IWE program during
20 the audits. And there was a letter that pretty much
21 documented the containment liner and all the other
22 things including the valve chambers as well. And that
23 letter is HNP-07-112. And what I was going to do is
24 just mention some of things that we found, kind of
25 history of the valve chambers.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 In 1993, there was an indication on the
2 outside of the alpha containment spray valve chamber
3 and it was due ground water intrusion. As I mentioned
4 this morning, these chambers, these tanks are
5 partially embedded and it's not at a joint basically
6 on the building. It's between the reactor building
7 and the containment building. So there is some ground
8 water intrusion in that area. So there was some minor
9 corrosion on the surface, on the outside of the tanks.
10 There was UTs done and cleaned up and recoded, and
11 although we still do have some drainage in that area,
12 there's not been any further corrosion issues with
13 that area. That was in 1993.

14 We've also had -- and I'll just say now
15 the frequency of inspections on the valve chamber for
16 the IWE program is every other outage. So it would be
17 basically every three years is the frequency that's
18 been established for inspection. It's actually one
19 period, but you get -- but you have to do it every
20 other outage in order to achieve that according to the
21 IWE engineer.

22 The second occasion that we have some
23 information and this information that we reported in
24 this letter, but it's also part of the ISI summary
25 reports that we did send to the NRC. In refueling

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 outage nine which was in 2000 -- and I'll read this
2 here -- there was some rust and pitting was identified
3 inside the alpha containment spray valve chamber.
4 Metal thickness was above nominal thickness as
5 determined by UT, and that was -- of course, that was
6 again corrected, repaired and recoated and all that at
7 that time.

8 Again, in -- that was in 2000 -- in 2004,
9 they also had some history on that as well, and let me
10 just get to that. Okay. There was some visual
11 inspection inside the alpha containment spray valve
12 chamber and it was performed. No recordable
13 indications were observed. In addition, a visual
14 examination inside the three remaining valve chambers
15 was performed, but no recordable indications. And
16 there was one small damaged coating area in the alpha
17 containment spray valve chamber area, but that was
18 basically because they damaged the coating getting in
19 and out of the tank, and that was due to a ladder, I
20 think, that was inside there they had installed. So
21 they recoated that and so that's the history of it.

22 And in 2006, when the last inspection was
23 done, there were no recordable indications inside the
24 valve chambers as documented in the IWE ISI inspection
25 reports and also in the ISI summary report that we

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 sent to the NRC.

2 The atmosphere inside the tank, as we use
3 for the license renewal, is a dry -- inside air
4 environment. It's not normally -- I wouldn't be went
5 unless there was some leakage of a valve in there, but
6 in discussions with the coatings engineers, he never
7 noted any water inside the tank when they were going
8 in for the inspections.

9 Any other questions on that?

10 MEMBER ABDEL-KHALIK: The determination in
11 1993 that the water was caused by ground water
12 intrusion --

13 MR. MALLNER: Yes, sir.

14 MEMBER ABDEL-KHALIK: -- what was that,
15 the detail --

16 MR. MALLNER: That would be we have non-
17 aggressive groundwater at the Harris Plant, but there
18 is some areas where water does leak into the
19 buildings, and one of these locations is a location
20 between the reactor building and the containment
21 building where these containment spray valve chambers
22 are located and there was water. It doesn't really
23 say how much was coming in, but you could see evidence
24 of the rust on the outside of the tank due to the
25 water drippage in that area.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MEMBER ABDEL-KHALIK: But how is that
2 ameliorated that would allow you to say that in 2006,
3 there was no visual indication of any corrosion or
4 water intrusion?

5 MR. MALLNER: Well, in 2006, I mean when
6 they looked at the tank, there was no corrosion on the
7 inside or outside of the tank. In other words, the
8 surfaces have all been -- anywhere there was any
9 damage have always -- have been repaired. And
10 although there may be some drippage on it, there's not
11 any corrosion.

12 MEMBER ABDEL-KHALIK: But my question
13 pertains to what actions did you take in 1993 to
14 ameliorate ground water intrusion?

15 MR. CAVES: I'll have to get back to you
16 on that.

17 CHAIR STETKAR: Okay. Thank you.

18 MR. CAVES: I think that's all the
19 responses that we have. Is that correct?

20 CHAIR STETKAR: Okay. Great. Thank you
21 very much for the very, very responsive, quick. We
22 appreciate it. And with that, I guess I'll turn it
23 over to Maurice and the staff and tell us what you
24 have.

25 MR. HEATH: Thank you. Good afternoon.

1 My name is Maurice Heath, and I'm the Project Manager
2 for the license renewal application at Shearon Harris.
3 To my right is Mr. Caudle Julian who is the Lead for
4 the Regional Inspection. He's out of Region II. And
5 also in the audience, we have the staff that -- our
6 reviewers that are in the audience to answer any
7 questions that you might have with any of the issues.

8 Introduction -- I just want to step
9 through briefly what we're going to go over today, a
10 brief overview. Then we'll step into section two,
11 scoping and screening review followed by Caudle will
12 go over license renewal inspections. Then we'll go
13 back to section three, aging management review results
14 and then we'll go to section four, time-limited aging
15 analysis.

16 As a brief overview, as the applicant
17 stated earlier, but I'll just step through it a little
18 bit, the LRA was submitted by letter dated November
19 14, 2006, Westinghouse three-loop PRW, 29 megawatts
20 thermal, 900 megawatts electric. The operating
21 license expires October 24th, 2026, and the plant is
22 located approximately 20 miles southwest of Raleigh,
23 North Carolina.

24 Safety evaluation report with open items
25 was issued March 18th, 2008. We had one open item and

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealgross.com

1 two confirmatory items. During the audit process, we
2 asked 346 audit questions. And during the review, we
3 also had 75 requests for additional information --

4 MR. BARTON: That's a low number of RAIs.
5 Is that -- can you explain that? I know the audit
6 team did a real good review of all the aging
7 management programs and had lots of questions. Would
8 that have affected the number of RAIs the staff issue,
9 because this seemed to be a number of RAIs on an
10 application, I thought.

11 MR. SIEBER: Yes. It's about a third of
12 --

13 MR. BARTON: Right.

14 MR. HEATH: Possibly, because during the
15 audits, we covered the majority of section four and
16 section three which is the majority of the
17 application, so that could possibly be one reason why
18 the RAIs are such. That's why we have quite a few
19 audit questions, because we did amount of work during
20 those three audits.

21 MEMBER BONACA: Those other questions were
22 through reactive change or they were formally written?

23 MR. HEATH: They were written and they
24 were actually -- we submitted, with the audit summary
25 report, a database with the --

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 MEMBER BONACA: So everything was pretty
2 much documented --

3 MR. HEATH: Yes.

4 MEMBER BONACA: -- in fact, to replace the
5 RAIs?

6 MR. HEATH: Yes.

7 MEMBER SHACK: Those are face-to-face and
8 then you record them basically, right? I mean that's
9 the --

10 MR. HEATH: Correct. We interviewed the
11 site staff engineers onsite and everything, so.

12 MEMBER SHACK: So there is a record but
13 you get more immediate direct feedback --

14 MR. HEATH: Correct. And we also had 35
15 commitments in the SER, and right now, because of the
16 two confirmatory items, the applicant estimated a
17 letter that had two additional commitments which
18 brings it the total now to 37, and I'll go over those
19 a little bit later.

20 This is just a brief highlight of the
21 weeks we were onsite for audits. I won't read each
22 step. Now starting with section two. Section one was
23 scoping and screening methodology, and after the
24 staff's audit and review, the conclusion was that the
25 applicant's methodology is consistent with the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 requirements of 10 CFR 54.4 and 54.21(a)(a).

2 And that's where we'll go to section two,
3 which consists of the one open item. I'll just go
4 through a brief summary of the open item. In the
5 license renewal application, the applicant states that
6 the feedwater regulating and bypass valves are
7 nonsafety-related. Chapter 10 and 15 of the Harris
8 FSAR credits these valves for a redundant isolation
9 function in the event of a main steamline break. The
10 applicant's methodology referred to the industry
11 guidance NEI 91-10 rev. 6 which infers that these
12 components would be in scope per 10 CFR 54.4(a)(1).
13 And in the application, it was designated they were
14 in-scope with 54.4(a)(2).

15 MEMBER BONACA: Let me understand now and
16 if you go to line break -- in a steamline break,
17 whatever analysis you're doing on a steam generator,
18 if you're assuming that the main steam isolation is
19 the main -- if water isolation fails, do they isolate
20 through the bypass? Is that what the second bullet
21 means?

22 MR. JONES: This is Steve Jones in
23 balance-of-plant branch of NRR. The main fed reg
24 valves are credited to reduce the amount of main
25 framework flow delivered to the steam generators to

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 prevent excessive cool down allowing the boration of
2 the primary to maintain a negative or a shutdown
3 condition within the core. I guess they're not fully
4 required to be leak tight, but -- and they also serve
5 a secondary function of preventing over-pressurization
6 of containment in the event of too much mass edition
7 to containment during a steamline break.

8 MEMBER BONACA: So they're used in the
9 analysis, in the Chapter 15 analysis?

10 MR. JONES: Right, in the event of a
11 single failure of the main feedwater isolation valves.

12 I guess the staff's concern here was
13 predominantly regarding whether or not additional
14 components surrounding the valve should be brought
15 into scope in the possibility that some type of age-
16 related degradation could cause the valves to have a -
17 - be in a latent condition where they would not close
18 on demand. Since typically the feed reg valves have
19 a separate solenoid valve that would relieve air
20 pressure and allow the valves to close, that would not
21 be indicated as operational during routing operation.

22 And I guess a statement from the licensee
23 such as that if air pressure is lost, the valves would
24 fail closed or if water were introduced into any of
25 the electrical connections, it would cause the valve

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 to close, that would be sufficient to resolve the
2 issue as well as, I guess -- or otherwise evaluating
3 the components surrounding the valve. That's the real
4 focus, not really whether or not it's (a)(1) or not.

5 MEMBER MAYNARD: I'm sorry, I just need to
6 -- okay, the major concern is for a steamline break
7 and in coincidence with a failure of the main feed
8 isolation valve? From that point on -- I'm trying to
9 understand a little. We're dealing with a license
10 renewal issue here or a current licensing issue?

11 MR. JONES: Well, from the current
12 licensing basis, the staff understands these valves
13 were configured, and in a number of plants, are
14 configured as nonsafety-related valves in that they're
15 not protected from tornado missiles, from missiles
16 generated within the turbine building and high-energy
17 line breaks. And the basis for that was that the
18 probability of those events occurring coincident with
19 a steamline break within containment is low enough
20 that they need not be considered.

21 But in the area of aging management, we're
22 talking about potential for these carbon steel piping
23 systems that are all around. The feedwater system
24 could be leaking or that the air lines going to these
25 valves that typically have raised connections could be

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 aging and weakening over time and just verifying that
2 that age-related phenomenon doesn't cause some latent
3 condition that would prevent these valves from serving
4 their backup function.

5 MEMBER MAYNARD: I'm still struggling,
6 though, current licensing basis versus license
7 renewal. And I understand your aging, but what you're
8 really doing is saying for an extended 20 years, these
9 should be safety-related.

10 MR. JONES: No. We're saying that aging
11 management programs should be applied to the feedwater
12 system if there is a way for those types of failures
13 to cause a failure of the reg valve to actuate and
14 it's a safety-related or -- I don't want to get into
15 safety-related, nonsafety-related -- but in its
16 Chapter 15 functioning.

17 MEMBER MAYNARD: Well, I'm trying to
18 understand that. So you're not saying that these have
19 to be reclassified to safety-related?

20 MR. JONES: No.

21 MEMBER MAYNARD: Okay. By then putting it
22 into the (a) (2) versus the (a) (1) part of it, doesn't
23 that accomplish what you're needing or -- I --

24 MR. JONES: It would --

25 MEMBER MAYNARD: I'm trying to understand

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 what --

2 MR. JONES: It would with an additional
3 step. I guess we're looking for, okay, it's in-scope
4 for (a)(2). I believe there was an addition or a
5 modification to their initial application to call the
6 valves (a)(2), and then we -- that was my
7 understanding. And then the -- a statement -- I think
8 we've accepted in the past a statement that if the
9 valve -- if the air system fails, the valve fails
10 closed. If the electrical components that would cause
11 the valve to close for the Chapter 15 function, loss
12 of voltage there would cause the valve to close, then
13 we don't need to look around the valve for any other
14 failures.

15 MR. HEATH: I'm going to step in and get
16 the record straight for one thing. In the
17 application, those valves are actually in-scope for
18 (a)(2). So that was actually in the application. I
19 just wanted to make sure that was -- I think it just
20 misspoke --

21 MEMBER MAYNARD: I'm trying to figure out
22 whether they're --

23 MR. HEATH: And to answer your other
24 question, that kind of gets into a COB question,
25 because the rule for license renewal states that

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 safety-related SSC, so their COB says that these are
2 nonsafety-related, so that --

3 MEMBER MAYNARD: Most Westinghouse plants
4 have this design, you're saying?

5 MR. HEATH: Correct.

6 MEMBER MAYNARD: But you're saying they
7 don't have to be reclassified as safety-related,
8 right? But I'm just trying to see how close we are
9 here on the delta here as to what -- you know, they
10 proposed (a)(2), and you're saying in addition to
11 that, what?

12 MR. JONES: Well, as I had indicated, if
13 you apply the NEI methodology, you would typically
14 call it (a)(1). The key point about that is that if
15 you call it (a)(1) and continue to apply the NEI
16 methodology, you would look around for spacial
17 interactions. But I guess if you go back to the
18 baseline rule, the (a)(2) part of 54.4 states that if
19 a component failure could cause an age-related
20 failure, could cause failure of the function, an
21 (a)(1) function, then it should be within scope per
22 (a)(2).

23 Since the feed reg valve performs
24 essentially an (a)(1) function, then it's credited for
25 a Chapter 15 accident. That's why we're looking

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 around that -- is there something that could cause a
2 failure of that valve performance function. I guess
3 that explains the open item --

4 MEMBER ABDEL-KHALIK: In a steamline
5 break, what is the signal that causes the people at a
6 reg valve to modulate close --

7 MR. JONES: The same signal --

8 MEMBER ABDEL-KHALIK: -- and what is the
9 signal that causes feedwater isolation?

10 MR. JONES: It's the same safety-related
11 signal, I mean steam isolation --

12 MEMBER ABDEL-KHALIK: Which is what?

13 MR. JONES: Main steam isolation signal at
14 Harris.

15 MEMBER ABDEL-KHALIK: And that's based on
16 what parameter?

17 MR. JONES: I think I'd have to defer to
18 Harris. I believe it gets inputs from containment
19 pressure and feed flow/steam flow mismatch. I'm not
20 sure.

21 MEMBER ABDEL-KHALIK: Is the peak
22 containment pressure that you calculate in this
23 scenario based on the fact that the feedwater reg
24 valve will modulate closed?

25 MR. JONES: Excuse me, I didn't hear that

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 full question.

2 MEMBER ABDEL-KHALIK: The peak containment
3 pressure that you calculate during that scenario
4 assumes that you will reduce feedwater flow so that
5 the total amount of water or steam discharge into the
6 containment is reduced?

7 MR. JONES: Correct.

8 MR. SIEBER: One steam generator full.

9 MEMBER ABDEL-KHALIK: So the calculated
10 peak containment pressure is predicated on these
11 valves working correctly?

12 MR. JONES: On feedwater isolation
13 working, yes, whether it's this valve or the main
14 feedwater isolation valves.

15 MEMBER BONACA: Or if you assume the
16 failure of the main steam -- main feedwater isolation
17 valve, then you rely on this to get the peak pressure.

18 MEMBER ABDEL-KHALIK: Okay.

19 MR. SIEBER: In effect, if we imply the --
20 or if we look at the implications of the licensing
21 renewal rule, that changes your current licensing
22 basis for this plant?

23 MR. HEATH: Can you state that again, I'm
24 sorry?

25 MR. SIEBER: Between (a)(1) and (a)(2), if

1 you apply the way the license renewal rule is written
2 to this plant, it seems to me that it changes the
3 current licensing basis for nonsafety-related to
4 safety related. Is that true?

5 MR. LEE: Yes, this is Samson Lee from
6 License Renewal, Dr. Sieber. Yes. We heard your
7 comment but license renewal does not change the
8 current licensing basis.

9 MR. SIEBER: It should not.

10 MR. LEE: Okay. It's not a safety or
11 statement on safety in your licensing basis, but the
12 thing is that for license renewal, we define a scope
13 for license renewal. So anything that meets that
14 scope definition, okay, that performs its function and
15 is defined in the rule, if you perform the function,
16 you're in (a)(1). Okay? If your failure can prevent
17 something else from performing the (a)(1) function,
18 you're in (a)(2).

19 MR. SIEBER: Okay. Thanks.

20 MR. HEATH: Do we have any more questions
21 on this open item?

22 CHAIR STETKAR: Yes. As long as it's
23 open, I'll ask you the same question that I asked the
24 applicant this morning, and that is they said they
25 believe they see a path forward to resolving this. Is

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 that your interpretation also? Do you feel --

2 MR. HEATH: Yes. That's our
3 interpretation that we do have a path forward, but
4 until we get, you know, the documentation in-house, we
5 really don't now exactly what it says, so we can't --
6 I can't comment further on that. But we do believe
7 that we have a math.

8 MEMBER BONACA: We're going to hold our
9 breath?

10 (Laughter.)

11 CHAIR STETKAR: Apparently, we need to
12 wait for chapter two.

13 MEMBER MAYNARD: I think there's two
14 issues and one's a legal issue.

15 CHAIR STETKAR: That's right.

16 MEMBER MAYNARD: You know, the other is
17 what are the real safety implications and everything
18 there. And, you know, I'm not sure what needs to be
19 done to assure, but, you know, most things are going
20 to cause the valves to close, pumps are going to trip.
21 There's a number of ways to stop the -- I'm not overly
22 concerned from the safety standpoint. You know,
23 what's been done in the past, I think, is going to be
24 fine for the future. But I think you got to work
25 through the legal issues of that and, you know, what

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 needs to be done aging management wise to provide
2 that.

3 MR. SIEBER: Well, there is a potential
4 for an accident, as Said said. If you have a
5 steamline break and you keep pumping water into a hot
6 steam generator, pressure and containment is going to
7 go up and up and up until something stops it. What
8 you're relying on in a single failure is that feed reg
9 valve.

10 MEMBER BONACA: Right.

11 MEMBER MAYNARD: Well, the feed reg valve
12 tripping the -- you know, you also trip main feedpumps
13 and you have other things that trip themselves from
14 going in there.

15 MR. SIEBER: Yes.

16 MEMBER MAYNARD: Yes. You're relying on
17 a nonsafety system to provide an important function.

18 MR. SIEBER: But you got to pick something
19 and that's -- they picked on the valve.

20 MEMBER BONACA: You have they just liked
21 the single feature and you can credit the system here
22 to give you the results, yes?

23 CHAIR STETKAR: These valves at Shearon
24 Harris are air operated valves, air to open, they'll
25 close?

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MR. SIEBER: Yes, solenoids operate the
2 air. They fail closed.

3 CHAIR STETKAR: Do you normally operate --
4 I'm trying to thing a big about things that could
5 prevent them from closing which is basically what
6 we're talking about here. Obviously, the feed reg
7 valves are normally operating. The bypass -- do you
8 ever use the bypass valves?

9 MEMBER MAYNARD: You also have manual
10 isolation valves, but normally, it takes a while to
11 set the manual isolation valves.

12 MR. SIEBER: You have to get somebody to
13 go out there.

14 CHAIR STETKAR: Just to find -- okay,
15 thanks.

16 MR. HEATH: Section 2.3, Mechanical
17 Systems. There were 110 mechanical systems
18 identified, 72 of which are balance-of-plant. One
19 hundred percent were reviewed during this. Now the
20 balance-of-plant review, there is a Tier 1 and Tier 2
21 review. The Tier 1 review took into account 41
22 systems, and the Tier 2 review took into account 31
23 systems, and the difference between Tier 1 and Tier 2
24 is that Tier 2 reviews the detailed review of the
25 boundary drawings.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 Now during the scoping and screening
2 review, the staff a few areas which were difficult on
3 the boundary drawings. It was difficult to assess the
4 non-safety systems interacting with safety which is
5 54.4(a)(2), so the staff requested that the regional
6 inspection team verify these areas to ensure that the
7 applicant properly implemented criteria for 10 CFR
8 54.4(a)(2). And the inspectors found no potential for
9 space or interaction between nonsafety and safety-
10 related SSCs at these locations.

11 CHAIR STETKAR: Maurice, I only had one
12 question reading through your decisions for Tier 1
13 verus Tier 2, and that is I notice that the steam
14 dumps and I've forgotten what else -- main feedwater
15 system certainly was in your Tier 2 review which is
16 more detailed -- but the condensate system -- the
17 steam dumps, circulating water and feedwater system
18 were included in Tier 2 based on their risk
19 significance. That's the words I found. However, the
20 condensate system was not included in Tier 2, the
21 implication that, for some reason, the condensate
22 system is much risk significant than those other
23 systems. And that struck me as a bit odd since the
24 condensate system feeds the feedwater system. Do you
25 know why that decision was made?

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MR. HEATH: Not -- I have to let balance-
2 of-plant, Steve to answer if he knows the answer to
3 that one.

4 MR. JONES: This is Steve Jones in
5 balance-of-plant branch. The -- I guess typically
6 with regard to -- you mention like the circulating
7 water system would get a more detailed review because
8 often it's associated with internal flooding scenarios
9 that could affect large parts of the plant. Feedwater
10 is a little more safety-significant with respect to
11 while it does provide the same function as condensate
12 in terms of providing a normal heat sink to the steam
13 generators, it also is a potential high-energy line
14 break source, more so than the condensate system. And
15 typically, it goes in areas of the plant where there
16 are more -- there's more equipment that could be
17 vulnerable to high-energy line break issues. I think
18 that's the distinction or was there another system
19 that --

20 CHAIR STETKAR: Steam dumps -- against the
21 steam dumps.

22 MR. JONES: Steam dumps -- again, they're
23 credited as a normal heat removal path. I guess --
24 was it the atmospheric steam dumps or just the
25 turbine?

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 CHAIR STETKAR: You know, they're only
2 called steam dumps in the thing that I read, so -- I
3 thought they were probably the condenser steam dumps
4 but I'm not sure.

5 MR. JONES: I believe they're meant to be
6 atmospheric steam dumps, and those are safety-related
7 components.

8 CHAIR STETKAR: Okay. I was just -- you
9 know, the implication in what I read said because of
10 risk significance, and I was curious what type of risk
11 significance rating was used to make those decisions.
12 But I understand the high energy line break. That
13 could throw things into one category or another.
14 Okay. Thanks.

15 MR. HEATH: And Section 2.4, the
16 Structural Systems, during the review, we brought one
17 component into scope which was the insulation on low-
18 temperature, small-diameter containment penetrations.
19 And Section 2.5, Electrical Instrumentation and
20 Control Systems, there were no omission of electrical
21 and instrumentation and control system components
22 within the scope of license renewal.

23 In summary of Section 2, applicant's
24 methodology, scoping and screening methodology meets
25 the requirements of 10 CFR 54.4 and 54.21(a)(1), and

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 the scoping results, as amended and pending open item
2 2.2 resolution includes all SSCs within the scope of
3 license renewal and subject to AMR. Now with that, I
4 want to turn it over to Caudle to discuss the Region
5 II inspections.

6 MR. JULIAN: You've seen these slides
7 before. They're the generic ones that I usually use
8 to talk to you. The scoping and screening
9 inspections, the objective of what we're trying to do
10 there is to confirm the applicant has included in-
11 scope all appropriate SSCs. And we, if you recall, a
12 year or so ago rewrote our manual chapter to decrease
13 our work in the area of scoping and screening when we
14 recognized it was somewhat of a duplication of the
15 work that NRR is doing that you just heard described
16 in Tier 1 and Tier 2. We primarily have looked at
17 things that are in doubt. The focus of those is on
18 the 54.4(a)(2) situations where nonsafety-related
19 could affect safety-related. We're asked to look at
20 those sometimes.

21 Our license renewal program is described
22 in manual chapter 2516 and the inspection procedure
23 itself is 71002. We developed a site-specific
24 inspection plan for each applicant, and it's scheduled
25 to support NRR's review, usually six to nine months

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 after the application comes in. Region II uses a
2 consistent team of five inspectors to do these
3 inspections. We kept the same people on them as best
4 we can all the time. And when we lose somebody, we
5 have a training program for their replacement,
6 inspectors.

7 The objective of these inspections now is
8 mainly focusing on aging management programs, to
9 confirm that the existing aging management programs
10 are working well and to examine the applicant's plans
11 for establishing any new aging management programs or
12 enhancing the existing ones..

13 Inspection is two weeks in length and with
14 a week off in between and a week onsite -- a week off
15 in between and the second week onsite.

16 We examine the records of past tests,
17 surveillances, operating experience for the equipment
18 in question and corrective actions that have been
19 taken for existing aging management programs. And we
20 examine implementation plans for new and standard
21 AMPs, verify the inclusion of any future tasks into an
22 established site task-tracking system, make sure that
23 they track the things that need doing in the future
24 before entering the period of extended operation. And
25 we do system and plant walkdowns to verify that the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 material condition of the plant is being adequately
2 maintained.

3 MEMBER BONACA: Do you share experience
4 with the other Regions regarding the --

5 MR. JULIAN: Yes, we do.

6 MEMBER BONACA: You do, right?

7 MR. JULIAN: Yes, we do. We started out
8 that way by using inspectors interchangeably between
9 Regions I and II and then between II and III and II
10 and IV, and we've kept that up. We loan people back
11 and forth for cross pollination of information and
12 issues, and that's still going on today.

13 We have the option -- this slide just
14 talks about an optional inspection to follow-up on any
15 open items. If we end up at the end of two weeks and
16 there are things that we don't feel we have enough
17 information, we can do that. We have determined that
18 we don't think that's necessary in the case of Harris.
19 We think things came out very clean and we do not
20 intend to follow-up inspection on open items from this
21 current inspection.

22 The results at Shearon Harris -- our
23 inspection was conducted the dates you see, July 9th
24 through the 27th. Our conclusions, big picture, were
25 the existing programs to be credited is aging

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 management programs for license renewal are generally
2 functioning well. And in walking down plant systems
3 and examining plant equipment, the inspectors found no
4 significant adverse conditions. And it appears to us
5 that the plant equipment was being maintained
6 adequately.

7 MR. BARTON: What does that mean? I see
8 that all the time. What does it mean when I see it's
9 maintained adequately? What's your definition or
10 what's your criteria for using that terminology?

11 MR. JULIAN: I guess everyone would have
12 a different perspective on it. I think our
13 perspective is that our inspectors go to most of the
14 Region II plants. They're mainly out of Division of
15 Reactor Safety. And we see the condition of the
16 equipment in the plant the same as the other power
17 plants that we see. We're continually comparing --

18 MR. BARTON: One of the definitions of
19 adequate is that it's barely sufficient or
20 satisfactory, so I want to know where you're spectrum
21 is. I don't ever remember seeing the words that the
22 team has used that says that equipment is well-
23 maintained. I only see maintained adequately. So
24 every plant in the country is maintained adequately,
25 and I don't really understand what that means.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MR. SIEBER: Well, you have a choice of
2 two.

3 MR. BARTON: What?

4 MR. SIEBER: It's a choice of two. It's
5 either adequate or inadequate.

6 MR. BARTON: All right.

7 MR. JULIAN: I tend to use the terminology
8 of adequate, because I think that adequate is
9 satisfactory, and it's not outstanding.

10 MR. BARTON: Okay. It meets the
11 regulations?

12 MR. JULIAN: That's correct.

13 MR. BARTON: Or it meets your standards?

14 MR. JULIAN: That's correct. And it --

15 MR. BARTON: That's what that means.
16 Okay.

17 MR. JULIAN: That's correct. And it's
18 based on our -- all my people's observations from
19 other plants. I'm hesitant to use the word
20 outstanding when it comes to plant --

21 MR. BARTON: I didn't say outstanding.
22 Well-maintained would be something that would mean
23 more to me than maintained adequately.

24 MR. JULIAN: Okay.

25 MEMBER BONACA: And I just never see that.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 I'm just trying to get your feeling of what you meant
2 by that. Okay. So it meets the regulations, I guess.

3 MEMBER ABDEL-KHALIK: Has any of these
4 regulators seen inside the containment spray valve
5 chambers?

6 MR. CAVES: I do not think we have -- the
7 containment spray valve chambers. I remember when we
8 were looking in that area, that condition, I saw the
9 external surfaces, I did, of those chambers if it's
10 what I'm thinking of. It's a valve chamber. I
11 believe it's hooked up to the containment. It
12 contains the isolation valves inside there. And we
13 talked about the history of those valves and what --

14 MEMBER ABDEL-KHALIK: Well, you've never
15 seen the inside?

16 MR. JULIAN: I have not, no. I don't know
17 if our -- maybe if Progress has any information on it.
18 Have there been any of our ISI inspectors happen to be
19 there when those were open? We do an ISI baseline
20 inspection to every unit every outage for a one-week
21 inspection, in-service inspection.

22 MR. BURTON: I cannot answer that
23 question.

24 MR. JULIAN: Don't know.

25 MR. SIEBER: But that's inside containment

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 so for you to see it when the plant's running, you
2 have to go through the containment and down to it?

3 MR. JULIAN: These penetration capsules
4 that we're talking about have a portion inside and
5 outside. Right.

6 MR. REYNOLDS: This is Bob Reynolds,
7 Progress Energy.

8 MR. JULIAN: Yes, Bob.

9 MR. REYNOLDS: The -- same as we were
10 speaking of earlier, they're partially embedded in the
11 containment wall and also in the lower area of the
12 reactor auxiliary building which we did observe when
13 we walked down to the lower area. Yes. They're not
14 accessible to my understanding here in operation.
15 You'd have to look at them during an outage.

16 MR. JULIAN: Can't look inside of it --

17 MR. REYNOLDS: That's correct.

18 MR. JULIAN: -- but you can see the
19 external surface.

20 MR. BARTON: When you did your
21 inspections, was the plant not in an outage? Were you
22 able to inspect material conditions inside
23 containment?

24 MR. JULIAN: When we did this team
25 inspection, the plant was running, but as part of our

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 inspection -- I didn't put it in the slides -- Luis
2 Reyes has always insisted that we include a look see
3 inside at least one unit of a two-unit site. And so
4 we relied, in this case in Harris, on our previous ISI
5 baseline inspection:

6 MR. BARTON: Which was during a refuel --

7 MR. JULIAN: During an outage, right. And
8 we send one of our inspectors in with the licensees to
9 go a complete walk of the containment, top to bottom
10 and --

11 MR. BARTON: So part of his inspection is
12 looking at material condition of the equipment inside
13 containment?

14 MR. JULIAN: That's correct. He knows
15 that he's part of the license renewal inspection team.
16 We have just completed that, for example, on Vogel's
17 last outage.

18 CHAIR STETKAR: When was that walkdown
19 done for Harris?

20 MR. JULIAN: I'm sorry, I don't have the
21 dates. I would say it was before this inspection, so
22 it would have been the previous outage before --

23 CHAIR STETKAR: Within the last couple of
24 years or --

25 MR. JULIAN: Oh, yes, it's --

1 CHAIR STETKAR: Okay.

2 MR. JULIAN: We try to set it up just
3 before the team inspection if we can, and so we have
4 to catch the previous outage. And we used to go do a
5 totally separate look see, but then it came to us,
6 well, we're doing in-service inspection anyway, and
7 that inspector's going to go inside containment
8 looking for boric acid. The boric acid program has
9 received a lot more emphasis in the last few years,
10 and so while he's doing that, we put him on our team.
11 He's also inspecting for evidence of aging inside the
12 containment, and he goes with the licensee folks. So
13 we're jotting down anything we see and we get an
14 explanation for it.

15 MEMBER BONACA: So you're also looking at
16 the corrective action program in a way?

17 MR. JULIAN: Yes.

18 MEMBER BONACA: Because you're looking at
19 conditions that you might find. Do you go back to see
20 the effectiveness of their corrective action program?

21 MR. JULIAN: When we run upon things of
22 that nature, we've pursued them.

23 MEMBER BONACA: Of course, you have the
24 results of previous inspections anyway. I mean so --

25 MR. JULIAN: We've -- very seldom have we

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 run upon a real serious condition that needs attention
2 so far. There have been some leakage in, typically,
3 component cooling water lines and leakage inside
4 containment's a problem. And, of course, like I say,
5 we're putting a lot of emphasis on boric acid deposits
6 these days.

7 What we saw at Shearon Harris, I'll just
8 give you a few examples. The applicant had
9 established and implemented plans in their plant --
10 they call it their action request system -- to track
11 the committed future actions for license renewal to
12 ensure that they get completed. And we thought they
13 did a good job of that at Harris. That's something we
14 worked on with Robinson and then Brunswick, and we
15 thought they did a real good job at Harris.

16 And Region II, of course, will follow-up
17 on these things during the follow-up inspection.
18 NRC's intentions are we're getting a lot of promises
19 that so and so is going to be done before entering the
20 period of extended operation. And so we intend to do
21 another round of inspections using inspection
22 procedure 71003. That'll be starting shortly before
23 they enter the period.

24 Specifics -- I picked a few examples. The
25 NRC inspectors identified several areas where

1 enhancements could be made in the performance of
2 existing programs. An example I use happened to be
3 one you talked about this morning -- when I looked
4 into their manholes checking for water, and they had
5 a quarterly preventative maintenance task of pumping
6 out existing water. And the folks that were doing
7 that were craftsmen, and they were dutifully writing
8 down what they saw out there. And I asked well, where
9 does that information go, and he didn't know.

10 And so I started asking the system
11 engineer, and the system engineer was fairly new in
12 that particular assignment, and he wasn't getting that
13 information. And so after we discussed it, now
14 they're routing those completed PM tasks back to the
15 system engineer so that he gets the information
16 automatically and has it there for tracking and
17 trending purposes.

18 They measure, my recollection is, the
19 water in the manholes with something very simple like
20 a dip stick, as I remember, that they do quarterly.
21 And so they're looking to see if there's water there,
22 and the craftsmen do it routinely. And so they have
23 a memory of what's there. Periodically, they go
24 actually lift the heavy concrete lids and look inside
25 there. And these are more like cabled vaults than

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 manholes. They're very big, huge concrete vaults.

2 And we looked inside, asked them to open
3 them,, and we opened one on the cable run that goes
4 from the aux building to the diesel generators, vice
5 versa, diesel generators to the aux building, and one
6 on the run that goes from the aux building down to the
7 service water intake structure. And both of those
8 looked in good condition to me relative to what I've
9 seen other places based on my experience there. I
10 have seen some places where the darn things are
11 flooded when we open them up.

12 MR. SIEBER: So these were adequate?

13 MR. JULIAN: But these were adequate. I'm
14 sorry. NRC also learned that the applicant had
15 previously identified that there had been problems
16 with the past management and implementation of the in-
17 service inspection program. The applicant had an
18 improvement plan in place and were committed to add
19 resources to recover the ISI program. And Region II
20 followed up on that issue.

21 The ins-service inspection program is a
22 very important one we think. It's credited as an
23 aging management program, and when we came upon the
24 scene there, we thought that due to people's
25 retirement that had been doing that work for a long

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 time and replacement with people who had just come on
2 the scene that the program had kind of fallen a little
3 bit behind. Their program records are not up to date.

4 And there was a commitment that they made
5 way back when in the FSAR to do an augmented
6 inspection on the feedwater lines as they come into
7 the containment and the steamlines, and it looked like
8 they could find no record that that had ever got done.
9 And so they went to work and got some new folks on the
10 scene and brought those programs up to date and
11 performed those augmented inspections.

12 And we went back during our next baseline
13 ISI inspection and followed up on those and think that
14 Harris corrected that matter in good shape.

15 MEMBER ABDEL-KHALIK: If the water levels
16 in these wells had not been trended, where is that OE
17 recorded? Where is that information?

18 MR. COLLETT: The information is recorded
19 in the work orders.

20 MR. JULIAN: They have plan --

21 MR. BARTON: Where does that go?

22 MR. COLLETT: Work orders are simply the
23 orders for the guy to pump out the manhole --

24 MR. SIEBER: Yes and there's blanks that
25 say what you find.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MR. JULIAN: They've simply been filed.

2 MR. SIEBER: They're permanent documents.

3 MEMBER ABDEL-KHALIK: If one is trying to
4 find out if any of the MSPI systems had at one time
5 been affected by this, how would one go about doing
6 that?

7 MR. CAVES: We'll be doing that in
8 preparation for the full ACRS meeting, so what we will
9 have to do is go back, as I had mentioned earlier --
10 this is John Caves one more time -- the initial
11 inspections were performed in the 2003 timeframe.
12 Okay, prior to 2003, we did not have the PMS in place
13 that we do right now. Once we put the PMS in place,
14 though, you know, the information then recorded in the
15 work orders and the system engineer will go back to
16 those work requests that are in the records management
17 system as QA records and pull that information out and
18 present that to us. That's the mechanism that we'll
19 use to get that data.

20 MEMBER ABDEL-KHALIK: How far back does
21 that --

22 MR. CAVES: 2003.

23 MEMBER ABDEL-KHALIK: Okay.

24 MEMBER BONACA: So before 2002, this was
25 not considered a condition corrected?

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MR. CAVES: Prior to 2003, we didn't have
2 a formal program to monitor and measure the actual
3 water in the manholes.

4 MR. JULIAN: I think this kind of started
5 to surface as an industry issue in 2001 --

6 MR. CAVES: Yes. It was about that
7 timeframe.

8 MR. JULIAN: -- 2003 and people who had no
9 program at all but were starting to come around to
10 build such a program.

11 MEMBER ABDEL-KHALIK: Thank you.

12 MR. JULIAN: And unless you have further
13 questions, that concludes what I brought to say --
14 oops, one more. Pardon me. Often, the Subcommittee
15 is asked about what is the current performance of
16 Shearon Harris, and so I pulled up our slide that's on
17 our external website for performance indicators, and
18 as you can see, all the performance indicators are
19 green. And I consider Shearon Harris to be a good
20 operating plant at the current time, and their history
21 is good with us. That's all I have. Maurice?

22 MR. HEATH: All right. Now I want to
23 start with Section 3, Aging Management Review results,
24 and these are the sections in Section 3. What I'm
25 going to do is just highlight portions of the review.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 First, Section 3.03 is the aging management programs,
2 and there were 40 aging management programs, 12 which
3 are new programs, 1 which was added as a result of
4 review which I'll discuss next slide, and there were
5 28 existing programs.

6 As I said, the program that was added as
7 a result of the onsite audit is the oil-filled cable
8 testing program. During that audit, one of the NRC
9 staff asked the question about the 230 kV cables from
10 the switchyard to the startup transformers. There
11 appeared to be an aging effect for these oil-filled
12 cables. However, there is a lack of an aging
13 management program, so the applicant added an oil-
14 filled cables testing program to address this need.
15 And this program will periodically test the cable to
16 determine the cable insulation properties.

17 MR. SIEBER: This is just a Megger exam?

18 MR. HEATH: I'm sorry, I didn't hear you.

19 MR. SIEBER: Is this just a Megger
20 examination?

21 MR. HEATH: Well, with this, they have
22 options on how they want to do the examination, so I
23 mean --

24 MR. HEATH: This is Mike Heath. We
25 currently do Dolby testing every four years on --

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MR. HEATH: One of our two confirmatory
2 items come from Section 3.4 and this is basically, the
3 applicant credits managing changes in materials and
4 cracking of elastomeric and thermoplastic piping and
5 piping components with the external surface monitoring
6 program. Now the GALL AMP does not specifically
7 address these components or provide any provisions for
8 inspection methods. So the applicant has proposed to
9 use a preventative maintenance program which will
10 periodically replace these components based on
11 operating experience and vendor recommendations.

12 MR. SIEBER: Where do you use elastomeric
13 and thermoplastic pipe? Is that bed plate drains or -
14 - I've seen it used there but I'm curious as to where
15 you use it.

16 MR. MALLNER: This is Chris Mallner from
17 Progress Energy. the components in question were some
18 -- we had some hoses on the main steam PORVs. We had
19 a breather cap. We had a polyethylene sample line in
20 the sampling system, and there was a rubber hose and -
21 - that connected air to the feedwater reg valve tanks.
22 And the other component was another plastic that went
23 to flow instrumentation associated with the condensate
24 system. That was it. Those are the components we're
25 talking about.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 So instead of trying to age-manage them,
2 as Maurice said, we've decided we're just going to
3 replace them.

4 MEMBER BONACA: So really, you're taking
5 them out of the aging program?

6 MR. MALLNER: Correct.

7 MEMBER BONACA: They're not part of
8 license renewal anymore?

9 MR. MALLNER: Correct.

10 MR. SIEBER: Yes. I'm not sure how you'd
11 determine the remaining life of a rubber hose.

12 MR. HEATH: Section 3.5 is aging
13 management of inaccessible concrete. Now what this
14 table shows is readings from two wells, 57 and 59 and
15 just gives the pH, chlorides and sulfate values and
16 showing that they have met the acceptance criteria, so
17 they're below grade environment is nonaggressive. But
18 looking forward in license renewal, the ground water
19 testing will be performed in a yearly interval by the
20 Structures Monitoring Program in the period of
21 extended operation.

22 MEMBER BONACA: Do you have any idea why
23 you have the difference in chlorides --

24 MR. BARTON: Chlorides in two wells, yes.

25 CHAIR STETKAR: Well, it's not only -- to

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 interrupt here for a second, the things that I read
2 were that during early life, there were several more
3 wells that they monitored and the chlorides and all of
4 those wells were substantially lower than this 290
5 also. So that 290 seems to be a real singularity.

6 MR. REYNOLDS: This is Bob Reynolds with
7 Progress Energy again. I can answer that. We
8 selected these two wells based on their proximity to
9 the plant. The closest one is of the over wells that
10 we had established back during -- maybe during the
11 construction period of time. And so we just sampled
12 these particular two. When you saw all of this, a
13 question came up about the variation between two
14 wells, 290 and 42 on the chlorides. We wen back last
15 week actually and did another test. And actually, we
16 came up with the same readings again on the same two
17 welds. So we thought maybe we might have had a
18 decimal place off or something, so we went back and
19 did check it.

20 In addition, the site of Harris is a
21 proposed for some new plants, so we've started some
22 well monitoring north of our existing plant just a few
23 hundred feet, and we -- I think there's five or six
24 wells there that we're starting to examine over the
25 last two years. And all of them fall in the range of

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 the lower numbers here except for I think there was
2 one well that also had a high reading of like 260. So
3 we talked to our chemistry person on site who's an
4 expert in this area. He said possibly it's just an
5 area where there's maybe salt deposits or something
6 where this particular well is.

7 So although we do have a little disparity,
8 we also -- like I said, we found another well that had
9 a little higher reading as well, so we think we -- the
10 fact that we went back and retested the same well, it
11 was the same reading, and the fact that we found
12 another well with a high reading, you know, we felt
13 like that was -- it proved that, you know, it could
14 exhibit a variation in the wells.

15 MEMBER BONACA: The other well with the
16 higher reading, is it in proximity of this one?

17 MR. REYNOLDS: Actually, it was not. The
18 other reading -- this particular well is south of the
19 plant, not too far from the emergency service water
20 intake structure. And the ones -- the other reading
21 we just recently took last -- I mean of the ones in
22 the new plants is actually north of the plant several
23 hundred feet.

24 MR. HEATH: Next, we're going to Section
25 4 or the TLAA portion, and I'm just going to highlight

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 briefly a couple things in that section. First, in
2 Section 4.2 is reactor vessel neutron embrittlement,
3 upper shelf energy. And what this graph -- it's upper
4 shelf energy assessment is based on a one-fourth t
5 fluence value at 55 effective full power years and the
6 copper content in the limiting beltline material using
7 the methodology in Reg Guide 199 rev. 2. Acceptance
8 criteria comes from Part 50, Appendix G for
9 maintaining upper shelf energy values of reactor
10 vessel beltline materials above 50 foot-pounds. And
11 as you see on the graph, the staff has done an
12 independent calculation to verify that this value is
13 within the acceptance criteria.

14 And next is the reference temperature for
15 the pressurized thermal shock values. And 10 CFR
16 50.61 defines a screening criteria for the
17 embrittlement of reactor vessel materials and
18 pressurized water reactors and for plates, forgings
19 and axial welds, the PTS screening criteria is 270
20 degrees. And the staff did an independent calculation
21 to verify tht they are within the acceptance criteria.

22 Section 4.3 --

23 MEMBER BONACA: The numbers you're showing
24 here, they're there the licensee's number, right, like
25 199?

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MR. HEATH: Yes, which was verified by the
2 staff. Yes, they did it independently and also came
3 up with that.

4 MEMBER BONACA: And it came first?

5 (Off the record comments.)

6 MR. HEATH: Now Section 4.3 is metal
7 fatigue and let me give you first a brief methodology
8 and we'll talk about the confirmatory item. The
9 applicant used a special-purpose computer code in
10 calculating the stresses for temperature transients.
11 The code is benchmarked for pressure, external
12 movement and thermal transients. Sixty-year fatigue
13 re-analysis were completed for all NUREG 6260
14 components with two components having 60 years CFUen
15 greater than 1. Harris will use fatigue monitoring
16 program AMP to manage according to 10 CRF 54.21(iii)
17 for all reactor coolant pressure boundary components
18 including the surge line and pressurizer lower head
19 penetration for 60 years CUFen greater than 1.

20 The confirmatory item -- Harris will
21 update the piping design specifications to reflect the
22 current design basis operating transient which is
23 currently commitment number 37. And the FSAR will be
24 updated to reflect Harris' crediting fatigue
25 monitoring program AMP to manage aging for reactor

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 coolant pressurizer components according to 10 CFR
2 54.21(iii). And all confirmatory items are closed by
3 LRA Amendment 7 dated April 23rd, 2008.

4 Next slide we actually briefed on in the
5 morning session, talked about -- Mr. Robert Hsu
6 clarified and pointed out how this works.

7 MR. HSU: This is Robert Hsu. I was the
8 audit team leader for the Shearon Harris an
9 responsible for the metal fatigue analysis. When we
10 went to Harris, we found the applicant used this
11 stress-based software to calculate their stress.
12 Things we just finished the current right now in the
13 U.S. market -- there are two software. They both use
14 the stress-based fatigue evaluation. They used the
15 same theory which is one called Green's function. And
16 they also could be called a transfer function. So the
17 concept is as long as you get the stress -- you get
18 the temperature, you can convert the temperature to
19 the stress immediately.

20 So we asked both software user the same
21 question -- how you mark your software, how you do the
22 benchmarking. And Shearon Harris provided us the
23 benchmarking. And this one provide us the
24 benchmarking result which is a complete report which
25 include about 29 pages. And this is just one of the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 examples they provided to us which they pick up a
2 random transient and compared their result with NSYS
3 result, and which everybody can see that this shows
4 that pretty good match, and the other software which
5 we have a question relate to was the other plants --
6 okay, those lines are the Sxx, Syy, Szz, which the one
7 is coming from the NSYS result. Another one is coming
8 from their software result, so that's the comparison.
9 And the solid line is from the NSYS. All those low
10 points are coming from the WESTEM which shows a pretty
11 good match.

12 And so which thermo-phase (phonetic) says
13 their benchmark is pretty successful. And the other
14 one, we have the problem is the other one doesn't have
15 the -- when we asked the question, they say they never
16 do a benchmark. And so from that point, we are asking
17 for the detail. And the detail is they say they only
18 use one stress value to calculate the stress time
19 history result. So we ask them to do the benchmark.
20 Their benchmark shows they cannot have the match.
21 They can -- they create like a fatigue result, like
22 40% off, underestimate.

23 And for this one, we found this is a
24 pretty good match. You use the WESTEM to calculate
25 this result. Because this one they use exactly six

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 stress tensor to perform the Green's function
2 integration. The Green's function integration
3 basically from the theory or concept wise is valid.
4 The only two -- both software, they use the same
5 thing. The only difference is one, the input is
6 different. This input uses all six stress tensor.
7 The other one, they only use one value, this value
8 which is based on their determination to determine how
9 could one stress can represent all stress tensor.

10 So the other one's problem is their input.
11 Their input problem is that they use a simplified
12 input.

13 MEMBER SHACK: When they do these
14 calculations for like the 60-year CUF, are these still
15 based on an assumption of a number of design basis
16 cycles from the original history, or are they now
17 extrapolating using their observed 20-year history?
18 Are these realistic amounts of numbers of transients?

19 MR. HSU: The first time they did
20 analysis, they used a projection. Then after we asked
21 the question how they justified their projection and
22 because some of the things that they are based on the
23 18 years history, they say this transient never
24 happened. So they 60 years, this never happened.
25 They use this kind of logic. Then we asked this kind

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 of question and then they changed it. They go back to
2 the design basis.

3 MEMBER SHACK: Oh, and that's what the --
4 the bullet that says they will update the typing
5 design specification?

6 MR. HSU: The design -- the piping design
7 specification, that's a different story, because when
8 they're doing a surge line on the NSYS, the original
9 surge line was not considered. There's this
10 insurge/outsurge and a stratification. This thing was
11 come out at 8811 and 8808, so they updated their
12 analysis but they did not update their original design
13 spec. So we are asking things. You have a design
14 analysis. Your design spec should be matched with
15 your design analysis. So that's the reason they're
16 going to do the update.

17 MEMBER ABDEL-KHALIK: Where is this node
18 located?

19 MR. HSU: This node located? I'm not
20 quite sure which nozzle this one is. This is their
21 benchmark report. This is come out from the software
22 benchmark report.

23 MEMBER ABDEL-KHALIK: How do you know that
24 this representative?

25 MR. HSU: How do I know this is

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

- 1 representative? This is a software tool.

2 MEMBER ABDEL-KHALIK: No, no, no. I mean
3 you're showing a comparison for a specific node, a
4 specific location.

5 MR. HSU: This is not a specific location.
6 This one is the benchmark and benchmark to make sure
7 this tool is valid and this tool is valid. This tool
8 can be applied to any random transient and applied to
9 any location, any -- it doesn't matter, okay, what
10 kind of geometric it's come out. This is just trying
11 to represent this methodology. It's perfect. And --

12 MEMBER SHACK: No, but he's asking if you
13 selected another node on the nozzle, would you get as
14 good agreement.

15 MEMBER ABDEL-KHALIK: Thank you, Bill.

16 MR. HSU: According to the Green function,
17 development, theory and concept, you are supposed to
18 get exactly match result, which is good.

19 MEMBER ABDEL-KHALIK: Okay. Let me ask
20 the question a different way. Why was this node
21 selected to generate this plot?

22 MR. HSU: Why is the node selected to
23 generate? This is -- doesn't matter it's a pipe or
24 it's nozzle or anything. This is just a random and
25 try to prove the program is good. This is just a

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 tool.

2 MEMBER ABDEL-KHALIK: How many nodes are
3 there in the finite element code, in the finite
4 element model?

5 MR. MALLNER: This is Chris Mallner. If
6 I can just interject for a second.

7 MEMBER ABDEL-KHALIK: Thank you.

8 MR. MALLNER: As part of the response to
9 the audit question we got, we didn't generate one
10 plot. We generated like for about 18 different
11 locations, 18 different series of plots we came up
12 with including an explanation of how each one of these
13 -- when I see we, our NSSS supplier did the calcs for
14 us -- and how these things were generated, and we
15 presented that to the audit team for their review as
16 part of the audit review process. So it's we didn't
17 give them just one plot. We gave them, I think it
18 was, 18 plots which covered a range of evaluations so
19 they could see that for a particular evaluation that
20 we would get good agreement between the results from
21 the ANSYS software and the results from the software
22 that we were using at the plant which would be
23 WESTEMs.

24 MEMBER ABDEL-KHALIK: Thank you.

25 MEMBER MAYNARD: Now, were they all in

1 about the same agreement?

2 MR. MALLNER: I'll leave the
3 characterization to the staff.

4 MR. SIEBER: It was adequate.

5 CHAIR STETKAR: The implication is the
6 staff has something like 17 or 18 more of these plots
7 available. I think we might be interested in seeing
8 those.

9 MEMBER MAYNARD: Basically, we're saying
10 that this is representative.

11 CHAIR STETKAR: That's right. I mean this
12 is -- since it's become an issue quite recently, if
13 there is a broader sampling at least for -- from the
14 runs that Harris has made --

15 MR. CHANG: This is Ken Chang. I'm the
16 Engineering Review Branch 1 Branch Chief. When we
17 were there asking this question, we got a benchmarking
18 report on the next day. So this benchmarking was made
19 for proving that a computer code is doing the right
20 thing. Okay? And we look at the various plots. As
21 far as I can remember, all the components and stress
22 intensity comparison is within plus/minus half a
23 percent, all the plots. And I have a copy of the
24 plots here if anyone is interested in taking a look.

25 CHAIR STETKAR: Okay. That's the answer.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MEMBER SHACK: That's the answer.

2 MEMBER SHACK: That was the answer we were
3 looking for. This is representative of a reasonably
4 large sample.

5 MR. CHANG: That's correct. The computer
6 code, before you use, you should benchmarking on a
7 selected configuration and then you apply it. That's
8 the standard way of doing it.

9 MR. SIEBER: Very good agreement raises
10 questions.

11 MR. HEATH: Do we have any more questions
12 on this graph? In conclusion, pending resolution of
13 open item 2.2, the staff determined, on the basis of
14 it's review of the LRA, the requirements of 10 CFR
15 54.21(a) have been met. With that, I'd like to open
16 it up for any additional questions for the staff.

17 MEMBER BONACA: I have a question. We
18 have addressed it in the past, but suppose that a few
19 years from now Shearon Harris decided to uprate power
20 level by a significant amount, 5%, 10%, I don't know,
21 something, is there a process by which some of the
22 commitments which may be affected by the power uprate
23 are going to be revisited? For example, assume that
24 you have now much higher exit temperature from the
25 core.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 MR. SIEBER: It would be even higher.

2 MEMBER BONACA: Yes. You would have
3 probably some impact on some inspections of internals
4 and you would have -- is there a mechanism by which
5 they would go back and look at their commitments?

6 MR. STEWART: This is Roger Stewart. Let
7 me address that. Earlier this morning, we talked
8 about we were doing the NFPA-805 commitment or the
9 change. That's going to be a license amendment. The
10 process that the staff has under the rules, under
11 54.37 Bravo, if there's any changes to our license or
12 anything that impacts license renewal, we report that
13 back to the staff in the form of our FSAR update that
14 we do after every refueling cycle. So any changes
15 that we make that potentially impact anything in the
16 license renewal, we report back to the staff. That's
17 the process.

18 MEMBER BONACA: And so you have a
19 communication management program, really tentatively,
20 to track these commitments and determines whether or
21 not some changes --

22 MR. STEWART: Well, it requires internally
23 that anything that we do that would result in a change
24 in the licensing basis that might affect license
25 renewal by the rule, we have to report it back to the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 staff. It's already a requirement.

2 MEMBER BONACA: So you would have to have
3 an evaluation of your programs, right, after you have
4 the power uprate --

5 MR. STEWART: That's correct.

6 MEMBER BONACA: -- to determine if there
7 is any impact on --

8 MR. STEWART: That's correct. We would do
9 that.

10 MR. SIEBER: These are changes under
11 50.59. Any change that does affect one of the three
12 conditions, you have to go to the staff before you
13 make the change, get an amendment to do it. So this
14 is just 50.59 changes that end up reported through the
15 --

16 MR. STEWART: What we're talking with the
17 power uprate or with NFPA-805 type change, you're
18 actually talking a license amendment.

19 MR. SIEBER: That's right.

20 MR. STEWART: And we haven't been looking
21 as much up front on the 805 because until you actually
22 issue that amendment and it becomes part of the COB,
23 we haven't saw -- I haven't tried to see what systems
24 that might bring in or bring out that we credit safe
25 shutdown.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MR. SIEBER: Right. Well, until you get
2 the amendment, it's not official.

3 MR. STEWART: That's correct.

4 MEMBER SHACK: But typically in power
5 uprates, you know, the ones that we've looked at the
6 constant pressure, constant temperature ones, there is
7 an emphasis at looking at things like flow-induced
8 vibration and FAC. If you had one where you raised
9 the temperature, that would raise a whole new set of
10 things to look at.

11 MR. SIEBER: Well, PWRs raises
12 temperatures. BWRs are constant pressure. The other
13 way to do it is lower T-aves. The T-h stays the same.

14 MEMBER BONACA: On the other hand, I mean
15 there is a bunch of programs here which have been
16 keyed to the needs of a client, as understood now, and
17 with power uprates, you may have some changes out
18 there that would have an affect. And I think it would
19 have to be to be almost like almost like a small
20 project to go back and review these programs and say,
21 yes, this is impacted by the power uprate or no, it's
22 not, nothing changes.

23 CHAIR STETKAR: I think that the NFPA-805
24 that he mentioned could affect the scoping of things,
25 for example, for the license renewal, because

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 depending on what -- if I'm correctly interpreting
2 what you said as a result of that NFPA-805 assessment,
3 you might wind up taking credit for additional SSCs
4 for mitigating fire risk. That could, in principle,
5 extend the scope of items that would then fall under
6 the aging management portion of the fire protection.

7 MEMBER BONACA: I could see that for an
8 impact on Section 4 with your TLAAs. Most likely,
9 they'd have to deal with it.

10 MEMBER SHACK: But that's typically
11 evaluated in a power uprate analysis that we've seen,
12 and people look at them and --

13 MR. SIEBER: Yes, right.

14 MEMBER BONACA: Yes, right.

15 MS. LUND: This is Louise Lund --

16 MEMBER BONACA: It's more like, you know,
17 requesting a configuration map to show that you
18 covered all grounds.

19 MEMBER SHACK: That's the thing. You
20 know, are you going to miss something as you do it.
21 I mean people look at some things, but the question of
22 whether you're looking at it systematically may be
23 another issue.

24 MS. LUND: This is Louise Lund. You're
25 exactly right, we are, as far as the power uprate

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 reviews. You know, you look at whatever information
2 is there, and because a lot of times it's, you know,
3 whether a power uprate comes before license renewal or
4 after license renewal. and, you know, sometimes it's
5 a benefit to have the additional information to look
6 back, because when the tech or reviewer is actually
7 looking at -- you know, there's a lot of overlap in
8 the technical areas you look at, and it does provide
9 more information, in fact, you know, operating
10 experience and a lot of information you would find
11 useful as a technical reviewer when you do look at
12 this. So, you know, I think that there's a lot of
13 things that go on vis-a-vis each other and need to be
14 looked at, you know, in that way. But there is a lot
15 of information that is made available through the
16 license renewal process that can be looked at, you
17 know, in any power uprate review as well.

18 MEMBER BONACA: Yes. I think we wrote
19 something about it years ago.

20 CHAIR STETKAR: Okay. Thank you very
21 much. Good presentation. I think let me just take
22 the opportunity to give each individual one last
23 hurrah. Are there any open questions? Jack, start
24 with you.

25 MR. SIEBER: I have considered the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 questions that you asked, and I think things are in
2 pretty good shape here. I think that both the
3 applicant and the staff has done a pretty good job on
4 this one.

5 CHAIR STETKAR: John?

6 MR. BARTON: The only thing I'd add that
7 I think the full committee ought to hear is the what
8 is the applicant planning to do about this water in
9 the ducts and cable-wetting program and testing of
10 those cables and a history and that whole thing.
11 That's the only thing I've got outstanding against
12 this application. I thought it was a pretty good
13 application overall.

14 CHAIR STETKAR: Bill?

15 MEMBER SHACK: Nothing to add what John
16 said.

17 CHAIR STETKAR: Mario?

18 MEMBER BONACA: I thought it was a good
19 application. I thought it was a good SER. I have no
20 further questions.

21 CHAIR STETKAR: I echo those sentiments.
22 I think the staff did a really good job on this. The
23 audit team, I was really impressed with the audit team
24 questions and the feedback, so sounds good.

25 MEMBER MAYNARD: I have nothing to add to

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 what's been said.

2 MEMBER ABDEL-KHALIK: Yes. I echo this
3 and, you know, we really want to understand what
4 systems may potentially be affected by that --

5 CHAIR STETKAR: I think -- yes, that's --

6 MEMBER ABDEL-KHALIK: -- details of, you
7 know, operational experience that you've had and just
8 knowing exactly the systems that may be affected by
9 those six locations in which you have had persistent
10 flooding.

11 The other issue in my mind is that without
12 a root cause evaluation to identify the cause of
13 containment spray valve chamber corrosion, I'm not
14 sure if this issue is completely off the table, and
15 I'd like to find out more about what is -- after all,
16 this is a part of containment. I'd like to find out
17 of a root cause had been done and what actions had
18 been taken to ameliorate the situation.

19 MR. BARTON: That's a good one.

20 MEMBER BONACA: These are good ideas for
21 the full committee meeting.

22 CHAIR STETKAR: Yes, these -- just, you
23 know, staff and Progress making notes, heads up, you
24 come prepared to discuss these things.

25 MEMBER MAYNARD: I might add for the full

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 committee, it would be helpful if we got into
2 discussion on the cooling system again, if you had a
3 little bit bigger picture that showed the lakes, and
4 you could point those out. I've looked it up on the
5 internet. I think I understand it now but it's easier
6 to understand it with a little bit bigger picture.

7 MR. STEWART: I have the full satellite
8 view that I took that snapshot from on a jump drive if
9 you want it.

10 MEMBER MAYNARD: No, like I said, I've
11 looked it up on the internet, but for the full
12 committee --

13 CHAIR STETKAR: For the full committee,
14 it's kind of interesting.

15 MR. SIEBER: Yes. And it would also be
16 good if you pointed out the names of the various
17 buildings that are there, because I couldn't tell from
18 the photographs.

19 CHAIR STETKAR: So a good cartoon with a
20 site layout and some arrows showing buildings and
21 locations of things. One last question --

22 MEMBER ABDEL-KHALIK: Is the issue with
23 the feedwater reg valve --

24 CHAIR STETKAR: No. That's -- I was just
25 going to mention that. Is -- have we set a full

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 committee meeting date for this

2 MR. WEN: Not exactly.

3 CHAIR STETKAR: Not yet. Okay.

4 MEMBER SHACK: We won't have one until the

5 --

6 CHAIR STETKAR: I was going to say for our
7 planning purposes, is -- are you close? I mean are
8 you talking about the next month or so or?

9 MR. HEATH: I think we'll have it done by
10 -- I anticipate having it done by October, full
11 committee.

12 MEMBER MAYNARD: I think the main thing
13 for us is we -- that when we do have a full committee
14 meeting, I'd like to know how that's resolved.

15 CHAIR STETKAR: How that's resolved and
16 from my perspective, and I think somebody else
17 mentioned earlier, more in the sense of effect on
18 safety rather than just simply regulation. I wanted
19 to make sure that the resolution, you know, addresses
20 both of those topics.

21 Okay. Hearing nothing else, we're -- not
22 bad on schedule -- we're closed.

23 (Whereupon, at 3:08 p.m., the foregoing
24 matter was adjourned.)

25

CERTIFICATE


This is to certify that the attached proceedings
before the United States Nuclear Regulatory Commission
in the matter of: Plant License Renewal Subcommittee

Name of Proceeding: Advisory Committee on
 Reactor Safeguards

Docket Number: n/a

Location: Rockville, MD

were held as herein appears, and that this is the
original transcript thereof for the file of the United
States Nuclear Regulatory Commission taken by me and,
thereafter reduced to typewriting by me or under the
direction of the court reporting company, and that the
transcript is a true and accurate record of the
foregoing proceedings.



Charles Morrison
Official Reporter
Neal R. Gross & Co., Inc.

NEAL R. GROSS
COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com



**Advisory Committee on Reactor Safeguards
(ACRS) License Renewal Subcommittee**

**Shearon Harris Nuclear Power Plant Unit 1
Safety Evaluation Report with Open Items**

May 7, 2008

Maurice Heath, Project Manager
Office of Nuclear Reactor Regulation



Introduction

- Overview
- Section 2: Scoping and Screening Review
- License Renewal Inspections
- Section 3: Aging Management Review Results
- Section 4: Time-Limited Aging Analyses (TLAAs)

2



Overview

- LRA Submitted by letter dated November 14, 2006
- Westinghouse 3-Loop - PWR
- 2900 megawatt thermal, 900 megawatt electric
- Operating license NPF-63 expires October 24, 2026
- Location is approximately 20 miles SW of Raleigh, NC

3



Overview

- Safety Evaluation Report with Open Items was issued March 18, 2008
- 1 Open item
- 2 Confirmatory items
- 346 Audit Questions
- 75 RAI's Issued
- 35 Commitments

4



Overview

- Scoping and Screening Methodology Audit
 - April 23, 2007 - April 27, 2007
- Aging Management Programs (AMP) Audit
 - May 21, 2007 – May 25, 2007
- Aging Management Review (AMR) & Time-Limited Aging Analysis (TLAA) Audit
 - June 25, 2007 – June 29, 2007
- Regional License Renewal Inspections
 - July 9, 2007 – July 13, 2007 and July 23 – July 27, 2007
- TLAA Audit
 - August 13, 2007 – August 15, 2007

5



Section 2: Structures and Components Subject to Aging Management Review

Section 2.1 – Scoping and Screening Methodology

- Staff's Audit and Review concluded that the applicants methodology is consistent with the requirements of 10 CFR 54.4 and 54.21(a)(1)

6



**Section 2: Structures and Components
Subject to Aging Management Review**

Section 2.2 – Plant-Level Scoping Results

- Open Item 2.2
 - In the LRA, the applicant states the feedwater regulating and bypass valves are non-safety related
 - Chapter 10 and 15 of the HNP FSAR credit these valves for redundant isolation function in the event of main steam line break
 - The applicants methodology referred to the industry guidance, NEI 95-10 which infers that these components would be in scope per 10 CFR 54.4(a)(1)

7



**Section 2: Structures and Components
Subject to Aging Management Review**

Section 2.3 – Mechanical Systems

- 110 Mechanical Systems
 - 72 BOP
- 100% Reviewed
- BOP: Tier 1 Review: 41 Systems
 - Review LRA and FSARTier 2 Review: 31 Systems
 - Detailed review of Boundary Drawings, LRA and FSAR

8



**Section 2: Structures and Components
Subject to Aging Management Review**

Section 2.4 – Structural Systems

- Component Brought Into Scope
 - Insulation on low temperature, small diameter containment penetrations

9



**Section 2: Structures and Components
Subject to Aging Management Review**

**Section 2.5 – Electrical and Instrumentation and
Control Systems**

- No omission of electrical and instrumentation and control system components within the scope of license renewal

10



**Section 2: Structures and Components
Subject to Aging Management Review**

Summary

- The applicant's scoping and screening methodology meets the requirements of 10 CFR 54.4 and 54.21(a)(1)
- Scoping and screening results, as amended and pending OI-2.2 resolution, included all SSCs within the scope of license renewal and subject to AMR

11



License Renewal Inspections

Caudle Julian

Region II Inspection Team Leader

12



License Renewal Inspections

- Scoping and Screening Inspection
- Objective: To confirm that the applicant has included all appropriate SSCs in the scope of License Renewal as required by the Rule
- MC 2516 and IP 71002 have been revised to reduce the scope of Scoping and Screening inspections and combine them with Aging Management Program inspections
- Focus is on 10 CFR 54.4 (a)(2) situations - non safety related that could effect safety related equipment

13



License Renewal Inspections Program Implementation

- License renewal manual chapter - MC 2516
- License renewal inspection procedure - IP 71002
- Site-specific inspection plan for each applicant
- Scheduled to support NRR's review
- Resources - consistent team of the same five inspectors
- Training program for replacement team members

14



Aging Management Programs (AMPs) Implementation

- Objective: To confirm that existing AMPs are working well and to examine the applicant's plans for establishing new AMPs and enhancing existing AMPs
- Two weeks in length
- Examine records of past tests, surveillances, operating experience and corrective actions from existing AMPs
- Examine implementation plans for new or expanded AMPs
- Verify inclusion of future tasks into established site task tracking system
- Verify that material condition of plant was being adequately maintained to date

15



Additional (Optional) Inspection: Open Items

- 2 - 3 days in length
- Close any open items from previous inspections
- Close any inspection items requested by NRR
- Verify that applicant has loaded future tasks into established site task tracking system
- Verify that a transition plan for completion of license renewal project was established

16



Shearon Harris License Renewal Inspection

- AMP inspection conducted July 9 - 27, 2007
- Inspection concluded that existing programs to be credited as aging management programs for license renewal are generally functioning well.
- In walking down plant systems and examining plant equipment the inspectors found no significant adverse conditions and it appears plant equipment was being maintained adequately.
- Applicant had established implementation plans in the plant Action Request system to track the committed future actions for license renewal to ensure they are completed.
- Region II will follow up on these issues during a future IP 71003 inspection.


17



Shearon Harris License Renewal Inspection

- Inspectors identified several areas where enhancements could be made in the performance of existing programs. For example the applicant had established a quarterly preventive maintenance task of pumping any existing water from the safety related electrical cable vaults. They were measuring and recording the as-found water levels but there was no trending of the information being performed.
- NRC learned that the applicant had previously identified that there had been problems with past management and implementation of the ISI program. Applicant had an improvement plan in place and were committed to add resources to recover the ISI program to acceptable status. Region II followed up during a subsequent ISI Baseline inspection and observed substantial improvement.

18



Section 3: Aging Management Review Results

- 3.0 – Aging Management Programs
- 3.1 – Reactor Vessel & Internals
- 3.2 – Engineered Safety Features
- 3.3 – Auxiliary Systems
- 3.4 – Steam and Power Conversion System
- 3.5 – Containment, Structure and Component Supports
- 3.6 – Electrical and Instrumentation and Controls System

20

Section 3: Aging Management Review Results

Section 3.0.3 – Aging Management Programs (AMPs)

- 40 AMPs
 - 12 New Programs
 - 1 Program added during review
 - 28 Existing Programs

21



Section 3: Aging Management Review Results

Section 3.0.3.3.1 – Oil-Filled Cable Testing Program

- Added as a result of on-site audit
- Program manages oil-filled cables that connect the 230KV switchyard to startup transformers
- Periodic cable testing will be performed to determine the cable insulation properties

22



Section 3: Aging Management Review Results

Section 3.4 – Steam and Power Conversion System

- Confirmatory Item 3.4-1
 - Applicant credits managing changes in materials and cracking of elastomeric and thermoplastic piping and piping components with External Surfaces Monitoring Program
 - GALL AMP XI.M36 does not specifically address these components or provide any provision for inspection method
 - Applicant has proposed to use a preventative maintenance program, which will periodically replace these components based on operating experience and vendor recommendations

23



Aging Management of Inaccessible Concrete

	Acceptance Criteria	Well 57	Well 59
pH	>5.5	7.6	7.9
Chlorides	<500 ppm	290	42
Sulfates	<1500 ppm	2.4	2.1

- Below grade environment is non-aggressive
- Ground water testing will be performed on a yearly interval by the Structures Monitoring Program

24



Section 4: Aging Management Review Results

- 4.1 TLAA Process
- 4.2 Reactor Vessel Neutron Embrittlement
- 4.3 Metal Fatigue
- 4.4 Environmental Qualification of Electrical Equipment
- 4.5 Concrete Containment Tendon Prestress (N/A)
- 4.6 Containment Liner Plate, Metal Containments, and Penetration Fatigue
- 4.7 Other Plant Specific TLAA

25



Reactor Vessel Neutron Embrittlement – Upper Shelf Energy

Limiting Bellline Material—Intermediate Shell Plate

% CU	55 EFPY Fluence (E>1 MeV) at 1/4T 10 ¹⁹ (n/cm ²)	Initial Charpy V notch USE Value ft-lb	Irradiated Charpy V notch USE Value at 55 EFPY ft-lb	Acceptance Criteria per RG 1.99 rev 2 ft-lb
0.09	4.209	71	52.8	50

26



Reference Temperature for Pressurized Thermal Shock (PTS) Values

Limiting Bellline Material—Intermediate Shell Plate

% CU	55 EFPY Fluence (E>1 MeV) at Clad-Base Metal Interface 10 ¹⁹ (n/cm ²)	Initial Charpy RT _{NDT} °F	RT _{PTS} °F	Acceptance Criteria per 10 CFR 50.61 °F
0.09	6.803	+91	199	270

27



Section 4: Aging Management Review Results

4.3 Metal Fatigue

- Applicant used a special purpose computer code in calculating stresses from temperature transients
- The code is bench marked for pressure, external moment and thermal transients
- 60-year fatigue reanalysis were completed for all NUREG/CR 6260 components with two (2) components having 60-year CUFen>1.0
- HNP will use fatigue monitoring program AMP to manage aging according to 10 CFR 54.21(c)(1)(ii) for all reactor coolant pressure boundary components, including the surge line and the pressurizer lower head penetration with 60-year CUFen>1.0

28



Section 4: Aging Management Review Results


4.3 Metal Fatigue – Confirmatory Item (CI) 4.3

- HNP will update the piping design specification to reflect the current design basis operating transients (Commitment 37)
- The FSAR will be updated to reflect HNP crediting fatigue monitoring program AMP to manage aging for reactor coolant pressure boundary components according to 10 CFR 54.21(c)(1)(iii)
- All confirmatory items are closed by LRA Amendment 7 dated April 23, 2008

29



Reactor Trip
APM Node 37 (outside)





Conclusion

- Pending the resolution of OI 2.2, staff determined, on the basis of its review of the LRA, that the requirements of 10 CFR 54.29(a) have been met

31



Agenda

- Plant Background
- Site Description
- Improvements
- License Renewal Scoping
- GALL
- Commitments
- Open Item
- Confirmatory Items



Background

April 1971	Plans for Plant Construction Announced
January 1978	Construction Permit Issued
October 1986	Facility License Issued
May 1987	Commercial Operation
October 2026	Operating License Expires



Site Description

- Westinghouse (NSSS) EBASCO (AE)
- 3 Loop PWR 2900 MWt; 900 Mwe (net)
- 18 Month refueling cycle
- Site Area: 10,723 acres
- Cooling via lake with Cooling Tower
- Ownership - Progress Energy (~84%) and NC Eastern Municipal Power Agency (~16%)



Major Improvements

- Steam Generator Replacement (2001)
- Power Uprate (4.5%) (2001)
- Alloy 600 Pressurizer weld overlay (2007)
- Reactor Vessel Head inspections (2007)
- Containment Sump enlargement (2007)



Future Improvements

- NFPA-805 transition in progress
- Digital Control Systems infrastructure for future applications
- Planned Power Uprates



License Renewal Scoping

- Sources of Information include:
 - Equipment database
 - Provides a listing of systems, components and component locations
 - Provides Quality Classification and other component information
 - FSAR
 - Design Basis Documents
 - Current Licensing information (SERs and other docketed information)
 - Maintenance Rule database



License Renewal Scoping

Scoping performed on a system level:

- Quality Class designations in the equipment database were reviewed and when a component was identified as potentially in scope based on the criteria of 54.4 (a) (1), (2) or (3), the system containing that component was evaluated as being in scope for license renewal
- Structures were included in scope based on their contents



Application of GALL

- Gall consistency
- Aging evaluation 89% consistent with GALL (standard notes A through D)
- 40 aging management programs
- 28 existing programs credited
 - 19 require enhancement
- 12 new aging management programs credited
- 14 aging management programs take one or more exceptions to GALL
- 1 site specific aging management program (oil filled cable testing program)



Commitments

- Harris has made 37 commitments in support of License Renewal
- Tracked by Progress Energy commitment tracking process
- Implementation Plan developed for each commitment
- All open commitments will be assigned to station personnel prior to closure of the License Renewal Project



Open Item Discussion

Background

- Mitigation of a main steam line break includes redundant isolation of feedwater lines (FSAR 15.1-5)
- Isolation of feedwater is accomplished by closure of the feedwater isolation valves with back up closure of the feedwater regulating and bypass valves (in the event of a single failure of the isolation valves)




Open Item Discussion

Background *continued*

- The feedwater isolation valves are nuclear safety related and located in the reactor auxiliary building and were identified as being within the scope of license renewal per the criteria of 10 CFR 54.4(a)(1)
- The feedwater regulating and bypass valves are non-nuclear safety related and located in the turbine building and were identified as being within the scope of license renewal per the criteria of 10 CFR 54.4(a)(2)





Open Item Discussion

OI-2.2

The staff's position remains that the main feedwater regulating and bypass valves, by definition, fulfill a safety-related function; therefore, they should be included in scope under 10 CFR 54.4(a)(1). In addition, the function to provide main feedwater isolation should be included in scope under 10 CFR 54.4(a)(1) for Section 2.3.4.6, to include the main feedwater isolation valves and the regulating and bypass valves.

Open Item Discussion

Discussion

- The CLB for Harris recognizes the feedwater regulating and bypass valves are non-nuclear safety related and that they provide backup isolation to mitigate a main steam or feedwater line break (NUREG 1038 dated November 1983)
- The Standard Review Plan states *"For postulated instantaneous pipe failures in seismically qualified portions of the main steam line (inside containment and upstream of the MSIVs), only safety related equipment should be assumed operative. If, in addition, a single malfunction or failure of an active component is postulated, credit may be taken for the use of a backup nonsafety-related component to mitigate the consequences of the break."* (NUREG 0800, Section 15.1.5 revision 2 dated 07/1981 and revision 3 dated 03/2007)



Confirmatory Items Discussion

Confirmatory Item 3.4-1

- The External Surfaces Monitoring Program was credited for aging management of elastomeric and thermoplastic components in the steam and power conversion systems
- The staff questioned specifics of inspection method, acceptance criteria and GALL applicability for this application



Confirmatory Items Discussion

Confirmatory Item 3.4-1

Progress Energy has responded by amending the LRA to:

- Include the condensate storage tank diaphragm in the Inspection of Internal Surfaces in Miscellaneous Piping and Ducting Components Program (*diaphragm was replaced in 1994 and inspected in 2006*)
- Replace other elastomeric and thermoplastic components (prior to the period of extended operation) and add them to the Preventive Maintenance Program



Confirmatory Items Discussion

Confirmatory Item 4.3, Part 1

- Operational transients for Harris were redefined in consideration of pressurizer insurge/outsurge and thermal stratification
- The staff expressed a concern that the design specification had not been updated to reflect the redefined transients
- Progress Energy has responded by amending the LRA to include a commitment to update the design specification prior to the period of extended operation.



Confirmatory Items Discussion

Confirmatory Item 4.3, Part 2

- Disposition of the TLAA for Environmentally-Assisted Fatigue analysis relied upon either projection (thru the period of extended operation) or management by the Fatigue Monitoring Program
- The staff requested that the FSAR supplement description indicate specifics of disposition for the components evaluated for Environmentally-Assisted Fatigue



Confirmatory Items Discussion

Confirmatory Item 4.3, Part 2

- Progress Energy has responded by amending the LRA to describe either 10 CFR 54.21(c)(1) method (ii) or method (iii) management of Environmentally-Assisted Fatigue in the FSAR supplement



Questions

