

June 16, 2008

Mr. M. R. Blevins
Executive Vice President
& Chief Nuclear Officer
Luminant Generation Company LLC
ATTN: Regulatory Affairs
P. O. Box 1002
Glen Rose, TX 76043

SUBJECT: COMANCHE PEAK STEAM ELECTRIC STATION, UNITS 1 AND 2 – FINAL ENVIRONMENTAL ASSESSMENT AND FINDING OF NO SIGNIFICANT IMPACT FOR PROPOSED STRETCH POWER UPRATE (TAC NOS. MD6615 AND MD6616)

Dear Mr. Blevins:

Enclosed is a copy of the Final Environmental Assessment and Finding of No Significant Impact related to your application for the proposed stretch power uprate amendment dated August 28, 2007, as supplemented by letters dated October 24, November 7, and December 3, 2007, January 10, 29, and 31, February 21, 26, and 28, March 6, April 17, and May 14, 2008.

The proposed amendment would allow an increase in the maximum authorized power level from 3458 megawatts thermal (MWt) to 3612 MWt, and make changes to the technical specifications, as necessary, to support operation at the higher power level.

The assessment is being forwarded to the Office of the Federal Register for publication.

Sincerely,

/RA/

Balwant K. Singal, Senior Project Manager
Plant Licensing Branch IV
Division of Operating Reactor Licensing
Office of Nuclear Reactor Regulation

Docket Nos. 50-445 and 50-446

Enclosure:
Final Environmental Assessment

cc w/encl: See next page

June 16, 2008

Mr. M. R. Blevins
Executive Vice President
& Chief Nuclear Officer
Luminant Generation Company LLC
ATTN: Regulatory Affairs
P. O. Box 1002
Glen Rose, TX 76043

SUBJECT: COMANCHE PEAK STEAM ELECTRIC STATION, UNITS 1 AND 2 – FINAL ENVIRONMENTAL ASSESSMENT AND FINDING OF NO SIGNIFICANT IMPACT FOR PROPOSED STRETCH POWER UPRATE (TAC NOS. MD6615 AND MD6616)

Dear Mr. Blevins:

Enclosed is a copy of the Final Environmental Assessment and Finding of No Significant Impact related to your application for the proposed stretch power uprate amendment dated August 28, 2007, as supplemented by letters dated October 24, November 7, and December 3, 2007, January 10, 29, and 31, February 21, 26, and 28, March 6, April 17, and May 14, 2008.

The proposed amendment would allow an increase in the maximum authorized power level from 3458 megawatts thermal (MWt) to 3612 MWt, and make changes to the technical specifications, as necessary, to support operation at the higher power level.

The assessment is being forwarded to the Office of the Federal Register for publication.

Sincerely,

/RA/

Balwant K. Singal, Senior Project Manager
Plant Licensing Branch IV
Division of Operating Reactor Licensing
Office of Nuclear Reactor Regulation

Docket Nos. 50-445 and 50-446

Enclosure:
Final Environmental Assessment

cc w/encl: See next page

DISTRIBUTION:

PUBLIC	RidsNrrDprRerb Resource	RidsOgcRp Resource
LPLIV R/F	RidsNrrLAJBurkhardt Resource	RidsRgn4MailCenter Resource
RidsAcrsAcnw_MailCTR Resource	RidsNrrPMBSingal Resource	
RidsNrrDorlLpl4 Resource	RidsNrrPMTAlexion Resource	

ADAMS Accession Nos. Pkg ML081410231, Letter ML081510241, Final EA ML081510247

OFFICE	NRR/LPL4/PM	NRR/LPL4/LA	NRR/RERB/BC	OGC	NRR/LPL4/BC
NAME	BSingal	JBurkhardt	EBenner*	BMizuno	THiltz
DATE	6/16/08	6/4/08	6/4/08	6/11/08	6/16/08

OFFICIAL AGENCY RECORD

Comanche Peak Steam Electric Station

(10/2007)

cc:

Senior Resident Inspector
U.S. Nuclear Regulatory Commission
P.O. Box 2159
Glen Rose, TX 76403-2159

Regional Administrator, Region IV
U.S. Nuclear Regulatory Commission
612 Lamar Blvd., Suite 400
Arlington, TX 76011-4125

Mr. Fred W. Madden, Director
Regulatory Affairs
Luminant Generation Company LLC
P.O. Box 1002
Glen Rose, TX 76043

Timothy P. Matthews, Esq.
Morgan Lewis
1111 Pennsylvania Avenue, NW
Washington, DC 20004

County Judge
P.O. Box 851
Glen Rose, TX 76043

Environmental and Natural
Resources Policy Director
Office of the Governor
P.O. Box 12428
Austin, TX 78711-3189

Mr. Richard A. Ratliff, Chief
Bureau of Radiation Control
Texas Department of Health
1100 West 49th Street
Austin, TX 78756-3189

Mr. Brian Almon
Public Utility Commission
William B. Travis Building
P.O. Box 13326
1701 North Congress Avenue
Austin, TX 78701-3326

Ms. Susan M. Jablonski
Office of Permitting, Remediation
and Registration
Texas Commission on Environmental
Quality
MC-122
P.O. Box 13087
Austin, TX 78711-3087

Anthony P. Jones
Chief Boiler Inspector
Texas Department of Licensing
and Regulation
Boiler Division
E.O. Thompson State Office Building
P.O. Box 12157
Austin, TX 78711