

SURVEILLANCE REQUIREMENTS

SURVEILLANCE	FREQUENCY
<p>SR 3.8.2.1</p> <p>-----NOTE-----                      The following SRs are not required to be performed:                      SR 3.8.1.3, SR 3.8.1.10 through SR 3.8.1.12,                      SR 3.8.1.15 through SR 3.8.1.17, and SR 3.8.1.18.                      -----</p> <p>For AC sources required to be OPERABLE, the SRs of Specification 3.8.1, "AC Sources -- Operating," except SR 3.8.1.9, SR 3.8.1.13, SR 3.8.1.14 (ESF actuation signal portion only), SR 3.8.1.19, SR 3.8.1.20, SR 3.8.1.21, and SR 3.8.1.22, are applicable.</p>	<p>In accordance with applicable SRs</p>
<p>SR 3.8.2.2</p> <p>One of the following SRs is applicable when the electrical distribution subsystem is being supplied by "backfeed" from an offsite source via the main transformer and a unit auxiliary transformer:</p> <ul style="list-style-type: none"> <li>a. SR 3.8.1.9.a when the preferred offsite circuit is required to be OPERABLE by LCO 3.8.2.a, or</li> <li>b. SR 3.8.1.9.b when the alternate offsite circuit is required to be OPERABLE by LCO 3.8.2.a.</li> </ul>	<p>In accordance with applicable SR</p>

SURVEILLANCE REQUIREMENTS

SURVEILLANCE	FREQUENCY
<p>SR 3.8.2.1</p> <p>-----NOTE-----</p> <p>The following SRs are not required to be performed: SR 3.8.1.3, SR 3.8.1.10 through SR 3.8.1.12, SR 3.8.1.15 through SR 3.8.1.17, and SR 3.8.1.18.</p> <p>-----</p> <p>For AC sources required to be OPERABLE, the SRs of Specification 3.8.1, "AC Sources -- Operating," except SR 3.8.1.9, SR 3.8.1.13, SR 3.8.1.14 (ESF actuation signal portion only), SR 3.8.1.19, SR 3.8.1.20, SR 3.8.1.21, and SR 3.8.1.22, are applicable.</p>	<p>In accordance with applicable SRs</p>
<p>SR 3.8.2.2</p> <p>One of the following SRs is applicable when the electrical distribution subsystem is being supplied by "backfeed" from an offsite source via the main transformer and a unit auxiliary transformer:</p> <ul style="list-style-type: none"> <li>a. SR 3.8.1.9.a when the preferred offsite circuit is required to be OPERABLE by LCO 3.8.2.a, or</li> <li>b. SR 3.8.1.9.b when the alternate offsite circuit is required to be OPERABLE by LCO 3.8.2.a.</li> </ul>	<p>In accordance with applicable SR</p>