Rancho Seco

Final Status Survey Summary Report

April 3, 2008

Central N-S Transit Industrial Area

Survey Unit F8000041

Prepared By:	Muhaf Sain	_ Date:_	4/3/2008
	FSS Engineer	1 2	
Reviewed By:	Lead FSS Enginee	_ Date:_ r	4/4/08
Approved By: Disma	5. 7 ntlement Superintendent,	_ Date:_ , Radiolo	<u>4−78−0</u> 8 gical

FINAL STATUS SURVEY SUMMARY REPORT

Survey Unit:

F8000041, Central N-S Transit Industrial Area

Survey Unit Description:

Operating History: This area covers the majority of Industrial Area soils exclusive of the building footprints and rail line in this area. Operating records and the HSA document no specific release of radioactivity in these survey areas however this area does border known contaminated areas. The HSA recorded no specific unplanned release events.

Site Characterization: Soil and sediment samples were collected and analyzed for the presence of plant-derived radionuclides. Cs-137 was the only detected nuclide of plant origin with a mean activity level of 0.062 pCi/g and a maximum value of 0.299 pCi/g. (Site background levels of Cs-137 have been determined to be approximately 0.312 pCi/g.) As described in section 2 of the LTP, the area was evaluated using DSIP-0020 and was designated as Class 3.

Survey Unit Design Information:

The Survey Unit Design Parameters are presented in Table 1 below. The survey unit and measurement locations are depicted on the maps in Attachment 1. Direct measurement locations were randomly determined and 679 m² were scanned for approximately 10% coverage. Soil samples were collected at direct measurement locations where soil was present and analyzed by HPGe detector. Gamma spectroscopy field measurements were obtained with a NaI detector at direct measurement locations where either asphalt or concrete was present. The instrumentation used for the survey along with the MDC values are listed in Tables 2-1 and 2-2 in Attachment 2.

Table 1. Survey Unit Design Parameters

Survey Design Parameter	Value	Comment
Survey Area:	F800	Central N-S Transit
		Industrial Area
Survey Unit:	0041	Open Land Area
Class:	. 3	LTP Table 5-4
SU Area (m ²):	6634	
Evaluator:	Michael Stein	
DCGL Cs137 surrogate (pCi/g):	51.2	
Area Factor:	N/A	Class 3
Design DCGLemc (pCi/g):	N/A	Class 3
LBGR (pCi/g):	25.6	Default = 50% DCGL
Design Sigma (pCi/g):	. 0.01	DTBD-06-001, Table 5-B
Type I Error:	0.05	
Type II Error:	0.05	
Nuclide:	Cs137	
Sample Area (m²):	N/A	Class 3
Total Area Scanned (m ²):	679	
Scan Coverage (%):	10.2%	Class 3
Z_{1-a} :	1.645	
\mathbf{Z}_{1-eta} :	1.645	
Sign P:	0.99865	·
Calculated Relative Shift:	2560	
Relative Shift Used:	3	Uses 3.0 if Rel Shift >3
N-Value:	11	,
Design N-Value + 20%:	14	NUREG-1575 Table 5-5
Grid Spacing L:	N/A	Class 3

Survey Results:

A total of 14 direct measurements were made in F8000041. The results including mean, median, standard deviation and range are shown in Table 2. All of the direct measurements were less than the DCGL. Soil samples (SS) and gamma direct (GD) measurements were counted to the MDCs shown in Table 2-1 of Attachment 2.

Table 2. Direct Measurement Results (all activity values in pCi/g)

Measurement ID	Cs137 MDA	Cs137 Activity	Uncertainty
Mean: Median: Standard Deviation:		6.65E-01 8.29E-01 3.38E-01	The second secon
Range:		5.00E-02 to 8.96E-01	
F8000041 A0007GD	8.65E-01	< 8.65E-01	
F8000041 A0013GD	8.96E-01	< 8.96E-01	
F8000041 A0009GD	8.23E-01	< 8.23E-01	
F8000041 A0008GD	7.96E-01	< 7.96E-01	
F8000041 A0011GD	8.70E-01	< 8.70E-01	
F8000041 A0014GD	8.31E-01	< 8.31E-01	:
F8000041 A0003GD	8.26E-01	< 8.26E-01	
F8000041 A0001GD	8.62E-01	< 8.62E-01	· d
F8000041 A0012GD	8.85E-01	< 8.85E-01	
F8000041 C0006GD	6.27E-01	< 6.27E-01	
F8000041 A0005GD	8.69E-01	< 8.69E-01	
F8000041S0004SS	5.54E-02	< 5.54E-02	
F8000041S0010SS	5.00E-02	< 5.00E-02	
F8000041S0002SS	5.26E-02	< 5.26E-02	3

Survey Unit Data Assessment:

The survey design required 14 direct measurements for the Sign Test. The critical value and the results of the Sign Test are presented in Table 3. The sample mean and median values were less than the DCGL. The sample standard deviation was greater than the design standard deviation. However, both values of sigma result in a relative shift of greater than 3 so no additional samples were required.

Table 3. Data Assessment Results

. ,		
Survey Results Parameter	Value	Comment
Actual Direct Measurements (N):	14	·.
Median (pCi/g):	8.29E-01	
Mean (pCi/g):	6.65E-01	·
Standard Deviation (pCi/g):	3.38E-01	
Maximum (pCi/g):	8.96E-01	
Sign Test Final N Value:	14	
S+ Value:	14	
Critical Value:	10	
Sufficient Samples Collected:	Yes	·
Maximum Value < DCGL:	Yes	
Median Value < DCGL:	Yes	
Mean Value < DCGL:	Yes	
Maximum Value < DCGLemc:	N/A	Class 3
Standard Deviation <= Sigma:	Investigate	No additional Samples
		Required
Pass the Sign Test?	Yes	
Reject the Null Hypothesis?	Yes	•
The survey unit passes all conditions?	Investigate	Survey Unit Passes

Survey Unit Investigations and Results:

No investigations were required for either direct or scan measurements and no investigation results are reported.

ALARA Statement:

As stated in Chapter 4 of the LTP, as long as the residual activity within the survey unit is less than the DCGL (i.e. the survey unit average activity is less than the DCGL), the ALARA criterion has been met.

Changes in Initial Survey Unit Assumptions:

The survey unit was designed as a Class 3 land survey and the sample results are consistent with that classification. The sample standard deviation was greater than the design standard deviation. However, both values of sigma result in a relative shift of greater than 3 so no additional samples were required.

Conclusion:


The FSS of this survey unit was properly designed as a Class 3 survey based on Table 5-4 of the LTP. The required number of direct measurements was made and the scan coverage met the requirement of Table 5-6 of the LTP. All of the direct measurements were less than the DCGL.


The direct measurement data support rejection of the null hypothesis, providing high confidence that the survey unit satisfied the release criteria and that the data quality objectives were met.

It is concluded that survey unit F8000041 meets the release criteria of 10CFR20.1402.

Attachment 1 Maps April 3, 2008

Survey Unit F8000041





Attachment 2

Instrumentation

April 3, 2008

Survey Unit F8000041

Table 2-1. Survey Unit Instrumentation

Instrument	Detector Model No.	Detector Serial No.	MDC
HPGe	N/A	05069128	Soil – 5.54E-2 pCi/g Cs-137 5.88E-2 pCi/g Co-60
Inspector	N/A	08051294	Concrete – 6.27E-1 pCi/g Cs-137 6.55E-1 pCi/g Co-60 Asphalt – 8.96E-1 pCi/g Cs-137 9.05E-1 pCi/g Co-60
ISOCS	N/A	2983947	Soil – 2.93E-1 pCi/g Cs-137 2.31E-1 pCi/g Co-60 Concrete – 3.31E-1 pCi/g Cs-137 2.28E-1 pCi/g Co-60 Asphalt – 3.19E-1 pCi/g Cs-137 2.46E-1 pCi/g Co-60

Table 2-2. Investigation Criteria and DCGL

Instrument	Parameter	Value
ISOCS	Investigation Criteria - Scan	20 pCi/g Cs-137
All	DCGL _W	51.2 Cs-137 12.6 Co-60
All	DCGL _{EMC}	N/A

Table 2-1. Survey Unit Instrumentation

Instrument	Detector Model No.	Detector Serial No.	MDC
HPGe	N/A	05069128	Soil – 5.54E-2 pCi/g Cs-137 5.88E-2 pCi/g Co-60
Inspector	N/A	08051294	Concrete – 6.27E-1 pCi/g Cs-137 6.55E-1 pCi/g Co-60 Asphalt – 8.96E-1 pCi/g Cs-137 9.05E-1 pCi/g Co-60
ISOCS	N/A	2983947	Soil – 2.93E-1 pCi/g Cs-137 2.31E-1 pCi/g Co-60 Concrete – 3.31E-1 pCi/g Cs-137 2.28E-1 pCi/g Co-60 Asphalt – 3.19E-1 pCi/g Cs-137 2.46E-1 pCi/g Co-60

Table 2-2. Investigation Criteria and DCGL

Instrument	Parameter	Value
ISOCS	Investigation Criteria - Scan	20 pCi/g Cs-137
All	DCGL _W	52.6 Cs-137 12.6 Co-60
All	DCGL _{EMC}	N/A

Attachment 3
Investigation
April 3, 2008
Survey Unit F8000041

(none required)

Attachment 4 Data Assessment April 3, 2008 Survey Unit F8000041

