Rancho Seco

Final Status Survey Summary Report

March 24, 2008

Intake Pump Structure

Survey Unit F8230001

Prepared By: Kin L. Brown **FSS Engineer** Date: 3/24/08 **Reviewed By:** Lead FSS Engineer 4-28-08 Date: Approved By:_

Dismantlement Superintendent, Radiological

FINAL STATUS SURVEY SUMMARY REPORT

Survey Unit:

F8230001, Intake Pump Structure

Survey Unit Description:

Operating History: This structure, located south of the cooling towers, housed the pumps which delivered cooling water to the cooling towers. This area was not reported to have been used for the storage of radioactive material. Operating records and the HSA document no events with the potential for a release of radioactivity associated with this survey area.

Site Characterization: Direct measurements were made of the surfaces of the structure which confirmed the absence of plant-derived radionuclides. Direct measurements showed a mean gross activity level of 260 dpm/100 cm² and a maximum value of 1,375 dpm/100 cm². Based on the classification procedure (DSIP-0020) and levels of gross activity reported, the area was determined to be a Class 3 area.

HSA Events: None

Survey Unit Design Information:

The Survey Unit Design Parameters are presented in Table 1 below. The survey unit and measurement locations are depicted on the maps in Attachment 1. Direct measurement locations were randomly determined and 21 m² were scanned for approximately 5% coverage. Samples of removable contamination were collected at each direct measurement location. The instrumentation used for the survey along with the MDC values are listed in Tables 2-1 and 2-2 in Attachment 2.

Survey Design Parameter	Value	Comment
Survey Area:	F823	Intake Pump Structure
Survey Unit:	0001	Structure Surface
Class:	3	LTP Table 5-4
SU Area (m ²):	402	
Evaluator:	Erin L. Brown	
DCGL (dpm/100 cm ²):	43000	Gross Activity DCGL
Area Factor:	N/A	Class 3
Design DCGLemc	N/A	Class 3
(dpm/100 cm ²):		
LBGR (dpm/100 cm ²):	21500	Default = 50% DCGL
Design Sigma (dpm/100 cm ²):	667	
Type I Error:	0.05	
Type II Error:	0.05	
Predominant Nuclide:	Cs-137	
Sample Area (m ²):	N/A	Class 3
Scan Area (m ²):	21	· · · · · ·
Scan Coverage (%):	5%	Class 3
$Z_{1-\alpha}$:	1.645	
Z _{1-β} :	1.645	
Sign P:	0.99865	
Calculated Relative Shift:	32.2	· · · · ·
Relative Shift Used:	. 3	Uses 3.0 if Relative Shift is
		>3
N-Value:	11	
Design N-Value + 20%:	14	NUREG-1575 Table 5-5
Design Min Samples N:	14	Class 3
Grid Spacing L:	N/A	Class 3

Table 1. Survey Unit Design Parameters

Survey Results:

A total of 14 direct measurements were made in F8230001. The results including mean, median, standard deviation and range are shown in Table 2. All direct measurements were less than the DCGL. None of the scan measurements indicated areas of elevated activity. Scan activity ranged from 4013 to 6896 dpm/100 cm², based on a surveyor efficiency of 0.5 and no background subtracted. Samples for removable surface activity were all less than 10% of the DCGL as shown in Table 3. Removable surface activity samples were counted for alpha activity and none was detected at the MDC shown in Table 2-1 of Attachment 2.

Measurement ID	Gross Activity (dpm/100 cm²)
F8230001-C0001BD	2314
F8230001-C0002BD	2282
F8230001-C0003BD	2469
F8230001-C0004BD	2256
F8230001-C0005BD	2350
F8230001-C0006BD	2443
F8230001-C0007BD	1810
F8230001-C0008BD	1790
F8230001-C0009BD	2298
F8230001-C0010BD	2371
F8230001-C0011BD	2630
F8230001-C0012BD	1935
F8230001-C0013BD	2469
F8230001-C0014BD	2552
Mean:	2284
Median:	2332
Standard Deviation:	262
Range:	1790 - 2630

Measurement ID	Surface Beta Activity (dpm/100 cm ²)
F8230001C0001SM	-2.24
F8230001C0002SM	-2.24
F8230001C0003SM	-3.53
F8230001C0004SM	-3.53
F8230001C0005SM	-2.24
F8230001C0006SM	-0.95
F8230001C0007SM	1.64
F8230001C0008SM	-3.53
F8230001C0009SM	-4.82
F8230001C0010SM	-4.82
F8230001C0011SM	1.64
F8230001C0012SM	1.64
F8230001C0013SM	0.34
F8230001C0014SM	1.64
Mean:	1.5
Median:	-2.24
Standard Deviation:	2.47
Range:	-4.82 to 1.64

Table 3. Removable Surface Activity Results

Survey Unit Data Assessment:

The survey design required 14 direct measurements for the Sign Test. The critical value and the results of the Sign Test are presented in Table 4. The sample mean and median values were less than the DCGL. The sample standard deviation was less than the design standard deviation so no additional samples were required.

		· · · · · · · · · · · · · · · · · · ·
Survey Results Parameter	Value	Comment
Material Background Used (dpm/100 cm ²):	N/A	
Ambient Background Used (dpm/100 cm ²):	N/A	Average Ambient BKG = 0
Actual Direct Measurements (N):	14	
Median (dpm/100 cm ²):	2332	
Mean (dpm/100 cm ²):	2284	
Direct Measurement Standard Deviation	262	
(dpm/100 cm ²):		
Total Standard Deviation (dpm/100 cm ²):	262	Based on samples and backgrounds.
Maximum (dpm/100 cm ²):	2630	-
Material Type:	N/A	Background Subtract Not
		Applied
Sign Test Final N Value:	14	
S+ Value:	· 14	
Critical Value:	. 10	
Sufficient Samples Collected:	Yes	· · · · · · · · · · · · · · · · · · ·
Maximum Value < DCGL:	Yes	
Median Value < DCGL:	Yes	
Mean Value < DCGL:	Yes	
Maximum Value < DCGLemc:	N/A	Class 3
Total Standard Deviation <= Sigma:	Yes	
Pass the Sign Test?	Yes	
Reject the Null Hypothesis?	Yes	· ·
Does the Survey Unit Pass All Criteria?	Yes	

Table 4. Data Assessment Results

Survey Unit Investigations and Results:

No investigations were required for either direct or scan measurements and no investigation results are reported.

ALARA Statement:

As stated in Chapter 4 of the LTP, as long as the residual activity within the survey unit is less than the DCGL (i.e. the survey unit average activity is less than the DCGL), the ALARA criterion has been met.

Changes in Initial Survey Unit Assumptions:

The survey unit was designed as a Class 3 structure survey and the sample results are consistent with that classification. The variability of the survey results was less than the characterization data used for survey design. No potential areas of elevated activity were detected.

Conclusion:

The FSS of this survey unit was properly designed as a Class 3 survey based on Table 5-4 of the LTP. The required number of direct measurements was made and the scan coverage met the requirement of Table 5-6 of the LTP. No direct measurements exceeded the DCGL of 43000 dpm/100 cm² and none of the removable surface activity measurements exceeded 10% of the DCGL. No investigations were required.

The direct measurement data support rejection of the null hypothesis, providing high confidence that the survey unit satisfied the release criteria and that the data quality objectives were met.

It is concluded that survey unit F8230001 meets the release criteria of 10CFR20.1402.

Attachment 1

Maps

March 24, 2008

Survey Unit F8230001



Page 2 of 10

Att. 1 Maps



Page 3 of 10

Att. 1 Maps





Page 5 of 10

Att. 1 Maps



Page 6 of 10

Att. 1 Maps



Page 7 of 10

Att. 1 Maps



Page 8 of 10

Att. 1 Maps



Page 9 of 10

Att. 1 Maps



Page 10 of 10

Att. 1 Maps

Attachment 2 Instrumentation March 24, 2008

Survey Unit F8230001

Instrument Model; Serial No.	Detector Model; Serial No.	MDC Static (dpm/100 cm²)	MDC Scan (dpm/100 cm²)
M2350; 193715	43-68B; 160703	433	1033
Tennelec; 0401171	[*] N/A	5.9 dpm α, 11.7 dpm β	N/A

Table 2-1. Survey Unit Instrumentation

Table 2-2. Investigation Criteria and DCGL

Parameter	Value (dpm/100 cm²)	
Investigation Criteria - Direct	21500	
Investigation Criteria – Scan	43000	
DCGLw	43000	
DCGL _{EMC}	N/A	

Attachment 3 Investigation March 24, 2008 Survey Unit F8230001

(none required)

Attachment 4 Data Assessment March 24, 2008

Survey Unit F8230001



Page 2 of 4

Att. 4 Data Assessment

Att. 4 Data Assessment



Page 3 of 4



Page 4 of 4

Att. 4 Data Assessment