

**From:** Getachew Tesfaye  
**Sent:** Thursday, May 29, 2008 11:20 AM  
**To:** 'usepr@areva.com'  
**Cc:** John Rycyna; Kenneth See; Mark Thaggard; Joseph Colaccino; Judith McLellan  
**Subject:** U.S. EPR Design Certification Application RAI No. 13  
**Attachments:** RAI 13 RHEB 260261262263264.doc

Attached please find the subject requests for additional information (RAI). A draft of the RAI was provided to you on May 18, 2008, and discussed with your staff on May 29, 2008. No change was made to the draft RAI as a result of that discussion. The schedule we have established for review of your application assumes technically correct and complete responses within 30 days of receipt of RAIs. For any RAIs that cannot be answered within 30 days, it is expected that a date for receipt of this information will be provided to the staff within the 30 day period so that the staff can assess how this information will impact the published schedule.

Getachew Tesfaye  
Office of New Reactors  
U.S. Nuclear Regulatory Commission  
(301) 415-3361

---

### E-mail Properties

Mail Envelope Properties (C56E360E9D804F4B95BC673F886381E71441ADD374)

**Subject:** U.S. EPR Design Certification Application RAI No. 13  
**Sent Date:** 5/29/2008 11:20:24 AM  
**Received Date:** 5/29/2008 11:19:00 AM  
**From:** Getachew Tesfaye

**Created By:** Getachew.Tesfaye@nrc.gov

#### Recipients:

usepr@areva.com ('usepr@areva.com')  
Tracking Status: None  
John.Rycyna@nrc.gov (John Rycyna)  
Tracking Status: None  
Kenneth.See@nrc.gov (Kenneth See)  
Tracking Status: None  
Mark.Thaggard@nrc.gov (Mark Thaggard)  
Tracking Status: None  
Joseph.Colaccino@nrc.gov (Joseph Colaccino)  
Tracking Status: None  
Judith.McLellan@nrc.gov (Judith McLellan)  
Tracking Status: None

Post Office:  
HQCLSTR02.nrc.gov

Files	Size	Date & Time	
MESSAGE	41245	5/29/2008	
RAI 13 RHEB 260261262263264.doc			30498

Options

Expiration Date:

Priority: olImportanceNormal

ReplyRequested: False

Return Notification: False

Sensitivity: olNormal

Recipients received:

Request for Additional Information No. 13, Revision 0

5/29/2008

U. S. EPR Standard Design Certification  
Alternate Energy Holdings  
Docket No. 52-020  
SRP Section: 02.04 - Hydrology  
SRP Section: 02.04.04 - Potential Dam Failures  
SRP Section: 02.04.06 - Probable Maximum Tsunami Flooding  
SRP Section: 02.04.09 - Channel Diversions  
SRP Section: 09.02.05 - Ultimate Heat Sink  
Application Section: 2.4  
RHEB Branch

QUESTIONS

02.04-1

Table 5.0-1 (Tier 1) states the maximum rainfall rate parameters as being for roof design while Table 2.1-1 (Tier 2) does not mention roof design. Is the rainfall rate of 19.4 in/hr to be used only for roof design?

02.04.04-1

Section 2.4.4 of the EPR DCD appears to only address seismically induced dam failures. SRP 2.4.4 addresses both seismic and non-seismic causes of dam failure. Please provide a basis for excluding non-seismic causes?

02.04.06-1

Section 2.4.6.2 states that the COL applicant will "...determine the extent to which safety-related facilities require protection from tsunami effects ". Clarify that "tsunami effects" includes the Probable Maximum Tsunami? If not, please provide a basis for excluding the Probable Maximum Tsunami.

02.04.09-1

Section 2.4.9.2 states that the COL applicant will "demonstrate in the event of upstream diversion or rerouting of the source of cooling water, alternate water supplies will be available to safety-related equipment." Explain why nearby down-stream diversions, which could lead to a backwater effect and therefore alter the water surface elevation at the site, not considered.

09.02.05-1

Section 9.2.5 UHS, Table 9.2.5 Ultimate Heat Sink Design Parameters. Were the values given based on the most severe meteorological conditions expected at a site? If so, what assures that they are representative of a reasonable number of sites?