

June 13, 2008

Mr. Charles G. Pardee  
Chief Nuclear Officer and Senior Vice President  
Exelon Generation Company, LLC  
200 Exelon Way  
Kennett Square, PA 19348

SUBJECT: LIMERICK GENERATING STATION, UNIT NOS. 1 AND 2 - INDIVIDUAL  
NOTICE OF CONSIDERATION OF ISSUANCE OF AMENDMENT REGARDING  
PROPOSED INCREASE IN EMERGENCY DIESEL GENERATOR DAY TANK  
MINIMUM FUEL VOLUME (TAC NOS. MD6599 AND MD6600)

Dear Mr. Pardee:

The Nuclear Regulatory Commission (NRC) has forwarded the enclosed "Notice of Consideration of Issuance of Amendment to Facility Operating License, Proposed No Significant Hazards Consideration Determination, and Opportunity for a Hearing," to the Office of the Federal Register for publication.

The proposed amendment would revise Technical Specification Limiting Condition for Operation 3.8.1.1.b.1, for the emergency diesel generator (EDG) day tanks, from its current minimum volume of 200 gallons to 250 gallons. This increase in required day tank volume is needed as a result of a Limerick Generating Station re-analysis of EDG fuel storage requirements, including the effects of using ultra-low sulfur diesel fuel oil.

Please contact me at 301-415-2833 if you have any questions.

Sincerely,

**/ra/ (JHughey for)**

Peter J. Bamford, Project Manager  
Plant Licensing Branch I-2  
Division of Operating Reactor Licensing  
Office of Nuclear Reactor Regulation

Docket Nos. 50-352 and 50-353

Enclosure: Notice of Consideration

cc w/encl: See next page

Limerick Generating Station, Unit Nos. 1 and 2  
cc:

Christopher Mudrick  
Site Vice President  
Limerick Generating Station  
Exelon Generation Company, LLC  
3146 Sanatoga Road  
Sanatoga, PA 19464

Ed Callan, Plant Manager  
Limerick Generating Station  
Exelon Generation Company, LLC  
3146 Santoga Road  
Sanatoga, PA 19464

Manager Regulatory Assurance - Limerick  
Generating Station  
Exelon Generation Company, LLC  
3146 Sanatoga Road  
Sanatoga, PA 19464

Senior Vice President - Mid-Atlantic  
Operations  
Exelon Generation Company, LLC  
200 Exelon Way, KSA 3-N  
Kennett Square, PA 19348

Chief Operating Officer– Exelon Nuclear  
Exelon Generation Company, LLC  
4300 Winfield Road  
Warrenville, IL 60555

Senior Vice President –Operations Support  
Exelon Generation Company, LLC  
4300 Winfield Road  
Warrenville, IL 60555

Vice President  
Licensing and Regulatory Affairs  
Exelon Generation Company, LLC  
4300 Winfield Road  
Warrenville, IL 60555

Director, Licensing and Regulatory Affairs  
Exelon Generation Company, LLC  
Correspondence Control  
P.O. Box 160  
Kennett Square, PA 19348

Manager Licensing  
Exelon Generation Company, LLC  
Correspondence Control  
P.O. Box 160  
Kennett Square, PA 19348

Correspondence Control Desk  
Exelon Generation Company, LLC  
200 Exelon Way, KSA 1-N-1  
Kennett Square, PA 19348

Regional Administrator, Region I  
U.S. Nuclear Regulatory Commission  
475 Allendale Road  
King of Prussia, PA 19406

Senior Resident Inspector  
U.S. Nuclear Regulatory Commission  
Limerick Generating Station  
P.O. Box 596  
Pottstown, PA 19464

Library  
U.S. Nuclear Regulatory Commission  
Region I  
475 Allendale Road  
King of Prussia, PA 19406

Director, Bureau of Radiation Protection  
Pennsylvania Dept. of Environmental  
Protection  
Rachel Carson State Office Building  
P.O. Box 8469  
Harrisburg, PA 17105-8469

Chairman  
Board of Supervisors of Limerick Township  
646 West Ridge Pike  
Linfield, PA 19468

Dr. Judith Johnsrud  
National Energy Committee  
Sierra Club  
433 Orlando Avenue  
State College, PA 16803

Limerick Generating Station, Unit Nos. 1 and 2  
cc:

J. Bradley Fewell, Esquire  
Associate General Counsel  
Exelon Generation Company, LLC  
4300 Winfield Road  
Kennett Square, PA 19348

Mr. Charles G. Pardee  
Chief Nuclear Officer and Senior Vice  
President  
Exelon Generation Company, LLC  
4300 Winfield Road  
Warrenville, IL 60555

June 13, 2008

Mr. Charles G. Pardee  
Chief Nuclear Officer and Senior Vice President  
Exelon Generation Company, LLC  
200 Exelon Way  
Kennett Square, PA 19348

SUBJECT: LIMERICK GENERATING STATION, UNIT NOS. 1 AND 2 - INDIVIDUAL NOTICE OF CONSIDERATION OF ISSUANCE OF AMENDMENT REGARDING PROPOSED INCREASE IN EMERGENCY DIESEL GENERATOR DAY TANK MINIMUM FUEL VOLUME (TAC NOS. MD6599 AND MD6600)

Dear Mr. Pardee:

The Nuclear Regulatory Commission (NRC) has forwarded the enclosed "Notice of Consideration of Issuance of Amendment to Facility Operating License, Proposed No Significant Hazards Consideration Determination, and Opportunity for a Hearing," to the Office of the Federal Register for publication.

The proposed amendment would revise Technical Specification Limiting Condition for Operation 3.8.1.1.b.1, for the emergency diesel generator (EDG) day tanks, from its current minimum volume of 200 gallons to 250 gallons. This increase in required day tank volume is needed as a result of a Limerick Generating Station re-analysis of EDG fuel storage requirements, including the effects of using ultra-low sulfur diesel fuel oil.

Please contact me at 301-415-2833 if you have any questions.

Sincerely,  
**/ra/ JHughey for**  
Peter J. Bamford, Project Manager  
Plant Licensing Branch I-2  
Division of Operating Reactor Licensing  
Office of Nuclear Reactor Regulation

Docket Nos. 50-352 and 50-353

Enclosure: As stated

cc w/encl: See next page

DISTRIBUTION:

PUBLIC LPL1-2 R/F RidsNrrPMPBamford RidsNrrLAABaxter  
RidsOgcRp RidsAcrcsAcnw&mMailCenter RidsNrrDorlLpl1-2 RidsRgn1MailCenter  
RidsNrrDorlDpr

Accession Number: ML081630605

OFFICE	LPL1-2/PM	LPL1-2/LA	LPL1-2/BC
NAME	PBamford	ABaxter	HChernoff
DATE	6/12/08	6/12/08	6/13/08

**Official Record Copy**