



**State of New Jersey**

DEPARTMENT OF ENVIRONMENTAL PROTECTION  
Division of Environmental Safety and Health  
Radiation Protection and Release Prevention Element  
Bureau of Nuclear Engineering  
P. O. Box 415  
Trenton, New Jersey 08625-0415  
Tel (609) 984-7700  
Fax (609) 984-7513

JON S. CORZINE  
Governor

LISA P. JACKSON  
Commissioner

May 22, 2008

United States Nuclear Regulatory Commission  
Document Control Desk  
Washington, DC 20555

Dear Commissioners:

Subject: Salem Generating Station Units 1 and 2  
Docket Nos. 50-272 and 50-311  
License Amendment Request S08-01  
Request for Change to Technical Specifications  
Refueling Operations – Decay Time

PSEG Nuclear LLC submitted the proposed change to the Salem Technical Specifications by letter to the NRC dated March 11, 2008. The proposed amendment would revise the requirements for fuel decay time prior to commencing movement of irradiated fuel. Technical Specification 3/4.9.3 "Decay Time" would be (1) revised to allow fuel movement to commence at 80 hours after the reactor is subcritical between October 15<sup>th</sup> and May 15<sup>th</sup>, and (2) relocated to the Salem UFSAR or the Technical Requirements Manual (TRM).

The BNE has no comments on the proposed change. If you need to discuss this subject further, please contact Elliot Rosenfeld at (609) 984-7548.

Sincerely,

Patrick Mulligan, Manager  
Bureau of Nuclear Engineering

Refueling Operations – Decay Time  
Request for Change to Technical Specifications  
License Amendment Request S08-01  
Docket Nos. 50-272 and 50-311  
Salem Generating Station

A001  
NRRA

Ditribution

Dr. Jill Lipoti, DEP

Paul Baldauf, DEP

Elliot Rosenfeld, DEP

Nancy McNamara, NRC Region 1

Rick Ennis, NRC Licensing Project Manager

Christine Neely, Director – Regulatory Assurance, PSEG Nuclear LLC

William Mattingly, Regulatory Assurance Manager, Salem Generating Station