



Tennessee Valley Authority, 1101 Market Street, LP 5A, Chattanooga, Tennessee 37402-2801

June 12, 2008

10 CFR 52.80

Document Control Desk
U.S. Nuclear Regulatory Commission
Washington, D.C. 20555

In the Matter of)
Tennessee Valley Authority)

Docket Numbers 52-014 and 52-015

NUCLEAR REGULATORY COMMISSION (NRC) – BELLEFONTE NUCLEAR
PLANT (BLN) – RESPONSE TO NRC INFORMATION NEEDS RELATED TO
ALTERNATIVES

Reference: Letter from Ashok Bhatnagar (TVA) to Mr. R. William Borchardt (NRC),
“Application for Combined License for BLN Units 3 and 4,” dated
October 30, 2007.

The purpose of this letter is to provide responses to the information needs relating to Alternatives, as identified by the NRC reviewers during the Environmental Report (ER) site audit conducted at the Tennessee Valley Authority (TVA) Bellefonte Nuclear Plant, Units 3 and 4 (BLN) site during the week of March 31 through April 4, 2008.

By the referenced letter, TVA submitted an application for a combined license for two AP1000 advanced passive pressurized-water reactors at the BLN site. Included in the review of a combined license application (COLA) is an environmental site audit during which the NRC staff tours the proposed plant site and environs and reviews the applicable documents that support the information provided in the ER. At the April 4, 2008 exit meeting for the BLN site audit, the NRC staff provided a list of information that was determined to be necessary to complete the review of the ER.

D085
N120


June 12, 2008

The enclosure to this letter provides responses to the NRC information needs related to alternatives and identifies changes that will be made in a future revision of the BLN application. The enclosure also provides the status of the alternatives information needs. Attachments A1 through N to the enclosure provide the documents that are identified in the BLN responses.

If there are any questions regarding this application, please contact Phillip Ray at 1101 Market Street, LP 5A, Chattanooga, Tennessee 37402-2801, by telephone at (423) 751-7030, or via email at pmray@tva.gov.

I declare under penalty of perjury that the foregoing is true and correct.

Executed on this 12th day of June, 2008.



Jack A. Bailey
Vice President, Nuclear Generation Development
Nuclear Generation Development & Construction

Enclosure and Attachments A1 - N
See Page 8

Enclosure: Response to NRC Information Needs – Alternatives (Alt)

Attachments A1 – N:

- A1. Business Week, July 4, 2005, News Analysis and Commentary, “Alternate Power: A Change Is in the Wind,” Website, http://www.businessweek.com/magazine/content/05_27/b3941036_mz011.htm, accessed January 12, 2007.
- A2. U.S. Department of Energy (DOE), Energy Information Administration (EIA), Nuclear Power., Website, no date, <http://www.eia.doe.gov/cneaf/nuclear/page/analysis/nuclearpower.html> (pages 1 - 7), accessed April 9, 2008.
- A3. Iowa Energy Center, Wind Energy Manual, “Wind Energy Economics,” 2006, Website, http://www.energy.iastate.edu/renewable/wind/wem/wem-13_econ.html, accessed January 18, 2007.
- A4. New Jersey’s Clean Energy Program, “Frequently Asked Questions – Offshore Wind Systems,” April 2006, Website, <http://www.njcep.com/html/faqs/offshorewind.html>, accessed January 12, 2007.
- A5. Tennessee Valley Authority (TVA), “The Role of Renewable Energy in Reducing Greenhouse Gas Buildup,” September 2003, Website, <http://www.tva.gov/environment/air/ontheair/renewable.htm>, accessed January 12, 2007.
- B1. Solarbuzz LLC, Fast Solar Energy Facts, “Global Performance,” March 2006, Website, <http://www.solarbuzz.com/FastFactsIndustry.htm>, accessed January 12, 2007.
- B2. University for Applied Sciences, Esslingen, Germany, “Solar Power Towers,” Mesanovic & Philippsen, 1996, Website, http://www.stud.fhtesslingen.de/projects/alt_energy/sol_thermal/powertower.html, accessed January 12, 2007.
- B3. U.S. Department of Energy (DOE), Concentrating Solar Power (CSP) Technologies, “Overview,” no date, Website, <http://www.energylan.sandia.gov/sunlab/overview.htm#cost>, accessed January 12, 2007.
- B4. U.S. Department of Energy (DOE), Energy Efficiency and Renewable Energy (EERE), Solar Energy Technology Program, “Furthering Energy Independence,” July 2006, Website, http://www1.eere.energy.gov/office_eere/pdfs/solar_fs.pdf, accessed November 2006.
- B5. U.S. Department of Energy (DOE), Energy Efficiency and Renewable Energy (EERE), Solar Energy Technologies Program, “Program Areas,” October 2006, Website, http://www1.eere.energy.gov/solar/program_areas.html, accessed January 12, 2007.

- B6. U.S. National Renewable Energy Laboratory (NREL), "Fuel from the Sky: Solar Power's Potential for Western Energy Supply," Leitner, July 2002, Website, <http://www.nrel.gov/csp/pdfs/32160.pdf>, accessed November 2006.
- B7. U.S. National Renewable Energy Laboratory (NREL), U.S. Solar Radiation Resource Maps, "Atlas for the Solar Radiation Data Manual for Flat-Plate and Concentrating Collectors," no date, Website, http://rredc.nrel.gov/solar/old_data/nsrdb/redbook/atlas, accessed November 2006.
- C. Idaho National Engineering and Environmental Laboratory, Renewable Energy Products Department, "U.S. Hydropower Resource Assessment, Final Report," December 1998, Website, <http://hydropower.inel.gov/resourceassessment/pdfs/doeid-10430.pdf>, accessed November 2006.
- D1. Geothermal Energy Association, "All about Geothermal Energy – Basics," no date, Website, <http://www.geoenergy.org/aboutGE/basics.asp#cap>, accessed January 12, 2007.
- D2. U.S. Department of Energy (DOE), Energy Efficiency and Renewable Energy (EERE), Geothermal Technologies Program, "Geothermal Power Plants," January 2006, Website, <http://www1.eere.energy.gov/geothermal/powerplants.html>, accessed April 26, 2007.
- D3. U.S. Department of Energy (DOE), Energy Efficiency and Renewable Energy (EERE), Geothermal Technologies Program, "U.S. Geothermal Resource Map," January 2006, Website, <http://www1.eere.energy.gov/geothermal/geomap.html>, accessed January 18, 2007.
- E1. REPP, Biomass, "What Can a Dash of Biomass Do?" no date, Website, <http://www.repp.org/bioenergy/link3.htm>, accessed April 23, 2007.
- E2. State of Oregon, Renewable Resources, "Biomass Energy: Cost of Production," no date, Website, <http://www.oregon.gov/ENERGY/RENEW/Biomass/Cost.shtml>, accessed April 26, 2007.
- E3. U.S. Department of Agriculture (DOA) and U.S. Department of Energy (DOE) Joint Study, "Biomass as Feedstock for A Bioenergy and Bioproducts Industry: The Technical Feasibility of a Billion-Ton Annual Supply," ORNL/TM-2005/66, April 2005, Website, http://feedstockreview.ornl.gov/pdf/billion_ton_vision.pdf, accessed November 2006.
- E4. U.S. Department of Energy (DOE), Energy Efficiency and Renewable Energy (EERE), Biopower Fact Sheet, "Biomass Cofiring: A Renewable Alternative for Utilities," DOE/GO-102000-1055, June 2000, Website, <http://www.nrel.gov/docs/fy00osti/28009.pdf>, accessed November 2006.

- E5. U.S. Department of Energy (DOE), Energy Information Administration (EIA), Forecasts, "Biomass for Electricity Generation," November 2002, Website, <http://www.eia.doe.gov/oiaf/analysispaper/biomass>, accessed January 12, 2007.
- F1. Florida Public Service Commission and the Department of Environmental Protection, "An Assessment of Renewable Electric Generating Technologies for Florida," January 2003, Website, http://www.psc.state.fl.us/publications/pdf/electricgas/Renewable_Energy_Assessment.pdf, accessed November 2006.
- F2. U.S. Environmental Protection Agency (EPA), "Electricity from Municipal Solid Waste," November 2006, Website, <http://www.epa.gov/cleanenergy/muni.htm>, accessed January 12, 2007.
- G1. RTI International, Jeffrey Cole, "Beyond-The-Floor Analysis for Existing and New Coal- And Oil-Fired Electric Utility Steam Generating Units National Emission Standards for Hazardous Air Pollutants," December 2003, Website, http://www.epa.gov/ttn/atw/utility/beyond_floor_012804.pdf, accessed November 2006.
- G2. U.S. Department of Energy (DOE), Energy Information Administration (EIA), "Net Generation by Energy Source by Type of Producer," October 2006, Website, <http://www.eia.doe.gov/cneaf/electricity/epa/epatlpl.html>, accessed January 18, 2007.
- G3. U.S. Department of Energy (DOE), Energy Information Administration (EIA), "Share of U.S. Net Electric Utility Generation by Energy Source," no date, Website, <http://www.eia.doe.gov/emev/25opec/sld027.htm>, accessed April 9, 2008.
- G4. U.S. Department of Energy (DOE), Energy Information Administration (EIA), "Summary Statistics: Receipts and Cost of Fossil Fuels for the Electric Power Industry by Sector, BTUs," October 2006, Website, <http://www.eia.doe.gov/cneaf/electricity/epm/tablees2b.html>, accessed January 18, 2007.
- H1. Breakthrough Technologies Institute (BTI), Fuel Cells 2000, "Fuel Cells 2000 Projects Database," November 2000, Website, <http://www.fuelcells.org/db/projects.php>, accessed March 25, 2008.
- H2. Electric Power Research Institute (EPRI), "Status & Trends for Stationary Fuel Cell Power Systems," 2005, Website, http://www.mitstanfordberkeleynano.org/events_past/0507%20-%20Fuel%20Cell/Stanford%20Fuel%20Cell%20Symposium.pdf, accessed November 2006.
- H3. Fuel Cell Today, "Facts & Figures," no date, Website, <http://www.fuelcelltoday.com/FuelCellToday/EducationCentre/EducationCentreExternal/edukit09en.pdf>, accessed November 2006.

- H4. University of California, Berkeley, "Fuel Cell System Economics: Comparing the Costs of Generating Power with Stationary and Motor Vehicle PEM Fuel Cell Systems," April 2004 (pages 1 and 113), Website, <http://rael.berkeley.edu/files/2004/lipman-edwards-kammen-fuelcelleconomics-2004.pdf>, accessed March 25, 2008.
- I1. U. S. Department of Energy (DOE) and JEA Joint Study, "The JEA Large-Scale CFB Combustion Demonstration Project," Clean Coal Technology Technical Report Number 22, March 2003 (cover page and pages 1 – 4), Website, www.fossil.energy.gov/programs/powersystems/publications/Clean_Coal_Topical_Reports/topical22.pdf, accessed June 1, 2008.
- I2. The University of Chicago, "The Economic Future of Nuclear Power," August 2004 (cover page, Table 1-1, and page 5-1), Website, http://213.130.42.236/wna_pdfs/uocstudy.pdf, accessed November 2006.
- I3. U.S. Department of Energy (DOE), National Energy Technology Laboratory (NETL), "Combustion - Fluidized-Bed Combustion, Program Overview," no date, Website, <http://www.netl.doe.gov/technologies/coalpower/Combustion/FBC/fbcoverview.html>, accessed April 23, 2007.
- J. Gasification Technologies Conference, San Francisco, Higman, DellaVilla, & Steele, "The Reliability of Integrated Gasification Combined Cycle (IGCC) Power Generation Units," October 2005, Website, http://www.gasification.org/Docs/2005_Papers/38HIGM%20Paper.pdf, accessed November 2006.
- K1. U.S. Department of Energy (DOE), Energy Information Administration (EIA), "Assumptions to the Annual Energy Outlook," DOE/EIA-0554(2006), March 2006, Website, [http://www.eia.doe.gov/oiaf/aeo/assumption/pdf/0554\(2006\).pdf](http://www.eia.doe.gov/oiaf/aeo/assumption/pdf/0554(2006).pdf), accessed November 2006.
- K2. Instituto Nacional de Investigaciones Nucleares, México, Palacios & others, "Levelized Costs for Nuclear, Gas and Coal for Electricity, under the Mexican Scenario," 2004, Website, <http://www.osti.gov/bridge/servlets/purl/840500-YJxBpR/native/840500.pdf>, accessed November 2006.
- K3. California Energy Commission, "Moss Landing Power Plant Project," August 1, 2007, Website, <http://www.energy.ca.gov/sitingcases/mosslanding/index.html>, accessed June 4, 2008.
- L. Big Stone II, "Plant project overview," 2006, Website, <http://www.bigstoneii.com/PlantProject/PlantProjectOverview.asp>, accessed April 23, 2007.
- M1. Hill & Associates report "Economic Benefits of a Coal-Fueled Power Plant Compared to Natural Gas, prepared for Peabody Energy, Website,

<http://coalcandothat.com/pdfs/EconBeneCoalFuel.pdf>, accessed November 2006.

- M2. Portland General Electric (PGE), "Frequently Asked Questions about Port Westward Power Plant," 2005, Website, http://www.portlandgeneral.com/about_pge/current_issues/portwestward/timeline.asp?bhcp=1, accessed April 23, 2007.
- M3. Portland General Electric (PGE), News Room, "Portland General Electric Announces Port Westward Plant Available for Commercial Generation," no date, Website, http://www.portlandgeneral.com/about_pge/news/06_12_2007_pge_announces_that_its_port_w.asp?bhcp+1, accessed April 9, 2008.
- N. Topographical Map Showing Dry Creek Basin and 630 Ft. Elevation Contour

cc (Enclosure and Attachments A1 - N):

M. A. Hood, NRC/HQ

cc (w/o Enclosure and Attachments A1 - N):

S. P. Frantz, Morgan Lewis

R. C. Grumbir, NuStart

P. S. Hastings, NuStart

R. H. Kitchen, PGN

M. C. Kray, NuStart

A. M. Monroe, SCE&G

M. C. Nolan, Westinghouse

N. T. Simms, Westinghouse

C. R. Pierce, SNC

L. Reyes, NRC/RII

R. F. Smith-Kevern, DOE/HQ

J. M. Sebrosky, NRC/

G. A. Zinke, NuStart

**RESPONSE TO NRC
INFORMATION NEEDS

ALTERNATIVES (Alt)**

TVA Letter Dated: June 11, 2008

Responses to Environmental Report Information Needs – Alternatives

This enclosure provides the status of the 33 NRC information needs related to the NRC review of Alternatives (Alt) and provides BLN responses to 17 of these Alt Information Needs.

Status of “Alt” Information Needs

NRC Information Need Number	Status
• Alt-01	Resolved at BLN site audit.
• Alt-02	Response provided in this enclosure.
• Alt-03	Response provided in this enclosure.
• Alt-04	Response provided in this enclosure.
• Alt-05	Response provided in this enclosure.
• Alt-06	Response provided in this enclosure.
• Alt-07	Response provided in this enclosure.
• Alt-08	Response provided in this enclosure.
• Alt-09	Response provided in this enclosure.
• Alt-10	Response provided in this enclosure.
• Alt-11	Response provided in this enclosure.
• Alt-12	Response provided in this enclosure.
• Alt-13	Response provided in this enclosure.
• Alt-14	Response provided in this enclosure.
• Alt-15	Response to be included in a separate TVA response letter providing Alternatives White Paper No. 3 (WP#3).
• Alt-16	Response to be included in a separate TVA response letter providing Alternatives White Paper No. 3 (WP#3).
• Alt-17	Response to be included in a separate TVA response letter providing Alternatives White Paper No. 3 (WP#3).
• Alt-18	Response to be included in a separate TVA response letter providing Alternatives White Paper No. 2 (WP#2).
• Alt-19	Response to this information need to be provided in separate TVA letters providing Alternatives White Paper No. 1 (WP#1) for subparts 1, 2 and 4 and White Paper No. 2 (WP#2) for subpart3.
• Alt-20	Response provided in this enclosure.
• Alt-21	Response to be included in a separate TVA response letter providing

TVA Letter Dated: June 11, 2008

Responses to Environmental Report Information Needs – Alternatives

**NRC Information
Need Number****Status**

- | | Alternatives White Paper No. 2 (WP#2). |
|----------|--|
| • Alt-22 | Response provided in this enclosure. |
| • Alt-23 | Response provided in TVA ER Ltr. 15 (Ref. 2) |
| • Alt-24 | Response provided in TVA ER Ltr. 08 (Ref. 3) |
| • Alt-25 | Response to be provided in a separate TVA response letter. |
| • Alt-26 | Resolved at BLN site audit. |
| • Alt-27 | Response provided in TVA ER Ltr. 08 (Ref. 03) |
| • Alt-28 | Response provided in TVA ER Ltr. 08 (Ref. 03) |
| • Alt-29 | Response provided in this enclosure. |
| • Alt-30 | Resolved at BLN site audit. |
| • Alt-31 | Response provided in this enclosure. |
| • Alt-32 | Response to be included in a separate TVA response letter providing Alternatives White Paper No. 4 (WP#4). |
| • Alt-33 | Response to be included in a separate TVA response letter providing Alternatives White Paper No. 3 (WP#3). |

References

1. Letter from Andrea L. Sterdis, Tennessee Valley Authority, to NRC Document Control Desk, "Response to Environmental Report (ER) Sufficiency Review Comments," dated May 2, 2008.
2. Letter from Jack A. Bailey, Tennessee Valley Authority, to NRC Document Control Desk, "Response to NRC Information Needs Related to Reservoir Vital Signs Monitoring Reports and Coal Gasification Project Environmental Impact Statement," dated June 11, 2008.
3. Letter from Jack A. Bailey, Tennessee Valley Authority, to NRC Document Control Desk, "Response to NRC Information Needs Related to Hydrology," dated June 12, 2008.

NRC Review of the BLN Environmental Report

NRC Information Needs - BLN ER Site Audit Exit Meeting

NRC Environmental Category: ALTERNATIVES

During the BLN Environmental Report site audit exit meeting on April 4, 2008, the NRC staff identified the following information need:

Reference/s needed for Wind Section, 9.2.2.1.

BLN INFORMATION NEED: Alt-02

BLN RESPONSE:

The source documents for ER Subsection 9.2.2.1 are provided as Attachments A1 through A5 to this enclosure, as addressed below.

ASSOCIATED BLN COL APPLICATION REVISIONS:

None.

ATTACHMENTS:

The following documents are provided as Attachments A1, A2, A3, A4, and A5 to this enclosure:

- A1. Business Week, July 4, 2005, News Analysis and Commentary, "Alternate Power: A Change Is in the Wind," Website, http://www.businessweek.com/magazine/content/05_27/b3941036_mz011.htm, accessed January 12, 2007.
- A2. U.S. Department of Energy (DOE), Energy Information Administration (EIA), Nuclear Power., Website, no date, <http://www.eia.doe.gov/cneaf/nuclear/page/analysis/nuclearpower.html> (pages 1 – 7), accessed April 9, 2008.
- A3. Iowa Energy Center, Wind Energy Manual, "Wind Energy Economics," 2006, Website, http://www.energy.iastate.edu/renewable/wind/wem/wem-13_econ.html, accessed January 18, 2007.
- A4. New Jersey's Clean Energy Program, "Frequently Asked Questions – Offshore Wind Systems," April 2006, Website, <http://www.njcep.com/html/faqs/offshorewind.html>, accessed January 12, 2007.
- A5. Tennessee Valley Authority (TVA), "The Role of Renewable Energy in Reducing Greenhouse Gas Buildup," September 2003, Website, <http://www.tva.gov/environment/air/ontheair/renewable.htm>, accessed January 12, 2007.

NRC Review of the BLN Environmental Report**NRC Information Needs - BLN ER Site Audit Exit Meeting****NRC Environmental Category: ALTERNATIVES**

During the BLN Environmental Report site audit exit meeting on April 4, 2008, the NRC staff identified the following information need:

Reference/s needed for Solar Section, 9.2.2.2 (specific to solar technology and capacity).

BLN INFORMATION NEED: Alt-03**BLN RESPONSE:**

The source documents for ER Subsection 9.2.2.2 are provided as Attachments B1 through B-7 to this enclosure, as addressed below.

ASSOCIATED BLN COL APPLICATION REVISIONS:

None.

ATTACHMENTS:

The following documents are provided as Attachments B1 through B7 to this enclosure:

- B1. Solarbuzz LLC, Fast Solar Energy Facts, "Global Performance," March 2006, Website, <http://www.solarbuzz.com/FastFactsIndustry.htm>, accessed January 12, 2007.
- B2. University for Applied Sciences, Esslingen, Germany, "Solar Power Towers," Mesanovic & Philippsen, 1996, Website, http://www.stud.fhtesslingen.de/projects/alt_energy/sol_thermal/powertower.html, accessed January 12, 2007.
- B3. U.S. Department of Energy (DOE), Concentrating Solar Power (CSP) Technologies, "Overview," no date, Website, <http://www.energylan.sandia.gov/sunlab/overview.htm#cost>, accessed January 12, 2007.
- B4. U.S. Department of Energy (DOE), Energy Efficiency and Renewable Energy (EERE), Solar Energy Technology Program, "Furthering Energy Independence," July 2006, Website, http://www1.eere.energy.gov/office_eere/pdfs/solar_fs.pdf, accessed November 2006.
- B5. U.S. Department of Energy (DOE), Energy Efficiency and Renewable Energy (EERE), Solar Energy Technologies Program, "Program Areas," October 2006, Website, http://www1.eere.energy.gov/solar/program_areas.html, accessed January 12, 2007.

- B6. U.S. National Renewable Energy Laboratory (NREL), "Fuel from the Sky: Solar Power's Potential for Western Energy Supply," Leitner, July 2002, Website, <http://www.nrel.gov/csp/pdfs/32160.pdf>, accessed November 2006.
- B7. U.S. National Renewable Energy Laboratory (NREL), U.S. Solar Radiation Resource Maps, "Atlas for the Solar Radiation Data Manual for Flat-Plate and Concentrating Collectors," no date, Website, http://rredc.nrel.gov/solar/old_data/nsrdb/redbook/atlas, accessed November 2006.

TVA Letter Dated: June 11, 2008

Responses to Environmental Report Information Needs – Alternatives

NRC Review of the BLN Environmental Report

NRC Information Needs - BLN ER Site Audit Exit Meeting

NRC Environmental Category: ALTERNATIVES

During the BLN Environmental Report site audit exit meeting on April 4, 2008, the NRC staff identified the following information need:

Provide formal reference for “The Idaho National Laboratory Hydro Resource Assessment” (Section 9.2.2.3).

BLN INFORMATION NEED: Alt-04

BLN RESPONSE:

The requested source document for ER Subsection 9.2.2.3 is provided as Attachment C to this enclosure, as addressed below.

ASSOCIATED BLN COL APPLICATION REVISIONS:

None.

ATTACHMENT:

The following document is provided as Attachment C to this enclosure:

- C. Idaho National Engineering and Environmental Laboratory, Renewable Energy Products Department, “U.S. Hydropower Resource Assessment, Final Report,” December 1998, Website, <http://hydropower.inel.gov/resourceassessment/pdfs/doeid-10430.pdf>, accessed November 2006.

NRC Review of the BLN Environmental Report

NRC Information Needs - BLN ER Site Audit Exit Meeting

NRC Environmental Category: ALTERNATIVES

During the BLN Environmental Report site audit exit meeting on April 4, 2008, the NRC staff identified the following information need:

Reference/s needed for Geothermal Section, 9.2.2.4.

BLN INFORMATION NEED: Alt-05

BLN RESPONSE:

The source documents for ER Subsection 9.2.2.4 are provided as Attachments D1 through D3 to this enclosure, as addressed below.

ASSOCIATED BLN COL APPLICATION REVISIONS:

None.

ATTACHMENTS:

The following documents are provided as Attachments D1, D2, and D3:

- D1. Geothermal Energy Association, "All about Geothermal Energy – Basics," no date, Website, <http://www.geoenergy.org/aboutGE/basics.asp#cap>, accessed January 12, 2007.
- D2. U.S. Department of Energy (DOE), Energy Efficiency and Renewable Energy (EERE), Geothermal Technologies Program, "Geothermal Power Plants," January 2006, Website, <http://www1.eere.energy.gov/geothermal/powerplants.html>, accessed April 26, 2007.
- D3. U.S. Department of Energy (DOE), Energy Efficiency and Renewable Energy (EERE), Geothermal Technologies Program, "U.S. Geothermal Resource Map," January 2006, Website, <http://www1.eere.energy.gov/geothermal/geomap.html>, accessed January 18, 2007.

NRC Review of the BLN Environmental Report**NRC Information Needs - BLN ER Site Audit Exit Meeting****NRC Environmental Category: ALTERNATIVES**

During the BLN Environmental Report site audit exit meeting on April 4, 2008, the NRC staff identified the following information need:

Reference/s needed for Biomass Related Fuels Section. 9.2.2.5.

BLN INFORMATION NEED: Alt-06**BLN RESPONSE:**

The source documents for ER Subsection 9.2.2.5 are provided as Attachments A5 and E1 through E5 to this enclosure, as addressed below.

ASSOCIATED BLN COL APPLICATION REVISIONS:

None.

ATTACHMENTS:

The following document is provided as Attachment A5, in response to Information Need Alt-02:

- A5. Tennessee Valley Authority (TVA), "The Role of Renewable Energy in Reducing Greenhouse Gas Buildup," September 2003, Website, <http://www.tva.gov/environment/air/ontheair/renewable.htm>, accessed January 12, 2007.

The following documents are provided as Attachments E1 through E5 to this enclosure:

- E1. REPP, Biomass, "What Can a Dash of Biomass Do?" no date, Website, <http://www.repp.org/bioenergy/link3.htm>, accessed April 23, 2007.
- E2. State of Oregon, Renewable Resources, "Biomass Energy: Cost of Production," no date, Website, <http://www.oregon.gov/ENERGY/RENEW/Biomass/Cost.shtml>, accessed April 26, 2007.
- E3. U.S. Department of Agriculture (DOA) and U.S. Department of Energy (DOE) Joint Study, "Biomass as Feedstock for A Bioenergy and Bioproducts Industry: The Technical Feasibility of a Billion-Ton Annual Supply," ORNL/TM-2005/66, April 2005, Website, http://feedstockreview.ornl.gov/pdf/billion_ton_vision.pdf, accessed November 2006.
- E4. U.S. Department of Energy (DOE), Energy Efficiency and Renewable Energy (EERE), Biopower Fact Sheet, "Biomass Cofiring: A Renewable Alternative for Utilities," DOE/GO-102000-1055, June 2000, Website, <http://www.nrel.gov/docs/fy00osti/28009.pdf>, accessed November 2006.

- E5. U.S. Department of Energy (DOE), Energy Information Administration (EIA),
Forecasts, "Biomass for Electricity Generation," November 2002, Website,
<http://www.eia.doe.gov/oiaf/analysispaper/biomass>, accessed January 12, 2007.

NRC Review of the BLN Environmental Report

NRC Information Needs - BLN ER Site Audit Exit Meeting

NRC Environmental Category: ALTERNATIVES

During the BLN Environmental Report site audit exit meeting on April 4, 2008, the NRC staff identified the following information need:

Reference/s needed for Municipal Solid Waste Section. 9.2.2.6.

BLN INFORMATION NEED: Alt-07

BLN RESPONSE:

The source documents for ER Subsection 9.2.2.6 are provided as Attachments F1 and F2 to this enclosure, as addressed below.

ASSOCIATED BLN COL APPLICATION REVISIONS:

None.

ATTACHMENTS:

The following documents are provided as Attachments F1 and F2 to this enclosure:

- F1. Florida Public Service Commission and the Department of Environmental Protection, "An Assessment of Renewable Electric Generating Technologies for Florida," January 2003, Website, http://www.psc.state.fl.us/publications/pdf/electricgas/Renewable_Energy_Assessment.pdf, accessed November 2006.
- F2. U.S. Environmental Protection Agency (EPA), "Electricity from Municipal Solid Waste," November 2006, Website, <http://www.epa.gov/cleanenergy/muni.htm>, accessed January 12, 2007.

NRC Review of the BLN Environmental Report**NRC Information Needs - BLN ER Site Audit Exit Meeting****NRC Environmental Category: ALTERNATIVES**

During the BLN Environmental Report site audit exit meeting on April 4, 2008, the NRC staff identified the following information need:

Reference/s needed for Petroleum Liquids Section. 9.2.2.7.

BLN INFORMATION NEED: Alt-08**BLN RESPONSE:**

The source documents for ER Subsection 9.2.2.7 are provided as Attachments G1 through G4 to this enclosure, as addressed below.

ASSOCIATED BLN COL APPLICATION REVISIONS:

None.

ATTACHMENTS:

The following documents are provided as Attachments G1 through G4 to this enclosure:

- G1. RTI International, Jeffrey Cole, "Beyond-The-Floor Analysis for Existing and New Coal- And Oil-Fired Electric Utility Steam Generating Units National Emission Standards for Hazardous Air Pollutants," December 2003, Website, http://www.epa.gov/ttn/atw/utility/beyond_floor_012804.pdf, accessed November 2006.
- G2. U.S. Department of Energy (DOE), Energy Information Administration (EIA), "Net Generation by Energy Source by Type of Producer," October 2006, Website, <http://www.eia.doe.gov/cneaf/electricity/epa/epat1p1.html>, accessed January 18, 2007.
- G3. U.S. Department of Energy (DOE), Energy Information Administration (EIA), "Share of U.S. Net Electric Utility Generation by Energy Source," no date, Website, <http://www.eia.doe.gov/emev/25opec/sld027.htm>, accessed April 9, 2008.
- G4. U.S. Department of Energy (DOE), Energy Information Administration (EIA), "Summary Statistics: Receipts and Cost of Fossil Fuels for the Electric Power Industry by Sector, BTUs," October 2006, Website, <http://www.eia.doe.gov/cneaf/electricity/epm/tablees2b.html>, accessed January 18, 2007.

NRC Review of the BLN Environmental Report

NRC Information Needs - BLN ER Site Audit Exit Meeting

NRC Environmental Category: ALTERNATIVES

During the BLN Environmental Report site audit exit meeting on April 4, 2008, the NRC staff identified the following information need:

Reference/s needed for Fuel Cells Section. 9.2.2.8.

BLN INFORMATION NEED: Alt-09

BLN RESPONSE:

The source documents for ER Subsection 9.2.2.8 are provided as Attachments H1 through H4 to this enclosure, as addressed below.

ASSOCIATED BLN COL APPLICATION REVISIONS:

None.

ATTACHMENTS:

The following documents are provided as Attachments H1 through H4 to this enclosure:

- H1. Breakthrough Technologies Institute (BTI), Fuel Cells 2000, "Fuel Cells 2000 Projects Database," November 2000, Website, <http://www.fuelcells.org/db/projects.php>, accessed March 25, 2008.
- H2. Electric Power Research Institute (EPRI), "Status & Trends for Stationary Fuel Cell Power Systems," 2005, Website, http://www.mitstanfordberkeleynano.org/events_past/0507%20-%20Fuel%20Cell/Stanford%20Fuel%20Cell%20Symposium.pdf, accessed November 2006.
- H3. Fuel Cell Today, "Facts & Figures," no date, Website, <http://www.fuelcelltoday.com/FuelCellToday/EducationCentre/EducationCentreExternal/edukit09en.pdf>, accessed November 2006.
- H4. University of California, Berkeley, "Fuel Cell System Economics: Comparing the Costs of Generating Power with Stationary and Motor Vehicle PEM Fuel Cell Systems," April 2004 (pages 1 and 113), Website, <http://rael.berkeley.edu/files/2004/lipman-edwards-kammen-fuelcelleconomics-2004.pdf>, accessed March 25, 2008.

NRC Review of the BLN Environmental Report**NRC Information Needs - BLN ER Site Audit Exit Meeting****NRC Environmental Category: ALTERNATIVES**

During the BLN Environmental Report site audit exit meeting on April 4, 2008, the NRC staff identified the following information need:

Reference/s needed for Pulverized Coal Section. 9.2.2.9. Specifically references needed for following conclusions/numbers:

- See paragraph 5, "FBC is not a cost-effective alternative for the proposed project."
- See paragraph 6, "PFBC systems would eventually exceed 50 percent."
- See paragraph 8, "Recent estimates indicate that capital costs for conventional pulverized-coal-fired power plants range from \$1094/kW to \$1169/kW. The levelized cost of electricity produced from pulverized-coal-fired power plants is \$0.033/kWh to \$0.041/kWh."

BLN INFORMATION NEED: Alt-10**BLN RESPONSE:**

The source documents for ER Subsection 9.2.2.9 are provided as Attachments I1 through I3 to this enclosure, as addressed below.

During the review of the documentation provided in response to this information need, it was identified that the capital cost information from Table 1-1 of the University of Chicago paper (Attachment I2) is misstated in Subsection 9.2.2.9, paragraph 8. The high-end capital cost estimate should be \$1350/kW, rather than \$1169/kW. This information is corrected in the BLN COL Application below.

ASSOCIATED BLN COL APPLICATION REVISIONS:

Revise COLA Part 3, ER Chapter 9, Section 9.2.2.9, by revising the first sentence in the 8th paragraph, as follows:

Recent estimates indicate that capital costs for conventional pulverized-coal-fired power plants range from \$1094/kW to ~~\$1169/kW~~ \$1350/kW.

ATTACHMENTS:

The following documents are provided as Attachments I1 through I3 to this enclosure:

- I1. U. S. Department of Energy (DOE) and JEA Joint Study, "The JEA Large-Scale CFB Combustion Demonstration Project," Clean Coal Technology Technical Report Number 22, March 2003 (cover page and pages 1 – 4), Website,

TVA Letter Dated: June 11, 2008

Responses to Environmental Report Information Needs – Alternatives

- www.fossil.energy.gov/programs/powersystems/publications/Clean_Coal_Topical_Reports/topical22.pdf, accessed June 1, 2008.
12. The University of Chicago, "The Economic Future of Nuclear Power," August 2004 (cover page, Table 1-1, and page 5-1), Website, http://213.130.42.236/wna_pdfs/uocstudy.pdf, accessed November 2006.
 13. U.S. Department of Energy (DOE), National Energy Technology Laboratory (NETL), "Combustion - Fluidized-Bed Combustion, Program Overview," no date, Website; <http://www.netl.doe.gov/technologies/coalpower/Combustion/FBC/fbcoverview.html>, accessed April 23, 2007.

NRC Review of the BLN Environmental Report

NRC Information Needs - BLN ER Site Audit Exit Meeting

NRC Environmental Category: ALTERNATIVES

During the BLN Environmental Report site audit exit meeting on April 4, 2008, the NRC staff identified the following information need:

Explain who/what is the source of “experience” (listed as basis for Integrated Gasification Combined Cycle conclusions – Section 9.2.2.10, paragraph 4). Describe experience or list reference.

BLN INFORMATION NEED: Alt-11

BLN RESPONSE:

The source of the experience listed as the basis for the Integrated Gasification Combined Cycle conclusions in the fourth paragraph of ER Subsection 9.2.2.10, is provided as Attachment J to this enclosure, as addressed below.

ASSOCIATED BLN COL APPLICATION REVISIONS:

None.

ATTACHMENT:

The following document is provided as Attachment J to this enclosure:

- J. Gasification Technologies Conference, San Francisco, Higman, DellaVilla, & Steele, “The Reliability of Integrated Gasification Combined Cycle (IGCC) Power Generation Units,” October 2005, Website, http://www.gasification.org/Docs/2005_Papers/38HIGM%20Paper.pdf, accessed November 2006.

NRC Review of the BLN Environmental Report**NRC Information Needs - BLN ER Site Audit Exit Meeting****NRC Environmental Category: ALTERNATIVES**

During the BLN Environmental Report site audit exit meeting on April 4, 2008, the NRC staff identified the following information need:

Provide reference for studies listed as source of Natural Gas discussion and verify sizing assumptions throughout assessment of reasonable alternatives.

BLN INFORMATION NEED: Alt-12**BLN RESPONSE:**

The source documents for the studies listed in the natural gas discussion are provided as Attachments K1 through K3 to this enclosure, as addressed below.

Sizing assumptions throughout the assessment of reasonable alternatives were verified to confirm they are reasonable for the alternative energy source plants used in the comparison. The 530 MW plant sizes were chosen to provide a plant configuration that could be developed for an easy comparison with the AP1000 net capacity. As stated in ER Subsection 9.2.3.2, TVA understands that four 530 MW units would provide less capacity than the proposed two AP1000 nuclear units, as this configuration would minimize the potential for overestimating environmental impacts from the alternatives. The capacity of TVA's current fleet of coal-fired plants ranges from less than 100 MW to greater than 1200 MW. Based on this range, a 530 MW pulverized-coal-fired generation was determined to be both reasonable and achievable. Similarly, the 530 MW combined-cycle natural-gas-fired generation units were chosen based on research that determined the feasibility of constructing units that meet this sizing criterion. An example of 530 MW natural-gas-fired units is presented in Attachment K3.

ASSOCIATED BLN COL APPLICATION REVISIONS:

None.

ATTACHMENTS:

The following documents are provided as Attachments K1 through K3 of this enclosure:

- K1. U.S. Department of Energy (DOE), Energy Information Administration (EIA), "Assumptions to the Annual Energy Outlook," DOE/EIA-0554(2006), March 2006, Website, [http://www.eia.doe.gov/oiaf/aeo/assumption/pdf/0554\(2006\).pdf](http://www.eia.doe.gov/oiaf/aeo/assumption/pdf/0554(2006).pdf), accessed November 2006.

- K2. Instituto Nacional de Investigaciones Nucleares, México, Palacios & others, "Levelized Costs for Nuclear, Gas and Coal for Electricity, under the Mexican Scenario," 2004, Website, <http://www.osti.gov/bridge/servlets/purl/840500-YJxBpR/native/840500.pdf>, accessed November 2006.
- K3. California Energy Commission, "Moss Landing Power Plant Project," August 1, 2007, Website, <http://www.energy.ca.gov/sitingcases/mosslanding/index.html>, accessed June 4, 2008.

NRC Review of the BLN Environmental Report

NRC Information Needs - BLN ER Site Audit Exit Meeting

NRC Environmental Category: ALTERNATIVES

During the BLN Environmental Report site audit exit meeting on April 4, 2008, the NRC staff identified the following information need:

Provide source of socioeconomic data listed in “Other Impacts,” Section 9.2.3.1.3.

BLN INFORMATION NEED: Alt-13

BLN RESPONSE:

The source document for the socioeconomic data listed in ER Subsection 9.2.3.1.3 is provided as Attachment L to this enclosure, as addressed below.

ASSOCIATED BLN COL APPLICATION REVISIONS:

None.

ATTACHMENT:

The following document is provided as Attachment L to this enclosure:

- L. Big Stone II, “Plant project overview,” 2006, Website,
<http://www.bigstoneii.com/PlantProject/PlantProjectOverview.asp>, accessed April 23,
2007.

NRC Review of the BLN Environmental Report

NRC Information Needs - BLN ER Site Audit Exit Meeting

NRC Environmental Category: ALTERNATIVES

During the BLN Environmental Report site audit exit meeting on April 4, 2008, the NRC staff identified the following information need:

Provide source of socioeconomic data listed in “Other Impacts,” Section 9.2.3.2.3.

BLN INFORMATION NEED: Alt-14

BLN RESPONSE:

The source documents for ER Subsection 9.2.3.2.3 are provided as Attachments M1 through M3 to this enclosure, as addressed below.

ASSOCIATED BLN COL APPLICATION REVISIONS:

None.

ATTACHMENTS:

The following documents are provided as Attachments M1, M2, and M3 to this enclosure:

- M1. Hill & Associates report “Economic Benefits of a Coal-Fueled Power Plant Compared to Natural Gas, prepared for Peabody Energy, Website, <http://coalcandothat.com/pdfs/EconBeneCoalFuel.pdf>, accessed November 2006.
- M2. Portland General Electric (PGE), “Frequently Asked Questions about Port Westward Power Plant,” 2005, Website, http://www.portlandgeneral.com/about_pge/current_issues/portwestward/timeline.asp?bhcp=1, accessed April 23, 2007.
- M3. Portland General Electric (PGE), News Room, no date, “Portland General Electric Announces Port Westward Plant Available for Commercial Generation,” Website, http://www.portlandgeneral.com/about_pge/news/06_12_2007_pge_announces_that_its_port_w.asp?bhcp=1, accessed April 9, 2008.

NRC Review of the BLN Environmental Report

NRC Information Needs - BLN ER Site Audit Exit Meeting

NRC Environmental Category: ALTERNATIVES

During the BLN Environmental Report site audit exit meeting on April 4, 2008, the NRC staff identified the following information need:

Page 9.3-4 of ER, #2, states that “The selected sites received subsequent evaluations under NEPA (from both TVA and the NRC) that included comparisons for environmental impacts and engineering feasibility as nuclear plant sites with the alternative sites.” Describe evaluation activities that took place, including dates, and reference formal documents if available.

BLN INFORMATION NEED: Alt-20

BLN RESPONSE:

Item 2 on page 9.3-4 is referring to the analyses and documentation in the Final Environmental [Impact] Statements, prepared for the Bellefonte, Hartsville, and Yellow Creek nuclear sites and the Murphy Hill Coal Gasification site, and the Environmental Report prepared for the Phipps Bend nuclear site. The pertinent TVA documents are the five cited on page 9.3-3 of the ER (References 2 through 6). The statement simply means that the selected and alternative candidate sites identified in those review documents underwent comparison of environmental impacts and engineering feasibility under the NEPA process. These references were made available to the NRC reviewers as references for the BLN ER. A change to the text in Item 2 is provided to delete the word “subsequent,” which leads to the misunderstanding that additional evaluations occurred after the completion of the Final Environmental Statements.

Evaluations performed for these documents were typical of EIS-level reviews involving siting and construction of nuclear generation facilities. They included review of potential impacts for the selected site; consideration of alternative sites, plant operations; construction and operation of transmission and other ancillary infrastructure requirements; and management and transportation of new fuel, spent fuel, and radioactive waste. Issue areas and potential impacts to resources considered included geology, soils, seismology, climatology and meteorology, air quality, solid waste, noise, socio-economics, surface water (quality, use, thermal impacts) and groundwater, land use and land use compatibility, aesthetics, transportation, recreation, aquatic and terrestrial ecology (plants and animals), rare and endangered species, cultural resources, and human health.

ASSOCIATED BLN COL APPLICATION REVISIONS:

Revise COLA Part 3, ER Chapter 9, Section 9.3.2.2, by revising item 2 on page 9.3-4, as follows:

2. The selected sites received ~~subsequent~~ evaluations under NEPA (from both TVA and the NRC) that included comparisons for environmental impacts and engineering feasibility as nuclear plant sites with the alternative sites.

ATTACHMENTS:

None.

NRC Review of the BLN Environmental Report

NRC Information Needs - BLN ER Site Audit Exit Meeting

NRC Environmental Category: ALTERNATIVES

During the BLN Environmental Report site audit exit meeting on April 4, 2008, the NRC staff identified the following information need:

It is stated that the 4 alternative sites conformed with land use urban and industrial development controls and policies during the original construction planning was taking place (1970s and 1980s); however, there is no description of the current land use zoning and policies may be for the 4 alternative sites. An updated description of these local government controls and policies (if any) is needed.

BLN INFORMATION NEED: Alt-22

BLN RESPONSE:

As an instrument of the federal government, TVA is not subject to local zoning or state regulation, but considers such factors in its review of sites. In support of this review, TVA staff contacted local county governments to update the status of local zoning and land use planning for the alternative sites. At three of the alternative sites, local governments exercise no zoning controls and do not have other land use plans or reviews that could conflict with the use of the sites for nuclear power production. These include the Phipps Bend nuclear (PBN) site in Hawkins County, Tennessee, the Yellow Creek nuclear (YCN) site in Tishomingo County, Mississippi, and the Murphy Hill (MH) site in Marshall County, Alabama.

Although acquired for power production purposes, the MH site is currently designated by TVA for natural resource conservation purposes. The Alabama Department of Transportation is re-evaluating a segment of a planned interstate highway, the Memphis to Atlanta Corridor, that would cross through the southern part of the MH site, between river miles 368 and 369. This potential highway expansion is currently under consideration; no firm plans have been made to move forward on this project.

As shown in ER Figure 9.3-4, the Hartsville nuclear (HVN) site is located within two Tennessee counties. Most of the current site is in Trousdale County, but a small portion on the east side of the site is in Smith County. The land in the Trousdale County portion of the HVN site is currently zoned either M-1 or M-2. These zoning classifications are different categories of light to intermediate impact industries. The portion in Smith County and the immediate area around the eastern side of the site is zoned either agricultural or light industry (I-1). In addition, there is adjoining land along the east side, also in Smith County, that could be considered for nuclear construction. In both counties, the County Commission has zoning authority. Zoning requests are reviewed by the county planning commission and, in Trousdale County, by the county Building and Codes Department. Recommendations by these bodies are sent to the County Commissions for final action.

As discussed with the NRC reviewers during the HVN site visit on May 14, 2008, Corrections Corporation of America recently announced (February 22, 2008) its intention to build the

TVA Letter Dated: June 11, 2008

Responses to Environmental Report Information Needs – Alternatives

Trousdale Corrections Center on the PowerCom Industrial Center site. A customer for this maximum-security prison facility has not yet been finalized.

ASSOCIATED BLN COL APPLICATION REVISIONS:

None.

ATTACHMENTS:

None.

NRC Review of the BLN Environmental Report

NRC Information Needs - BLN ER Site Audit Exit Meeting

NRC Environmental Category: ALTERNATIVES

During the BLN Environmental Report site audit exit meeting on April 4, 2008, the NRC staff identified the following information need:

Location of Dry Creek Basin

BLN INFORMATION NEED: Alt-29

BLN RESPONSE:

The Dry Creek “basin” would be the depression in which Dry Creek runs (i.e., the creek valley). Dry Creek is several miles away from the plant, and any impoundment to elevation 630 ft. msl for a cooling pond would be a significant distance from the site and impact not only Dry Creek, but Town Creek as well. A topographical map that shows the Dry Creek basin and the 630 ft. elevation contour (in red) is provided as Attachment N. This alternative was determined not to be viable, because of the large amount of land that would be required to support it. Therefore, no effort was made to develop a more detailed design of this cooling pond, and the map provided as Attachment N is not modified to include dikes, bridges, or any other engineering features that would be required to pursue this alternative further.

ASSOCIATED BLN COL APPLICATION REVISIONS:

None.

ATTACHMENT:

N. Topographical Map Showing Dry Creek Basin and 630 Ft. Elevation Contour

NRC Review of the BLN Environmental Report**NRC Information Needs - BLN ER Site Audit Exit Meeting****NRC Environmental Category: ALTERNATIVES**

During the BLN Environmental Report site audit exit meeting on April 4, 2008, the NRC staff identified the following information need:

Explanation of Fish Return Alternate Systems for intake systems

BLN INFORMATION NEED: Alt-31**BLN RESPONSE:**

TVA has no plan to install a fish return system for the BLN intake system. BLN's through-screen velocities are estimated to be 0.12 fps at maximum pool elevation of 595 feet, well below the Section 316(b) 0.5 fps requirement. Because the BLN through-screen velocities are less than the Section 316(b) requirement, BLN is exempt from the EPA Phase II rule and is not required to collect impingement mortality studies to comply with the rule. Similarly, Watts Bar Nuclear Plant was not required to collect impingement mortality samples on their intake below Watts Bar Dam, because they were also exempt. While impingement mortality at Widows Creek Fossil Plant (WCF) is low compared to other TVA plants on the Tennessee River, BLN impingement mortality of fish and shellfish is expected to be extremely low in comparison to WCF, due to BLN's very low, through-screen velocities.

ASSOCIATED BLN COL APPLICATION REVISIONS:

None.

ATTACHMENTS:

None.

ATTACHMENT A1
BUSINESS WEEK
“ALTERNATE POWER: A CHANGE IS IN THE WIND”
JULY 4, 2005

Business Week
News Analysis and Commentary

“Alternate Power: A Change is in the Wind”

July 4, 2005



BusinessWeek online

SEARCH SITE

GO

Advanced Search

TOP NEWS

BW MAGAZINE

INVESTING

ASIA

EUROPE

TECHNOLOGY

AUTOS

INNOVATION

SMALL BIZ

B-SCHOOLS

CAREERS

JULY 4, 2005

NEWS: ANALYSIS & COMMENTARY

Get Four Free Issues

Register

Subscribe to BW

Customer Service

Full Table of Contents
Cover Story
Up Front
Readers Report
Corrections & Clarifications
Voices of Innovation
Technology & You
Media Centric
The Barker Portfolio
Business Outlook
News: Analysis & Commentary

In Biz This Week
Washington Outlook
Asian Business
European Business
International Outlook
Industry Insider
Developments to Watch
The Corporation
Marketing
Government
Information Technology
Finance
Social Issues
Personal Business
Plus

Alternate Power: A Change Is In The Wind

The industry is gaining critical mass, but its economic future remains iffy

The words "solar power" conjure up images of ungainly rooftop panels mounted by die-hard environmentalists. But Jigar Shah plans to change all that. As CEO of Baltimore-based SunEdison LLC, he dreams of the sun supplying up to 10% of the electricity needed in many parts of the country. And now he has the financial muscle to embark on his vision. On June 9, SunEdison announced a \$60 million fund, financed by Goldman Sachs (**GS**) and Hudson United Bank (**HU**), to oversee BP Solar's (**BP**) installation of 25 electric systems on Staples (**SPLS**) and Whole Foods Market (**WFMI**) stores, along with other locations. The recipients get reliable power at a guaranteed price, providing a hedge against cost spikes during periods of peak electricity demand. The financiers catch a ride on a global solar market that's already more than \$7 billion per year and expanding at a rate of more than 30% annually. "The growth opportunities are tremendous," says Shah.

Get 4 FREE Issues! ▶



STORY TOOLS

- ▶ Printer-Friendly Version
- ▶ E-Mail This Story



RELATED ITEMS

Chart: Getting Cheaper

Graphic: Powering Up

NEWS: ANALYSIS & COMMENTARY

Courtroom Strategies On Trial

Tyco's Tentative Turnaround

Alternate Power: A Change Is In The Wind

TODAY'S MOST POPULAR STORIES

1. Satellite Static
2. The Real Genius of Apple's iPhone
3. Wedding Bells for XM and Sirius?
4. More Headaches for Big Oil
5. China Stocks: A Pause in the Party?

Get Free RSS Feed >>

MARKET INFO

DJIA	12554.47	+39.40
S&P 500	1430.33	+6.51
Nasdaq	2498.51	+13.66

STOCK LOOKUP GO

Stocks Inch Higher After Retail Sales Gain

Create / Check Portfolio
Launch Pop-up Ticker

Inside Wall Street
Ideas -- Books
Ideas -- Viewpoint
Figures Of The Week
Editorials

INTERNATIONAL
EDITIONS
International -- Readers
Report
International -- Int'l Figures
of the Week

BUSINESS DIRECTORY

Stop searching,
start finding!

401K Plans
Accounting
Advertising &
Marketing
Air Charter
Air Travel
Annuities
Antivirus / Antispan

POWERED BY
DIRECTORY M

PREMIUM CONTENT

MBA Insider

BW MAGAZINE

Get Four Free Issues

Register

Subscribe

Customer Service

ONLINE FEATURES

Book Reviews

BW Video

Columnists

Interactive Gallery

Newsletters

Past Covers

Philanthropy



Precise in a world that isn't.™ **SPDRs**
S&P 500 INDEX FUND

Everybody Wants A Piece Of
The Air

GM: Flirting With The Nuclear
Option

Looks Like A Sure Thing, But...

Dude, Where's My Digital Car?

The new dawn isn't limited to solar power. An array of alternative-energy, energy-efficiency, and other green technologies -- together known as "cleantech" -- are beginning to boom. A host of forces is responsible for the trend: high prices for oil, gas, and coal; expanded government incentives and mandates; advances in technology that are reducing costs; concern over global warming; and investors looking for the Next Big Thing. "What has changed dramatically is the number of mainstream institutions that have decided they can make money in this area," says Dan Reicher, president of New Energy Capital Corp. and a former top Energy Dept. official. "Who would have thought two years ago that Goldman Sachs would be investing in wind and solar power?"

SHIFT IN THE GROUND

Indeed, an increasing number of major corporate players like General Electric and Siemens (**SI**), traditional venture-capital firms such as Kleiner Perkins Caufield & Byers, and even states are putting money into the market. In its so-called Green Wave Initiative, California plans to use \$500 million from two state pension funds -- CalPERS and CalSTRS -- to seed proposals for alternative energy. "Clean technology is becoming the enabling technology of the 21st century industrial society," says Nicholas Parker, chairman of Cleantech Venture Network LLC, which tracks the field for its investor members.

But cleantech comes with daunting risks as well as opportunities. The big uncertainty: Its economics and profitability vary dramatically with changes in energy prices and government policies. "For a long time, with low gas and coal

Podcasts

Special Reports

BLOGS

Auto Beat

Bangalore Tigers

Blogspotting

Brand New Day

Byte of the Apple

Deal Flow

Economics Unbound

Fine On Media

Hot Property

Investing Insights

New Tech in Asia

NussbaumOnDesign

Tech Beat

Working Parents

TECHNOLOGY

J.D. Power Ratings

Product Reviews

Tech Stats

Wildstrom: Tech
Maven**AUTOS**

Home Page

Auto Reviews

Classic Cars

Car Care & Safety

Hybrids

**INNOVATION
& DESIGN**

Home Page

Architecture

Brand Equity

Auto Design

Game Room

SMALLBIZ

Smart Answers

Success Stories

prices, renewables of all kinds couldn't compete," explains Jerry Peters, senior vice-president at Hudson United Bank. But now, with natural gas rising to more than \$7 per million BTUs and eastern coal up to \$60 per ton, average U.S. electricity prices, by state, now range from 5 cents to 16 cents per kilowatt hour (kwh). In some states, that's a 25% jump since 1995. At the same time, technological improvements and economies of scale have significantly lowered the costs of alternatives. Wind-power costs have declined to as little as 3 cents to 5 cents per kwh, making wind cost competitive. That's one reason why GE's wind business has soared from \$500 million in 2002 to a predicted \$2 billion this year.

Yet wind power wouldn't be growing at its current U.S. rate of 37% per year without government mandates and incentives. When Congress delayed renewing the 1.8 cents per kwh credit for wind power last summer, for instance, the business tanked until the credit was restored.

The delicate interplay of prices and policies is even more complicated for solar power, which is still at least 3 to 5 times as costly as conventional sources and thus dependent on subsidies. Germany has become a leader in solar electricity because of what Erik Straser, general partner at Mohr, Davidow Ventures, calls a "masterful" policy: When companies or individuals install photovoltaic panels, the government pays them about four times the going rate of electricity for any power that flows back into the grid. The approach has been "successfully copied by South Korea, Japan, and Spain," says Straser. "It's a way for a country to take a fundamental step toward energy independence."

While that may seem a high price to pay for energy alternatives, such policies are paving the way for a lower-cost future. Because of the growing worldwide market and manufacturing advances at big silicon-panel makers like Sharp Corp. (SHCAY), installed costs for solar systems have been dropping at a steady 5% per year for the past decade -- and should continue to do so. By 2010 or 2015, predicts SunEdison's Shah, solar electricity will be cost-competitive in some parts of the U.S.

In the meantime, U.S. subsidies are fueling growth. The federal government offers tax credits for wind, solar, and other renewables. In addition, 19 states have so-called renewable portfolio standards, requiring that a percentage of energy come from green sources. That has created a market for renewable energy credits that utilities can trade to meet the goals.

As a result, SunEdison's solar power project, for instance, brings many financial benefits. Hudson Bank gets revenue from sales of electricity and renewable-energy credits, while Goldman Sachs gets a write-off from the tax credits and accelerated depreciation. "This is a great example of how innovative financing and

Today's Tip

INVESTING

Investing: Europe

Annual Reports

BW 50

S&P Picks & Pans

Stock Screeners

Free S&P Stock Report

SCOREBOARDS

Hot Growth 100

Mutual Funds

Info Tech 100

S&P 500

B-SCHOOLS

Undergrad Programs

MBA Blogs

MBA Profiles

MBA Rankings

Who's Hiring Grads

BW EXTRAS

BW Digital

BW Mobile

BW Online Alerts

Dashboard Widgets

Podcasts **RSS 2.0**RSS Feeds **RSS 2.0**

Reprints/ Permissions

Conferences

Research Services

the right technology can deliver solar or alternatives now," says Raymond Crespo, vice-president at Energy Conservation & Supply Inc., a New York consultancy that helps office buildings and retailers improve energy efficiency.

BUBBLE AHEAD?

Meanwhile, venture capitalists are betting that innovative new technologies can bring down the costs of solar power far faster than the current 5% rate of decline. In early June, San Jose (Calif.)-based Miasolé, which uses the technology underlying computer disk drives to make thin-film solar cells, snared \$16.5 million from venture-capital firm Kleiner Perkins.

On June 13, Nanosolar announced that it had closed \$20 million in Series B funding from investors such as Mohr, Davidow Ventures, and Benchmark Capital Management Co. The Menlo Park (Calif.) company uses new materials and processes to sidestep the problems of conventional silicon cells.

While promising, these technologies carry plenty of risk. One of them might emerge as the eventual winner, or downturns in conventional energy prices or government policies could put a damper on the market. Some venture capitalists caution that the current rush to invest could create a bubble similar to the one that happened with fuel cells a few years ago. "Oil prices are on the front page, and there has been a bit of herd mentality," says Bill Green, venture capitalist with VantagePoint Venture Partners.

Still, high demand for energy around the world is likely to keep oil, gas, and coal prices high. And environmental concerns will bring more incentives for alternative energy and energy efficiency, not fewer. "If people are convinced that subsidies will remain, capital will follow," says Howard H. Newman, vice-chairman of private equity investor Warburg Pincus.

A powerful convergence of events, from global action against climate change to rising demand for oil, is happening. There will be bumps in the road, but renewable energy and energy-efficiency technologies look set to command an increasing share of investment dollars and markets.

By John Carey in Washington and Adam Aston in New York, with Justin Hibbard in San Mateo, Calif., and Ronald Grover in Los Angeles

BW MALL SPONSORED LINKS

- **Ontario Lawyers: Toronto, Mississauga & Ottawa** Heydary Hamilton PC: Top Ten Boutique Law Firm - We are a reputable full service law firm with offices in Toronto, Mississauga, North York & Ottawa – Call us for reasonable fees & quality

services.

- **Fidelity Investments** Put 60 years of money management expertise to work for you.
- **ETF Investing** Discover iShares. More Tools. More strategies. More possibilities.
- **Build an Effective Supplier Management Program** Explore the latest issues and practices for managing supplier relationships. Jan 30-31. Chicago, IL
- **4.5% Student Loan Consolidation** Lock in rate now as low as 4.5%. Pre-qual in 1 minute. Apply online.
- **Buy a link now!**

Get BusinessWeek directly on your desktop with our **RSS feeds**. RSS 2.0

Add BusinessWeek news to your Web site with our **headline feed**.

Click to buy an **e-print or reprint** of a *BusinessWeek* or BusinessWeek Online story or video.

To subscribe online to *BusinessWeek* magazine, please **click here**.

Learn more, go to the **BusinessWeekOnline home page**

▲
BACK TO TOP

Copyright 2005, by The McGraw-Hill Companies Inc. All rights reserved.
Terms of Use | Privacy Notice

Media Kit | Special Sections | MarketPlace | Knowledge Centers

The McGraw-Hill Companies

ATTACHMENT A2
ENERGY INFORMATION ADMINISTRATION
“NUCLEAR POWER”
(NO DATE)

**U.S. Department of Energy
Energy Information Administration**

Nuclear Power

(no date)



Energy Information Administration

Official Energy Statistics from the U.S. Government

[Glossary](#)

[search](#)

[Home](#) > [Nuclear](#) > [U.S. Analytical Studies](#) > [Nuclear Power](#)

Nuclear Power

Nuclear Power: 12 percent of America's Generating Capacity, 20 percent of the Electricity

[Charts on plant ownership, costs, license extensions, and future trends.](#)

Opinions vary regarding the future of nuclear power, but it is a fact that existing U.S. plants are performing well. Nuclear power plants now operate at a 90 percent capacity factor, compared to 56 percent in 1980. Additionally and in contrast to oil and gas, nuclear fuel costs are low and relatively stable. Fuel costs now average less than one half cent per kilowatthour. This is well below the costs of major competing fossil fuels. Production costs for nuclear power, operation and maintenance plus fuel costs, are also low, averaging 1.8 cents per kilowatt-hour. This cost roughly matches coal and is significantly below the costs of operating a natural gas plant.

Despite all of this relatively attractive news regarding nuclear power, there has been no new order for a nuclear power plant since the 1970s. The last nuclear plant to be completed went on line in 1996. A few, perhaps four, construction licenses are still valid or are being renewed for half-completed reactors, but there are no active plans to finish these reactors.

What follows is an attempt to describe the sources of nuclear power's apparent strength. This will also include a brief overview of the varied problems that nuclear power industry faces if it seeks to expand its market share further.

The Track Record of Nuclear Power

Nuclear power is a relatively new industry even though nuclear generation capacity has been almost constant since 1990. While prototype and early plant designs have been around since the 1950s, the first large scale and truly commercial units only began operating in the late 1960s in the United States. The following table includes only light water reactors that have been licensed for commercial operation since 1968. The oldest reactors still operating in the United States were licensed in 1969.

U.S. Light Water Reactors Operating License Year

License Year	Reactors Licensed	Share of Reactors	Closed Reactors	Operable Reactors	Share of Operable
1968-74	38	33.6%	6	32	30.8%
1975-78	23	20.4%	3	20	19.2%
1979-96	52	46.0%	0	52	50.0%
Total	43	100.0%	9	104	100.0%

Half of the commercial nuclear reactors operating in the United States are less than 24 years old. Because the newer units tend to be larger than the older units, this represents slightly more than half of the generating capacity of the operating units. The column of "closed" reactors illustrates that about 92 percent of all commercial reactors built in the United States since 1968 are still operable. The list also indicates that only the oldest reactors have had a problem with premature closures. Only one reactor (Three Mile Island 2) completed since 1976 has permanently closed. No U.S.

reactor has closed since 1998.

Although nuclear generating capacity has remained roughly constant from 1990, the amount of electric produced has increased 33 percent during the same period because capacity utilization has increased from 66 percent in 1990 (56 percent in 1980) to over 90 percent in 2002. The increase in nuclear power generation due to capacity factor increases is roughly equivalent to building a number of new power plants operating at former capacity levels.

Capacity Factors at U.S. Nuclear Power Plants, 1980-2002

Year	Capacity Factor
1980	56%
1990	66%
2000	88%
2002	>90%


Due to the 1990 electric

utilities knew that for nuclear power to be commercially viable, operating and maintenance costs had to be reduced. One way to do this was to improve plant utilization. A series of institutional changes have facilitated the process since then. During the 1980s the Institute of Nuclear Plant Operators (INPO) was set up to share technical information. New fuel designs permitted higher burnups. Such improvements permitted the expansion of periods between refueling outages to be increased from 12 months to 18 months and sometimes to two years. Refueling outages have also been cut from as much as three months in 1980 to about a month today. Methods of undertaking other maintenance and capital replacement during these outages or even during operations have also been improved. Time requirements for planned and unplanned maintenance have been shortened. More recently techniques such as risk informed maintenance have also been expanded to the government regulatory environment, improving the contribution of regulators to safe and continued plant operation. Finally, the introduction of competition to the wholesale electricity market has honed the motivations of plant operators toward safe and reliable plant operation.

It would be difficult to separate one of these trends out as more important than another, though the reduction in outage time is a major component. Because refueling and maintenance outages must still continue at reactors, we are clearly approaching a technical limit for average plant capacity factors. We are probably not there yet but it will not be more than a few percentage points higher. Improved nuclear power performance in the future must come from other sources.

In addition to increased availability, lower costs have influenced the use of nuclear power. Not all electricity is the same. There are many means by which and locations where one can produce electricity. There are also cycles in demand that vary by day, week, and season. The incentive is to produce electricity for each part of the cycle at the lowest possible cost. When it comes to average and marginal operating costs, nuclear power usually has the advantage.

Average Operating Expenses (Cents/kWh, 2001)



Source: EIA, Electric Power Annual 2000

A number of notes should be made on this chart. The first of these is that the data gather all steam-based fossil fuel energy together. Fuel costs are lower for steam-based power for coal than for oil or gas. Thus, coal-based power has only a slightly higher U.S. average production cost than does nuclear. The costs are so close that, while nuclear costs average lower than coal, there is a good deal of overlap when regions of the country or individual reactors are considered.

Nuclear power does, however, have an advantage in day-to-day operations in its low marginal costs. Day-to-day marginal costs are primarily fuel costs. A disproportionate part of nuclear power operating costs come from operations and maintenance costs that do not vary much with output. Because nuclear power's marginal costs are lower than coal's marginal costs, nuclear power plants tend to use their full output capacity before coal plants. This gives nuclear power an advantage in base load operations and results in a higher capacity factor.

U.S. Capacity and Market Share by Fuel 2000

Fuel	Capacity Factor (percent)	Generation Share (percent)	Generation (billion kWh)
Coal	71.0	51.7	1966
Oil & Gas	29.1	19.0	724
Nuclear	87.9	19.8	754
Hydro	39.6	7.3	276
Geothermal	57.6	0.4	14
Biomass	69.1	1.6	61
Wind	26.8	0.1	6
Photovoltaic	15.1	<0.1	0.5

This table is a bit misleading though it does indicate the impact of availability, demand, and cost. In this case it is the oil and gas numbers that are not consistent with what one anticipates. The term "oil and gas" includes a good deal of peaking and cycling capacity. Thus while modern gas turbine-based combined cycle plants might see relatively high capacity factors, many oil and gas plants operate only rarely during the year. The peaking and cycling character of a large portion of oil and gas capacity makes capacity factor data look worse than it really is, though coal and nuclear plants

will generally have higher capacity factors than oil and gas plants. Hydroelectric power capacity factors were low because of the drought during 2000. Also, cheap hydropower can be stored in the form of water. This allows it to be sold when prices are higher, during peak demand periods, when such cycles are permitted. Numbers for nuclear presently are around 90-91 percent capacity factor and 20-21 percent generation share.

One recent trend in the U.S. nuclear power industry that might influence future performance has been an increased concentration of operations into fewer and fewer hands. This had taken place almost exclusively through the acquisition of existing commercial reactors by firms that already manage commercial reactors.


Operators of U.S. Reactors

Organization	Capacity (MWe)	Share of Capacity
Exelon-AmerGen	16,850	17.3%
Entergy	9,033	9.2%
Duke	6,996	7.2%
TVA	6,658	6.8%
Southern	5,698	5.8%
2nd Five Firms	22,680	23.2%
Others (3+ Reactors)	7,164	7.3%
Others (<3 Reactors)	22,588	23.1%

If this were ownership rather than management the percentages would be smaller for many firms. This is because many reactors have joint ownership arrangements that differ from management arrangements. Of the top five managers, only Entergy and Exelon have been buying management rights at U.S. nuclear plants. Exelon has not done so lately and has talked about either buying or selling AmerGen claims and responsibilities. The second tier firms, plus those managing three plus units have also bought management rights. In some ways recent acquisitions have thus been a leveling process among managing firms. The data in the table do not include the Stars group which shares some responsibilities among the managers of many of the smaller managerial groupings.

Another recent trend that will result in increased nuclear capacity to help sustain the nuclear share of electricity generated is referred to as capacity uprates. Uprating capacity has been an ongoing process since the inception of the nuclear power industry. Uprates have also occurred in other power sub-sectors such as coal and hydroelectric. Nuclear uprates have however garnered a substantial portion of the media attention, if only because the regulatory environment makes nuclear uprates public knowledge.

Present technologies permit uprates of existing nuclear reactors of around 5-20 percent. In some cases these uprates have already occurred. EIA's projections place the near term potential around 4 GWe, based primarily on utility and regulatory announcements. Others such as the Nuclear Energy Institute go as high as 10 GWe. One restriction on higher numbers will be balance of plant considerations and occasionally the economics of the increase. When uprates are viable they provide low cost increases in plant capacity with little change in operations and maintenance costs. These low operations and maintenance costs can mean that some uprates might make economic sense even when they are more expensive than adding less expensive capacity using other fuels. The industry now investigating yet further means to raise plant capacity. These might result in additional uprates beyond present anticipations.



Source: Nuclear Regulatory Commission Energy Information Administration Press Reports

License renewal has also been an issue in the nuclear power industry that is related to future nuclear power generation. Operating licenses expire after 40 years but may be extended with the approval of the Nuclear Regulatory Commission. License renewals add 20 years. The NRC has indicated that “substantially all” existing reactors intend to renew their licenses. The renewal process has been less burdensome than was once anticipated and is at best only an indicator of the future of particular plants. Because the license renewal process takes time to complete, reactors built during 1968-74 have to announce and implement proposed renewal applications within the next few years.

The following table is based on NRC’s published list indicating which reactor managers have announced their intention to renew operating licenses.

U.S. Nuclear Power Plant Renewal Status

License Year	Number of Reactors	On NRC List	Not On NRC	List Closed
1968-74	38	22	10	6
1975-78	23	15	5	3
1979-96	52	15	37	0
Total	113	52	52	9

The 1968-74 group has been less forward with their plans than the later 1975-1978 group. In contrast the newest reactors have no reason to hurry their announcements. Just two firms manage most of the ten oldest excluded reactors. These firms thus might be withholding announcements for policy reasons rather than because of uncertain plans. The basic point is that there might still be issues related to eventual license renewal though the only reactors of immediate concern are the very oldest units. The NRC list is complicated by the inclusion of five potential applications described as “not publicly announced.” Some plants in this group might include more than one reactor and sometimes more than one plant. Thus a minimum of five and probably more reactors should be added to the table. It is though where they belong and whether the apparent problem is statistical or

real.

New Nuclear Construction

Nuclear power's future share in electricity generation will decline if there are no new orders. The nuclear power industry presently has no commitments to build new reactors. The TVA has announced that by 2007 it hopes to bring Browns Ferry-1 back into operation. That reactor has been closed since 1985. The TVA also has three partially completed reactors for which construction licenses are either active or for which extended licenses are being sought. Three firms also plan to apply for early site permits, though such permits are not commitments to build. Nonetheless the business environment has not encouraged power plant construction of any type by any firm during 2002-03. Nuclear plants are no exception.

There are several reasons why there are no firm plans to build new nuclear power reactors. First among these in the short term is that many if not most regions of the Nation presently have surplus baseload generating capacity. There are exceptions to this conclusion. California imports much of its base load electricity needs but also effectively discourages new production from the typical base load power sources, coal and nuclear. This short term base load surplus must be worked off before any new nuclear construction can be seriously considered.

A longer-term reason why no nuclear power has been built is that the capital costs of building a new nuclear power plant have historically been high. There are also considerable financial costs and risks related to the long construction periods in the industry. The last completed nuclear reactor, Watts Bar-1, took 24 years to complete. There has been a history of regulatory uncertainty. The extreme case is the Shoreham plant on Long Island that was essentially completed before it was decided that it would not be allowed to operate. Policy issues such as spent fuel disposal methods, liability insurance questions, and overall safety concerns on the part of the public have also adversely affected nuclear construction.

The nuclear power industry and its promoters are addressing each of these issues. Prospective builders now promise lower costs. Regulatory processes are now better specified and, when possible, implemented early and consistently in the decision process. Financial risk, construction periods, waste disposal, and safety are now being handled in more direct and organized manners. Difficulties with public acceptance remain but are hard to gauge.

The Energy Information Administration in its Annual Energy Outlook 2003 projects in its reference case that no nuclear units will become operable between 2001 and 2025. This projection is a reference scenario that functions as a mid-term forecast under current laws and regulations. The EIA also examined a scenario where the costs of nuclear construction were lowered to a level that some vendors say they will achieve after first of a kind engineering and financing difficulties are worked out. The Annual Energy Outlook's conclusion under this "advanced nuclear cost case" is that additional nuclear power capacity would come on line if cost targets are reached.

Are the changes in the nuclear power industry enough to make a difference in its future? There are still no new orders. Thus in the short term recent achievements are not enough. Getting new orders is the challenge that the nuclear industry must still meet if it wishes to expand. Most of the risks in building nuclear power plants must be faced early in the plant's life cycle. A fossil fuel plant faces its greatest risks, uncertain demand and fuel prices, after the plant begins operation. This will discourage nuclear power investment when other anticipated costs are comparable. Nuclear power's task remains controlling its risks better than competing fuels control their risks.

Contact:

Tom Murphy

Phone: 202-586-1517

E-Mail: [Tom Murphy](#)

[Contact Us](#) • [Feedback](#) • [Privacy/Security](#) • [Careers](#) • [About EIA](#)

[Fedstats](#) • [USA.gov](#) • [Dept. of Energy](#)

ATTACHMENT A3
IOWA ENERGY CENTER
WIND ENERGY MANUAL, "WIND ENERGY ECONOMICS"
2006

Iowa Energy Center

Wind Energy Manual
"Wind Energy Economics"

2006

Wind Energy Economics

contents > wind issues > wind energy economics

The energy supply market is very competitive, led by utilities and fuel companies that meet nearly all our energy demands. Alternative energy sources like wind power provide new options and certain advantages, but to be truly competitive with conventional energy sources, they also must be economical.

Throughout their lives, people make informed decisions on major purchases and financial investments. In the case of home and car purchases, the decision is usually which one to buy, rather than whether to buy, because these items are considered necessities. Many sources of professional advice are available to assist the buyer in making a sound decision for these common types of investments. For wind turbines, where the choice to buy is voluntary, good advice can be hard to find.

How does the average homeowner, farmer or business person choose between wind energy and the energy source he or she now uses? A wind energy system requires a large initial capital outlay, but over its lifetime it will provide years of energy with no fuel cost while the costs of other sources of energy may escalate.

How much do wind turbines cost and will they eventually pay for themselves? Will utility rates change in the future and by how much? This chapter addresses these kinds of questions and charts a course toward a well-informed investment decision. Previous chapters described the steps necessary to choose an efficient wind system for given wind conditions and energy needs. The following pages prepare prospective buyers to determine the potential financial gain available from the wind system chosen to fit a particular energy profile.

Cost

The cost of a wind system has two components: initial installation costs and operating expenses. The initial installation cost includes the purchase price of the complete system (including tower, wiring, utility interconnection or battery storage equipment, power conditioning unit, etc.) plus delivery and installation charges, professional fees and sales tax.

The total installation cost can be expressed as a function of the wind system's rated electrical capacity. A grid-connected residential-scale system (1-10 kW) generally costs between \$2,400 and \$3,000 per installed kilowatt. That's \$24,000-\$30,000 for a 10 kW system. A medium-scale, commercial system (10-100 kW) is more cost-effective, costing between \$1,500 and \$2,500 per kilowatt. Large-scale systems of greater than 100 kW cost in the range of \$1,000 to \$2,000 per kilowatt, with the lowest costs achieved when multiple units are installed at one location. In general, cost rates decrease as machine capacity increases. The curve's width reflects the range of costs available. For exact figures applicable to you, contact a manufacturer or dealer. A partial list of manufacturers and dealers can be found at **Wind Turbine Manufacturers**.


Remote systems with operating battery storage typically cost more, averaging between \$4,000 and \$5,000 per kilowatt. Individual batteries cost from \$150 to \$300 for a heavy-duty, 12 volt, 220 amp-hour, deep-cycle type. Larger capacity batteries, those with higher amp-hour ratings, cost more. A 110-volt, 220 amp-hour battery storage system, which includes a charge controller, costs at least

ATTACHMENT A4
NEW JERSEY'S CLEAN ENERGY PROGRAM
"FREQUENTLY ASKED QUESTIONS – OFFSHORE WIND SYSTEMS"
APRIL 2006

New Jersey's Clean Energy Program

**"Frequently Asked Questions –
Offshore Wind Systems"**

April 2006




[Home](#)[Renewable Energy Home](#)[Overview](#)[Residential Financial Incentives](#)[Commercial & Industrial Eligibility and Guidelines](#)[Applications and E-forms](#)[Renewable Energy Contacts and Resources](#)

[FAQs Home](#)[General Energy Issues](#)[NJ CleanPower Choice Program](#)[Residential and Energy Star](#)[Solar Renewable Energy Certificates \(SREC\)](#)[Off Shore Wind Systems](#)[NJ SmartStart Buildings](#)[Renewable Energy Business Venture Assistance Program](#)[Federal Tax Credit](#)

FREQUENTLY ASKED QUESTIONS

Off Shore Wind Systems


[Click to download](#) PDF version of FAQ

- [Wind energy systems- wind turbines: What they are and how do they work?](#)
- [What is the current capacity of wind energy?](#)
- [How is the output of wind turbines determined?](#)
- [How are wind areas classified?](#)
- [What is the general capacity factor a wind energy system?](#)
- [What is the average wind speed offshore?](#)
- [Why look offshore for wind energy systems?](#)
- [How many homes can one offshore wind turbine supply?](#)

- How much does a wind system cost compared to other renewable energy or traditional energy systems?
 - Can wind energy systems meet all of New Jersey's electric demand?
 - How much energy can the offshore wind resource generate?
-

Q. Wind energy systems- wind turbines: What they are and how do they work?


A. A wind energy system transforms the kinetic energy of the wind into mechanical or electrical energy. A wind turbine operates like a fan in reverse using wind to make electricity. The wind turns the blades, which spin a shaft, which is connected to a generator that makes electricity.



Back to top

Q. What is the current capacity of wind energy systems in the US and worldwide?

A. As of 2004, there were 6,740 MW of installed onshore wind energy systems in states. There are currently no installed offshore wind energy systems in the U.S. Several offshore wind projects are in the planning stage in a number of states. The furthest along are the 140 MW system off the shore of Long Island proposed by Long Island Power Authority and the Cape Wind 420 MW project in Nantucket Sound, MA. Both projects have developed detailed Environmental Impact Statements (EIS). As of 2003, there are 28,706 MW of installed wind energy systems in 29 countries, with over 500 MW offshore wind energy systems in 16 countries in Europe. There are over 10,000 MW of new offshore wind energy systems in various planning stages in these countries.




A. The energy output of a wind turbine depends on the turbine's size and the wind's speed at the turbine height. Wind speed is the crucial element in projecting wind energy system performance. A site's wind speed is measured through a wind resource assessment prior to a wind system's construction. Generally, annual average wind speeds greater than six

meters per second (m/s) or 14 miles per hour (mph) are required for large-scale wind systems.

[Back to top](#)

Q. How are wind areas classified?

A. Wind power is characterized by a simple system that assigns the wind potential to one of seven wind classes. The wind potential in Class 1 or 2 areas are low and not suitable for utility-scale wind energy systems. Class 3 and 4 are fair to good; and Class 5 and higher are excellent for utility-scale wind energy systems. Most of New Jersey is a Class 1 or Class 2 wind area. There are some Class 3 wind areas along the New Jersey coast and in the northwestern mountain ridges. There are Class 4, and higher wind areas off-shore.



A. A wind energy system is “fueled” by the wind, which blows steadily at times and not at all at other times. During the year there are times when the wind does not blow or at speeds below which the wind turbine will turn to produce energy. Even when the wind is blowing the wind energy system does not always produce energy at its full rated capacity. The capacity factor of wind energy systems ranges from 25 percent to 45 percent. The theoretical maximum capacity factor for a rotor wind turbine is 59 percent. Offshore wind energy systems will achieve higher capacity factors.

[Back to top](#)

Q. What is the average wind speed offshore?

A. Over the year the wind speed offshore in New Jersey varies between 5 to 9 m/s. The offshore wind in New Jersey peaks between October to April and is highest in December/January. It is lowest in July/August. The wind speed offshore can varies roughly 1.5 m/s over the day. In addition, during the summer months because of the thermal difference between the temperature of the water and the land a sea breeze circulation develops along the shore. The sea breeze can increase wind speeds between four m/s one half mile offshore to one m/s six miles offshore. Overall the wind is steadier and more predictable offshore.

[Back to top](#)

Q. Why look offshore for wind energy systems?

A. There are a number of factors that influence the performance of a wind energy system. These includes: wind shear, turbulence, wake effect, and tunnel effect. These factors can lower the overall performance of as wind energy system and are evident to a lesser degree offshore. This coupled with higher wind speeds offshore increase the potential performance of offshore wind energy systems. With equivalent offshore and onshore wind energy systems (same MW capacity), an offshore wind energy system will produce more energy over the year.

[Back to top](#)

Q. How many homes can one offshore wind turbine supply?

A. A New Jersey household uses, on average, 8,500 kilowatthours (kWh) of electricity per year. Each home on average represents a 2 to 4 kW load. A 3.6 MW wind turbine in a Class 4 or higher wind area can produce more than 10,800,000 kWh of energy in a year – enough electricity to power more than 1,200 households on an annual basis.

[Back to top](#)

Q. How much does a wind system cost compared to other renewable energy or traditional energy systems?

A. Onsite wind can generate electricity for less than 5 cents per kWh in a Class 5 or higher wind area. In PJM, grid baseload power plants generate electricity for 1.5 to 3 cents per kWh. Solar electric or photovoltaic (PV) costs 21 cents per kWh and sustainably grown and harvested biomass (organic matter such as willow trees, switch grass, food waste) can generate electricity for approximately 6 to 7 cents per kWh. Offshore wind cost more than onshore wind because of additional costs which includes: additional construction cost to install the foundation; additional operating costs for a corrosive salt environment and more severe weather; and additional power collection and transmission costs. A 100 MW offshore wind energy facility, in an area with a wind speed of 8 to 8.5 m/s and a capacity factor between 32 to 35, would result in a levelized electricity cost of between 8.5 to 8.9 cents per kWh.

[Back to top](#)

Q. Can wind energy systems meet all of New Jersey's electric demand?

A. Wind is an intermittent resource and because of this intermittent nature some have looked at a limiting factor for wind of approximately 20% of the total system capacity. However, there is no firm or maximum limit. Development of future energy storage systems or advanced voltage regulation control technology with the wind energy system could significantly increase this factor. In addition, matched with other intermittent renewables like solar electric (photovoltaics), can also increase this factor.

[Back to top](#)

Q. How much energy can the offshore wind resource generate?

A. Based on the Atlantic Renewable Energy Corp. Feasibility Report

dated May 2004, accounting for areas that would be excluded because of conflicting concerns, an area mostly beyond 3 miles offshore in up to 100 feet of water encompassing 1,223 square miles stretching 75 mile from Seaside Hts./Park to Cape May could be conditionally viable. At densities of 20 MW per sq mile, each MW of installed capacity could produce 3,000 MWh per year while occupying less than 0.01% of the seabed in the project area.

[\[Top\]](#) - [\[Back\]](#)



[Residential](#) • [Commercial & Industrial](#) • [Renewable Energy](#) • [CleanPower Choice](#)
[FAQs](#) • [Library](#) • [Contact & Comments](#) • [Site Map](#) • [Home](#)



This site is best used with Netscape 4.5 and higher or Internet Explorer 5 and higher, at a screen resolution of 800 x 600 or greater.

Other New Jersey Energy Efficiency Programs

Learn more about saving energy!

www.njcleanenergy.com

Last updated Sunday, December 3, 2006

ATTACHMENT A5
TENNESSEE VALLEY AUTHORITY
“THE ROLE OF RENEWABLE ENERGY IN REDUCING GREENHOUSE GAS BUILDUP”
SEPTEMBER 2003

Tennessee Valley Authority

**“The Role of Renewable Energy in Reducing
Greenhouse Gas Buildup”**

September 2003


TENNESSEE VALLEY AUTHORITY
[site help](#) [con](#)

 search
[TVA Home](#) [About TVA](#) [Power System](#) [Environmental Stewardship](#) [River System](#) [Economic Development](#) [Investor Resources](#)
[Return to On the Air Main](#)

On the Air

The Role of Renewable Energy in Reducing Greenhouse Gas Buildup

As a result of human activities, greenhouse gases (GHG) are increasing in the earth's atmosphere. Many in the scientific community now believe that this increase of carbon dioxide (CO₂), methane (CH₄), and other GHG is causing the earth's temperature to rise, and that this increase in GHG will lead to even greater global warming during this century. However, significant scientific disagreement still exists regarding the relative importance of anthropogenic GHG emissions versus natural variability in climate as the cause of these temperature changes.

To address this uncertainty, the Bush Administration, in 2002, proposed increased funding for scientific research on the impact of anthropogenic GHG emissions on climate change and on GHG reduction and sequestration technologies. Also, the Administration announced the Global Climate Change Initiative, with the goal of reducing the U.S. GHG intensity by 18 percent over the next 10 years. To minimize the potential impact on TVA, various types of GHG mitigation technologies are being evaluated to determine costs, impacts on the system, timing of implementation, and any additional environmental benefits. One strong option is to increase the use of renewable energy in electric power generation.




Figure 1. TVA wind turbines on Buffalo Mountain near Oak Ridge, Tennessee.

What is Renewable Energy?

Electricity produced from wind (Figure 1), solar, or geothermal sources, biomass energy conversion systems, and increases resulting from modernization of hydroelectric systems (HMOD) generally are considered renewable energy. Biomass energy systems encompass a wide range of sources, including dedicated energy crops, wood waste, landfill gas, digester gas, animal waste, and municipal solid waste. However, what qualifies as a renewable energy source varies among private and governmental organizations.

How Does Renewable Energy Reduce GHG Emissions?

Unlike the combustion of coal, natural gas, and distillate fuel—which produces carbon dioxide—wind, solar, and hydroelectric energy

systems emit no GHG because their fuel or energy source is carbon-free. Thus, the amount of GHG emitted into the atmosphere can be reduced only when fossil-fuel generation is avoided or replaced by renewable systems or other non-GHG-emitting electric generation systems.

Although biomass energy systems utilize combustion and do produce carbon dioxide emissions in producing electricity, these emissions are considered "carbon dioxide neutral." The carbon dioxide in these emissions is not considered to increase the amount of GHG in the atmosphere because the carbon dioxide was removed from the atmosphere by plants within the very recent past as part of the natural global carbon cycle. Also, if not used for electricity generation, the biomass would have decayed, thus emitting an equivalent amount of carbon dioxide to the atmosphere. In contrast, coal and other fossil fuels contain carbon that has been "locked-up" for millions of years. Therefore, when fossil fuels are used to generate electric power, carbon dioxide that has been locked away and otherwise would not have been emitted is added to the atmosphere. Thus the use of biomass as an energy source reduces the amount of "fossil" carbon dioxide that is emitted to the atmosphere by displacing fossil fuels.

Co-firing wood waste with coal reduces the amount of methane that is emitted into the atmosphere. Wood waste, if disposed in a landfill, would decay and emit methane from the decomposition of the organic matter. Methane is a potent GHG that, pound-for-pound, has 21 times the impact of carbon dioxide on global warming. Therefore, significant GHG reductions can be achieved from co-firing wood waste with coal.

Landfill gas energy systems also reduce GHG emissions by combusting the methane that is generated within the landfill. Carbon dioxide is emitted from the combustion of the methane, but, as discussed above, this carbon dioxide comes from biomass sources that are considered carbon dioxide neutral. Therefore, using landfill gas to produce electricity reduces GHG emissions in two ways: (1) by destroying methane, and (2) by using it as a fuel to displace carbon dioxide emissions from fossil fuel combustion.

Renewable Energy Resources in the Valley

A preliminary study by TVA's Renewable Energy Team concluded that approximately 3,000 MW-equivalent of energy—from wind, HMOD, bioenergy (wood waste, energy crops, and landfill gas), and solar energy—exist within and directly adjacent to the TVA service territory. However, at present, less than 30 percent of this is cost-competitive with TVA's generation mix. But technology improvements over the next 15 years are expected to lower the cost of electricity produced by renewable energy systems.

Biomass. Biomass is the largest renewable energy resource in the Tennessee Valley. Approximately 11 million tons of wood waste (mill residue, forest residue, and urban wood waste) is generated each year. Also, studies project that approximately 10 million tons of

switchgrass, a native, high-yielding grass, could be grown annually as an energy crop in the TVA service area. Combined, these could produce an energy equivalent of approximately 900 MW in the TVA service territory. However, the cost of switchgrass and other energy crops currently is almost twice the cost of coal on a Btu basis. Furthermore, the lack of adequate infrastructure, along with transportation and handling costs, are primary obstacles when considering the economic and technical feasibility of this renewable energy source.

Wind. Approximately 800 MW of wind capacity energy is available within 5 miles of the TVA service area. Since the average capacity factor for wind energy systems in the Valley is about 25 percent, the 800 MW of wind capacity is equivalent to only 267 MW of fossil capacity.

HMOD. It is projected that modernization of TVA's hydroelectric generating facilities will increase the total hydro capacity by 750 MW.

Landfill Gas. The installation of waste-to-energy systems at municipal landfills can provide significant GHG reductions; however, the capacity of the system, existing electrical infrastructure, and the age and projected life of the landfill must be taken into account when considering such systems. Electricity also can be produced from methane generated at wastewater treatment and animal waste treatment facilities. In 1999, it was estimated that a total of 150 MW of landfill gas energy capacity exists in the TVA service territory. However, only about 70 MW of that was considered economically viable.

Solar. Although a considerable amount of solar photovoltaic (PV) capacity exists in the Valley—roughly 400 MW of capacity—the large land requirement and high capital cost of solar PV systems make them a non-viable renewable energy source at the present time.

GHG Reduction Costs

Although renewable energy systems produce little or no GHG emissions, the electricity produced by these systems typically costs more than electricity generated from fossil, hydroelectric, and/or nuclear power plants. The higher cost is the result of higher capital and fuel costs and the availability of the energy source.

Figure 2 reveals the range in generation costs (dollars per kilowatt hour) and GHG reduction costs (dollars per ton of carbon dioxide-equivalent) for HMOD, wood waste co-firing (with and without assuming methane reductions), landfill gas, and wind energy systems. As the graph indicates, HMOD has the lowest generation cost, and wood waste co-firing and landfill gas energy systems can generate electricity at a lower cost than wind. Solar PV is not shown because of the very high generation costs associated with this system—from 35 to 60 cents/kWh.

The cost per unit of GHG reduction from renewable energy sources is lowest with wood waste (with methane reduction) and landfill gas. The lines in the graph depicting these two energy systems exhibit different slopes than the other systems because their reduction in carbon-dioxide-equivalents per dollar is greater as a result of reductions in both carbon dioxide and methane emissions. Wind and solar energy systems avoid coal-based carbon dioxide emissions, but they have rather high capital costs and low capacity factors that make them less attractive for reducing GHG emissions at the present.

Potential Issues

Wind and solar energy systems depend on the availability of sufficient wind and sunlight to produce electricity. The lack of control over when and how much wind and solar energy will be available makes these renewable energy systems non-dispatchable, thus reducing their value to the system. TVA is investigating energy storage technologies that may help solve this problem.

Unlike sulfur dioxide and nitrogen oxide emissions, which can be readily measured and monitored by gas analyzers and flow rate meters, reductions in, or avoidance of, GHG emissions may require that an independent third-party be brought in to verify that the reduction has occurred. Depending on the size of the GHG reduction/avoidance project, third-party verification costs can be significant.




Figure 2. Current estimated ranges in costs per kWh and per ton of carbon-dioxide-equivalent (CO₂e) for five types of renewable energy systems. HMOD refers to modernization of hydroelectric facilities.

Conclusions

The use and incorporation of renewable energy systems into the electric power generation mix is one way that utilities could address the buildup of GHG in the atmosphere. The utilization of renewable energy depends upon resource availability, capital, and fuel cost. Reductions in generation cost, and possibly tax incentives, are needed if the utilization of renewable energy is to increase in the Tennessee Valley and the nation.

[Click here for a PDF version of this report. \(372 kb, PDF\)](#)

Information Contacts:

[Edward A. Stephens, Jr.](#), (423) 751-7474,

[L. Daryl Williams](#), (256) 386-2973

If you would like additional information on important air quality topics, please contact Jeanie Ashe by telephone (256-386-2033), E-mail (jbashe@tva.gov), facsimile (256-386-2499), or mail at TVA, CEB 2A-M, Muscle Shoals, Alabama 35662.




[Contact Us](#) | [Search](#) | [Legal Notices](#) | [Privacy Policy](#) | [Employment](#) | [FOIA](#) | [No Fear Act Data](#) | [Linking Policy](#)
[TVA Home](#) | [About TVA](#) | [Power](#) | [Environment](#) | [Rivers](#) | [Economic Development](#) | [Investors](#) | [News](#)

ATTACHMENT B1
SOLARBUZZ, LLC
FAST SOLAR ENERGY FACTS, "GLOBAL PERFORMANCE"
MARCH 2006

Solarbuzz, LLC

**Fast Solar Energy Facts
"Global Performance"**

March 2006



FAST SOLAR ENERGY FACTS

Global Performance

[Home](#)

Global
Australia
Germany
Japan
USA

Uses of Solar Energy	Utility Power	Distributed Generation	Types of Plants	Technologies	Codes and Certifications	Fast Facts Global	Solar Manufacturers	Home
----------------------	---------------	------------------------	-----------------	--------------	--------------------------	-------------------	---------------------	------

Information updated as of March 2006

Solar Energy Demand ([click here](#) to try our Solar Industry statistics section)

Worldwide photovoltaic installations increased by 1460 MW in 2005, up from 1,086 MW installed during the previous year. In 1985, annual solar installation demand was only 21 Megawatts.

For comparison purposes, total worldwide wind energy installations in 2000 were around 4000 Megawatts, growing at about 35% pa.

Cumulative solar energy production accounts for less than 0.01% of total Global Primary Energy demand.

Solar Energy demand has grown at about 25% per annum over the past 15 years (hydrocarbon energy demand typically grows between 0-2% per annum).

The US market showed 27% growth in 2004 compared to 17% in the previous year. Japan's market reached 277 MW, an increase of 27%, but a fall from 36% growth in 2003.

The "Feed-in Law" in Germany permits most customer applications to receive 45.7 euro cents/kWh for solar generated electricity. The program now calls for a total of 1000 Megawatts to be installed. By the end of 2003, the Kreditanstalt für Wiederaufbau (KfW) Bank who administer the 100,000 Roof Program in Germany, had approved loans for over 250 Megawatts of PV systems.

For the Fiscal Year 2002, the Japanese solar roof top program received applications from 42,838 households.

Jobs in the solar and renewable energy industries may be found at greenjobs.com

Photovoltaic Manufactured Solar Cells

Around 50 % of the world's solar cell production was manufactured in Japan in 2003. United States accounted for 12%.

On the supply side, the amount of product manufactured by PV cell manufacturers worldwide reached 742 Megawatts in 2003.

Japan has taken over from the United States as the largest net exporter of PV cells and modules.

Four Companies account for over 50% of solar cell production: Sharp, Kyocera, BP Solar, and Shell Solar.

Among the top five manufacturers, Sharp remains the largest and has shown the fastest growth over the last five years. Sanyo, fifth largest, has shown the second highest rate of growth over the same period.

[Click here](#) to find worldwide solar energy product manufacturers.

Solar Energy Prices

Solar Energy (photovoltaic) prices have declined on average 4% per annum over the past 15 years. Progressive increase in conversion efficiencies and manufacturing economies of scale are the underlying drivers.

The Solarbuzz [global price survey](#) on this site shows that prices have consistently declined for over the last two years. A detailed analysis of the worldwide PV Market is in our premier industry report, [Marketbuzz 2006](#). The US Grid Connect Market is analyzed in detail in [this report](#).

A residential solar energy system typically costs about \$8-10 per Watt. Where government incentive programs exist, together with lower prices secured through volume purchases, installed costs as low as \$3-4 watt - or some 10-12 cents per kilowatt hour can be achieved. Without incentive programs, solar energy costs (in an average sunny climate) range between 22-40 cents/kWh for very large PV systems.

Other Solar Energy Facts

Did you know that solar energy is dependent upon nuclear power? Solar Energy's nuclear power plant, though, is 93 million miles away.

An average crystalline silicon cell solar module has an efficiency of 15%, an average thin film cell solar module has an efficiency of 6%. Thin film manufacturing costs potentially are lower, though.

A Megawatt is 1,000,000 Watts; a Gigawatt is 1000 Megawatts.

The earth receives more energy from the sun in just one hour than the world uses in a whole year.

Two billion people in the world have no access to electricity. For most of them, solar photovoltaics would be their cheapest electricity source, but they cannot afford it.

Crystalline Silicon cell technology forms about 90% of solar cell demand. The balance comes from thin film technologies.

Approximately 45% of the cost of a silicon cell solar module is driven by the cost of the silicon wafer, a further 35% is driven by the materials required to assemble the solar module.

Global Energy and Electricity Industry

The United States, Russia, China, Saudi Arabia, and Canada were the world's five largest producers of energy in 1999, supplying 47.9 percent of the world's total energy. Worldwide oil consumption rose by slightly less than 1 million barrels per day in 2000 (vs 1999).

Source: US DOE

World energy consumption is projected to increase by 59% from 1999 to 2020. Much of the growth in worldwide energy use is expected in the developing world

Source: International Energy Outlook 2001, EIA

1999 World Production of Primary Energy (Quadrillion (10¹⁵) Btu)

Source: US

DOE EIA

Petroleum	149.7	Hydroelectric	27.10
Natural Gas	87.31	Nuclear	25.25
Coal	84.90	Geothermal, solar, wind, wood, waste	2.83

Renewable energy use is expected to increase 53% between 1999 and 2020. Much of the growth is attributable to large scale hydroelectricity projects in the developing world. Renewable Energy currently accounts for 9% of total energy consumption and is projected to decline to 8%.

Source: US DOE EIA

A conventional energy Power Plant can range in size from 500-3000 Megawatts.

Total USA Megawatt hour demand was 3,312,087,081 across 125,945,003 customers in 1999.
Source: US DOE, 1999

Total European Union Megawatt hour demand is around 2,300,000,000. (1999)

Electricity Price tariffs by country can be found on this site by [clicking here](#).

Uses of Solar Energy	Utility Power	Distributed Generation	Types of Plants	Technologies	Codes and Certifications	Fast Facts Global	Solar Manufacturers	Home
----------------------	---------------	------------------------	-----------------	--------------	--------------------------	-------------------	---------------------	------

If you have a Fast Fact you would like us to include in our listing, please email us at info@solarbuzz.com. We like our Fast Facts to be interesting, accurate, quantified where appropriate and insightful to those researching the solar energy industry for the first time.

[Terms of Use](#)

[Privacy Policy](#)

© 2007 Solarbuzz, LLC. All rights reserved

ATTACHMENT B2
UNIVERSITY FOR APPLIED SCIENCES
“SOLAR POWER TOWERS”
1996

University for Applied Sciences

“Solar Power Towers”

1996

Solar Power Towers



1. *How it works*
2. *Heat storage and transfer*
3. *Scheme*
4. *Technical, Facts and Tests*
5. *Location*

How it works

Solar power towers consist of a large field of sun-tracking mirrors, called heliostats, which focus solar energy on a receiver atop a centrally located tower. The enormous amount of energy, coming out of the sun rays, concentrated at one point (the tower in the middle), produces temperatures of approx. 550°C to 1500°C. The gained thermal energy can be used for heating water or molten salt, which saves the energy for later use.

Heated water gets to steam, which is used to move the turbine-generator. This way thermal energy is converted into electricity.

Heat storage and transfer


As already mentioned there are two main fluids which are used for the heat transfer, water and molten salt. Water for example is the oldest and simplest way for heat transfer. But the difference is that the method in which molten salt is used, allows to store the heat for the terms when the sun is behind clouds

or even at night. Molten salt - better: the heat of it - can be used until the next dawn when the sun will be back to heat the cooled down salt again.

The molten salt consists of 60% sodium nitrate and 40% potassium nitrate (saltpeter). The salt melts at about 700°C and is liquid at approx. 1000°C, it will be kept in an insulated storage tank until the time, when it will be needed for heating up the water in the steam generator.

This way of energy storage has an efficiency of approx. 99%, i.e. due to the imperfect insulation 1% of the stored energy gets lost.

Scheme



Technical, Facts and Tests


E.g.: The Power Tower Project "Solar II" (California):

- 1,926 sun-tracking heliostats (mirrors)
- molten salt thermal storage system
- tower (300 ft) with central receiver
- conventional steam driven turbine and generator
- produces about 10 MWe, enough power to serve 10,000 homes with electricity
- costs about 40 million US\$
- will be used in an experiment until 1998

Location

Until now, there are only few solar power towers because they're rentable only in regions with a high

amount of sunshine and the costs are at a fairly high level.



Questions, comments, t-shirts, cookies, pizza, milk and honey to:

Mustafa Mesanovic <mm@rhlx01.rz.fht-esslingen.de>


Nils Philippsen <nils@rhlx01.rz.fht-esslingen.de>

Fri Dec 20 10:44:48 MET 1996

ATTACHMENT B3
U.S. DEPARTMENT OF ENERGY
CONCENTRATING SOLAR POWER TECHNOLOGIES
“OVERVIEW”
(NO DATE)

U. S. Department of Energy
“Concentrating Solar Power Technologies
Overview”

(no date)



HOME

CSP Technologies Overview

OVERVIEW

CSP PROGRAM

TECHNOLOGY PATHS

MAJOR PROJECTS

R & D

SUN+LAB

SOLARPACES

CSP INDUSTRY

PHOTOGRAPHS

DOCUMENTS

MEETINGS

FAQs

CONTACTS

RELATED LINKS

Feature

Technology Overview

The Solar Resource

How Does It Work?

Trough Systems

Power Tower Systems


Dish/Engine Systems

Business and Market Opportunities

What Does It Cost?

Technology Overview

Concentrating solar power plants produce electric power by converting the sun's energy into high-temperature heat using various mirror configurations. The heat is then channelled through a conventional generator. The plants consist of two parts: one that collects solar energy and converts it to heat, and another that converts heat energy to electricity.




By collecting solar energy during daylight hours and storing it in hot molten salt, concentrating solar power technologies like power towers give utilities an alternative method for meeting peak loads.
(Warren Gretz)

Concentrating solar power systems can be sized for village power (10 kilowatts) or grid-connected applications (up to 100 megawatts). Some systems use thermal storage during cloudy periods or at night. Others can be combined with natural gas and the resulting hybrid power plants provide high-value, dispatchable power. These attributes, along with world record solar-to-electric conversion efficiencies, make concentrating solar power an attractive renewable energy option in the Southwest and other sunbelt regions worldwide.

The Solar Resource

The solar resource for generating power from concentrating solar

power systems is plentiful. For instance, enough electric power for the entire country could be generated by covering about 9 percent of Nevada—a plot of land 100 miles on a side—with parabolic trough systems.



The solar resources for generating power from concentrating solar power systems is plentiful. For instance, enough electric power for the entire country could be generated by covering about 9 percent of Nevada – a plot of land 100 miles on a side – with parabolic trough systems.

The amount of power generated by a concentrating solar power plant depends on the amount of direct sunlight. Like concentrating photovoltaic concentrators, these technologies use only direct-beam sunlight, rather than diffuse solar radiation.

The southwestern United States potentially offers the best development opportunity for concentrating solar power technologies in the world. There is a strong correlation between electric power demand and the solar resource due largely to air conditioning loads in the region. In fact, the Solar Electric Generating System plants operate for nearly 100% of the on-peak hours of Southern California Edison.

How Does It Work?

There are three kinds of concentrating solar power systems—troughs, dish/engines, and power towers—that are classified by how they collect solar energy.

Trough systems:

The sun's energy is concentrated by parabolically curved, trough-shaped



reflectors onto a receiver pipe running along the inside of the curved surface. This energy heats oil flowing through the pipe, and the heat energy is then used to generate electricity in a conventional steam generator.

A collector field comprises many troughs in parallel rows aligned on a north-south axis. This configuration enables the single-axis troughs to track the sun from east to west during the day to ensure that the sun is continuously focused on the receiver pipes. Individual trough systems currently can generate about 80 megawatts of electricity.

Trough designs can incorporate thermal storage—setting aside the heat transfer fluid in its hot phase—allowing for electricity generation several hours into the evening. Currently, all parabolic trough plants are "hybrids," meaning they use fossil fuel to supplement the solar output during periods of low solar radiation. Typically a natural gas-fired heat or a gas steam boiler/reheater is used; troughs also can be integrated with existing coal-fired plants.

For more information, see the following documents:

Technology Characterization: Solar Parabolic Trough ([PDF Format 303KB](#))

Solar Trough Power Plants ([HTML Format](#); [PDF Format 230KB](#))

Parabolic Trough Roadmap ([PDF Format 1053KB](#))

Power tower systems:

What is a Power Tower and How Does it Work?

A power tower converts sunshine into clean electricity for the world's electricity grids. The technology utilizes many large, sun-tracking mirrors (heliostats) to focus sunlight on a receiver at the top of a tower. A heat transfer fluid heated in the receiver is used to generate steam, which, in turn, is used in a conventional turbine-generator to produce electricity. Early power towers (such as the Solar One plant) utilized steam as the heat transfer fluid; current designs (including Solar Two, pictured) utilize molten nitrate salt because of its superior heat transfer and energy storage capabilities. Individual commercial plants will be sized to produce anywhere from 50 to 200 MW of electricity.



What are the Benefits of Power Towers?

Solar power towers offer large-scale, distributed solutions to our nation's energy needs, particularly for peaking power. Like all solar technologies, they are fueled by sunshine and do not release greenhouse gases. They are unique among solar electric technologies in their ability to efficiently store solar energy and dispatch electricity to the grid when needed — even at night or during cloudy weather. A single 100-megawatt power tower with 12 hours of storage needs only 1000 acres of otherwise non-productive land to supply enough electricity for 50,000 homes.

Throughout the sunny Southwest, millions of acres are available with solar resources that could easily produce solar power at the scale of hydropower in the Northwest U. S.

What is the Status of Power Tower Technology?

Power towers enjoy the benefits of two successful, large-scale demonstration plants. The 10-MW Solar One plant near Barstow, CA, demonstrated the viability of power towers, producing over 38 million kilowatt-hours of electricity during its operation from 1982 to 1988. The Solar Two plant was a retrofit of Solar One to demonstrate the advantages of molten salt for heat transfer and thermal storage. Utilizing its highly efficient molten-salt energy storage system, Solar Two successfully demonstrated efficient collection of solar energy and dispatch of electricity, including the ability to routinely produce electricity during cloudy weather and at night. In one demonstration, it delivered power to the grid 24 hours per day for nearly 7 straight days before cloudy weather interrupted operation.

The successful conclusion of Solar Two sparked worldwide interest in power towers. As Solar Two completed operations, an international consortium, led by U. S. industry including Bechtel and Boeing (with technical support from Sandia National Laboratories), formed to pursue power tower plants worldwide, especially in Spain (where special solar premiums make the technology cost-effective), but also in Egypt, Morocco, and Italy. Their first commercial power tower plant is planned to be four times the size of Solar Two (about 40 MW equivalent, utilizing storage to power a 15MW turbine up to 24 hours per day).

This industry is also actively pursuing opportunities to build a similar plant in our desert Southwest, where a 30 to 50 MW plant would take advantage of the Spanish design and production capacity to reduce costs, while providing much needed peaking capacity for the Western grid. The first such plant would cost in the range of \$100M and produce power for about 15¢/kWh. While still somewhat higher in cost than conventional technologies in the peaking market, the cost differential could be made up with modest green power subsidies and political support, jump-starting this technology on a path to 7¢/kWh power with the economies of scale and engineering improvements of the first few plants. It would, at that point, provide clean power as economically as more conventional technologies.

For more information, see the following documents:

Technology Characterization: Solar Power Towers ([PDF Format 303KB](#))

Solar Two Demonstrates Clean Power for the Future ([HTML format](#); [PDF format 557KB](#))


Dish/engine systems:

What is a Solar Dish-Engine System?

A Solar Dish-Engine System is an electric generator that "burns" sunlight instead of gas or coal to produce


electricity. The major parts of a system are the solar concentrator and the power conversion unit. Descriptions of these subsystems and how they operate are presented below.

THE DISH, which is more specifically referred to as a concentrator, is the primary solar component of the system. It collects the solar energy coming directly from the sun (the solar energy that causes you to cast a shadow) and concentrates or focuses it on a small area. The resultant solar beam has all of the power of the sunlight hitting the dish but is concentrated in a small area so that it can be more efficiently used. Glass mirrors reflect ~92% of the sunlight that hits them, are relatively inexpensive, can be cleaned, and last a long time in the outdoor environment, making them an excellent choice for the reflective surface of a solar concentrator. The dish structure must track the sun continuously to reflect the beam into the thermal receiver.



The Boeing/Stirling Energy Systems DECC project will evaluate the performance of the "critical" parts of the Stirling engine and develop the next-generation of the 25 kW Dish-Stirling System.

THE POWER CONVERSION UNIT includes the thermal receiver and the engine/generator. The thermal receiver is the interface between the dish and the engine/generator. It absorbs the concentrated beam of solar energy, converts it to heat, and transfers the heat to the engine/generator. A thermal receiver can be a bank of tubes with a cooling fluid, usually hydrogen or helium, which is the heat transfer medium and also the working fluid for an engine. Alternate thermal receivers are heat pipes wherein the boiling and condensing of an intermediate fluid is used to transfer the heat to the engine.



This Science Application International Corporation/STM Power Inc. 25 kW Dish-Stirling System is operating at a Salt River Project site in Phoenix, AZ.

The engine/generator system is the subsystem that takes the heat from the thermal receiver and uses it to produce electricity. The most common type of heat engine used in dish-engine systems is the Stirling engine. A Stirling engine uses heat provided from an external source (like the sun) to move pistons and make mechanical power, similar to the internal combustion engine in your car. The mechanical work, in the form of the rotation of the engine's crankshaft, is used to drive a generator and produce electrical power.


In addition to the Stirling engine, microturbines and concentrating photovoltaics are also being evaluated

as possible future power conversion unit technologies. Microturbines are currently being manufactured for distributed


generation systems and could potentially be used in dish-engine systems. These engines, which are similar to (but much smaller than) jet engines, would also be used to drive an electrical generator. A photovoltaic conversion system is not actually an engine, but a semi-conductor array, in which the sunlight is directly converted into electricity.

What are the markets for Solar Dish-Engine Systems?

Solar dish-engine systems are being developed for use in emerging global markets for distributed generation, green power, remote power, and grid-connected applications. Individual units, ranging in size from 9 to 25 kilowatts, can operate independent of power grids in remote sunny locations to pump water or to provide electricity for people living in remote areas. Largely because of their high efficiency and "conventional" construction, the cost of dish-engine systems is expected to compete in distributed markets.



This small photovoltaic solar dish conversion system is being developed by Concentrating Technologies, LLC.



The Advanced Dish Development System is a 10 kW water pumping system developed by WG Associates for use by Native Americans in the southwest U.S.

Opportunities are emerging for the deployment of dish-engine systems in the Southwest U.S. Many states are adopting green power requirements in the form of "portfolio standards" and renewable energy mandates. While the potential markets in the U.S. are large, the size of developing worldwide markets is immense. The International Energy Agency projects an increased demand for electrical power worldwide more than doubling installed capacity. More than half of this is in developing countries and a large part is in areas with good solar resources, limited fossil fuel supplies, and no power distribution network. The potential payoff for dish-

engine system developers is the opening of these immense global markets for the export of power generation systems.

For more information, see the following documents:


Technology Characterization: Solar Dish Engine ([PDF Format 888KB](#))

Solar Dish/Engine Systems ([PDF Format 200KB](#))

Business and Market Opportunities

With one of the best direct normal insolation resources anywhere on earth, the southwestern

states are poised to reap large and as yet largely uncaptured economic benefits from this important natural resource. California, Nevada, Arizona, and New Mexico are each exploring policies that will nurture the development of their solar-based industries.



Experience gained with Solar Two has established a foundation on which industry can develop its first commercial plants.

(Joe Flores, Southern California Edison)

In addition to the concentrating solar power projects under way in this country, a number of projects are being developed in India, Egypt, Morocco, and Mexico. In addition, independent power producers are in the early stages of design and development for potential parabolic trough power projects in Greece (Crete) and Spain. Given successful deployment of one or more of these initial markets, additional project opportunities are expected in these and other regions.

One key competitive advantage of concentrating solar energy systems is their close resemblance to most of the power plants operated by the nation's power industry. Concentrating solar power technologies utilize many of the same technologies and equipment used by conventional central station power plants, simply substituting the concentrated power of the sun for the combustion of fossil fuels to provide the energy for conversion into electricity. This "evolutionary" aspect—as distinguished from "revolutionary" or "disruptive"—results in easy integration into today's central station-based electric utility grid. It also makes concentrating solar power technologies the most cost-effective solar option for the production of large-scale electricity generation.

Analysts predict the opening of specialized niche markets in this country for the solar power industry over the next 5 to 10 years. The U.S. Department of Energy estimates that by 2005 there will be as much as 500 megawatts of concentrating solar power capacity installed worldwide.


For more information, see the following document:

Markets for Concentrating Solar Power ([HTML Format](#); [PDF Format 82KB](#))

What Does It Cost?

Concentrating solar power technologies currently offer the lowest-cost solar electricity for large-scale power generation (10 megawatt-electric and above). Current technologies cost \$2–\$3 per watt. This results in a cost of solar power of 9¢–12¢ per kilowatt-hour. New innovative hybrid systems that combine large

concentrating solar power plants with conventional natural gas combined cycle or coal plants can reduce costs to \$1.5 per watt and drive the cost of solar power to below 8¢ per kilowatt hour.



Advancements in the technology and the use of low-cost thermal storage will allow future concentrating solar power plants to operate for more hours during the day and shift solar power generation to evening hours. Future advances are expected to allow solar power to be generated for 4¢–5¢ per kilowatt-hour in the next few decades.

For more information about how concentrating solar power technologies compare financially with one another, see page 3 of "Overview Of Solar Thermal Technologies" ([PDF Format 296KB](#)).

For more information about how concentrating solar power technologies compare financially with other renewable energy electricity technologies, see page 3 of "Project Financial Evaluation" ([PDF Format 34KB](#)).

[Questions/Comments](#) • [Privacy & Security Notice](#)

ATTACHMENT B4
U.S. DEPARTMENT OF ENERGY
ENERGY EFFICIENCY AND RENEWABLE ENERGY
SOLAR ENERGY TECHNOLOGY PROGRAM
“FURTHERING ENERGY INDEPENDENCE”
JULY 2006


**U. S. Department of Energy
Energy Efficiency and Renewable Energy
Solar Energy Technology Program**

“Furthering Energy Independence”

July 2006

Solar Energy Technology Program

Furthering Energy Independence



A Portfolio of Solar Technologies

Solar technologies use the sun to provide heat, light, hot water, electricity and even cooling for homes, businesses and industry. Through public-private partnerships, the U.S. Department of Energy's Solar Energy Technologies Program sponsors research and development that improves the performance and reduces the cost of solar power. To achieve this goal, the Program supports the research activities of world-class scientists and engineers in industry, academia and the national laboratories.

Program Basics

The Program has two primary research efforts:

- **Photovoltaics (PV)** develops semiconductor materials to convert sunlight directly into electricity, through an instantaneous, quiet process that uses no moving parts
- **Concentrating Solar Power (CSP)** develops reliable, cost-competitive systems that drive steam turbines

and engines using heat from concentrated sunlight

In his 2006 State of the Union address, President Bush launched the Solar America Initiative, marking a new drive to make PV cost-competitive with other forms of retail energy by 2015.

Multiple Markets, Multiple Solutions

With continued R&D, solar technologies can provide our nation with low-cost energy from abundant sunlight, and help reduce the country's greenhouse gas emissions. Through a combination of photovoltaic and thermal technologies, it will be practical to provide all the energy needed by an energy efficient home. It will also be cost-effective in some regions to generate power at a utility-scale through concentrating solar power systems

Improvements in performance and cost will continue to open new markets for solar technologies. Photovoltaics are already making significant inroads in high-value niche markets, such as remote,

stand-alone power for telecommunications and other "off-grid" applications.

International market growth is also strong for photovoltaics, fueled by incentives by such countries as Germany. Domestic growth is increasing as a result of the Energy Policy Act of 2005 tax incentives for residential and commercial use as well as State incentives. As manufacturing costs fall, photovoltaics are increasingly used for homes and other businesses already connected to the grid.

While it is true that some solar technologies have been commercialized, we still have a long way to go to reach market competitiveness for photovoltaic (PV) technologies in the U.S. without incentives. Due in large part to the research funded by the Department of Energy the cost of electricity from PV has dropped from more than \$2.00 per kilowatt-hour in 1976 to \$0.18-\$0.23 per kilowatt hour today. Yet, to compete with conventional power sources, PV costs still need to fall by another two-thirds. Under the President's Solar America Initiative,

ATTACHMENT B5
U.S. DEPARTMENT OF ENERGY
ENERGY EFFICIENCY AND RENEWABLE ENERGY
SOLAR ENERGY TECHNOLOGIES PROGRAM
“PROGRAM AREAS”
OCTOBER 2006

**U. S. Department of Energy
Energy Efficiency and Renewable Energy
Solar Energy Technology Program**

“Program Areas”

October 2006



Solar Energy Technologies Program

[About the Program](#) | [Program Areas](#) | [Information Resources](#) | [Financial Opportunities](#) | [Technologies](#) | [Deployment](#) | [Home](#)

[Search](#)

[Search Help](#) | [More Search Options](#)

[Printable Version](#)

[EERE Information Center](#)

The U.S. Department of Energy's Solar Program encompasses three major types of solar energy technologies: photovoltaics, concentrating solar power, and solar heating and lighting. These technologies are introduced briefly below, but you can learn much more about them in the [Technologies Section](#).

Concentrating solar power (CSP) systems concentrate the thermal energy of the sun to drive a steam turbine or heat engine. The turbine or engine then drives a generator to produce electricity. The three distinct CSP technologies are parabolic troughs, power towers, and dish-engine systems. The troughs and towers are applicable to large utility-scale projects in the megawatt range, but dish systems have been demonstrated at the 10-25-kilowatt scale.



This Chesapeake, Virginia, home takes advantage of both solar water heating and photovoltaics. The solar pool-heating system, located over the front porch, keeps the pool temperature in the 80° range from March to October. The solar collectors, located over the garage, face east, but still produce 75% of the annual hot water needs for this family of four. The PV modules are on the highest part of the roof, and they produce 1 kilowatt of electricity.

Photovoltaics (PV) is the direct conversion of light energy into


electricity using semiconductor materials. PV systems are composed of groups of solar cells wired in series to form modules, which can then be interlinked to form arrays. This modular nature allows PV to be used for applications ranging from a fraction of a watt, such as for handheld calculators, to large-scale, multi-megawatt power plants containing millions of solar cells. The most common type of PV device is the flat-plate module, which consists of flat sheets of glass or other materials containing the solar cells. Concentrating PV systems use lenses or mirrors to focus sunlight onto the solar cells, which enhances the light-to-electricity conversion efficiency of the solar cell.

Solar heating includes solar thermal systems that heat a working fluid for various applications. Solar collectors can provide thermal energy for direct use in the form of hot water for domestic water heating, space heating, and process heat, and in the form of hot air for space heating and process heat. Higher-temperature collectors can drive absorption and desiccant air-conditioning systems and can provide low-temperature steam.

Solar lighting is a newly emerging field. The Solar Program is also investigating hybrid lighting, which uses small solar concentrators and fiber optics to bring daylight into building interiors.

Evaluating Research Progress

Annually, all program research activities are formally reviewed at the National Center for Photovoltaics (NCPV) and Solar Program Review Meeting. Researchers from the national laboratories, universities, and industry present the latest developments for photovoltaics, concentrating solar power, solar thermal, solar lighting, and building technologies. Program managers present status report for their technologies and outlooks




Parabolic troughs are currently the

for the future. Invited speakers from outside the Solar Program offer fresh perspectives, which help to energize the meeting and those who attend. The [Program Review Highlights](#) describe the presentations and activities of the 2003 meeting.

most proven of the concentrating solar power technologies. Nine commercial-scale solar-electric generating stations, the first of which began operating in 1984, produce electricity in the California Mojave Desert.

More about the Program Areas

Under the Solar Program's [Deployment](#) section you'll see how Solar Program research is being put to practical use. [Financial Opportunities](#) features links for consumers who are interested installing solar energy and research professionals who may want to partner with the Solar Program. [Information Resources](#) is the place to link to solar energy information generated within the United States and around the world.

 [Printable Version](#)

[Solar Energy Technologies Program Home](#) | [EERE Home](#) | [U.S. Department of Energy](#)
[Webmaster](#) | [Web Site Policies](#) | [Security & Privacy](#) | [USA.gov](#)

Content Last Updated: 10/24/2006

ATTACHMENT B6
U.S. NATIONAL RENEWABLE ENERGY LABORATORY
“FUEL FROM THE SKY:
SOLAR POWER’S POTENTIAL FOR WESTERN ENERGY SUPPLY”
JULY 2002


U. S. National Renewable Energy Laboratory

**“Fuel from the Sky: Solar Power’s Potential
for Western Energy Supply”**

July 2002

Fuel from the Sky

Solar Power's Potential for Western Energy Supply



July 2002
NREL/SR-550-32160

Executive Summary

The Potential of Solar Power for Western Energy Supply

A reliable and affordable supply of electricity is essential to protect public health and safety and to sustain a vigorous economy in the West. Rolling blackouts in California in 2000 and 2001, low hydro generation in the Pacific Northwest in 2001, and a power plant construction boom in Texas have drawn attention to electricity issues in the West. All across the nation, demand for and supply of electricity have become unbalanced in the late 1990s, but nowhere has the issue been more pressing than in the West.

With population growing in the western states, electricity demand is poised for growth for the remainder of this decade. Both energy demand, that is the number of megawatt-hours (MWh) consumed over the course of the year, as well as peak demand, the highest hourly demand across the hours of the year, will continue to increase. Economic activity and population growth continue to be the most important drivers of electricity demand.

In 2001, a total of about 237,078 megawatts (MW) of capacity was installed in the West. Coal-fired generation provided about 44% of the electricity generated in the West and gas-fired generation accounted for about 24%. Hydroelectric power accounts for 22% of capacity and 18% of the generation in the states of the Western Governors' Association (WGA). Nuclear plants provide 7% of capacity and 11% of the energy. Of the remainder, about 1.5% comes from non-hydro renewables.

For almost 20 years, little new generating capacity has been built in the U.S. Now, however, new projects totaling over 133,747 MW by 2010 have been announced. Although not all of the announced projects will be completed, many thousands of megawatts, primarily gas-fired combined cycle power plants, are expected to come on-line in the West. The large amount of gas-fired capacity planned may result in more volatile gas prices for customers and will increase the reliance on fossil fuels for power generation. Energy conservation and energy efficiency can help offset the need for new generating capacity. However, renewable energy, in the form of wind or solar, provides one of the means of meeting the demand for power while minimizing adverse impacts on the environment, increasing fuel diversity, and hedging against fuel price volatility.

Concentrating solar power (CSP) is the most efficient and cost-effective way to generate electricity from the sun. Hundreds of megawatts of CSP solar-generating capacity could be brought on-


direct normal, and global radiation. Global radiation is the sum of direct and diffuse radiation. Haze increases the amount of diffuse radiation while at the same time the amount of direct normal radiation decreases. Haze also results in reflection and absorption of sunlight, which reduces the overall amount of global radiation. On an overcast day, essentially all radiation that reaches the ground is diffuse, while on a clear day 93% to 95% of all radiation is direct normal.

While flat panel PV power plants use both diffuse and direct radiation, CSP power plants (CPV, dish Stirling, power tower, and parabolic trough) can only use the direct component of the sunlight. This makes CSP unsuitable for areas with high humidity and frequent cloud cover, both of which result in scattering. However, this imposes little limitation on CSP power plants, because for the western U.S., areas of highest total (global) radiation are also areas with low humidity and few clouds.

Radiation levels are affected by both weather conditions and the position of the sun above the horizon. The angle of the sun's rays relative to the Earth's surface changes during the day and with the seasons. In the winter, the sun is lower in the sky and less energy reaches the ground. In the summer, the sun is overhead and sunshine is stronger. In the Desert Southwest, toward the fall and winter, cloud cover increases and often shields the sun.

For solar power generation using CSP, the annual average amount of solar energy reaching the ground needs to be 6.0 kilowatt-hours per square meter per day ($\text{kWh}/\text{m}^2/\text{day}$) or higher. This is the case in many regions of the West (see "The Solar Energy Potential"). In premium solar resource areas, the average annual solar radiation exceeds $7.0 \text{ kWh}/\text{m}^2/\text{day}$. Using the most efficient solar generating technology (dish Stirling), an area the size of an NBA basketball court located in a premium solar resource would generate 60,740 kWh of electricity a year. To generate the same amount of electric energy, natural gas equivalent to 60 barrels of oil would have to be burned in a combined cycle power plant. Exhibit 20 displays this energy and shows that solar radiation is a concentrated form of power. Current technology can capture large amounts of this energy and convert it to electricity—indeinitely, domestically, and with no pollution or price volatility.

Exhibit 19: Direct Normal, Diffuse, and Global Solar Radiation



SOURCE: Status Report on Solar Thermal Power Plants, Pilkinton Solar International, 1996. Used by permission.

Exhibit 37: Cost and Performance of Flat Panel PV and Concentrating PV

	Flat Panel Photovoltaic (1)		Concentrating PV
	Crystalline Silicon	Amorphous Silicon	
Unit Size	50 x 2 kW = 100 kW	50 x 2 kW = 100 kW	22–28 kW
Max Conversion Efficiency % (2)	13	6.5	18–19
Generation Threshold W/m ²	≥50 (3)	≥50 (3)	50
Annual Average Efficiency % (4)	11	6	TBD
Annual Avg. Capacity Factor % (4)	24	24	30–32
Equiv. Forced Outage Rate (EFOR)	TBD	TBD	1–3
Off-sun Generation	None	None	None
Acres/MW	3.8	7.6	8–10
Construction Time	2 weeks	4 weeks	3–4 days per unit
Capital Cost \$/kW	7,500–8,500		TBD
Fixed O&M \$/kW-year	10	TBD	10
Variable Non-fuel O&M \$/MWh	10	TBD	10
Production Capacity for U.S. Market MW/year	68	6.5	TBD
Cumulative U.S. Sales	140 MW		0.5 MW
Largest Unit in the U.S.	1 MW		TBD
Demonstrated System Hours	Unknown	Unknown	TBD

SOURCE: National Renewable Energy Laboratory (NREL); Golden, Colorado, private communication; see reference in endnote 3.

(1) Commercially available technologies only. Crystalline silicon modules account for about 90% of the flat panel PV market, while amorphous silicon modules account for the remaining 10%.

(2) At 1,000 W/m².

(3) Direct normal and diffuse radiation.

(4) Premium solar resource area. Flat panel PV tilted to latitude.

Concentrating PV

PV cells using multiple semiconductor junctions are capable of converting a much larger spectrum of sunlight to electricity than the single-junction cells used in conventional flat panel PV and thus have much higher efficiencies—up to 30%.⁴ Nevertheless, multi-junction cells can be used more cost effectively if sunlight is concentrated first. The same solar module then produces more power than under normal light conditions. For example, if mirrors or lenses concentrate light on multi-junction cells and increase the sunlight concentration by a factor of 10, that cell will produce about 10 times more power than under direct sunlight. Concentrating PV (CPV) uses mirrors or lenses to focus sunlight on high-efficiency cells. The concentrating optics, as in all concentrating solar power technologies, can only focus direct normal radiation, but not diffuse light.

The idea behind CPV is that a few high-performance (and high-cost) PV cells are put to maximum use by concentrating light on them by using either mirrors or lenses. Because the concentrating optics is cheaper than PV modules, this approach is expected to result in an overall lower system cost. Currently, most CPV systems use lenses to concentrate sunlight and employ two-axis tracking mechanics to follow the sun as it makes its way across the sky. Exhibit 37 provides cost and performance data on CPV.

We believe that CPV is a promising form of PV power generation because it uses only one-tenth, or even less, semiconductor material than flat panel PV and it can thus employ more expensive

Exhibit 40: Cost and Performance of Thermal Concentrating Solar Power Plants

	Dish/Stirling	Parabolic Trough	Power Tower
Standard Plant Size	2.5 MW/100 MW	100 MW	100 MW
Max Conversion Efficiency % (1)	30%	24%	22%
Generation Threshold W/m ²	200	300	300
Annual Average Efficiency (2)	21.40%	13.70%	16.00%
Annual Avg. Capacity Factor (2)			
Basic Plant	25-20%	23%	29%
With Thermal Storage (3)	N/A	33% (4 hrs, 1.8 x)	48% (8 hrs, 1.8 x)
With Fossil Fuel Hybridization	N/A	23-95%	29-95%
Equiv. Forced Outage Rate (EFOR) %	5 (estimate)	5	5 (estimate)
Off-Sun Generation	Fossil Hybrid	Heat Storage/Fossil Hybrid	Heat Storage/Fossil Hybrid
Acres/MW of Collectors	4	5	8
Construction Time (4)	3-4 days per unit; 35 days/6 months	12 months	12 months
Incremental Capital Cost			
Basic Plant \$/kW	2,650	1,956	2,065
Heat Storage \$/kWh	N/A	103	27
Additional Solar Field \$/kW	N/A	510	540
Fossil Fuel Hybridization \$/kW	Not commercial	196	196
Fossil Heat Rate (HHV) (4)	TBD	10,800	10,000
Incremental Fixed O&M \$/kW-year			
Basic	40/2.5	33	30
Heat Storage	N/A	2	1.5
Additional Solar Field Only	N/A	2	1.5
Fossil Fuel Hybridization	N/A	—	—
Incremental Variable Non-fuel O&M \$/MWh			
Basic	16.80/15	2	2
Heat Storage	N/A	—	—
Fossil Fuel Hybridization	N/A	—	—
RDI estimated new Capacity (MW) that could be built (5)			
2002	0.7	—	—
2003	3.1	30	—
2004	27.5	100	50
2005	75	200	50
2006	100	300	150
Total	206.3	630	250
Cumulative U.S. Installations	118 kW	354 MW	10 MW
Largest Unit in the U.S.	25 kW	80 MW	10 MW (decommissioned)
Demonstrated System Hours	80,000	300,000	2,000

(1) At 1,000 W/m²

(2) Premium solar resource area.

(3) The number of hours of full-load heat storage and the solar-to-electricity ratio are given in parentheses, e.g. "13 hrs, 1.6 x" means three hours of full-load electric generation from heat storage and a solar field, which is oversized by 60% with regard to the electric capacity of the power island.

(4) Based on natural gas.

(5) Assumes sufficient tax or buydown incentives and private sector financing, but no government-backed programs, such as loan guarantees.

ATTACHMENT B7
U. S. NATIONAL RENEWABLE ENERGY LABORATORY
U.S. SOLAR RADIATION RESOURCE MAPS
“ATLAS FOR THE SOLAR RADIATION DATA MANUAL
FOR FLAT-PLATE AND CONCENTRATING COLLECTORS”
(NO DATE)


U. S. National Renewable Energy Laboratory

**U.S. Solar Radiation Resource Maps
“Atlas for the Solar Radiation Data Manual
for Flat-Plate and Concentrating Collectors”**

(no date)

Average Daily Solar Radiation Per Month

ANNUAL




East-West Axis Tracking Concentrator

Alaska




Hawaii



Hawaii, Puerto Rico, and Guam are not shaded.

San Juan, PR



Guam, PI



Collector Orientation

One-axis tracking parabolic trough with a horizontal east-west axis

This map shows the general trends in the amount of solar radiation received in the United States and its territories. It is a spatial interpolation of solar radiation values derived from the 1961-1990 National Solar Radiation Data Base (NSRDB). The dots on the map represent the 239 sites of the NSRDB.

Maps of average values are produced by averaging all 30 years of data for each site. Maps of maximum and minimum values are composites of specific months and years for which each site achieved its maximum or minimum amounts of solar radiation.


Though useful for identifying general trends, this map should be used with caution for site-specific resource evaluations because variations in solar radiation not reflected in the maps can exist, introducing uncertainty into resource estimates.

Maps are not drawn to scale.

*** NREL**

National Renewable Energy Laboratory
Resource Assessment Program

kWh/m²/day



ATTACHMENT C
IDAHO NATIONAL ENGINEERING AND ENVIRONMENTAL LABORATORY
“U.S. HYDROPOWER RESOURCE ASSESSMENT, FINAL REPORT”
DECEMBER 1998

**Idaho National Engineering and
Environmental Laboratory**

**“U.S. Hydropower Resource Assessment”
Final Report**

December 1998

U.S. Hydropower Resource Assessment Final Report

**Alison M. Conner
James E. Francfort
Ben N. Rinehart**

Published December 1998

**Idaho National Engineering and Environmental Laboratory
Renewable Energy Products Department
Lockheed Martin Idaho Technologies Company
Idaho Falls, Idaho 83415**

**Prepared for the
U.S. Department of Energy
Assistant Secretary for Energy Efficiency and Renewable Energy
Under DOE Idaho Operations Office
Contract DE-AC07-94ID13223**

ABSTRACT

To provide a more accurate assessment of the domestic undeveloped hydropower capacity, the U.S. Department of Energy's Hydropower Program developed a computer model, Hydropower Evaluation Software (HES). HES allows the personal computer user to assign environmental attributes to potential hydropower sites, calculate development suitability factors for each site based on the environmental, legal, and institutional attributes present, and generate reports based on these suitability factors. This report describes the development of HES, its data requirements, and its application to each state assessment; in addition, it summarizes the data derivation process and data for the states. Modeling of the undeveloped hydropower resources in the United States, based on environmental, legal, and institutional constraints, has identified 5,677 sites that have a total undeveloped capacity of about 30,000 megawatts.

SUMMARY

This report presents the culmination of U.S. Department of Energy's (DOE's) efforts to produce a more definitive assessment of undeveloped hydropower resources within the United States. Initial efforts began in 1989 and information from the last state was received in 1998. State agencies contributed information about hydropower resources within their states to DOE's computer model, Hydropower Evaluation Software, and completed their review of the data. The state agencies involved in the project have included departments of dam safety, water resources, environmental quality, fish and game, history, and commerce. The Association of Dam Safety Officials has served as a conduit to identify the appropriate agencies from each state to assist in the modeling effort. Each state received on the average of \$4,000 to complete the hydropower assessment. This level of funding did not cover each state's expenses, so the states provided the difference.

Past efforts to identify and measure the undeveloped hydropower capacity in the United States have resulted in estimates ranging from about 50,000 MW to almost 600,000 MW; these include the Hydropower Resource Assessment team's original estimate of 52,900 MW, the FERC's estimate of 70,000 MW, and the Corps of Engineers' theoretical estimate of 580,000 MW. None of these historical estimates have been universally accepted. These early estimates failed to consider the environmental, legal, and institutional constraints to developing hydropower projects. To provide a more accurate assessment of the domestic undeveloped hydropower capacity, the DOE Hydropower Program developed a computer model, Hydropower Evaluation Software (HES). HES allows the personal computer user to assign environmental attributes to potential hydropower sites, calculate development suitability factors for each site based on the environmental, legal, and institutional attributes present, and generate reports based on these suitability factors. Modeling of the undeveloped hydropower resources in the United States, based on environmental, legal, and institutional constraints, has identified 5,677 sites that have a total undeveloped capacity of about 30,000 megawatts.

This report summarizes the data derivation process and data for the United States. It also describes the development of HES, its data requirements, and its application to each state assessment. This report does not discuss or present the various user-friendly menus of HES. Readers are referred to the User's Manual for specifics. Information for ordering is provided on pages 33-34.

ACKNOWLEDGMENTS

The authors would like to thank Peggy A. M. Brookshier and John V. Flynn of the Department of Energy for their active participation and timely comments. We also thank all those individuals from the states for providing valuable information and positive feedback.

CONTENTS

ABSTRACT	iii
SUMMARY	v
ACKNOWLEDGMENTS	vii
INTRODUCTION	1
Need For Uniform Criteria	1
Model Development	2
Model Validation	2
Modeling Process	3
Model Goal	3
DATA SOURCES	4
Primary Data Sources	4
Secondary Data Sources	5
Data Sources for Threatened and Endangered Species	6
SITE ATTRIBUTES AND SUITABILITY FACTOR DETERMINATION	7
Environmental, Legal, and Institutional Attribute Definitions	7
Suitability Factor Values	11
Dam Status	11
Overall Project Suitability Factor	12
LIMITATIONS AND APPLICABILITY	14
ASSESSMENT PROCESS AND ASSUMPTIONS	15
SUMMARY OF COMPLETED HYDROPOWER RESOURCE ASSESSMENT	16
CONCLUSIONS	32
OBTAINING INDIVIDUAL STATE INFORMATION	33
ADDITIONAL HYDROPOWER EVALUATION SOFTWARE INFORMATION	34
REFERENCES	35

Appendix A—Basic Site Data.....	A-1
---------------------------------	-----

FIGURES

1. Sample printout of resource database listing.....	10
2. Number of sites with undeveloped hydropower capacity by state for Alabama through Missouri	25
3. Number of sites with undeveloped hydropower capacity by state for Montana through Wyoming	26
4. Total undeveloped hydropower capacity by state for Alabama through Missouri.....	27
5. Total undeveloped hydropower capacity by state for Montana through Wyoming.....	27
6. Total undeveloped hydropower capacity by site status.....	28
7. Location of the majority of hydropower sites by state, reported as a percentage of the total number of sites.....	29

TABLES

1. Valuation of environmental attributes.....	11
2. Suitability factors by dam status for environmental attributes.....	12
3. Overall project suitability factor computation.....	13
4. Hydropower capacity summary modeled by HES	17
5. The percent of the original undeveloped hydropower capacity that remains after HES is applied.	29

U.S. Hydropower Resource Assessment Final Report

INTRODUCTION

In June 1989, the U.S. Department of Energy (DOE) initiated the development of a National Energy Strategy to identify the energy resources available to support the expanding demand for energy in the United States. Public hearings conducted as part of the strategy development process indicated that the undeveloped hydropower resources were not well defined. One of the reasons was that no agency had previously estimated the undeveloped hydropower capacity based on site characteristics, stream flow data, and available hydraulic heads. The Federal Energy Regulatory Commission's (FERC's) Hydropower Resource Assessment (HPRA) database was used as the basis for this evaluation. The undeveloped capacity data is based on individual site evaluations that included capacity estimation. It was this information that for the first time was reviewed by the various state agencies and then modeled based on environmental, legal, and institutional constraints. As a result, DOE established an interagency Hydropower Resource Assessment Team to ascertain the country's undeveloped hydropower potential. The team consisted of representatives from each power marketing administration (Alaska Power Administration, Bonneville Power Administration, Western Area Power Administration, Southwestern Power Administration, and Southeastern Power Administration), the Bureau of Reclamation, the Army Corps of Engineers, the Federal Energy Regulatory Commission (FERC), the Idaho National Engineering and Environmental Laboratory (INEEL), and the Oak Ridge National Laboratory. The interagency team drafted a preliminary assessment of potential hydropower resources in February 1990. This assessment estimated that 52,900 MW of undeveloped hydropower energy existed in the United States.

Partial analysis of the hydropower resource database by groups in the hydropower industry

indicated that the hydropower data included redundancies and errors that reduced confidence in the published estimates of developable hydropower capacity. The DOE has continued assessing hydropower resources to correct these deficiencies, improve estimates of developable hydropower, and determine future policy. To support these efforts by the DOE, the INEEL designed the Hydropower Evaluation Software (HES).

This report summarizes and discusses the undeveloped conventional hydropower capacity for the 5,677 sites within the United States. However, this capacity does not include that produced by pumped storage sites. The resource assessment is limited to sites with conventional undeveloped hydropower potential. In addition, while every reasonable effort was made to include all sites with undeveloped potential, the authors acknowledge that not every site in the United States with undeveloped hydropower potential was included. Only sites that have been either previously identified by third parties and included in the FERC HPRA database, or sites that local state agencies are aware of, are included in the database.

Need For Uniform Criteria

The INEEL's HES, both a database and a probability-factor computer model, is a menu-driven software application that is intended to be user-friendly. Computer screens and report generation capabilities were developed to meet the needs of users nationwide. HES considers a uniform set of possible site-specific environmental attributes to assess the likelihood of developing the undeveloped hydropower resources of regions and states. These site-specific environmental attributes, derived from the Nationwide Rivers Inventory, include whether a site has Wild and Scenic Protection or is on a tributary of a site with such protection;

whether cultural, historical, fishery, geologic, recreational, scenic, or wildlife attributes are present; and whether threatened or endangered fish or wildlife are present. The attributes are based on the potential project's location, including whether the site is within a national park, national grasslands, national wildlife refuge, or other federal lands. HES's use of uniform criteria allows personal computer users nationwide to identify environmental attributes present at sites with undeveloped hydropower capacity, calculate development suitability factors for each site based on the attributes present, and generate uniform reports based on these factors.

HES was developed as a tool for use by regional power marketing administrations and state energy agencies, because they are the most likely to need accurate hydropower information. HES was not intended to provide precise development factors for individual sites, but to provide regional or state capacity totals. Because the software was developed as a generic measurement tool encompassing national issues, regional and state totals must be considered judiciously; various local issues may skew hydropower capacity totals. Employing HES as a national measurement tool will smooth any local anomalies.

Model Development

HES uses environmental attribute data to generate an overall project suitability factor between 0.1 and 0.9, with 0.1 representing the lowest possibility of development and 0.9 representing the least impediment to development. A combination of attributes results in a lower suitability factor because multiple environmental considerations reduce the likelihood that a site may be developed to its physical capacity.

HES was developed with input from Oak Ridge National Laboratory, which provided the essential environmental evaluation support (Sale 1990). The INEEL also received valuable assistance from the Southwestern Power

Administration, which helped defined the database requirements and the reporting capabilities required by a power marketing administration, and valuable managerial assistance from the Association of Dam Safety Officials.

Model Validation

The INEEL used the HES to assess the undeveloped hydropower capacity in the Southwestern Power Administration area during the HES testing stage. The states in this area include Arkansas, Kansas, Louisiana, Missouri, Oklahoma, and Texas. HES identified about 250 sites with undeveloped hydropower capacity. After the HES computer model analysis was completed, the estimated Southwestern Power Administration hydropower resources were reduced 33.5%. This reduction resulted from the influence of various environmental attributes on the reality of successfully developing a hydropower site.

After successfully developing and testing HES in conjunction with the Southwestern Power Administration, the interagency team recognized that a process was necessary to successfully integrate the evaluation process between the individual states and the DOE's Hydropower Program. With administrative relationships already in place with the individual states, the team believed that using the DOE's Support Offices to coordinate the assessment process might prove to be a practical method to assess the entire United States. The Denver Support Office coordinated the assessments of the individual states within their administrative region (Colorado, Montana, North Dakota, South Dakota, Utah, and Wyoming), as did the Boston Support Office (Connecticut, Maine, Massachusetts, New Hampshire, Rhode Island, and Vermont), the Kansas Support Office (Iowa), and the Chicago Support Office (Indiana). The test assessments, including obtaining individual state input, proved to be a viable method that could be used to assess hydropower capacity throughout the United States.

Modeling Process

The basic modeling process incorporated the following steps:

1. The FERC HPRA database was used for basic site information such as site name, river, county, state, if a dam or power plant was previously developed, and the undeveloped hydropower potential.
2. This data was reviewed by the INEEL for redundancy and accuracy and entered into the HES model.
3. The National Rivers Inventory data, containing environmental, institutional, and legal attributes, was entered into the HES by the INEEL for those undeveloped sites that are located on river reaches containing NRI-listed attributes.
4. Wild and Scenic information was obtained from several sources and this information was also entered by the INEEL into the HES for those undeveloped sites that are located on river reaches with either wild and scenic designation or river reaches being considered for wild and scenic designation.
5. The HES containing the above information for each respective state was then sent to the

individual states agencies for review and input.

6. After the state information was entered into the HES, the INEEL generated individual state reports for public dissemination via published reports and the internet (<http://www.inel.gov/national/hydropower/state/stateres.htm>)

Model Goal

The goal of HES is to ensure that a set of uniform criteria is used to determine the viable national hydropower capacity. This undeveloped hydropower is not limited to that which could be produced at new sites; it also includes the hydropower that could be produced at sites that currently produce hydropower but are not developed to their full capacity. This undeveloped hydropower is a source of nonpolluting, renewable energy available to meet the growing power needs of the United States. HES has helped to make this goal obtainable and ensured the use of uniform criteria during the national assessment process.

The HES is not intended to be a static assessment, as sites can be added and changes can be made to the modeling dynamics if the need for additional renewable sites becomes such that the influence of the attributes changes in the future.

DATA SOURCES

Primary Data Sources

The Federal Energy Regulatory Commission's (FERC's) HPRA database and the National Park Service's Nationwide Rivers Inventory database are the two main information databases used for hydropower site data. State input is used to validate the HES-modeled results.

Hydropower Resource Assessment Database. This database is maintained by FERC and contains the best available national inventory of undeveloped hydropower capacity. It contains information about all sites that have been subject to any FERC hydropower licensing action and information on project sites that have been identified by FERC, or other agencies, as having development capacity even if no licensing action has taken place. This database lists project sites and corresponding basic site data. Approximately 5,700 sites with undeveloped hydropower capacity are listed in the HPRA database.

Nationwide Rivers Inventory Database. The Nationwide Rivers Inventory was initially completed in 1982 by the National Park Service and has been periodically updated since that time. Park Service regional offices systematically collected information on rivers and identified those with outstanding resources. Uniform procedures for identifying rivers for the Nationwide Rivers inventory, including field and map verification of each river's values, were applied throughout the country. Specific outstanding resources were identified for those river reaches selected for inclusion in the Nationwide Rivers Inventory. Reaches were identified if outstanding fisheries, wildlife, geologic features, historical resources, cultural resources, recreation resources, scenic values, or other resources were present. The Nationwide Rivers Inventory also indicates the presence of threatened and endangered species (classified as fish or terrestrial wildlife) and whether the reach is part of, or considered for, inclusion in a state or federal wild and scenic rivers program.

Although the National Park Service used uniform procedures to consider rivers throughout the United States for inclusion in the Nationwide Rivers Inventory, it would be incorrect to assume that if a potential site is not on a reach listed in the Nationwide Rivers Inventory there would be few environmental impediments to development: significant changes, such as new fisheries or increased recreational use, may have occurred since the Nationwide Rivers Inventory was last updated.

State Resource and Energy Agencies. After the information contained in FERC's HPRA database and the National Park Service's Nationwide Rivers Inventory database were entered into HES, the modeled results were presented to the natural resource departments or energy offices. Each state was then able to provide input, validate, and in many cases update the environmental and physical attributes present at each of the undeveloped hydropower sites. Additionally, the individual states were able to add previously unlisted sites that were known to state agencies as having undeveloped hydropower capacity.

State input is often the result of coordinated canvassing between several state agencies within each state. For instance, water management agencies may identify sites with undeveloped hydropower capacity that were not listed in FERC's HPRA database. Or, state agencies may be aware of state historical sites such as archeological sites of early Indian societies or other historical values that would impact the probability of developing a hydropower site. This state input often results in an adjustment of a site's overall project suitability value. In the case of the addition of previously unidentified sites with undeveloped hydropower capacity, a state's sum of undeveloped hydropower capacity may be increased. The value of state input to the modeling of undeveloped hydropower capacity cannot be overstated. Based on site visits such as dam safety inspections, wildlife field work, and cultural assessments, each state is the best source of local site knowledge.

Secondary Data Sources

Other data sources can also be used to identify project locations and to assign environmental attributes to these locations. Some of these data sources are national in coverage, while others are available only for smaller areas such as individual states. Each additional database used will need to be obtained from its source, and the environmental attributes it lists will need to be extracted.

Power Marketing Administrations.

Power marketing administrations possess significant information that is of primary importance to the successful application of HES. Each power marketing administration can verify any outside sources of data that are used; but, of greater importance, each power marketing administration can provide significant information about anything affecting potential hydropower development within its region. Power marketing administrations will be aware of possible state opposition and any local action regarding a specific project.

State Environmental Databases. Many states keep inventories of aquatic and riparian resources. These inventories can include lists of high-quality and possibly protected streams, natural areas, and recreational resources. State data is often very useful for determining the environmental feasibility of hydropower sites, but the data may require a great deal of manipulation before it can be incorporated into a regional database for hydropower evaluation. Because little state information is available in digital format, it is difficult to input state data into the HES database.

An example of a state database is the California Department of Fish and Game Wild Trout Program inventory, which lists streams identified as outstanding trout fisheries; such streams are protected from development under California law. As another example, the state of Utah has rated each of its streams by the following categories: (a) type of fishery, (b) productivity, (c) reproductive success, (d) spawning habitat, and (e) aesthetics. Projects

on streams with high ratings in these categories will have greater environmental concerns.

American Rivers Outstanding Rivers

List. During 1988, an organization named American Rivers published its Outstanding Rivers List. This list is a comprehensive, nationwide compilation of rivers that possess some outstanding ecological, recreational, natural, cultural, or scenic values. Rivers protected by legislation and rivers currently unprotected are included. The list contains an estimated 15,000 river reaches, totaling about 300,000 river-miles. Each river reach is described in terms such as its upriver and downriver end points, its total length, its significance, and the source of information. Some of this information is redundant with the Nationwide Rivers Inventory, which is included within the Outstanding River List, but much of it is additional information.

Northwest Power Planning Council.

Streams under the jurisdiction of the Bonneville Power Administration have been studied by area states and rated by the Northwest Power Planning Council for the suitability of additional hydropower development. Streams were rated for values such as anadromous fish presence, resident fish populations, wildlife, natural features, cultural features, and recreation. In 1987, the Northwest Power Planning Council published a list of streams deemed unsuitable for hydropower development, which generally includes all streams containing anadromous fisheries. For projects proposed in the Bonneville Power Administration marketing area, the stream ratings are an important source of environmental attributes.

Wetlands Inventories. The presence of wetlands that could be affected by a potential hydropower project is an important environmental attribute because wetlands are protected under the Clean Water Act. The U.S. Fish and Wildlife Service has inventoried wetlands in some regions, and maps of these inventoried wetlands are available. Wetland inventories are also available from some states.

Data Sources for Threatened and Endangered Species

U.S. Fish and Wildlife Service Threatened and Endangered Species Database. Geographic information in this database is given by county and hydrologic unit and sometimes at finer resolutions. Species information includes locations of species, life histories of species, legal histories of the designation as threatened and endangered species, habitat use, bibliographies, contact

people, and key words that identify species as aquatic, wetland, or riparian species. The database has been in transition between in-house development and contracted management (by the Nature Conservancy) for several years. It appears that a wealth of information exists but may be difficult to access.

Nature Conservancy. The Nature Conservancy has a national database of all species that identifies threatened and endangered species. This database organizes geographic information by county.

SITE ATTRIBUTES AND SUITABILITY FACTOR DETERMINATION

Environmental, Legal, and Institutional Attribute Definitions

The INEEL derived the following 19 environmental attributes from the Nationwide Rivers Inventory. The corresponding suitability factors are fully explained in the Suitability Factor Determination section below.

Wild/Scenic Protection. This attribute identifies project sites that are included in the federal wild and scenic rivers system, under consideration for inclusion in the federal system, included in a state river protection program, in a designated wilderness area, or protected from development under another program. Relatively few sites have this status, but those that do are highly unlikely to be developed. Projects at undeveloped sites on state or federally protected wild and scenic rivers, or in wilderness areas, must be assumed to be legally protected from hydropower development. Also, projects at sites under consideration for protection are highly likely to be opposed by state and federal resource agencies, and protection will be approved at many such sites before hydropower development could occur. Since it is possible, but highly unlikely, that development could occur at a site with wild and scenic river protection, the suitability factor assigned to all such projects at undeveloped sites is 0.1.

It is highly unlikely that a project at an existing dam would be on a wild and scenic river since rivers are usually designated as wild and scenic only if they are free of developments such as dams. A suitability factor of 0.5 is assigned for such unusual cases.

Wild and Scenic Tributary or Upstream or Downstream of a Wild and Scenic Location. This attribute is assigned to a project if it is at the upstream or downstream end of a wild and scenic river reach or is on a tributary of a wild and scenic river. A project at

a developed site would affect a downstream wild and scenic river if additional alterations to the flow regime resulted. A suitability factor of 0.75 is assigned for such projects. Projects at undeveloped sites are highly likely to alter the flow regime and may cause changes in downstream water quality, so a suitability factor of 0.5 is assigned to undeveloped sites.

Cultural and Historic Values. Project impacts on cultural and historic resources can often be mitigated (for example, by excavating archeological sites or relocating historic structures). Projects at existing dams are unlikely to affect such resources unless an increase in reservoir pool elevation occurs or major new structures are built. A suitability factor of 0.75 is assigned to such projects. Development of undeveloped sites is more likely to affect cultural and historic resources, so a suitability factor of 0.5 is assigned.

Fish Presence Value. A stream reach may or may not have legally protected fisheries. In either case, however, strong state opposition to new development must be expected if a valuable fishery resource exists. Relatively high instream flow release requirements can mitigate the impact on fisheries, but a high instream flow release would reduce the economic viability of the project. Projects at developed sites could have some impact, such as increased turbine mortality. A suitability factor of 0.75 is assigned to projects at developed sites. Development at undeveloped sites could have a major impact on aquatic habitat through inundation, migration blockage, turbine mortality, water quality, and altered flows. Some of these can be mitigated, but such mitigation could be expensive. A suitability factor of 0.25 is assigned to undeveloped sites.

Geologic Value. Geologic values such as rock formations are rarely protected legally and are not generally affected by small projects. Development at existing sites is not affected by

geologic resources, so a suitability factor of 0.9 is assigned. Development at undeveloped sites may inundate geologic features, so a suitability factor of 0.5 is assigned.

Recreation Value. River recreation users tend to be effective opponents of hydropower development. Development at any storage dam would affect recreation by altering flow releases; mitigation typically includes higher flow releases during periods of high recreation use. Such releases can be made through turbines, but higher flow releases tend to occur when power demands are low. Projects at existing dams would have little effect on recreation besides flow alterations, so they are assigned a suitability factor of 0.75. Projects at undeveloped sites would inundate reaches, block the passage of boats, and reduce aesthetics. Because projects at undeveloped sites are likely to be strongly opposed, a suitability factor of 0.25 is assigned.

Scenic Value. Scenic values are not legally protected but must be considered in assessing the impact of a project. Scenic values are also important to recreational river users. The addition of power to existing dams would alter scenic values only through the addition of new structures and perhaps by reducing visually attractive spillage, so a suitability factor of 0.9 is assigned. New projects at undeveloped sites would have important effects on scenic resources because views would be altered by the project. Undeveloped projects are assigned a suitability factor of 0.5.

Wildlife Value. Terrestrial wildlife and wildlife habitat are protected by fish and game agencies that are influential in determining mitigation requirements for hydropower projects. Development at existing sites would have little effect on wildlife unless reservoir pool elevations are altered or construction of major facilities is required. A suitability factor of 0.75 is assigned for projects at existing sites. Development at undeveloped sites could inundate wildlife habitat, and construction would cause a great deal of disturbance. It is difficult to mitigate for such impacts, so opposition to such a project could be strong.

Undeveloped projects are assigned a suitability factor of 0.25.

Other Value. The effects of other values, such as the presence of rare wetland communities or consideration for wilderness designation, are assigned by using the most commonly assigned suitability factor for the other values. For projects at developed sites, the suitability factor is 0.75. For projects at undeveloped sites, the suitability factor is 0.5.

Threatened and Endangered Fish or Wildlife. The presence of threatened and endangered species near a project site requires additional consultations with wildlife agencies and can result in additional studies and mitigation requirements. The presence of threatened and endangered fish species may preclude development of new storage projects because new projects can involve the greatest alteration of aquatic habitat. Terrestrial threatened and endangered species are unlikely to be highly affected by run-rivers projects, but storage reservoirs could affect terrestrial habitat. For existing sites, a suitability factor of 0.75 is assigned when threatened and endangered species are present. For projects at undeveloped sites, a suitability factor of 0.5 is assigned when threatened and endangered species are present.

Federal Land Code 103: National Park, Monument, Lakeshore, Parkway, Battlefield, Or Recreation Area. These lands are legally protected from development. A suitability factor of 0.1 is assigned for such projects.

Federal Land Code 104: National Forest or Grassland. These lands are not legally protected from development, but the managing agency has the right to impose additional mitigation requirements on projects. A suitability factor of 0.75 is assigned to projects at existing sites, since these projects typically have fewer impacts. A suitability factor of 0.5 is assigned for undeveloped sites.

Federal Land Code 105: National Wildlife Refuge, Game Preserve, or Fish Hatchery. These lands are managed for fish

and wildlife habitats, and hydropower development would almost always be incompatible. A suitability factor of 0.1 is assigned for such projects.

Federal Land Code 106: National Scenic Waterway or Wilderness Area.

These lands are legally protected from development. A suitability factor of 0.1 is assigned for such projects.

Federal Land Code 107: Indian Reservation. These lands are not legally protected from development, but Indian tribes have the right to impose additional mitigation requirements on projects. A suitability factor of 0.75 is assigned for projects at developed sites, and a suitability factor of 0.5 is assigned for projects at undeveloped sites.

Federal Land Code 108: Military Reservation. These lands are not legally protected from development, but the managing agency has the right to impose additional mitigation requirements on projects. A suitability factor of 0.75 is assigned for projects at developed sites, and a suitability factor of 0.5 is assigned for projects at undeveloped sites.

Federal Land Code 198: Not on Federal Land. This variable indicates that the project is not on federal land, so there are not any development constraints based on Federal Land Codes. The value for this variable is 0.9.

Figure 1 illustrates all of the data requirements presented above in a report printout from HES. The cultural, fish presence, historic, and scenic values combine to give the sample site a project suitability factor (PESF) of 0.5.

Georgia Hydropower Resource Database Listing

FERC Number: 01218

Plant Name: FLINT RIVER

Class: P

Stream: FLINT R

Owner: GEORGIA POWER CO

County: DOUGHERTY

Basin: APALACHICOLA RIVER BASIN

<i>Name Plate</i>			<i>Annual Energy Rating</i>		<i>PESF Annual Energy</i>	
<i>Rating (KW)</i>	<i>PESF</i>	<i>PESF*KW</i>	<i>(MWh)</i>		<i>Rating (MWh)</i>	
2800	0.5	1400	8700		4350	
<i>Unit Type</i>	<i>Plant Type</i>	<i>Project Status</i>	<i>Dam Status</i>	<i>Latitude</i>	<i>Longitude</i>	
C	ROR	MO	W	3137	8406	
<i>Factor</i>	<i>Exists</i>	<i>Prob</i>	<i>Factor</i>	<i>Exists</i>	<i>Prob</i>	
<i>Wild/Scenic Protection</i>		0.9	<i>Wildlife Value</i>	Y	0.75	
<i>Wild/Scenic Tributary or</i>			<i>Threatened/Endangered Fish</i>		0.9	
<i>Upstream/Downstream</i>			<i>Threatened/Endangered</i>			
<i>Wild/Scenic Location</i>		0.9	<i>Wildlife</i>		0.9	
<i>Cultural Value</i>		0.9	<i>Federal Land Code 103</i>		0.9	
<i>Fish Presence Value</i>	Y	0.75	<i>Federal Land Code 104</i>		0.9	
<i>Geologic Value</i>	Y	0.9	<i>Federal Land Code 105</i>		0.9	
<i>Historic Value</i>		0.9	<i>Federal Land Code 106</i>		0.9	
<i>Other Value</i>		0.9	<i>Federal Land Code 107</i>		0.9	
<i>Recreation Value</i>	Y	0.75	<i>Federal Land Code 108</i>		0.9	
<i>Scenic Value</i>	Y	0.9	<i>Federal Land Code 198</i>		0.9	

Figure 1. Sample printout of resource database listing.

Suitability Factor Values

Suitability factors depend on the environmental attributes of the potential project site. They reflect the probability that environmental considerations can make a project site unacceptable, prohibiting its development. The suitability factors were developed in conjunction with Oak Ridge National Laboratory staff who are experienced in hydropower licensing cases. Five potential values were selected, as shown in Table 1. *These suitability factors are appropriate only for the regional analysis of overall hydropower development capacity and are not useful for determining the ultimate viability of developing a specific project site.*

Dam Status

The effects of environmental attributes vary by dam status. The dam status classifications follow FERC standard, which is

- W = Developed hydropower site with power.
- W/O = Developed site without power generation (the site has some type of developed impoundment or diversion structure).

U = Undeveloped site (the site does not have power generation capability, no developed impoundment, nor a diversion structure).

Undeveloped sites do not have any power or civil structures in place; developed sites without power do not have any power generation capability but do have some type of civil structure such as a dam or water diversion structure; and developed sites with power have current generation and a civil structure onsite with additional, undeveloped hydropower capacity.

The best way to explain the influence dam status has on a project's environmental suitability factor is to provide an example: development at an undeveloped site will have a greater impact on recreation than additional development at an existing site. So if a recreation value is present at an undeveloped site, a probability of 0.25 is assigned to reflect the decreased likelihood of development. If a recreation value is present at a developed site (either with or without power), then a value of 0.75 is assigned because additional development of a site already having a structure, either with or without power, is less likely to be impacted by any recreation value. These factors and all the other factors used are shown in Table 2.

Table 1. Valuation of environmental attributes.

Effect of Environmental Attribute	Value of Suitability Factor
Least impediment to development	0.90
Minor reduction in likelihood of development	0.75
Likelihood of development reduced by half	0.50
Major reduction in likelihood of development	0.25
Development prohibited or highly unlikely	0.10

Table 2. Suitability factors by dam status for environmental attributes.

Environmental Attribute	Suitability Factors		
	Existing Dam With/Without Power	Undeveloped Site	Not Applicable
Wild/Scenic Protection	0.50	0.10	0.90
Wild/Scenic Tributary or Upstream/Downstream Wild/Scenic Location	0.75	0.50	0.90
Cultural Value	0.75	0.50	0.90
Fish Presence Value	0.75	0.25	0.90
Geologic Value	0.90	0.50	0.90
Historic Value	0.75	0.50	0.90
Other Value	0.75	0.50	0.90
Recreation Value	0.75	0.25	0.90
Scenic Value	0.90	0.50	0.90
Wildlife Value	0.75	0.25	0.90
Threatened/Endangered Fish	0.75	0.50	0.90
Threatened/Endangered Wildlife	0.75	0.50	0.90
Federal Land Code 103	0.10	0.10	0.90
Federal Land Code 104	0.75	0.50	0.90
Federal Land Code 105	0.10	0.10	0.90
Federal Land Code 106	0.10	0.10	0.90
Federal Land Code 107	0.75	0.50	0.90
Federal Land Code 108	0.75	0.50	0.90
Federal Land Code 198	0.90	0.90	0.90

The “not applicable” column in Table 2 assigns the default value of 0.90 if the user indicates the attribute is not present or if the entry is left blank. Environmental concerns will exist even if no environmental attributes are assigned, so a default value of 0.90 (rather than 1.0) is used to reflect this reality.

Overall Project Suitability Factor

The final step in evaluating the environmental suitability of each project site is

to combine the suitability factors for the individual environmental attributes into a single factor for each project site. This overall suitability factor is an estimate of the probability of a project's successful development, considering only the attributes identified in Table 2 and their effects on site development. The project environmental suitability factors will be used to predict the contribution that each individual project makes to the aggregate potential energy supply for a state or region.

The overall suitability factor is a function of the suitability factors for the individual

environmental attributes. The presence of more than one environmental attribute means that more than one environmental concern affects a project. *The overall suitability factor should obviously be no greater than the lowest factor for individual attributes, and it should be less than the lowest factor if multiple significant environmental constraints are present.* For example, if an undeveloped project has both fish values (suitability factor = 0.25) and recreation values (suitability factor = 0.25), the cumulative effects of these two concerns will make its overall suitability even less than 0.25; so an overall suitability factor of 0.1 is assigned.

If the environmental suitability factors for individual environmental attributes were truly the probability of the project's being developed, then the overall probability of development could be mathematically calculated. And, if the individual suitability factors were true and independent probabilities, then the probability of

developing the project site because of environmental concerns would be equal to the product of all the individual factors. However, FERC's licensing process is not a statistical probability function, and it cannot be assumed that suitability factors can be handled as independent probabilities (for example, there is a strong correlation between the scenic, recreational, and fishing values of a stream). In addition, environmental attributes not considered by HES would bias the value of the overall suitability factor if it were calculated as a probability.

The procedure outlined in Table 3 is used for assigning overall suitability factors. This procedure assumes that the lowest suitability factor dominates the likelihood of a project's development. However, it also considers the reduced likelihood of development resulting from the occurrence of multiple low suitability factors.

Table 3. Overall project suitability factor computation.

Individual Environmental Suitability Factors	Project Suitability Factors
No environmental attributes assigned	0.90
Lowest individual factor(s) = 0.90	0.90
Lowest individual factor = 0.75	0.75
Two or more lowest individual factors = 0.75	0.50
Lowest individual factor = 0.50	0.50
Two or more lowest individual factors = 0.50	0.25
Lowest individual factor = 0.25	0.25
Two or more lowest individual factors = 0.25	0.10
Lowest individual factor(s) = 0.10	0.10

LIMITATIONS AND APPLICABILITY

HES is not intended to model the likelihood of development of any specific hydropower project. To perform this function, HES would have had to encompass the many site-specific factors affecting a distinctive site. With so many unique sites in the nation, an unmanageable number of single-site-specific attributes would be required; the database and software would become burdensome and unmanageable, and it would fail to provide a uniform nationwide evaluation. In the Pacific Northwest, for instance, if HES incorporated single-site-specific criteria it would have included any outcomes from the "Salmon Summit," the attempt to aid the migration of salmon and steelhead. This consideration would have been unique to the Northwest area only, not to the majority of the United States. Additionally, if a single state decreed that there would be no additional hydropower development within its boundaries, HES would fail in its mission if it included an

attribute unique to that single state but not pertinent to the remaining 49 states. If there is significant state opposition, it will most likely be based on factors such as fish and recreation values, which HES is designed to model; and if the site is undeveloped and fish and recreation values are present, then HES would assign an overall project suitability factor of 0.1. Tests conducted with the Southwestern Power Administration, and through them several states, indicated that HES does satisfactorily model local concerns affecting hydropower development when environmental, legal, and institutional constraints to development are present. The model provides a uniform evaluation of hydropower capacity, and it should be used to accumulate regional capacity, not individual project capacity. Summing the regional totals provides a national total of the undeveloped hydropower resources available.

ASSESSMENT PROCESS AND ASSUMPTIONS

The assessment process uses a logical extraction of data from the two primary data sources discussed previously: the Nationwide Rivers Inventory and the HPRA databases. The basic site data is relatively easy to download. However, extracting the environmental attributes data is somewhat tedious because of the cross-referencing needed between the two database sources and the interpretation of narrative descriptions of outstanding environmental attributes.

Environmental attributes for sites on river reaches listed in the Nationwide Rivers Inventory can be assigned several ways. The first and simplest is to assign the environmental attributes of a Nationwide Rivers Inventory reach to any undeveloped hydropower project that is located in the same state and county and on the same river that is listed in the Nationwide Rivers Inventory. This method relies on the state, county, and river identifiers in the HPRA database for location; these identifiers are unlikely to be inaccurate.

A second method for assigning Nationwide Rivers Inventory attributes to projects is to (a) use the river mile designations for Nationwide Rivers Inventory reaches to locate the reaches on FERC river basin maps, (b) use the Geographic Information System to map the projects at the same scale, and (c) overlay the

project maps on the Nationwide Rivers Inventory reach maps to see which projects fall on Nationwide Rivers Inventory reaches. This method is potentially more accurate since only the projects actually on the Nationwide Rivers Inventory reach would be identified. Sites within a specified distance upstream or downstream of the Nationwide Rivers Inventory reach could also be identified and assigned the environmental attributes of the Nationwide Rivers Inventory reach. The main disadvantage of this method is that it uses the latitude-longitude coordinates of projects from the HPRA database, which are occasionally missing or inaccurate. For this and other reasons, the first method was used. The first method also ensures that any upstream or downstream impacts from development are also considered.

The application of suitability factors is straightforward once all of the environmental attributes have been identified. One simply follows the specifications in Table 2.

The underlying assumption in the evaluation process is that the suitability factors being assigned to environmental attributes represent the degree to which these attributes will decrease the likelihood of developing a site. One must also assume that the combination of suitability factors is not multiplicative but can be represented by the weighing scheme shown in Table 3.

SUMMARY OF COMPLETED HYDROPOWER RESOURCE ASSESSMENT

This status report discusses the undeveloped hydropower capacity within the United States. The hydropower resource assessment utilized the Hydropower Evaluation Software (HES).

As stated in the Abstract, the Southwestern Power Administration was used for model testing. The six states in this power marketing administration are Arkansas, Kansas, Louisiana, Missouri, Oklahoma, and Texas. The remaining 44 states have also been assessed. The information for the resource assessment was obtained primarily from FERC's Hydroelectric Power Resources Assessment database and the National Park Service's National Rivers Inventory database. Input was also obtained from individual state agencies regarding the undeveloped hydropower capacity and the natural resources present within their respective states. Note, Delaware was not asked to participate due to only one site reported in Delaware.

The goal of HES is to ensure that a set of uniform criteria is used to determine the viable national hydropower capacity. Undeveloped hydropower is not limited to that which could be developed at new sites; it also includes power that could be produced at sites that currently have hydropower but are not developed to their full capacity. This criterion includes environmental, legal, and institutional attributes. These attributes can include (1) scenic, cultural, historical, and geological values; (2) Federal and state land-use, which includes parks, wildlife preserves, recreation areas, forests, wilderness areas, scenic waterways, and military or Indian reservations; and (3) legal protection issues such as Wild and Scenic legislation, and Threatened or Endangered Fish and Wildlife legislative protection.

The amount that each attribute affects the likelihood of development depends on the physical state of a site. HES assumes that a site

can have one of three development states. These are (a) completely undeveloped with no structures present; (b) developed site without power—some type of civil structure such as a dam, weir, or abandoned power plant may be present, but there is no power being generated; or (c) ongoing power generation with additional undeveloped capacity.

Using the hydropower summary report menu feature of HES, the 50 states are summarized in Table 4. Figures 2 through 7 elaborate on the capacity adjustments presented in Table 4. The figures show that HES will adjust the undeveloped capacity downward due to the effects of environmental, legal, and institutional attributes. The figures also demonstrate the wide variation in the number of sites and the undeveloped capacities that are unique to each state.

Figures 2 and 3 summarize the number of potential hydropower sites in each of the 50 states, based on environmental and legal conditions existing as of 1998 or earlier. The number of sites does not change after HES adjustments are made. California has the highest total number of sites (763) and the most undeveloped sites (463), and Delaware has the fewest sites (1). Wisconsin has the largest number of developed sites (46) that also have additional undeveloped hydropower capacity. While Delaware, Florida, Louisiana, Mississippi, New Hampshire, New Jersey, Rhode Island, Tennessee, West Virginia, and Wyoming do not have any sites with existing power production that are not already developed to their full capacity. The total number of sites for the 50 states is 5,677. Developed sites with existing power (389) account for about 7% of the total number of sites while there are 2,527 developed sites without power, and 2,761 undeveloped sites.

Table 4. Hydropower capacity summary modeled by HES.

State	Category	Number Of Projects	Name Plate Capacity (MW)	HES Adjusted Capacity (MW)
Alabama	With Power	4	71	35
	W/O Power	21	281	216
	<u>Undeveloped</u>	<u>8</u>	<u>146</u>	<u>112</u>
	State Total	33	498	363
Alaska	With Power	3	65	58
	W/O Power	60	2,866	1,610
	<u>Undeveloped</u>	<u>56</u>	<u>1,111</u>	<u>490</u>
	State Total	119	4,042	2,158
Arizona	With Power	2	207	157
	W/O Power	6	51	15
	<u>Undeveloped</u>	<u>13</u>	<u>1,552</u>	<u>166</u>
	State Total	21	1,810	338
Arkansas	With Power	13	193	174
	W/O Power	28	378	332
	<u>Undeveloped</u>	<u>20</u>	<u>638</u>	<u>231</u>
	State Total	61	1,209	737
California	With Power	26	1,745	653
	W/O Power	274	4,812	1,894
	<u>Undeveloped</u>	<u>463</u>	<u>3,834</u>	<u>843</u>
	State Total	763	10,391	3,390
Colorado	With Power	5	156	78
	W/O Power	91	782	377
	<u>Undeveloped</u>	<u>155</u>	<u>1,408</u>	<u>209</u>
	State Total	251	2,346	664

Table 4. (continued).

State	Category	Number Of Projects	Name Plate Capacity (MW)	HES Adjusted Capacity (MW)
Connecticut	With Power	3	21	11
	W/O Power	50	27	14
	<u>Undeveloped</u>	<u>15</u>	<u>191</u>	<u>19</u>
	State Total	68	239	44
Delaware	With Power	0	0	0
	W/O Power	1	0.18	0.02
	<u>Undeveloped</u>	<u>0</u>	<u>0</u>	<u>0</u>
	State Total	1	0.18	0.02
Florida	With Power	0	0	0
	W/O Power	8	49	34
	<u>Undeveloped</u>	<u>5</u>	<u>12</u>	<u>9</u>
	State Total	13	61	43
Georgia	With Power	7	145	89
	W/O Power	31	717	486
	<u>Undeveloped</u>	<u>24</u>	<u>275</u>	<u>37</u>
	State Total	62	1,137	612
Hawaii	With Power	1	3	3
	W/O Power	7	20	13
	<u>Undeveloped</u>	<u>17</u>	<u>406</u>	<u>52</u>
	State Total	25	429	68
Idaho	With Power	14	1,003	504
	W/O Power	86	541	447
	<u>Undeveloped</u>	<u>273</u>	<u>6,169</u>	<u>704</u>
	State Total	373	7,713	1,655

Table 4. (continued).

State	Category	Number Of Projects	Name Plate Capacity (MW)	HES Adjusted Capacity (MW)
Illinois	With Power	9	80	41
	W/O Power	35	457	242
	<u>Undeveloped</u>	<u>5</u>	<u>58</u>	<u>18</u>
	State Total	49	595	301
Indiana	With Power	3	16	8
	W/O Power	24	51	34
	<u>Undeveloped</u>	<u>3</u>	<u>17</u>	<u>2</u>
	State Total	30	84	44
Iowa	With Power	7	115	61
	W/O Power	69	310	219
	<u>Undeveloped</u>	<u>3</u>	<u>30</u>	<u>25</u>
	State Total	79	455	305
Kansas	With Power	1	0.06	0.03
	W/O Power	12	53	45
	<u>Undeveloped</u>	<u>5</u>	<u>100</u>	<u>38</u>
	State Total	18	153	83
Kentucky	With Power	1	19	10
	W/O Power	46	851	425
	<u>Undeveloped</u>	<u>4</u>	<u>43</u>	<u>4</u>
	State Total	51	913	439
Louisiana	With Power	0	0	0
	W/O Power	14	78	67
	<u>Undeveloped</u>	<u>8</u>	<u>148</u>	<u>133</u>
	State Total	22	226	200

Table 4. (continued).

State	Category	Number Of Projects	Name Plate Capacity (MW)	HES Adjusted Capacity (MW)
Maine	With Power	24	83	47
	W/O Power	74	1,069	768
	<u>Undeveloped</u>	<u>269</u>	<u>554</u>	<u>227</u>
	State Total	367	1,706	1,042
Maryland	With Power	1	196	20
	W/O Power	32	32	10
	<u>Undeveloped</u>	<u>3</u>	<u>1</u>	<u>0.10</u>
	State Total	36	229	30
Massachusetts	With Power	12	28	14
	W/O Power	87	118	62
	<u>Undeveloped</u>	<u>31</u>	<u>179</u>	<u>56</u>
	State Total	130	325	132
Michigan	With Power	11	25	17
	W/O Power	53	459	354
	<u>Undeveloped</u>	<u>22</u>	<u>129</u>	<u>18</u>
	State Total	86	613	389
Minnesota	With Power	12	98	72
	W/O Power	21	73	51
	<u>Undeveloped</u>	<u>7</u>	<u>55</u>	<u>14</u>
	State Total	40	226	137
Mississippi	With Power	0	0	0
	W/O Power	13	81	62
	<u>Undeveloped</u>	<u>6</u>	<u>47</u>	<u>29</u>
	State Total	19	128	91

Table 4. (continued).

State	Category	Number Of Projects	Name Plate Capacity (MW)	HES Adjusted Capacity (MW)
Missouri	With Power	6	116	104
	W/O Power	12	203	181
	<u>Undeveloped</u>	<u>11</u>	<u>378</u>	<u>38</u>
	State Total	29	697	323
Montana	With Power	7	470	235
	W/O Power	72	1,129	502
	<u>Undeveloped</u>	<u>79</u>	<u>2,073</u>	<u>277</u>
	State Total	158	3,672	1,014
Nebraska	With Power	3	46	28
	W/O Power	23	117	62
	<u>Undeveloped</u>	<u>19</u>	<u>182</u>	<u>59</u>
	State Total	45	345	149
Nevada	With Power	9	5	4
	W/O Power	48	41	31
	<u>Undeveloped</u>	<u>124</u>	<u>80</u>	<u>32</u>
	State Total	181	126	67
New Hampshire	With Power	0	0	0
	W/O Power	63	51	25
	<u>Undeveloped</u>	<u>34</u>	<u>65</u>	<u>7</u>
	State Total	97	116	32
New Jersey	With Power	0	0	0
	W/O Power	9	6	5
	<u>Undeveloped</u>	<u>3</u>	<u>5</u>	<u>4</u>
	State Total	12	11	9

Table 4. (continued).

State	Category	Number Of Projects	Name Plate Capacity (MW)	HES Adjusted Capacity (MW)
New Mexico	With Power	2	11	6
	W/O Power	12	48	24
	<u>Undeveloped</u>	<u>8</u>	<u>31</u>	<u>5</u>
	State Total	22	90	35
New York	With Power	44	286	162
	W/O Power	212	754	495
	<u>Undeveloped</u>	<u>96</u>	<u>1,079</u>	<u>652</u>
	State Total	352	2,119	1,309
North Carolina	With Power	6	16	14
	W/O Power	57	594	369
	<u>Undeveloped</u>	<u>30</u>	<u>848</u>	<u>125</u>
	State Total	93	1,458	508
North Dakota	With Power	2	86	43
	W/O Power	10	13	7
	<u>Undeveloped</u>	<u>2</u>	<u>0.04</u>	<u>0.04</u>
	State Total	14	99	50
Ohio	With Power	1	2	1
	W/O Power	33	183	138
	<u>Undeveloped</u>	<u>9</u>	<u>57</u>	<u>44</u>
	State Total	43	242	183
Oklahoma	With Power	9	274	179
	W/O Power	18	78	68
	<u>Undeveloped</u>	<u>6</u>	<u>190</u>	<u>94</u>
	State Total	33	542	341

Table 4. (continued).

State	Category	Number Of Projects	Name Plate Capacity (MW)	HES Adjusted Capacity (MW)
Oregon	With Power	3	45	11
	W/O Power	101	2,549	1,916
	<u>Undeveloped</u>	<u>118</u>	<u>950</u>	<u>318</u>
	State Total	222	3,544	2,245
Pennsylvania	With Power	5	207	105
	W/O Power	67	310	187
	<u>Undeveloped</u>	<u>32</u>	<u>1,701</u>	<u>411</u>
	State Total	104	2,218	703
Rhode Island	With Power	0	0	0
	W/O Power	27	12	10
	<u>Undeveloped</u>	<u>3</u>	<u>2</u>	<u>1</u>
	State Total	30	14	11
South Carolina	With Power	2	6	3
	W/O Power	31	855	444
	<u>Undeveloped</u>	<u>16</u>	<u>273</u>	<u>33</u>
	State Total	49	1,134	480
South Dakota	With Power	5	569	285
	W/O Power	25	548	405
	<u>Undeveloped</u>	<u>3</u>	<u>6</u>	<u>5</u>
	State Total	33	1,123	695
Tennessee	With Power	0	0	0
	W/O Power	11	20	10
	<u>Undeveloped</u>	<u>11</u>	<u>476</u>	<u>128</u>
	State Total	22	496	138

Table 4. (continued).

State	Category	Number Of Projects	Name Plate Capacity (MW)	HES Adjusted Capacity (MW)
Texas	With Power	23	56	46
	W/O Power	26	164	140
	<u>Undeveloped</u>	<u>40</u>	<u>1,014</u>	<u>832</u>
	State Total	89	1,234	1,018
Utah	With Power	8	48	8
	W/O Power	69	900	414
	<u>Undeveloped</u>	<u>245</u>	<u>990</u>	<u>472</u>
	State Total	322	1,938	894
Vermont	With Power	29	69	32
	W/O Power	70	261	130
	<u>Undeveloped</u>	<u>50</u>	<u>90</u>	<u>12</u>
	State Total	149	420	174
Virginia	With Power	9	16	12
	W/O Power	52	690	376
	<u>Undeveloped</u>	<u>27</u>	<u>544</u>	<u>229</u>
	State Total	88	1,250	617
Washington	With Power	11	1,033	875
	W/O Power	238	3,373	1,777
	<u>Undeveloped</u>	<u>313</u>	<u>3,069</u>	<u>762</u>
	State Total	562	7,475	3,414
West Virginia	With Power	0	0	0
	W/O Power	27	1,597	1,002
	<u>Undeveloped</u>	<u>10</u>	<u>328</u>	<u>147</u>
	State Total	37	1,925	1,149

Table 4. (continued).

State	Category	Number Of Projects	Name Plate Capacity (MW)	HES Adjusted Capacity (MW)
Wisconsin	With Power	46	190	111
	W/O Power	35	53	16
	<u>Undeveloped</u>	<u>21</u>	<u>210</u>	<u>26</u>
	State Total	102	453	153
Wyoming	With Power	0	0	0
	W/O Power	36	920	487
	<u>Undeveloped</u>	<u>36</u>	<u>708</u>	<u>317</u>
	State Total	72	1,628	804
Totals	With Power	389	7,820	4,316
	W/O Power	2,527	29,625	16,998
	<u>Undeveloped</u>	<u>2,761</u>	<u>32,452</u>	<u>8,466</u>
	Grand Total	5,677	69,897	29,780




Figure 2. Number of sites with undeveloped hydropower capacity by state for Alabama through Missouri.




Figure 3. Number of sites with undeveloped hydropower capacity by state for Montana through Wyoming.

Figures 4 and 5 summarize the nonmodeled (unadjusted) and the HES-modeled (adjusted) total undeveloped hydropower capacity. California has the highest unadjusted undeveloped capacity, and Washington has the highest undeveloped capacity after adjustment for environmental attributes using HES. California also has the largest adjustment decrease (7,001 MW). Delaware and New Jersey show the smallest capacity decreases of 0.16 MW and 2 MW, respectively. Delaware also remains the state with the least undeveloped capacity with or without modeling. The unadjusted undeveloped hydropower capacity total for the 50 states is 69,897 MW. HES results lowers this estimate about 57% to 29,780 MW.

Figure 6 compares unadjusted and adjusted total undeveloped hydropower capacity by site status. As expected by the probability-weighting

scheme, the capacity associated with an undeveloped site has the largest reduction from 32,452 to 8,466 MW, or a loss of 23,986 MW (74%). Developed sites with power (389 sites) have a reduction in undeveloped capacity from 7,820 MW to 4,316 MW, or a loss of 3,504 MW (45%). Developed sites without power (2,527 sites) have a reduction from 29,625 MW to 16,998 MW, or a loss of 12,627 MW (43%). Developed sites without power have the greatest overall capacity after adjustment (16,998 MW). The additional hydropower capacity for developed sites with current power generation remains considerably less (4,316 MW).

As shown in Figure 7, the majority of the hydropower sites (53% or 2,990) are located within seven states: California, Colorado, Idaho, Maine, New York, Utah, and Washington; five of those states are in the western United States.




Figure 4. Total undeveloped hydropower capacity by state for Alabama through Missouri.




Figure 5. Total undeveloped hydropower capacity by state for Montana through Wyoming.




Figure 6. Total undeveloped hydropower capacity by site status.

Table 5 identifies the percent of the original undeveloped hydropower capacity that remains after HES is applied. Louisiana has the greatest percentage (89%) of the undeveloped hydropower capacity remaining for

development, while Delaware and Maryland have the least remaining original capacity. Many (25) of the states have greater than 50% of the original hydropower capacity remaining for development after HES model is applied.




Figure 7. Location of the majority of hydropower sites by state, reported as a percentage of the total number of sites.

Table 5. The percent of the original undeveloped hydropower capacity that remains after HES is applied.

State	Sites	Modeled Capacity (MW)	Nonmodeled Capacity (MW)	Percent of Original
AK	119	2,158	4,042	53.39%
AL	33	363	498	72.89%
AR	61	737	1,209	60.96%
AZ	21	338	1,810	18.67%
CA	763	3,390	10,391	32.62%
CT	68	44	239	18.41%
CO	251	664	2,346	28.30%
DE	1	0.02	0.18	11.11%
FL	13	43	61	70.49%
GA	62	612	1,137	53.83%

Table 5. (continued).

State	Sites	Modeled Capacity (MW)	Nonmodeled Capacity (MW)	Percent of Original
HI	25	68	429	15.85%
IA	79	305	455	67.03%
ID	373	1,655	7,713	21.46%
IL	49	301	595	50.59%
IN	30	44	84	52.38%
KS	18	83	153	54.25%
KY	51	439	913	48.08%
LA	22	200	226	88.50%
MA	130	132	325	40.62%
MD	36	30	229	13.10%
ME	367	1,042	1,706	61.08%
MI	86	389	613	63.46%
MN	40	137	226	60.62%
MO	29	323	697	46.34%
MS	19	91	128	71.09%
MT	158	1,014	3,672	27.61%
NC	93	508	1,458	34.84%
ND	14	50	99	50.51%
NE	45	149	345	43.19%
NH	97	32	116	27.59%
NJ	12	9	11	81.82%
NM	22	35	90	38.89%
NV	181	67	126	53.17%
NY	352	1,309	2,119	61.77%
OH	43	183	242	75.62%
OK	33	341	542	62.92%
OR	222	2,245	3,544	63.35%
PA	104	703	2,218	31.70%
RI	30	11	14	78.57%
SC	49	480	1,134	42.33%
SD	33	695	1,123	61.89%
TN	22	138	496	27.82%

Table 5. (continued).

State	Sites	Modeled Capacity (MW)	Nonmodeled Capacity (MW)	Percent of Original
TX	89	1,018	1,234	82.50%
UT	322	894	1,938	46.13%
VA	88	617	1,250	49.36%
VT	149	174	420	41.43%
WA	562	3,414	7,475	45.67%
WI	102	153	453	33.77%
WV	37	1,149	1,925	59.69%
WY	72	804	1,628	49.39%
Totals	5,677	29,780	69,897	42.61%

CONCLUSIONS

The trend for hydropower development is downward because of current environmental attributes and legal and institutional constraints. After loading hydropower data for the states into HES and checking the data with the respective states, the analysis indicates that undeveloped hydropower capacity will drop by about 43%. The greatest decrease for any state is always at undeveloped sites. However, with the development of new technologies (e.g., environmentally friendly turbines, ultra-low head turbines), or changes in the energy picture (e.g., another oil crisis), hydropower production could increase.

The results of the HES are obtained in a viable, low-cost manner and can be used by

developers as a preliminary means for identifying developable sites. These results provide a peerless means for identifying the undeveloped hydropower capacity essential for continued energy growth, which in turn is necessary for the continued economic strength of the United States.

Application of HES to current data significantly reduces state and regional totals for undeveloped hydropower capacity. However, an abundance of potential sites remain that are likely to be developed, given the current environmental awareness and geopolitical constraints. Strategies may need to be formulated to further assess those sites with the most potential for development.

OBTAINING INDIVIDUAL STATE INFORMATION

The HES results for the 49 states^a can be obtained by accessing DOE's Hydropower Program homepage on the Internet at www.inel.gov/national/hydropower/index.html, writing or calling the authors, or calling the National Technical Information Service (NTIS). Hydropower Evaluation Software can be obtained by contacting the authors. Reports of DOE-sponsored projects or reports received on foreign exchange agreements can be ordered from Oak Ridge, Tennessee. Reports are available in paper, microfiche, computer disks, and magnetic tape formats.

Telephone Orders. (703) 487-4650.

NTIS sales desk and customer services are available between 8:30 a.m. and 5:00 p.m., Eastern Standard Time.

Fax. (703) 321-8547. Customers may fax their orders to NTIS. These orders may be charged to an NTIS deposit account, American Express, VISA, or MasterCard.

Email. Customers mail email their requests to info@ntis.fedworld.gov.

Mail Orders. Mail orders should be sent to National Technical Information Service, Document Sales, 5285 Port Royal Road, Springfield, VA 22161. Call the sales desk [(703)487-4650] for prices before placing an order.

Method of Payment. Customers may pay for reports (and other NTIS products and services) by (a) credit card (American

Express, Visa, or MasterCard); (b) check or money order on a United States bank payable to NTIS; (c) an NTIS deposit account; or (d) in the United States, Canada, and Mexico, by asking to be billed (add \$7.50 per order).

Handling Fee. A \$3.00 handling fee per total order applies to orders from the United States, Canada, and Mexico. Handling charges do not apply to rush order service or pick-up orders.

Postage and Shipping. Orders are shipped first class mail, or equivalent, to addresses in the United States, Canada, and Mexico.

Order Turnaround Time. Technical reports are generally shipped within 2 to 8 days after the order is received. For faster service, NTIS offers rush order service.

Rush Order Service. Call 1-800-533-NTIS. In Virginia, Canada, and Mexico call (703) 487-4700. For NTIS rush order service add \$15.00 per item. This guarantees that an order will be processed through NTIS within 24 hours of its receipt. These orders receive immediate, individual attention. The items ordered are delivered by first class mail. Call NTIS for information on rush order service for computer products.

For Help Tracing an Order. Call (703)487-4650 and request the customer service option.

^a Delaware was not included because of few hydropower resources.

ADDITIONAL HYDROPOWER EVALUATION SOFTWARE INFORMATION

Additional information concerning HES can be obtained by contacting Alison Conner, Jim Francfort, or Ben Rinehart at the addresses provided below. Copies of the software and the User's Manual may also be obtained from these individuals.

Alison Conner
Idaho National Engineering and Environmental
Laboratory
P. O. Box 1625, MS 3634
Idaho Falls, ID 83415-3634
phone: (208) 526-7799
fax: (208) 526-8861

Jim Francfort
Idaho National Engineering and Environmental
Laboratory
P.O. Box 1625, MS 3830
Idaho Falls, ID 83415-3830
phone: (208) 526-6787
fax: (208) 526-0969

Ben Rinehart, Project Manager
Idaho National Engineering and Environmental
Laboratory
P.O. Box 1625, MS 3830
Idaho Falls, ID 83415-3830
phone: (208) 526-1002
fax: (208) 526-0969

REFERENCES

- Conner, Alison M., James E. Francfort, 1998, *U.S. Hydropower Resource Assessment for Alabama*, Idaho National Engineering and Environmental Laboratory, DOE/ID-10430(AL).
- Conner, Alison M., James E. Francfort, 1997, *U.S. Hydropower Resource Assessment for Alaska*, Idaho National Engineering and Environmental Laboratory, DOE/ID-10430(AK).
- Conner, Alison M., James E. Francfort, 1997, *U.S. Hydropower Resource Assessment for Arizona*, Idaho National Engineering and Environmental Laboratory, DOE/ID-10430(AZ).
- Conner, Alison M., James E. Francfort, 1998, *U.S. Hydropower Resource Assessment for California*, Idaho National Engineering and Environmental Laboratory, DOE/ID-10430(CA).
- Conner, Alison M., James E. Francfort, 1998, *U.S. Hydropower Resource Assessment for Florida*, Idaho National Engineering and Environmental Laboratory, DOE/ID-10430(FL).
- Conner, Alison M., James E. Francfort, 1997, *U.S. Hydropower Resource Assessment for Georgia*, Idaho National Engineering and Environmental Laboratory, DOE/ID-10430(GA).
- Conner, Alison M., James E. Francfort, 1996, *U.S. Hydropower Resource Assessment for Hawaii*, Idaho National Engineering Laboratory, DOE/ID-10430(HI).
- Conner, Alison M., James E. Francfort, 1997, *U.S. Hydropower Resource Assessment for Idaho*, Idaho National Engineering and Environmental Laboratory, DOE/ID-10430(ID).
- Conner, Alison M., James E. Francfort, 1997, *U.S. Hydropower Resource Assessment for Illinois*, Idaho National Engineering Laboratory, DOE/ID-10430(IL).
- Conner, Alison M., James E. Francfort, 1997, *U.S. Hydropower Resource Assessment for Kentucky*, Idaho National Engineering and Environmental Laboratory, DOE/ID-10430(KY).
- Conner, Alison M., James E. Francfort, 1997, *U.S. Hydropower Resource Assessment for Maryland*, Idaho National Engineering and Environmental Laboratory, DOE/ID-10430(MD).
- Conner, Alison M., James E. Francfort, 1998, *U.S. Hydropower Resource Assessment for Michigan*, Idaho National Engineering and Environmental Laboratory, DOE/ID-10430(MI).
- Conner, Alison M., James E. Francfort, 1996, *U.S. Hydropower Resource Assessment for Minnesota*, Idaho National Engineering Laboratory, DOE/ID-10430(MN).
- Conner, Alison M., James E. Francfort, 1997, *U.S. Hydropower Resource Assessment for Mississippi*, Idaho National Engineering and Environmental Laboratory, DOE/ID-10430(MS).
- Conner, Alison M., James E. Francfort, 1997, *U.S. Hydropower Resource Assessment for Nebraska*, Idaho National Engineering Laboratory, DOE/ID-10430(NE).
- Conner, Alison M., James E. Francfort, 1997, *U.S. Hydropower Resource Assessment for Nevada*, Idaho National Engineering and Environmental Laboratory, DOE/ID-10430(NV).

- Conner, Alison M., James E. Francfort, 1996, *U.S. Hydropower Resource Assessment for New Jersey*, Idaho National Engineering Laboratory, DOE/ID-10430(NJ).
- Conner, Alison M., James E. Francfort, 1997, *U.S. Hydropower Resource Assessment for New Mexico*, Idaho National Engineering Laboratory, DOE/ID-10430(NM).
- Conner, Alison M., James E. Francfort, 1997, *U.S. Hydropower Resource Assessment for New York*, Idaho National Engineering and Environmental Laboratory, DOE/ID-10430(NY).
- Conner, Alison M., James E. Francfort, 1997, *U.S. Hydropower Resource Assessment for North Carolina*, Idaho National Engineering Laboratory, DOE/ID-10430(NC).
- Conner, Alison M., James E. Francfort, 1997, *U.S. Hydropower Resource Assessment for Ohio*, Idaho National Engineering and Environmental Laboratory, DOE/ID-10430(OH).
- Conner, Alison M., James E. Francfort, 1998, *U.S. Hydropower Resource Assessment for Oregon*, Idaho National Engineering and Environmental Laboratory, DOE/ID-10430(OR).
- Conner, Alison M., James E. Francfort, 1997, *U.S. Hydropower Resource Assessment for Pennsylvania*, Idaho National Engineering and Environmental Laboratory, DOE/ID-10430(PA).
- Conner, Alison M., James E. Francfort, 1997, *U.S. Hydropower Resource Assessment for South Carolina*, Idaho National Engineering Laboratory, DOE/ID-10430(SC).
- Conner, Alison M., James E. Francfort, 1997, *U.S. Hydropower Resource Assessment for Tennessee*, Idaho National Engineering and Environmental Laboratory, DOE/ID-10430(TN).
- Conner, Alison M., James E. Francfort, 1996, *U.S. Hydropower Resource Assessment for Vermont*, Idaho National Engineering Laboratory, DOE/ID-10430(VT).
- Conner, Alison M., James E. Francfort, 1997, *U.S. Hydropower Resource Assessment for Virginia*, Idaho National Engineering and Environmental Laboratory, DOE/ID-10430(VA).
- Conner, Alison M., James E. Francfort, 1997, *U.S. Hydropower Resource Assessment for Washington*, Idaho National Engineering and Environmental Laboratory, DOE/ID-10430(WA).
- Conner, Alison M., James E. Francfort, 1998, *U.S. Hydropower Resource Assessment for West Virginia*, Idaho National Engineering and Environmental Laboratory, DOE/ID-10430(WV).
- Conner, Alison M., James E. Francfort, 1996, *U.S. Hydropower Resource Assessment for Wisconsin*, Idaho National Engineering Laboratory, DOE/ID-10430(WI).
- Conner, Alison M., James E. Francfort, and Ben N. Rinehart, 1996, *Uniform Criteria for U.S. Hydropower Resource Assessment, Hydropower Evaluation Software Status Report--II*, Idaho National Engineering Laboratory, DOE/ID-10430.1.
- Francfort, James E., Scott D. Matthews, and Bennie N. Rinehart, 1991, *Hydropower Evaluation Software User's Manual*, Idaho National Engineering Laboratory, DOE/ID-10338.

Francfort, James E., 1993, *U.S. Hydropower Resource Assessment for Arkansas*, Idaho National Engineering Laboratory, DOE/ID-10430(AR).

Francfort, James E., 1994, *U.S. Hydropower Resource Assessment for Colorado*, Idaho National Engineering Laboratory, DOE/ID-10430(CO).

Francfort, James E., 1995, *U.S. Hydropower Resource Assessment for Connecticut*, Idaho National Engineering Laboratory, DOE/ID-10430(CT).

Francfort, James E., 1995, *U.S. Hydropower Resource Assessment for Indiana*, Idaho National Engineering Laboratory, DOE/ID-10430(IN).

Francfort, James E., 1995, *U.S. Hydropower Resource Assessment for Iowa*, Idaho National Engineering Laboratory, DOE/ID-10430(IA).

Francfort, James E., 1993, *U.S. Hydropower Resource Assessment for Kansas*, Idaho National Engineering Laboratory, DOE/ID-10430(KS).

Francfort, James E., 1993, *U.S. Hydropower Resource Assessment for Louisiana*, Idaho National Engineering Laboratory, DOE/ID-10430(LA).

Francfort, James E., 1995, *U.S. Hydropower Resource Assessment for Maine*, Idaho National Engineering Laboratory, DOE/ID-10430(ME).

Francfort, James E., 1995, *U.S. Hydropower Resource Assessment for Massachusetts*, Idaho National Engineering Laboratory, DOE/ID-10430(MA).

Francfort, James E., 1993, *U.S. Hydropower Resource Assessment for Missouri*, Idaho National Engineering Laboratory, DOE/ID-10430(MO).

Francfort, James E., 1993, *U.S. Hydropower Resource Assessment for Montana*, Idaho National Engineering Laboratory, DOE/ID-10430(MT).

Francfort, James E., 1995, *U.S. Hydropower Resource Assessment for New Hampshire*, Idaho National Engineering Laboratory, DOE/ID-10430(NH).

Francfort, James E., 1993, *U.S. Hydropower Resource Assessment for North Dakota*, Idaho National Engineering Laboratory, DOE/ID-10430(ND).

Francfort, James E., 1993, *U.S. Hydropower Resource Assessment for Oklahoma*, Idaho National Engineering Laboratory, DOE/ID-10430(OK).

Francfort, James E., 1995, *U.S. Hydropower Resource Assessment for Rhode Island*, Idaho National Engineering Laboratory, DOE/ID-10430(RI).

Francfort, James E., 1993, *U.S. Hydropower Resource Assessment for South Dakota*, Idaho National Engineering Laboratory, DOE/ID-10430(SD).

Francfort, James E., 1993, *U.S. Hydropower Resource Assessment for Texas*, Idaho National Engineering Laboratory, DOE/ID-10430(TX).

Francfort, James E., 1993, *U.S. Hydropower Resource Assessment for Utah*, Idaho National Engineering Laboratory, DOE/ID-10430(UT).

Francfort, James E., 1993, *U.S. Hydropower Resource Assessment for Wyoming*, Idaho National Engineering Laboratory, DOE/ID-10430(WY).

Sale, M. J., 1990, *Hydropower Resources Study--Environmental Evaluation* (Draft), Oak Ridge National Laboratory, Environmental Sciences Division, Oak Ridge, Tennessee.

Appendix A

Basic Site Data

Appendix A

Basic Site Data

The INEEL obtained the basic site data for each of the undeveloped sites from FERC's Hydropower Resource Assessment database. The following data fields were copied into HES from the FERC database for each site. The names used are the actual structural names assigned to each field in the database. (Note: “_” is used in dBASE as a separator character.)

PROJNUM. The number assigned to each project by FERC. When a PROJNUM is not assigned for a project, the user is strongly encouraged to provide a pseudo number (see HES User's Manual).

PLANT_NM. Name of the project.

STREAM. Name of the stream where the project is located.

STATE_NM. Name of the state where the project is located.

LAT_U. The latitude of the site.

LONG_U. The longitude of the site.

CLASS_C. The owner class code:

C = Cooperative

F = Federal

I = Industrial

M = Municipal and other nonfederal

P = Private utility

R = Private nonutility.

OWNER_NM. Name of the project owner.

KWRATE_P. The estimated potential nameplate rating (kW) of the project assigned by the Hydropower Resource Assessment database. This is not the current capacity at a developed site. It is the undeveloped capacity at a site or the additional capacity of a site that already has power generation capability.

GEN_AA_P. The potential Average Annual Generation (MWh) of a site estimated by Hydropower Resource Assessment database. This is not the current average annual generation at a developed site but the undeveloped capacity average annual generation at a site or the additional average annual generation of a site that already has power generation capability.

UNITYP_P. Type of unit:

C = Conventional

R = Reversible

Z = Missing.

PLANTTYP. The project type or type of operation:

CMB = Combined conventional and reversible units

DIV = Gravity diversion (powerhouse on different stream)

PDV = Pumped diversion (one-way pumped storage)

PMP = Pure (recycled) pump storage

RES = Reservoir only

ROR = Run-of-river (dam 10 ft high with minimal storage)

RRG = Reregulating

STG = Storage, conventional (dam > 10 ft high with significant storage)

TID = Tidal conventional hydropower.

STATUS_C. Project status code:

DJ = Disclaimer of FERC jurisdiction

EA = Exemption applied for

FA = Federally authorized

FR = Federally recommended

LE = License exception

LJ = Lack of FERC jurisdiction

MA = FERC major license application

MO = FERC major license outstanding

NA = FERC minor license application

NO = FERC minor license outstanding

PA = FERC preliminary permit application

PO = FERC preliminary permit outstanding

XX = No status

YO = FERC minor part license outstanding

ZZ = Missing.

BASIN_NM. The river basin where the project is located.

CNTY_NM. The county where the project is located.

Not all of the above 15 variables are present for each site in the Hydropower Resource Assessment database, and the information the database provided was not always accurate. Various state agencies and INEEL personnel reviewed the information in an effort to ensure the accuracy of the site information.

ATTACHMENT D1
GEOTHERMAL ENERGY ASSOCIATION
“ALL ABOUT GEOTHERMAL ENERGY – BASICS”
(NO DATE)

Geothermal Energy Association

“All about Geothermal Energy – Basics”

(no date)



GEO THERMAL ENERGY ASSOCIATION

GEA MEMBERSHIP DATABASE TRADE SHOW GEA PUBLICATIONS INFORMATION

About GEA

Office Location

Staff

Geothermal Basics ▶

Industry Priorities

Member Access

ALL ABOUT GEOTHERMAL ENERGY - BASICS

What is geothermal energy?

What are the different ways in which geothermal energy can be used?

What more can you tell me about geothermal electric power plants?

What is a baseload resource?

What is "availability factor" and "capacity factor"?

Where can I find more detailed information about geothermal energy?

What is geothermal energy?

Geothermal energy is defined as heat from the Earth. It is a clean, renewable resource that provides energy in the United States and around the world. It is considered a renewable resource because the heat emanating from the interior of the Earth is essentially limitless. The heat continuously flowing from the Earth's interior is estimated to be equivalent to 42 million megawatts of power.⁽¹⁾ The interior of the Earth is expected to remain extremely hot for billions of years to come, ensuring an inexhaustible flow of heat.

What are the different ways in which geothermal energy can be used?

Geothermal energy can be used for electricity production, for direct use purposes, and for home heating efficiency (through geothermal heat pumps).

Geothermal electricity: To develop electricity from geothermal resources, wells are drilled into the natural hot water or steam, known as a geothermal reservoir. The reservoir collects many meters below the groundwater table. Wells bring the geothermal liquid to the surface, where it is converted at a power plant into electricity (see below for more information about the different types of geothermal electricity production).


Direct Use: Direct use applications utilize geothermal heat without first converting it to electricity, such as for space heating and cooling, food preparation, industrial processes, etc. People have been taking advantage of direct use applications for centuries, with documentation of early uses tracing back to ancient Roman times.

Geothermal Heat Pumps (GHPs): Geothermal heat pumps are devices that take advantage of the relatively constant temperature of the Earth's interior, using it as a source and sink of heat for both heating and cooling. When cooling, heat is extracted from the space and dissipated into the Earth; when heating, heat is extracted from the Earth and pumped into the space. Geothermal heat pumps can be used anywhere on Earth, and are considered by the EPA to be one of the most efficient heating and cooling systems available. For more information about GHPs, please visit www.geo-exchange.org.


What more can you tell me about geothermal electric power plants?

There are four widely used types of geothermal power plants, and three types that are more experimental at this time.


1) **Flash Power Plant:** Geothermal steam is separated in a surface vessel (steam separator) and delivered to the turbine, and the turbine powers a generator.



2) **Dry Steam Power Plant:** steam directly from the geothermal reservoir runs the turbines that power the generator, and no separation is necessary because wells only produce steam. The image below is a more simplified version than the image above.



3) **Binary Power Plant:** Recent advances in geothermal technology have made possible the economic production of electricity from lower temperature geothermal resources, at 100o C (212o F) to 150o C (302 o F). Known as binary geothermal plants, these facilities reduce geothermal energy's already low emission rate to near zero. In the binary process, the geothermal water heats another liquid, such as isobutane, that boils at a lower temperature than water. The two liquids are kept completely separate through the use of a heat exchanger used to transfer the heat energy from the geothermal water to the "working-fluid." The secondary fluid vaporizes into gaseous vapor and (like steam) the force of the expanding vapor turns the turbines that power the generators.



4) **Flash/Binary Combined Cycle:** This type of plant, which uses a combination of flash and binary technology, has been used effectively to take advantage of the benefits of both technologies. In this type of plant, the flashed steam is first converted to electricity with a backpressure steam turbine, and the low-pressure steam exiting the backpressure turbine is condensed in a binary system.

For more information about the above four types of power plants, access GEA's [Environmental Guide](#).

5) **Enhanced Geothermal System or Hot Dry Rock** (not commercial): Producing electricity from hot dry rock requires fracturing hot rocks, pumping water into and out of the hot rock, and generating electricity. Research applications of this technology are being pursued in the US, France, Australia, and elsewhere. They are not yet economically viable or even near-commercial.

6) **Kalina System:** A small demonstration powerplant using the "Kalina" cycle operated as part of Iceland's Husavik GeoHeat Project. The Kalina cycle uses an ammonia-water mixed working fluid that claims higher efficiency. This system is not considered commercial and reports on the demonstration are not available.

7) **Rankine Cycle System:** The U.S. Department of Energy is proposing to demonstrate a remote geothermal power system at Chena Hot Springs in Alaska using the Rankine Cycle. In this system, a compressor/motor module is expected to be converted into a turbogenerator by simply reversing the flow direction. This is a demonstration project, and this system is not considered commercial. (For more information about the Chena Hot Springs Project, click [here](#))

What is a baseload resource?

A baseload resource operates most efficiently at a relatively constant level of generation and is not limited by changes in weather patterns or other factors. Geothermal relies on a readily available, constant source of

heat for generation, and is therefore considered a baseload resource. Other resources such as coal, oil, and natural gas are also considered baseload resources.

Because some renewable energy sources can only operate under favorable weather conditions, they are often considered to be limited in their ability to meet the looming large-scale power needs of the twenty-first century. Geothermal, however, has the potential to provide reliable sources of electricity while still offering significantly lower emissions levels than fossil fuel sources and avoiding problems of radioactive waste disposal.

What is “availability factor” and “capacity factor”?

Availability factor is measured as the number of hours that a power plant is available to produce power divided by the total hours in a set time period, usually a year. Geothermal's availability factor is about 95 percent. This means that geothermal electric-power plants are available for generation 95 percent of any given time, based on decades of observations by plant operators.⁽²⁾

While availability factor measures a plant's potential for use, capacity factor measures the amount of real time during which a facility is used. To understand availability and capacity factor, consider the analogy of a working car. When a car is not in use, but is free from defects and available to be used, we may speak of the car's availability factor. When the car is actually being driven, we may speak of the car's capacity factor. Geothermal's capacity factor ranges from 89 to 97 percent, depending upon the type of geothermal system in place.

Where can I find more detailed information about geothermal energy?

The Geothermal Energy Association (GEA) has recently produced several updated, comprehensive documents on the issues of cost, employment, and the environment, all of which can be found at the GEA website. The environmental paper also includes more detailed basic information about geothermal energy. Click below to access the following links:

Factors Affecting Cost of Geothermal Power Development

Geothermal Industry Employment - Survey Results and Analysis September 2005

A Guide to Geothermal Energy & The Environment

If you are looking for a current update about geothermal energy, renewable energy, and global warming issues in the U.S., the world, and in our nation's capitol, take a look at GEA's latest Update.

For the truths behind common geothermal myths, take a look at our Mythbusters section.

For the list of useful links with more information and resources related to geothermal energy, click here.

(1) Energy and Geosciences Institute, University of Utah. Prepared by the U.S. Geothermal Industry for the Renewable Energy Task Force (1997), Briefing on Geothermal Energy. Washington, D.C.

(2) U.S. DOE. Energy and Geosciences Institute at University of Utah, (May 2001). Geothermal Energy: Clean Sustainable Energy for the Benefit of Humanity and the Environment. [Brochure].

Geothermal Energy Association - Washington, DC - USA

ATTACHMENT D2
U.S. DEPARTMENT OF ENERGY
ENERGY EFFICIENCY AND RENEWABLE ENERGY
GEOTHERMAL TECHNOLOGIES PROGRAM
“GEOTHERMAL POWER PLANTS”
JANUARY 2006

**U.S. Department of Energy
Energy Efficiency and Renewable Energy
Geothermal Technologies Program**

“Geothermal Power Plants”

January 2006



U.S. Department of Energy
Energy Efficiency and Renewable Energy

[EERE Home](#)

Geothermal Technologies Program

[About the Program](#) | [Program Areas](#) | [Information Resources](#) | [Financial Opportunities](#) | [Technologies](#) | [Deployment](#) | [Home](#)

[Search](#)
[Search Help](#) | [More Search Options](#)

[EERE Information Center](#)

Geothermal Basics

[Geothermal Resource Map](#)

[Research & Development](#)

[R&D Successes](#)

Applications

[Power Plants](#)

[Direct Use](#)

[Heat Pumps](#)


[Impacts](#)

[Laws & Standards](#)

[Printable Version](#)

Geothermal Power Plants

There are three



Geothermal power plant in the Imperial Valley, California.

geothermal power plant technologies being used to convert hydrothermal fluids to electricity. The conversion technologies are dry steam, flash, and binary cycle. The type of conversion used depends on the state of the fluid (whether steam or water) and its temperature. Dry steam power plants systems were the first type of geothermal power generation plants built. They use the steam from the geothermal reservoir as it comes from wells, and route it directly through turbine/generator units to produce electricity. Flash steam plants are the most common type of geothermal power generation plants in operation today. They use water at temperatures greater than 360°F (182°C) that is pumped under high pressure to the generation equipment at the surface. Binary cycle geothermal power generation plants differ from Dry Steam and Flash Steam systems in that the water or steam from the geothermal reservoir never comes in contact with the turbine/generator units.

U.S. Geothermal Power Plants

Power plant photographs

- [Casa Diablo](#)
- [Honey Lake](#)
- [Navy 1](#)
- [Imperial Valley](#)
- [The Geysers](#)
- [Nevada](#)
- [Hawaii](#)
- [Utah](#)

Dry Steam Power Plants

Steam


plants use hydrothermal fluids that are primarily steam. The steam goes directly to a turbine, which drives a generator that produces electricity. The steam eliminates the

need to burn fossil fuels to run the turbine. (Also eliminating the need to transport and store fuels!) This is the oldest type of




Dry steam power plants at The Geysers in California.

geothermal power plant. It was first used at Lardarello in Italy in 1904, and is still very effective. Steam technology is used today at The Geysers in northern California, the world's largest single source of geothermal power. These plants emit only excess steam and very minor amounts of gases.




Flash Steam Power Plants

Hydrothermal fluids above 360°F (182°C) can be used in flash plants to make electricity. Fluid is sprayed into a tank held at a much lower pressure than the fluid, causing some of the fluid to rapidly vaporize, or "flash." The vapor then drives a turbine, which drives a generator. If any liquid remains in the tank, it can be flashed again in a second tank to extract even more energy.



Binary-Cycle Power Plants

Most geothermal areas contain moderate-temperature water (below 400°F). Energy is extracted from these fluids in binary-cycle power plants. Hot geothermal fluid and a secondary (hence, "binary") fluid with a much lower boiling point than water pass through a heat exchanger. Heat from the geothermal fluid causes the secondary fluid to flash to vapor, which then drives the turbines. Because this is a closed-loop system, virtually nothing is emitted to the atmosphere. Moderate-temperature water is by far the more common geothermal resource, and most geothermal power plants in the future will be binary-cycle plants.



The Future of Geothermal Electricity

Steam and hot water reservoirs are just a small part of the geothermal resource. The Earth's magma and hot dry rock will provide cheap, clean, and almost unlimited energy as soon as we develop the technology to use them. In the meantime, because they're so abundant, moderate-temperature sites running binary-cycle power plants will be the most common electricity producers.

Before geothermal electricity can be considered a key element of the U.S. energy infrastructure, it must become cost-competitive with traditional forms of energy. The U.S. Department of Energy is working with the geothermal industry to achieve \$0.03 to \$0.05 per kilowatt-hour. We believe the result will be about 15,000 megawatts of new capacity within the next decade.

DOE Support

The U.S. Department of Energy recognizes the strategic value of geothermal electricity, and supports its development in several ways through its Geothermal Technology Development Program. First, it works with Congress to ensure support for geothermal energy and renewables in general. Second, it sponsors millions of dollars in research and development at national laboratories and universities. Investigators are working on issues in exploration, geochemistry, drilling, resource usage, and equipment operation. Third, through its GeoPowering the West initiative, it works with state and local officials and other stakeholders to identify and overcome regulatory and institutional barriers to geothermal power development.

 [Printable Version](#)

[Geothermal Technologies Program Home](#) | [EERE Home](#) | [U.S. Department of Energy](#)
[Webmaster](#) | [Web Site Policies](#) | [Security & Privacy](#) | [USA.gov](#)

Content Last Updated: 01/19/2006

ATTACHMENT D3
U.S. DEPARTMENT OF ENERGY
ENERGY EFFICIENCY AND RENEWABLE ENERGY
GEOTHERMAL TECHNOLOGIES PROGRAM
“U.S. GEOTHERMAL RESOURCE MAP”
JANUARY 2006

**U.S. Department of Energy
Energy Efficiency and Renewable Energy
Geothermal Technologies Program**

“U.S. Geothermal Resource Map”

January 2006



U.S. Department of Energy
Energy Efficiency and Renewable Energy

[EERE Home](#)

Geothermal Technologies Program

[About the Program](#) | [Program Areas](#) | [Information Resources](#) | [Financial Opportunities](#) | [Technologies](#) | [Deployment](#) | [Home](#)

[Search](#)

[Search Help](#) | [More Search Options](#)

Geothermal Basics

Geothermal Resource Map

Research & Development

R&D Successes

Applications

Impacts


Laws & Standards

[Printable Version](#)

[EERE Information Center](#)

U.S. Geothermal Resource Map

The geothermal resources map of the United States below shows the estimated subterranean temperatures at a depth of 6 kilometers. To determine the Earth's internal temperature at any depth below the capabilities of normal well drilling, multiple data sets are synthesized. The data used for this figure are: thermal conductivity, thickness of sedimentary rock, geothermal gradient, heat flow, and surface temperature.




ATTACHMENT E1
REPP-CREST
“WHAT CAN A DASH OF BIOMASS DO”
(NO DATE)

REPP-CREST


“What Can a Dash of Biomass Do?”


(no date)

BIOENERGY



Search REPP WWW





HOME

REPP LIBRARY:
CURRENT PAPERS
& ARCHIVE

ENERGY AND ENVIRONMENT

DISCUSSION GROUPS

COMMUNITY CALENDAR

GLOBAL ENERGY MARKETPLACE

ABOUT US

BIOENERGY * **HYDRO** * **GEO THERMAL** * **WIND** * **SOLAR** * **HYDROGEN** * **EFFICIENCY**

[Bioenergy Basics](#) * [Types of Biomass](#) * [A Dash Of Biomass...](#) * [Ways to Generate Electricity](#)


* [Costs of Bioenergy](#) * [Current Use](#) * [Barriers To Widespread Use](#) * [Current Policies](#)

What Can A Dash of Biomass Do?

Biomass can be used in a variety of energy conversion processes in order to yield power, heat, steam and fuel.

Power


Biopower can be generated any number of ways, which are detailed in Chapter 4 of this report. Most biopower is generated through a co-firing method or with a traditional steam turbine. In any system, a turbine is stimulated, either by steam or gas. The turbine is connected to a generator which contains magnets which are positioned to ensure repulsion, meaning the polar opposites are unable to attract to one another. When calibrated correctly the magnets inside the generator generate a magnetic field. A conductor rod will be passed through the magnetic field, causing electrons in the conductor rod will flow freely thereby creating an electrical current.



©2003 HowStuffWorks

The conducting rod is metal, often copper, wound into tight coils to maximize the amount of electricity created. The ends of the coils are connected to an outside transmission station and eventually fed to the grid [1]. Below is a flow chart of the McNeil Generating System in Burlington, Vermont; one of the oldest online biomass generating power plants in the country. It was founded in 1986 and uses woodchips as its primary fuel.

REPP
1612 K Street, NW
Suite 202
Washington, DC 20006




According to the Energy Efficiency and Renewable Energy Office of the Department of Energy, today's biopower plants have a combined capacity of 10.3 gigawatts. With the average home requiring 3 to 4 Kw, today's biopower plants generate enough electricity to supply over 34 million homes with electricity. Astonishingly, this is only 1.4% of our nation's energy capacity [2]! Biomass is expected to supply up to 30% of our nation's power by 2020 [3].

[Back to Top](#)

Heat and Steam

The same power plants that produce power also yield useful steam and heat which can be used to heat residential and commercial buildings. The process of capturing the heat and the steam that is released from the process is called combined-heat-and-power or CHP. Taking advantage of these products can improve the efficiency of the operation by over 35%. Pulp and paper mills in the Southeast, Northeast and Great Lakes region of the U.S. already generate power, steam and heat from biomass. Finland hosts CHP operations that heat homes and businesses. Below is a map of the United States which shows where biomass can hope to be harvested to aid in one of the energy sectors.



Back to Top

Traditional Heat

Of course, biomass such as wood in fireplaces and kilns also heat homes and provide energy for cooking. Biomass is the oldest known source of renewable energy—humans have been using it since we discovered fire—and it has high energy content. The energy content of dry biomass ranges from 7,000 Btu/lb for straws to 8,500 Btu/lb for wood [4]. Below is a chart that lists the heat content of different types of biomass, as supplied by the Energy Information Administration. For perspective, it takes about 10,000 Btu to cook a meal. Alternatively, one gallon of gasoline is equivalent to 124,884 btu.

Table B6. Average Heat Content of Selected Biomass Fuels

Fuel Type	Heat Content	Units
Agricultural Byproducts	8.248	Million Btu/Short Ton
Black Liquor	11.759	Million Btu/Short Ton
Digester Gas	0.619	Million Btu/Thousand Cubic Feet
Landfill Gas	0.490	Million Btu/Thousand Cubic Feet
Methane	0.941	Million Btu/Thousand Cubic Feet
Municipal Solid Waste	9.945	Million Btu/Short Ton
Paper Pellets	13.029	Million Btu/Short Ton
Peat	8.000	Million Btu/Short Ton
Railroad Ties	12.618	Million Btu/Short Ton
Sludge Waste	7.512	Million Btu/Short Ton
Sludge Wood	10.071	Million Btu/Short Ton
Solid Byproducts	25.830	Million Btu/Short Ton
Spent Sulfite Liquor	12.720	Million Btu/Short Ton
Tires	26.865	Million Btu/Short Ton
Utility Poles	12.500	Million Btu/Short Ton
Waste Alcohol	3.800	Million Btu/Barrel

Wood/Wood Waste	9.961	Million Btu/Short Ton
-----------------	-------	-----------------------

Source: Energy Information Administration, Form EIA-860B (1999), "Annual Electric Generator Report - Nonutility 1999."

[Back to Top](#)

Fuel


Solid biomass can also be converted into liquid fuels that power cars, engines including those in diesel generators, and even industrial operations. Methanol, ethanol, biofuel and biodiesel can all be created from biomass. Methanol is a wood alcohol which is not as efficient as gasoline as a fuel and is mostly used in antifreeze and in the production of other chemicals, such as formaldehyde [5]. For more information on methanol, visit the [Methanol Institute](#).


Ethanol, or ethyl alcohol, is a clear, colorless, flammable oxygenated fuel currently added as a gasoline additive in 30 states to increase octane and lower tailpipe greenhouse gas emissions [6]. It is biodegradable and water soluble. Ethanol (which comes from cellulosic biomass such as corn) is produced through fermentation at either a dry mill or at a wet mill, both displayed below. The dry mill process is simpler than the wet mill process. The wet mill breaks the corn into its components and processes each separately. In addition to ethanol, both processes also create distiller's grain, which is fed to farm animals.

Up to 24% ethanol can be added to gasoline before engine modifications are necessary. A blend known as E85, which is 85% ethanol and 15% gasoline, can be used to power flexible fuel vehicles (FFVs). Many cars on the market today are already built to run on E85. Brazil has had much success converting nearly all of its vehicles to run on E85 made from sugar. It even announced that it would stop importing oil by the end of 2006 [7].

Ethanol has a better environmental profile than gasoline as measured at both the production facility and the tailpipe. Ethanol production plants produce less carbon dioxide, methane and particulates than gasoline refineries, which help meet clean air standards. A blend of 10% ethanol, or E10, yields a 26% reduction in greenhouse gases when compared to gasoline alone [8]. The Senate version of The Energy Policy Act of 2005 includes an ethanol provision that would boost ethanol production to 8 billion gallons from the current level of 3.9 billion gallons by 2012 [9]. For more information on ethanol, please see visit the [Renewable Fuels Association](#) website.

The Ethanol Production Process (Dry Mill)





Both Diagrams courtesy of the Renewable Fuels Association, Production Processes

Biodiesel is the result of combining alcohol (including ethanol) with oil extracted from soybeans, rapeseed, animal fats, or other biomass. Biodiesel is an American-made fuel that can be produced from any fat or vegetable oil, such as soybean oil often sold as 2% (B2) or 10% (B10) blends with diesel. "Concerns that biodiesel can't perform or flow well in adverse weather are based on myths," according to Kelly Streb, a research engineer for the University of Minnesota Center for Diesel Research at Minneapolis, Minnesota [10]. Biodiesel performs very well in cold climates and is being used in airport snowplows and school buses according to an article a Missouri paper. It also burns much cleaner than traditional diesel, making it more environmentally friendly. Seen below are two liters of biodiesel. Some biodiesel companies are even contracting with restaurants to make biodiesel from their used vegetable oils.



[Back to Top](#)

Sources Cited:

- [1] "How Electromagnetics Work." How Stuff Works.Com. <http://science.howstuffworks.com/electromagnet3.htm>
- [2] "Energy Savers: Bioenergy." Office of Energy Efficiency and Renewable Energy, the Department of Energy. <http://www.eere.energy.gov/consumerinfo/factsheets/nb2.html>
- [3] "Economic Analysis Highlights Major Economic Impact of 8 Billion Gallon RFS." May 23, 2005. Press Release of the Renewable Fuels Association. Available Online at www.ethanolrfa.org. June 20, 2005.
- [4] "Bioenergy." Montana Green Power National Center for Appropriate Technology. May12, 2005. <http://www.montanagreenpower.com/renewables/bioenergy/>
- [5] "Definition of Methanol." *Wikipedia Online*. <http://en.wikipedia.org/wiki/Methanol>
- [6] "Economic Analysis Highlights Major Economic Impact of 8 Billion Gallon RFS." May 23, 2005. Press Release of the Renewable Fuels Association, in reference to the footnote listed below. Available Online at www.ethanolrfa.org. June 20, 2005
- [7] Jim Landers. "Ethanol's Sweet Allure." The Dallas Morning News. June 10, 2005.
- [8] Michael Wang. "Ethanol: the Complete Lifecycle Picture." Argonne National Laboratory and the Department of Energy Efficiency and Renewable Energy Office. June 2005.
- [9] "Economic Analysis Highlights Major Economic Impact of 8 Billion Gallon RFS." May 23, 2005. Press Release of the Renewable Fuels Association. Available Online at www.ethanolrfa.org. June 20, 2005

[10] "Biodiesel Beats the Cold: Coldest Spots in the Country Succeed with Biodiesel Even at Subzero Temperatures. Bioenergy news, Montana Green Power National Center for Appropriate Technology May 12, 2005.
<http://www.montanagreenpower.com/renewables/bioenergy/>.

[11] Environmental News Network. www.enn.com

ATTACHMENT E2
STATE OF OREGON
RENEWABLE RESOURCES
“BIOMASS ENERGY: COST OF PRODUCTION”
(NO DATE)

**State of Oregon
Renewable Resources**

“Biomass Energy: Cost of Production”

(no date)

[Text-Only Site](#)[State Directory](#)[Agencies A-Z](#)[Accessibility](#)[Advanced Help](#)**OREGON**[Business](#)[Education](#)[Human Services](#)[Natural Resources](#)[Public Safety](#)[Recreation](#)[Transportation](#)

Renewable Resources

[Departments](#) [Divisions](#)

Biomass Energy: Cost of Production

Combustion and Gasification Facilities

Using conventional combustion technology without cogeneration, the estimated cost to generate electricity from biomass ranges from 5.2 to 6.7 cents per kilowatt-hour in Oregon and the Pacific Northwest. Actual costs would vary depending on financing, location, system design and fuel cost. In the future, new gasification technologies may lower the cost of generating electric power from waste wood and other biomass fuels. In contrast, the estimated cost of generating electricity from a new natural gas-fired, combined-cycle power plant is 2.8 cents per kilowatt-hour.

For biomass-fueled power plants, reliance on variable supplies of forest and agricultural residues means that a continuous supply of fuel may be uncertain. Generation of electric power requires large quantities of biomass. Fuel transportation, storage and handling costs are a significant part of the costs of biomass energy production. One strategy to deal with fuel supply uncertainty is to design the facility to handle multiple biomass fuel types. Future expansion of the biomass power market may require the development of a feedstock supply system based on large-scale production of biomass fuel from energy crops.

Heat is a byproduct of producing electric power using biomass. Steam produced in a biomass-fired boiler can both generate electric power and supply industrial process heat. Cogeneration is the combined production of electricity and process heat. In a cogeneration power plant, sale of steam to an industrial user can offset the cost of producing electric power from biomass.

Biogas Facilities

Naturally-occurring anaerobic digestion in solid waste landfills produces methane, which can be used to generate electricity. In Oregon, generating electricity from landfill gas is cost-competitive with natural gas power generation. The estimated cost is 2.9 to 3.6 cents per kilowatt-hour. Sale of power generated from landfill gas can offset the cost of equipment needed otherwise to collect and flare methane produced in landfills.

At wastewater treatment plants that use anaerobic digesters as part of the treatment system, methane is a by-product of the treatment process. Wastewater treatment plants can use digester gas to generate electricity and offset the cost of buying power from the local utility. Because treatment plants receive revenue for treating wastewater, these plants have a negative feedstock cost for power generation from their methane gas.

The estimated cost of producing electric power from anaerobic digestion of animal manure is 3.7 to 5.4 cents per kilowatt-hour. Digester technology can be part of an integrated facility that produces electricity and heat, eliminates waste disposal and odor problems and helps to protect the environment.

The cost of a farm-site manure digester depends on local site conditions and the number of animals on the farm. A plug-flow digester designed to process the manure of 500 dairy cows will have capital costs in the range of \$230,000 to \$260,000. Electricity and heat generated from digester gas reduce farm energy costs. Liquid and fiber digester residues have value as fertilizers and soil amendments. The costs of building and operating the digester can be recovered from sales of these products and from energy cost savings.

Dairy farm runoff presents an environmental hazard from poorly managed animal manure. Runoff can pollute local streams and spread disease. Anaerobic digestion protects surface streams from contamination because the process destroys harmful microorganisms that are carried in manure. Although it is expensive to construct a manure digester, there is also a cost for alternative manure management and cleanup measures that produce no income for the dairy operator.

Ethanol Production

The cost of producing ethanol varies with the cost of the feedstock used and the scale of production. Approximately 85 percent of ethanol production capacity in the United States relies on corn feedstock. The cost of producing ethanol from corn is estimated to be about \$1.10 per gallon. Although there is currently no commercial production of ethanol from cellulosic feedstocks such as agricultural wastes, grasses and wood, the estimated production cost using these feedstocks is \$1.15 to \$1.43 per gallon.

ATTACHMENT E3
U.S. DEPARTMENT OF AGRICULTURE AND U.S. DEPARTMENT OF ENERGY
“BIOMASS AS A FEEDSTOCK FOR A BIOENERGY AND BIOPRODUCTS INDUSTRY: THE
TECHNICAL FEASIBILITY FOR A BILLION-TON ANNUAL SUPPLY”
APRIL 2005

**U.S. Department of Agriculture
and U.S. Department of Energy**

Joint Study

**“Biomass as Feedstock for A Bioenergy and
Bioproducts Industry: The Technical
Feasibility of a Billion-Ton Annual Supply”**

ORNL/TM-2005/66

April 2005

Biomass as Feedstock for a Bioenergy and Bioproducts Industry: The Technical Feasibility of a Billion-Ton Annual Supply

April 2005



U.S. Department of Energy



U.S. Department of Agriculture

2. The Biomass Feedstock Resource Base


2.1 Land Resources for Biomass Production

The land base of the United States encompasses nearly 2,263 million acres, including the 369 million acres of land in Alaska and Hawaii. About 33 percent of the land area is classified as forest land, 26 percent as grassland pasture and range, 20 percent as cropland, 8 percent as special uses (e.g., public facilities), and 13 percent as miscellaneous uses such as urban areas, swamps, and deserts (Vesterby and Krupa, 2001; Alig et al., 2003). About one-half of this land has some potential for growing biomass. This percentage is nearly 60 percent without Alaska and Hawaii.

Currently, slightly more than 75 percent of biomass consumption in the United States (about 142 million dry tons) comes from forestlands. The remainder (about 48 million dry tons), which includes biobased products, biofuels and some residue biomass, comes from cropland.

2.2 Biomass Feedstock Consumption

In 2003, biomass contributed nearly 2.9 quadrillion BTU (quad) to the nation's energy supply, nearly 3 percent of total U.S. energy consumption of about 98 quads (EIA, 2004a). At 47 percent of total renewable energy consumption, biomass is the single largest renewable energy resource, recently surpassing hydropower (Figure 2). More than 50 percent



Biomass Consumption	Million dry tons/year
Forest products industry	
Wood residues	44
Pulping liquors	52
Urban wood and food & other process residues	35
Fuelwood (residential/commercial & electric utilities)	35
Biofuels	18
Bioproducts	6
Total	190

- Forestlands and agricultural lands contribute 190 million dry tons of biomass - 3% of America's current energy consumption.

Source: EIA, 2004a & b

Figure 2: Summary of biomass resource consumption


ATTACHMENT E4
U.S. DEPARTMENT OF ENERGY
ENERGY EFFICIENCY AND RENEWABLE ENERGY
BIOPower FACT SHEET
“BIOMASS COFIRING: A RENEWABLE ALTERNATIVE FOR UTILITIES”
JUNE 2000

U.S. Department of Energy
Energy Efficiency and Renewable Energy

Biopower Fact Sheet
“Biomass Cofiring: A Renewable Alternative
for Utilities”
DOE/GO-102000-1055

June 2000

Biomass Cofiring: A Renewable Alternative for Utilities





Biomass Cofiring

Cofiring is a near term, low-cost option for efficiently and cleanly converting biomass to electricity by adding biomass as a partial substitute fuel in high-efficiency coal boilers. It has been demonstrated, tested, and proved in all boiler types commonly used by electric utilities. There is little or no loss in total boiler efficiency after adjusting combustion output for the new fuel mixture. This implies that biomass combustion efficiency to electricity would be close to 33%-37% when cofired with coal. Extensive demonstrations and tests also confirmed that biomass energy can provide as much as 15% of the total energy input with only feed intake system and burner modifications. The opportunities for biomass cofiring are great because large scale coal-powered boilers represent 310 gigawatts of generating capacity. Cofiring biomass with coal offers several environmental benefits. Cofiring reduces emissions of carbon dioxide, a greenhouse gas that can contribute to the global warming effect (see picture on the reverse side). Also, biomass contains significantly less sulfur than most coal. This means that cofiring will reduce emissions of sulfurous gases such as sulfur dioxide that will then reduce acid rain. Early test results with woody biomass cofiring showed a reduction potential as great as 30% in oxides of nitrogen, which can cause smog and ozone pollution.

During the 1990s, electric utilities across the country implemented biomass cofiring demonstrations and commercial operations. Five power plants started the year 2000 regularly cofiring coal with wood residue products. Another plant closed in 1998 after 10 years of operating successfully with biomass. Five additional plants were planning tests in the year 2000. More than 10 years of experience produced information that is now available on the technical and economic performance of cofiring biomass with coal.

The Dunkirk Power Station will use hybrid willow grown by New York farmers to generate renewable electricity.



Biomass Cofiring Plants

- △ In commercial operation
- Demonstrations conducted
- Tests planned

Economic Considerations

Cofiring economics depends on location, power plant type, and the availability of low-cost biomass fuels. A typical cofiring installation includes modifications to the fuel-handling and storage systems and possibly the burner to accommodate biomass. Costs can increase significantly if wood needs to be dried, size needs to be reduced, or the boiler requires a separate feeder. Retrofit costs range from \$150 to \$300 per kilowatt (kW) of biomass generation in pulverized coal boilers. Cyclone boilers offer the lowest cost opportunities, as low as \$50 per kW.

Fuel supply is the most important cost factor. Costs for biomass fuels depend on many factors such as climate, closeness to population centers, and the presence of industries that handle and dispose of wood. Low price, low shipping cost, and dependable supply are paramount. Usually the cost of biomass fuels must be equal to or less than the cost of coal per unit of heat for cofiring to be economically successful. Some utilities reduce fuel costs by cofiring with biomass; the Tennessee Valley Authority, for example, estimates that it will save \$1.5 million per year in fuel costs cofiring with biomass at its Colbert plant.

Technical Challenges



Several technical questions about fuel feed, boiler chemistry, and ash deposition and disposal have been raised and are approaching resolution. Losses in boiler efficiency caused by cofiring are small and are usually due to high moisture content in the biomass fuels. A consensus

ATTACHMENT E5
U.S. DEPARTMENT OF ENERGY
ENERGY INFORMATION ADMINISTRATION
FORECASTS
“BIOMASS FOR ELECTRICITY GENERATION”
NOVEMBER 2002

**U.S. Department of Energy
Energy Information Administration**

**Forecasts
“Biomass for Electricity Generation”**

November 2002



Home > Modeling and Analysis Papers > Biomass for Electricity Generation

Biomass for Electricity Generation

by Zia Haq

This paper examines issues affecting the uses of biomass for electricity generation. The methodology used in the National Energy Modeling System to account for various types of biomass is discussed, and the underlying assumptions are explained. The Energy Information Administration's estimation of biomass resources shows that there are 590 million wet tons of biomass available in the United States on an annual basis; 20 million wet tons (enough to supply about 3 gigawatts of capacity) are available today at prices of \$1.25 per million Btu or less. The average price of coal to electric utilities in 2001 was \$1.23 per million Btu.

Introduction

The U.S. economy uses biomass-based materials as a source of energy in many ways. Wood and agricultural residues are burned as a fuel for cogeneration of steam and electricity in the industrial sector. Biomass is used for power generation in the electricity sector and for space heating in residential and commercial buildings. Biomass can be converted to a liquid form for use as a transportation fuel, and research is being conducted on the production of fuels and chemicals from biomass. Biomass materials can also be used directly in the manufacture of a variety of products.

In the electricity sector, biomass is used for power generation. The Energy Information Administration (EIA), in its *Annual Energy Outlook 2002 (AEO2002)* reference case,¹ projects that biomass will generate 15.3 billion kilowatthours of electricity, or 0.3 percent of the projected 5,476 billion kilowatthours of total generation, in 2020. In scenarios that reflect the impact of a 20-percent renewable portfolio standard (RPS)² and in scenarios that assume carbon dioxide emission reduction requirements based on the Kyoto Protocol,³ electricity generation from biomass is projected to increase substantially. Therefore, it is critical to evaluate the practical limits and challenges faced by the U.S. biomass industry. This paper examines the range of costs, resource availability, regional variations, and other issues pertaining to biomass use for electricity generation. The methodology by which the National Energy Modeling System (NEMS) accounts for various types of biomass is discussed, and the underlying assumptions are explained.

A major challenge in forecasting biomass energy growth is estimating resource potential. EIA has compiled available biomass resource estimates from Oak Ridge National Laboratory (ORNL),⁴ Antares Group, Inc.,⁵ and the U.S. Department of Agriculture (USDA).⁶ This paper discusses how these data are used for forecasting purposes and the implications of the resulting forecasts, focusing on biomass used in grid-connected electricity generation applications.

Background

Biomass has played a relatively small role in terms of the overall U.S. energy picture, supplying 3.2 quadrillion Btu of energy out of a total of 98.5 quadrillion Btu in 2000.⁷ The vast majority of it is used in the pulp and paper industries, where residues from production processes are combusted to produce steam and electricity. The industrial cogeneration sector consumed almost 2.0 quadrillion Btu of biomass in 2000. Outside the pulp and paper industries, only a small amount of biomass is used to produce electricity. There are power plants that combust biomass exclusively to generate electricity and facilities that mix biomass with coal (biomass co-firing plants). The electricity generation sector (excluding cogenerators) consumed about

0.7 quadrillion Btu of biomass in 2000. The remaining 0.5 quadrillion Btu of biomass was consumed in the residential and commercial sectors in the form of wood consumption for heating buildings. To put these numbers in perspective, the electricity generation sector consumed 20.5 quadrillion Btu of coal and 6.5 quadrillion Btu of natural gas in 2000.⁸

Biomass played a significant role among renewables in 2000, however, providing 48 percent of the energy coming from all renewable sources. In EIA's *AEO2002* reference case projection, growth in demand for biomass is expected to be modest. In the *AEO2002* high renewables case projection, the demand for biomass is higher than in the reference case due to assumptions of reduced initial capital cost⁹ and increased supply. In aggressive RPS cases,¹⁰ the demand for biomass is much higher than projected even in the high renewables case.

Among many reasons for increased biomass utilization in those cases, environmental benefits are the most important. Compared with coal, biomass feedstocks have lower levels of sulfur or sulfur compounds.¹¹ Therefore, substitution of biomass for coal in power plants has the effect of reducing sulfur dioxide (SO₂) emissions. Demonstration tests have shown that biomass co-firing with coal¹² can also lead to lower nitrogen oxide (NO_x) emissions. Perhaps the most significant environmental benefit of biomass, however, is a potential reduction in carbon dioxide (CO₂) emissions.

A closed-loop process is defined as a process in which power is generated using feedstocks that are grown specifically for the purpose of energy production. Many varieties of energy crops are being considered, including hybrid willow, switchgrass, and hybrid poplar. If biomass is utilized in a closed-loop process, the entire process (planting, harvesting, transportation, and conversion to electricity) can be considered to be a small but positive net emitter of CO₂. It is not precisely a net zero emission process in a life-cycle sense, because there are CO₂ emissions associated with the harvesting, transportation, and feed preparation operations (such as moisture reduction, size reduction, and removal of impurities). However, those emissions are not the result of combustion of biomass but result instead from fuel consumption (mostly petroleum and natural gas) for harvesting, transportation, and feed preparation operations.

Although biomass-based generation is assumed to yield no net emissions of CO₂ because of the sequestration of biomass during the planting cycle, there are environmental impacts. Wood contains sulfur and nitrogen, which yield SO₂ and NO_x in the combustion process. However, the rate of emissions is significantly lower than that of coal-based generation. For example, per kilowatthour generated, biomass integrated gasification combined-cycle (BIGCC) generating plants can significantly reduce particulate emissions (by a factor of 4.5) in comparison with coal-based electricity generation processes.¹³ NO_x emissions can be reduced by a factor of about 6 for dedicated BIGCC plants compared with average pulverized coal-fired plants.¹⁴

Biomass Technologies for Electricity Generation

Both dedicated biomass and biomass co-firing are used in the electricity generation sector. New dedicated biomass capacity is represented in NEMS as BIGCC technology. It is assumed that hot gas filtration will be used for gas cleanup purposes in this technology. Hot gas cleanup technology is relatively new, and the U.S. Department of Energy (DOE) and many industrial partners are conducting tests to demonstrate the technology. The alternative to hot gas cleaning is low-temperature gas cleaning. In low-temperature cleaning the gas is quenched with water, and particulates are removed in a series of cyclone vessels. There are advantages and disadvantages associated with both processes.

The advantages of cold gas cleaning are that it is commercially available, the capital cost is relatively low, and the systems are easier to operate than hot gas cleanup systems. The disadvantages of cold gas cleanup are that the cooling process, the cold gas cleanup system, and fuel gas recompression systems reduce the overall process efficiency by up to 10 percent. The gas turbines downstream of the gasifier require the gas at high temperatures and pressure, and therefore the gas that has just undergone cooling for cleanup purposes must be repressurized and reheated in order to conform to gas turbine inlet specifications. The advantages of the newer hot gas cleanup technology are that it allows the process to be operated at higher efficiencies and it generates less waste water than the cold gas cleanup processes. The disadvantages of the hot gas

cleanup technology are that operational experience is limited, it has higher costs, and it adds complexity to the process; however, it is considered to be the technologically more advanced choice for new dedicated biomass plants.

The McNeil Generating Station demonstration project in Burlington, Vermont, is an example of a biomass gasification plant. It has a capacity of 50 megawatts and supplies electricity to the residents of the City of Burlington. This is an existing wood combustion facility whose feedstock is waste wood from nearby forestry operations, including forest thinnings and discarded wood pallets. To this existing wood combustion facility a low-pressure wood gasifier has been added that is capable of converting 200 tons per day of wood chips into fuel gas. The fuel gas, fed directly into the existing boiler (Figure 1) augments the McNeil Station's capacity by an additional 12 megawatts. The system was designed and constructed in 1998 and attained fully operational status in August 2000.

In addition to the Vermont project, DOE has funded five new advanced biomass gasification research and development projects beginning in 2001. Emery Recycling in Salt Lake City, Utah, will test new IGCC and integrated gasification and fuel cell (IGFC) concepts based on a new gasifier that uses segregated municipal solid waste, animal waste, and agricultural residues. Sebesta Blomberg in Roseville, Minnesota, has begun a project on an atmospheric gasifier with gas turbine at a malting facility, using barley residues and corn stover. Alliant Energy in Lansing, Iowa, is developing a new combined-cycle concept that involves a fluidized-bed pyrolyzer and uses corn stover as a feedstock. United Technologies Research Center in East Hartford, Connecticut, has begun a project that will test a biomass gasifier coupled with an aero-derivative turbine with fuel cell and steam turbine options, using clean wood residues and natural gas as feedstocks. Carolina Power and Light in Raleigh, North Carolina, will develop a biomass gasification process that will produce a reburning fuel stream for utility boilers, using clean wood residues. After completion of research and development tests, these projects are candidates for commercialization over the next few years.¹⁵

Biomass co-firing involves combining biomass material with coal in existing coal-fired boilers. Coal-fired boilers can handle a pre-mixed combination of coal and biomass in which the biomass is combined with the coal in the feed lot and fed through an existing coal feed system. Alternatively, boilers can be retrofitted with a separate feed system for the biomass such that the biomass and coal actually mix inside the boiler.

Table 1 shows the power plants that currently are co-firing with biomass on a commercial basis. The portion of biomass consumed varies from less than 1 percent to about 8 percent of total heat input, with two exceptions: Excel Energy's Bay Front plant in Ashland, Wisconsin, and Tacoma Steam Plant Number 2, owned by Tacoma Public Utilities.

The Bay Front Station can generate electricity using coal, wood, shredded rubber, and natural gas. Experience has shown that it is better to operate units 1 and 2 on 100 percent coal during periods of high load and on 100 percent biomass during off-peak periods. A blending of coal and biomass can cause ash fouling and slagging problems. Therefore, the heat input from biomass averages about 40 percent in this plant.¹⁶

Tacoma Public Utilities is a municipal utility that provides water, electricity, and rail services. Tacoma Steam Plant uses a fluidized-bed combustor that can co-fire wood, refuse-derived fuel, and coal. The plant runs for only as many hours as necessary to burn the refuse-derived fuel it receives. The City of Tacoma Refuse Utility has modified its resource recovery facility to produce refuse-derived fuel. The generating plant is paid \$5.50 per ton to accept the refuse-derived fuel from the Refuse Utility. A memorandum of understanding between the Refuse Utility and Tacoma Public Utilities commits the latter to burn the refuse-derived fuel for electricity generation. Coal is the most expensive fuel for the plant, making it desirable to burn as much biomass as possible.¹⁷ The fuel mix varies from season to season, depending on the availability of biomass feedstocks. The cost of renovating the steam plant to co-fire the biomass fuel was about \$45 million. Washington State's Department of Ecology provided a grant of \$15 million to partially offset the renovation costs.

Biomass for electricity generation is treated in four ways in NEMS: (1) new dedicated biomass or biomass gasification, (2) existing and new plants that co-fire biomass with coal, (3) existing plants that combust biomass directly in an open-loop process,¹⁸ and (4) biomass use in industrial cogeneration applications. Existing biomass plants are accounted for using information such as on-line years, efficiencies, heat rates,

and retirement dates, obtained through EIA surveys of the electricity generation sector.

Description of Biomass Supply Curves

The biomass fuel price is calculated from regional supply curves, which are an input to the model. The raw data for the supply schedules are available at the State or county level. These are aggregated to form the regional supply schedule by North American Electric Reliability Council (NERC) region. Supply schedules are aggregated for four fuel types: agricultural residues, energy crops, forestry residues, and urban wood waste/mill residues. Table 2 shows the biomass supply available in the United States. The data in Table 2 are based on survey and modeling work by ORNL, the USDA, and Antares Group, Inc. Table 2 represents the maximum supply available in the various regions at a price of \$5 per million Btu.¹⁹ A brief description of each type of biomass is provided below:

- *Agricultural residues* are generated after each harvesting cycle of commodity crops. A portion of the remaining stalks and biomass material left on the ground can be collected and used for energy generation purposes. Residues of wheat straw and corn stover²⁰ are included in the biomass supply schedule used in NEMS. Wheat straw and corn stover make up the majority of crop residues.
- *Energy crops* are produced solely or primarily for use as feedstocks in energy generation processes. Energy crops includes hybrid poplar,²¹ hybrid willow,²² and switchgrass,²³ grown on cropland acres currently cropped, idled, or in pasture, and in the Conservation Reserve Program (CRP).²⁴
- *Forestry residues* are the biomass material remaining in forests that have been harvested for timber. Timber harvesting operations do not extract all biomass material, because only timber of certain quality is usable in processing facilities. Therefore, the residual material after a timber harvest is potentially available for energy generation purposes. Forestry residues are composed of logging residues, rough rotten salvageable dead wood, and excess small pole trees.
- *Urban wood waste/mill residues* are waste woods from manufacturing operations that would otherwise be landfilled. The urban wood waste/mill residue category includes primary mill residues and urban wood such as pallets, construction waste, and demolition debris, which are not otherwise used.

By 2020, the United States is estimated to have a maximum of 7.1 quadrillion Btu of biomass available at prices of \$5 per million Btu or lower. Agricultural residues, forestry residues, and urban wood waste/mill residues are currently available. EIA also assumes that energy crops can become available on a commercial basis beginning in 2010. By 2020, the four biomass types are projected to be fairly evenly divided, with agricultural residues providing most of the supply and urban wood waste/mill residues providing the least amount at the high end of the supply curves.

Figure 2 shows the variation in the resource as a function of price. A relatively small portion of the supply is available at \$1 per million Btu or less. Feedstock cost is a contributing factor that keeps the growth of biomass-based electricity generation at low levels under AEO2002 reference case conditions. The available low-cost feedstock (<\$1 per million Btu) is almost exclusively urban wood waste and mill residues. This category of biomass continues to be the only significant resource available at prices up to about \$2 per million Btu. At that price level, agricultural residues become viable as a second source of biomass. Energy crops and forestry residues begin to make significant contributions at prices around \$2.30 per million Btu or higher. A brief description of the methodology by which the supply curves are derived is provided below. Table 3 shows the biomass quantities, expressed in various units, that are projected to be available at different price levels.

Agricultural Residue Supply Curve

The underlying assumption behind the agricultural residue supply curve is that after each harvesting cycle of agricultural crops, a portion of the stalks can be collected and used for energy production. Agricultural residues cannot be completely extracted, because some of them have to remain in the soil to maintain soil quality (i.e., for erosion control, carbon content, and long-term productivity). It is assumed that 30 to 40 percent of the residues could be removed from the soil, depending on the State. In terms of acreage, the

most important agricultural commodity crops being planted in the United States are listed in Table 4. Corn, wheat, and soybeans represent about 70 percent of total cropland harvested.

The agricultural residue supply curve used in NEMS incorporates only the residues available from corn stover and wheat straws. While this may appear to understate the agricultural residues that are potentially available for energy production, there are compelling reasons for excluding other types of commodity crops. In the case of hay, the whole crop is harvested and fed to livestock; therefore, it is assumed that there would be no useful amount of residue available. An attempt has been made to produce alfalfa, pellet the leaves using adhesive materials, and use the stems as biomass. The processing costs were too high, however, and there was no market for alfalfa pellets in the United States. In the case of tobacco the whole plant is used, leaving little or no residue. Residue from soybeans is relatively small and tends to deteriorate rapidly in the field, making it unsuitable for collection and energy extraction. Barley, oats, rice, and rye are produced in relatively small geographical areas and thus are not likely to have an impact on the national biomass supply curve.

The procedure for estimating the agricultural residue supply curve is as follows. Data on the quantities of corn and wheat produced in each State are available from the USDA.²⁵ From the harvested quantities of corn and wheat grain, a certain amount must be subtracted, representing the amount that the farmer needs to leave on the soil in order to maintain organic matter and prevent erosion. The quantity of residue that must remain depends on the crop type and rotation, soil type, weather conditions, and the tillage system. ORNL is currently preparing detailed estimates of how much residue needs to remain on the soil, taking into consideration these factors. For NEMS, only State-wide average yields and soil carbon needs using a reduced till practice (somewhat similar to mulch till and continuous crop rotations) are being considered.

The price of corn stover and wheat straw includes three components: the cost of collecting the residues, a transportation cost for transporting the material from the farm gate to the energy conversion facility, and a premium paid to farmers to encourage participation. For each harvest operation, a list of needed equipment is determined. Using standard engineering estimates consistent with those used by the USDA, the time per acre required to complete each operation and the cost per hour of using each piece of equipment are calculated.

Both the premiums to farmers and the transportation costs are based on current market practices. Several companies purchase corn stover or wheat straw to produce bedding, insulating materials, particle board, paper, and chemicals. These firms typically pay \$10 to \$15 per dry ton (\$0.58 to \$0.87 per million Btu) to farmers to compensate for any lost nutrient or environmental penalties (such as land erosion) that result from harvesting the residues. Studies have shown that transporting giant round bales of switchgrass costs \$5 to \$15 per dry ton (\$0.29 to \$0.87 per million Btu) for distances of less than 50 miles. Because agricultural residue bales would be of similar size, weight, and density as switchgrass bales, it is assumed that the cost of transporting bales from the farm gate to the energy conversion facility would be \$10 per dry ton (\$0.58 per million Btu). It is assumed by ORNL that the premium that would have to be paid to farmers would amount to \$10 per dry ton (\$0.58 per million Btu), for a total premium and transportation cost of \$20 per dry ton (\$1.16 per million Btu).

Energy Crop Supply Curve

Energy crops are not currently being commercially grown in the United States. Demonstration programs are underway with DOE funding in Iowa and New York, including IES Utilities Inc.'s biomass co-firing project at its Ottumwa Station plant in Iowa, for which there are plans to produce 200,000 tons of switchgrass harvested from 40,000 to 50,000 acres of land; and NRG's Dunkirk Station at Dunkirk, New York, where willow from 400 acres of farmland is being co-fired with coal. Therefore, the energy crop supply curve in NEMS represents future resources that could be more profitable at different market prices for farmers to plant in place of existing uses of cropland. An important assumption is that energy crops will not become commercially available until 2010.

The energy crop supply curve prepared by ORNL for EIA has three components: hybrid poplar, hybrid willow, and switchgrass. ORNL uses a model called the Policy Analysis System (POLYSYS) to estimate the quantities of energy crops that could be produced at various prices. POLYSYS is an agricultural sector model that forecasts the production of major agricultural crops. In addition, it has a livestock sector and food, feed, industrial, and export demand functions. POLYSYS was developed and is maintained by the

Agricultural Policy Analysis Center at the University of Tennessee and is also used by the USDA Economic Research Service to conduct economic and policy analysis. The underlying assumption in the POLYSYS model is that a farmer will plant and harvest energy crops only if the crop can be sold at a price that assures a profit higher than the profit made by producing conventional agricultural crops on the same piece of land. POLYSYS captures the interaction between energy crops and conventional crops when land is switched from conventional crops to energy crop production. As a joint project between USDA and DOE, POLYSYS has been modified to include dedicated energy crops. POLYSYS uses the 1999 USDA crop and livestock projection as a baseline and can be used to estimate deviations from that baseline.

POLYSYS considers the availability of four types of cropland in the United States: acreage that is currently being planted with traditional crops, idled acreage, acreage in pasture, and acreage in the CRP. The model assumes that energy crop production will be limited to areas that are climatically suited for their production, thus excluding all States in the Rocky Mountain and Western Plains regions. The rationale for these exclusions is that there is a natural rain gradient in the United States, as a result of which land to the west of the gradient generally requires irrigation for crop production, which may have significant environmental penalties. Irrigation has been excluded as a viable management practice for energy crop production. All land east of the rain gradient has been included in POLYSYS, but land to the west has been excluded. Future genetic improvements in energy crops could, however, extend this range.

A POLYSYS model run using assumptions that optimize the yield of biomass was used for NEMS.²⁶ These assumptions apply only to the acreage under CRP programs and not to acreage currently planted, in pasture, or idle. Different management practices are assumed for CRP and non-CRP acres, because the CRP acres are among the most environmentally sensitive cropland and because CRP is explicitly an environmental program.

Energy crop yields in the supply curve vary within and between States and are based on field trial data and expert opinion. [Table 5](#) shows the energy crop yield assumptions that have been used for POLYSYS. The variation in yields is due to differences in weather and soil conditions across the country. The lowest yields are assumed to be in the Northern Plains and the highest in the heart of the corn belt, as is the pattern observed with traditional crops. In addition, POLYSYS assumes that different varieties of switchgrass, hybrid poplar, and willow are produced in different parts of the country, with different yield assumptions. Energy crop production costs are estimated using the same full-cost accounting approach that is used by USDA to estimate the cost of producing conventional crops.²⁷ The approach includes both fixed costs (such as equipment) and variable costs (such as labor, fuel, seed, and fertilizers).

Switchgrass stands are assumed to remain in production for 10 years before replanting, to be harvested annually, and to be delivered as large round bales. The plants can regenerate, and the same plant can continue to produce switchgrass for up to 10 years. It is assumed that new switchgrass varieties will have been developed after 10 years, and that it will be financially beneficial to plow under the existing switchgrass stand and replant with a new variety. Once established, a switchgrass field could be maintained in perpetuity, but the advantages of new, higher yield varieties would warrant periodic replanting.

Hybrid poplars are assumed to be planted at spacings of 8 feet by 10 feet (545 trees per acre) and to be harvested after 6, 8, and 10 years of growth in the Pacific Northwest, southern United States, and northern United States, respectively. Harvesting is assumed to be by custom operation, and the product is assumed to be delivered as whole tree chips.

Willow production is assumed only in the northern United States. Willows can technically be grown throughout the entire eastern United States, but limited research has been done for areas outside the Northeast and North Central regions. Willows are produced in a coppice system with a replant every 22 years. They are planted in 2 x 3 double rows (6,200 trees per acre) with first harvest in year 4 and subsequent harvests every 3 years for a total of 7 harvests. Willow is delivered as whole tree chips.

In terms of product quality, hybrid poplar and willow contain about 45 to 50 percent moisture when harvested. The trees would typically be fed into a wood chipper, which generally would provide chips between 0.5 and 1 inch square and less than 0.25 inch thick. Switchgrass is harvested at about 15 percent moisture, baled, and generally ground in a tub grinder before use.

It is assumed in POLYSYS that energy crops are produced if they generate a profit equal to or greater than those earned for existing agricultural uses of cropland. Energy crops compete for land not only with existing uses but also with each other. Under the assumed yields and management practices, switchgrass dominates the biomass supply curve due to higher average yields and lower average production costs than hybrid poplar or willow. POLYSYS provides an estimate of the farm-gate price. To that price, an average transportation cost of \$10 per dry ton (1997 dollars) is added to determine the plant-gate price.

Forestry Residue Supply Curve

The forestry residue supply curve was derived on the basis of work done by the USDA Forest Service (USDA-FS) and ORNL. The ORNL estimate of the availability of forestry residues is based on a 1984 USDA-FS study by McQuillan et al.,²⁸ which analyzed several types of data, including forestry inventory, logging and chipping costs, hauling distances and costs, stocking densities, wood types, slope, and equipment operability constraints. The McQuillan study is the only such analysis with national coverage. More recent studies exist, but they are local or regional in scope. The fundamental approach used in the McQuillan study still remains valid.

The input data were used to estimate regional supply schedules for softwood and hardwood chips for 1983 and to provide projections for 1990, 2010, and 2030. The USDA-FS study used estimates of "recoverability factors" that reduced the size of the inventory. Recoverability is used to account for the accessibility of the resource (i.e., existence of roads), whether the resource occurs in stands that are available, and how much of the resource can be retrieved (taking into account gathering problems with small pieces, breakage, etc.). The original data for the study came from a national inventory of "waste wood," which was defined as logging residues, rough rotten salvable wood, excess sapling, and small pole trees.

The forestry residue supply curve used in NEMS is based on the 1984 USDA-FS analysis and a 1994 ORNL study by Turhollow and Cohn,²⁹ which was revised in 1995 by Decision Analysis Corporation under contract to EIA.³⁰ The amount of waste wood available has been updated using the most recent USDA-FS inventory data. Other adjustments to reflect the availability of waste wood include (1) the exclusion of sapling and small pole trees, (2) changes to the recoverability factors, (3) the addition of a nominal stumpage fee, and (4) conversion from 1980 dollars to 1998 dollars based on an index of agricultural prices paid. The modifications were implemented by ORNL, based on the following rationale:

1. Saplings as a source of waste wood generally do not become available below costs of \$6 per million Btu (1998 dollars). Because of the relatively high cost of recovering sapling waste wood, it was excluded from the updated supply curves. The USDA-FS defines polewood as trees with greater than 5 inch dbh (diameter breast high) but smaller than saw timber trees. Although large quantities of pole trees become available at costs of about \$3.60 per million Btu (1998 dollars) or higher, the polewood has potential to grow into future pulpwood or future saw timber inventory and, therefore, is not likely to be harvested by the forest products industry.

2. The recoverability factor is a resource reduction factor that takes into account three site-specific considerations: retrieval efficiency due to technology or equipment, site accessibility or existence of roads, and steepness of slopes. In modifying the recoverability factors, ORNL did not change the retrieval efficiency assumptions from those in the USDA-FS study (i.e., 50 percent of inventory is assumed to be recoverable); however, ORNL's changes to the site access and steep slope factors reduced the inventory of softwood and hardwood that could potentially be recovered to 54 percent and 43 percent of the existing inventory, respectively. ORNL assumed that cable or helicopter logging would be necessary on steep slopes, and that in either situation it would not be economical to haul out much of the low-value wood, such as cull or branches.

3. For live cull, sound dead wood, and logging residues a stumpage fee of \$2 per dry ton was assumed. The stumpage fee represents a cost to acquire the materials, based on data that was provided to ORNL by USDA's Southern Research Station.

4. ORNL subtracted the cost of transporting forestry residues from collection sites to power plants. Therefore, the ORNL data for forestry residues represent the supply schedule at the collection point (i.e., at the edge of the forest). EIA assumes a transportation cost from the collection point to the power plant of \$10

per dry ton, which is added to the forestry residue supply curve from ORNL. This constant transportation cost is applied to all regions in all years for agricultural residues, forestry residues, and energy crops.

The spatial distribution of agricultural residues, energy crops, and forestry residues varies considerably. Transportation costs are dependent on spatial distribution and on the quantity needed by a facility.³¹ Therefore, the estimation of transportation costs is highly problematic for these resources. For example, the estimated transportation cost for supplying switchgrass to hypothetical facilities in Tennessee varies by 50 percent among facilities of the same size and increases on average by 30 percent when the facility demand changes from 100,000 dry tons per year to 630,000 dry tons per year. Similar or even larger variations can be expected with agricultural residues, because less is removed per acre at harvest, and thus the hauling distances would have to be greater to supply a given quantity of feedstock. There are also regional differences that result from differences in road regulations and labor costs.

Estimating transportation costs for forestry residues is especially difficult, because they vary significantly depending on whether the chips are hauled on primary or secondary roads. There are no national studies that have examined the variations in transportation costs for different feedstocks, different regions, and different facility demands. For this reason, a uniform transportation cost of \$10 per dry ton was assumed. The transportation cost for urban wood waste/mill residues, which are point sources of biomass, is calculated somewhat differently, as described below.

Urban Wood Waste and Mill Residue Supply Curve

Most of the residues in this category are waste wood from manufacturing operations and wood that would otherwise be landfilled. Antares Group, Inc., performed this analysis for EIA. Antares estimated the State-by-State available supplies of urban wood waste and mill residues. Urban wood waste is further broken down into wood yard trimmings, construction residues, demolition residues, and other waste wood, including discarded consumer wood products. The mill residues are further broken down into bark residues and wood residues, both from primary mills. When available, State-level data from existing reports were used to construct supply curves of urban wood waste and mill residues. When published State-level data were not available, quantities were estimated by disaggregating reported national quantities. The disaggregation from national to State-level data was done by using accepted "indicators" (such as housing start data) that are correlated with residue generation.

The cost at which these residues can be obtained was estimated using processing costs, State-specific landfill tipping fees, and transportation costs. If a residue is typically landfilled, it was assumed that a 50-percent reduction in tipping fees would be offered at a waste collection facility as an incentive for people to take their wood waste to the collection facility instead of a landfill. The maximum distance beyond which transporting the residues would become prohibitive was assumed to be 100 miles from a potential biopower site. Costs were estimated for each residue type for hauling distances of 25, 50, 75, and 100 miles.

An important assumption in this analysis, made by Antares, was that urban wood waste and mill residues would be considered to be available only if they are not currently being used for other productive purposes. In other words, it was assumed that if urban wood waste and mill residues are currently being used for any purpose, it would not be economically attractive to divert them to electricity generation at any price.

Table 6 shows representative characteristics for different subcategories of urban wood waste and mill residues. The collection and processing costs are obtained from the available literature. While these are average collection and processing costs, the actual costs are expected to range from \$0 to \$8 per wet ton for mill residues and from \$10 to \$14 per wet ton for urban residues. A transportation cost is added to the collection and processing costs. The total expenditure in local transportation costs in 1996 was reported to be \$122 billion (in 1996 dollars).³² Local trucking accounted for 506 billion ton-miles in 1996.³³ This implies a national average local freight charge of about \$0.24 per ton-mile (1996 dollars). For distances of 50, 75, and 100 miles around a co-firing facility, this would translate to transportation costs of \$12, \$18, and \$24 per dry ton (\$0.70, \$1.05, and \$1.40 per million Btu), respectively.

The national average was converted to State averages using transportation price indexes for different geographical areas. For pallets, construction debris, and demolition debris, a particular State's major urban-based transportation indexes were used. For primary mill residues, the State's lowest transportation index

was used to reflect the more rural nature of the location of wood processing centers. A supply curve for urban wood waste and mill residues was constructed using this methodology.

Supply Curve Uncertainties

Although a significant amount of effort has gone into estimating the available quantities of biomass supply, the following uncertainties still are associated with the numbers:

- Perhaps the most significant uncertainty is the value of competing uses of biomass materials. For example, the mulch market consumes large amounts of waste biomass material. Different qualities of mulch are available at different prices. How much mulch and other biomass-derived materials can be diverted from their current markets into electricity generation and the prices at which such reallocations might take place are not well understood.
- In agricultural waste, the significant uncertainty is in the impact of biomass removal on soil quality. A general consensus in the farming community that more agricultural residues need to be left on the soil to maintain soil quality could result in significant losses of biomass for electric power generation purposes.
- In forestry residues, the unknown factor is the impact of changes in forest fire prevention policies on biomass availability. A policy whereby the vegetation in forests is reduced to minimize the potential for forest fires could significantly increase the quantity of forestry residues available.
- Similarly, while the amount of material that is recycled from municipal solid waste streams has steadily grown, it is generally recognized that a significant portion of the municipal solid waste stream is still landfilled. An aggressive attempt to recycle more of the municipal solid waste stream might translate into less available biomass for electricity generation.

Given these uncertainties, the current supply curves represent our best understanding of the availability of biomass at this point in time. Responses of the biomass, solid waste, agricultural waste, and forestry communities to market changes will determine the ultimate availability of biomass materials in the United States.

Implementation in NEMS

NEMS represents both dedicated biomass (BIGCC) and biomass co-firing plants for new capacity. BIGCC is treated in the same way as any other generation option in NEMS. In addition to the supply curves, which provide feedstock costs, NEMS needs the following BIGCC-specific inputs in order to generate the biomass forecast: capital cost, operating and maintenance cost (fixed and variable), project life, production tax credits, and heat rate. [Table 7](#) shows the overnight capital costs assumed for BIGCC projects in the AEO2002 reference case. BIGCC plants are assumed to have a 4-year construction lead time. Therefore, for projects initiated in 2001, the earliest time that a plant could come on line would be 2005. The BIGCC capital cost assumption in the reference case is derived from a 1997 estimate published by DOE and the Electric Power Research Institute.³⁴ The DOE/EPRI costs are adjusted upward to take into account greater uncertainties concerning the costs for the gasification portion of the plant as opposed to the gas conditioning/power generation portion of the plant. EIA assumptions are used in place of the published values for interest during construction and contingency costs. [Figure 3](#) shows the capital costs used in NEMS for biomass, compared with the costs used for several other technologies. BIGCC, at \$1,536 per kilowatt, has a relatively high capital cost in comparison with coal- and natural-gas-based generation technologies. BIGCC capital costs are higher than coal IGCC capital costs mainly as a result of the need for additional feed preparation equipment. Capital costs are assumed to decline over time as more units are built.

Biomass co-firing is represented in NEMS by assuming that coal-fired capacity can be retrofitted for biomass co-firing at levels up to 5 percent on a heat input basis. It is assumed that, for such low levels of co-firing, no additional capital or operating and maintenance costs would be incurred. The biomass would be commingled with coal, and the mixture would be fed into the boiler through the existing coal feed system. Therefore, no new capital expenditure would be required. The existing coal feedlot operators would be able to manage the

tasks of mixing biomass and coal without the need for additional labor.

It is also assumed that the biomass co-firing limits will vary by region (Table 8). The regional limits are based on the availability of biomass and of coal-fired capacity. These are the maximum upper bounds on biomass co-firing. NEMS chooses lower levels of co-firing, depending on the other generation options available in each region. It has been suggested, based on demonstration-scale tests, that biomass co-firing could be carried out at higher levels by incurring an incremental capital cost.³⁵ Incorporation of this capability into NEMS is currently being investigated.

NEMS Projections

AEO2002 Reference Case

Figure 4 shows the AEO2002 reference case projection for biomass use in electricity generation. Biomass continues to be the largest nonhydroelectric renewable technology throughout the forecast horizon, growing from a capacity of about 6.7 gigawatts in 2000 to about 10.4 gigawatts by 2020, including dedicated biomass and industrial cogeneration (Table 9).³⁶ In comparison, wind capacity, which has a much lower utilization rate than biomass, is projected to grow from about 2.4 gigawatts in 2000 to 9.1 gigawatts in 2020. Similarly, generation from biomass grows from 38.0 billion kilowatthours in 2000 to 64.3 billion kilowatthours by 2020 (Table 10).

AEO2002 High Renewables Case

AEO2002 also includes a high renewables case that assumes more favorable cost and performance characteristics for nonhydroelectric renewable energy technologies, including biomass, than are assumed in the reference case. The assumptions in the high renewables case include lower capital costs, lower operating and maintenance costs, and increased availability of biomass fuel supplies. Capital costs are assumed to be similar to those in the publication *Renewable Energy Technology Characterizations*.³⁷ The costs are about 3 percent lower than those assumed in the reference case in the early years of the forecast period due to more optimistic assumptions about the costs for the gasification portion of the plant. In addition, it is assumed that operation and maintenance costs would be 14 percent lower than in the reference case, also based on the same document. The biomass supplies are increased by 10 percent at each step of the supply curve. Fossil and nuclear technology assumptions remain unchanged from those in the reference case.

The basic trends in the high renewables case are similar to those in the reference case, but biomass capacity increases to 12.3 gigawatts by 2020 instead of 10.4 gigawatts in the reference case (Table 9). Generation from biomass plants increases to 76.0 billion kilowatthours by 2020, as compared with 64.3 billion kilowatthours in the reference case (Table 10).

10% and 20% RPS Cases

EIA has analyzed the impact of imposing 10-percent and 20-percent renewable portfolio standards by 2020.³⁸ The 10% RPS case assumed that a legislatively mandated nationwide RPS would require 10 percent of the Nation's electricity to be generated from nonhydroelectric renewable energy sources in 2020 and beyond. Similarly, the 20% RPS case assumed that a legislatively mandated nationwide RPS would require 20 percent of the Nation's electricity to be generated from nonhydroelectric renewable energy sources in 2020 and beyond. The RPS cases assumed the same NO_x and SO₂ caps as mandated by the Clean Air Act Amendments of 1990, which is the assumption made in the AEO2002 reference case.

The biomass supply curves used for the RPS cases are the same as those used for the AEO2002 reference case. The emissions caps are applied only to the electricity generation sector (excluding cogenerators) and are assumed to cover emissions from both utility-owned and independently owned electric power plants. In the 20% RPS case, as a result of the assumed nationwide legislative mandate, renewables are projected to enter the market much more rapidly than in the reference case (Tables 9 and 10). Figure 5 shows projected biomass consumption in the different cases. In the 20% RPS case, dedicated biomass is projected to provide 3.8 quadrillion Btu of energy for electricity generation by 2020. An additional 0.7 quadrillion Btu of biomass

energy is projected to be consumed for co-firing and as ethanol derived from cellulose. Ethanol from cellulose utilizes biomass from the same supply curve as dedicated biomass and biomass co-firing, and thus the three biomass applications compete with each other for their respective feedstocks.

The growth of biomass generation depends on the level of renewables required by the RPS. A low RPS requirement (such as 10 percent or less by 2020) would first be met by wind, which is more economical than biomass. In addition, biomass co-firing with coal is sensitive to the growth of other electricity generation technologies. In general, biomass co-firing with coal is more economical than biomass gasification; however, it is less economical than biomass gasification in scenarios where large amounts of coal-fired capacity are projected to be retired, such as cases which assume that U.S. emission reduction targets under the Kyoto Protocol will be met exclusively through reductions in domestic carbon dioxide emissions. In the 20% RPS case, biomass gasification grows substantially by 2020, and this translates into a large demand for biomass feedstocks, which increases the feedstock cost for co-firing, making the use of biomass for co-firing uneconomical relative to biomass gasification.

The projected growth of biomass consumption in the 20% RPS case raises the question of whether or not there would be sufficient land to sustain the required level of biomass production. An analysis of the results of the 20% RPS case shows that there would be a requirement for approximately 9.6 to 14.4 million acres of land devoted to energy crops by 2020, depending on the yield obtained.³⁹ There were 932 million acres of land in U.S. farms and ranches in 1997. The acreage devoted to farms and ranches has been declining steadily since the 1950s, at a rate of about 4.9 million acres per year.⁴⁰ It is possible to grow biomass energy crops on CRP lands. Under the Farm Security and Rural Investment Act of 2002, signed into law on May 13, 2002, the acreage that can be enrolled in the CRP has been increased to 39.2 million acres. Therefore, in the 20% RPS case, if all the energy crops were planted on CRP land, approximately 24 percent to 37 percent of the CRP land would have to be devoted to energy crop production by 2020. Land use for biomass-based energy consumption is not expected to conflict with land requirements for crop production, because the land requirements for energy crops are far smaller and less than the land that has been removed from agricultural production as a result of improvements in farm productivity.

Conclusion

EIA's estimation of biomass resources shows that there are 590 million wet tons (equivalent to 413 million dry tons) of biomass available in the United States on an annual basis. Historically, biomass consumption for energy use has remained at low levels, although it is the largest nonhydroelectric renewable source of electricity in the United States (considering both industrial cogeneration from biomass and electricity sector generation). The main impediment has been the cost of obtaining the feedstock. Of the estimated total resource of 590 million wet tons, only 20 million wet tons (equivalent to 14 million dry tons, or enough to supply about 3 gigawatts of capacity) is available today at prices up to \$1.25 per million Btu.

Biomass use for power generation is not projected to increase substantially by 2020 in the AEO2002 reference case because of the cost of biomass relative to the costs of other fuels and the higher capital costs relative to those for coal- or natural-gas-fired capacity. Slightly more growth is projected in the high renewables case, but the difference from the reference case projection is relatively small. In the 20% RPS case, significantly more use of biomass for electricity generation is projected than in the reference case, because electric utilities would be required to generate a portion of their power from renewable resources, including biomass.

E-Mail Subscription

EIA Home
Contact Us

ATTACHMENT F1
FLORIDA PSC & DEPT. OF ENVIRONMENTAL PROTECTION
“ASSESSM’T OF RENEWABLE ELEC. GENERATING TECHNOLOGIES FOR FLORIDA”
JANUARY 2003

**Florida Public Service Commission
and
Department of Environmental Protection**

**“An Assessment of Renewable Generating
Technologies for Florida”**

January 2003



An Assessment of Renewable Electric Generating Technologies for Florida

PREPARED BY THE

Florida Public Service Commission and the
Department of Environmental Protection

JANUARY 2003

Cost Considerations of Renewable Resources

Renewable fueled generating technologies ultimately must compete with traditional generating technologies to sustain themselves as a viable alternative resource. Presently, renewable technologies are, for the most part, more expensive than the incremental generating unit that would be built to serve electric customers. Due to advances in jet engine technologies, the electric industry's preferred generating technology to serve peak load is a natural gas fired combustion turbine generator operating in a simple cycle mode. When a more base loaded type generator is needed the simple cycle can be connected to a heat recovery unit to capture the high temperature exhaust gases from the turbine, which in turn produces steam that is also used to produce electricity. While natural gas is the preferred fuel for these kinds of machines, oil and coal that have been converted into a gas can also be used as fuels.

Proponents of renewable technologies point out that renewables have certain desirable characteristics which may not always be appropriately captured by bottom line production costs. They cite the modular nature of many technologies, the fact that renewables do not use coal, oil, natural gas, or nuclear fuels, and that fuel input costs are either negligible or have less volatility than fossil based fuels. On the other hand, some renewables have characteristics which may diminish their economic value. Intermittent resources like solar and wind are sometimes harder to incorporate into reserve requirements. Some renewables that are remote from load centers may require transmission upgrades to get the energy to customers and there may be line losses associated with moving the power. Finally, while distributed resources can be helpful for certain aspects of distribution stability, power quality must be maintained.

Chapter III provides a discussion of the various life cycle cost estimates for renewable resources.

Environmental Considerations of Renewable Resources

Many people assume that by definition renewable resources are "cleaner" or have less environmental impacts than non-renewable resources. Such assertions should be carefully examined. All energy infrastructure has some kind of impacts. The challenge is to evaluate the relative seriousness of various impacts and how to best mitigate them. For example, windmills have no air emissions associated with combustion processes, but where they are sited has generated controversy on the aesthetic issues associated with their construction.⁷ Likewise, MSW facilities, while deemed renewable by definition in this statute, often are opposed because of the combustion process involved in producing electricity. The air emission profile for a MSW facility would look more similar to a conventional fossil fueled unit depending on the vintage of the unit. Here again, this report discusses the environmental characteristics of various renewable technologies, but does not attempt to assign a single, unidimensional ranking in terms of their qualitative impacts on the environment.

An emission profile of regulated air emissions was established for Florida's current "fleet" of renewable resource electrical generators, and is presented in Figure 4. It should be noted that this chart reflects actual data reported during the year 2001, for existing Florida generating units

⁷ "Cape Cod: Twisting in the Wind," *Public Utilities Fortnightly*, May 15, 2002, Vol. 140, No. 10.

One conclusion which can be reached, is that most of Florida's current fleet of electrical generating units constructed primarily for the purpose of combusting renewable fuels are at least as clean, with respect to regulated emissions, as Florida's existing coal- and oil-fired units (which includes grandfathered units). However, combined cycle natural gas-fired units clearly emit the lowest amount of air pollutants per MWh generated of all existing carbon-based fuels. Modern natural gas-fired combined cycle power plants emit nearly no sulfur dioxide and about 3 parts per million of nitrogen oxides.

Concerning thermal emissions, each of the above types of generating units (whether fossil or renewable fuel-fired) is responsible for heat being emitted to the air and, in some cases, water bodies. Additionally, modern units of each type are typically designed as zero discharge facilities, implying that no wastewater streams exist. Older units, however, represent a source of wastewater discharges.

The waste streams to land associated with each technology can also vary. As a general rule, waste streams are higher for solid fuels than liquid fuels, with gaseous fuels having nearly no ash. For example, the quantities of ash generated from the combustion of MSW and RDF are typically double that of coal combustion. Ash generated from the combustion of coal is roughly equivalent to that of bagasse, wood or bark, per MWh of electricity produced. Comparably speaking, fuels such as petcoke and oil generate very low quantities of ash (perhaps five percent that of coal), while the generation of ash from the combustion of natural gas and landfill gas is essentially zero.⁸

Figures 4 and 5 do not include carbon dioxide emissions because carbon dioxide is currently not a regulated pollutant in the U.S. Nevertheless, many scientists, and perhaps a majority of scientists, believe that carbon dioxide emissions are the principal anthropogenic contributor to global warming. There are active discussions nationally and internationally regarding whether or not carbon dioxide emissions should be regulated. Indeed, the U.S. has agreed to voluntarily monitor and report the annual inventory of carbon dioxide emissions. To this end, the U.S. Environmental Protection Agency publishes an annual report entitled *Inventory of U.S. Greenhouse Gas Emissions and Sinks*.

⁸ For additional information regarding waste streams see the U.S. Environmental Protection Agency's Report to Congress dated March, 1999 entitled *Wastes from the Combustion of Fossil Fuels Volume 2 – Methods, Findings, and Recommendations*.

Black and Veatch provided Table 10 which lists typical ranges of performance and costs for a facility directly burning 2,000 tons of waste per day.

Questionnaire responses were received from the representatives of 12 operating direct combustion MSW generators within Florida, as well as one potential site. Net summer plant capacity ratings of the units ranged from 10 MW to 75.5 MW. Most questionnaires indicated that it is technically feasible to dispatch the unit. However, several cited contract provisions which currently prevent the unit from being dispatched, or make it uneconomical for the generator to do so. Only one of the responses included cost data, citing a \$6,500 per kW capital cost. Performance data is comparable to the Black and Veatch data above. Heat rates for the units ranged from 13,300 to 18,000 Btu per kWh, with capacity factors of between 78 and 95 percent. MSW plants have negative fuel costs in that they are paid to take waste materials. Each respective municipality pays a tipping fee to the generator to deliver MSW. One response provided a fuel cost of negative \$4.23 per Mbtu, indicating a tipping fee is received by the generator from the municipality.

TABLE 10
PRODUCTION COSTS FOR
50 MW MSW Generator

Plant Capacity	50 MW
Net Plant Heat Rate	16,000 Btu per kWh
MSW tons per day	2,000
Capacity Factor	60 to 80 percent
Capital Cost	\$2,500 to \$4,600 per kW
Fixed O&M	\$100 to \$175 per kWyear
Variable O&M	\$25 to \$50 per MWh
Levelized Cost	3.5 to 15.3* cents per kWh

This assumes a \$25 per ton tipping fee. Information presented by Integrated Waste Services Association indicates that for Florida plants a \$50 per ton fee is more typical and thus production costs could be closer to 2¢.

Landfill Gas

Landfill gas is one of the more mature options for obtaining energy from municipal wastes. Many landfill sites within Florida already have gas collection technology installed in order to meet Federal Clean Air and New Source Performance Standards. Energy Developments, Ltd., stated that for every 1 million tons of municipal solid waste in a landfill, enough gas is produced to fuel approximately 1 MW of generating capacity, yielding about 8,500 MWhs.²² The capital costs for landfill gas projects is dependent on site characteristics, the conversion technology used, and the extent of the collection systems already in place. However, according to Black and Veatch, the payback period for landfill gas sites is often between 2 and 5 years. Capacity factors can vary greatly depending on the technology used to convert the landfill gas into electricity. Data provided by workshop participants and on questionnaire responses indicates that landfill gas projects are not available for utility dispatch.

²² David R. Wentworth, Energy Developments, Ltd., *Landfill Gas to Electricity Development in the State of Florida*. Presentation at the FPSC Staff Renewable Assessment.

ATTACHMENT F2
U.S. ENVIRONMENTAL PROTECTION AGENCY
“ELECTRICITY FROM MUNICIPAL SOLID WASTE”
NOVEMBER 2006

U.S. Environmental Protection Agency
“Electricity from Municipal Solid Waste”

November 2006



U.S. Environmental Protection Agency


Clean Energy

[Contact Us](#) | [Print Version](#)

Search:

GO[EPA Home](#) > [Clean Energy](#) > [Impacts](#) > Electricity from Municipal Solid Waste[Clean Energy Home](#)[Energy & You](#)[How does electricity use affect the environment?](#)[How clean is the electricity I use?
Power Profiler](#)[How can I reduce my impact?](#)[Clean Energy Programs](#)[Clean Energy Tools](#)[Clean Energy Events](#)[Newsroom](#)[Glossary](#)[Links](#)[Site Map](#)

Electricity from Municipal Solid Waste



Municipal solid waste (MSW) refers to the stream of garbage collected through community sanitation services. Medical wastes from hospitals and items that can be recycled are generally excluded from MSW used to generate electricity. Paper and yard wastes account for the largest share of the municipal waste stream,¹ and much of this can be recycled directly or composted.

Currently, over 30 percent of MSW generated in the United States is recycled annually. While not producing this waste in the first place is the preferred management strategy for this material, recycling is preferred over any method of disposal. The majority of MSW that is not recycled is typically sent to landfills after it is collected. As an alternative, MSW can be directly combusted in waste-to-energy facilities to generate electricity. Because no new fuel sources are used other than the waste that would otherwise be sent to landfills, MSW is often considered a renewable power source. Although MSW consists mainly of renewable resources such as food, paper, and wood products, it also includes nonrenewable materials derived from fossil fuels, such as tires and plastics.

Environmental Impacts of:
Natural Gas
Coal
Oil
Hydroelectricity
Non-Hydro Renewable
Nuclear Energy

At the power plant, MSW is unloaded from collection trucks and shredded or processed to ease handling. Recyclable materials are separated out, and the remaining waste is fed into a combustion chamber to be burned. The heat released from burning the MSW is used to produce steam, which turns a steam turbine to generate electricity.

The United States has about 89² operational MSW-fired power generation plants, generating approximately 2,500 megawatts, or about 0.3 percent of total national power generation. However, because construction costs of new plants have increased, economic factors have limited new construction.

Environmental Impacts

Although power plants are regulated by both federal and state laws to protect human health and the environment, there is a wide variation of environmental impacts associated with power generation technologies. The purpose of the following section is to give consumers a better idea of the specific air, water, land, and solid waste impacts associated with MSW-fired electricity generation.

Air Emissions Impacts

Burning MSW produces nitrogen oxides and sulfur dioxide as well as trace amounts of toxic pollutants, such as mercury compounds and dioxins. Although MSW power plants do emit carbon dioxide, the primary greenhouse gas, the biomass-derived portion is considered to be part of the Earth's natural carbon cycle. The plants and trees that make up the paper, food, and other biogenic waste remove carbon dioxide from the air while they are growing, which is returned to the air when this material is burned. In contrast, when fossil fuels (or products derived from them such as plastics) are burned, they release carbon dioxide that has not been part of the Earth's atmosphere for a very long time (i.e., within a human time scale).

The average air emission rates in the United States from municipal solid waste-fired generation are: 2988 lbs/MWh of carbon dioxide, (it is estimated that the fossil fuel-derived portion of carbon dioxide emissions represent approximately one-third of the total carbon emissions) 0.8 lbs/MWh of sulfur dioxide, and 5.4 lbs/MWh of nitrogen oxides.³

The variation in the composition of MSW affects the emissions impact. For example, if MSW containing batteries and tires are burned, toxic materials can be released into the air. A variety of air pollution control technologies are used to reduce toxic air pollutants from MSW power plants.

There can be significant greenhouse gas reduction benefits from recycling and source reduction when compared to other management options. Note also that over 1.6 million ton of ferrous and non-ferrous metals, plastics, glass and combustion ash are recycled annually.⁴

Water Resource Use

Power plants that burn MSW are normally smaller than fossil fuel power plants but typically require a similar amount of water per unit of electricity generated. When water is removed from a lake or river, fish and other aquatic life can be killed, affecting those animals and people who depend on these resources.

Water Discharges

Similar to fossil fuel power plants, MSW power plants discharge used water. Pollutants build up in the water used in the power plant boiler and cooling system. In addition, the cooling water is considerably warmer when it is discharged than when it was taken. These water pollutants and the higher temperature of the discharged water can upon its release negatively affect water quality and aquatic life. This discharge usually requires a permit and is monitored. For more information about these regulations, visit EPA's Office of Water Web site.

Solid Waste Generation

The combustion of MSW reduces MSW waste streams, reducing the creation of new landfills. MSW combustion creates a solid waste called ash, which can contain any of the elements that were originally present in the waste. MSW power plants reduce the need for landfill capacity because disposal of MSW ash requires less land area than does unprocessed MSW. However, because ash and other residues from MSW operations may contain toxic materials, the power plant wastes must be tested regularly to assure that the wastes are safely disposed to prevent toxic substances from migrating into ground-water supplies. Under current regulations, MSW ash must be sampled and analyzed regularly to determine whether it is hazardous or not.⁵ Hazardous ash must be managed and disposed of as hazardous waste. Depending on state and local restrictions, non-hazardous ash

may be disposed of in a MSW landfill or recycled for use in roads, parking lots, or daily covering for sanitary landfills.

Land Resource Use

MSW power plants, much like fossil fuel power plants, require land for equipment and fuel storage. The non-hazardous ash residue from the burning of MSW is typically deposited in landfills.

Fuel Reserves

U.S. residents, businesses, and institutions produced more than 229 million tons of MSW in 2001, which is equivalent to approximately 4.4 pounds of waste per person per day. In 2001, 33.6 million tons (14.7 per cent) of MSW were combusted.⁶

1. U.S. EPA, Office of Solid Waste, *Basic Facts*.
2. A Look at Waste-to-Energy/Maria Zannes, IWSA; presented at the NAWTEC Fall 2004 Meeting, Columbia University, NYC.
3. U.S. EPA, *Compilation of Air Pollutant Emission Factors (AP-42)*.
4. Kiser, Jonathan V. L., *Recycling and Waste-to-Energy: The Ongoing Compatibility Success Story*, [EXIT: Disclaimer](#) *MSW Management*, May/June 2003.
5. U.S. EPA, Office of Solid Waste, *MSW Disposal*.
6. *Municipal Solid Waste in the United States: 2001 Facts and Figures*. EPA530-S--011.

[EPA Home](#) | [Privacy and Security Notice](#) | [Contact Us](#)

Last updated on Friday, January 12th, 2007
URL: <http://www.epa.gov/cleanenergy/muni.htm>

ATTACHMENT G1
RTI INTERNATIONAL
“BEYOND-THE-FLOOR ANALYSIS FOR EXISTING AND NEW COAL- AND OIL-FIRED
ELECTRIC UTILITY STEAM GENERATING UNITS NATIONAL EMISSION
STANDARDS FOR HAZARDOUS AIR POLLUTANTS”
DECEMBER 2003

RTI International

**“Beyond-the-Floor Analysis for Existing and
New Coal- and Oil-Fired Electric Utility
Steam Generating Units National Emission
Standards for Hazardous Air Pollutants”**

December 2003

TO: Bill Maxwell, U.S. Environmental Protection Agency, OAQPS (C439-01)

FROM: Jeffrey Cole, RTI International

DATE: December 2003

SUBJECT: Beyond-the-floor analysis for existing and new coal- and oil-fired electric utility steam generating units national emission standards for hazardous air pollutants

This memorandum describes the development of the beyond-the-floor analysis for existing and new coal- and oil-fired electric utility steam-generating units National Emission Standard for Hazardous Air Pollutants (NESHAP). In this memorandum, we considered available regulatory options (i.e., technologies or work practices) that were more stringent than the MACT floor level of control for each of the different subcategories that make up the Electric Utility source category.

OUTLINE

- 1.0 Introduction
- 2.0 Beyond-the-floor Options for Existing Coal- and Oil-fired Electric Utility Steam Generating Units
 - 2.1 Coal-fired Units
 - 2.2 Integrated-coal Gasification Combined Cycle Units
 - 2.3 Coal Refuse-fired Units
 - 2.4 Oil-fired Units
- 3.0 Beyond-the-floor Options for New Coal- and Oil-fired Electric Utility Steam Generating Units
 - 3.1 Coal-fired Units
 - 3.2 Integrated-coal Gasification Combined Cycle Units
 - 3.3 Coal Refuse-fired Units
 - 3.4 Oil-fired Units

1.0 INTRODUCTION

As discussed in the memorandum entitled “MACT Floor Analysis for Coal- and Oil-Fired Electric Utility Steam-Generating Units National Emission Standards for Hazardous Air Pollutants,” the EPA chose to set MACT for mercury (Hg) from existing and new coal-fired electric utility steam-generating units and nickel (Ni) from existing and new oil-fired electric utility steam-generating units. Therefore, this discussion addresses beyond-the-floor control options for existing or new units.

2.0 BEYOND-THE-FLOOR OPTIONS FOR EXISTING COAL- AND OIL-FIRED ELECTRIC UTILITY STEAM GENERATING UNITS

In order to determine possible beyond-the-floor control options for existing units, we analyzed all available emissions data on air pollution control devices (APCD) that are currently utilized or experimental (both full-size and pilot-scale). The following are the possible beyond-the-floor control options for existing units.

2.1 Coal-fired Units

Conventional PM controls (electrostatic precipitators [ESP] and fabric filters) generally do not remove the vapor-phase HAP (i.e., elemental Hg, hydrochloric acid [HCl], and hydrogen fluoride [HF]) from coal-fired unit emissions. This is because these controls do not effectively capture gaseous pollutants. Two technologies that possibly could be used to further reduce the amount of vapor-phase HAP emitted from utilities are sorbent injection and selective catalytic reduction (SCR).¹

2.1.1 Sorbent injection. Due to their multiple internal pores and high specific surface area, sorbents have the potential to improve the removal of Hg (mostly through the capture of elemental mercury (Hg^0 ; sorbents will also remove Hg^{++}) as well as other gaseous pollutants that are carried with combustion fine particulates in all coal-fired subcategories (except for integrated gasification combined cycle [IGCC] units because of their lack of external PM control device).

The extent of the potential Hg removal is dependent on: (1) efficient distribution of the sorbent (e.g., activated carbon) in the flue gas; (2) the amount of sorbent needed to achieve a specific level of Hg removal, which will vary depending on the fuel being burned; (3) the amount of chlorine (Cl) present in the fuel; and (4) the type of PM control device (e.g., at a given sorbent feed rate, a fabric filter provides more Hg control than an ESP because of the additional adsorption that occurs on the bags of the fabric filter because of the increased gas contact time).

Sorbents can be introduced by two basic methods: by channeling flue gas through a bed of sorbent or by direct sorbent injection. Sorbent bed designs consist of fixed-sorbent filter beds, moving beds, or fluidized sorbent filter beds. With direct sorbent injection, after sorbent is introduced into the flue gas, it adsorbs Hg and other contaminants and is captured downstream in an existing or sorbent-specific PM control device. The types of sorbent that may be viable in sorbent injection include two basic types of activated carbon (AC; regular and impregnated) as well as other carbon (mixed with other sorbents) and noncarbon sorbents.

Activated carbon is a specialized form of carbon produced by pyrolyzing coal or various hard, vegetative materials (e.g., wood) to remove volatile material. The resulting carbon-based material (char) then undergoes a steam or chemical activation process to produce an AC that contains multiple internal pores and has a very high specific surface area. With this internal pore structure, the AC can adsorb a broad range of contaminants. Various studies, shown in Table 1, have shown good to excellent Hg removal with the injection of AC (particularly on bituminous-fired units); however, other studies (also shown in Table 1) have not shown good Hg removal (particularly on subbituminous- and lignite-fired units). The Hg removal performance of AC injection seems to be highly dependent on coal rank and composition (i.e., Hg and Cl content of the coal) and specific utility plant configuration (e.g., sequencing of APCD equipment). Further, little long-term data are available.

Chemically impregnated AC is AC that has been supplemented with chemicals to improve its Hg removal. The Hg in the flue gas reacts with the chemical that is bound to the AC, and the resulting compound is removed by the PM control device. Typical impregnants for AC are chlorine, sulfur, and iodide. Chemically impregnated AC has shown enhanced Hg removal over regular AC. Chemically impregnated AC requires smaller rates of carbon injection than does regular AC for equivalent Hg removals. The required carbon-to-mercury mass ratio may be

reduced by a factor of from 3 to 10 with the chemically impregnated AC.² The cost per mass unit of impregnated AC may, however, be significantly greater than that of unmodified AC.

Other commercially available sorbent materials are Sorbalit™ (a mixture of lime with additives and 3 to 5 percent AC) and Darco FGD (an AC derived from lignite).² Zeolites constitute another category of sorbent. There are naturally occurring mineral zeolites, in addition to commercially available synthetic zeolites. Both types contain large surface areas and have a good potential for Hg removal.

The AC test data available to EPA, representing full-scale electric utility units, consists of tests taken at four sites. The sites had initial baseline tests conducted without AC injection in 2001, and parametric tests and long-term test programs conducted in 2002 and 2003 after installation of AC injection. The test sites' sampling description, coal type, control device configuration, and total Hg removal (both the maximum Hg removal during each test and average Hg removal during the entire test period) are listed in Table 1. Even though these tests were taken over an extended period of time, the summary data available show that there appears to be variability in Hg removal results between the maximum Hg removal during each test and the average Hg removal during the entire test period at a given site.

Although AC, chemically impregnated AC, and other sorbents show potential for improving Hg removal over what is achieved with conventional PM and SO₂ controls, this technology is not currently available on a commercial basis and has not been installed, except on a demonstration basis, on any electric utility unit in the United States to date. Further, limited long-term data (e.g., longer than a few days) are available to indicate the performance of this technology on all representative coal ranks or on a significant number of different power plant configurations. Therefore, these technologies do not provide a viable basis for either establishing or going beyond the floor.

2.1.2 Selective catalytic reduction (SCR). The SCR test data available to EPA, representing full-scale electric utility units, consists of tests taken at four sites in 2001, two of the original four sites were then retested in 2002, and finally two additional sites were tested in 2002, for a total of eight sets of data. The test sites' coal type, control device configuration, and total Hg removal (with SCR turned off and SCR operating) are listed in Table 2. The data suggests

that, although designed as a nitrogen oxides (NO_x) control technology, the SCR has ability to transform certain species of Hg into other speciated forms that are easier for conventional PM and SO_2 controls to capture. The transformation of Hg species can be seen most prominently when an SCR is operating at a site with a PM control device and a wet FGD control device or a site with only a single particulate (venturi) scrubber. The Hg emitted during combustion, which would (in the absence of the SCR) tend to remain as Hg^0 , is oxidized to Hg^{++} . The highly soluble oxidized Hg is then removed by the wet FGD or particulate (venturi) scrubber. However, this Hg reduction effect has been observed in limited stack testing on bituminous coal-fired sites (S2 and S4), and results on a subbituminous coal-fired site have not been uniformly successful.³ Sites S1 and S3 showed only minimal Hg oxidation across the SCR. To EPA's knowledge, no commercial-scale, lignite-fired, SCR-equipped unit has been tested to date, though it is entirely possible that greater Hg removal would result when applied to a lignite-fired unit. Similarly, SCR has not yet been tested on all types of coal sources as well as on blends of coal. It should be noted that these tests were of short-term nature and the maximum Hg removal seen may not represent the long-term average observed even at a given site. Also, the data show that SCR does not lead to increased Hg oxidation and removal in all cases on all coal ranks.

In summary, sorbent injection has not been sufficiently demonstrated in practice, nor have long-term economic considerations (e.g., carbon availability, waste disposal issues, and required permitting for new waste landfill and sludge ponds) been evaluated to allow sorbent injection to be considered viable as a beyond-the-floor option. With regard to the use of SCR, there is inadequate effectiveness information on which to base a beyond-the-floor standard.

Table 1. Full-scale Activated Carbon Injection Emission Tests at Coal-fired Electric Utility Sites

Test site, Location	Description of test plan	Coal type	Control device	Maximum Hg removal during each test	Average Hg removal during the entire test period
Alabama Power, Gaston ⁴	Long-term tests over 10 days, constant conditions, are scheduled for 2002-2003.	Bituminous	Hot-side ESP; COHPAC FF	S-CEM: • 90%	S-CEM: • 78% Ontario-Hydro: • 90% total • 86% oxidized • >98% elemental
WE Energies, Pleasant Prairie ⁵	Long-term tests over 10 days, constant conditions. <i>Note: The S-CEM removal efficiencies shown here averages and maximums taken over (1) three days with an average injection rate of 1.6 lbs/MMacf, (2) four days with an average injection rate of 3.7 lbs/MMacf and (3), five days with an average injection rate of 11.3 lbs/MMacf.</i>	Powder River Basin Subbituminous	Cold-side ESP, SCA	S-CEM: • 49%, 61%, and 70%	S-CEM: • 47%, 57%, and 66% Ontario-Hydro: • 72.9% total • 74.5% oxidized • 70.7% elemental
PG&E NEG Salem Harbor Station ³	Parametric tests and long-term tests in Spring 2002.	Bituminous	Cold-side ESP; SNCR	280-290F: 68%, 70% 298-306F: 67%, 75%, 78% 322-327F: 65%, 85%, 85% 343-347F: 25%, 45%	280-290F: 69% 298-306F: 73% 322-327F: 78% 343-347F: 35%
PG&E NEG Brayton Point Station ⁶	Parametric tests and long-term tests in Fall 2002.	Bituminous	2 Cold-side ESP, in series with combined SCA	Hg capture varied based on sorbent and operating conditions.	S-CEM: • 62%

COHPAC - combination of an upstream electrostatic precipitator followed by a high air-to cloth ratio fabric filter

SCA - Specific Collection Area

S-CEM - Semi-Continuous Emissions Monitor

Ontario Hydro - Ontario Hydro speciated mercury analysis method

SNCR - Selective Non-Catalytic Reduction

Table 2. Full-scale SCR Emission Tests at Coal-fired Electric Utility Sites⁷

Site	Coal	Year sampled	PM Control	SO ₂ Control	Total Hg removal, % (w/SCR off: w/SCR on)
S1	Powder River Basin Subbituminous	2001	ESP	None	60 / 78
S2	Ohio Bituminous	2001	ESP	Wet FGD	51 / 88
S2*	Ohio Bituminous	2002	ESP	Wet FGD	NA / 84
S3	Pennsylvania Bituminous	2001	ESP	None	16 / 13
S4	Kentucky Bituminous	2001	Particulate (Venturi) Scrubber	None	46 / 90
S4*	Kentucky Bituminous	2002	Particulate (Venturi) Scrubber	None	44 / 91
S5	West Virginia Bituminous	2002	ESP	Wet FGD	51 / 91
S6	Kentucky & West Virginia Bituminous	2002	ESP	None	No data currently available

* Retest

NA - Not analyzed with SCR off.

2.2 IGCC Units

Integrated gasification combined cycle units are specialized units in which coal is first converted into synthetic coal gas. In this conversion process, the carbon in the coal reacts with water to produce hydrogen gas and carbon monoxide (CO). The synthetic coal gas (syngas) is then combusted in a combustion turbine, which drives an electric generator. Hot gases from the combustion turbine then pass through a waste heat boiler to produce steam. This steam is fed to a steam turbine connected to a second electric generator. Because of their design, IGCC units have no external APCD. Therefore, we believe the best potential way of reducing Hg emissions from existing IGCC units is to remove Hg from the syngas before combustion. An existing industrial IGCC unit has demonstrated a process, using sulfur-impregnated AC carbon beds, that has proven to yield 90 to 95 percent Hg removal from the coal syngas.⁸ This technology could potentially be adapted to the electric utility IGCC units.

To our knowledge, neither of the two existing IGCC units have run tests of this type of carbon bed, fuel cleaning, device. Because of concerns about the costs involved and because existing IGCC units utilize older technology, it is not clear if using sulfur-impregnated AC carbon beds would be effective on the particular syngas burned in these units.

2.3 Coal Refuse-fired Units

Coal refuse units (i.e., 99 percent of their heat input supplied by burning coal refuse) are located adjacent to old coal mine refuse piles. The units are specially designed to burn this high-ash silt. All of the 13 coal refuse-fired units existing in 1999 are equipped with fluidized bed combustors (FBC); 10 of these 13 units inject limestone as a sorbent for SO₂ control, and 4 of these 13 units are equipped with SCR for NO_x control. The only two coal refuse-fired units on which performance tests were conducted in response to the ICR are the MACT floor facilities for the coal-refuse fired subcategory.

To our knowledge, there are no currently available technologies that could be used as beyond-the-floor options for coal refuse units.

2.4 Oil-fired Units

The only emission control technology that we are aware of to consider as a beyond-the-floor option for existing oil-fired units is fabric filtration. Fabric filters have been shown in pilot-scale testing to be more effective at reducing Ni emissions than an ESP. However, the use of fabric filters on oil-fired units is also known to be problematic due to the prevalence of the “sticky” PM emitted from such units, which sticks to the fabric and creates a fire safety hazard. No existing oil-fired units are known to employ fabric filters as their PM control. Because of this, fabric filters are not considered to be a viable beyond-the-floor option for oil-fired units.

3.0 BEYOND-THE-FLOOR OPTIONS FOR NEW COAL- AND OIL-FIRED ELECTRIC UTILITY STEAM GENERATING UNITS

Once the MACT floor determinations were done for new units in each subcategory (by fuel type), EPA considered various regulatory options more stringent than the MACT floor level of control (i.e., additional technologies or other work practices that could result in lower emissions) for the different subcategories. Due to the technical complexities of controlling Hg and Ni emissions from the sources affected by this rule, we have not been able to determine whether (identified) potential beyond-the-floor options are available. The following describes the possible beyond-the-floor options of which we are aware for new units.

3.1 Coal-fired Units

As discussed in Section 2 of this memorandum, two technologies that possibly could be used to further reduce the amount of vapor phase Hg emitted from utilities are sorbent injection and SCR. However, as explained in Section 2, sorbent injection is not available on a commercial basis and has not been demonstrated on a utility unit operating at full capacity over an extended period of time. Similarly, SCR has not shown the same change-in-speciation effect on Hg emissions on all types of coal sources (and among different seams within a coal rank).

3.2 IGCC Units

Because of their design, IGCC units have no external APCD controls. Therefore, as is explained in Section 2 of this memorandum, the best potential way of improving Hg removal from IGCC units is to remove the Hg from the syngas before combustion. Based on published information regarding the industrial IGCC unit noted in Section 2, EPA believes that a 90 percent reduction in Hg emissions is possible from new IGCC units based on the use of carbon bed technology. Therefore, we believe that proposing a 90 percent Hg reduction based on the use of carbon bed technology as a beyond-the-floor level for new IGCC units is reasonable.

3.3 Coal Refuse-fired Units

Existing coal refuse-fired units utilizing 100 percent coal refuse, all of which utilize FBC technology, have demonstrated the best Hg control of any emissions-tested electric utility unit in the industry based on the electric utilities information collection request (ICR).

3.4 Oil-fired Units

There has not been a new oil-fired unit constructed in the United States since 1981. As discussed in Section 2 of this memorandum, if a new oil-fired unit is constructed, the only technology that would offer emissions control better than the proposed new MACT limits for emission control is the use of fabric filtration; however, fabric filtration is not presently considered to be a viable control option for oil-fired units because of the prevalence of the “sticky” PM emitted from these units, which sticks to the fabric and creates a fire safety hazard.

REFERENCES

1. Kilgroe, James D., Charles B. Sedman, Ravi K. Srivastava, Jeffrey V. Ryan, C.W. Lee, and Susan A. Thorneloe. "Control of Mercury Emissions from Coal-fired Electric Utility Boilers: Interim Report." Chapter 5. EPA-600/R-01-109. December 2001.
2. New Jersey Mercury Task Force. "Volume 1: Executive Summary and Recommendations." pp. 50-52. December 2001.
3. Srivastava, Ravi K. "Current and Emerging Mercury Control Technologies." Western Mercury Workshop, April 21-22, 2003, Denver, CO.
4. "Final Site Report for: E.C. Gaston Unit 3: Sorbent Injection into a Cold-Side ESP for Mercury Control" prepared by ADA Environmental Solutions, Report No. 41005R11, May 2003, pp. 31-32.
5. "Final Site Report for: Pleasant Prairie Power Plant Unit 2: Sorbent Injection into a Cold-Side ESP for Mercury Control" prepared by ADA Environmental Solutions, Report No. 41005R12, May 2003, pp. 27-28.
6. Durham, M. "Update on Full-Scale Activated Carbon Injection for Control of Mercury Emissions." Presentation slide show given by ADA Environmental Solutions to Utility MACT Working Group, August 8, 2002. Docket A-92-55, Item No. II-E-81.
7. Laudal, D., P. Chu, L. Brickett, C.W. Lee. "Effect of SCR on mercury Speciation for Coal-fired Power Plants." Presentation by Energy & Environmental Research Center (EERC) University of North Dakota.
8. Rutkowski, M.G., M.G. Klett, and R.C. Maxwell. "The Cost of Mercury Removal from Coal-Based IGCC Relative to a PC Plant." Gasification Technologies 2002 Symposium, October 27-30, 2002, San Francisco, CA. Docket A-92-55, Item No. II-I-23.

ATTACHMENT G2
U.S. DEPARTMENT OF ENERGY
ENERGY EFFICIENCY AND RENEWABLE ENERGY
“NET GENERATION BY ENERGY SOURCE BY TYPE OF PRODUCER”
OCTOBER 2006

U.S. Department of Energy
Energy Information Administration

**“Net Generation by Energy Source by
Type of Producer”**

October 2006



Energy Information Administration

Official Energy Statistics from the U.S. Government

[Glossary](#)

[Home](#) > [Electricity](#) > Net Generation by Energy Source by Type of Producer

Net Generation by Energy Source by Type of Producer

Electric Power Annual with data for 2005

Report Released: October 4, 2006

Next Release Date: October 2007

Table 1.1 [xls](#) [pdf](#) [format](#)

Table 1.1. Net Generation by Energy Source by Type of Producer, 1994 through 2005
(Thousand Megawatthours)


Period	Coal[1]	Petroleum [2]	Natural Gas	Other Gases[3]	Nuclear	Hydroelectric Conventional[4]	Other Renewables[5]	Hydroelectric Pumped Storage[6]	Other [7]	Total
Total (All Sectors)										
1994	1,690,694	105,901	460,219	13,319	640,440	260,126	76,535	-3,378	3,667	3,247,522
1995	1,709,426	74,554	496,058	13,870	673,402	310,833	73,965	-2,725	4,104	3,353,487
1996	1,795,196	81,411	455,056	14,356	674,729	347,162	75,796	-3,088	3,571	3,444,188
1997	1,845,016	92,555	479,399	13,351	628,644	356,453	77,183	-4,040	3,612	3,492,172
1998	1,873,516	128,800	531,257	13,492	673,702	323,336	77,088	-4,467	3,571	3,620,295
1999	1,881,087	118,061	556,396	14,126	728,254	319,536	79,423	-6,097	4,024	3,694,810
2000	1,966,265	111,221	601,038	13,955	753,893	275,573	80,906	-5,539	4,794	3,802,105
2001	1,903,956	124,880	639,129	9,039	768,826	216,961	77,985	-8,823	4,690	3,736,644
2002	1,933,130	94,567	691,006	11,463	780,064	264,329	86,922	-8,743	5,714	3,858,452
2003	1,973,737	119,406	649,908	15,600	763,733	275,806	87,410	-8,535	6,121	3,883,185
2004	1,978,620	120,646	708,979	16,766	788,528	268,417	90,408	-8,488	6,679	3,970,555
2005	2,013,179	122,522	757,974	16,317	781,986	269,587	94,932	-6,558	4,749	4,054,688
Electricity Generators, Electric Utilities										
1994	1,635,493	91,039	291,115	--	640,440	247,071	8,933	-3,378	--	2,910,712
1995	1,652,914	60,844	307,306	--	673,402	296,378	6,409	-2,725	--	2,994,529
1996	1,737,453	67,346	262,730	--	674,729	331,058	7,214	-3,088	--	3,077,442
1997	1,787,806	77,753	283,625	--	628,644	341,273	7,462	-4,040	--	3,122,523
1998	1,807,480	110,158	309,222	--	673,702	308,844	7,206	-4,441	--	3,212,171
1999	1,767,679	86,929	296,381	--	725,036	299,914	3,716	-5,982	--	3,173,674
2000	1,696,619	72,180	290,715	--	705,433	253,155	2,241	-4,960	--	3,015,383

ATTACHMENT G3
U.S. DEPARTMENT OF ENERGY
ENERGY INFORMATION ADMINISTRATION
“SHARE OF US NET ELECTIC UTILITY GENERATION BY ENERGY SOURCE”
(NO DATE)

U.S. Department of Energy
Energy Information Administration

**“Share of U.S. Net Electric Utility Generation
by Energy Source”**

(no date)



Slide 27 of 30

- Electric Utilities used petroleum for 17 percent of electric generation in 1973. During the 1973 oil embargo petroleum prices soared while its availability was labeled as questionable, thus began a long-term decline in the use of petroleum as a fuel for electric generation.
- Petroleum-fired electric plants produced only 2 percent of electric generation in 1997 -- due to increased use of nuclear, gas-fired and coal-fired electric generation.
- A rapid growth of nuclear electricity generation was slowed by the 1979 accident at the Three Mile Island nuclear power plant. No new orders for nuclear reactors were made after 1978.
- Electric utility generation by nuclear reactors has improved significantly. The national capacity factor-below 65 percent in the 1970's and 1980's-has surpassed 70 percent since 1991, achieving 76 percent in 1996.

Source: Nuclear portion of domestic electricity: Energy Information Administration, Annual Energy Review 1997, DOE/EIA-0384(97). (Washington, DC, July 1998), Table 8.3; Reactor performance: Annual Energy Outlook 1998, DOE/EIA-0383(98), (Washington, DC-December 1997), p 54; Form EIA-759, "Monthly Power Plant Report."

ATTACHMENT G4
U.S. DEPARTMENT OF ENERGY
ENERGY INFORMATION ADMINISTRATION
“SUMMARY STATISTICS: RECEIPTS AND COST OF FOSSIL FUELS FOR THE
ELECTRIC POWER INDUSTRY BY SECTOR, BTUS”
OCTOBER 2006

U.S. Department of Energy
Energy Information Administration

**“Summary Statistics: Receipts and Cost of
Fossil Fuels for the Electric Power Industry
by Sector, BTUs”**

October 2006



Energy Information Administration

Official Energy Statistics from the U.S. Government

[Glossary](#)

[Home](#) > [Electricity](#) > Summary Statistics: Receipts and Cost of Fossil Fuels for the Electric Power Industry by Sector, Btus

Summary Statistics: Receipts and Cost of Fossil Fuels for the Electric Power Industry by Sector, Btus

Electric Power Monthly with data for October 2006

Report Released: January 12, 2007

Next Release Date: Mid-February 2007

Table ES2.b. [xls](#) format [Electric Power Monthly](#)

Table ES2.b. Summary Statistics: Receipts and Cost of Fossil Fuels for the Electric Power Industry by Sector, Btus, 2006 and 2005

Items	September Total (All Sectors)									
	Receipts (billion Btu)		Cost (dollars/million Btu)		Number of Plants [1]		Year-to-Date Receipts		Cost	
	Sep-06	Sep-05	Sep-06	Sep-05	Sep-06	Sep-05	Sep-06	Sep-05	Sep-06	Sep-05
Coal[2]	1,753,632	1,784,392	1.72	1.6	464	472	15,826,758	15,469,407	1.69	1.53
Petroleum Liquids [3]	34,735	95,228	8.14	9.09	311	409	330,138	676,562	8.88	7.03
Petroleum Coke	17,443	17,905	1.38	1.11	25	30	157,089	160,050	1.29	1.09
Natural Gas[4]	599,686	599,696	6.22	10.63	830	864	5,355,872	5,018,753	7	7.53
Fossil Fuels	2,405,496	2,497,220	2.93	4.05	1,140	1,180	21,669,856	21,324,771	3.11	3.11

Items	Electric Utilities									
	Receipts (billion Btu)		Cost (dollars/million Btu)		Number of Plants		Year-to-Date Receipts		Cost	
	Sep-06	Sep-05	Sep-06	Sep-05	Sep-06	Sep-05	Sep-06	Sep-05	Sep-06	Sep-05
Coal ²	1,337,707	1,343,424	1.71	1.61	310	315	12,150,627	11,850,474	1.69	1.52
Petroleum Liquids ³	26,425	55,340	7.94	8.5	203	250	219,057	401,539	8.4	6.66
Petroleum Coke	9,478	9,427	1.5	1.26	10	11	80,398	77,990	1.44	1.27
Natural Gas ⁴	196,723	182,295	6.83	10.81	317	306	1,790,453	1,453,607	7.38	7.72
Fossil Fuels	1,570,334	1,590,486	2.45	2.9	515	511	14,240,534	13,783,611	2.5	2.32

Items	Independent Power Producers									
	Receipts (billion Btu)		Cost (dollars/million Btu)		Number of Plants		Year-to-Date Receipts		Cost	
	Sep-06	Sep-05	Sep-06	Sep-05	Sep-06	Sep-05	Sep-06	Sep-05	Sep-06	Sep-05
Coal ²	387,198	412,078	1.73	1.55	129	129	3,431,615	3,355,251	1.69	1.55

ATTACHMENT H1
BREAKTHROUGH TECHNOLOGIES INSTITUTE
“FUEL CELLS 2000 PROJECTS DATABASE”
NOVEMBER 2000

Breakthrough Technologies Institute

“Fuel Cells 2000 Projects Database”




November 2000





Use the Binocular
Icon in Acrobat
Reader to Search
this Document











Worldwide Fuel Cell Installations




Fuel cell Manufacturer	Project Partners	Fuel cell	Location	Building	Start date	Status	Fuel used	Picture	Comments / Contact Information
Acumentrics Corporation	U.S. Department of Defense, the National Park Service, Electric Power Research Institute, First Energy	5 kW tubular SOFC beta unit	Cleveland, Ohio	Cuyahoga Valley National Park Environmental Education Center	May 2005	Ongoing			Will be operated in grid parallel mode with additional capability to operate in independent island mode to meet critical needs of the educational facility during power loss. Will add another 5 kW unit in the spring of 2006 to bring total installed capacity to 10 kW.
Acumentrics Corporation	Sumitomo Corporation, Nippon Steel Corporation	5 kW tubular SOFC	Japan	Nippon Steel Corporation's Yawata Laboratories	Shipped Jan. 2005		Natural gas		
Acumentrics Corporation	US Army Corp of Engineers Construction and Engineering Research Laboratory (CERL), Fuel Cell Test and Evaluation Center (FCTec), SOFCo EFS Holdings LLC	Two 5 kW tubular SOFC CHP units	Sheridan, Wyoming	Big Goose Ranger Station in Bighorn National Forest	Jul. 2005	Ongoing	Propane		Provides power to two cabins, an office/shop, five trailers and drinking and wastewater pumping systems. Recycled heat provides heat to one cabin. The fuel cell and station will be shut down for six months during cold weather.
Acumentrics	SOFCo EFS Holdings LLC	10 kW tubular SOFC	Ohio		Announced Aug. 2005		Commercial 2007 Certified Diesel fuel		Completed a 500-hour demonstration using the SOFC along with a diesel reformer. Funded by Ohio's Third Frontier Program to demonstrate a sulfur-tolerant SOFC.
Acumentrics Corporation	US Department of Energy National Energy Technology Laboratory (NETL), University of Alaska-Fairbanks, Ohio Department of Development, SOFCo EFS Holdings LLC	5 kW tubular SOFC	Idaho Falls, Idaho	NETL's Idaho National Engineering and Environmental Laboratory	Jun. 2005		2007 Certified Diesel and Syntroleum diesel		Three-day demonstration using the SOFC with a catalytic partial oxidation (CPOX) diesel reformer. The fuel cell will be transferred to the US Department of Energy's Arctic Energy Technology Development Laboratory at the University of Alaska, Fairbanks for 18 months of testing using natural gas.
Acumentrics Corporation	National Park Service, University of Alaska-Fairbanks	5 kW tubular SOFC	Seward, Alaska	Exit Glacier Nature Center in Kenai Fjords National Park	May 2004		Propane		Provides power and heat to the nature center year-round.
Acumentrics Corporation	ChevronTexaco Technology Ventures	Five 2 kW tubular BB-SOFC 2000 units	Houston, Texas		Shipped Jan. 2003				
Acumentrics Corporation	ChevronTexaco Technology Ventures	2 kW tubular BB-SOFC 2000	Houston, Texas		Shipped Oct. 2002				
American Fuel Cell Corp.	EPRIGEN, Inc.	Sixteen 3 kW Alpha Residential Power	Various locations				Natural gas		For alpha testing. US DoD Climate Change Fuel Cell Program grant (\$48,000)



		Generation (RPG) units							
Ansaldo Fuel Cells Spa	MTU-CFC Solutions, IZAR, FhG Umsicht, CESPA, Z.A.E., OVM, University Genova, ASM, Nitra, Technip, E.ON	"MW-sized" MCFC fuel cell plant	Italy		Planned		Biogas		BICEPS project-Biogas Integrated Concepts.
Ansaldo Fuel Cells Spa	Marmara Research Centre	500 kW hybrid plant MCFC/Gas Turbine	Turkey		Planned plant start-up Spring 2006	Planned, undergoing site preparations	NATO F76 Diesel oil		MCFC-NAV project. Prototype of diesel-fueled MCFC for naval applications
Ansaldo Fuel Cells Spa	FN Spa (site owner)	125 kW hybrid plant MCFC/Gas Turbine	Bosco Marengo, Italy	FN Spa, outdoor site	Jun. 2005	Operational	Natural gas		TECNODEMO project. 3,000 operational hours achieved by Oct. 2005.
Ansaldo Fuel Cells Spa	Iberdrola, ENEA, Balcke	Series 2tW, 500 kW hybrid plant MCFC/Gas Turbine	Guadalix, Spain		Dec. 2004	Plant improvements ongoing after first operational run	Natural gas		FOAK project. First of the "Series 2TW"
Ansaldo Fuel Cells Spa	ENEL	100 kW MCFC	Milan, Italy	ENEL site	1998-1999	Completed	Natural gas		Proof of Concept
Ansaldo Fuel Cells Spa	IBERDROLA	100 kW MCFC	Guadalix, Spain	IBERDROLA stack test and conditioning facility	1999	Completed	Natural gas		
Apollo Energy Systems Inc.	Hydrolec, Inc	10 kW Apollo alkaline fuel cell w/ 12 kW lead-cobalt battery	Ft. Lauderdale, Florida		2002	In production			Contract to supply 2,000 Apollo power plants per month to Hydrolec, Inc. for power back up and elevator systems around the world; starting in 2002. Contract worth \$223 million.
Astris Energi Inc.	Electronic Machining srl (El.Ma), Energie Rinnovabili Italia srl (ERI)	Alkaline fuel cells	Rovereto, Italy	Astris Energi site	Sale announced Aug. 2005	Planned			Order for fuel cells, test equipment and an E8 generator. Will be used to demonstrate Astris' fuel cell technology to potential clients and partners. Success during this trial may lead to 24 mountain shelter projects and a demonstration in Isera, Italy.
Ballard	US Department of Defense, LOGANEnergy	Two AirGen 1 kW PEM units	Ayer, Massachusetts	Fort Devens office security hut	Planned	Contract awarded Jun. 2005	Hydrogen		US Department of Defense Residential PEM Fuel Cell Demonstration Program FY 2004. The fuel cells will be installed in a stand-by power support role at the security hut of the main office facility.
Ballard	Government of Canada, National Research Council, MGE UPS Systems	NexaRM	Vancouver, Canada	National Research Council's Institute for Fuel Cell Innovation	Planned				Will serve as a backup power source for uninterruptible power supply (UPS). Part of Canada's h2 Early Adopters Program (h2EA)
Ballard	Government of Canada, Bell Canada	NexaRM	Canada	Bell Canada backup power site	Planned				Part of Canada's h2 Early Adopters Program (h2EA)
Ballard	Government of Canada, University of Toronto at Mississauga. MGE UPS Systems	NexaRM	Mississauga, Canada	University of Toronto at Mississauga	Planned				Will provide critical backup power for server room applications at the University. Part of Canada's h2 Early Adopters Program (h2EA)
Ballard	Nippon Oil	Nine 1 kW PEM	Japan	Four houses	Aug. 2005		Coil oil		World's first coil oil-fueled

		units		and 5 multi-family residences					fuel cell demonstration.
Ballard	Tokyo Gas	1 kW MK1030 PEM fuel cell	Tokyo, Japan	Prime Minister's residence	Apr. 2005		Natural gas		Co-generation unit--provides electricity and reuses waste heat.
Ballard	Tokyo Gas	One-hundred 1 kW Lifuel PEM units	Various locations, Japan	Residential	Installed by Jun. 2005				
Ballard	Osaka Gas	Twenty-eight PEM units	Japan	Residential	Installations begin Aug. 2005				Part of the first stage of the "Large-Scale Demonstration Project of Stationary Fuel Cells"
Ballard	Nippon Oil	1 kW PEM	Yokohama, Japan	Nippon Oil's Yokohama Oil Refinery	Apr. 2004		Kerosene		
Ballard	Keiyo Gas	1 kW PEM	Chiba, Japan		2004				Field test.
Ballard	Osaka Gas	PEM-"semi commercial unit, type-2"	Japan		Shipped Jan. 2004				Cogeneration system for field testing.
Ballard	Tokyo Gas	1 kW PEM	Yokohama, Japan	Tokyo Gas employee's residence	Unknown	Mar. 2003			Cogeneration units. Ten-month test operation.
Ballard	Japan Gas Association	1 kW PEM	Tobitakyu, Japan	Kajima Technical Research Institute	Feb. 2003				Japan Gas Assoc. Phase 2 test of residential PEM fuel cells of different manufacturers.
Ballard	EnBW	250 kW PEM	Mingolsheim, Germany	Spa bath	Sep. 2002	One-year demonstration	Natural gas		Logged 6,000 hours of operation at 75% efficiency with utilization of waste heat. Part of EDISON (Intelligent Energy Distribution System) program.
Ballard	EUS GmbH, AEG SVS Power Supply Systems GmbH, E.ON Engineering GmbH, MVV Energie AG, University of Dortmund	250 kW stationary PEM generator CHP with micro-turbine	Oberhausen, Germany	Fraunhofer Institute for Environmental Safety and Energy Engineering	Jun. 2002	Ongoing	Natural gas		"PEM-Oberhausen" project http://www.pem-oberhausen.de/englisch/index.html
Ballard	Japan Gas Association	1 kW PEM	Tokyo and Osaka, Japan		Phase 1: Dec. 2001	Phase I completed Feb. 2002			Japan Gas Assoc. test of residential PEM fuel cells from seven manufacturers (Ballard, Matsushita Electric, Toshiba, Toyota, Sanyo Electric, Mitsubishi Electric, Plug Power). Completed 1,000 hours of operation in Phase I testing, 8,000 hours scheduled in Phase 2 using fuel cells of different manufacturers.
Ballard		250 kW stationary PEM generator	Tomakomai, Japan	Nishimachi Sewage Treatment Center	Jul. 2001	Nov. 2002	Methane gas from anaerobic digester		
Ballard	Nippon Telegraph and Telephone (NTT)	250 kW PEM stationary generator	Tokyo, Japan	NTT's Musashino Research and Development Center	Mar. 2001	May 2003	Town gas		Cogeneration system incorporating an adsorption chiller for air conditioning. Operated for 5,026 hours.

Ballard	Promocell, University of Liege	220 kW PEM stationary generator	Liege, Belgium	University of Liege	2001	Ongoing	Natural gas		Provides power to the university campus and heats the university swimming pool.
Ballard		250 kW stationary PEM generator	Tomakomai, Japan	Nishimachi Sewage Treatment Center	2001	Ongoing	Methane gas from anaerobic digester		
Ballard	Bewag AG	250 kW PEM	Berlin, Germany	Bewag's Fuel Cell Innovation Park	Jun. 2000	Ongoing	Natural gas		Provides power to the park.
Ballard	Bewag, Hamburgische Elektrizitäts-Werke AG, EDF, PreussenElektra AG, VEAG Vereinigte Energiewerke AG	250 kW PEM stationary generator	Berlin, Germany	Bewag's Treptow heating plant	Jun. 2000	Ongoing	Natural gas		Five-year demonstration project. Being tested by a consortium of European electric companies led by Bewag, the largest supplier of power and heat in Berlin.
Ballard	Nippon Telegraph and Telephone (NTT)	250 kW PEM stationary generator	Tokyo, Japan	NTT research lab	Nov. 2000	Ended May 2003	Town gas		Cogeneration system incorporating an adsorption chiller for air conditioning. Operated for 5,026 hours.
Ballard	Elektra Birseck Muenchenstein (EBM)	250 kW PEM stationary generator	Basel, Switzerland	EBM corporate headquarters	2000		Natural gas		
Ballard	Cinergy Technology Inc.	250 kW PEM stationary generator	Crane, Indiana	Crane Naval Surface Warfare Center	Sept. 1999	Ended 2001	Natural gas		First 250 kW PEM fuel cell generator in the world to enter field testing. Provided heat and power during the two-year evaluation.
Bharat Heavy Electricals Ltd. (BHEL)		50 kW PAFC power plant (two 25 kW stacks)	India	BHEL testing facility		2000	By-product hydrogen from a chlor-alkali factory		In-house design, operated for 500 hours.
Brennstoffzellentechnik GmbH (ZBT)	VNG, Stadtwerke Chemnitz, DBI Gas und Umweltechnik, Bergakademie Freiberg, Schalt und Regeltechnik	4 kW Inhouse 4000 PEM CHP	Chemnitz, Germany	Chemnitz Botanical Garden	Jun. 2005		Natural gas		Part of DemoCell project conducted by German Company, VNG. Provides heat and power, with excess fed to the local utility grid.
Ceramic Fuel Cells Ltd. (CFCL)	szencorp	1 kW Micro-CHP SOFC	South Melbourne, Australia	szencorp's revamped commercial building	Planned		Natural gas		Two-year installation, with possible extension. To be installed in a certified "green building".
Ceramic Fuel Cells Ltd. (CFCL)	GippsTAFE	1 kW Micro-CHP SOFC	Chadstone, Australia	Energy and Telecommunications Training Australia (ETTA) office at GippsTAFE's Chadstone campus	Announced Apr. 2005		Natural gas		Three-month field trial, trial may be extended.
Ceramic Fuel Cells Ltd. (CFCL)	EWE, VNG AG	1 kW Micro-CHP SOFC	Brandenburg, Germany		Installation planned in early 2006		Natural gas		Combined heat and power. CFCL and EWE have signed an agreement to develop a fuel cell.








									powered CHP unit for the residential market.
Ceramic Fuel Cells Ltd. (CFCL)	Powerco	1 kW Micro-CHP SOFC	State of Tasmania, New Zealand		Announced 2005	To be delivered	Natural gas		Combined heat and power
Ceramic Fuel Cells Ltd. (CFCL)	Powerco	1 kW Micro-CHP SOFC	Wellington, New Zealand	Industrial Research Limited site	Aug. 2005		Natural gas		Combined heat and power.
Ceramic Fuel Cells Ltd. (CFCL)	EWE	1 kW Micro-CHP SOFC	Oldenburg, Germany		Installation planned in late 2005		Natural gas		Combined heat and power. CFCL and EWE have signed an agreement to develop a fuel cell-powered CHP unit for the residential market.
Dais Analytic	Hamburg Gas Consult, Wingas, Technische Werke Ludwigshafen, European Fuel Cell GmbH	Two 3 kW PEM Alpha units	Ludwigshafen, Germany	Test house	First unit installed Aug. 1999, second unit installed May 2000		Natural gas		Provided combined heat and power. Incorporated in "House of the Future, Prototype 1" demonstrator. Preliminary prototypes were installed at Verbundnetz AG in Machern, Germany, Mar. 1999.
Dais Analytic	Hamburg Gas Consult, European Fuel Cell GmbH	PEM	Kassel, Germany		2000				
Dais Analytic	Hamburg Gas Consult, European Fuel Cell GmbH	PEM	Hannover, Germany		2000				
Dais Analytic	Hamburg Gas Consult, European Fuel Cell GmbH	3 kW PEM	Hamburg, Germany		1999				
Dais Analytic	Hamburg Gas Consult, VNG	Alpha PEM CHP	Leipzig, Germany	Apartment	Aug. 1999				
DCH Technologies		5 kW PEM		Unspecified global natural gas utility	Shipped Mar. 2002		Natural gas		
DCH Technologies	Con Edison Co. of New York	5 kW Enable Fuel Cell system	New York	Con Edison	Shipped May 2002		Hydrogen or natural gas		Con Edison to test and validate the system, then place the fuel cell with targeted customers for evaluation as a power quality and/or peak shaving system. Company no longer in business.
European Fuel Cell GmbH	siGEN, Berwickshire Housing Association (BHA), Scottish Power, Scottish Enterprise, Baxi Group	1.5 kW PEM Home Energy Center Micro-CHP	Eyemouth, UK (Scotland)	Residential	Sept. 2005	One-year trial	Natural gas		First residential fuel cell micro-CHP unit demonstrated in the UK. Will supply power and heat. European Fuel Cell plans about 100 installations at various European locations.
European Fuel Cell GmbH	EnBW	1.5 kW PEM beta prototype	Germany	Residential					First European Fuel Cell GmbH unit to be tested at an operational site.
Fuel Cell Technologies (FCT)	University of Toronto	Four 5 kW SOFC units	Mississauga, Canada	12-unit student townhouse block at the University of Toronto-Mississauga	Jul. 2005		Natural gas		The four fuel cells will be connected to form a "mini-grid". The units will provide power and co-generated heat. Sponsored by Technology Partnerships Canada h2 Early Adopters Program.
Fuel Cell Technologies (FCT)	US Army Construction Engineering Research Laboratory (CERL), Fuel Cell Test and Evaluation Center (FCTec) Siemens Power	5 kW SOFC CHP	Ft. Meade, Maryland	Maintenance and repair facility at Fort Meade	To be delivered to Ft. Meade in Jun. 2005 after testing at FCTec in Apr.-May 2005	One-year demonstration	Natural gas		









	Generation, Inc								
Fuel Cell Technologies (FCT)	Canadian Centre for Housing Technology, Natural Resources Canada	5 kW SOFC	Kingston, Canada	Demonstration residential unit at the Canadian Centre for Housing Technology	Mar. 2005	Installed	Natural gas		Improved system with gas-powered heat-up to allow starting without an additional electrical power source. The inverter, which converts fuel cell energy to AC power used by most household appliances, was redesigned to satisfy residential standards.
Fuel Cell Technologies (FCT)	Federal University Itajuba	5 kW SOFC	Itajuba, Brazil	Federal University-Itajuba	Shipped Mar. 2005		Natural gas		First SOFC system tested in South America. The system will be evaluated for performance, to provide parameters to validate various SOFC modeling tools and serve as a demonstration system for Brazilian universities and energy companies.
Fuel Cell Technologies (FCT)	National Research Council	5 kW SOFC	Vancouver, Canada	Institute for Fuel Cell Innovation at National Research Council	Planned, shipped Mar. 2005		Natural gas, methanol		Will provide electricity to power a ground source heat pump to provide climate control for the NRC-IFCI building. Co-generated waste heat will be utilized for building services.
Fuel Cell Technologies (FCT)	Siemens Power Generation, Inc.	SOFC balance of plant assembly	Pittsburgh, Pennsylvania	Siemens Westinghouse Power Corporation	Planned, shipped Mar. 2005				Will be used to test Siemens' new High Power Density cells as part of a federal 10-year, US\$500 million program to develop innovative, low-cost ways to commercialize SOFCs that can be mass-produced at a target cost of US\$400/kW.
Fuel Cell Technologies (FCT)	University of Liege	5 kW tubular SOFC CHP	Liege, Belgium	University of Liege	Shipped Jun. 2005				For testing and validation.
Fuel Cell Technologies	Siemens Power Generation, Inc., Penn State Energy Institute, Pennsylvania Department of Conservation and Natural Resources	5 kW SOFC	Parker Dam State Park, Pennsylvania	Parker Dam State Park Fuel Cell Pavilion	Received Dec. 2004	Operational	Natural gas from Pennsylvania forests		Heats cabins and administration buildings, and provides hot water for showers.
Fuel Cell Technologies (FCT)	University of Alaska, Fairbanks Natural Gas	5 kW SOFC Alpha unit	Fairbanks, Alaska	Fairbanks Natural Gas site	Aug. 2003	Operational	High pressure natural gas		By April 2004 the system had operated 6,158 hours.
Fuel Cell Technologies (FCT)	RWE	5 kW SOFC Alpha unit	Mechernich and Essen, Germany	RWE Fuel Cell Pavilion, Meteor Park	Shipped to Mechernich in Aug. 2003, relocated to Essen in Nov. 2003	De-commissioned	Low pressure natural gas at Mechernich, high pressure natural gas at Essen		First tested at the RWE Lab in Mechernich, then installed at Fuel Cell Pavilion. Operated 3,541 hours. System degraded by over temperature and returned to FCT. RWE planned to upgrade to a Beta Unit.
Fuel Cell Technologies (FCT)	JFE Urban Development Corporation	5 kW SOFC Alpha unit	Yokohama, Japan	JFE	Sep. 2003	Operational	Low pressure natural gas		JFE will promote, sell, distribute and service FCT's SOFC products up to 50kW in the commercial and residential East Asian markets. By April 2004, had operated 1,700 hours. JFE will upgrade to a Beta unit, which can be modified for different NG








									compositions.
Fuel Cell Technologies (FCT)	Ford, DTE Energy	5 kW SOFC Alpha unit	Dearborn, Michigan	Ford's Dearborn Assembly Plant	Jul. 2003	Testing completed	Low pressure natural gas, natural gas augmented with hydrogen gas derived from paint fume emissions		Part of Ford's 'Fumes-to-Fuel' System. The pilot system consumes emissions from Ford's vehicle paint shop and turns them into electrical energy and heat for the facility. By Apr. 2004 the fuel cell had operated 1,164 hours. A 50 kW system is being discussed. The 5 kW SOFC System may be relocated to Ford's Visitors center for demonstration.
Fuel Cell Technologies (FCT)	BC Research Inc, Methanex, NORAM Engineers & Constructors, QuestAir Technologies	5 kW SOFC	Vancouver, Canada	BC Research Inc.'s laboratory building	Agreement signed Jun. 2003		Natural gas of varying NGL composition s, methanol, hydrogen, propane and heavier hydrocarbon s		Will provide an uninterrupted power supply to BC Research's bio-assay lab. The heat and hot water output from the SOFC will also be used by the BC Research Complex.
Fuel Cell Technologies (FCT)		5 kW SOFC	Kingston, Canada	FCT research facility		Operational	Natural gas		
Fuel Cell Technologies (FCT)	U.S. Department of Energy's National Energy Technology Laboratory (NETL), Electric Power Research Institute, U.S. Environmental Protection Agency	5 kW SOFC	Morgantown, West Virginia	NETL	Mid-2003				NETL will conduct tests and then deliver the unit to the EPA to install the at an abandoned hardrock mine in Montana, where it will be used to provide electricity for operating instrumentation and communications equipment for environmental monitoring.
Fuel Cell Technologies (FCT)	Gas Technology Institute, Memphis Botanic Garden, Memphis Light, Gas and Power	5 kW Beta 1 SOFC	Memphis, Tennessee	Memphis Botanic Garden	Prototype unit was to be delivered by Apr. 2004	One-year demonstration project			Technical issues, including the inability to operate above 3 kW, arose during a 300 hour pre-delivery laboratory test. Field delivery was postponed until issues are resolved.
Fuel Cell Technologies (FCT)	The Presidio Trust	5 kW SOFC system	San Francisco, California	The Presidio Trust	2002				Buy Down Recipient FY2000 US DoD Climate Change Fuel Cell Program.
Fuel Cell Technologies (FCT)	Hammarby Sjostad project	Two 5 kW SOFC CHP units	Stockholm, Sweden	Hammarby Sjostad project, residential units	Aug. 2002		Biogas		Progressive 8,000 unit residential development project focusing on environmental concerns, largely powered by renewable energies.
Fuel Cell Technologies (FCT)	South Coast Air Quality Management District (SCAQMD)	Ten 5 kW SOFC CHP units	Various locations, California	Two or three units to be located at LADWP, one or two units at Sempra Utilities and one to two units at the University of California-Irvine	First delivery in 2004				Contract to provide 10 residential fuel cell units. The contract is scheduled to run though the end of 2005, during which time FCT will install, then operate and maintain the residential fuel cells for two years.
FuelCell Energy	Starwood Hotels & Resorts Worldwide, Inc, Alliance Star Energy	500 kW Direct Fuel Cell (DFC) MCRC	San Francisco, California	The Westin San Francisco Airport Hotel	Planned				Will supply base load power. The heat byproduct will be used to heat the hotel's indoor pool. CPUC's Self-Generation Incentive Program is expected to \$1.25 million in funding.








FuelCell Energy	US Department of Defense, US Department of Energy	250 kW Direct FuelCell (DFC) MCFC	Twentynine Palms, CaliforniaA	Marine Corp Air Ground Combat Center, training center	Delivery in July 2006	Planned			Will improve the availability of reliable electricity to help the training center meet security requirements and cope with fluctuating power needs.
FuelCell Energy	Alliance Power	Two 250 kW Direct FuelCell power plants	Fontana, California	TST, Inc.	To be delivered first quarter 2006	Planned	Natural gas		Will replace a large burner that preheats air as part of TST's aluminum manufacturing process.
FuelCell Energy	South Coast Air Quality Management District (SCAQMD), California Cast Metals Association, Emergent Energy Group	Two 250 kW MCFC units	Fontana, Carson, and Rancho Dominguez, California	Metal foundries	To be delivered	Planned			These high temperature fuel cells will be used for metal pre-heating or other co-generation applications depending on the installation site.
FuelCell Energy	Select Energy Services, Eastern Connecticut State University	Four 250 kW MCFC units	Willimantic, Connecticut	Eastern Connecticut State University's central heating plant	To be installed Feb. 2006	Planned	Natural gas		Grid parallel operation to displace existing facility electric demand. Thermal energy from the fuel cells will be captured and used to preheat water returning to the central heating plant. Buy Down Recipient FY2003 US DoD Climate Change Fuel Cell Program (\$ 1 million).
FuelCell Energy	Chevron Energy Solutions, US Postal Service San Francisco Processing and Distribution Center (P&DC), Bonneville Power Administration	250 kW DFC 300A MCFC	San Francisco, California	USPS Embarcadero Postal Center	Installed Feb. 2005	Operational	Natural gas		Will provide base load heat and power (grid parallel, grid independent during an outage). Funding: up to \$625,000 from California's Self Generation Incentive Program .Buy Down Recipient FY2003 US DoD Climate Change Fuel Cell Program. (\$250,000)
FuelCell Energy	Alameda County, Chevron Energy Solutions	1 MW DFC1500 MCFC (Four 250 kW units)	Dublin, California	Alameda County's Santa Rita Jail	To be installed Nov. 2005	Planned			Will provide 90% of base load power, to be used in conjunction with an existing 1.18 MW solar power system. Funding: up to \$1.4 million from the California Public Utilities Commission's Self Generation Incentive Program, .Buy Down Recipient FY2003 US DoD Climate Change Fuel Cell Program (\$1 million).
FuelCell Energy	The Korean Ministry of Commerce, Industry and Energy	250 kW DFC300A MCFC	Kwangju, South Korea	Chosun University Hospital	Fall 2005	Planned			The Korean Ministry of Commerce, Industry and Energy (MOCIE) has targeted more than 20 percent of the country's power generation to be from fuel cells.
FuelCell Energy	The Korean Ministry of Commerce, Industry and Energy	250 kW DFC300A MCFC	Seoul, South Korea	Tancheon Sewage Treatment Plant	Fall 2005	Planned			The Korean Ministry of Commerce, Industry and Energy (MOCIE) has targeted more than 20 percent of the country's power generation to be from fuel cells.
FuelCell Energy	MTU CFC Solutions GmbH, RWE Fuel Cells, Festo GmbH	225 kW Hot Module MCFC	St. Ingbert, Germany	Festo facility	2005				Provides heat, air conditioning and power.











FuelCell Energy	Starwood Hotels and Resorts Worldwide Inc.	500 kW DFC MCFC	San Diego, California	Sheraton San Diego Hotel & Marina, West Tower	Installed Sep. 2005				The Sheraton San Diego fuel cell installation including both the East and West Towers) is the largest commercial fuel cell installation in the United States. Funding of up to \$1.25 million from the from the California Public Utilities Commission's (CPUC) Self-Generation Incentive Program.
FuelCell Energy	Alliance Power, Starwood Hotels and Resorts Worldwide Inc.	Four 250 kW DFC MCFC units	San Diego, California	Sheraton San Diego Hotel & Marina, East Tower	Summer 2004				Will supply base load electricity for the 1,044-room hotel, with heat byproduct used for the hotel's pool. Funding: up to \$1.25 million from the California Public Utilities Commission's (CPUC) Self-Generation Incentive Program.
FuelCell Energy	PPL EnergyPlus, Pepperidge Farm	Two 250 kW DFC 300A MCFC units	Bloomfield, Connecticut	Pepperidge Farm bakery	Third quarter 2005	Planned			Will provide about 20% of the facility's base load power, with the heat byproduct converted to process steam for the bakery. Funding: Connecticut Clean Energy Fund and US DoD Climate Change Fuel Cell Program (\$500,000) grants.
FuelCell Energy	Salt River Project (SRP)	250kW DFC MCFC	Mesa, Arizona	Arizona State University East Campus	Shipped first quarter 2005	Planned			The unit will feed the electricity output into SRP's local grid.
FuelCell Energy	RWE, City Council Ahlen, MTU CFC Solutions GmbH	250 kW DFC HotModule MCFC	Ahlen, Germany	Municipal wastewater treatment facility	2005	Planned	Sewage gas		Will provide combined heat and power.
FuelCell Energy	Marubeni Corporation, Bioenergy Co.	250 kW DFC 300A MCFC	Tokyo, Japan	Food recycling facility at "Super Eco-Town"	Shipment expected in first half of 2005		Anaerobic digester gas		Will provide approximately 50% of the facility's base load electricity requirement. Heat will be converted to process steam for the recycling operations.
FuelCell Energy	State University of New York (SUNY), New York State Energy Research and Development Authority, New York Power Authority	250 kW MCFC CHP	Syracuse, New York	Walters Hall at SUNY's College Environmental Science and Forestry	Installed Apr. 2005	Operational	Natural gas		Providing electricity with waste heat used for campus hot water, space heating and/or cooling. Funding: over \$2.5 million from NYPA, \$1 million grant from NYSERDA, \$250,000 US DoD Climate Change Fuel Cell Program.
FuelCell Energy	Alliance Power, Sierra Nevada Brewing Co.	1 MW DFC MCFC units (four 250 kW units)	Chico, California	Sierra Nevada Brewing Co. brewery	Installed Mar. 2005		Natural gas, possibly anaerobic digester gas		Will supply electric power and heat to the brewery's production processes. Funding: 40% of eligible costs from the California Public Utilities Commission's (CPUC) Self-Generation Incentive Program. Buy Down Recipient FY2003 US DoD Climate Change Fuel Cell Program (\$1 million).
FuelCell Energy	Marubeni Corp/Fuel Cell Japan Co., Mitsubishi Heavy Industries,	250 kW MCFC	Osaka, Japan	Kawasaki's Akashi Works	2005				Long-term testing and evaluation.


	Kawasaki								
FuelCell Energy	Mitsubishi Heavy Industries, Bio Energy, Co.	250 kW MCFC power plant	Tokyo, Japan	Food waste treatment facility	Late 2004 or early 2005		Digester gas		Largest food waste treatment plant in Japan. The plant treats 110 tons of garbage/day to generate digester gas. Uses a fermentation reactor and the MCFC to generate and sell electric power.
FuelCell Energy	Marubeni Corporation, Epson, First Energy Service Company Ltd., Seiko Epson	Two 250 kW DFC 300A MCFC units	Ina, Japan	Seiko Epson's Quartz Devise Division facilities	Apr. 2004	Operational	Liquefied natural gas		Will supply power and steam. The plant also has a PAFC unit.
FuelCell Energy	Marubeni Corporation, City of Fukuoka	250 kW DFC 300A MCFC	Hukuoka, Japan	Seibu Water Treatment Center	Jan. 2004	Mar. 2005	Digester gas		Supplies electricity and steam.
FuelCell Energy	Caterpillar Inc, City of Santa Barbara, Alliance Power	Two 250 kW. DFC MCFC units	Santa Barbara, California	El Estero Wastewater Treatment Facility	Sep. 2004	Operational	Anaerobic digester gas (methane)		Provides electricity and heat for the facility's wastewater treatment system. Funding: \$2.25 million from California Public Utilities Commission's (CPUC) Self-Generation Incentive Program (\$500,000). Buy Down Recipient FY2003 US DoD Climate Change Fuel Cell Program.
FuelCell Energy	Marubeni Corporation, Japan Petroleum Exploration Co. Ltd. (JAPEX)	250 kW DFC 300A MCFC	Nagaoka, Japan	JAPEX's Katakai natural gas gathering station	Fourth quarter 2004	Operational	Liquefied natural gas		Will supply power and steam.
FuelCell Energy	RWE, MTU CFC Solutions GmbH, Fernwärmeversorgung Niederrhein, Stadtwerke Dinslaken	Two 250 kW DFC HotModule MCFC units	Krefeld-Fischein, Germany	Residential units	Apr. 2004	Operational			Will provide residential supply of combined heat and power in the Dinslaken area (will supply 40 homes in the winter and up to 300 during the summer). Funded by the region of NordRhein Westphalia.
FuelCell Energy	Vattenfall/BeWag, MTU CFC Solutions GmbH	250 kW DFC HotModule MCFC	Berlin, Germany	Vattenfall Europe AG's Fuel Cell Innovation Park	Sep. 2004	Operational	Natural gas, methanol or both		Bi-fuel project: liquid fuel used is derived from wastes generated in the city of Berlin. Provides combined heat and power. Has logged over 4,000 operational hours.
FuelCell Energy	US Army Construction Engineering Research Laboratory (CERL), Fuel Cell Test and Evaluation Center (FCTec), Concurrent Technologies Corporation	250 kW DFC 300A MCFC	Johnstown, Pennsylvania	FCTec Environmental Technologies Facility	Cooperative agreement signed Aug. 2004	12-month demonstration planned	Natural gas		Will supply electricity to the facility.
FuelCell Energy	Ohio Cat/Caterpillar Inc, City of Westerville Electric Division, American Municipal Power Ohio	250 kW DFC MCFC	Westerville, Ohio	Electric substation	Nov. 2004	Operational			Will feed power to 180 homes from an electric substation. Funded in part through Ohio's Third Frontier Fuel Cell Initiative.

FuelCell Energy	Quinn Power Systems Associates/Caterpillar Inc, Los Angeles County Sanitation Districts	250 kW DFC 300A MCFC	Los Angeles, California	Palmdale Water Reclamation Plant	Nov. 2004	Operational	Digester gas		The Districts, which treat about 530 million gallons of wastewater daily, are industry leaders in recovering and utilizing biogas and biomass byproducts from waste to generate electricity. Funding: \$1,125,000 from the California Public Utilities Commission.
FuelCell Energy	Democratic National Committee	250 kW DFC 300A MCFC	Boston, Massachusetts	Democratic National Convention	Jul. 2004	Completed	Natural gas		Part of a distributed generation "micro-grid" that provided electricity to support the existing grid to meet the expected additional demand of the convention.
FuelCell Energy	Grand Valley State University	250 kW DFC 300A MCFC	Muskegon, Michigan	Michigan Alternative and Renewable Energy Center	Apr. 2004	Operational	Natural gas		Provides electricity, heating and cooling for research space, incubator facilities, conference center and classrooms. Funding for the project, including the building and fuel cells, is provided by a \$3 million grant from the Michigan Public Service Commission and bonding from the City of Muskegon.
FuelCell Energy	PPL EnergyPlus, Starwood Hotels & Resorts Worldwide, Inc.	250 kW DFC 300A MCFC	Manhattan, New York	Sheraton New York Hotel & Towers	Summer 2004	Operational			The fuel cell provides about 10% of the power and hot water requirements of the 1,750 room hotel. Funding: \$820,000 grant from the New York State Energy Research and Development Authority (NYSERDA).
FuelCell Energy	King County, CH2M Hill, Brown and Caldwell, US Environmental Protection Agency	1 MW DFC MCFC (four 250 kW modules)	Renton, Washington	South Treatment Plant	Apr. 2004	Two-year demonstration	Wastewater digester gas		Provides power to the plant. EPA is providing federal funding estimated at \$12.5 million. The total value of the project is \$22 million.
FuelCell Energy	US Department of Energy, US Army Corp of Engineers	250 kW DFC 300A MCFC	Los Angeles, California	LADWP headquarters (John Ferraro Building)	2003		Natural gas		Replaced a trial FuelCell Energy MCFC plant that ran from 2001-2002. Buy Down Program Recipient FY1999 US DoD Climate Change Fuel Cell Program.
FuelCell Energy	RWE AG, MTU CFC Solutions GmbH	250 kW DFC HotModule MCFC	Essen, Germany	RWE Fuel Cell Pavilion, Meteorit Park	Jul. 2003	Operational			Has logged over 22,000 operating hours.
FuelCell Energy	E-on, Rhoen Klinikum AG, MTU CFC Solutions GmbH	250 kW DFC HotModule MCFC	Bad Berka, Germany	Hospital	Oct. 2003	Operational			Provides combined heat and power. Has logged over 1,500 operating hours.
FuelCell Energy	EnBW/Michelin, MTU CFC Solutions GmbH	250 kW DFC HotModule MCFC	Karlsruhe, Germany	Michelin tire plant	Feb. 2003	Operational			Provides power, heat and process steam for tire production. Has logged over 17,000 operating hours. Funded by the Federal Ministry of Economics and Labor which financed 50% as part of the Future Investment Program.
FuelCell Energy	Pfalzwerke, MTU CFC Solutions GmbH	250 kW DFC HotModule MCFC	Gruenstadt, Germany	Gruenstadt Hospital	Jul. 2003	Operational			Provides 100% of the hospital's energy needs, with excess capacity sent to the public utility system.





									Has logged over 14,000 operating hours. Funded by the Federal Ministry of Economics and Labor, which financed 50% as part of the Future Investment Program.
FuelCell Energy	PPL Energy Plus, Millennium Builders (a PPL subsidiary)	250 kW DFC 300A MCFC	Toms River, New Jersey	Ocean County College	Dec. 2003	Operational	Natural gas		Provides 90% of the daily power requirements for the Instructional Building, Lecture Hall and Nursing Arts Building. 20% of heating needs are also provided to the above plus the Administration Building, Library and planetarium. Funding: \$827,000--New Jersey Clean Energy Program. Buy Down Recipient \$250,000 FY2002 US DoD Climate Change Fuel Cell Program.
FuelCell Energy	PPL EnergyPlus, US Coast Guard	250 kW DFC MCFC	Bourne, Massachusetts	US Coast Guard Air Station	May 2003	Operational	Natural gas		Provides electricity to the air station, including its hangars and administrative buildings, and supplies hot water for use in the air station's barracks. Funding project came from a variety of federal, state and private sources, including the Massachusetts Renewable Energy Trust Fund.
FuelCell Energy	Starwood Hotels, PPL Energy Plus	250 kW DFC 300A MCFC	Parsippany, New Jersey	Sheraton Hotel	Oct. 2003	Operational	Natural gas		Provides 25% of the electric power and hot water requirements of the hotel. The New Jersey Clean Energy Program provided \$860,000 in funding.
FuelCell Energy	Starwood Hotels, PPL Energy Plus	250 kW DFC 300A MCFC	Edison, New Jersey	Sheraton Hotel	Aug. 2003	Operational	Natural gas		Provides 25% of the electric power and hot water requirements of the hotel. The New Jersey Clean Energy Program provided \$860,000 in funding. Buy Down Program Recipient FY2002 US DoD Climate Change Fuel Cell Program (\$250,000).
FuelCell Energy	Zoot Enterprises, PPL EnergyPlus	250 kW DFC MCFC	Bozeman, Montana	Zoot Enterprises' business park	Aug. 2003	Operational	Natural gas		Supplies the primary electric requirements of the building. Zoot Enterprises is installing the necessary equipment for its DFC power plants to operate independent of the electric utility grid.
FuelCell Energy	Connecticut Clean Energy Fund, Yale University	250 kW DFC MCFC	New Haven, Connecticut	Yale University's archival storage facility for the Yale Peabody Museum and the Yale Environmental Science Center	Dec. 2003	Dedicated	Natural gas		Provides approximately 25% of the Peabody Museum's electricity needs, with the heat being used primarily to maintain tight temperature and humidity controls at the Environmental Science Center.



FuelCell Energy	Harrison Mining Corporation/ AEP Ohio Coal LLC, Northwest Fuel Development Inc.	200 kW DFC MCFC	Hopedale, Ohio	AEP Ohio Coal LLC site	Aug.-Dec. 2003	Completed	Coal mine methane		Achieved 1,456 operating hours. Successfully demonstrated that coalmine methane could be used at high efficiency to produce fuel cell power. Co-funded by the U.S. Department of Energy's National Energy Technology Laboratory.
FuelCell Energy	Caterpillar Inc.	250 kW DFC 300A MCFC	Peoria, Illinois	Caterpillar Technical Center	Oct. 2003	Operational			Connected to the Peoria area electricity grid, allowing Caterpillar to utilize the power plant as a demonstration unit for customers, Caterpillar dealers and development engineers.
FuelCell Energy	Los Angeles Department of Water and Power (LADWP), Los Angeles Department of Public Works/Bureau of Sanitation, US Army Corp of Engineers	250 kW DFC 300 MCFC	San Pedro, California	LADWP's Terminal Island Fuel Cell Power Plant	Sep. 2003	Operational	Natural gas, converting to sewage digester gas (methane) during Summer 2004		Provides electricity to serve about 250 households. Largely funded by LADWP's Public Benefits Program. The US Department of Defense also provided \$250,000 in grant funding. (Buy Down Program).
FuelCell Energy	Marubeni Corporation, Kirin	250 kW DFC 300A MCFC	Toride, Japan	Kirin Brewery	Jan. 2003	Operational	Wastewater treatment gas		Supplies electricity and steam.
FuelCell Energy	Marubeni Corporation, City of Fukuoka	250 kW DFC 300A MCFC	Fukuoka, Japan	Municipal wastewater treatment facility	Early 2003	Two-year demonstration project	Digester gas		Supplies electricity and steam.
FuelCell Energy	Marubeni Corporation, Nippon Metal	250 kW DFC 300A MCFC	Sagamihara, Japan	Nippon Metals Sagamihara Works	Fall 2003	Operational	Natural gas		Supplies electricity and steam.
FuelCell Energy	US Department of Energy's National Energy Technology Laboratory, Wabash River Energy Ltd., Global Energy Inc	2 MW DFC 3000 MCFC	Terre Haute, Indiana	Global Energy Wabash River Energy Ltd. facility	Fourth quarter 2003	Operational	Natural gas, coal-derived synthesis gas		Part of the federal Clean Coal Technology Program. Was the first plant to use a combination of coal and renewable fuels. Initial plan was to operate at the Kentucky Pioneer Energy IGCC site, but the site was moved to Wabash River to begin operation two years ahead of schedule. Funding provided by the US Department of Energy (Buy Down Program).
FuelCell Energy	IZAR, MTU CFC Solutions GmbH	250 kW DFC HotModule MCFC	Cartagena, Spain	IZAR shipyard facility	2003	Operational	Natural gas		Provides combined heat and power. Has logged over 18,000 operating hours.
FuelCell Energy	US Coast Guard Research and Development Center	3 kW DMFC MCFC	Virginia Beach, VA	Cape Henry Lighthouse at U.S. Army Fort Story	Mar. 2002	Completed	Methanol and water mixture		Six month evaluation. Total running time of 4,090 hours. Provided heat and lighting.
FuelCell Energy	MTU Friedrichshafen, VSE	250 kW MCFC	Ensdorf, Germany	Handicapped workshop	2003				Heat and power supply.



FuelCell Energy	De Te Immobilien/ Deutsche Telekom, MTU CFC Solutions GmbH	250 kW DFC HotModule MCFC	Munich, Germany	De Te Immobilien headquarters	Nov. 2002	Operational			Direct current backup application (telecom) and air conditioning. Has logged over 12,000 operating hours
FuelCell Energy	IPF KG, MTU Friedrichshafen, MTU CFC Solutions GmbH, Otto-von-guericke Clinic	250 kW DFC HotModule MCFC	Magdeberg, Germany	Otto-von-guericke Clinic	Oct. 2002	Operational			Combined heat and power. Has logged over 19,000 operating hours. Funded by the Federal Ministry of Economics and Labor which financed 50% as part of the Future Investment Program.
FuelCell Energy	MTU-CFC Solutions, RWE	250 kW MCFC HotModule	Essen, Germany	RWE Fuel Cell Pavilion, Meteorit Park	Jan. 2002				The system will be grid connected and will contribute to the electricity and heat supply of the adjacent Meteorit Park.
FuelCell Energy	Siemens Power Generation, Inc., BP, Chugach Electric Association	200 kW DFC MCFC	Nikiski, Alaska	BP's gas-to-liquid test facility, powering administration building and warehouse	Aug. 2001	To be installed 2003	Natural gas		Funding: \$4 million from BP, \$2 million from the US. Department of Energy, \$450,000 grant from the Cooperative Research Network of the National Rural Electric Cooperative Association.
FuelCell Energy	Los Angeles Department of Water and Power (LADWP), US Department of Energy, US Army Corp of Engineers	250 kW trial MCFC plant	Los Angeles, California	LADWP headquarters (John Ferraro Building)	Aug. 2001	Dec. 2002	Natural gas		The power plant sends electricity to the City's power grid. This trial plant was replaced with permanent model in 2003. Buy Down Program Recipient FY1999 US DoD Climate Change Fuel Cell Program.
FuelCell Energy	Southern Company, Alabama Municipal Electric Authority (AMEA), Mercedes Benz US	250 kW DFC MCFC	Tuscaloosa, Alabama	Mercedes Benz M-class production facility	2001	Completed	Natural gas		The plant fed the Mercedes-Benz production facility power distribution system. Also, the entire power plant was skid-mounted, making it easy to transport to different locations for demonstrations.
FuelCell Energy	State of Bavaria, Ferngas Nordbayern, E-on/Rhoen Klinikum AG, MTU Friedrichshafen	250 kW DFC HotModule MCFC	Bad Neustadt, Germany	Rhoen Klinikum (medical clinic)	May 2001	Operational	Natural gas		Emergency power supply and combined heat and power. Had logged over 21,000 operating hours by 2004.
FuelCell Energy	MTU Friedrichshafen, Stadwerke Bielefeld, BEB Erdgas-Erdol	250 kW DFC HotModule MCFC	Bielefeld, Germany	University of Bielefeld Hospital	Feb. 2000	2002	Natural gas		Field trial. Completed over 16,000 operating hours
FuelCell Energy	MTU Friedrichshafen GmbH, Elkraft A.m.b.A, Ruhrgas AG, RWE-Energie AG	HotModule MCFC	Dorsten, Germany	Ruhrgas plant	1997	1998			First system demonstrator
FuelCell Energy	FuelCell Energy Facility Demonstration	250 kW DFC MCFC	Danbury, Connecticut	FuelCell Energy's Facility	Feb. 1999	Jun. 2000	Natural gas		Fuel cell was grid-connected and operated for 11,800 hours delivering 11.8 million kW/hr of electricity. Excess energy was sold to the local power grid.


FuelCell Energy	Los Angeles Department of Water and Power	2 MW DFC MCFC	Santa Clara, California	Scott Receiving Station	Apr. 1996	Mar. 1997			First full scale utility demonstration of a molten carbonate fuel cell system. Grid-connected. Operated for more than 3,600 hours.
Fuji Electric		1 kW PEM	Yokkaichi, Japan	FamilyMart chain convenience store	Announced May 2005	Installed			one of Mie Prefecture's demonstration program. Half of the installation cost subsidized by the local government. It will supply electric power to 1/3 of consumption by fluorescent lamps in the store.
Fuji Electric	Unspecified Japanese research association	5 MW PAFC	Japan	Unspecified Japanese research association	2004				
Fuji Electric	Toho Gas, Okazaki Shinkin Bank	100 kW PAFC	Okazaki, Japan	Okazaki Shinkin Bank headquarters	Feb. 2004				Fuel cell purchase.
Fuji Electric		100 kW PAFC	Japan	Fuji Electric Human Resources Development Center	2002				Provides power to the facility.
Fuji Electric	Yamagata City	Two 100 kW PAFC	Yamagata, Japan	Yamagata City Purification Center (sewage treatment facility)	May 2002	Operational	Methane digester gas		The fuel cells cover 40 % of power consumption at the center.
Fuji Electric	Kajima Corporation, New Energy and Industrial Technology Development Organization (NEDO)	100 kW PAFC	Kobe, Japan	Garbage anaerobic digestion facility	Jul. 2001		Methane biogas from anaerobic digestion of kitchen waste		Generates hydrogen fuel from 6 tons of garbage/day.
Fuji Electric		100 kW PAFC	Japan	Fuji Electric factory	Dec. 2001				
Fuji Electric	Toho Gas Co., Ltd	100 kW PAFC CHP	Nagoya, Japan	Nagoya Sakae Washington Hotel Plaza	Feb. 1999	Operational			The plant reduces the hotel's energy costs by 40%. Used for hot water and air conditioning. Operated for over 40,000 hours. The fuel cell was overhauled in 2004, replacing cell stack and reformer.
Fuji Electric	Vattenfall AB	50 kW PAFC	Varberg, Netherlands		Feb. 1993				
Fuji Electric	Enagas	50 kW PAFC	Madrid, Spain		Dec. 1991				
Fuji Electric	WNAM Eniricerche	50 kW PAFC	Milan, Italy		Nov. 1991				
Fuji Electric	Sydraft AB	50 kW PAFC	Astorp, Sweden		Dec. 1991				The Swedish utility company will test the unit.
Fuji Electric	Vattenfall	50 kW PAFC	Varberg, Sweden		Nov. 1992				
Fuji Electric	Tokyo Electric Power Co (TEPCO)	50 kW PAFC	Japan	TEPCO New Energy Park	Jun. 1993	Completed Dec. 1996			This unit accumulated 39,291 hours by 10/00.
Fuji Electric	Kansai Electric Power Co	5 MW PAFC	Japan	Kansai Electric's "Urban Energy Center"	Installed between 1993-1995				
Fuji Electric	Kansai Electric Power Co	Fourteen 50kW PAFC units	Japan	Kansai Electric Power Co.'s Rokko Island test center	1990's				



Fuji Electric	Kansai Electric Power Co	Twenty-one 50 and 200 kW PAFC units	Various locations, Japan		Installed between 1993-1995				Other Kansai Electric listings in this chart may be a part of this purchase.
Fuji Electric	Osaka Gas, Global Environment Centre Foundation	50 kW PAFC	Japan	Global Environment Centre Foundation office	Jul. 1993	Completed Oct. 2000			Operated for 50,358 hours.
Fuji Electric	Osaka Gas	Three 500 kW PAFC units	Japan						
Fuji Electric	Osaka Gas	Fifteen 50 and 100 kW PAFC units	Japan		Installed between 1993-1995				Other Osaka Gas listings in this chart may be a part of this purchase.
Fuji Electric	Tokyo Electric Power Co (TEPCO), Mitsubishi	200 kW PAFC	Japan		Installed between 1993-1995				
Fuji Electric	Toho Gas	50 kW PAFC	Japan		Mid-1990s				
Fuji Electric		100 kW PAFC power plant	Japan				Town gas, LP gas		
Fuji Electric		100 kW PAFC	Japan	Fuji Electric's Human Resources Development Center					Provides power to the facility.
Fuji Electric	Hokkaido Electric Power Co	200 kW PAFC	Japan		Installed between 1993-1995				
Fuji Electric	Tohoku Electric Power Co	Two 50 kW PAFC units	Japan		Installed between 1993-1995				
Fuji Electric	Tokyo Gas	Ten 50 and 100 kW PAFC units	Japan		Installed between 1993-1995				
Fuji Electric	Chubu Electric Power Co, Mitsubishi	Three 50 and 200 kW PAFC units	Japan		Installed between 1993-1995				
Fuji Electric	Hokuriku Electric Power Co	50 kW PAFC	Japan		Installed between 1993-1995				
Fuji Electric	Chugoku Electric Power Co, Mitsubishi	Four 50, 100 and 200 kW PAFC units	Japan		Installed between 1993-1995				
Fuji Electric	Toagosei Company, Shikoku Electric	100 kW PAFC	Japan	Toagosei Company's Toshima plant	1993	Mar. 1999			Cogeneration of waste heat for hot water. Operated 1,064 hours. Achieved power generating efficiency of 40.5% and an overall efficiency with cogeneration of 44.6%.
Fuji Electric	Shikoku Electric Power Co, Mitsubishi	50 kW PAFC	Japan		Installed between 1993-1995				
Fuji Electric	Kyushu Electric Power Co, Mitsubishi	One 50 and one 200 kW PAFC units	Japan		Installed between 1993-1995				
Fuji Electric	Saibu Gas	50 kW PAFC	Japan		Installed between 1993-1995				
Fuji Electric		1 kW PEM test stack	Japan						Exceeded 10,000 hours of test operation. Prototype PEM for residential use was to be ready by 2004. The goal is for 20,000-30,000 hours of operation, with market entry in 2007-2008. Fuji may develop a 5 kW version for restaurants or convenience stores.
GenCell		40 kW MCFC	Storrs,	Connecticut	Delivered		Natural gas		Grid-connected. Provides

		CHP	Connecticut	Global Fuel Cell Center	Jan. 2005				power and heat, with excess power delivered to the grid. Funded by Connecticut Conservation & Load Management Fund and the Connecticut Clean Energy Fund.
General Electric	Florida Power & Light Co. (FPL), Florida Department of Environmental Protection	5 kW PEM	Fort Lauderdale, Florida	Hugh Taylor Birch State Park Visitor Center	Dec. 2002	One-year demonstration	Natural gas		Located next to park manager's house. Provided power to FPL's electric grid.
Global Thermoelectric	Bonneville Power Administration (BPA)	Three 2 to 5 kW SOFC systems	Various locations, USA	Field testing sites	2003	To be delivered	Natural gas or propane		
Global Thermoelectric	Montana State University, Montana Dakota Utilities Co.	3 to 5 kW SOFC remote power system for light industrial applications	Billings, Montana	Montana State University	Agreement announced 2002	Planned	Methane		Two year testing and evaluation program. Partial funding from Montana-Dakota Utilities
Global Thermoelectric	Montana State University, Montana Dakota Utilities Co.	2 kW SOFC	Billings, Montana	Montana State University	Agreement announced 2002	Planned	Natural gas		Two year testing and evaluation program. Partial funding from Montana-Dakota Utilities
Global Thermoelectric	Enbridge Inc.	Two 2.3 kW SOFC systems	Calgary, Canada	Enbridge Inc. facility	Late 2001	2002			Six-month prototype testing.
GM		75 kW PEM	Manhattan, New York	General Motors Drive-In movie theater	May 2004	Completed	Hydrogen		Provided power to the movie screen for three days during the Tribeca Film Festival.
GM	Dow Chemical Company	75 kW PEM	Freeport, Texas	Dow Chemical Company plant	Feb. 2004	Phase I: 4-6 months			More fuel cells and electrical generating capacity to be added during the summer months. The initial GM fuel cell will generate 75 kW of power, enough electricity for 50 average homes. Dow and GM plan to install up to 400 fuel cells to generate 35 megawatts of electricity, enough power for 25,000 average sized American homes. DOW Chemical Harold Nicoll 989-636-5162 hgnicoll@dow.com GM Scott Fosgard 586-947-3295 scott.fosgard@gm.com
GM		75 kW PEM	Rochester, New York	GM's fuel cell research facility	2001	Ongoing	Natural gas, methanol, gasoline		Prototype testing
H Power Corp.	Gaz de France	4 kW PEM	Dunkerque, France	Dunkerque traffic control center	May 2003	Testing between 2002 and 2005	Natural gas		H Power was acquired by Plug Power in March 2003.
H Power Corp.	Gaz de France, The National Polytechnical Institute of Lorraine (INPL)	4 kW PEM	Nancy, France	The National Polytechnical Institute of Lorraine	Feb. 2003	Testing between 2002 and 2005	Natural gas		Produces heat and electricity for green-houses of the bio and agricultural department of INPL, outside the university buildings, and close to the greenhouses. H Power was acquired by

									Plug Power in March 2003.
H Power Corp.	Gaz de France	4 kW PEM	Limoges, France	City Hall of Feytiat	Apr. 2003	Testing between 2002 and 2005	Natural gas		H Power was acquired by Plug Power in March 2003.
H Power Corp.	Gaz de France	4 kW PEM	Sophia-Antipolis, France	Centre Scientifique et Technique du Bâtiment's computer rooms and science laboratory	Jun. 2003	Testing between 2002 and 2005	Natural gas		H Power was acquired by Plug Power in March 2003.
H Power Corp.	US National Park Service, Fall River Rural Electric Cooperative, Energy Co-Opportunity, Inc.	4.5 kW PEM CHP	Yellowstone National Park, Montana	West Entrance of Yellowstone National Park	Jun. 2002		Propane		Part of "Greening of Yellowstone" initiative. Powers lights, communication equipment and computers to ticket kiosks and an office. The system's byproduct heat is used for space heating. H Power was acquired by Plug Power in March 2003.
H Power Corp.	Mitsui & Co., Ltd., Osaka Gas	500 W PEM Alpha residential CHP	Kansai area of Japan		Jan. 2002	Completed	Natural gas		Osaka Gas's in-house and field beta testing for the Japanese residential market. H Power was acquired by Plug Power in March 2003.
H Power Corp.	Naps Systems Oy, Birka Energi, ABB	4 kW PEM CHP	Stockholm, Sweden	Environmental Information Centre in Hammarby Sjostad	Jun. 2002		Hydrogen produced through a photovoltaic solar cell system, biogas from municipal waste		Excess electricity generated by the fuel cell system to be fed back into the power grid. H Power Corp. was acquired by Plug Power in 2003.
H Power Corp.	Gaz de France	4 kW PEM	Dunkerque, France	City Hall of Petite Synthe	Nov. 2002	Testing between 2002 and 2005	Natural gas		Supplies electricity and space heating. H Power was acquired by Plug Power in March 2003.
H Power Corp.	US Department of Defense	Three 500 W PEM units	Fort Belvoir, Virginia	Fort Belvoir office building	2002		Hydrogen		H Power was acquired by Plug Power in March 2003.
H Power Corp.	Energy Co-Opportunity Inc, Rappahannock Electric Cooperative	4.5 kW Beta PEM CHP	Bowling Green, Virginia	Rappahannock Electric Cooperative	2002		Propane		Provides stand-alone power and heat for the 2,000 square foot office facility with the grid available for back up. The cooperative also participated in alpha testing. H Power was acquired by Plug Power in March 2003.
H Power Corp.	Energy Co-Opportunity Inc, Delta-Montrose Electric Association	4.5 kW Beta PEM CHP	Montrose, Colorado	Delta-Montrose Electric Association	2002		Propane		The cooperative also participated in alpha testing. H Power was acquired by Plug Power in March 2003.
H Power Corp.	Energy Co-Opportunity Inc, Enerstar Power Corporation	4.5 kW Beta PEM CHP	Paris, Illinois	Enerstar Power Corporation	2002		Propane		The cooperative also participated in alpha testing. H Power was acquired by Plug Power in March 2003.
H Power Corp.	Energy Co-Opportunity Inc, Platte-Clay Electric Cooperative	4.5 kW Beta PEM CHP	Kearney, Missouri	Platte-Clay Electric Cooperative	2002		Propane		The cooperative also participated in alpha testing. H Power was acquired by Plug Power in March 2003.
H Power Corp.	US Department of Defense, Southern Maryland Electric Cooperative	4.5 kW PEM	Patuxent River, Maryland	Patuxent River Naval Air Station Natural Resources office	Oct. 2002	One-year demonstration	Propane		DOD Residential Fuel Cell Demonstration Program. H Power was acquired by Plug Power in March 2003.





H Power Corp	US Department of Defense, Southern Maryland Electric Cooperative	4.5 kW PEM	Patuxent River, Maryland	Patuxent River Naval Air Station single-family home	Oct. 2002	One-year demonstration	Natural gas		DOD Residential Fuel Cell Demonstration Program H Power was acquired by Plug Power in March 2003.
H Power Corp	U.S. Army Corps of Engineers Construction Engineering Research Laboratory (CERL)	4.5 kW PEM	Herlong, California	Sierra Army Depot barracks	Installed Oct. 2002		Propane		H Power was acquired by Plug Power in March 2003.
H Power Corp.	Gaz de France	Beta PEM CHP	La Plaine Saint-Denis, France	Gaz de France's research and development campus, model house	2002				H Power was acquired by Plug Power in March 2003.
H Power Corp	Kamata Inc.	4.5 kW PEM CHP	Gotenba, Japan	Kamata's Gotenba employee facility	June 2002		Propane		The first field test of a propane-powered PEM for an actual load in the Japanese residential market. H Power was acquired by Plug Power in March 2003.
H Power Corp.	US Air Force Expeditionary Forces Battlelab (AEFB)	4 kW PEM	USA	US Air Force base	2001	Completed			Demonstrated under the Air Force's Common Core Power Production (C2P2) Initiative. The system powered an office suite, followed by a flight line lighting unit. H Power was acquired by Plug Power in March 2003.
H Power Corp.	US Air Force Expeditionary Forces Battlelab (AEFB)	Two 4 kW PEM units	USA	US Air Force base	2001	Completed			Demonstrated under the Air Force's Common Core Power Production (C2P2) Initiative. Supplied power to a simulated aircraft load on the ground. H Power was acquired by Plug Power in March 2003.
H Power Corp.	US Air Force Expeditionary Forces Battlelab (AEFB)	Three 4 kW PEM units	USA	US Air Force base	2001	Completed			Demonstrated under the Air Force's Common Core Power Production (C2P2) Initiative. Powered industrial shop equipment and various aircraft support equipment. H Power was acquired by Plug Power in March 2003.
H Power Corp	Fortum Oy, Finnish Chemicals Oy	PEM CHP	Aetsa, Finland	Test house	Mar. 2001		Hydrogen		Supplied all electricity and heat used by a typical household and was "net metered" to sell surplus electricity to the local electric utility. H Power was acquired by Plug Power in March 2003.
H Power Corp.	Gaz de France	Alpha PEM CHP	La Plaine Saint-Denis, France	Gaz de France's research and development campus model house	Jan. 2001	Jul. 2001	Natural gas		Five month evaluation. H Power was acquired by Plug Power in March 2003.
H Power Corp	US Department of Defense	4.5 kW PEM CHP	Various locations	ECO Fuel Cells, LLC facility	Mar. 2000				First H Power prototype stationary fuel cell. In 2001 ECO agreed to purchase 12,300 stationary fuel cell systems for an aggregate purchase price of \$81 million. The full delivery has not yet occurred. H Power was acquired by Plug Power in March 2003.
H Power Corp	Hydro-Quebec	Stationary PEM	Canada	Hydro-Quebec laboratory	Nov. 2000		Propane		Generates both electricity and hot water. H Power


									was acquired by Plug Power in March 2003.
Hydrogenics, Corp.	Florida Department of Environmental Protection, Progress Energy Florida	PEM	Homosassa, Florida	Homosassa Springs State Wildlife Park's Wildlife Pavilion	Mar. 2005		Hydrogen gas generated by an electrolyzer		Integrated fuel cell/solar photovoltaic system provides a portion of the Pavilion's electricity.
Hydrogenics, Corp.	Japan Automobile Research Institute (JARI)	10 kW HyPM PEM	Tsukuba, Japan	Japan Automobile Research Institute	Delivery during first quarter 2005				To be used as part of JARI's mandate to establish standards for fuel cell power module testing, a program sponsored by Japan's Ministry of Economy, Trade and Industry and the New Energy and Industrial Technology Development Organization.
Hydrogenics, Corp.	NASA	5 kW PEM	USA		Oct. 2004		Hydrogen-oxygen		To be used in NASA's research program for fuel cell operation in future aerospace applications. This was Hydrogenics' first hydrogen-oxygen PEM stack sale. The stack was designed to be very light, which is critical for this type of application.
Hydrogenics, Corp.	Unspecified power company	25 HyPM 10kW PEM			2004--2005				HyPM fuel cells will be incorporated into back-up power products for one of the world's largest suppliers of uninterruptible power.
Hydrogenics, Corp.	City of Toronto	HyLYZER PEM powered hydrogen refueler	Toronto, Canada	Exhibition Place at Hydrogen Village	Aug. 2004				The refueler will use electricity generated by a wind turbine, sited at Exhibition Place, to produce clean hydrogen.
Hydrogenics, Corp.	Itochu Corp, Hitachi Zosen Corporation	10 kW HyPM	Yokkaichi, Japan	"Communal facilities"	Jul. 2004	One-year test	Hydrogen supplied by water electrolysis		Demonstration project. An electrolyser will produce hydrogen on site using electricity from existing solar photovoltaic panels. The hydrogen will then be stored to fuel the power module during hours of peak electricity demand.
Hydrogenics, Corp.	US Navy	PEM-powered refueler	Crane, Indiana	US Navy's Naval Surface Warfare Center-Crane Division	Mar. 2004				
Hydrogenics, Corp.	Science World	20 kW HyPM-LP2 PEM	Vancouver, Canada	Science World geodesic dome	Feb or Mar. 2003	Completed			Used to light the Science World geodesic dome.
Hydrogenics, Corp.	Nextel	25 kW HyUPS	Northern California	Nextel Communications remote cell tower site	Jul. 2002	Sept. 2003			Integrated with an electrolyser to charge the fuel storage module with hydrogen for use by the fuel cell in the event of a power outage. Test protocol was designed to compress the profile of a full year's intermittent outages into a two-month time period.
IdaTech	US Army Corps of Engineers, Construction Engineering Research Lab (CERL), Arizona State University, City of Mesa	5 kW nGen PEM	Mesa, Arizona	Sgt. Herrera US Army Reserve Center	Apr. 2005	Operational	Natural gas		US Department of Defense Residential PEM Fuel Cell Demonstration Program FY 2003. Two fuel cells, made by different manufacturers (Idatech and Plug Power), are operated in parallel during the demonstration. One project objective is to evaluate the performance of each unit under the


									severe heat of Arizona summers.
IdaTech	US Army Corps of Engineers, Construction Engineering Research Lab (CERL), Omaha Public Power District	5 kW EtaGen5 PEM	Omaha, Nebraska	Offutt Air Force Base, Elkhorn Communications Detachment	Jun. 2005	Operational	Propane		US Department of Defense Residential PEM Fuel Cell Demonstration Program FY 2003. Provides grid independent power to field office support loads.
IdaTech	US Army Corps of Engineers, Construction Engineering Research Lab (CERL), Rappahannock Electric Cooperative	5 kW EtaGen 5 PEM	Rappahannock, Virginia	Fort AP Hill Administrative Support building	Jun. 2005	Operational	Propane		US Department of Defense Residential PEM Fuel Cell Demonstration Program FY 2003. Operating off-grid to provide security lighting.
Idatech	RWE Fuel Cells	Nine PEM units	Various locations, Europe			Ongoing in 2004			Being tested at RWE locations and partner sites
IdaTech	RWE Fuel Cells	Two 5 kW PEM CHP units	Berlin, Germany	Office of the representative of the State of the North Rhine-Westphalia	Mar. 2004	Operational	Natural gas		Used in conjunction with a micro gas turbine for the decentralized supply of power, heat and air conditioning for the innovative building.
IdaTech	RWE	4.6 kW EtaGen PEM	Essen, Germany	RWE Fuel Cell Pavilion, Meteorit Park		Ongoing			RWE is testing the fuel cells in a joint project with the municipal utilities and regional suppliers in 2005.
IdaTech	Portland General Electric, Bonneville Power Administration	5 kW PEM	Portland, Oregon	Portland General Electric Earth Advantage National Center	Jan. 2004	Operational			Part of BPA's Northwest demonstration program. First fuel cell in Oregon connected to a power grid. Mira Vowles 503.230.4796 mkvowles@bpa.gov
IdaTech	Propane Education & Research Council	3.6 kW PEM	Bend, Oregon	Remote telecommunications site	Aug. 2003		Propane		Off-grid telecom application for field test and evaluation in the Cascade mountain range.
IdaTech	Electricite de France	1.2 kW FCS 1200 PEM	France	Remote locations	2003				Will be used for integration with solar photovoltaic technology in a hybrid power system for remote locations. The fuel cell system will act as a backup and primary power source, charging the batteries when sunlight is not adequate for the PV panels to generate electricity.
IdaTech	Bonneville Power Administration, Central Electric Co-Operative	5 kW PEM Alpha unit	Redmond, Oregon	Central Electric Co-Operative	Winter 2003	No longer operational			First commercial testing of residential fuel cell systems in the northwest. Six were installed at participating utilities in the initial phase of the test. Buy Down Program Recipient FY1999. (Alpha) fuelcells@bpa.gov Mira Vowles 503.230.4796 mkvowles@bpa.gov
IdaTech	Portland General Electric, Bonneville Power Administration program, Emerald Peoples Utility District	3 kW PEM Alpha unit	Eugene, Oregon	Emerald Peoples Utility District	Winter 2003	No longer operational	Methanol		Alpha unit testing. Supplied power for lights, heat and a cable puller used to stock line trucks from a great spool for 14 hours during a power outage in 2002. Mira Vowles 503.230.4796 mkvowles@bpa.gov

IdaTech	Bonneville Power Administration, PNGC Power	5 kW PEM Alpha unit	Rotating location, USA	PNGC Power	Winter 2003	No longer operational			Alpha unit testing. Mira Vowles 503.230.4796 mkvowles@bpa.gov
IdaTech	Bonneville Power Administration, Energy Northwest Mobile	5 kW PEM Alpha unit	Richmond, Washington	Energy Northwest Mobile	Winter 2003	No longer operational			Alpha unit testing. Mira Vowles 503.230.4796 mkvowles@bpa.gov
IdaTech	Bonneville Power Administration, Lincoln Electric	5 kW PEM Alpha unit	Eureka, Montana	Lincoln Electric	Winter 2003	No longer operational			Alpha unit testing. Mira Vowles 503.230.4796 mkvowles@bpa.gov
IdaTech	Bonneville Power Administration, Fergus Electric	5 kW PEM Alpha unit	Lewiston, Montana	Fergus Electric	Winter 2003	No longer operational			Alpha unit testing. Mira Vowles 503.230.4796 mkvowles@bpa.gov
IdaTech	Governor's Office of Planning and Research, California EPA, the Sacramento Public Utility District	FCS 1200 PEM fuel cell unit	Sacramento, California	California EPA building	Dec. 2002	Completed			Powered lights on a holiday tree.
IdaTech	Electricite de France (EDF)	3 kW PEM unit	France	Research and Development Division of EDF	Feb. 2001	Spring 2002			Field test of prototype unit, targeted for a residential application in France.
IdaTech	Bonneville Power Administration	One-hundred - ten 6 kW CHP fuel cell units	Various locations in the northwest USA	Bonneville Power Administration	2000	No longer operational			10 "alpha" units first installed and tested by BPA, then the remaining 100 "beta" units shipped in late 2000. Testing performed at a variety of electric utility customer sites in the Pacific Northwest, including Central Electric Cooperative in Redmond, Oregon, Consumer's Power Incorporated in Philomath, Oregon; Fergus Electric in Lewistown, Montana; Lincoln Electric in Eureka, Montana; and Energy Northwest in Richland, Washington, among others.
IdaTech	Bonneville Power Administration, Kootenai Electric Cooperative	PEM	Post Falls, Idaho	"Next House" showcase home	Jul. or Aug. 1999	Completed			
IdaTech	Sandia National Laboratories, University of Alaska-Fairbanks	Three PEM fuel cell units	Alaska		Nov. 1998				Initially tested at Sandia Labs before moving to the University of Alaska.
IdaTech	Bonneville Power Administration	5 kW PEM	Bend, Oregon	Private home	Nov. 1998	Completed	Methanol		Provided electricity to a residence. The home was disconnected from the electric power grid of Pacific Power & Light prior to testing and reconnected afterward.
Industrial Research Laboratory (IRL)	Australian Cooperative Research Center for Renewable Energy	6 kW alkaline fuel cell	Perth, Australia	Wind turbine at Murdoch University	Oct. 2002		Hydrogen		The proof-of-concept system is linked to a wind turbine powering an electrolyzer to generate hydrogen. The fuel cell stores energy generated by the turbine and serves as back up when the wind turbine is not capable of producing power. The AFC


									was replaced by a PEM unit in late 2004.
Intelligent Energy	Centre for Renewable Energy Systems Technology (CREST)	2 kW PEM CHP	Leicestershire, UK (England)	West Beacon farm	Installed Fall, 2003				Intelligent Energy is a spin-off company from Loughborough University. Part of the HARI (Hydrogen and Renewable Integration) Project. Incorporates a fuel cell, two wind turbines, electrolyzer and hydrogen storage and feeds commercial and domestic loads on a local mini-grid at West Beacon Farm.
Ishikawajima-Harima Heavy Industries (IHI)	Takagi Industry, Shizuoka Gas, Ishikawajima Shibaura Machinery	Several 1 kW PEM units	Various locations, Japan	Residential	Aug. 2005		Natural gas		Commercialization planned in 2006.
Ishikawajima-Harima Heavy Industries (IHI)	Idemitsu Kosan	5 kW PEM	Suzuka, Japan	Fire station	Mar. 2005	Oct. 2005	LP gas		Will operate 8 hours/day and provide 30% of the electric needs of the building and heat for hot water.
Ishikawajima-Harima Heavy Industries (IHI)	Idemitsu Kosan	5 kW PEM	Tomakomai, Japan	Hokkaido Oil Refinery dormitory	Mar. 2004				Provides one-sixth of the power and hot water requirements of the facility.
Ishikawajima-Harima Heavy Industries (IHI)	Chubu Electric	300 kW MCFC	Nagoya, Japan	Chubu Electric's Shin-Nagoya Thermal Power Station	Spring 2004		Waste gas		
Ishikawajima-Harima Heavy Industries (IHI)	Japan Gas Association	PEM	Japan		2003				Japan Gas Assoc. Phase 2 test of residential PEM fuel cells of different manufacturers.
Ishikawajima-Harima Heavy Industries (IHI)	Idemitsu Kosan	5 kW PEM	Japan	Anegasaki Service Station of Keiyo Apollo Co., Ltd. (subsidiary of Idemitsu Kosan)	Jul. 2003		Kerosene		Demonstration unit.
Ishikawajima-Harima Heavy Industries (IHI)	Chubu Electric Power Co., New Energy and Industrial Technology Development Organization (NEDO), MCFC Research Association	Two 300 kW MCFC units	Nagoya, Japan	Chubu Electric's Kawagoe Thermal Power Station	Jan. 2003	Mid-2004			Verification of performance and durability for 10,000 h by the first half of 2004.
Ishikawajima-Harima Heavy Industries (IHI)	Chubu Electric Power Co., New Energy and Industrial Technology Development Organization (NEDO), MCFC Research Association	300 kW MCFC	Nagoya, Japan	Chubu Electric's Shin-Nagoya Thermal Power Plant	2002		Waste gas		
Ishikawajima-Harima Heavy Industries (IHI)	Toyota, New Energy and Industrial Technology Development Organization (NEDO)	300 kW MCFC-gas turbine hybrid system	Toyota City, Japan	Motomachi Environmental Center of Toyota Motor Corporation	Oct. 2002				Incorporated with a 50 kW gas turbine manufactured by Toyota Turbine and Systems.
Ishikawajima-Harima Heavy Industries (IHI)	Hitachi, Chubu Electric, New Energy and Industrial Technology Development Organization (NEDO), MCFC Research	(1 MW MCFC without internal reformer (Four 250 kW units)	Nagoya, Japan	Chubu Electric's Kawagoe Thermal Power Station	Jun. 1999	1999			5,000 hour demonstration.


Ishikawajima-Harima Heavy Industries (IHI)	Association	40 kW MCFC	Japan		Apr. 1996	3,000-5,000 hours of operation were planned			Verification testing. World's first MCFC with external reforming. Plans for future commercialization.
Ishikawajima-Shibaura Machinery Co. (ISM)	Shizuoka Gas, Takagi Industry Co.	Multiple 1 kW PEM units	Japan	Residential	Aug. 2005		Natural gas		Demonstration of cogeneration system as part of a national large scale monitoring demonstration project. Commercialization planned in 2006.
M-C Power Corp.	San Diego Gas and Electric Co, Bechtel National Inc, Alternative Energy Systems Consulting, Stewart and Stevensen	75 kW MCFC	San Diego, California	Marine Corp Air Station -- Miramar	2002	Five-month test completed			Operated for 3,300 hours. The fuel cell generated 250 kW of electricity. Heat produced by the fuel cell was used in adjacent buildings at the site.
M-C Power Corp.	Electric Power Research Institute, Gas Research Institute, Institute of Gas Technology, Ishikawajima-Harima Heavy Industries Co., Ltd, San Diego Gas & Electric, U.S. Department of Energy	250 MCFC kW	San Diego, California	Marine Corp Air Station -- Miramar	1997	1998			This unit operated for 2,350 hours and delivered 158 MW/hr of direct current output and 296,500 pounds of 110 psig steam to the base.
M-C Power Corp.	San Diego Gas and Electric Co, Gas Research Institute, Bechtel Corp, Stewart and Stevenson, Electric Power Research Institute, Southern California Gas, Institute of Gas Technology	250 MCFC kW	Brea, California	Unocal's research center	1995	Decommissioned			
Minaton (Russian Ministry of Atomic Energy)	International Science and Technology Centers (ISTC), Gaz-prom, Norelsk Nickel Company, Russian Academy of Sciences	1 kW SOFC	Snezhinsk, Russia	All Russia Research Institute of Technical Physics facility	Dec. 2003	Test system operated for several days	Natural gas		First SOFC tested in Russia, built at Minaton factory. Part of multinational ISTC fuel cell construction initiative. Plans to develop a 2.5 kW system.
Matsushita Electrical Industrial Co.	Osaka Gas, Ministry of Land, Infrastructure and Transport	1 kW PEM	Osaka, Japan		2004				Field test.
Matsushita Electrical Industrial Co.	Tokyo Gas	1.3 kW PEM	Saitama, Japan	Tokyo Gas employee's residence	Ten month test operation	Mar. 2003			Cogeneration units.
Matsushita Electrical Industrial Co.	Japan Gas Association	Two 1.3 kW PEM units	Japan		2002		Natural gas		Japan Gas Assoc. Phase 2 test of residential PEM fuel cells of different manufacturers.




Matsushita Electrical Industrial Co.	Japan Gas Association	1 kW PEM	Demonstration tests (7 companies) held in Tokyo, Osaka and Nagoya, Japan		Phase 1: Dec. 2001	Phase I completed Feb. 2002		Japan Gas Assoc. test of residential PEM fuel cells from seven manufacturers (Ballard, Matsushita Electric, Toshiba, Toyota, Sanyo Electric, Mitsubishi Electric, Plug Power). Completed 1,000-hours of operation in Phase I testing, 8,000 hours scheduled in Phase 2 using fuel cells of different manufacturers.
Mitsubishi Electric Corp.	Japan Gas Association	1 kW PEM	Japan		2002		Natural gas	Japan Gas Assoc. Phase 2 test of residential PEM fuel cells from nine manufacturers.
Mitsubishi Electric Corp.	Japan Gas Association	1 kW PEM	Demonstration tests (7 companies) held in Tokyo, Osaka and Nagoya, Japan		Phase 1: Dec. 2001	Phase I completed Feb. 2002		Japan Gas Assoc. test of residential PEM fuel cells from seven manufacturers (Ballard, Matsushita Electric, Toshiba, Toyota, Sanyo Electric, Mitsubishi Electric, Plug Power). Completed 1,000 hours of operation in Phase I testing, 8,000 hours scheduled in Phase 2 using fuel cells of different manufacturers.
Mitsubishi Heavy Industries (MHI)	Electric Power Development Co. (EPDC)	150-200 kW SOFC	Japan	EPDC's Technology Development Center	2006	Planned		10,000 hour test planned.
Mitsubishi Heavy Industries (MHI)	Nippon Oil Corp.	10 kW PEM	Hiroshima Japan	Hiroshima Diamond Hotel	Jun. 2005		Kerosene	
Mitsubishi Heavy Industries (MHI)	Iwatani	PEM CHP	Moriyama, Japan	Shiga technology center	Mar. 2005		LP gas	
Mitsubishi Heavy Industries (MHI)	Electric Power Development Co. (EPDC)	25 kW SOFC with internal reforming	Japan	EPDC's Technology Development Center	Apr. 2005			
Mitsubishi Heavy Industries (MHI)	Nippon Oil Corp.	10 kW PEM	Tokyo, Japan	Convenience store	Mar. 2004	One-year test	Kerosene	
Mitsubishi Heavy Industries (MHI)		Twelve 1 kW PEM units	Japan		Two units shipped Dec. 2002, ten units in 2003		City gas	Field testing to verify performance.
Mitsubishi Heavy Industries (MHI)	Electric Power Development Co. (EPDC)	SOFC	Japan	EPDC's Wakamatsu Works coal gasification pilot plant	Feb. 2002			
Mitsubishi Heavy Industries (MHI)	Chubu Electric Power	15 kW T-MOLB SOFC	Kobe, Japan	MHI's Kobe dockyard	Jul. 2000		Natural gas	Test operated for 7,500 hours.
Mitsubishi Heavy Industries (MHI)	Electric Power Development Co.	Pressurized 1 kW SOFC	Nagasaki, Japan	MHI's Nagasaki Dockyard and Shipping Works	1996			
Mitsubishi Heavy Industries (MHI)	Electric Power Development Co.	1 kW SOFC	Japan	EPDC's Wakamatsu Power Station	1993			Operated continuously for 3,000 hours.
MOSAIC Energy	NiSource Inc., Ishikawajima-Harima Heavy Industries, Gas Technology Institute, Nippon Mitsubishi Oil Corp.	5 kW PEM	Yokohama, Japan	Nippon Mitsubishi Oil's Negishi retail gasoline service station	Jul. 2001	2002	Naphtha	World's first liquid fuel PEM fuel cell test.
MOSAIC Energy	NiSource Inc., Ishikawajima-Harima Heavy Industries, Gas Technology Institute	3 kW PEM	Chesterton, Indiana	Residential unit in new housing development	2000		Natural gas	9+ months of field testing during 2000-2001.





MTU CFC Solutions	Ansaldo Fuel Cells Spa, IZAR, FhG Umsicht, CESPAS, Z.A.E., OVM, University Genova, ASM, Nitra, Technip, E.ON	"MW-sized" MCFC fuel cell plant	Spain		Planned		Biogas		BICEPS project-Biogas Integrated Concepts.
MTU CFC Solutions	Seaborne GmbH	300 kW MCFC	Owschlag, Germany	Seaborne's industrial research center	May 2002	Completed six-month test	Industrial waste biogas		Part of the EFFECTIVE Project, which is testing biogas purification in combination with MCFC units. Co-funded by EU. Operated for 2,500 hours. Used a mobile test bed, with tests on this unit performed in Germany, Austria and Spain.
MTU CFC Solutions	Urbaser SA, CIEMAT	300 kW MCFC	Pinto, Spain	Urbaser waste treatment plant	Feb. 2004	Summer 2004	Landfill gas		Part of the EFFECTIVE Project, which is testing biogas purification in combination with MCFC units. Co-funded by EU. Operated for 2,000 hours. Used a mobile test bed, with tests on this unit performed in Germany, Austria and Spain.
MTU CFC Solutions	University of Nitra	300 kW MCFC	Nitra, Slovak Republic	University of Nitra's Agricultural Biogas plant		Two-year test	Agricultural biogas		Part of the EFFECTIVE Project, which is testing biogas purification in combination with MCFC units. Co-funded by EU. Operated for 2,400 hours in the first cycle, 3,300 hours in the second cycle and 3,600 hours in the third cycle. Achieved less than 10 ppm of H ₂ S in the outlet gas.
MTU CFC Solutions	Linz AG	300 kW MCFC	Linz, Austria	Asten waste water treatment plant	Mar. 2003	Two-month test	Wastewater treatment biogas		Part of the EFFECTIVE Project, which is testing biogas purification in combination with MCFC units. Co-funded by EU. Operated for 1,500 hours. Used a mobile test bed, with tests on this unit performed in Germany, Austria and Spain.
Nuvera	US Department of Defense, Earthwell Energy	4.6 kW PEM	Fort Knox, Kentucky	Fort Knox indoor pool	Planned	Contract awarded Jun. 2004	Natural gas		US Department of Defense Residential PEM Fuel Cell Demonstration Program FY 2004.
Nuvera	Deere & Co.	5.5 kW H ₂ e PEM		Deere & Co.	Sale completed Mar. 2005				Sold for testing and evaluation as a potential off-road equipment power source.
Nuvera	Toro Co.	H ₂ e PEM		Toro Co.	Delivered Nov. 2004				For evaluation for potential use in professional grounds and turf care equipment.
Nuvera	Takagi Industrial Co., Ltd, Japan Gas Association, Mitsui & Co. Ltd	3.3 kW Avanti PEM	Japan	Japan Gas Association facility	Mar. 2004		Natural gas		Delivered under the Japanese government's Millennium Program – a five-year effort to examine PEM fuel cells to establish technical codes and standards for the Japanese market.
Nuvera	US Army Corps of Engineers, Construction Engineering Research Lab (CERL)	Two 5 kW Avanti PEM units	Bristol, Rhode Island	Coast Guard Aids to Navigation Team, maintenance facility	Feb. 2004	Completed	Natural gas		US Department of Defense Residential PEM Fuel Cell Demonstration Project FY 2002.. Operated in parallel with the electric grid. Grant awarded by Connecticut Renewable Energy Trust's






									Green Power Fuel Cell Initiative.
Nuvera	Aventine Renewable Energy (formerly Williams Bioenergy)	15 kW PEM	Pekin, Illinois	Visitors Center at Aventine Renewable Energy's ethanol production facility	Planned	Announced in 2003	Corn-based ethanol		Six-month, 4,000 hour demonstration planned.
Nuvera	RWE	Twenty-five 5 kW CHP PEM units	Germany	Apartment buildings	Aug. 2002		Natural gas		Field test--part of joint venture between Nuvera and RWE Plus AG to develop and distribute fuel cell systems up to 50 kW (CHP) to Europe. Gianfranco.mora@denora.it
Nuvera	RWE	5 kW PEM	Essen, Germany	RWE Fuel Cell Pavilion, Meteorit Park	Aug. 2002	Completed			Field testing for use in residential energy sector.
Nuvera	Verizon	5 kW PEM	Cambridge, Massachusetts	Arthur D. Little's international headquarters	2001	Two-year demonstration	Natural gas		Powered a portion of the telecommunications infrastructure.
Nuvera	Massachusetts Technology Collaborative, SatCon Tech. Corp., KeySpan Energy Delivery, Verizon	5 kW PEM	Woburn, Massachusetts	Verizon's engineering facility	Dec. 2001	Completed 500-hour demonstration	Natural gas		US's first fuel cell powered telecommunications site. Grant awarded by Connecticut Renewable Energy Trust's Green Power Fuel Cell Initiative. Mark.a.marchand@verizon.com Derby.r@nuvera.com
Plug Power, Inc.	US Army Corps of Engineers Construction Engineering Research Lab (CERL), LOGANEnergy	5 kW GenCore PEM	Washington, DC	Department of State, Administrative Center of the International Chancery Conclave (ICC)	Planned	Contract awarded Aug. 2003	Hydrogen		US Department of Defense Residential PEM Fuel Cell Demonstration Program FY 2002. Will provide grid parallel service to selected circuits in the administration building to simulate support of critical or emergency loads.
Plug Power, Inc.	State of Florida, US Department of Defense	5 kW PEM	Florida	Tyndall Air Force Base tent city	Planned	Contract awarded Jun. 2005	Propane		US Department of Defense Residential PEM Fuel Cell Demonstration Program FY 2004.
Plug Power, Inc.	US Department of Defense, LOGANEnergy	5 kW GenSys PEM	Colorado Springs, Colorado	US Air Force Academy gymnasium	One year demonstration planned	Contract awarded Jun. 2005	Natural gas		US Department of Defense Residential PEM Fuel Cell Demonstration Program FY 2004. The unit will be electrically configured to provide grid parallel service to the site and it will also be thermally integrated with a building domestic hot water system.
Plug Power, Inc.	US Department of Defense, LOGANEnergy	5 kW PEM	Puerto Rico	Muniz Air National Guard base	Planned	Contract awarded Jun. 2005	Propane		US Department of Defense Residential PEM Fuel Cell Demonstration Program FY 2004.
Plug Power, Inc.	US Department of Defense, LOGANEnergy	Two 5 kW PEM units	Keflavick, Iceland	US Naval Air Station	Planned	Contract awarded Jun. 2005	Hydrogen		US Department of Defense Residential PEM Fuel Cell Demonstration Program FY 2004.
Plug Power, Inc.	US Department of Defense, LOGANEnergy	Two 5 kW PEM units	Fort Hood, Texas	Fort Hood	Planned	Contract awarded Jun. 2005	Hydrogen		US Department of Defense Residential PEM Fuel Cell Demonstration Program FY 2004.
Plug Power, Inc.	Federal Aviation Administration, LOGANEnergy	5 kW PEM	Sandersonville, Georgia	FAA site, Sandersonville Airport	Planned	Contract awarded Jun. 2005	Hydrogen		US Department of Defense Residential PEM Fuel Cell Demonstration Program FY 2004.
Plug Power, Inc.	Alcorn State University, LOGANEnergy	5 kW PEM	Lorman, Mississippi	Alcorn State University ROTC facility	Planned	Contract awarded Jun. 2005	Natural gas		US Department of Defense Residential PEM Fuel Cell Demonstration Program FY 2004.

Plug Power, Inc.	US Army Corps of Engineers Construction Engineering Research Lab (CERL), LOGANEnergy	5 kW PEM	Austin, Texas	NGB Camp Mabry Texas National Guard Museum	Planned	One year demonstration	Natural gas		US Department of Defense Residential PEM Fuel Cell Demonstration Program FY 2003. Will provide grid parallel service to the site and will also be thermally integrated with a small desiccant HVAC unit to provide seasonally warm or cool dry air to benefit moisture sensitive displays in the museum.
Plug Power, Inc.	US Army Corps of Engineers Construction Engineering Research Lab (CERL), LOGANEnergy	5 kW GenSys PEM	London, United Kingdom	US Embassy, Abbey Road Residence, mechanical room	Planned	Contract awarded Apr. 2004	Natural gas		US Department of Defense Residential PEM Fuel Cell Demonstration Program FY2003 and UK PEM demonstration project. Will be electrically configured to provide grid parallel / grid independent service to the facility. The fuel cell installation will also provide up to 8,000 Btu/h to the facility's hot water system.
Plug Power, Inc.	US Department of Defense	Ten 5 kW PEM units	Warner Robins, Georgia	Robins Air Force Base	Planned	Announced Jul. 2005	Liquefied petroleum gas		Part of the US Department of Defense Common Core Power Production Program.
Plug Power, Inc.	US Army Corps of Engineers Construction Engineering Research Lab (CERL), LOGANEnergy	5 kW GenSys 5C PEM	Champaign, Illinois	ERDC / CERL equipment shed	Planned	One-year demonstration	Liquid propane gas		US Department of Defense Residential PEM Fuel Cell Demonstration Program FY 2002. Will provide grid parallel/grid independent service to the site, as well as be thermally integrated with a fan coil space heater to provide supplemental heating to the equipment shed during the test period.
Plug Power, Inc.	US Army Corps of Engineers Construction Engineering Research Lab (CERL), LOGANEnergy	5 kW PEM	Biloxi, Mississippi	Keesler Air Force Base housing	Mar. 2005	Operational	Natural gas		US Department of Defense Residential PEM Fuel Cell Demonstration Program FY 2003
Plug Power, Inc.	US Army Corps of Engineers Construction Engineering Research Lab (CERL), LOGANEnergy	5 kW PEM	Eastover, South Carolina	McEntire Air National Guard fire station	Mar. 2005	Operational	Natural gas		US Department of Defense Residential PEM Fuel Cell Demonstration Program FY 2003. Electrically configured to provide grid parallel/grid independent service to the facility and will also be thermally integrated with its gas-fired water to support domestic thermal loads.
Plug Power, Inc.	US Army Corps of Engineers Construction Engineering Research Lab (CERL), LOGANEnergy	5 kW PEM	Herlong, California	Sierra Army Depot housing	Mar. 2005	One year demonstration	Propane		Electrically configured to provide grid parallel/grid independent service to the site, and it will also be thermally integrated with a SynDex heat pump to provide supplemental heating and cooling. US Department of Defense Residential PEM Fuel Cell Demonstration Program
Plug Power		GenCore PEM	New York	New York Institute of Technology campus	Fall 2005		Hydrogen supplied by PV panels		The fuel cell provides power and heat to the "Green machine/Blue Space" project, a 100% solar house competing in the US DOE's Solar Decathlon. The house will be displayed on the National Mall, Washington

									DC during Oct. 2005. Partly funded by the Long Island Power Authority.
Plug Power, Inc	H.M. Cragg Co, FTTH Communications LLC, Loretel Systems	5 kW GenCore PEM	Albertville, Minnesota	FTTH Communications facility	Installed Sep. 2005		Hydrogen		Partly funded by a Minnesota Department of Commerce grant for fuel cell telecom back up power projects.
Plug Power, Inc.	Delaware County Electric Cooperative, State University of New York-Delhi, Gaia Power Technologies	PEM	Tompkins, New York	Residential	Jun. 2005	One-year demonstration	Propane		The fuel cell is integrated with a power electronics and battery storage system. Demonstration is part of a New York State Energy Research and Development Authority (NYSERDA) and US DOE Energy Storage Initiative. Funded by a \$300,000 grant under a US Congressional Earmark and \$175,000 NYSERDA grant.
Plug Power, Inc.	Vaillant, EnBW, Caritas, Stadtwerke Ettlingen GmbH	EURO 2 PEM CHP	Ettlingen, Germany	Caritas Nursing Home	Jun. 2005		Natural gas		Provides heat and power.
Plug Power, Inc.	Tyco Electronics Power Systems	Ninety-eight 5 kW GenCore 5T PEM units		Tele-communication sites	Sale announced July 2005				Purchased by Tyco Electronics Power Systems for resale to a US telecommunications company.
Plug Power, Inc.	Vaillant	4.6 kW PEM micro-CHP	Lievin, France		First quarter 2005		Natural gas		
Plug Power, Inc.	Florida Department of Environmental Protection	Twelve 5 kW GenCore PEM units	Florida	Florida Department of Environmental Protection field offices throughout the state	Sale announced June 2005		Hydrogen gas		Will provide back-up power.
Plug Power, Inc.	Yurtec Corporation of Tohoku Electric Power Co., Inc	5 kW PEM	Miyagi Prefecture, Japan	Yurtec Corp's Development Center of Human Resources	Apr. 2005	One-year demonstration			
Plug Power, Inc.	Long Island Power Authority (LIPA), Local 25 International Brotherhood of Electrical Workers (IBEW)	5 kW PEM	Hauppauge, New York	Local 25 International Brotherhood of Electrical Workers headquarters	Apr. 2005	Installed			Will generate electricity and provide supplemental domestic hot water to the IBEW facility. During an electrical outage the fuel cell is capable of operating independent of the electric grid, supplying electricity to critical loads and emergency lighting throughout the facility.
Plug Power, Inc.	The Stella Group Ltd.	5 kW GenCore PEM	Arlington, Virginia	The Stella Group Ltd. office	Leased May 2005		Hydrogen		
Plug Power, Inc.	US Army Corps of Engineers Construction Engineering Research Lab (CERL), LOGANEnergy	5 kW GenSys PEM CHP	Kaneohe Bay, Hawaii	Marine Corp Base Hawaii-Kaneohe Bay base housing	Mar. 2005	Ongoing	Propane		US Department of Defense Residential PEM Fuel Cell Demonstration Program FY 2003. Supplies power to kitchen appliances and outlets, and cogenerated heat is used for hot water.
Plug Power, Inc.	US Army Corps of Engineers, Construction Engineering Research Lab (CERL), Arizona State University, City of Mesa Gas Division	5 kW GenSys 5CS PEM	Mesa, Arizona	Sgt. Herrera US Army Reserve Center	Mar. 2005	Operational	Natural gas		US Department of Defense Residential PEM Fuel Cell Demonstration Program FY 2003. Two fuel cells, made by different manufacturers (Idatech and Plug Power), are operated in parallel during the demonstration. One project objective is to evaluate the performance of each unit under the severe heat of Arizona




								summers.
Plug Power, Inc.	US Army Corps of Engineers Construction Engineering Research Lab (CERL), Flint Energies	5 kW PEM	Ft. Benning, Georgia	Ft. Benning Sandhill Recreation Center	Contract awarded Jun. 2004	Installed	Natural gas	US Department of Defense Residential PEM Fuel Cell Demonstration Program FY 2003. Will operate in grid parallel mode to provide supplemental on-site power and usable heat for heating and domestic hot water.
Plug Power, Inc.	Vaillant, Salzburg AG, Salzburg Wohnbau	EURO 2 PEM CHP	Salzburg, Austria	Apartment	Late 2004	Two-year project	Natural gas	Provides heat and power. Testing project for possible future introduction of a fuel cell CHP product by Salzburg AG and Salzburg Wohnbau.
Plug Power, Inc.	US Army Corps of Engineers Construction Engineering Research Lab (CERL), LOGANEnergy	5 kW GenSys5P PEM	Honolulu, Hawaii	Schofield Barracks fire station	Dec. 2004	Operational	Propane	 US Department of Defense Residential PEM Fuel Cell Demonstration Program FY 2003. Combines both grid parallel/grid independent electrical configurations to support the power requirements of the fire station. The unit is also thermally integrated with the fire station's hot water heater in order to transfer fuel cell process heat to the fire station's hot water tank.
Plug Power, Inc.	Vaillant, Dalkia	4.6 kW PEM micro-CHP	Giromany, France		Dec. 2004	Ongoing		
Plug Power, Inc.	Vaillant	4.6 kW PEM micro-CHP	Orleans, France		Dec. 2004	Ongoing	Natural gas	
Plug Power, Inc.	Vaillant, EDF, Dalkia, OPHLM of Sarreguemines	Fifty-two 4.6 kW PEM micro-CHP, Euro 2 version	Sarreguemines, France	Various residences	Jun. 2004	Ongoing	Natural gas	Produces power, and heat for hot water. Vaillant is evaluating performance.
Plug Power, Inc.	US Army Corps of Engineers, Construction Engineering Research Lab (CERL), City of Mesa Gas Division, Arizona Army National Guard	5 kW GenSys 5CS PEM	Mesa, Arizona	Arizona Army National Guard Center	Jul. 2005	On-year demonstration	Natural gas	 US Department of Defense Residential PEM Fuel Cell Demonstration Program FY 2003. Grid connected in parallel mode. The thermal energy produced will be used to generate domestic hot water for the building.
Plug Power, Inc.	Montana State University, US Army Corp of Engineers Construction Engineering Research Laboratory (CERL)	5 kW GenSys 5CS PEM	Billings, Montana	Montana Army National Guard Armed Forces Reserve Center	Dec. 2004	One-year demonstration	Natural gas	 US Department of Defense Residential PEM Fuel Cell Demonstration Program FY 2003. The unit will operate at 50% capacity and configured to serve a portion of the base electrical load, operating in parallel with the existing grid-supplied power. The project is also configured for heat recovery.
Plug Power, Inc.	US Army Corps of Engineers Construction Engineering Research Lab (CERL), LOGANEnergy	5 kW GenSys 5C PEM	El Segundo, California	Los Angeles Air Force Base Civil Engineering Office	May 2005	Operational	Natural gas	Electrically configured to provide grid parallel/grid independent service and also thermally integrated with the facility's hot water system. US Department of Defense Residential PEM Fuel Cell Demonstration Program
Plug Power, Inc.	US Army Corps of Engineers Construction Engineering Research Lab (CERL), LOGANEnergy	5 kW GenSys 5C PEM	Hill Air Force Base, Utah	Hill Air Force Base fire station	Feb. 2005	One year demonstration	Natural gas	US Department of Defense Residential PEM Fuel Cell Demonstration Program FY 2003
Plug Power, Inc.	US Army Corps	5 kW GenSys	Riverside,	March Air	Feb. 2005	Operational	Natural gas	Electrically configured to










	of Engineers Construction Engineering Research Lab (CERL), LOGANEnergy	5C PEM	California	Reserve Base airman's dormitory					provide grid parallel/grid independent service and also thermally integrated with the facility's hot water system. US Department of Defense Residential PEM Fuel Cell Demonstration Program FY 2003
Plug Power, Inc.	US Army Corps of Engineers Construction Engineering Research Lab (CERL), LOGANEnergy	5 kW GenSys5C PEM	Alexandria, Virginia	Fort Belvoir fire station	Mar. 2005	One year demonstration	Natural gas		US Department of Defense Residential PEM Fuel Cell Demonstration Program FY 2002. Will provide grid parallel/grid independent service to the facility and it is also thermally integrated with its gas-fired water heater to support domestic thermal loads.
Plug Power, Inc.	US Army Corps of Engineers Construction Engineering Research Lab (CERL), LOGANEnergy	5kW GenSys5P PEM	Cherry Point, North Carolina	Marine Corps Air Station Cherry Point maintenance facility	Dec. 2004	Operational	Propane		US Department of Defense Residential PEM Fuel Cell Demonstration Program. FY 2002. Operates in both grid parallel and grid independent configurations. To demonstrate the thermal energy capability of the fuel cell, a 22,000 BTU fan coil unit will be installed on the facility's ceiling to distribute waste heat from the fuel cell.
Plug Power, Inc.	US Army Corps of Engineers Construction Engineering Research Lab (CERL), LOGANEnergy, Georgia Tech, Energy Signature Associates	5 kW GenSys5C PEM	Atlanta, Georgia	Georgia Institute of Technology Air Force ROTC resource center	Mar. 2005	Operational	Natural gas		US Department of Defense Residential PEM Fuel Cell Demonstration Program FY 2002.
Plug Power, Inc.	US Army Corps of Engineers Construction Engineering Research Lab (CERL), LOGANEnergy, Energy Signature Associates.	5 kW GenSys 5C PEM	Fort Gordon, Georgia	Fort Gordon Army University of Technology Resource Center	Jun. 2004	Demonstration completed	Natural gas		US Department of Defense Residential PEM Fuel Cell Demonstration Program FY 2002. Provided back up to the servers that support the online virtual training center.
Plug Power, Inc.	BOC Group plc, Johnson Matthey, Greater London Authority, London Hydrogen Partnership, siGEN.	5 kW PEM GenCore 5T	London, UK (England)	Trafalgar Square	Dec. 2004	Completed			Provided electricity for the holiday tree located in London at Trafalgar Square
Plug Power, Inc.	Oneida County Rural Telephone Company	5 kW PEM GenCore 5T	Oneida County, New York	Remote telecommunicati ons hut	Jul. 2004	Ongoing	Natural gas		Has successfully provided backup power during storm-related power interruptions.
Plug Power, Inc.	HyRadix Inc, Department of Energy, Propane Education and Research Council, Texas Fuel Cell Partnership	5 kW PEM	San Antonio, Texas	Texas Department of Transportation TransGuide headquarters	Apr. 2004	Completed three month demonstration	Propane		Technical Contact: Dan Kelly dan.kelly@rrc.state.tx.us Partnership Contact: Ken Zarker kzarker@tceq.state.tx.us







Plug Power, Inc.	US Army Corps of Engineers Construction Engineering Research Lab (CERL), LOGANEnergy, Energy Signature Associates	5 kW GenSys5P PEM	Stennis Space Center, Mississippi	Mars Habitat at the Stennis Space Center's Visitors Facility	Sep. 2004	Ongoing	Natural gas		US Department of Defense Residential PEM Fuel Cell Demonstration Project FY 2002.
Plug Power, Inc.	Orange, BOC Group, FDT Associates	5 kW PEM GenCore 5T PEM	Elgin, UK (Scotland)	Remote telecommunications site at Huntly Nordic Ski Center training site	Jan. 2004	Ongoing	Hydrogen		The cell site is situated in a forest at the Huntly Nordic Ski Center, providing telecommunication coverage between Rhynie and Elgin. The GenCore provides back-up power to a LPG generator.
Plug Power, Inc.	LP Gas, Logan Energy Corp, US Army Corp of Engineers Construction Engineering Research Lab (CERL)	5 kW PEM GenSys 5P	Yosemite National Park, California	Administration building at Yosemite Village	Apr. 2004	Operational	Liquid petroleum gas (LPG)		Yosemite National Park PEM Fuel Cell Demonstration Project. The fuel cell provides electricity to the Administration Building in Yosemite Village and fuel cell heat is used to provide hot water. A set of plug-ins added to the circuit from the cell to the building allows the park to recharge its electric car fleet. A second Plug Power fuel cell has been purchased and will be installed at a separate location in the park.
Plug Power, Inc.	Florida Power and Light Co., US Department of Energy, Florida Department of Environmental Protection	5 kW PEM	North Port, Florida	North Port High School	Apr. 2004	Installed			The first of 10 Hydrogen Education sites nationwide. DOE has supplied the school with a hydrogen curriculum and laboratory experiments.
Plug Power, Inc.	US Army Corps of Engineers Construction Engineering Research Lab (CERL), Southern Maryland Electric Cooperative	5 kW PEM	Patuxent River, Maryland	Patuxent Naval Air Station office building	Jan. 2004	Completed 12-month demonstration	Propane		Department of Defense PEM Residential Fuel Cell Demonstration Program FY 2001. Powered 9 desktop computers, office lighting, oil furnace, and life support systems for animals on display in environmental / conservation building. Grid connected. Excess power transferred to the grid. Cogenerated heat used to provide heat to the building during cold months.
Plug Power, Inc.	US Army Corps of Engineers Construction Engineering Research Lab (CERL), Southern Maryland Electric Cooperative	5 kW PEM	Patuxent River, Maryland	Patuxent Naval Air Station single-family residence	Jan. 2004	Completed 12-month demonstration	Natural gas		Department of Defense PEM Residential Fuel Cell Demonstration Program FY 2001. Powered lighting, boiler and pumps, refrigerator, kitchen counter receptacles and sump pump. Grid connected. Excess power transferred to the grid. Co-generated heat used the entire year for water heater.
Plug Power, Inc.	Long Island Power Authority (LIPA)	Two 5 kW GenSys 5C PEM CHP units	Garden City, New York	Nassau Community College	Installed Feb. 2004	Operating	Natural gas		
Plug Power, Inc.	VNG, Freiburger Erdgas	4.5 kW EURO 2 PEM CHP	Freiberg, Germany	Nursing home	Fall 2004	Operating	Natural gas		Part of the VNG DemoCell project. Provides power, heating, and heat for hot

									water.
Plug Power, Inc.	siGEN, Centre for Renewable Energy and Sustainable Technology (CREST)	5 kW Gencore PEM	UK	Beacon Energy	Summer, 2004				Part of CREST's HARI (Hydrogen and Renewables Integration) project.
Plug Power, Inc.	Vaillant, Erdgas, Energie AG	4.5 kW Euro 2 PEM CHP	Dietachdorf, Austria	Restaurant and hotel	Feb. 2004		Natural gas		Provides heat and power.
Plug Power, Inc.	Ichitaka Co., Mitsuuroko Co, Kamata Co., Sanwa	4 kW PEM	Tsukuba, Japan	House exhibition center	Aug. 2004	One-year demonstration	Liquefied petroleum gas (LPG)		Cogeneration system
Plug Power, Inc.	siGEN, Unst Partnership	5 kW Gencore PEM	Unst, UK (Scotland)	Hagdale Business Park	Contract signed Jan. 2004				Part of the Pure (Promoting Unst Renewable Energy) Project. Incorporates a fuel cell, two wind turbines, electrolyzer and hydrogen storage.
Plug Power, Inc.	Vaillant, EWE, E.ON Energie	4.6 kW Euro 2 (GenSys) PEM Fuel Cell Heating Appliance (FCHA)	Remscheid, Germany	Apartment building	Installed late 2003 or early 2004	Scheduled completion in 2006	Natural gas		Part of European Commission-funded project "European Virtual Fuel Cell Power Plant" to examine centrally controlled fuel cell heating systems connected to the electricity grid
Plug Power, Inc.	Vaillant, EWE, E.ON Energie	Three 4.6 kW Euro 2 (GenSys) PEM Fuel Cell Heating Appliance (FCHA)	Oldenburg, Germany	Two units at apartment buildings, one unit at the Federal Technological Center for Electrical Engineering and Information Technology	Installed late 2003 or early 2004	Scheduled completion in 2006	Natural gas		Part of European Commission-funded project "European Virtual Fuel Cell Power Plant" to examine centrally controlled fuel cell heating systems connected to the electricity grid
Plug Power, Inc.	Vaillant, EWE, E.ON Energie	4.6 kW Euro 2 (GenSys) PEM Fuel Cell Heating Appliance (FCHA)	Aurich, Germany	Apartment building	Installed late 2003 or early 2004	Scheduled completion in 2006	Natural gas		Part of European Commission-funded project "European Virtual Fuel Cell Power Plant" to examine centrally controlled fuel cell heating systems connected to the electricity grid
Plug Power, Inc.	Vaillant, EWE, E.ON Energie	4.6 kW Euro 2 (GenSys) PEM Fuel Cell Heating Appliance (FCHA)	Cuxhaven, Germany	Apartment building	Installed late 2003 or early 2004	Scheduled completion in 2006	Natural gas		Part of European Commission-funded project "European Virtual Fuel Cell Power Plant" to examine centrally controlled fuel cell heating systems connected to the electricity grid
Plug Power, Inc.	Vaillant, Ruhrgas, EAM EnergiePlus	4.6 kW Euro 2 (GenSys) PEM Fuel Cell Heating Appliance (FCHA)	Wolfhagen, Germany	Apartment building	Installed late 2003 or early 2004	Scheduled completion in 2006	Natural gas		Part of European Commission-funded project "European Virtual Fuel Cell Power Plant" to examine centrally controlled fuel cell heating systems connected to the electricity grid
Plug Power, Inc.	Vaillant, Ruhrgas, EAM EnergiePlus	4.6 kW Euro 2 (GenSys) PEM Fuel Cell Heating Appliance (FCHA)	Volkmarzen, Germany	Apartment building	Installed late 2003 or early 2004	Scheduled completion in 2006	Natural gas		Part of European Commission-funded project "European Virtual Fuel Cell Power Plant" to examine centrally controlled fuel cell heating systems connected to the electricity grid
Plug Power, Inc.	Vaillant, Ruhrgas, EAM EnergiePlus	4.6 kW Euro 2 (GenSys) PEM Fuel Cell Heating Appliance (FCHA)	Baunatal, Germany		Installed late 2003 or early 2004	Scheduled completion in 2006	Natural gas		Part of European Commission-funded project "European Virtual Fuel Cell Power Plant" to examine centrally controlled fuel cell heating systems connected to the electricity grid







Plug Power, Inc.	Vaillant, Ruhrgas, Stadtwerke Hilden, E.ON Energie	4.6 kW Euro 2 (GenSys) PEM Fuel Cell Heating Appliance (FCHA)	Hilden, Germany	Apartment building	Installed late 2003 or early 2004	Scheduled completion in 2006	Natural gas	electricity grid Part of European Commission-funded project "European Virtual Fuel Cell Power Plant" to examine centrally controlled fuel cell heating systems connected to the electricity grid
Plug Power, Inc.	Vaillant, ELE, Ruhrgas, E.ON Energie	4.6 kW Euro 2 (GenSys) PEM Fuel Cell Heating Appliance (FCHA)	Gelsenkirchen, Germany	Apartment building	Installed late 2003 or early 2004	Scheduled completion in 2006	Natural gas	Part of European Commission-funded project "European Virtual Fuel Cell Power Plant" to examine centrally controlled fuel cell heating systems connected to the electricity grid
Plug Power, Inc.	Vaillant, Gasunie, Vereniging van Eigenaren Minervavliet	4.6 kW Euro 2 (GenSys) PEM Fuel Cell Heating Appliance (FCHA)	Groningen, Netherlands	Apartment building	Installed late 2003 or early 2004	Scheduled completion in 2006	Natural gas	Part of European Commission-funded project "European Virtual Fuel Cell Power Plant" to examine centrally controlled fuel cell heating systems connected to the electricity grid
Plug Power, Inc.	Vaillant, Gasunie, Essent	Two 4.6 kW Euro 2 (GenSys) PEM Fuel Cell Heating Appliance (FCHA)	Hertogenbosch, Netherlands		Installed late 2003 or early 2004	Scheduled completion in 2006	Natural gas	Part of European Commission-funded project "European Virtual Fuel Cell Power Plant" to examine centrally controlled fuel cell heating systems connected to the electricity grid
Plug Power, Inc.	Vaillant, Gasunie, Inter Paris	4.6 kW Euro 2 (GenSys) PEM Fuel Cell Heating Appliance (FCHA)	Klazienaveen, Netherlands		Installed late 2003 or early 2004	Scheduled completion in 2006	Natural gas	Part of European Commission-funded project "European Virtual Fuel Cell Power Plant" to examine centrally controlled fuel cell heating systems connected to the electricity grid
Plug Power, Inc.	Vaillant, Gasunie, Woonstade Hookgerk-Noorddijk	4.6 kW Euro 2 (GenSys) PEM Fuel Cell Heating Appliance (FCHA)	Hoogkerk, Netherlands	Apartment building	Installed late 2003 or early 2004	Scheduled completion in 2006	Natural gas	Part of European Commission-funded project "European Virtual Fuel Cell Power Plant" to examine centrally controlled fuel cell heating systems connected to the electricity grid
Plug Power, Inc.	Vaillant, Gasunie, Vereniging van Eigenaren Hoogzandveld	4.6 kW Euro 2 (GenSys) PEM Fuel Cell Heating Appliance (FCHA)	Nieuwegein, Netherlands		Installed late 2003 or early 2004	Scheduled completion in 2006	Natural gas	Part of European Commission-funded project "European Virtual Fuel Cell Power Plant" to examine centrally controlled fuel cell heating systems connected to the electricity grid
Plug Power, Inc.	Vaillant, Gasunie, St. Elisabeth zorg en Verpleeghuis	4.6 kW Euro 2 (GenSys) PEM Fuel Cell Heating Appliance (FCHA)	Amersfoort, Netherlands		Installed late 2003 or early 2004	Scheduled completion in 2006	Natural gas	Part of European Commission-funded project "European Virtual Fuel Cell Power Plant" to examine centrally controlled fuel cell heating systems connected to the electricity grid
Plug Power, Inc.	Vaillant, Gasunie Wonen Breeburg	Two 4.6 kW Euro 2 (GenSys) PEM Fuel Cell Heating Appliance (FCHA)	Tilburg, Netherlands		Installed late 2003 or early 2004	Scheduled completion in 2006	Natural gas	Part of European Commission-funded project "European Virtual Fuel Cell Power Plant" to examine centrally controlled fuel cell heating systems connected to the electricity grid
Plug Power, Inc.	Vaillant, Gasunie Vidomes	4.6 kW Euro 2 (GenSys) PEM Fuel Cell Heating Appliance	Leidschendam, Netherlands		Installed late 2003 or early 2004	Scheduled completion in 2006	Natural gas	Part of European Commission-funded project "European Virtual Fuel Cell Power Plant" to examine centrally


		(FCHA)							controlled fuel cell heating systems connected to the electricity grid
Plug Power, Inc.	DLR, Sistemas De Calor	4.6 kW Euro 2 (GenSys) PEM Fuel Cell Heating Appliance (FCHA)	Almeria, Spain		Late 2003	Scheduled completion in 2006	Natural gas		Part of European Commission-funded project "European Virtual Fuel Cell Power Plant" to examine centrally controlled fuel cell heating systems connected to the electricity grid
Plug Power, Inc.	IST	4.6 kW Euro 2 (GenSys) PEM Fuel Cell Heating Appliance (FCHA)	Lisbon, Portugal	Instituto Superior Tecnico at the University of Lisbon	Late 2003	Scheduled completion in 2006	Natural gas		Part of European Commission-funded project "European Virtual Fuel Cell Power Plant" to examine centrally controlled fuel cell heating systems connected to the electricity grid
Plug Power, Inc.	Vaillant, Gasunie, BMW Den Haag	4.6 kW Euro 2 (GenSys) PEM Fuel Cell Heating Appliance (FCHA)	The Hague, Netherlands	BMW dealership	2003	Scheduled completion in 2006	Natural gas		Part of European Commission-funded project "European Virtual Fuel Cell Power Plant" to examine centrally controlled fuel cell heating systems connected to the electricity grid. Also part of BMW's H2ague Project promoting the non-mobile use of fuel cells.
Plug Power, Inc.	Vaillant, SOTEG Luxembourg, town of Luxembourg	4.6 kW Euro 2 (Gensys) PEM Fuel Cell Heating Appliance (FCHA) CHP	Luxembourg City, Luxembourg	School and Sporting Center	Jun. 2003				
Plug Power, Inc.	Mitsui & Co. Ltd, Osaka Gas	Eight 500 W Beta PEM CHP units	Kansai, Japan	Osaka Gas facility and field locations	Apr. 2003		Natural gas		Technical venture to develop a 500W residential cogeneration fuel cell system for the Japanese market. Provides primary power and hot water for a residence. One unit has been installed in Osaka Gas' NEXT21, an experimental condominium complex located in Osaka.
Plug Power, Inc.	Marubeni, New Energy Foundation	Two 5 kW GenSys PEM units	Japan		Lease announced Sep. 2003		Town gas		
Plug Power, Inc.	Marubeni	5 kW GenSys PEM	Oga, Japan		Lease announced Sep. 2003		Propane		
Plug Power, Inc.	Long Island Power Authority (LIPA)	Three 5 kW CHP PEM units	Hauppauge, New York	Suffolk County William Rogers Legislative Building	Installed Aug. 2003		Natural gas		Will be interconnected to LIPA's grid and operate in a combined heat and power mode, providing electricity and heat on-site
Plug Power, Inc.	US Army Corps of Engineers Construction Engineering Research Lab (CERL), Gas Technology Institute, Southwest Research Institute	GenSys5CS 5 kW PEM	San Antonio, Texas	Brooks City Base Challenger Learning Center	Feb. 2003	Completed one-year demonstration	Natural gas		DOD Residential Fuel Cell Demonstration Program. Provided heat and power.
Plug Power, Inc.	US Department of Defense, LOGANEnergy, Energy Signature Associates, Flint Energies	5 kW GenSys5C PEM	Warner Robins, Georgia	Robins Air Force Base fire station	Apr. 2003	Demonstration completed	Natural gas		US Department of Defense Residential PEM Fuel Cell Demonstration Program FY 2002.


Plug Power, Inc	US Army Corps of Engineers Construction Engineering Research Lab (CERL)	Eight 5 kW PEM units	Saratoga Springs, New York	Saratoga Springs Naval Support Unit base housing	Apr. 2003	Jul. 2004	Natural gas		US Department of Defense Residential PEM Fuel Cell Demonstration Program FY 2002. Provided electricity and hot water to four separate apartment buildings
Plug Power, Inc	US Army Corps of Engineers Construction Engineering Research Lab (CERL), LOGAN Energy, North Carolina State Agricultural and Technical University	5 kW GenSys 5CS PEM	Greensboro, North Carolina	North Carolina State Agricultural and Technical University's ROTC facility	Apr. 2003	Apr. 2004	Natural gas		US Department of Defense Residential PEM Fuel Cell Demonstration Program FY 2002. Operated in both a grid parallel and grid independent configuration. Provided stand-by power to a critical circuit panel and was outfitted with a thermal recovery system to capture waste heat for a hot water storage tank to supplement the current hot water system.
Plug Power, Inc.	US Army Corps of Engineers Construction Engineering Research Lab (CERL), DTE Energy Technologies	Two 5 kW GenSysT5CS PEM units	Selfridge Air National Guard Base, Michigan	Selfridge Air National Guard Base fire station	Nov. 2003	Demonstration completed	Natural gas		US Department of Defense Residential PEM Fuel Cell Demonstration Program FY 2002. Provided electricity and recovered waste heat for domestic hot water usage. The units operated in parallel with the base electrical grid and incorporate standby capability to allow the units to supply power to critical loads during grid outage.
Plug Power, Inc.	US Army Corps of Engineers Construction Engineering Research Lab (CERL), LOGAN Energy	5 kW GenSys5CS PEM	Sumpter, South Carolina	Shaw Air Force Base residence	May 2003	May 2004	Natural gas		US Department of Defense Residential PEM Fuel Cell Demonstration Program FY 2002. Provided power in a grid parallel /grid independent stand-by power to a 100amp critical circuit panel that serves plug loads in the kitchen area of the home. The system also contained a thermal recovery loop that supplemented the residence's hot water heater.
Plug Power, Inc.	US Army Corps of Engineers Construction Engineering Research Lab (CERL), Southwest Research Institute	Three GenSys5CS 5 kW PEM units	San Antonio, Texas	Brooks Air Force Base housing	Feb. 2003	Mar. 2004	Natural gas		US Department of Defense PEM Demonstration Program FY 2001.
Plug Power, Inc.	Verizon, NY State Energy Research and Development Authority (NYSEDA)	5 kW PEM GenCore	Albany, New York	Albany Airport	Jul. 2003	Demonstration completed in 2004 with subsequent purchase of the system	Natural gas	 	Prototype GenCore demonstration began in Jul. 2003, replaced by the GenCore 5T in Feb. 2004. At completion of the project, Verizon purchased several GenCore 5T systems, siting one at Albany Airport.
Plug Power, Inc.	Honda R&D Co., Ltd.	PEM Home Energy Station with reformer	Torrance, California and Latham, New York	Honda R&D facility in California and Plug Power facility in New York	Oct. 2003	Ongoing	Natural gas	 	Generates hydrogen from natural gas for use in fuel cell vehicles while supplying electricity and hot water to the home. 2003 Phase I demonstration in Torrance, CA; 2004 Phase II demonstration in Latham, NY



Plug Power, Inc.	Long Island Power Authority (LIPA), State University of New York (SUNY)	Three 5 kW GenSys™ 5C PEM CHP units	Farmingdale, New York	SUNY Farmingdale	2003	Operating	Natural gas		
Plug Power, Inc.	Long Island Power Authority (LIPA)	5 kW GenSys 5C PEM CHP	Hempstead, New York	Wantagh Animal Shelter	Oct. 2003	Operating	Natural gas		
Plug Power, Inc.	Long Island Power Authority (LIPA)	Two 5 kW GenSys 5C PEM CHP units	Southampton, New York	Southampton College	2003	Operating	Natural gas		
Plug Power, Inc.	Bonneville Power Administration (BPA), Northwest Natural Inc.	5 kW GenSys PEM CHP	Hillsboro, Oregon	Harkins House Juvenile Detention Facility	Nov. 2003	Operational	Natural gas		Produces electricity, water and usable heat. Can generate 40,000 kw-hrs/yr, about 20% of the needs of the 14,000 sq. ft. facility. Surplus energy will be fed into the PGE power grid. Mira Vowles 503.230.4796 mkvowles@bpa.gov
Plug Power, Inc.	US Army Corps of Engineers Construction Engineering Research Lab (CERL), LOGANEnergy, Energy Signature Associates	GenSys 5CS 5kW PEM	New Orleans, Louisiana	Coast Guard Station Administration and Operations building	Nov. 2003	Completed one-year demonstration	Natural gas		US Department of Defense PEM Demonstration Program FY 2001. Provided stand-by power to a dedicated load of the facility's freezers. Waste heat was captured to be a preheat source for the existing natural gas-fired hot water heaters.
Plug Power, Inc.	US Army Corps of Engineers Construction Engineering Research Lab (CERL)	Three 5 kW GenSys 5CS PEM units	West Point, New York	West Point Military Academy officer's quarters	May 2003	May 2004 (2 units), July 2004 (one unit)	Natural gas		Department of Defense Residential PEM Fuel Cell Demonstration Program FY 2002. Provided electricity to the facilities. Waste heat supplemented the existing domestic hot water and space heating systems. Provided power during the 2003 Northeast US grid power outage.
Plug Power, Inc.	US Army Corps of Engineers Construction Engineering Research Lab (CERL), LOGANEnergy Corp.	5 kW PEM	Bossier City, Louisiana	Barksdale Air Force Base airmen's dormitory	Feb. 2003	Feb. 2004	Natural gas		One year demonstration. US Department of Defense PEM Demonstration Program FY 2001.
Plug Power, Inc.	US Army Corps of Engineers, Construction Engineering Research Lab (CERL), LOGANEnergy	5 kW PEM	Columbia, South Carolina	Fort Jackson officer's residence	Mar. 2003	Mar. 2004	Natural gas		US Department of Defense PEM Demonstration Program FY 2001
Plug Power, Inc.	US Army Corps of Engineers, Construction Engineering Research Lab (CERL), LOGANEnergy	5kW GenSys 5CS PEM	Atlanta, Georgia	Fort McPherson single-family residence	Oct. 2003	2004	Natural gas		US Department of Defense PEM Demonstration Program FY 2001. Provided stand-by power to a dedicated load. The waste heat of the fuel cell is captured and acts as a preheat source for the existing hot water heaters.
Plug Power, Inc.	Vaillant GMBH, Gaz de France	4.6 kW EURO 1 (GenSys) PEM	La Plaine Saint-Denis, France	Gaz de France test research center experimental building	Oct. 2003	Ongoing	Natural gas		Produces electricity used for building needs and provides heating and hot water accumulated in balloons for 7 experimental residences. Has operated over 3,146 hours.
Plug Power, Inc.	Vaillant, MVV Energie	4.1 kW EURO I PEM Fuel Cell	Mannheim, Germany	MVV headquarters	Early 2003		Natural gas		









		Heating Appliance CHP		factory.					
Plug Power, Inc.	Long Island Power Authority/Central 03	Forty-five 5 kW GenSys 5CS PEM units	Long Island, New York	Twenty-five units to West Babylon Fuel Cell Test Site, twenty units to single- or multi-family residences on Long Island	Announced 2003				Buy Down Recipient FY2000 US DoD Climate Change Fuel Cell Program (\$225,000).
Plug Power, Inc.	Vaillant, Ruhrgas, EAM EnergiePlus, E.ON Energie	Two 4.1 kW EURO 1 (GenSys) PEM Fuel Cell Heating Appliance CHP units	Baunatal, Germany	Two semi-detached apartment buildings	Installed Winter 2002/2003	Scheduled completion in Mar.2005	Natural gas		Part of European Commission-funded project "European Virtual Fuel Cell Power Plant" to examine centrally controlled fuel cell heating systems connected to the electricity grid
Plug Power, Inc.	Vaillant, EWE, E.ON Energie	4.1 kW EURO 1 (GenSys) PEM Fuel Cell Heating Appliance CHP	Oldenburg, Germany	Apartment building	Installed Winter 2002/2003	Scheduled completion in Mar.2005	Natural gas		Part of European Commission-funded project "European Virtual Fuel Cell Power Plant" to examine centrally controlled fuel cell heating systems connected to the electricity grid
Plug Power, Inc.	Vaillant, EWE, E.ON Energie	4.1 kW EURO 1 (GenSys) PEM Fuel Cell Heating Appliance CHP	Brake, Germany	Apartment building	Installed Winter 2002/2003	Scheduled completion in Mar.2005	Natural gas		Part of European Commission-funded project "European Virtual Fuel Cell Power Plant" to examine centrally controlled fuel cell heating systems connected to the electricity grid
Plug Power, Inc.	Vaillant, Gasunie	4.1 kW EURO 1 (GenSys) PEM Fuel Cell Heating Appliance CHP	Groningen, Netherlands	Workshop	Installed Winter 2002/2003	Scheduled completion in Mar.2005	Natural gas		Part of European Commission-funded project "European Virtual Fuel Cell Power Plant" to examine centrally controlled fuel cell heating systems connected to the electricity grid
Plug Power, Inc.	Vaillant, Ruhrgas, Stadwerke Remscheid, EWR, E.ON Energie	Two 4.1 kW EURO 1 (GenSys) PEM Fuel Cell Heating Appliance CHP units	Remscheid, Germany	Apartment building	Installed Winter 2002/2003	Scheduled completion in Mar.2005	Natural gas		Part of European Commission-funded project "European Virtual Fuel Cell Power Plant" to examine centrally controlled fuel cell heating systems connected to the electricity grid
Plug Power, Inc.	Vaillant GmbH	Fifty PEM units	Various locations in Germany, Netherlands, Austria, Luxembourg	Apartments and small businesses	2002/2003	Scheduled completion in Mar. 2005	Natural gas		Plug Power launched the European Union Fuel Cell Virtual Power Plant project with academic and industrial partners in Europe. Preproduction is planned in 2007, to be marketed by the end of the decade. A number of these installations are listed separately in this chart.
Plug Power, Inc.	Fuel Cell Test and Evaluation Center (FCTec)	5 kW PEM	Johnstown, Pennsylvania	FCTec test facility	Sale announced Sept. 2002		Natural gas		Combined heat and power unit purchased to develop a test protocol for residential fuel cells.
Plug Power, Inc.	Miller Burton Homes, Built Green Colorado, City and County of Denver, Governor's OEMC, IREA, Xcel Energy	5 kW PEM CHP	Denver, Colorado	Miller Burton Homes' Roaring Fork Parade Home	Aug. 2002	Oct. 2002	Natural gas		After the Parade of Homes, this unit will be stationed at the City and County of Denver's fire station at Washington Park.




Plug Power, Inc.	Governor's Office of Energy Management and Conservation, Xcel Energy, City and County of Denver, Alpha Technologies	5 kW PEM CHP	Denver, Colorado	Washington Park Fire Station	Dec. 2002	One-year demonstration	Natural gas		Provides a portion of the facilities' electricity and heat, to operate the fire station's computers, lights and garage doors. After the demonstration, Plug Power will replace the fire station's fuel cell with a future production model.
Plug Power, Inc.	Long Island Power Authority (LIPA), Hofstra University	Three 5 kW GenSys 5C PEM CHP units	Hempstead, New York	Hofstra University, dormitory	2002	Operating	Natural Gas		Providing power to the dormitory.
Plug Power, Inc.	Long Island Power Authority (LIPA)	5 kW GenSys 5C PEM CHP	Babylon, New York	Town Hall	Jul. 2002	Ongoing			Produces 5 kW of electricity.
Plug Power, Inc.	US Army Corps of Engineers Construction Engineering Research Lab (CERL), Watervliet Arsenal	Ten 5 kW PEM fuel cell units	Watervliet, New York	Watervliet Arsenal's R&D test lab (three units), telecommunications room (three units) and officer's quarters (four units)	Jan. 2002	Completed Jan. 2003	Natural gas		Department of Defense PEM Residential Fuel Cell Demonstration Program FY 2001. Provided supplemental power to telecommunications facility and laboratory. Provided all power for four units of base housing. Operated for more than 80,000 hours and generated about 210,000 kWh of electricity.
Plug Power, Inc.	New York State Energy Research and Development Authority (NYSERDA), US Department of Energy	Two 5 kW SU-1 PEM units	Lewiston, and Colden, New York	Two single family homes	Apr. 2002	One-year demonstration	Natural gas		
Plug Power, Inc.	Long Island Power Authority (LIPA), US Army Corps of Engineers Construction Engineering Research Lab (CERL),	Three 5 kW GenSys 5C PEM units	Kings Point, New York	US Merchant Marine Academy	Planned installation Fall 2002		Hydrogen		The new system marks Plug Power's first shipment into the backup/UPS markets..
Plug Power, Inc.	US Army Corps of Engineers Construction Engineering Research Lab (CERL)	Eight 5 kW GenSys 5C CHP PEM units	San Diego, California	Naval Air Station North Island enlisted quarters, gymnasium and laundry	Sep. 2002	Ongoing	Natural gas		Will provide electricity and heat for hot water.
Plug Power, Inc.	US Army Corps of Engineers Construction Engineering Research Lab (CERL)	5 kW GenSys 5C CHP PEM	China Lake, California	Naval Air Weapons Station indoor pool	Sep. 2002		Natural gas		Provided electricity and heat to the indoor pool.
Plug Power, Inc.	Long Island Power Authority (LIPA), Hunt Enterprises/McDonalds	5 kW GenSys 5C PEM CHP	Deer Park, New York	McDonalds	2002	2003	Natural gas		
Plug Power, Inc.	DTE Energy Technologies, Detroit Edison	Two 5 kW PEM units	Commerce Township, Michigan	Detroit Edison's Hancock Station	Jun. 2002	2003	Natural gas		Provides heat and electricity to the Center.
Plug Power, Inc.	Flint Energies and GE Fuel Cell Systems	5 kW PEM	Warner Robins, Georgia	Flint Energies Service Center facility	Jul. 2002	Ongoing	Natural gas		Generates electricity and heat. The heat will be used in water heaters in Flint's service center.
Plug Power, Inc.	US Army Corps of Engineers, Construction Engineering Research Lab (CERL), LOGANEnergy	5 kW PEM	Fort Bragg, North Carolina	Fort Bragg Environmental Center	Nov. 2002	Feb. 2004	Natural gas		US Department of Defense PEM Demonstration Program FY 2001
Plug Power, Inc.	Osaka Gas Co.	500 W PEM	Osaka, Japan	NEXT21 experimental	Apr. 2002				Will provide power and heat.



				condominium					
Plug Power, Inc.	Japan Gas Association	4.5 kW PEM	Japan		2002				Japan Gas Assoc. Phase 2 test of residential PEM fuel cells of different manufacturers.
Plug Power, Inc.	Japan Gas Association	3 kW hybrid PEM/battery	Japan		2002				Japan Gas Assoc. Phase 2 test of residential PEM fuel cells of different manufacturers.
Plug Power, Inc.	Japan Gas Association	1 kW PEM	Demonstration tests (7 companies) held in Tokyo, Osaka and Nagoya, Japan		Phase 1: Dec. 2001	Phase I completed Feb. 2002			Japan Gas Assoc. test of residential PEM fuel cells from seven manufacturers (Ballard, Matsushita Electric, Toshiba, Toyota, Sanyo Electric, Mitsubishi Electric, Plug Power). Completed 1,000 hours of operation in Phase I testing, 8,000 hours scheduled in Phase 2 using fuel cells of different manufacturers.
Plug Power, Inc.	Gaz de France	Six 4.5 kW PEM beta CHP units	La Plaine Saint-Denise, France	Gaz de France	Dec. 2001 - Feb. 2002		Natural gas		
Plug Power, Inc.	Vaillant, E.ON, ELE, EUS, Ruhrgas	4 kW PEM Fuel Cell Heating Appliance (FCHA)	Gelsenkirchen, Germany	Multiple family home	Dec. 2001	Scheduled test completion at end of 2002	Natural gas		Supplies seven families with electricity, room heat, and hot water. Provides 80% of the home's electricity and nearly all of the hot water and room heating requirements. Supported by the North Rhine-Westphalia (NRW) Ministry of Economic Affairs as part of "Rational Energy Use" program
Plug Power, Inc.	Vaillant, Stadtwerke Duesseldorf, Ruhrgas AG, E.ON, ELE, EUS, German Gas Association, German Technical Surveillance Organization	4.1 kW GenSys PEM Fuel Cell Heating Appliance (FCHA)	Dusseldorf, Germany	Im Füchsen micro-brewery	Late 2001		Natural gas		Supplies about 80% of the electricity and heat to the traditional brewery, plus hot water for the brewing process, cleaning and dishwashing. Excess power is fed to the power network of the adjacent building complex. Supported by the North Rhine-Westphalia (NRW) Ministry of Economic Affairs as part of "Rational Energy Use" program
Plug Power, Inc.	German Gas Association, German Technical Surveillance Organization, Ruhrgas, Vaillant	PEM Fuel Cell Heating Appliance (FCHA)	Essen, Germany	Multiple family home	2001				Supported by the North Rhine-Westphalia (NRW) Ministry of Economic Affairs as part of "Rational Energy Use" program.
Plug Power, Inc.	Long Island Power Authority (LIPA), DOE, NY State Energy Research and Development Authority (NYSERDA)	75 PEM systems	West Babylon, New York	Long Island Fuel Cell Farm R&D at LIPA substation	2001				Forty-five of the original seventy-five units were in use as of 2003. The electricity is distributed to customers through LIPA's electric transmission and distribution system. Expected to produce more than 1 million kWh of electricity during the two-year project. Part of Gov. Pataki's Clean Energy Initiative.
Plug Power, Inc.		Fifty 5 kW SU-1 PEM units	Various residential locations, New York		Installed in 2001		Natural gas		Part of Gov. Pataki's Clean Energy Initiative.
Plug Power, Inc.	Long Island Power Authority	Six alpha 5 kW PEM CHP units	Four Long Island locations,	Homes	2000		Natural gas		





	(LIPA), DOE, NY State Energy Research and Development Authority (NYSERDA), Elemco Testing Company		New York						
Plug Power, Inc.	Long Island Power Authority (LIPA), DOE, NY State Energy Research and Development Authority (NYSERDA)	Twelve 5 kW PEM units	New York	Various New York public facilities	2000				
Plug Power, Inc.	Long Island Power Authority (LIPA), US Department of Energy, NY State Energy Research and Development Authority (NYSERDA)	Three 5 kW PEM units	Brookhaven, New York	DOE's Brookhaven National Lab	Mar. 2000				
Plug Power, Inc.	Hofstra University	Six PEM units	Hempstead, New York	Hofstra University	2000	Completed			These were among the first systems demonstrated outside of Plug Power's laboratory.
Plug Power, Inc.		PEM	Latham, New York	Plug Power's Demonstration Home	Jun. 1998		Hydrogen , natural gas		Four month demonstration using hydrogen fuel, followed by demonstration using natural gas.
Plug Power, Inc.	Long Island Power Authority/Central 02	Thirty-seven 5 kW PEM units	New York						Buy Down Recipient FY2000 US DoD Climate Change Fuel Cell Program (\$185,000).
Plug Power, Inc.	Idaho State University	7 kW PEM	Idaho						Buy Down Recipient FY1999 US DoD Climate Change Fuel Cell Program (\$7,000).
Plug Power, Inc.	NJR Power Services Group, GE	Twenty7 kW 7000 PEM units							Buy Down Recipient FY1999 US DoD Climate Change Fuel Cell Program (\$140,000).
Plug Power, Inc.	New York State Energy Research and Development Authority	Eighty 7 kW Plug Power 7000 PEM units	New York City metropolitan area, New York	New York State-owned facilities			Natural gas		24 units tested in Phase I. 6 units in Phase II, 50 units in Phase III.
Plug Power, Inc.	Town of East Hampton	PEM	East Hampton, New York	Town Hall					
Plug Power, Inc.	Vaillant	PEM	Delitzsch, Germany	Apartment building			Natural gas		
Plug Power, Inc.	Vaillant, Weingass	4.1 kW PEM Fuel Cell Heating Appliance (FCHA)	Vienna, Austria	Workshop			Natural gas		
Plug Power, Inc.	Vaillant, Stadtwerke Bielefeld	4.1 kW PEM Fuel Cell Heating Appliance (FCHA)	Bielefeld, Germany	Multi-family house			Natural gas		
Plug Power, Inc.	HEW	4.1 kW PEM Fuel Cell Heating Appliance (FCHA)	Hamburg, Germany	Workshop					
Plug Power, Inc.	Vaillant, Steirische Ferngas Austria, University of Graz, ESTAG	4.1 kW PEM Fuel Cell Heating Appliance (FCHA)	St. Ruppert, Austria	Hotel Ochensberger	Jan. 2003	May 2004	Natural gas		
Plug Power, Inc.	Vaillant, SOTEG Luxembourg	4.1 kW PEM Fuel Cell Heating	Luxembourg	School			Natural gas		







		Appliance (FCHA)						
Plug Power, Inc.	Vaillant, Weingas	Euro I PEM CHP	Wein, Austria	Residential	Feb. 2002	Dec. 2004	Natural gas	
Proton Energy Systems	Public Utilities Commission	15 kW regenerative fuel cell	Wallingford, Connecticut	Public Utilities Commission's Thorpe Avenue electric substation	Agreement announced May 2005	One-month demonstration		Will provide back-up power to a sub-station located next to Proton Energy Systems' office. \$500,000 is being provided by the Connecticut Clean Energy Fund.
ReliOn	US Department of Defense, Spokane Sector Department of Homeland Defense	Five 1 kW PEM units	Spokane, Washington	Radio repeater stations	Planned		Hydrogen	US Department of Defense Residential PEM Fuel Cell Demonstration Program FY 2004.
ReliOn	US Army Corps of Engineers, Construction Engineering Research Lab (CERL)	Four 1 kW Independence 1000 PEM units	Fort Rucker, Alabama	Fort Rucker Localizer and Glide Slope buildings (1 unit each), middle beacon (1 unit) and outer marker beacon (2 units)	Planned		Industrial grade hydrogen gas	US Department of Defense Residential PEM Fuel Cell Demonstration Program FY 2003. Provides air traffic control back up power. The Localizer and Glide Slope are located on Cairns Army Air Field just outside of Ft. Rucker. The Middle Marker is located just outside of Cairns Army Air Field and the Outer Marker is located approximately 10 miles from Cairns Army Air Field near a peanut farm. Each site will utilize one fuel cell.
ReliOn	US Army Corps of Engineers, Construction Engineering Research Lab (CERL)	4 kW Independence 1000 PEM units	Westhampton, New York	Gabreski Air National Guard, base telephone exchange	Dec. 2004	Operational	Hydrogen	 US Department of Defense Residential PEM Fuel Cell Demonstration Program FY 2003. The fuel cells are connected to the 48 V battery string on a new uninterruptible power supply (UPS) system installed for this project.
ReliOn	US Army Corps of Engineers, Construction Engineering Research Lab (CERL)	Four 1 kW Independence 1000 PEM units	Tacoma, Washington	Fort Lewis Localizer and Glide Slope buildings, middle and outer marker beacons (1 unit each)	Jul. 2004	Operational	Industrial grade hydrogen	US Department of Defense Residential PEM Fuel Cell Demonstration Program FY 2003. Provides air traffic control back up power.
ReliOn	US Army Corps of Engineers, Construction Engineering Research Lab (CERL), Industrial Research Ltd.	Two 1 kW Independence 1000 PEM units	Christchurch, New Zealand	US Antarctic Division Scientific Foundation Building	Apr. 2005	One-year trial	Methanol	 US Department of Defense Residential PEM Fuel Cell Demonstration Program BY 2003. Supplies security lighting at night and automatically switched off during daylight hours. During the day power output will be continually available for charging and other demonstration field instrumentation loads.
ReliOn	havePOWER, State of Washington	Independence 1000 PEM	Washington	Washington State Highway Patrol Emergency 911 system	Installed	Operational		
ReliOn	havePOWER, State of Washington	Independence 1000 PEM	Washington	Washington State Department of Transportation Emergency-911 system	Installed	Operational		




ReliOn	Bonneville Power Administration, havePOWER	Independence 1000 PEM	Vancouver, Washington	Bonneville Power Administration's Ross Substation	April 2004	Operational			
ReliOn	HavePOWER, Multi-Agency Radio Communications System (MARCS)	Four Independence 1000 PEM units	Washington Township, Ohio	MARCS microwave radio towers	Oct. 2004	Operational			Deployed at the MARCS installations--instead of lead acid based battery banks and engine generators--to provide long-term, emergency back-up power to critical digital communication infrastructure.
ReliOn	Bonneville Power Administration, Northwest Energy Technology Collaborative, Central Washington University	1 kW Independence 1000 PEM	Ellensburg, Washington	Central Washington University	Mar. 2004	Operational			A television and video player are powered by the fuel cell.
ReliOn	Maryland Department of Transportation, havePOWER	Independence 1000 PEM	Hancock, Maryland	Fiber optic repeater station	Feb. 2004	Operational	Hydrogen		World's first back-up for fiber optic repeater station.
ReliOn	Bahamas Telecommunications, Inc.	Independence 1000 PEM	Nassau, Bahamas	Back up telecommunications site	Aug. 2004	Operational			Successfully provided back up power during a Category 4 hurricane.
ReliOn	US Federal Aviation Administration	Independence 1000 PEM	Swin's Valley, Wisconsin	Radio communication-link repeaters	Jun. 2004	Operational			
ReliOn	US Federal Aviation Administration	Independence 1000 PEM	Wakeman, Ohio	Radio communication-link repeaters	Jun. 2004	Operational			
ReliOn	US Federal Aviation Administration	Independence 1000 PEM	Fargo, North Dakota	Radio communication-air to ground	Sep. 2004	Operational			
ReliOn	US Federal Aviation Administration	Independence 1000 PEM	Medical Lake, Washington	Radio communication-link repeaters		Operational			
ReliOn	Avista Labs/ReliOn	Two Independence 1000 PEM		Two Avista Corp/ReliOn substations	Sep. 2003 and Apr. 2004	Operational			Provides backup to substation protection and control equipment at two sites.
ReliOn	US Federal Aviation Administration	Independence 1000 PEM	Palwaukee, Illinois	Radio transmitter-repeaters	Dec. 2003	Operational			
ReliOn	US Bureau of Reclamation	Independence 1000 PEM	Loveland, Colorado	Bureau of Reclamation Pole Hill plant	Oct. 2003	Operational			Provides backup power to plant communication systems
ReliOn	havePOWER, State of Maryland	Independence 1000 PEM	Elk Neck State Park, Maryland	Emergency 911 (MIEMSS) system remote telecommunications site	Aug. 2003	Operational			Provides back-up power to a microwave radio site. Activated during Hurricane Isabel and provided continuous power until grid service was restored. Maryland has approved the fuel cell for primary back up power at other MIEMSS locations and the state's fiber optic network.
ReliOn (under former name-Avista Labs)	Army Corp of Engineers Construction Engineering	Six 500 W Independence 500 units (3 kW total power)	Tacoma, Washington	FAA radio transmitter-repeaters at McChord Air	Apr. 2003	Apr. 2004	Hydrogen		DOD Residential Fuel Cell Demonstration Program FY 2002. Provided critical backup power for a radio

	Research Laboratory (CERL)			Force Base					transmitter receiver (RTR) site. No cogeneration.
ReliOn (under former name-Avista Labs)	Flash Technology, havePOWER	EPAC PEM	Outside Wilkes Barre, Pennsylvania	Cellular communication tower	Feb. 2002	Ongoing			World's first cellular communication's tower powered by hydrogen fuel cells. Powers Flash Technology beacon on cell phone tower and cell phone radio.
ReliOn (under former name-Avista Labs)	US Department of Defense, LOGANEnergy	5 kW PEM	Kaneohe Bay, Hawaii	Marine Corp Base housing	Dec. 2002		Propane		No cogeneration
ReliOn (under former name-Avista Labs)	U.S. Army Corps of Engineers' Construction Engineering Research Laboratory (CERL)	3 kW SR-72 PEM	Spokane, Washington	Washington Air National Guard maintenance facility at Geiger Field	Mar. 2002	Mar. 2003	Industrial grade bottled hydrogen		DOD Residential Fuel Cell Demonstration Program FY 2001.
ReliOn (under former name-Avista Labs)	U.S. Army Corps of Engineers' Construction Engineering Research Laboratory (CERL)	5 kW PEM	Fayetteville, North Carolina	Fort Bragg base housing	Nov. 2002		Natural gas		DOD Residential Fuel Cell Demonstration Program
ReliOn (under former name-Avista Labs)	SGS Future srl	Ten Independence 1000 PEM units	Cavalese, Italy	Mountaintop alpine lodge	End of 2002				Installed in a parallel configuration providing 10kW of power.
ReliOn (under former name-Avista Labs)	Fuel Cell Test and Evaluation Center (FCTec)	SR 12 PEM	Johnstown, Pennsylvania	FCTec facility					Underwent testing and evaluation.
Sanyo Electric Co.	Urban Renaissance Agency (URA)	Forty-three 750 W PEM units	Osaka and Musashino, Japan	URA's rental condominiums	Mar. 2005		Town gas		PEMs are installed in 26 out of 252 homes in Osaka and 17 out of 85 homes in Musashino. Provides 74% of electric demand and 92% of hot water demand. There is no additional charge for the fuel cell-equipped homes.
Sanyo Electric Co.	Sumitomo Corporation, Nippon Steel Corporation	5 kW SOFC	Japan	Yahata Steel Works	Jun. 2004				Performance and demonstration test of unit designed by Sumitomo, Nippon Steel and Sanyo.
Sanyo Electric Co.	Daiwa House Industry Co., Ltd, Ministry of Land, Infrastructure and Transport	1 kW PEM	Nara prefecture, Japan		2004				Field test.
Sanyo Electric Co.	Osaka Gas Co.	1 kW PEM	Kyoto, Japan	Residential	Apr. 2002				
Sanyo Electric Co.	Coalition of the Kinki Bureau of Economy, Trade and Industry and 80 companies	Three 100 kW PEM units	Nishinomiya, Japan	Fire station	Apr. 2002				Will provide emergency power backup for lighting and rescue activity and emergency medical activity such as power for artificial respiration. The project was proposed after the Hanshin-Awaji Earthquake disaster.
Sanyo Electric Co.	Japan Gas Association	1 kW PEM	Demonstration tests (7 companies) held in Tokyo, Osaka and Nagoya, Japan		Phase 1: Dec. 2001	Phase I completed Feb. 2002			Japan Gas Assoc. test of residential PEM fuel cells from seven manufacturers (Ballard, Matsushita Electric, Toshiba, Toyota, Sanyo Electric, Mitsubishi Electric, Plug Power). Completed 1,000 hours of


									operation in Phase I testing, 8,000 hours scheduled in Phase 2 using fuel cells of different manufacturers.
Schatz Energy Research Center		100 W PEM	Redwood National Forest, California	Schoolhouse Peak	1999, refurbished 2001	2003	Hydrogen		Part of Yurok Indian telecommunications system providing cell phone service to a remote portion of the reservation. Links to Pacific Bell's telephone network. Logged 3,239 operating hours on the first stack, 3,836 hours on second stack.
Siemens Power Generation, Inc	Gas Turbine Technologies, SpA (GTT)	100 kW SOFC CHP	Turin, Italy	GTT facility	Successfully re-started Aug. 2005				Provides power and will provide heat and cooling to the building beginning Fall 2005. Grid connected. The fuel cell had previously operated for more than 20,000 hours in Germany and the Netherlands.
Siemens Power Generation, Inc	BP Alaska	125 kW SOFC	Alaska		Planned in 2006		Pipeline natural gas (PNG)		
Siemens Power Generation, Inc	Stadtwerke Hanover AG, E.ON Energie AG	250 kW SOFC	Hannover, Germany	Herrenhausen power plant	Planned installation in 2004		Pipeline natural gas (PNG)		In normal operating mode will simultaneously feed 225 kW of electricity into the grid operated by Stadtwerke Hanover and 160 kW of heat for Hanover's district heating network
Siemens Power Generation, Inc	Edison SpA	300 kW SOFC/gas turbine Pressurized Hybrid (PH) system	Sinetta Marengo, Italy	Edison thermo-electric power station	Early 2003	One-year demonstration	Natural gas		Electrical efficiency of 58%.
Siemens Power Generation, Inc	BP America	250 kW SOFC CHP	Nikiski, Alaska	BP gas-to-liquids plant, administration building and warehouse	2003		Natural gas		Excess power to be sold to local grid. Buy Down Recipient FY2000 US DoD Climate Change Fuel Cell Program. (\$250,000) One of two fuel cells installed at BP.
Siemens Power Generation, Inc	Ontario Power Generation, US Department of Energy and National Resources Canada, Kinectrics Inc.	250 kW SOFC CHP	Toronto, Canada	Kinectrics (formerly Ontario Hydro) test facility	2003	Ongoing			Proof-of-concept. By 2004 the system has operated for more than 1,100 hours. Buy Down Recipient FY1999 US DoD Climate Change Fuel Cell Program.
Siemens Power Generation, Inc	University of Toronto, Kinectrics, Ontario Power Generation	250 kW SOFC	Mississauga, Canada	University of Toronto-Mississauga	2003				Will be connected to the internal grid and is expected to provide 8% of the electrical needs for the campus as well as hot water.
Siemens Power Generation, Inc	Norske Shell	250 kW SOFC hybrid	Bergen, Norway	Kollsnes gas processing plant	2003		Natural gas		Demonstration of capture of fuel cell exhaust carbon dioxide gas for sequestration or for use in other industries.
Siemens Power Generation, Inc	RWE	300 kW SOFC/gas turbine Pressurized Hybrid (PH) CHP system	Essen, Germany	RWE Fuel Cell Pavilion, Meteorit Park	Apr. 2002	One-year demonstration	Natural gas		Provided power and heat to the RWE Meteorit Exposition Pavilion. Electrical efficiency of 58%.
Siemens Power Generation, Inc	Ontario Power Technologies	250 kW SOFC/gas turbine hybrid system	Toronto, Canada	Ontario Power Technologies facilities	2002	Completed	Pipeline natural gas (PNG)		Operated 1,000+ hours. Was to deliver 225 kW to the existing power grid and supply 145 kW of heat. FY 1999 US DoD Climate Change Fuel Cell








									Program. (\$200,000)
Siemens Power Generation, Inc	EnBW, TIWAG, Gax de France	1 MW SOFC with micro-turbine generator	Austria		Jan. 2000	Dec. 2003			
Siemens Power Generation, Inc	University of California, Edison Technology Solutions/Southern California Edison	220 kW SOFC/gas turbine hybrid system	Irvine, California	National Fuel Cell Research Center at the University of California-Irvine	Jun. 2000	Completed 2001	Natural gas		Proof-of-concept Operated for nearly 3,400 hours and achieved an electrical efficiency of ~53%
Siemens Power Generation, Inc	Southern California Edison, National Fuel Cell Research Center, Tokyo Gas, Osaka Gas	25 kW SOFC	Irvine, California	Highgrove Generation Station, (Southern California Edison), later relocated to the National Fuel Cell Research Center	1994	Will operate up to 20,000 hours. May be retired to the Smithsonian as the "world's first integrated solid oxide fuel cell system"	Jet fuel, diesel fuel, natural gas		Installed in 1994 at the Highgrove Generating Station of Southern California Edison. Operated approximately 6,500 hours on first stack before being replaced in 1995 with a new stack. Was shut down in 1996 after 11,500 hours of testing (5,000 hours on the new stack). Relocated to NRCRC and restarted in 1998. By 2002, the system has operated for a total of 19,750 hours (13,250 hours on the current stack).
Siemens Power Generation, Inc	EDB/Elsam, Nuon	100 kW SOFC CHP	Westervoort, Netherlands; Essen, Germany	EDB/Elsam power plant; RWE Fuel Cell Pavilion, Meteorit Park	Dec. 1997	Completed	Natural gas, pipeline natural gas (PNG)		Operated for 16,667 hours at a peak power of ~140 kW. Electrical efficiency was 46%. In June 2001 was moved to RWE Fuel Cell Pavilion and tested for an additional 3,700 hours, for a total of over 20,000 hours.
Siemens Power Generation, Inc	Joint Gas Utilities	25 kW SOFC/as turbine hybrid system	Japan		1995	Completed	Pipeline natural gas (PNG)		Logged 13,294 hours of operation.
Siemens Power Generation, Inc	Unidentified utility company	20 kW SOFC/gas turbine hybrid system			1993	Completed	Pipeline natural gas (PNG)		Logged 7,064 hours of operation.
Siemens Power Generation, Inc	Unidentified utility company	20 kW SOFC/gas turbine hybrid system			1992	Completed	Pipeline natural gas (PNG)		Logged 2,601 hours of operation.
Siemens Power Generation, Inc	Unidentified utility company	20 kW SOFC/gas turbine hybrid system			1992	Completed	Pipeline natural gas (PNG)		Logged 1,579 hours of operation.
Siemens Power Generation, Inc	Joint Gas Utilities	20 kW SOFC/gas turbine hybrid system	Japan		1992	Completed	Pipeline natural gas (PNG)		Logged 817 hours of operation.
Siemens Power Generation, Inc	Osaka Gas	Two 3 kW SOFC/gas turbine hybrid systems	Japan		1987	Completed	H2+CO		Logged 3,012 and 3,683 hours of operation.
Siemens Power Generation, Inc	Tokyo Gas	3 kW SOFC/gas turbine hybrid system	Japan		1987	Completed	H2+CO		Logged 4,882 hours of operation.
Siemens Power Generation, Inc	Tennessee Valley Authority	400 W SOFC/gas turbine hybrid power system			1986	Completed	H2+CO		Logged 1,760 hours of operation.
Smart Fuel Cell AG (SFC)		Multiple 120 W SFC A50 DMFC fuel cells	Brandenburg, Germany	Fire watch towers in Brandenburg	Jun. 2005		Methanol		Forest fire-watch cameras are operated by a photovoltaic system, with fuel cell back up power.
Sulzer Hexis	HEAG	SOFC	Darmstadt, Germany	Residence	Mar. 2005		Natural gas		Provides electricity and heat.




Sulzer Hexis	VNG, DREWAG	1 kW HXS 1000 Premiere SOFC CHP	Dresden, Germany	Kindergarten	Jan. 2004		Natural gas		Part of the VNG DemoCell project.
Sulzer Hexis	Axpo Holding AG	Pre-series HXS 1000 Premiere SOFC CHP system	Zurich, Switzerland	Single-family test house	Oct. 2003	Two-year testing project	Natural gas		
Sulzer Hexis	Gasverbund Mittelland AG	Thirty SOFC units	Northwestern Switzerland	Customer-residential	2003		Natural gas		Swiss natural gas supplier. Units delivered to interested customers. Very high demand for the 30 pre-production units.
Sulzer Hexis	Gaz de France	HXS 1000 Premiere SOFC	La Plaine Saint-Denis, Paris, France	Test house at Gaz de France research and development facility	Jan. 2003	Completed Dec. 2003	Natural gas		One year testing project.
Sulzer Hexis	VNG, Berliner Gaswerke AG	HXS 1000 Premiere SOFC	Berlin-Buckow, Germany	One side of a two-family house	Aug. 2003	Three year test	Natural gas		Part of the VNG DemoCell project. When the fuel cell can't produce as much heat as necessary, the integrated gas-fired condensing boiler steps in to meet peak needs. Surplus electricity is fed into the network of the local electricity supplier.
Sulzer Hexis	HGW, eon Hanse Gas AG, VNG	1 kW HXS 1000 Premiere SOFC CHP	Gadebusch, Germany	Three-apartments in a multi-family dwelling	Nov. 2002		Natural gas		Part of the VNG DemoCell project.
Sulzer Hexis	VNG, Erdgas Mittelsachsen	1 kW HXS 1000 Premiere SOFC CHP	Barby, Germany	Training center	Jun. 2002		Natural gas		Part of the VNG DemoCell project.
Sulzer Hexis	VNG, Stadtwerke Weimar	1 kW HXS 1000 Premiere SOFC CHP	Weimar, Germany	Training center	Oct. 2002		Natural gas		Part of the VNG DemoCell project.
Sulzer Hexis	VNG	Sixteen 1 kW HXS 1000 Premiere SOFC CHP systems	Various locations, Germany	Customer-sited	Purchased over 2002-2003		Natural gas		East German gas utility. Purchase over the period 2002-2003. Thermal output of 2.5 kW.
Sulzer Hexis	E.ON Energie AG	Fifty-six 1 kW HXS 1000 Premiere SOFC CHP systems	Various locations, Germany	Customer-sited	Purchased over 2002-2003		Natural gas		One of Europe's largest private electricity, gas and water utilities. Purchase over the period 2002-03. Thermal output of 2.5 kW.
Sulzer Hexis	Thyssengas GmbH	Forty-two 1 kW HXS 1000 Premiere SOFC CHP systems	North Rhine-Westphalia area, Germany	Customer-sited	Purchased over 2002-2003		Natural gas		Natural gas importer and supplier. Purchase over the period 2002-03. Thermal output of 2.5 kW.
Sulzer Hexis	RWE	1 kW HXS 1000 Premiere SOFC	Essen, Germany	RWE Fuel Cell Pavilion, Meteorit Park	Apr. 2002	Ongoing	Natural gas		Electrical output of 1 kW and thermal output of 2.5 kW. Designed exclusively for use in single-family homes. The SOFC achieves an electrical efficiency of approximately 25% and an overall efficiency of at least 80%.
Sulzer Hexis	Energie AG Oberösterreich, Oberösterreichischen Ferngas AG	1 kW HXS 1000 Premiere SOFC	Attnang Puchheim, Austria	Technology Center Salzkammergut	Mar. 2002	Mar. 2004	Natural gas		
Sulzer Hexis	Energy Research Centre of the Netherlands (ECN)	1 kW HXS 1000 Premiere SOFC	Petten, Netherlands	ECN test laboratory	Summer 2002	One-year testing and operation	Natural gas		Testing/analysis for usability in Dutch households.
Sulzer Hexis	EnBW	Forty 1 kW HXS 1000 Premiere SOFC CHP systems		Customer-sited	Purchased over 2001-2003, first installation in Dec. 2001		Natural gas		Over 6,000 persons responded to an advertisement placed by EnBW seeking 25 customers to test a fuel






									cell heating system. By 2006, about 55 customers will use this technology. The successor of the SOFC pre-series fuel cell system will be delivered in 2005.
Sulzer Hexis	EWE PLC	One hundred fifty-five 1 kW HXS 1000 Premiere SOFC CHP systems	Various locations, Germany	Customer-sited	Purchased over 2001-2003		Natural gas		Purchase over the period 2001 – 03. Thermal output of 2.5 kW. Unit 001 was tested at EWE's lab. The remainder were to be made available to customers for testing..
Sulzer Hexis	EWR	Sixty 1 kW HXS 1000 Premiere SOFC CHP systems	Various locations, Germany	Customer-sited	Purchased over 2001-2003		Natural gas		Sited with utility customers within the Rheinhessen/Ried. Region. Purchase over the period 2001 – 03. Thermal output of 2.5 kW.
Sulzer Hexis	EREP SA, Universite Lausanne, Herr Chabloz	1 kW SOFC	Lully, Switzerland	Chabloz biogas plant	Aug. 2001		Agricultural biogas		Operated for 5,000 hours at 35% efficiency.
Sulzer Hexis	Tokyo Gas	1 kW SOFC	Tokyo, Japan	Tokyo Gas Fundamental Technology Research Laboratory	Feb. 2000	2001	City gas		
Sulzer Hexis	Gasunie, Shell	1 kW SOFC	Groningen, Netherlands	Gasunie research facility	May 2000				Integrated into heating system.
Sulzer Hexis	Gas de Euskad, Ikerlan Energy, School of Engineers-Bilbao, EVE	1 kW SOFC CHP	Bilbao, Spain	Mirano technology park demonstration house	Installed Oct. 1999	2001	Natural gas		Combined heat and power.
Sulzer Hexis	City of Basel, AUE Basel	1 kW SOFC CHP	Basel, Switzerland	School	Installed Oct. 1998	2001			Produces power for the school. Excess energy sent to the grid. Operated for more than 8,000 hours.
Sulzer Hexis	Deutschland Überregionales Gasversorgungsunternehmen, Thyssengas	1 kW SOFC	Duisburg, Germany		Installed Nov. 1998	2001			
Sulzer Hexis	EWE, Deutschland Regionales Energieversorgungsunternehmen	1 kW SOFC	Oldenburg, Germany	EWE facility	Installed Nov. 1998	Sep. 2001			
Sulzer Hexis	Städtische Werke Winterthur	1 kW SOFC CHP	Winterthur, Switzerland		May 1997	1998	Natural gas		Field trial with Swiss utility company. Was controlled remotely by modem and telephone line. Was initially used to test various fuel cell developments under realistic conditions. Fed into the grid for the first time in Jul. 1998.
Sulzer Hexis	Dortmunder Energie- und Wasserversorgung GmbH	1 kW SOFC CHP	Dortmund, Germany		Sep. 1997	1998	Natural gas		Field trial with Germany utility company. Was remotely-controlled via modem and telephone line..
Sulzer Hexis		1 kW SOFC	Basel, Switzerland	Sulzer Hexis test lab	1997	1998	Hydrogen		Trial stack, operated over 12,000 hours. 35% energy efficiency.
Teledyne Energy Systems Inc. (formerly Energy Partners)	National Aeronautics and Space Administration (NASA)	12 kW PEM	Cleveland, Ohio	NASA's Glenn Research Center	Delivered Aug. 2005				Will undergo vibration and thermal vacuum testing to simulate conditions in space.
Teledyne Energy Systems Inc. (formerly Energy Partners)	National Aeronautics and Space Administration	5 kW PEM	Houston, Texas	NASA's Johnson Space Center	Delivered Apr. 2003		Hydrogen		For system validation under simulated flight conditions.






Teledyne Energy Systems Inc. (formerly Energy Partners)	(NASA) US Department of Energy (DOE)	7 kW PEM			Late 2002		Natural gas		For evaluation by DOE.
Tokyo Gas		SOFC	Japan	Tokyo Gas laboratory	Dec. 1998	Mar. 1999	City gas		World's first generation of power in the kilowatt range with a flat panel SOFC. The fuel cell was designed in-house.
Toshiba	Taiyo Oil Co., New Energy Foundation	Three PEM units	Matsuyama, Japan	Public facilities	Sep. 2005	Two-year demonstration	Liquefied petroleum gas (LPG)		
Toshiba	Taiyo Oil Co., New Energy Foundation	Four PEM units	Imabari, Japan	Residential	Sep. 2005	Two-year demonstration	Liquefied petroleum gas (LPG)		
Toshiba	Taiyo Oil Co., New Energy Foundation	PEM	Imabari, Japan	Nursing home	Sep. 2005	Two-year demonstration	Liquefied petroleum gas (LPG)		
Toshiba	Cosmo Oil Co Ltd	700 W PEM	Isakacho, Japan	Isaka Dam Cycle Park administrative office	Mar. 2005	Operational	Liquefied petroleum gas (LPG)		Provides power and exhaust heat used for hot water.
Toshiba	Ministry of Land, Infrastructure and Transport, Tokyo Gas	1 kW PEM	Yokohama, Japan		2004				Field test.
Toshiba	Chugoku Electric Power Co	PEM	Matsue, Japan	Research & Development Center for Energy Utilization Technology	Jun. 2003		Biogas from garbage		
Toshiba		700 kW PEM	Kamo, Japan	Toshiba Home Technology factory	Sep. 2002				Cogeneration system.
Toshiba	Tohoku Electric	1 kW PEM	Japan	Tohoku Electric research and development center	Early 2002		Town gas		Grid connected. Produces power and the waste heat is used for hot water.
Toshiba	Japan Gas Association	1 kW PEM	Demonstration tests (7 companies) held in Tokyo, Osaka and Nagoya, Japan		Phase 1: Dec. 2001	Phase I completed Feb. 2002			Japan Gas Assoc. test of residential PEM fuel cells from seven manufacturers (Ballard, Matsushita Electric, Toshiba, Toyota, Sanyo Electric, Mitsubishi Electric, Plug Power). Completed 1,000 hours of operation in Phase I testing, 8,000 hours scheduled in Phase 2 using fuel cells of different manufacturers.
Toshiba	Kyushu Electric Power Co. (KEPCO)	700 kW PEM	Japan	KEPCO Research Institute	Dec. 2001	2003	Town gas		
Toyota	Japan Gas Association	1 kW PEM	Demonstration tests (7 companies) held in Tokyo, Osaka and Nagoya, Japan		Phase 1: Dec. 2001	Phase I completed Feb. 2002			Japan Gas Assoc. test of residential PEM fuel cells from seven manufacturers (Ballard, Matsushita Electric, Toshiba, Toyota, Sanyo Electric, Mitsubishi Electric, Plug Power). Completed 1,000 hours of operation in Phase I testing, 8,000 hours scheduled in Phase 2 with nine manufacturers..
UTC Power	East Rochester School District	200 kW PureCell 200	East Rochester, New York	School	Planned		Natural gas		The fuel cell will provide 60-70% of the school energy needs. Will provide continuous electricity and heat for the high school and onsite backup power for the community's emergency response program.. The school district anticipates

									saving about \$100,000/year in energy costs. Total cost of the project is \$2.5 million, with \$1 million provided by NYSERDA and \$1.5 million from the district's Capital Reserve Fund.
UTC Power	Verizon	1.4 MW PAFC system (seven 200 kW units)	Garden City, New York	Major call-routing center serving (40,000 phone lines)	Commissioned Sep. 2005		Natural gas		The largest fuel cell deployment project in the world, providing primary electrical power for the facility. Four natural gas powered generators operate in parallel with the fuel cells as a hybrid back up system that can generate up to 4.4 MW of electrical power. Buy Down Recipient FY1999 US DoD Climate Change Fuel Cell Program (\$1.4 million).
UTC Power	New York Power Authority, Wildlife Conservation Society	200 kW PAFC	Bronx, New York	Bronx Zoo's Old Lion House	Planned		Natural gas		Buy Down Recipient FY2002 US DoD Change Fuel Cell Program (\$200,000).
UTC Power	New York Power Authority, New York City Transit	200 kW PAFC	New York City, New York	Corona Rail Car Maintenance Facility	Will be installed Apr. 2006		Natural gas		Will operate grid parallel to displace existing facility electric demand and can operate as stand alone generator during a power outage. Thermal energy will supplement the domestic hot water system. Buy Down Recipient FY2003 US DoD Climate Change Fuel Cell Program (\$200,000).
UTC Power	Anaheim Public Utilities	200 kW PAFC	Anaheim, California	East Anaheim Police Department and Community Center	Feb. 2005	Operational	Natural gas		Used for combined heat and power and back up power. Buy Down Recipient FY2002 US DoD Climate Change Fuel Cell Program (\$200,000).
UTC Power	Orgenergogaz (oil and gas pipeline engineering company)	200 kW PureCell PAFC	Russia	Orgenergogaz facility		Operational			Operated successfully during May 2005 grid power outage in Russia.
UTC Power	New York Power Authority, Grand Central Railroad	Two 200 kW PAFC	New York City, New York	Grand Central train station terminal	Installed Feb. 2005		Natural gas		Can operate in grid parallel and grid independent modes. Thermal energy will be used to produce domestic hot water for use in adjacent restaurants and hotels. Partial funding by New York State Energy Research and Development Authority. Buy Down Recipient FY2003 US DoD Climate Change Fuel Cell Program (\$400,000).
UTC Power	New York Power Authority, New York State Office of General Services	200 kW PAFC	Huappauge, New York	Suffolk State Office Building, Regional Emergency Management Office	Installed May 2005				Can operate in grid parallel and grid independent modes. Will supply power to New York Regional Emergency Management Office w. Buy Down Recipient FY2003 US DoD Climate Change Fuel Cell Program (\$200,000).
UTC Power	Hilton New York	200 kW PAFC	New York City, New York	New York Hilton Hotel	Installed Feb. 2005		Natural gas		May install at other hotel properties. Will provide power. 100% waste heat recovery for hot water in









									guest rooms, kitchens and laundry. Buy Down Recipient FY2003 US DoD Climate Change Fuel Cell Program (\$200,000).
UTC Power	LOGANEnergy, Army National Guard	200 kW PC25 PAFC	Paso Robles, California	Camp Roberts Army National Guard Base SatCOM facility	Installed Feb. 2005	Operational	Natural gas		Grid parallel to reduce electric demand and provide power stabilization. A possible California grant may allow installation of heat cogeneration equipment. Buy Down Recipient FY2003 US DoD Climate Change Fuel Cell Program (\$200,000).
UTC Power	LOGANEnergy, Guaranty Savings	Three 200 kW PAFC units	Fresno, California	Guaranty Savings-owned office building housing federal offices	Installed May 2004	Operational	Natural gas		Grid parallel to reduce facility electric demand. Provides uninterruptible power supply for computer server rooms, communications, building security, emergency lighting, elevator motors and stairwell ventilation fans. Also provides cooling and space heating. Buy Down Recipient FY2003 US DoD Climate Change Fuel Cell Program (\$600,000).
UTC Power	RWE	200 kW PC25 PAFC	Essen, Germany	RWE Fuel Cell Pavilion, Meteorit Park	Early 2004	Completed			As the system is no longer in operation, it offers visitors an insight of its interior.
UTC Power	The College of New Jersey	Three 200 kW PAFC units	Ewing Township, New Jersey	The College of New Jersey three building student housing facility	Planned start-up Sep. 2004		Natural gas		Combined heat and power operating cost savings are estimated to be \$259,000 per year. Buy Down Recipient FY2002 US DoD Climate Change Fuel Cell Program (\$600,000).
UTC Power	Toshiba, Nippon Petroleum Gas Co	200 kW PAFC	Japan	Nippon Petroleum's Niigata LPG import terminal	May 2004	Two year test	Dimethyl ester		
UTC Power	Northern Alberta Institute of Technology (NAIT)	200 kW PAFC	Edmonton, Canada	NAIT's main campus Interpretive Centre	2004	Operational			Buy Down Recipient FY2002 US DoD Climate Change Fuel Cell Program (\$200,000).
UTC Power	US Environmental Protection Agency, NORESO	200 kW PC25 PAFC	Ann Arbor, Michigan	EPA's National Vehicle Emissions Laboratory	Jan. 2004	Operational	Natural gas		Grid Parallel setup. Manufactured in 1996, had numerous upgrades prior to installation here. US DoD Climate Change Fuel Cell Program (\$200,000)
UTC Power	Erasto Gaertner children's cancer hospital, Sieco S.A., Company Paranaense de Energia	200 kW PC25 PAFC	Curitiba, Brazil	Erasto Gaertner children's cancer hospital	Delivered 2004		Natural gas		First fuel cell in Brazil. Supplies around 85% of the lighting, as well as energy for hot water for the kitchen and rooms.
UTC Power	New Haven Water Pollution Control Authority (WPCA New Haven)	200 kW PC25 PAFC	New Haven, Connecticut	WPCA facility	November 2003		Natural gas		Partly funded by Connecticut Clean Energy Fund. Providing the heat for a unique fat/oil/grease disposal system.
UTC Power	Johnson & Johnson	200-kW PAFC	New Brunswick, New Jersey	Johnson & Johnson World Headquarters administrative offices	Dec. 2003	Shut down Feb. 2005, experienced fuel reformer problems, anticipate restart summer 2006	Natural gas		Grid dependent to supplement incoming electrical service, displacing existing electric demand. Thermal energy from the fuel cell is used to provide hot water heating for the facility. Buy Down





									Recipient FY2003 US DoD Climate Change Fuel Cell Program (\$200,000).
UTC Power	New York Power Authority and New York State Energy Research and Development Authority	200 kW PC25 PAFC	New York City, New York	Oakwood Beach Water Pollution Control Plant	April 2004	Ongoing	Digester gas		Grid Parallel
UTC Power	New York Power Authority, New York Department of Environmental Protection	Two 200 kW PC25 units	New York City, New York	Ward 26 Water Pollution Control Plant	Dec. 2003	Ongoing	Digester gas		
UTC Power	New York Power Authority, New York State Energy Research and Development Authority (NYSERDA)	Three 200 kW PC25 units	New York, New York	Hunts Point Water Pollution Control Plant	Feb. 2005	Ongoing	Digester gas		Operated in grid parallel mode.
UTC Power	New York Power Authority, New York State Energy Research and Development Authority (NYSERDA)	Two 200 kW PC25C units	New York City, New York	Red Hook Water Pollution Control Plant	Dec. 2003	Ongoing	Digester gas		Operated in grid parallel mode.
UTC Power	AB Parking Facility, LLC, Logan Energy	Three 200 kW PC25 PAFC units	Fresno, California	AB Parking Facilities	Installed June 2004		Natural gas		Absorption chiller with fuel cells' waste heat will be used to provide 100 tons of cooling to 12 story commercial building. Buy Down Recipient FY1996-1997 US DoD Climate Change Fuel Cell Program (\$600,000).
UTC Power	St. Francis Hospital	200 kW PC25 PAFC	Hartford, Connecticut	St. Francis Hospital	October 2003	Operational	Natural gas		Provides power security to operating room and interconnected with hospital's distribution and air conditioning system.
UTC Power	Richard Stockton College of New Jersey, South Jersey Industries	200 kW PureCell PAFC	Pomona, New Jersey	Richard Stockton College of New Jersey	May 2003	Operational	Natural gas		Buy Down Recipient FY2002 US DoD Climate Change Fuel Cell Program (\$200,000). Officials anticipate the plant will cut energy costs by over \$81,000 annually, recovering the college's investment within four years.
UTC Power	LOGANEnergy, Austin Energy Rebekah Baines Johnson Health Center	200 kW PC25 PAFC	Austin, Texas	Rebekah Baines Johnson Health Center	Jul. 2002	Ongoing	Natural gas		Electricity is fed into the Austin Energy electric grid, (the 1 st fuel cell in Texas to feed power to the grid). The health center is using the 900,000 BTUs of thermal energy to heat their water. Austin Energy plans to provide tours and educational programs. Funding: \$200,000 US DoD Climate Change Fuel Cell Program. (Buy Down Recipient FY1996-1997)
UTC Power	LOGANEnergy, Merck & Co.	200 kW PC25C PAFC	Rahway, New Jersey	Merck & Co. plant	Jun. 2002	Four-year demonstration	Natural gas		Funding: \$710,000 from New Jersey Board of Public Utilities' clean energy initiative, \$200,000 from US DoD Climate Change Fuel Cell Program. Buy Down Recipient FY1996-1997.







UTC Power	Petrobras, Sieco S.A.	200 kW PC25 PAFC	Rio de Janeiro, Brazil	Petrobras research and development center (CENPES)	Jan. 2002	Operational			Supplies electric power needs to the center.
UTC Power	LACTEC, Sieco S.A., Polytechnical Center of the Federal University	200 kW PC25C PAFC	Curitiba, Brazil	LACTEC research and development facility	Apr. 2002	Operational	Natural gas		Buy Down Recipient FY2000 US DoD Climate Change Fuel Cell Program (\$200,000).
UTC Power	Los Angeles Department of Water and Power (LADPW)	200 kW PC25C PAFC	Los Angeles, California	LADWP Main Street Service Testing Facility	Feb. 2002	Jul. 2003	Natural gas		Buy Down recipient FY2000 US DoD Climate Change Fuel Cell Program (\$200,000).
UTC Power	New York Power Authority, New York State Energy Research and Development Authority	Two 200 kW PC25 PAFC	New York City, New York	Bowery Bay Waste Water Treatment Plant	2002	Ongoing	Digester gas		Grid Parallel
UTC Power	Connecticut Clean Energy Fund	200 kW PC25 PAFC	South Windsor, Connecticut	South Windsor High School	Oct. 2002	Ongoing	Natural gas		First municipal facility to be powered and heated by a fuel cell in Connecticut. Also serves as a basis of a comprehensive fuel-cell curriculum. The school also serves a regional emergency shelter. Funding was provided by the Connecticut Clean Energy Fund
UTC Power	Toshiba, Nippon Petroleum Gas Co	200 kW PAFC	Numazu, Japan	Nishijima Hospital	2001		Liquefied petroleum gas		
UTC Power	Henry Doorly Zoo, Omaha Public Power District	200 kW PC25 PAFC	Omaha, Nebraska	Lied Jungle exhibit at Henry Doorly Zoo	Installed Aug. 2001	Ongoing	Natural gas		The PC25's waste heat is used to warm the water in a number of ponds and heat 5,000 gallons of water used for irrigation each night. Buy Down Recipient FY1999 US DoD Climate Change Fuel Cell Program. (\$200,000)
UTC Power	Woking Borough Council	200 kW PC25C PAFC	Woking, UK (England)	Woking Park	Jan. 2002		Natural gas		First commercial fuel cell operating in the UK. Provides electricity and heat for the recreational center and electricity to light the park. Waste heat will be used to meet the recreational center's summer cooling and dehumidification requirements via heat-fired absorption cooling. Buy Down Recipient FY1998 US DoD Climate Change Fuel Cell Program (\$200,000).
UTC Power	Toshiba, Institute of Energy Economics, New Energy, Industrial Technology Development Organization (NEDO)	200 kW PC25	Guangzhou, China	Hog farm	May 2000	Inactive	Liquefied petroleum gas (LPG), waste methane gas produced at the farm		First commercial fuel cell power installation in China. Sold to Toshiba Corp. which was modified and sold to the customer. The unit is managed by the Industrial Technology Development Organization (NEDO) of Japan.









UTC Power	Companhia Paranaense de Energia (COPEL), Sieco S.A.	200 kW PC25 PAFC	Curitiba, Brazil	Companhia Paranaense de Energia (COPEL), computer system center	Aug. 2001	Operational	Natural gas		First stationary fuel cell in Brazil. Supplies energy to the center (grid parallel). Buy Down Recipient FY2000 US DoD Climate Change Fuel Cell Program (\$200,000).
UTC Power	Connecticut Juvenile Training School	1.2 MW PC25 (six 200 kW PAFC units)	Middletown, Connecticut	Connecticut Juvenile Training School	2001	Ongoing	Natural gas		Used in conjunction with traditional generators and the grid to provide primary power to the school. The heat produced by the fuel cells is used for heating and cooling the facility. Buy Down Recipient FY1996-1997 (\$1.2 million).
UTC Power	CTG Corporation, Mohegan Sun	Two 200 kW PAFC systems	Uncasville, Connecticut	Mohegan Sun Casino Hotel	March 2002	Ongoing	Natural gas		Provides back-up power. Buy Down Recipient FY1996-1997 US DoD Climate Change Fuel Cell Program. (\$400,000)
UTC Power	LOGAN Energy, Motor Co.	200 kW PAFC	Irvine, California	Ford Motor Company's North American Premier Automotive Group headquarters	Dec. 2001	Ongoing	Natural gas		Provides 25% of the building's power and hot water needs. Buy Down Recipient FY1996-1997 US DoD Climate Change Fuel Cell Program (\$200,000).
UTC Power	New York Power Authority (NYPA), KeySpan Energy, New York City Wildlife Conservation Society	200 kW PC25	Coney Island, New York	New York Aquarium	Installed Dec. 2001	Operational	Natural gas		Provides 20% of the aquarium's power needs (grid parallel). The installation will allow the Aquarium to decrease its demand on standard sources of electricity. It will also provide enough waste heat to warm domestic hot water and boiler supply water for buildings and tanks, further reducing energy needs
UTC Power	US Department of Energy, BEW GmbH, Thyssengas GmbH, TBE	200 kW PC25C PAFC	Bocholt, Germany	St. Agnes Hospital	Jan. 2001	Ongoing	Natural gas		Provides electrical power, heat and air conditioning--8,000 hrs of uninterrupted operation in first year, setting a European record. The fuel cell saves roughly 500 tons of carbon dioxide per year. Buy Down Recipient FY1998 US DoD Climate Change Fuel Cell Program (\$200,000).
UTC Power	US Army Corp of Engineers	200 kW PC25A PAFC	Tucson, Arizona	Arizona Air National Guard Pinal Air Park	Mar. 2001	Operational	Natural gas		The power plant was moved from Vandenberg Air Force Base (see entry below) to Pinal Air Park. It is now operating at 175 kW to facilitate long-term operation of the power plant.
UTC Power	Chevron	200 kW PAFC	San Ramon, California	Chevron Data Center	Jan. 2002	Ongoing	Natural gas		Supports critical data and retail transaction systems. During a power outage, special switching equipment ensures the fuel cell will continue to provide electricity to these systems without interruption. FY 2000 US DoD Climate Change Fuel Cell Program (\$200,000).
UTC Power	Hamburg Gas Consult	200 kW PAFC	Frankfurt, Germany	Frankfurt-Hoechst industrial park	Jul. 2001				Provides combined heat and power.
UTC Power	Los Angeles Department of Water and Power	200 kW PAFC	Los Angeles, California	Playa Vista Project (commercial and residential development)	March 2002	Inactive			Initially connected to the electric grid, with plans to provide electricity and heat to tenants of the Playa Vista Project. Buy Down











Recipient FY2000 US DoD Climate Change Fuel Cell Program (\$200,000).










UTC Power	Alcorn State University, Logan Energy	200 kW PC25C PAFC	Lorman, Mississippi	Alcorn State University	Oct. 2000	Oct. 2001	Natural gas		Supports campus electricity grid. Buy Down Recipient FY1995 US DoD Climate Change Fuel Cell Program. (\$200,000)
UTC Power	Energy 2000, Las Virgenes Waste Water Treatment	Two 200 kW PC25 PAFC	Calabasas, California	Las Virgenes Wastewater Treatment Plant	Dec. 1999	Inactive	Methane		Provided 99% of on-site electricity. Buy Down Recipient FY1996-1997 US DoD Climate Change Fuel Cell Program (\$400,000)
UTC Power	Chugach Electric Association	1 MW PAFC (five 200 kW PC25 200 PAFC units)	Anchorage, Alaska	US Postal Service headquarters	Aug. 2000	Ongoing	Natural gas		Was the largest commercial fuel cell system in the nation in 2000 and was the first time a fuel cell system was part of an electric utility's grid. Supplies all electrical power for the main postal sorting facility in Anchorage. Buy Down Recipient FY1998 US DoD Climate Change Fuel Cell Program (\$1 million).
UTC Power	TBE GmbH, GEW Köln AG	200 kW PC25C PAFC	Cologne, Germany	Cologne-Rodenkirchen sewage treatment plant	Installed Mar. 2000	Aug. 2001	Digester gas		Buy Down Recipient FY1998 US DoD Climate Change Fuel Cell Program (\$200,000). The first time in Europe a fuel cell was used to utilize waste methanol produced from sewage to generate electricity and heat efficiency. Heat generated will be used in the sewage treatment process. Operated 9,000 hours.
UTC Power	City of Mesa Utilities Department	200 kW PC25C PAFC	Mesa, Arizona	City of Mesa Utilities Department headquarters	Apr. 2000	Operational			Buy Down Program Recipient FY1995 US DoD Climate Change Fuel Cell Program (\$200,000).
UTC Power	Logan Energy, Chevron Texaco	200 kW PC25C PAFC	Bellaire, Texas	Texaco Energy Systems Central Plant	May 2000	Inactive			Combined heat and power production. Buy Down Recipient FY1996-1997 US DoD Climate Change Fuel Cell Program (\$200,000)
UTC Power	McBride Energy, College of New Jersey	Two 200 kW PAFC units	Mahwah, New Jersey	Ramapo College dormitory and computer center	Installed Nov. 2000		Natural gas		Grid parallel. Supplies power and thermal energy (hot water, space heating) to a student Dormitory and a core academic building complex (housing a computer center, telephone exchange and cable TV station). Buy Down Recipient FY1998 US DoD Climate Change Fuel Cell Program (\$400,000).
UTC Power	New York Power Authority, KepSpan Energy, New York City Health and Hospitals Corporation	200 kW PAFC	Bronx, New York	North Central Bronx Hospital	Installed Dec. 2000	Ongoing	Natural gas		Supplies supplemental power and back-up power. Buy Down Recipient FY1995 US DoD Climate Change Fuel Cell Program. (\$600,000)
UTC Power	Niagara Mohawk/Plum Street Enterprises, Onondaga-	200 kW PC25 PAFC	Liverpool, New York	Liverpool High School	Feb. 2000	Ongoing	Natural gas		Serves as an educational resource for science teachers. Grid-independent--will allow the high school to become an










	Courtland-Madison Board of Cooperative Educational Services								emergency shelter during community disasters. Buy Down Recipient in FY1995-1996-1997 US DoD Climate Change Fuel Cell Program (\$200,000).
UTC Power	Durst Corporation	Two 200 kW PAFC systems	Manhattan, New York	4 th floor Conde Nast Building in Times Square	Feb. 2000	Ongoing	Natural gas		Provides power for the NASDAQ sign. Buy Down Recipient FY1996-1997 US DoD Climate Change Fuel Cell Program (\$400,000).
UTC Power	Electricite de France, Gaz de France, GEPPAC	200 kW PC25C PAFC	Chelles, France	Council flats	Jan. 2000	Inactive	Natural gas		Provides heat and supplements power to 200 homes.
UTC Power	AEB	200 kW PC25 PAFC	Basel, Switzerland	AEB	2000				Provides electricity to the local grid and heat to a school.
UTC Power	DBI Gas, Technische Universitat Dresden, Gastec N.V., NVG, Hamburg Gas Consult	200 kW PC25C PAFC	Kamen, Germany	Malteser Hospital	Feb. 2000)	37-month project	Natural gas		Produces power, heat, and air-conditioning
UTC Power	Oak Ridge National Laboratory	200 kW PC25 PAFC	Oak Ridge, Tennessee		June 2003		Natural gas		Buy Down Recipient FY2000 US DoD Climate Change Fuel Cell Program. (\$200,000)
UTC Power	Louisiana Gas Services, Citizens Utilities	200 kW PC25C PAFC	Harvey, Louisiana	Louisiana Gas Services Systems Operation Facility	March 1999	Decommissioned	Natural gas		Project decommissioned after customer relocated. Buy Down Recipient FY1997 US DoD Climate Change Fuel Cell Program (\$200,000).
UTC Power	Reliant Energy Company, US Department of Defense	200 kW PC25C PAFC	Gulfport, Mississippi	Navy Combat Construction Battalion Base	1999	Inactive			Provides combined heat and power for mess hall. Buy Down Recipient FY1997 US DoD Climate Change Fuel Cell Program (\$200,000).
UTC Power	CLC S.r.l. Italy Ansaldo, Sun Chemical Corporation, Keyspan Energy, Brooklyn Union Gas Company	Two 200 kW PC25 PAFC units	Staten Island, New York	Sun Chemical manufacturing facility	Installed Jun. 1996		Natural gas		By 2002, both units had operated 40,000 hours each. Buy Down Recipient FY1995 US DoD Climate Change Fuel Cell Program (\$400,000).
UTC Power	CLC Srl Italy Ansaldo, Stadtwerke Oranienburg, Hamburg Gas Consult	200 kW PC25C PAFC	Oranienburg, Germany	Stadtwerke Oranienburg Power Generation Plant	Installed Jan. 1998		Natural gas		Buy Down Recipient FY1995 US DoD Climate Change Fuel Cell Program (\$200,000).
UTC Power	CLC Srl	200 kW PAFC	Italy				Natural gas		Buy Down Recipient FY1995 US DoD Climate Change Fuel Cell Program (\$200,000).
UTC Power	CLC.r.l. Italy Ansaldo, GSA, Hamburg Gas Consult	200 kW PC25C PAFC	Halle, Germany		Installed Aug. 1997		Natural gas		Buy Down Recipient FY1995 US DoD Climate Change Fuel Cell Program (\$200,000).
UTC Power	Ansaldo	200 kW PAFC	Leipzig, Germany		1997				
UTC Power	HEW, Hamburg Gas Consult	200 kW PC25C PAFC	Hamburg, Germany	Residential building at Lyserstrasse	Aug. 1997		Pure liquid hydrogen		The project is supported by the European Commission within the framework of the EQHPP. Focus on technical and operating aspects of hydrogen-fueled fuel cell, as well as public acceptance of, and legal aspects involved, in transporting and storing liquid hydrogen in an urban area.










UTC Power	Hamburg Gas Consult, HEW	200 kW PC25A PAFC	Hamburg, Germany	Residential building at Lyserstrasse	Jun. 1993		Natural gas		Buy Down Recipient FY1998 US DoD Climate Change Fuel Cell Program.
UTC Power	CLC.r.l. Italy Ansaldo, Stadtwerke Saarbrücken AG, Erdgas Energie Systeme, ABB Energie Systeme, VVS	200 kW PC25C PAFC	Saarbrücken, Germany	Housing estate	Installed May 1997		Natural gas		Buy Down Recipient FY1995 US DoD Climate Change Fuel Cell Program (\$200,000). Supplying energy to the "Nachtweide" district. Supplies electricity to 400 dwellings and heat to 125.
UTC Power	Ansaldo, Energie und Wasserversorg, Erdgas Energie Systeme, ABB Energie Systeme, Austria Ferngas, US Department of Defense	200 kW PC25C PAFC	Nuremberg, Germany		Installed Jan. 1998		Natural gas		Buy Down Recipient FY1995 US DoD Climate Change Fuel Cell Program (\$200,000). Average electrical efficiency of the fuel cell plant was more than 39% in 1998. The total efficiency of the system was about 70% in this period.
UTC Power	Connecticut Natural Gas Corp.	200 kW PAFC	Hartford, Connecticut	Connecticut Natural Gas headquarters			Natural gas		Buy Down Recipient FY1995 US DoD Climate Change Fuel Cell Program. Fuel cell provided power to Connecticut Natural Gas headquarters then was donated to the Department of Engineering at the University of Connecticut for research in 2001.
UTC Power	Equitable Resources	200 kW PAFC	Oakmont, Pennsylvania	Presbyterian Medical Center			Natural gas		Buy Down Recipient FY1995
UTC Power	Equitable Resources	200 kW PC25A PAFC	Squirrel Hill, Pennsylvania	Riverview Center for Jewish Seniors	1992		Natural gas		For demonstration purposes.
UTC Power	Hamilton Sunstrand	200 kW PC25A PAFC	Windsor Locks, Connecticut	Hamilton Sundstrand Data Center	Installed Dec. 1997		Natural gas		Buy Down Recipient FY1995 US DoD Climate Change Fuel Cell Program (\$200,000).
UTC Power	US Department of Defense	200 kW PC25C PAFC	Pittsburgh, Pennsylvania	911 Air Lift Wing	Feb. 1997	Decommissioned Feb. 2001			
UTC Power	Lord & Company	Three 200 kW PAFC units							Buy Down Recipient FY1998 US DoD Climate Change Fuel Cell Program. (\$600,000)
UTC Power	Bharat Heavy Electricals Ltd., India's Department of Non-conventional Energy Sources	200 kW PC25C PAFC	India	Bharat Heavy Electricals test facility	1998	2000	Liquefied petroleum gas (LPG)		Was to be restarted late using natural gas as fuel.
UTC Power	State of Alaska	Two 200 kW PAFC units	Anchorage, Alaska	Anchorage Readiness Center office-training facility	Dec. 1996		Natural gas		Buy Down Recipient FY1995 US DoD Climate Change Fuel Cell Program (\$400,000).
UTC Power	Toshiba Corporation, HEAG AG	200 kW PC25C PAFC	Endersbach, Germany		1997		Natural gas		Buy Down Recipient FY1995 US DoD Climate Change Fuel Cell Program.
UTC Power	Toshiba Corporation-Power Systems and Service Co.	200 kW PAFC	Japan	Toshiba Fuchu Works			Natural gas		Buy Down Recipient FY1998 US DoD Climate Change Fuel Cell Program (\$200,000).
UTC Power	Ontario Hydro	200 kW PAFC	Markham, Canada	Ontario Hydro's Markham Centre	Installed between				Provides baseload heat and electricity.







					1993-1995				
UTC Power	Sapporo Brewery	200 kW PC25 PAFC	Chiba, Japan	Sapporo Brewery	Jun. 1998	Ongoing	Digester gas		Estimated total energy savings at the Chiba brewery was about 4%.
UTC Power	Asahi Brewery	200 kW PC25 PAFC	Shikoku, Japan	Asahi Brewery		Ongoing	Methane gas from brewing process		
UTC Fuel Cells	Washington Water and Power, Avista Corporation, Double Tree Inn	200 kW PC25C PAFC	Spokane, Washington	Double Tree Inn Hotel	Installed Jul. 1997		Natural gas		Buy Down Recipient FY1995 US DoD Climate Change Fuel Cell Program (\$200,000). Provides the hotel's minimum electric load of 200 kW and supplements hot water requirements
UTC Power	ABB Energie Systeme GmbH	200 kW PC25C PAFC	Kaltenkirchen, Germany	School	Oct. 1998		Natural gas		Supplies power and heat.
UTC Power	Massachusetts Water Resources Authority, New England Power Company	200 kW PC25C PAFC	Boston, Massachusetts	Deer Island Sewage Treatment Plant	1997	Decommissioned Jun. 2002	Digester gas		Buy Down Recipient FY1995 US DoD Climate Change Fuel Cell Program (\$200,000).
UTC Power	AEC South County Hospital	200 kW PC25 PAFC	Wakefield, Rhode Island	South County Hospital	1999		Natural gas		Provides electricity and heat. Produces one-third of hospital's electricity during peak hours, saving \$60,000-\$90,000/year. Also provides back up power to the hospital's critical loads. Buy Down Recipient FY1998 US DoD Climate Change Fuel Cell Program (\$200,000).
UTC Power	New York Power Authority, KeySpan Energy, New York City Police Department	200 kW PureCell PAFC	Manhattan, New York	Central Park police headquarters	Apr. 1999	Ongoing	Natural gas		Provides all electricity for the police station, independent of the electric grid.
UTC Power	NORESCO, First National Bank of Omaha, Sure Power Corp.	Four 200 kW PC25 PAFC units	Omaha, Nebraska	First National Bank	Nov. 1999	Ongoing (purchase)	Natural gas		Provides the main power for a critical data processing facility. The bank is one of the largest credit card processors in the nation. Buy Down Recipient FY1995 US DoD Climate Change Fuel Cell Program (\$800,000).
UTC Power	Onondaga-Courtland-Madison Board of Cooperative Educational Services (BOCES)	200 kW PC25C PAFC	Syracuse, New York	BOCES Regional Information Center	Jan. 1997		Natural gas		Has operated for more than 22,000 hours. Funded by the US DoD Climate Change Fuel Cell Program (\$200,000) and NYSERDA (\$331,212)
UTC Power	Cape Cod Community College, NORESO	200 kW PC25C PAFC	West Barnstable, Massachusetts	Cape Cod Community College library	Installed Apr. 1999		Natural gas		Non-critical baseload power, with limited cogeneration (library space heating). Provides 15% of peak and 46% of summer power demand. Buy Down Recipient FY1995 US DoD Climate Change Fuel Cell Program (\$200,000).
UTC Power	Town of Groton, International Fuel Cells, US Environmental Protection Agency	200 kW PC25 PAFC	Groton, Connecticut	Flanders Road Landfill	Jun. 1996		Anaerobic digester gas		Provided approximately 140 kW of electricity to the Connecticut Light and Power Company







UTC Power	Northeast Utilities, International-Fuel Cells, US Environmental Protection Agency	200 kW PC25 PAFC	Sun Valley, California	Penrose Landfill power plant	1993	Completed 6 - month demonstration	Landfill gas		Power generated during the project was sold to the Los Angeles Department of Water and Power to help offset costs Relocated to Flanders Road Landfill in Connecticut.
UTC Power	Fuel Cell Test and Evaluation Center (FCTec)	200 kW PC25C PAFC	Johnstown, Pennsylvania	FCTec at National Defense Center for Environmental Excellence	Jan. 1999	Jan. 2003	Natural gas		http://www.fctec.com/main.html
UTC Power	City of Portland	200 kW PAFC	Portland, Oregon	Columbia Blvd. Waste Water Treatment Plant	Jul. 1999	Inactive	Methane digester gas		Provides heat and electricity to the facility. Portland's fuel cell generates as much as 1.6 million kW-hrs/yr. Buy Down Recipient FY1996-1997 US DoD Climate Change Fuel Cell Program (\$200,000).
UTC Power	Australian Technology Park Sydney LTD	200 kW PAFC	Sydney, Australia	Australian Technology Park	Nov. 1998	Operational	Natural gas		Australia's First fuel cell. Provides power to medical centers, labs and computer systems located within the Technology Park. Buy Down Program Recipient FY1998 US DoD Climate Change Fuel Cell Program (\$200,000).
UTC Power	US Army Corp of Engineers	200 kW PC25B PAFC	Newport News, Virginia	Fort Eustis, gymnasium/ pool	Sept. 1995	Jan. 2002	Natural gas		US Department of Defense PAFC Demonstration Program. Thermal output to DHW and pool (~68% est. thermal utilization).
UTC Power	US Army Corp of Engineers, Consolidated Natural Gas	200 kW PC25C PAFC	Pittsburgh, Pennsylvania	911th Airlift Wing Central Heating Plant	Feb. 1997	Off-line Sep. 2001	Natural gas		US Department of Defense PAFC Demonstration Program. Grid connected (no emergency back-up)
UTC Power	US Army Corp of Engineers	200 kW PC25B PAFC	White Hall, Arkansas	Pine Bluff Arsenal Boiler Plant	Oct. 1997	Jan 2000	Natural gas		US Department of Defense PAFC Demonstration Program Grid connected at splice after pole mounted transformer. Grid independent terminals power the boiler plant. Thermal output heats boiler make-up water. Total estimated thermal utilization ~90%.
UTC Power	US Army Corp of Engineers	200 kW PC25B PAFC	Minneapolis, Minnesota	934th Tactical Air Group Boiler Plant	Feb 1995	Sep. 2000	Natural gas		US Department of Defense PAFC Demonstration Program. Grid connected at new electrical transformer (fuel cell option). Thermal output to preheat boiler make-up water (~45% est. thermal utilization)
UTC Power	US Department of Defense	200 kW PC25B PAFC	West Point, New York	West Point Military Academy Central Boiler Plant	Dec. 1995	Feb. 2001	Natural gas		US Department of Defense PAFC Demonstration Program . Grid connected at existing panel. Thermal output for boiler make-up water (~70% estimated thermal utilization).
UTC Power	US Army Corp of Engineers	200 kW PC25B PAFC	Albany, New York	Watervliet Arsenal, Central Boiler Plant	Oct. 1997	Jul. 2002	Natural gas		US Department of Defense PAFC Demonstration Program . Grid connected at existing electrical panel. Emergency back-up for grid-independent operation. Thermal output to preheat boiler make-up (~58% est. thermal


									utilization).
UTC Power	US Department of Defense	200 kW PC25C PAFC	Bossier City, Louisiana	Barksdale Air Force Base hospital	Jul. 1997	Oct. 2002	Natural gas		US Department of Defense PAFC Demonstration Program. Grid connected. Total estimated thermal utilization ~90%.
UTC Power	US Army Corp of Engineers	200 kW PC25C PAFC	Tucson, Arizona	Davis-Monthan Air Force Base gymnasium	Dec. 1997	Apr. 2002	Natural gas		US Department of Defense PAFC Demonstration Program. Grid connected at new transformer (program option). High grade thermal output (program option) to absorption chillers. Low grade thermal output to hot water storage tank. Total estimated thermal utilization ~65%.
UTC Power	US Department of Defense	200 kW PC25C PAFC	Palmdale, California	Edwards Air Force Base hospital	Jul. 1997	Jul. 2002	Natural gas		US Department of Defense PAFC Demonstration Program. Grid connected at existing Transformer. High grade thermal output. (Program option) to space heating loop. Total estimated thermal utilization ~23%.
UTC Power	US Army Corp of Engineers	200 kW PC25B PAFC	Albuquerque, New Mexico	Kirtland Air Force Base Boiler Plant	Sep. 1995	Dec.-2001	Natural gas		US Department of Defense PAFC Demonstration Program. Grid connected at switch tied to electrical transformer. Grid independent connection to entire boiler plant. Thermal output to deaerator tank (~55% est. thermal utilization).
UTC Power	US Army Corp of Engineers	200 kW PC25C PAFC	Del Rio, Texas	Laughlin Air Force Base Hospital	Sep. 1997	Nov. 2002	Natural gas		US Department of Defense PAFC Demonstration Program. Grid connected at existing electrical transformer (no emergency back-up). Thermal output to space heat/cool reheat loop and DHW loop (~75% estimated thermal utilization)
UTC Power	US Army Corp. of Engineers	200 kW PC25C PAFC	Jacksonville, Arkansas	Little Rock Air Force Base hospital	Oct. 1997	Shut down Dec. 2000, was to be transferred to another facility	Natural gas		Department of Defense PAFC Demonstration Program. Grid connected at electrical panel. Thermal output heats space conditioning recirculation loop. Total estimated thermal utilization ~85%.
UTC Power	US Army Corp of Engineers	200 kW PC25B PAFC	Las Vegas, Nevada	Nellis Air Force Base Central Plant for dormitory facility	Oct. 1995	Jun. 2001	Natural gas		Department of Defense PAFC Demonstration Program. Grid connected at main breaker panel. Thermal to make-up water and heat pump loop (~40% est. thermal utilization).
UTC Power	US Army Corp of Engineers	200 kW PC25A PAFC	Lompoc, California	Vandenberg Air Force Base, Space Control Center	Mar. 1994	Feb. 2001	Natural gas		Department of Defense PAFC Demonstration Program. The power plant was moved to Pinal Air Park, Arizona Air National Guard in Tucson, Arizona.
UTC Power	US Army Corp of Engineers	200 kW PC25C PAFC	Johnstown, Pennsylvania	Naval Defense Center for Environmental Excellence (NDCEE) Industrial Building	Aug. 1997	Operational	Natural gas		Department of Defense PAFC Demonstration Program. Grid connected in spare panel slot. High grade thermal output heats evaporator tank. Total estimated thermal utilization ~19%.


UTC Power	US Army Corp of Engineers	200 kW PC25C PAFC	Annapolis, Maryland	Naval Academy galley	Sep. 1997	Sep. 2002	Natural gas		Department of Defense PAFC Demonstration Program. Grid connected in electrical room. Thermal output heats make-up water. Total estimated thermal utilization ~78%.
UTC Power	US Army Corp of Engineers	200 kW PC25C PAFC	Groton, Connecticut	Navy Subase New London Boiler Plant	Oct. 1997	Operational	Natural gas		Department of Defense PAFC Demonstration Program. Grid connected at existing electrical panel. Thermal output heats boiler make-up water. Total estimated thermal utilization ~90%.
UTC Power	US Army Corp of Engineers	200 kW PC25B PAFC	Twentynine Palms, California	Twentynine Palms Marine Corp Base Naval Hospital	Jun. 1996	May 2000	Natural gas		Department of Defense PAFC Demonstration Program. Grid connected at existing sub panel. Grid independent connection at new electrical sub panel. Thermal output to DHW loops (~60% est. thermal utilization).
UTC Power	US Army Corp of Engineers	200 kW PC25B PAFC	Newport, Rhode Island	Naval Education Training Center Boiler Plant	Feb. 1995	Apr. 2001	Natural gas		Department of Defense PAFC Demonstration Program. Grid connected at boiler plant electrical transformer. Thermal output to preheat boiler make-up water (~60% est. thermal utilization).
UTC Power	US Army Corp of Engineers	200 kW PC25B PAFC	Stennis Space Center, Mississippi	Naval Oceanic Center for NAVO support, Stennis Space Center	Sep. 1997	Oct. 2002	Natural gas		Department of Defense PAFC Demonstration Program. Grid connected at electrical panel. Grid independent load connected at new panel. Thermal output used for space heat/reheat loop Total estimated thermal utilization ~12%.
UTC Power	US Army Corp of Engineers	200 kW PC25C PAFC	Fallon, Nevada	Naval Air Station galley	Mar. 1997	Mar. 2002	Natural gas		Department of Defense PAFC Demonstration Program. Grid connected at new electric transformer (fuel cell option). Grid independent connection at new electric transformer (fuel cell option). Thermal output to DHW loop (~10% est. thermal utilization).
UTC Power	US Army Corp of Engineers	200 kW PC25C PAFC	Jacksonville, Florida	Naval Air Station Naval Hospital	Apr. 1997	Apr. 2002	Natural gas		Department of Defense PAFC Demonstration Program. Grid connected at existing electrical panel (no emergency back-up). Thermal output to DHW loop (~56% est. thermal utilization).
UTC Power	US Army Corp of Engineers	200 kW PC25C PAFC	Natick, Massachusetts	US Army Soldier Systems Command Boiler Plant	Feb. 1995	Jan. 2003	Natural gas		US Department of Defense PAFC Demonstration Program. Grid connected at existing sub panel. Thermal output to storage tank. Thermal output to storage tank (~45% estimated thermal utilization).
UTC Power	US Department of Defense	200 kW PC25B PAFC	Dover, New Jersey	Picatinny Arsenal, Boiler Plant	Oct. 1995	Jul. 2001	Natural gas		US Department of Defense PAFC Demonstration Program. Grid connected at panel inside electric room. Thermal output preheats make-up water (~100% estimated thermal utilization).
UTC Power	US Army Corp	200 kW PC25C	Anchorage,	Fort Richardson	Apr. 1997	Apr. 2001	Natural gas		US Department of Defense

	of Engineers	PAFC	Alaska	National Guard Armory					PAFC Demonstration Program. Grid connected at existing electrical panel (no emergency back-up. High grade thermal output (option) to space heating Loop. Thermal output to domestic hot water (total ~45% estimated thermal utilization).
UTC Power	US Army Corp of Engineers	200 kW C25B PAFC	Oceanside, California	Marine Corp Base Camp Pendleton Naval Hospital	Oct. 1995	Jan. 2002	Natural gas		Department of Defense PAFC Demonstration Program. Grid connected at existing panel. Thermal output for DHW storage (~75% est. thermal utilization).
UTC Power	US Department of Defense	200 kW PC25B PAFC	Sierra Vista, Arizona	Fort Huachuca Riley Barracks	Jul. 1997	Inactive	Natural gas		US Department of Defense PAFC Demonstration Program. Grid connected at existing Electrical transformer (no emergency back-up). High grade thermal output (option) to space heating loop. Thermal output to domestic hot water (total ~44% estimated thermal utilization).
UTC Power	US Army Corp of Engineers	200 kW PC25B PAFC	West Point, New York	U.S. Military Academy Central Boiler Plant	Dec. 1995	Feb. 2001	Natural gas		Department of Defense PAFC Demonstration Program. Grid connected at existing panel. Thermal output for boiler make-up water (~70% estimated thermal utilization).
UTC Power	US Army Corp of Engineers	200 kW PC25C PAFC	Chicopee, Massachusetts	Westover Air Reserve Bas, Boiler Plant	Sep. 1997	Jul. 2002	Natural gas		Department of Defense PAFC Demonstration Program. Grid connected at new electrical transformer (Program option). Low grade thermal output heats boiler make-up water. High grade thermal output (Program option) to condensate return loop. Total estimated thermal utilization ~45%.
UTC Power	US Army Corp of Engineers	200 kW PC25B PAFC	Port Hueneme, California	CBC, Port Hueneme swimming pool	Aug. 1997	Dec 2001	Natural gas		Department of Defense PAFC Demonstration Program. Grid connected at new transformer. Thermal output heats swimming pool. Total estimated thermal utilization ~92%.
UTC Power	US Army Corp of Engineers	200 kW PC25C PAFC	El Paso, Texas	Fort Bliss laundry	Sep.-1997	Jun. 2002	Natural gas		US Department of Defense PAFC Demonstration Program. Grid connected at new transformer. Thermal output heats laundry hot water storage tanks. Total estimated thermal utilization ~17%.
UTC Power	New York Power Authority, KeySpan Energy, Westchester County Department of Environmental Facilities	200 kW PAFC	Yonkers, New York	Yonkers Wastewater Treatment Plant	Apr. 1997	Ongoing	Anaerobic digester gas		Supplies grid parallel supplemental power. World's first anaerobic digester gas-fueled fuel cell.
UTC Power	Yankee Gas Services	Two 200 kW PAFC units	South Windsor, Connecticut	Yankee Corporation headquarters	Oct. 1997		Natural gas		Buy Down Recipient FY1996-1997 US DoD Climate Change Fuel Cell Program. (\$400,000)


UTC Power	Braintree Electric Light Department	200 kW PC25C PAFC	Braintree, Massachusetts	Landfill	Sep. 1999	Inactive	Landfill gas, natural gas		Baseload power serving town utility grid (less than 1% of peak load). Buy Down Recipient FY1995 US DoD Climate Change Fuel Cell Program (\$200,000).
UTC Power	US Airways, Peoples' Natural Gas	200 kW PC25C PAFC	Pittsburgh, Pennsylvania	U.S. Air's hanger #2 at Pittsburgh International Airport			Natural gas		
UTC Power	Toshiba Corporation	200 kW PAFC	Houston, Texas		1998	Operational	Natural gas		Grid-independent operation. Buy Down Recipient FY1995 US DoD Climate Change Fuel Cell Program (\$200,000).
UTC Power	Brooklyn Union Gas Co., St. Vincent's Medical Center	200 kW PAFC	New York, New York	Saint Vincent's Medical Center laundry facility	Oct. 1992	Ongoing	Natural gas		1995 Cogeneration Project of the Year by the Cogeneration and Competitive Power Institute
UTC Power	Toho Gas	200 kW PAFC	Japan		Installed between 1993-1995				
UTC Power	Osaka Gas	Ten 200 kW PAFC units	Japan		Installed between 1993-1995				
UTC Power	Tokyo Gas	Ten 200 kW PAFC units	Japan		Installed between 1993-1995				
UTC Power	Kaiser Permanente, Southern California Gas CO, Gas Research Institute, US Department of Energy	Two 200 kW PC25A units	Riverside, California	Riverside Medical Center	Sep. 1994	Feb. 2000 + Mar. 2001	Natural gas		Provided power and cogeneration of waste heat. Won the 1994 Efficient Building Award for Energy and the Environment sponsored by Energy User News
UTC Power	Southern California Gas Company	200 kW PC25A PAFC	Santa Barbara, California	Santa Barbara jail	Oct. 1994	Mar. 2001	Natural gas		Provides electricity and hot water.
UTC Power	Mitsubishi Electric, Toshiba Corporation	200 kW PC25 PAFC	Japan	Kyobashi DHC	Feb. 1994	Oct. 2000			This unit accumulated 43,139 hours by Oct. 2000.
UTC Power	Bharat Heavy Electricals Ltd. (BHEL), Toshiba	200 kW PAFC	India	BHEL testing facility	1998	2000	Liquefied propane gas (LPG)		Tested in grid-dependent and grid-independent modes.
UTC Power	Tokyo Electric Power Co (TEPCO), Toshiba Corporation	200 kW PC25 PAFC	Japan	TEPCO Research and Development Center	Sep. 1994		City gas		This unit accumulated 44,011 hours by Oct. 2000
UTC Power	Corporation, Southern California Gas, Kaiser Permanente	200 kW PC25A PAFC	Anaheim, California	Anaheim Medical Center	May 1993	End of Life May 2000	Natural gas		Provided power and cogeneration of waste heat. Buy Down Recipient FY1995 US DoD Climate Change Fuel Cell Program (\$200,000)
UTC Power	Sacramento Municipal Utility District, Kaiser Permanente	200 kW PAFC	Sacramento, California	South Sacramento Medical Center	Early 1990s				Provided power and cogeneration of waste heat.
UTC Power	Southern California Gas	200 kW PC25A PAFC	Buena Park, California	Kraft Foods	Jul. 1993	Removed Jun. 1996	Natural gas		Sold to City of Mesa, AZ
UTC Power	Southern California Gas	200 kW PC25A PAFC	Santa Barbara, California	University of California	Sep. 1993	Life ended Jun. 1998	Natural gas		

UTC Power	Commonwealth Gas	200 kW PC25 PAFC	Natick, Massachusetts	U.S. Army Soldier Systems Command	FY 1993		Natural gas		
UTC Power	Southern California Gas	200 kW PC25A PAFC	Irvine, California	Hyatt Hotel	Sep. 1992	Life ended Mar. 2002	Natural gas		
UTC Power	Southern California Gas	200 kW PC25A PAFC	Los Angeles, California	SCAQMD Office Building	Apr. 1992		Natural gas		Had a lifetime of about 40,000 hours. Cell stack was replaced in 1998 and returned to service. Provides 20-25% of building power.
UTC Power	Service du Gaz	200 kW PC25 PAFC	Geneva, Switzerland		Mar. 1993				Operated for 40,000 hours.
UTC Power	Tokyo Gas, Toshiba Corporation	200 kW PC25A PAFC	Tokyo, Japan	Tokyo Gas Research & Development facility	Apr. 1992	2000			
UTC Power	Tokyo Electric Power Co, Toshiba Corporation	11 MW PAFC unit (twenty 700 kW units)	Ichihara, Japan	Goi Station of Tokyo Electric Power Co	Mar. 1991	Completed Mar. 1997	Liquefied natural gas (LNG)		This unit accumulated 23,140 hours by Oct 2000.
UTC Power	Seiko Epson	400 kW PAFC	Ina, Japan	Seiko Epson's Quartz Devise Division facilities	Jan. 2000				
UTC Power	Toftlund Fjernvarmevær, Naturgas Syd Sønderjyllands	200 kW PC25A PAFC	Toftlund, Denmark	District Heating System	Nov. 1992				Europe's first fuel cell.
UTC Power	PreussenElektra, E.ON, MAINOVA AG, Hamburg Gas Consult	200 kW PC25C PAFC	Frankfurt, Germany	Bergen-Enkheim public swimming pool	Nov. 1998				Provides heat to the pool. The fuel cell contribution to peak thermal power is only 17 %, but makes up more than 50 % of all heat requirements over the year.
UTC Power	Hamburg Gas Consult	200 kW PC25C PAFC	Bargteheide, Germany		1998		Natural gas		
UTC Power	Ruhrgas AG, Stadtwerke Bochum	200 kW PC25A PAFC	Dorsten, Germany	Testing at Rohrgas, followed by two-year field test at Stadtwerke Bochum	Testing began Sep. 1992; field test started Feb. 1994	Completed			Tested over 40,000 hours.
UTC Power	Thyssengas, Stadtwerke Duren	200 kW PC25A PAFC	Duren, Germany	Thyssengas facility—one year; Stadtwerke Duren—four years	Oct. 1992	Decommissioned after 5 years of operation	Natural gas		Tested at Thyssengas facility in Duisburg before moving to Duren.
UTC Power	Sydkraft AB	200 kW PAFC	Bara, Sweden		Jun. 1992				
UTC Power	Imatran Voima Oy	200 kW PC25A PAFC	Tavastehus, Finland	Vanaja Power Plant	Dec. 1992				
UTC Power	Azienda Consorzio Servizi Reno, SEABO Spa, Ansaldo CLC	200 kW PC25A PAFC	Bologna, Italy	SEABO thermorefrigeration plant	Apr. 1993				Grid connected, operating concurrently with ENEL network electric network. Residual heat used in thermo-refrigeration plant. Operated over 17,490 hours.
UTC Power	Austria Ferngas, Wiengas, EVN	200 kW PC25A PAFC	Vienna, Austria	Tested at Austria Ferngas for 1.5 years, then moved to District Heating Plant of EVN	Installed Jan. 1993 by Austria Ferngas, transferred to EVN in 1994	1997			
UTC Power	HEAG-AG	200 kW PC25A PAFC	Darmstadt, Germany		Jun. 1993		Natural gas		
UTC Power	Equitable Resources	200 kW PC25 PAFC	Pittsburgh, Pennsylvania	Presbyterian Nursing Home			Natural gas		
UTC Power	Peoples' Gas & Light	200 kW PC25 PAFC	Chicago, Illinois	Div. of Street & Meter Repair			Natural gas		

UTC Power	Jersey Central Power & Light, GPU	200 kW PC25 PAFC	Morristown, New Jersey	AT&T Research Laboratory			Natural gas		
UTC Power	National Fuel Gas.	200 kW PC25 PAFC	Buffalo, New York	Rieffler Concrete			Natural gas		
UTC Power	Rochester Gas & Electric	200 kW PC25 PAFC	Rochester, New York	Rochester Institute of Technology			Natural gas		
UTC Power		200 kW PC25 PAFC	Ulsan, South Korea	Hotel			Natural gas		
UTC Power	Ansaldo Ricerche, ENEA, Milan Municipal Energy Co	1.3 MW PAFC with reformer	Milan, Italy				Natural gas		Located in Bicocca "technology zone". Hydrogen produced by the reformer is used for a hydrogen vehicle fueling station located on-site, with extra hydrogen used to fuel a 500 kW MCFC plant.
UTC Power	RuhrGas, Stadtwerke Bochum	200 kW	Bochum, Germany	Stadtwerke Bochum facility	1989				Tested for almost 40,000 hours.
UTC Power	Tokyo Electric Power Co.	200 kW PC25 PAFC	Japan	Shibaura DHC	Mar. 1989	Completed March 1997			This unit accumulated 45,333 hours by Oct. 2000.
UTC Power	Virginia Power, Virginia Natural Gas, Gas Research Institute	40 kW PAFC CHP	Norfolk, Virginia	Old Dominion University, 600 bed dormitory	1986	Concluded	Natural gas		Grid connected. Supplied hot water to the dormitory.
UTC Power	Tokyo Electric Power Co., Toshiba Corporation	4.5 MW PAFC	Ichihara, Japan	Goi Station of Tokyo Electric Power Co	1983				
Zentrum für Sonnenenergie- und Wasserstoff-Forschung (ZSW) (Center for Solar Energy and Hydrogen Research)	Gaz de France, The National Polytechnical Institute of Lorraine (INPL)	500 W PEM	Nancy, France	Agronomy laboratory at the National Polytechnical Institute of Lorraine	Feb. 2003				ZSW is developing fuel cells in the 2 W - 20 kW range.
ZTEK Corp.	Black Country Housing and Community Services Group	4.4 kW Alkaline fuel cell	Telford, UK (England)	Black Country Housing and Community Services Group house	Announced Jan. 2005		Compressed hydrogen		UK's first fuel cell house.
ZTEK Corp.	Connecticut Clean Energy Fund, The Renewable Resources Group, LLC	25 kW SOFC	Rocky Hill, Connecticut	Dinosaur State Park	Installed	Two-year demonstration with possible extension	Natural gas		Provides some of the park's baseload power and heating/ air conditioning for the Visitor Center. This system was previously demonstrated at the Tennessee Valley Authority's Huntsville, AL site.
ZTEK Corp.	Tennessee Valley Authority	25 kW SOFC	Huntsville, Alabama	Huntsville Utilities	1998	2000	Natural gas		
ZTEK Corp.	Electric Power Research Institute	1 kW SOFC	Japan	EPRI facility	1994	1995	Laboratory gas mixture partially comprised of bottled hydrogen		Proof of concept. Operated for over 16,000 hours.
Unknown		Alkaline fuel cell	Totara Valley, New Zealand		2004				Wind-Hylink-AFC demonstration project. Uses wind generator and electrolyzer to produce hydrogen, which is carried by pipeline to power the fuel cell.
Unknown	U.S. Army Corps of Engineers Construction and Engineering Research	Fuel cell	Yellowstone National Park, Montana	Yellowstone National Park	Planned		Canola oil		

	Laboratory (CERL)								
Unknown	RWE Fuel Cells, Ahaus	5 kW fuel cell with gas turbine	Germany	Ahaus facility	Planned				Ahaus utility will integrate the fuel cell/turbine hybrid unit into their local heating system.
Unknown	State of Florida, unspecified investor-owned utility and college	Fuel cell	Florida	Unspecified college residential complex	Planned				
Unknown	Shizuoka Resources, Shizuoka Gas Co.	Fuel cell	Shizuoka, Japan	School lunch center	2006	Planned	Mixture of natural gas and garbage biogas		
Unknown	Kawasaki City	200 kW PAFC	Kawasaki, Japan	Tama Hospital	2005 or 2006	Planned	Town gas		Cogeneration system
Unknown	Osaka Gas Co. Takenaka Corp.	200 kW PAFC	Osaka, Japan	Umeda Center Building					Operated for over 40,000 hours. Provides 5% of the power requirements for the 80,000 square meter building. Co-generated waste heat is used to supply 70% of the hot water needs.
Unknown	Japan Energy Corp.	About one-hundred-fifty 700 W PEM units			Announced Jun. 2005		Liquefied petroleum gas (LPG)		About 30 fuel cells will be installed in the Kanto area in the first year. About 150 total will be installed within three years.
Unknown	Northern Alberta Institute of Technology (NAIT)	5 kW SOFC	Edmonton, Canada	NAIT Power Engineering Laboratory	Planned for early 2005				For demonstration, education and research.
Unknown	Arakawa Ward	PEM	Arakawa Ward, Japan	Haketa-daini Primary School	Sept. 2005		Kerosene		
Unknown	Tokuyama Corp, Yamaguchi Prefecture	1 kW fuel cell	Yamaguchi Prefecture, Japan	Tokuyama Works		Mar. 2005	Hydrogen produced at the factory		
Unknown	Idemitsu Kosan Co, Corona Co.	1 kW PEM	Sanjo, Japan	Corona Co.'s New Energy Research Center	Apr. 2005				Test system.
Unknown	Idemitsu Kosan Co, Corona Co.	1 kW PEM	Sanjo, Japan	Idemitsu Kosan's Central Research Laboratory	Apr. 2005				Test system.
Unknown	Osaka Gas, Urban Renaissance Agency (URA)	Twenty-one fuel cells	Japan		2005				Twenty-one fuel cells will be delivered to URA by Osaka Gas. URA will demonstrate 80-100 fuel cells by various manufacturers.
Unknown	Sharp Corp.	10 kW PEM/solar cell hybrid electric system	Japan	Yokkaichi Technical High school	Mar. 2005				Combined power capacity of 10 kW. Generated power is stored in a battery and used for emergency power. Exhaust heat is supplied to the greenhouse.
Unknown	Sekisui House Corporation, Tokyo Gas	Seven PEM units	Mosashino, Japan	Residential	Sales began Apr. 2005		Natural gas		Seven out of 31 homes will be equipped with stationary PEMs. The home price will be higher than other homes in the development, but heating and electric costs will be lower.
Unknown	Yamaguchi Prefecture	Three 1 kW and one 5 kW fuel cell CHP units	Syunan, Japan		Jan. 2005	One year test	Pipeline-supplied hydrogen		
Unknown		Fuel cell	Strasbourg, France		July 2004				Fuel cell operates in tandem with a photovoltaic unit.
Unknown	Kandenko	3.7 kW PEM	Saitama, Japan	Kandenko's Urawa dormitory	Oct. 2004				Cogeneration system (power and heat).

									Produces 25% of the facilities power.
Unknown	Nippon Oil, Sekisho	PEM	Tsukuba, Japan	Company residence	Plan announced Aug. 2004		Liquefied petroleum gas (LPG)		Cogeneration system
Unknown	New Energy Foundation	Two 1 kW PEM units	Tokyo and Oita Prefecture, Japan	Condominiums	Aug. 2004		Pipeline-supplied hydrogen		
Unknown	Tokyo Gas	1 kW PEM	Japan	Minami-Senju Techno Station model house	May 2004				The house is open to the public.
Unknown	Hokkaido University, Japan Steel Works, Ministry of Land, Infrastructure and Transport	Fuel cell	Hokkaido, Japan		Jun. 2004		Biogas from livestock waste		
Unknown	Mie Prefecture, Yuasa Corp., Cosmo Oil, Fuji Electric, Advanced Technology Co., Showa Shell Sekiyu K.K., Idemitsu Kosan Co., Mie Prefecture, Mie University	PEM units of less than 10 kW	Yokkaichi, Kawagoe or Kusunoki, Japan	Residential	2004	2006	Liquefied petroleum gas (LPG)		This is the first step for "Establishment of the Center for FC Related Industries in Northern Part of the Prefecture". Three companies expressed their intention to participate and Toshiba IFC has been formally nominated.
Unknown	Nippon Oil Corp., Gas Bureau of city of Sendai	1 kW PEM	Sendai, Japan	"Gas Salon" of Gas Bureau	Feb. 2004				
Unknown	Nippon Oil, Matsumura Bussan Co.	5 kW PEM	Kanazawa, Japan	Osada gasoline service station	Apr. 2004				
Unknown	Niigata Prefecture	700 W PEM	Nagaoka, Japan		Mar. 2004	Dec. 2004			Data to be transmitted automatically to the Industrial Research Institute of Niigata Prefecture.
Unknown	Nippon Oil Corp.	1 kW PEM	Shizuoka, Japan	Suzuyo Irie Dormitory	Aug. 2003	One-year test			Testing e simulated conditions of a ordinary home and to verify the energy savings.
Unknown	Nippon Oil Corp.	Multiple 1 kW PEM units	Various locations, Japan	Public and company residences	Beginning Jan. 2003		Liquefied petroleum gas (LPG)		At least 80 demonstration units will be installed at locations including Yokohama, Niigata prefecture, Shizuoka prefecture, Tokyu Construction Co, Mitsubishi Estate Co, official residence of the Yokohama mayor, and others. Nippon Oil will follow operating conditions at the a monitoring center in Yokohama Refinery and deal with troubles 24 hours
Unknown	Nippon Oil Corp.	PEM	Shimizu, Japan	Gas station	Dec. 2002		Naphtha		Demonstration unit of fuel cell cogeneration system operating on naphtha fuel.
Unknown	Nippon Oil Corp.	1 kW PEM	Kanagawa Prefecture, Japan	Kanagawa Dome Theater	Jul. 2002		Liquefied petroleum gas (LPG)		Fuel cell cogeneration system.
Unknown	Shikoku Electric Power Co.	PEM CHP	Japan	Shikoku Research Institute, Inc.	Feb. 2002	Mar. 2004			Verification testing.
Unknown	Tokyo Electric	Two 3 kW PEM units	Japan	Tokyo Electric Power Technology Development Center	Mar. 2001		Liquefied petroleum gas (LPG), town gas		Purchased for testing
Unknown	Mitsubishi, Kansai Electric Power Co.	Two 200 kW units	Japan		Installed between 1993-1995				

Unknown	Toshiba	50 kW fuel cell unit	Japan		1984				
Unknown	Hokkaido Gas, Hokkaido University	PEM	Japan	Hokkaido University					Demonstration and testing. This unit will be replaced by a newer model 1 kW unit.
Unknown	Hokkaido Gas, Japan Gas Association	PEM	Sapporo, Japan	Residence					
Unknown	MVV Energie	Fuel cell	Mannheim, Germany	Rehabilitated apartment complex					Provides heat and power. "Three liter home" project goal is to reduce the building's annual energy requirements for heat to an equivalent of just three liters of heating oil per square meter of living space.
Unknown	City of Mesa, AZ, Arizona National Guard	Two 200 kW fuel cell units	Marana, Arizona	Western Army National Guard Aviation Training Site	Installed				Power reliable supply to flight simulator. Fuel cells were donated by a military base and a research facility.
Unknown	Tokyo Gas, Toshiba	1 MW fuel cell cogeneration plant	Japan	Tokyo Gas site					Installed by Toshiba
Unknown	TKG Consulting, San Diego Gas and Electric	Fuel cell	San Diego, California	TKG Consulting office			Natural gas		The group is aiming for LEED certification and also has 5 kW photovoltaic power installation.
Unknown	Mulheim Hotel	3 kW PEM	Mulheim, Germany	Mulheim Hotel					
Unknown	Hartford Gas (now Connecticut Natural Gas)	Fuel cell	Connecticut	Experimental home powered by a fuel cell	1969	Completed	Natural gas		

Notice: For additional information or comments on Fuel Cells 2000's charts, contact Jennifer Gangi at: jennifer@fuelcells.org.

ATTACHMENT H2
ELECTRIC POWER RESEARCH INSTITUTE
“STATUS & TRENDS FOR STATIONARY FUEL CELL POWER SYSTEMS”
2005

**Electric Power Research Institute
“Status & Trends for
Stationary Fuel Cell Power Systems”**

2005



ELECTRIC POWER
RESEARCH INSTITUTE

Status and Trends for Stationary Fuel Cell Power Systems

Dan Rastler

Technical Leader, Distributed Energy Resources
Program

drastler@epri.com

650-855-2521




Fuel Cell Types and Comparisons

Fuel Cell Type and Scale in kW	Electrical Efficiency, LHV	Current and {Projected} Cost \$/kW	Status
PAFC 200 – 1,000	40%	\$ 4000 {3000}	Commercial
MCFC 250-1000	44-55%	\$4000 {1200}	Pre-commercial
PEMFC 5 kW to 1,000	32-42%	\$2000-\$4000 {900}	Pre-production trials Under development
SOFC 5 kW – 1,000	40-55%	\$20,000 {700-900}	Beta trials Under development

Benchmarking Fuel Cells

Range of Total Energy Cost (\$/kWh)

Includes Capital, Financing, Fuel, and Maintenance (Net of Recovered Waste Heat)



Copyright © 2005 Electric Power Research Institute, Inc. All rights reserved

EPRI

ATTACHMENT H3
FUEL CELL TODAY
“FACTS & FIGURES”
(NO DATE)

Fuel Cell Today

“Facts & Figures”

(no date)



FUEL CELL TODAY

Opening doors to fuel cell commercialisation

Facts & Figures

Fuel Cell Today – Education Kit 9

The history of the fuel cell can be traced back to the nineteenth century. Since then the development and the usage of fuel cells in various applications have come a long way.

- William Grove invented the fuel cell in 1839.
- In 1959, Francis Bacon demonstrated a 5kW alkaline fuel cell.
- General Electric invented proton exchange membrane fuel cells in the 1950s.
- The first "commercial" use of fuel cells was by NASA in the 1960s during the Apollo space missions. Alkaline fuel cells have flown over 100 missions and operated for over 80,000 hours in spacecraft operated by NASA.
- The US Navy has used fuel cells in submarines since the 1980s.
- Fuel cell buses are running in several cities around the world. Currently, the largest fuel cell bus demonstration programme is the European Union backed CUTE project (Clean Urban Transport for Europe).
- All major car manufacturers already have prototypes on the road; the first few fuel cell cars have been leased to customers.
- Iceland is planning to convert its fishing fleet from diesel engines to hydrogen fuel cells as part of a national project to create a fossil fuel free economy.
- Many companies are hoping to produce their first semi-commercial models of fuel cell cars during the next decade. However, it is very unlikely that fuel cell cars will be produced in real commercial numbers before 2010.
- Companies have started to bring real fuel cell products to the market in 2004. In the future, portable direct methanol fuel cells could power mobile phones, laptops and cameras.
- Small stationary fuel cells, including residential units, have become available in small numbers from late 2004. They should become available to the public soon afterwards.
- Most commercial fuel cells are currently PEM (Proton Exchange Membrane) fuel cells, which operate at around 80°C.
- Solid oxide fuel cells operate at 800-1000°C.
- The main types of fuel cells are: alkaline, direct methanol, molten carbonate, phosphoric acid, proton exchange membrane and solid oxide.
- A fuel cell is around 60 per cent efficient at converting fuel to power, double the efficiency of an internal combustion engine.

ATTACHMENT H4
UNIVERSITY OF CALIFORNIA, BERKELEY
“FUEL CELL SYSTEM ECONOMICS: COMPARING THE COSTS OF GENERATING
POWER WITH STATIONARY AND MOTOR VEHICLE PEM FUEL CELL SYSTEMS”
APRIL 2004

University of California, Berkeley

**“Fuel Cell System Economics: Comparing
the Costs of Generating Power with
Stationary and Motor Vehicle PEM Fuel
Cell Systems”
(pages 1 and 113)**

April 2004

**FUEL CELL SYSTEM ECONOMICS: COMPARING THE
COSTS OF GENERATING POWER WITH STATIONARY
AND MOTOR VEHICLE PEM FUEL CELL SYSTEMS**

UCD-ITS-RP-04-21

April 2004

by

Timothy Lipman
University of California, Berkeley
Berkeley, CA 94720
Ph (510) 642-4501
Fax (530) 642-0910
telipman@socrates.berkeley.edu

with

Jennifer L. Edwards

and

Daniel M. Kammen

Institute of Transportation Studies
One Shields Avenue
University of California
Davis, California 95616
Tel: 530-752-0247 Fax: 530-752-6572
<http://www.its.ucdavis.edu/>
email: itspublications@ucdavis.edu




Fig. 6. California medium office building site load shape patterns.




Fig. 7. Residential and office building hot water load profiles source: (Arthur D Little, 1994).

10. Economic variable input assumptions

This analysis is intended to estimate the potential costs of using stationary and automotive fuel cells for distributed power in the 2010–2015 timeframe. Thus, we analyze cases with fuel cell system capital costs that are much lower than present-day capital costs for PEM fuel cells, which we believe to be on the order \$3000–4000 per kW³. PEM fuel cells are an emerging technology

³PEM fuel cell manufacturing costs are proprietary, and even selling prices are difficult to determine at present because systems in the 5–250 kW size range are not yet commercially available.


that is just beginning to become commercial after a decade of intense development throughout the 1990s, and costs are expected to fall sharply as production volume and manufacturing experience grow. However, manufacturing costs and sale prices of PEM fuel cells and natural gas reformers in higher volume production are uncertain, owing to several variables that can affect manufacturing cost. These variables include production volume, product design, material choices and material utilization rate improvements, production process development, and cost vs. efficiency tradeoffs with regard to fuel cell system operation (e.g., higher efficiency levels can be maintained with larger and more expensive fuel cell stacks).

**U.S. Department of Energy
and JEA**

**Joint Study
Clean Coal Technology
Technical Report Number 22
“The JEA Large-Scale CFB Combustion
Demonstration Project”
(Cover Page and pages 1 – 3)**

March 2003

CLEAN COAL TECHNOLOGY



The JEA Large-Scale CFB Combustion Demonstration Project

Executive Summary

The Clean Coal Technology (CCT) Demonstration Program is a government and industry co-funded effort to demonstrate a new generation of innovative coal utilization processes in a series of facilities built across the country. These projects are carried out on a commercial scale to prove technical feasibility and provide the information required for future applications.


The goal of the CCT Program is to furnish the marketplace with a number of advanced, more efficient coal-based technologies that meet strict environmental standards. Use of these technologies is intended to minimize the economic and environmental barriers that limit the full utilization of coal.

To achieve this goal, beginning in 1985, a multi-phased effort consisting of five separate solicitations was administered by the U.S. Department of Energy's (DOE) National Energy Technology Laboratory (NETL). Projects selected through these solicitations have demonstrated technology options with the potential to meet the needs of energy markets while satisfying relevant environmental requirements.

Part of this Program is the demonstration of advanced electric power generation technologies, including circulating fluidized bed combustion (CFB). This report discusses the JEA Large-Scale CFB Combustion Demonstration Project which is testing the CFB concept using inexpensive feedstocks such as high sulfur coal and coal fuel blends.

The project is being conducted at the Northside Generating Station of JEA (formerly Jacksonville Electric Authority) in Jacksonville, Florida, and JEA is the project Participant. Foster Wheeler Energy Corporation, the technology supplier, is an additional team member.

To date, the JEA Project has operated CFBs to generate electricity at a scale larger than previously demonstrated. The boilers at the Northside Station are the largest CFBs in the world. Power production on coal feed meets the target goal of 297.5 MWe gross (265 MWe net). Emissions of atmospheric pollutants are below the stringent limits set for this project. A two-year demonstration test program is planned to evaluate the operational and environmental performance of the CFB system.



JEA plant with CFB boilers in center and fuel storage domes in background

The JEA Large-Scale CFB Combustion Demonstration Project

Background

The Clean Coal Technology (CCT) Demonstration Program, sponsored by the U.S. Department of Energy (DOE) and administered by the National Energy Technology Laboratory (NETL), has been conducted since 1985 to develop innovative, environmentally friendly coal utilization processes for the world energy marketplace.

The CCT Program, which is co-funded by industry and government, involves a series of demonstration projects that provide data for design, construction, operation, and technical/economic evaluation of full-scale applications. The goal of the CCT Program is to enhance the utilization of coal as a major energy source.


Fluidized Bed Combustion

Among the technologies being demonstrated in the CCT Program is fluidized bed combustion (FBC). FBC is an advanced electric power generation process that minimizes the formation of gaseous pollutants by controlling coal combustion parameters and by injecting a sorbent (such as crushed limestone) into the combustion chamber along with the fuel. In the

JEA project described in this report, the fuel is coal or a blend of coal and petroleum coke. Crushed fuel mixed with the sorbent is fluidized on jets of air in the combustion chamber. Sulfur released from the fuel as sulfur dioxide (SO_2) is captured by the sorbent in the bed to form a solid compound that is removed with the ash. The resultant by-product is a dry, benign solid that can be disposed of easily or used in agricultural and construction applications. More than 90% of the sulfur in the fuel is captured in this process.

An additional environmental benefit of FBC power plants results from their relatively low operating temperature, which significantly reduces formation of nitrogen oxides (NO_x).

Five FBC demonstration projects are included in the CCT Program under Advanced Electric Power Generation: (1) the JEA Large-Scale CFB Combustion Demonstration Project, (2) the Nucla CFB Demonstration Project, (3) the Tidd PFBC Demonstration Project, (4) the McIntosh Unit 4A PCFB Demonstration Project, and (5) the McIntosh Unit 4B Topped PCFB Demonstration Project. This Topical Report describes the JEA project.



Panoramic view of JEA site

Project Description

The JEA Large-Scale CFB Combustion Demonstration Project consists of installing a new 300-MWe (297.5-MWe nameplate) atmospheric circulating fluidized bed (ACFB) boiler in conjunction with an existing turbine generator at JEA's Northside Generating Station (Unit 2) in Jacksonville, Florida. In parallel with this project, JEA replaced the Unit 1 oil/gas fired boiler with an identical ACFB unit. Unit 1 continues to use its existing turbine generator.

These boilers are designed to burn fuel blends consisting of coal and petroleum coke,

thereby greatly reducing plant fuel costs and maintaining fuel flexibility while meeting stringent emissions limits. These units are the world's largest ACFB boilers.

In this project, the existing Unit 2 turbine generator was upgraded, and other existing balance-of-plant (BOP) equipment and systems were either upgraded or replaced. The existing turbine building and some piping systems were re-utilized.

Steam from the combustor is used in an existing General Electric 297.5-MWe (nameplate) turbine to produce electric power. With parasitic power consuming 32.5 MWe, net power output is 265 MWe.

JEA Large-Scale CFB Combustion Demonstration Project

Project Participants and Responsibilities

JEA

- Overall project and construction management
- Funding (\$234 million)
- Environmental permitting

U.S. DOE

- Funding (\$75 million)
- Technology support/dissemination

Foster Wheeler Energy Corporation (Clinton, NJ)

- Design and supply of CFBs
- Engineering/procurement/construction for the extended boiler island, including CFBs, scrubbers, fabric filters, stack, and fuel and limestone preparation facilities

Black & Veatch (Kansas City, MO)

- Design of BOP and materials handling systems

Zachry Construction Corporation (San Antonio, TX)

- Procurement and construction of BOP system upgrades and replacements, including condensate, feedwater, and circulating water systems; water and wastewater treatment systems; distributed control system; station electric distribution system; and substation equipment

Fluor Global Services (Irvine, CA)

- Upgrade/uprate of turbine/generators
- Procurement and construction of materials handling systems, including continuous ship unloader (purchased by JEA), pier, conveyors, fuel storage domes, and fuel and limestone reclaim equipment

Project Participant

The Participant is JEA, who provided the host site. An additional team member is Foster Wheeler Energy Corporation (FWEC), who supplied the ACFB technology.

Fuel Supply

Coal feed is an Eastern bituminous coal having a sulfur content of 3.39 wt%. Petroleum coke having a sulfur content as high as 8% also serves as feed, either alone or in combination with coal.

Project Scale

The JEA project represents a scale-up of previous ACFB installations. The Nucla project, completed in 1992, had a capacity of 100 MWe (net) and the Tidd project, completed in 1995, had a capacity of 70 MWe (net). The McIntosh Unit 4A project (currently on hold) is designed for a capacity of 137 MWe (net), and the McIntosh Unit 4B project (also on hold) has a design capacity of an additional 103 MWe (net). At a nominal design capacity of 300 MWe gross (265 MWe net), the JEA project is the largest scale demonstration of FBC technology to date.

Jacksonville

A half century after Ponce de Leon claimed Florida for Spain, Frenchman Jean Ribault sailed into the St. Johns River to establish Fort Caroline for French Huguenot settlers. Within several years, Spanish forces from the military garrison at St. Augustine would destroy this small settlement.

In 1821, Spain ceded Florida to the United States, and one year later Isaiah D. Hart surveyed the village. He named it Jacksonville for General Andrew Jackson, the territory's first military governor.

Today, located at the crossroads of two transcontinental highways, Jacksonville is one of the Nation's largest cities in land area (841 square miles), a major port, site of Navy bases, and home of the NFL Jacksonville Jaguars, a Mayo Clinic medical center, and the Jacksonville Zoological Gardens. The area boasts beautiful beaches and numerous waterways for over 700,000 residents.

ATTACHMENT I2
THE UNIVERSITY OF CHICAGO
“THE ECONOMIC FUTURE OF NUCLEAR POWER”
AUGUST 2004

The University of Chicago

“The Economic Future of Nuclear Power”

August 2004

THE ECONOMIC FUTURE OF NUCLEAR POWER



A Study Conducted at The University of Chicago

August 2004



**Table 1-1: Summary Worksheet for Busbar Cost Comparisons, \$ per MWh, with
Capital Costs in \$ per kW, 2003 Prices**

Technology	Sandia Model GenSim		SAIC Model Power Choice			Scully Capital Report			EIA – AEO 2004	
	r=10%	r=15%	Debt r = 8%; Disc r = 8%	Debt r =10%; Disc r = 8%	Debt r =10%; Disc r = 10%	r = 8%	r = 10%	r = 10%	Debt r =10%; Eq = 15%; Disc r = 10%	Debt r =8%; Eq = 10%; Disc r = 10%
Nuclear (capital cost)	51 (1,853)	83 (1,853)								
Legacy Nuclear (capital cost)			65 (2,000)	70 (2,000)	77 (2,000)					
EIA Reference Case, New Nuclear (capital cost)									63 to 68 (1,752 to 1,928)	
EIA Advanced Technology Case, New Nuclear (capital cost)									43 to 53 (1,080 to 1,555)	
ABWR (capital cost)			53 (1,600)	50 (1,600)	55 (1,600)					
AP 1000 (capital cost)			49 (1,365)	46 (1,365)	51 (1,365)	36 (1,247)	40 (1,247)	44 (1,455)		
Pebble Bed Modular Reactor (PBMR) (capital cost)			40 (1,365)	41 (1,365)	45 (1,365)					
Gas-Turbine Modular Helium Reactor (GT- MHR) (capital cost)			39 (1,126)	39 (1,126)	43 (1,126)					
Advanced Fast Reactor (AFR) (capital cost)			57 (1,126)	57 (1,126)	64 (1,126)					
Coal (capital cost)	37 (1,094)	48 (1,094)	43 (1,350)	44 (1,350)	49 (1,350)					38 (1,169)
Gas Turbine Combined Cycle (capital cost)	35 (472)	40 (472)	38 (590)	38 (590)	40 (590)					41 (466)
Gas Combustion Turbine (capital cost)	56 (571)	68 (571)								
Solar- Photovoltaic	202	308								
Solar-Thermal	158	235								
Wind	55	77								

Chapter 5. FINANCING ISSUES

Summary

As a prelude to considering energy scenarios for the future, which will be the capstone of the study in Chapters 9 and 10, this chapter develops the basic financial model used to analyze nuclear energy economic viability. Features of the U.S. tax system are introduced. Risk is considered in some depth. To provide a benchmark for the energy scenarios for the future that will contemplate alternative nuclear energy policies, the model is used to estimate the sensitivity of economic viability to uncertainties in the no-policy case.

Taxes

Recognition that nuclear energy plants will be owned and operated by utilities or other private providers requires introducing tax treatment of debt and equity, deduction of depreciation from taxable income with effects of different allowed depreciation schedules, effects of special tax provisions, and effects of inflation on taxes.

Risk

The perceived risk of investments in new nuclear facilities is widely appreciated to contribute to the risk premium on any new nuclear construction. Principal sources of risk are the possibilities that new plants will exceed original cost estimates and that construction delays will escalate costs. In this chapter guidelines from the corporate finance literature are used to specify likely relationships between project risk and risk premiums for corporate bonds and equity capital. Risk premiums have an important influence on the economic competitiveness of nuclear energy. A 3 percent risk premium is used for the first few plants.

No-Policy Scenarios

In using the financial model to study sensitivity to uncertainties, an overnight cost range for new nuclear plants of \$1,200 to \$1,800 per kW is used, based partly on the three technologies discussed as being realistic in Chapter 3. Given the capital cost range, the LCOE of new nuclear plants in the absence of policies is from \$53 to \$71 per MWh, with a 7-year construction time. The range is lower at \$47 to \$62 per MWh with a 5-year construction time. Costs remain outside the range of competitiveness with coal and gas, which have LCOEs of \$33 to \$41 per MWh and \$35 to \$45 per MWh, respectively.


The nuclear LCOE for the most favorable case, \$47 per MWh, is close but still above the highest coal cost of \$41 per MWh and gas cost of \$45 per MWh. Longer debt terms and longer plant life span reduce nuclear LCOEs, but still do not bring them into the competitive range. The impact of construction delays is large, particularly if a 2-year delay occurs after all outlays have been made—capable of making the nuclear LCOE range from \$61 to over \$76 per MWh. These no-policy results provide benchmarks indicating the extent to which policies to be considered in Chapters 9 and 10 are needed to reduce nuclear LCOEs.

ATTACHMENT I3
U.S. DEPARTMENT OF ENERGY
NATIONAL ENERGY TECHNOLOGY LABORATORY
“COMBUSTION – FLUIDIZED-BED COMBUSTION, PROGRAM OVERVIEW”
(NO DATE)

**U.S. Department of Energy
National Energy Technology Laboratory**

**“Combustion - Fluidized-Bed Combustion,
Program Overview”**

(no date)



THE ONLY U.S. NATIONAL LABORATORY DEVOTED TO FOSSIL ENERGY TECHNOLOGY

ABOUT NETL

KEY ISSUES & MANDATES

ONSITE RESEARCH

TECHNOLOGIES

Oil & Natural Gas Supply
Coal & Power Systems
 Clean Coal Demonstrations
 Environmental & Water
 Gasification
 Turbines
 Combustion Technologies
 Fuel Cells
 FutureGen
 Advanced Research
 Contacts
Carbon Sequestration
Hydrogen & Clean Fuels
Technology Transfer

ENERGY ANALYSES

SOLICITATIONS & BUSINESS

CAREERS & FELLOWSHIPS

NEWSROOM

CONTACT NETL



Combustion - Fluidized-Bed Combustion Program Status

Advanced FBC Technology Demonstrations

Two Clean Coal Technology Demonstration Program projects are providing valuable information: one at Jacksonville, Florida, which is demonstrating circulating atmospheric FBC by 2000; and the other expected to be sited soon, which will demonstrate commercial-scale advanced GFBCC technology.

- ▶ [FBC Overview](#)
- ▶ [FBC Goals](#)
- ▶ [FBC Status](#)
- ▶ [FBC Roadmap](#)
- ▶ [FBC Benefits](#)

Pressurized Fluidized-Bed Combustion System

First-generation PFBCs are operated with 100 percent of the solid fuel conversion happening in the fluidized bed. Since PFBCs have a maximum operating temperature around 870°C (1600°F), the gas turbine operates at a relatively inefficient temperature rating.

Depending on the manufacturer and/or site-specific conditions, the fluidized bed could be either the circulating- or bubbling-bed type. First-generation PFBC systems now undergoing commercial demonstration are capable of achieving efficiencies up to 42 percent.

Pressurized circulating fluidized bed (PCFB) partial gasifiers used in CHIPPS and GFBCC have been tested in pilot scale.

Topping Combustor

Second-generation APFBC systems require the development and demonstration of a commercially viable topping combustor with suitable fuel flexibility, flame stability, and NO_x emissions. These need to accept hot APFBC syngas, and hot vitiated air. Tests of a multi-annular swirl burner (MASB) have demonstrated good flame stability and NO_x performance. Systems testing of the MASB was performed at the Wilsonville Power Systems Development Facility (PSDF) during 1998. With the integration of building-block technologies under development --hot gas cleanup, advanced gasifier technology, and turbine systems-- efficiencies for PFBC systems will eventually exceed 50 percent.

CHIPPS and GFBCC systems use moderate-temperature syngas, and ordinary gas turbine combustion air. Any gas turbine already developed for syngas operations should work.

Combustion By-Products Utilization

FBC economics improve as combustion by-products are reduced or high-value uses are found. The goal is to reduce solid by-products from FBC systems without compromising sulfur capture or producing in-bed sintering. Variability of limestone will be assessed as a factor in the volume of solid by-products from FBC systems without compromising sulfur capture or producing in-bed sintering. Variability of limestone will be assessed as a factor in the volume of solid by-products, and a limestone utilization model will be developed to optimize sulfur capture and minimize the volume of solid by-products. Expanding markets for FBC by-products will reduce net operating costs and landfill requirements. FBC ash will be characterized for conventional applications, such as agriculture, mine remediation, and structural fill, and high-value uses of solid by-products from FBC systems will be developed.

Hot Gas Filtration

In APFBC systems, ceramic filters are used that operate in the 1400°F to 1550°F temperature range to filter both syngas and vitiated air. Ceramic filter element durability, filter-ash bridging, and system costs are critical development issues being addressed. The challenge of producing candle-filter elements able to operate for more than three years is being met by enhancing monolithic filter elements made of various materials, such as clay-bonded silicon-carbide, porous-sintered metal, and alumina-mullite oxide. A number of composite-type ceramic and iron aluminide-type filter elements are also undergoing development. Filter cost can be reduced by 25 percent through optimized design of the system; filter vessel cost is about 75 percent of the total system cost.

CHIPPS and GFBCC use moderate temperature metallic syngas filters which have been successfully demonstrated.

Solids Transfer


Improved handling of hot-solids material --feed and withdrawal, flow control, and fines removal-- can achieve cost reduction and reliability improvement. A feasibility study of a rotary high-pressure dry-solids feeder will evaluate the system's potential for reducing capital and operating costs. An advanced system for simpler and more reliable transfer of hot char from the carbonizer to the fluid-bed combustor will be tested for its ability to decrease materials flow and handling-related downtime by at least 50 percent.

Sulfur/Alkali Removal

Alkali in hot-gas streams can limit gas turbine life and reliability. The severity of the alkali problem must be determined. Gas turbine tolerance to alkali, the amount of alkali released, the effect of filter-cake characteristics, and the ability to control alkali will be assessed. Also, experiments to determine sulfur removal and trace-contaminant levels in the gas stream during integrated demonstration will be conducted.

Cofiring of Biomass and Industrial By-Products

Existing fluidized beds are suitable for cofiring, but to date, only 8 of the 100 units in the U.S. cofire material. Cofiring of biomass and industrial by-products could evolve into a standard practice as a near-term means to reduce CO₂ emissions. R&D data on heavy metals are needed so that environmental approval and permits for cofiring projects are not any more difficult to obtain than for single-fuel solid-combustion units.



In a second-generation PFBC system, the coal is partially gasified in a pressurized fluidized-bed carbonizer. The carbonizer produces a low-Btu gas and a char. The char is burned in a PFBC. Both gases are cleaned by hot-gas filtration, and the carbonizer's syngas is burned in a topping combustor to heat the PFBC flue gas. This hot flue gas drives a gas turbine to generate power. The flue gas leaving the gas turbine then generates steam in a heat recovery steam generator, which is used to generate additional power. At the Wilsonville Power Systems Development Facility (PSDF), an advanced second-generation PFBC now demonstrates high efficiency at pilot scale.

Second-generation PFBC is also called "advanced circulating pressurized fluidized bed combined cycle," or "APFBC."

ATTACHMENT J
GASIFICATION TECHNOLOGIES CONFERENCE
“THE RELIABILITY OF INTEGRATED GASIFICATION COMBINED CYCLE POWER
GENERATION UNITS”
OCTOBER 2005

**Gasification Technologies Conference
San Francisco**

**“The Reliability of Integrated Gasification
Combined Cycle (IGCC) Power
Generation Units”**

October 2005

The Reliability of Integrated Gasification Combined Cycle (IGCC) Power Generation Units

Christopher Higman, Syngas Consultants Ltd.

Sal DellaVilla and Bob Steele, Strategic Power Systems, Inc. (SPS)

Gasification Technologies Conference,

San Francisco, October 11th, 2005

Introduction

The Integrated Gasification Combined Cycle (IGCC) has for many years been regarded as a technology with considerable potential for power production from coal and other fuels at high energy efficiency and with greatly reduced emissions in comparison with conventional combustion technologies. The inherent ability to capture CO₂ with substantially reduced energy and cost penalties has increased the focus on IGCC in the context of various CO₂ reduction strategies.

Beginning in the mid-1990's, a number of IGCC plants were built and operated so that a base of experience has begun to develop. These plants have confirmed the exceptionally low (SO_x, NO_x, particulate matter and, if required, mercury) or less toxic (waste water and slag) emissions from these plants. They have also confirmed the expectations of improved thermal efficiency, even if parallel advances in other technologies have not allowed this to be translated into the competitive advantage originally contemplated.

However, the reliability and availability of demonstration IGCC's has not been as high as desired by the power industry or as actually achieved by gasification plants operating in the chemical and other industries. The success of IGCC in realising its potential is therefore also dependant on establishing the reasons for this reduced reliability and taking appropriate steps to improve it.

This paper presents two interlinked projects aimed at supporting the improvement of IGCC reliability. The one project comprises the extension of SPS's existing ORAP (Operational Reliability Analysis Program) reliability, availability and maintainability (RAM) tracking technology from its existing base in natural gas open and combined cycle operations into IGCC.

The other project is using the extended ORAP database to evaluate performance data from existing plants. The initial work has concentrated on evaluating public domain data on the performance of gasification based power and chemical plants. This is being followed up by plant interviews in some 20 plants to verify and expand the database on current performance.

The paper will report on the current status of the projects and present analysis of some important issues already recognized.

1. Current Perceptions

1.1 The Importance of Reliability

Reliability is every bit as important to the economic success of a plant as the capital and operating expenditure (CAPEX and OPEX). This is illustrated in Figure 1. The cost of electricity (COE) was calculated for a base case (100%) and then sensitivities for the efficiency, the CAPEX and the availability performed. The efficiency has been plotted as heat rate and the availability as outage so that all plots have a positive slope. The graph shows that the cost of electricity is more sensitive

to availability and CAPEX than to the heat rate. Note that that all calculations were made with a constant fuel price.




Figure 1 Relative Influence of Availability, Investment and Efficiency on the Cost of Electricity

The data in Table 1 shows availability and capacity factors for various type of power plant in North America over the period 1998 to 2002. The data has been gathered through the Generating Availability Data System (GADS) operated by the North American Electricity Reliability Council (NERC). As can be seen from these figures, availabilities for conventional PC boilers run just below 87%, natural gas fired CC plant at just under 90%.

Table 1 NERC GADS Data 1998-2002 [from DellaVilla, 2004]

	Service Factors (%)	Capacity Factors (%)	Availability Factor (%)
Gas-fired boilers	46.7	28.9	86.3
Oil-fired boilers	42.2	27.6	86.3
Coal-fired boilers	82.3	69.9	86.9
Aero-derivatives	4.6	2.9	91.9
Single Cycle GTs	5	4.3	91.1
Combined Cycle GTs	61.3	49.9	89.9

Looking at Table 2, which shows data evaluated from the ORAP database, one can see that the best performing group of natural gas fired combustion turbines achieve an availability of 94.5%. These figures put the 90% target typically required for IGCCs into perspective. This target is clearly ambitious, which as a development goal is certainly correct. On the other hand the data from existing plants operating with conventional technologies shows that it may not be an absolute criterion for every application.

ATTACHMENT K1
U.S. DEPARTMENT OF ENERGY
ENERGY INFORMATION ADMINISTRATION
“ASSUMPTIONS TO THE ANNUAL ENERGY OUTLOOK”
MARCH 2006

**U.S. Department of Energy
Energy Information Administration**

**“Assumptions to the Annual Energy
Outlook”**

**DOE/EIA-0554(2006)
(Cover Page and Page 73)**

March 2006

Report #:DOE/EIA-0554(2006)

Release date: March 2006

Next release date: March 2007

Assumptions to the Annual Energy Outlook

2006



U.S. DEPARTMENT OF ENERGY
ENERGY INFORMATION ADMINISTRATION

Table 38. Cost and Performance Characteristics of New Central Station Electricity Generating Technologies

Technology	Online Year	Size (mW)	Leadtime (Years)	Base Overnight Costs In 2005 (\$2004/kW)	Contingency Factors		Total Overnight Cost In 2005 (2004 \$/kW)	Variable O&M (\$2004 mills/kWh)	Fixed O&M (\$2004/kW)	Heatrate In 2005 (Btu/kWh)	Heatrate nth-of-a-kind (Btu/kWh)
					Project Contingency Factor	Technological Optimism Factor					
Scrubbed Coal New ⁷	2009	600	4	1,167	1.07	1.00	1,249	4.18	25.07	8,844	8,600
Integrated Coal-Gasification Combined Cycle (IGCC) ⁷	2009	550	4	1,349	1.07	1.00	1,443	2.65	35.21	8,309	7,200
IGCC with Carbon Sequestration	2010	380	4	1,873	1.07	1.03	2,065	4.04	41.44	9,713	7,920
Conv Gas/Oil Comb Cycle	2008	250	3	556	1.05	1.00	584	1.88	11.37	7,196	6,800
Adv Gas/Oil Comb Cycle (CC)	2008	400	3	532	1.08	1.00	575	1.82	10.65	6,752	6,333
ADV CC with Carbon Sequestration	2010	400	3	1,021	1.08	1.04	1,147	2.68	18.12	8,613	7,493
Conv Combustion Turbine ⁶	2007	160	2	388	1.05	1.00	407	3.25	11.03	10,842	10,450
Adv Combustion Turbine	2007	230	2	367	1.05	1.00	385	2.89	9.59	9,227	8,550
Fuel Cells	2008	10	3	3,787	1.05	1.10	4,374	43.64	5.15	7,930	6,960
Advanced Nuclear	2013	1000	6	1,744	1.10	1.05	2,014	0.45	61.82	10,400	10,400
Distributed Generation -Base	2008	2	3	791	1.05	1.00	831	6.49	14.60	9,650	8,900
Distributed Generation -Peak	2007	1	2	951	1.05	1.00	998	6.49	14.60	10,823	9,880
Biomass	2009	80	4	1,659	1.07	1.02	1,809	3.13	48.56	8,911	8,911
MSW - Landfill Gas	2008	30	3	1,443	1.07	1.00	1,544	0.01	104.03	13,648	13,648
Geothermal ^{6,7}	2009	50	4	2,100	1.05	1.00	2,205	0.00	75.00	32,173	35,460
Conventional Hydropower ⁶	2009	500	4	1,320	1.10	1.00	1,452	3.20	12.72	10,338	10,338
Wind	2008	50	3	1,091	1.07	1.00	1,167	0.00	27.59	10,280	10,280
Solar Thermal ⁷	2008	100	3	2,589	1.07	1.10	3,047	0.00	51.70	10,280	10,280
Photovoltaic ⁷	2007	5	2	3,981	1.05	1.10	4,598	0.00	10.64	10,280	10,280

¹Online year represents the first year that a new unit could be completed, given an order date of 2005.

²The technological optimism factor is applied to the first four units of a new, unproven design, or regulatory structure. It reflects the demonstrated tendency to underestimate actual costs for a first-of-a-kind unit.

³Overnight capital cost including contingency factors, excluding regional multipliers and learning effects. Interest charges are also excluded. These represent costs of new projects initiated in 2005.

⁴O&M = Operations and maintenance.

⁵Combustion turbine units can be built by the model prior to 2007 if necessary to meet a given region's reserve margin.

⁶Because geothermal and hydro cost and performance characteristics are specific for each site, the table entries represent the cost of the least expensive plant that could be built in the Northwest Power Pool region, where most of the proposed sites are located.

⁷Capital costs are shown before investment tax credits are applied.

Sources: The values shown in this table are developed by the Energy Information Administration, Office of Integrated Analysis and Forecasting, from analysis of reports and discussions with various sources from industry, government, and the Department of Energy Fuel Offices and National Laboratories. They are not based on any specific technology model, but rather, are meant to represent the cost and performance of typical plants under normal operating conditions for each plant type. Key sources reviewed are listed in the 'Notes and Sources' section at the end of the chapter.

ATTACHMENT K2
INSTITUTO NACIONAL DE INVESTIGACIONES NUCLEARES
“LEVELIZED COSTS FOR NUCLEAR, GAS AND COAL FOR ELECTRICITY, UNDER
MEXICAN SCENARIO”
2004

**Instituto Nacional de Investigaciones
Nucleares
México**

**“Levelized Costs for Nuclear, Gas and Coal
for Electricity, under the Mexican
Scenario”**

(3 Pages - Not Consecutive)

2004

Levelized costs for nuclear, gas and coal for Electricity, under the Mexican scenario.

Javier C. Palacios, Gustavo Alonso, Ramón Ramírez, Armando Gómez, Javier Ortiz, Luis C. Longoria.

Instituto Nacional de Investigaciones Nucleares
México

palacios@nuclear.inin.mx, galonso@nuclear.inin.mx .

ABSTRACT

In the case of new nuclear power stations, it is necessary to pay special attention to the financial strategy that will be applied, time of construction, investment cost, and the discount and return rate. The levelized cost quantifies the unitary cost of the electricity (the kWh) generated during the lifetime of the nuclear power plant; and allows the immediate comparison with the cost of other alternative technologies.

The present paper shows levelized cost for different nuclear technologies and it provides comparison among them as well as with gas and coal electricity plants. For the calculations we applied our own methodology to evaluate the levelized cost considering investment, fuel and operation and maintenance costs, making assumptions for the Mexican market, and taking into account the gas prices projections.

The study also shows comparisons using different discount rates (5% and 10%), and some comparisons between our results and an OECD 1998 study. The results are in good agreement and shows that nuclear option is cost competitive in Mexico on the basis of levelized costs.

1- The Mexican Scenario

The globalization and liberalization processes that are taking place in the most advanced economic systems are establishing new behavior rules in the energy systems and, in particular, in the electricity market. The energy policy continues being defined by the smallest cost, considering the limits established by the environmental norms and regulations. However, the experiences registered in pioneer countries in the liberalization of the electric market have granted a great relevance to other objectives, among those that highlight the guarantee and supply quality and the stability of the production costs, and they have been the cause of important modifications in the current strategic valuation of the different energy sources, especially the nuclear.

The operation of the nuclear power stations has been improving until reaching marks of excellence that transforms them into a valuable asset for the electric systems. This technology has incorporated improvements coming from developments in other areas (computer science, materials) and a very solid infrastructure of legislation. Several countries have been developed new programs and designs in order to increase the nuclear capacity of the current operating nuclear power stations. Enlarging the useful life of the plants from 40 to 60 years and increasing their generation capacity from 100% to 105% (this is the case of Mexico) and in some cases up to 120%.

Currently, Mexico has one nuclear power plant located in Laguna Verde, in the state of Veracruz Mexico, starting commercial operation in 1990. This NPP has 2 BWR units with a combined capacity of 1365 MWe. This power represents 3.08% as of March 2004 of the total installed capacity in the country [1]. The Mexican government through Comisión Federal de Electricidad (CFE; Electricity Commission), is the utility owning and operating the nuclear power reactor. This power plant produced in the first three months of 2004 5.23% of the total electricity in the country. Figure 1 shows the distribution of the electricity production in Mexico as of March 2004.

Although in the past the nuclear option was no competitive in Mexico, at present this situation is changing, due to different factors. One of them is the high price of fossil fuel in Mexico mainly

In Figure 2 we present the total energy generation cost for all the scenarios considered in this paper.




Figure 2. Total energy cost for Nuclear, Gas and Coal Plants

As was discussed in section 3, the variation in the total cost of electricity generation of the different plants as a function of the variation of fuel price is more drastic in the case of gas, and coal fuel compared with uranium. As an example, we can see from figure 3 that if the fuel prices increase 100%, this would result in a 16.21% increase in the cost of nuclear generation, 55.44% in the case of coal generation and 79.01% for natural gas.




Figure 3. Variation in the total cost of electricity generation as a function of the variation of fuel price

Finally in figure 5 we show the results for the levelized cost of electricity generation at different discount rates.




Figure 4. Levelized cost at different discount rates for electricity generation.

5. Comparison between ININ results and OCDE and Finish studies.

As we mentioned in section 2 we use two recent studies to compare the obtained levelized costs. The first of them was carried out in 1998 and it was elaborated by the OECD [2], which projected the generation costs for the period 2005-2010. The second study was elaborated by the Finnish government in 2002 [3] to compare the electricity generation costs by means of gas, coal and nuclear.

For comparison purposes we use a discount rate of 5%. From the results obtained in this study and those reported by the OECD and Finland, we can observe the reduction of the levelized cost since the OCDE results. Also we can see that in the three studies it is demonstrated that the most economic option in generation for levelized cost is the nuclear one. The results of the comparison are shown in figure 5.

6. Final Discussion

The investment cost of the nuclear power stations could seem relatively high, but they can be redeemed in a reasonable time due to their variable costs (especially that of fuel) is reduced and is not vulnerable in front of fluctuations of the market. With these characteristics, the nuclear power stations are good to produce load-base electricity, it means, working the 24 hours of every day of the year.

ATTACHMENT K3
CALIFORNIA ENERGY COMMISSION
“MOSS LANDING POWER PLANT PROJECT”
AUGUST 1, 2007

California Energy Commission
“Moss Landing Power Plant Project”

August 1, 2007



PROJECT INFO

[Project Fact Sheet](#)

[Project Location
\(Maps\)](#)

[Project Photos](#)

COMPLIANCE PROCEEDINGS

[Announcements,
Documents,
Notices & Other Info
Relating to the
Compliance
Proceeding](#)
(Updated: 8/7/7)

[Docket Log](#)

ORIGINAL PROCEEDINGS

[Announcements,
Hearings,
Orders, Notices &
Workshops](#)
(Updated: 3/20/01)

[Documents,
Decisions and
Transcripts
In This Siting Case](#)
(Updated: 8/13/01)

[Docket Log](#)

[Schedule
For This Case](#)

[Proof of
Service List](#)

[List of
Reviewing Agencies](#)

[Commission
News Releases](#)

PARTICIPATION

[Public Adviser's Office](#)

[Guide to
Public Participation
In Siting Cases](#)

MOSS LANDING POWER PLANT PROJECT

Docket Number: 99-AFC-4C (Compliance Proceeding)
99-AFC-4 (Application For Certification)

Committee Overseeing This Case:

William J. Keese, Chairman
Presiding Member

Michal C. Moore, Commissioner
Associate Member

Hearing Officer: Gary Fay

Key Dates

- October 25, 2000 -- Energy Commission approves project.
- August 11, 1999 -- AFC deemed "data adequate" by the Energy Commission.
- May 7, 1999 -- Application for Certification (AFC) filed with Energy Commission.

General Description of Project

On May 7, 1999, Duke Energy Moss Landing LLC filed an Application for Certification (AFC) seeking approval from the California Energy Commission (Energy Commission) to construct and operate the proposed 1,060-megawatt (MW) Moss Landing Power Plant Project. The project is proposed to be located at the existing Moss Landing Power Plant site that was previously operated by PG&E for about 50 years. This site is located at the intersection of Highway 1 and Dolan Road, east of the community of Moss Landing near the Moss Landing Harbor.

The project, as proposed by Duke Energy, consists of replacing the existing electric power generation Units 1-5, (a total of 613 MW built in the 1950s and shut down in 1995), with two 530 MW, natural gas-fired, combined cycle, units. Each combined cycle unit consists of two natural gas fired combustion turbine generators (CTGs), two unfired heat recovery steam generators (HRSGs) and a reheat, condensing steam turbine generator (STG). Each combined cycle unit will use seawater for once-through cooling. Duke Energy also proposes to upgrade each of the existing Units 6 and 7 by 73 MW.

Duke also plans to remove eight 225-foot stacks and ten large oil tanks.

[Link to Duke Energy's \(project proponent\) Web site.](#)

Energy Commission Facility Certification Process

The Energy Commission is the lead agency under the California Environmental Quality Act (CEQA) and has a certified regulatory program under CEQA. Under its certified program, the Energy Commission is

ANNOUNCEMENTS

August 1, 2007
Possible approval of a petition to amend the existing certificate to permit the addition of a temporary pilot desalination plant to the project site.
(See the Petition on Compliance Page)

[Overview of
Siting Process](#)

[Title 20
Calif. Code of
Regulations](#)

[Commission
Siting Division](#)

[Acronyms
Used in Siting Cases](#)

exempt from having to prepare an environmental impact report. Its certified program, however, does require environmental analysis of the project, including an analysis of alternatives and mitigation measures to minimize any significant adverse effect the project may have on the environment.

For Questions About This Siting Case Contact:

Donna Stone
Compliance Project Manager
California Energy Commission
Facilities Siting Division
1516 Ninth Street, MS 2000
Sacramento, CA 95814
Tel: (916) 654-4745
Fax: (916) 654-3882
E-mail: dstone@energy.state.ca.us

Internet E-Mail List Server will be available at:
[mosslanding @ energy.ca.gov](mailto:mosslanding@energy.ca.gov)
(See [List Server Page](#) for subscription info.)

For Questions About Participation In Siting Cases Contact:

Public Adviser
California Energy Commission
1516 Ninth Street, MS-12 Sacramento, CA 95814
Phone: 916-654-4489
Toll-Free in California: 1-800-822-6228
E-mail: PAO@energy.state.ca.us

News Media Please Contact:

Claudia Chandler
Assistant Executive Director
Media & Public Communications Office
Phone: 916-654-4989
E-mail: mediaoffice@energy.state.ca.us

[| Homepage](#) | [Commission Info](#) | [Licensing Main Page](#) | [Calendar](#) | [Site Index](#) | [Search Site](#) | [Links](#) | [Contact Us](#) |

ATTACHMENT L
BIG STONE II
“PLANT PROJECT OVERVIEW”
2006

Big Stone II

“Plant Project Overview”

2006

Big Stone II

Home

Search

[Power plant»](#)[Transmission line»](#)[News/Media»](#)[Public meetings»](#)[Participants»](#)[Contact us»](#)

Plant project overview

[Power plant project > Project overview](#)

Power plant project

[Project overview](#)[Environmental impact](#)[Economic impact](#)[Project timeline](#)[Questions and answers
about the plant](#)

Transmission project

Seven local utilities have signed agreements to build a second electric generating unit on the site of the existing Big Stone Plant near Milbank, South Dakota.

Based on increasing demand and studies that point to a potential energy shortfall, seven companies began working together in 2003 to resolve their mutual need for baseload energy. Studies included:

- a cost and performance comparison of state-of-the-art coal combustion and emissions technologies in various size ranges,
- estimates of air emission rates, and
- an evaluation of designs to provide a reliable quantity of cooling water from Big Stone Lake while minimizing impacts and costs.

The result of these efforts was an agreement to develop an electric generating plant that would be:

- approximately 630 megawatts;
- coal-based;
- designed with the best available emission-control technologies at the time of purchase, and
- available to serve the customers of the investing utilities.

The seven utilities

Based in Minnesota, North Dakota, and South Dakota, the seven participating electric utilities serve more than 2.3 million customers in five states in the Upper Midwest.

[Otter Tail Power Company](#), lead developer
[Central Minnesota Municipal Power Agency](#)
[Great River Energy](#)
[Heartland Consumers Power District](#)
[Missouri River Energy Services](#)
[Montana-Dakota Utilities Co](#)
[Southern Minnesota Municipal Power Agency](#)

Project timeline

While plant construction is contingent on approval of all necessary permits, this is the proposed timeline:

- Initial announcement - October 2004
- Permitting and public comment - Early 2005 through third quarter 2006
- Construction begins - Mid-2008
- Plant commercially available - Mid-2011 to mid-2012

Project impact

Big Stone II represents the largest investment of private and public capital ever made in South Dakota. The electricity it produces will flow to customers in Minnesota, North Dakota, South Dakota, and Iowa. During its four-year construction period, the plant would employ an average of 625 construction workers, with a peak workforce of 1,500. Once online, Big Stone II would likely employ 35 to 40 operational workers at the site. [Learn more about the project's economic impact.](#)

Project cost

Early cost estimates for the power plant were at about \$1 billion, with an



additional \$200 million for the transmission line project. These costs estimates have increased, however, largely due to higher costs for construction materials and labor. Other factors include market pricing by vendors as well as design changes made by project participants to increase output and improve efficiency. Based on the most recent design refinements, the project, including transmission, is expected to cost \$1.6 billion. Efforts continue to maximize efficiencies and minimize costs.

Advantages of the proposed site


The South Dakota site has important economic advantages. Otter Tail Power company has operated Big Stone Plant, which it owns jointly with Montana-Dakota Utilities and NorthWestern Energy, for more than 25 years. The site contains much of the expensive infrastructure needed to support a second unit. A well-trained staff is in place, as are a railroad line and a water supply. In addition to having some existing transmission corridors, it's close to load centers where demand is high.

This reduces—by tens of millions of dollars—the expense of building additional transmission from sites farther removed from load centers. Some transmission upgrades or new construction will be necessary to deliver the power generated by the proposed new plant at Big Stone. Also, it is possible that the transmission upgrades could provide opportunities for the development of renewables, such as water, wind, and biomass. The transmission studies will first determine what is needed for the plant, and then what would be available for renewable or other generation. For the transmission project, two corridor options now appear most beneficial. In addition, while Big Stone II's primary fuel source would be Powder River Basin coal, biomass is also being investigated.


The Big Stone site was selected after Burns & McDonnell conducted a study to identify a preferred site, along with alternate sites, for a new coal-fired generating unit.

Site details


The existing Big Stone Plant is two miles northwest of Big Stone City, which is near Milbank, South Dakota. The new generator will be located adjacent to the 450-megawatt Big Stone Plant, which began operating in 1975 on the 2,200-acre site.



Location map:



Preliminary artist's rendering:



[Contact us](#) | [Privacy policy](#) | © |



ATTACHMENT M1
HILL & ASSOCIATES
“ECONOMIC BENEFITS OF A COAL-FUELED POWER PLANT”
(REPORT PREPARED FOR PEABODY ENERGY)
(NO DATE)

Hill & Associates

**“Economic Benefits of a Coal-Fueled Power
Plant Compared to Natural Gas”
(report prepared for Peabody Energy)**

(no date)

ECONOMIC BENEFITS OF A
COAL-FUELED POWER PLANT
COMPARED TO NATURAL GAS

PREPARED FOR
PEABODY ENERGY

Economic Benefits of a Coal-Fueled Power Plant Compared to Natural Gas

Summary

Peabody Energy has requested Hill & Associates, Inc to evaluate the potential economic benefits of constructing and operating a large coal-fueled power plant in the Midwest, compared to developing and operating a plant of similar size fueled by natural gas. This report presents the results of our analysis, which shows that coal has a much more favorable economic impact. The numbers presented are representative of the state-wide economic impacts that would be associated with development of a new power plant in any of the several mid-western states that produce coal.

The construction and operation of a coal-fueled power plant in a coal-producing state will bring major economic benefits in terms of jobs created and sales for regional businesses. Constructing a coal-fueled power plant and the associated mine will increase business volume at the state level by \$4.5 billion dollars and result in over 20,000 job-years of new employment. Operating the mine and plant over the estimated 40 – 50 year life will lead to an additional \$439 million dollars of business volume in the state each year and create almost 2,300 permanent jobs. Much of the economic activity and many of the new jobs will be created indirectly as a result of the expenditures made directly at the power plant and mine.

By contrast, a new gas-fueled power plant of the same size would have only about one third of coal's favorable impact on the economy and regional employment during the construction phase. Gas would also have a less favorable impact during the operating life of the plant because most of the dollars spent for operating the gas plant would probably go out-of-state for purchases of the natural gas. New jobs created by operation of the gas plant would amount to only 38% of the jobs created by the new coal plant and mine.

In addition to the advantages coal offers in terms of project-related spending and employment, the use of coal for power generation also provides broader economic benefits. Because fuel is a major element in the cost of electricity and coal is so much cheaper than gas, the use of coal-fueled generation provides a secure base of low-cost generation for all of the consumers and businesses in the region. Furthermore, low electricity costs will help attract other new business. Appendix A shows the current cost of coal to a mine-mouth power plant in the Midwest is likely to be about \$0.70 per million Btu. Based upon the typical performance pattern of an underground mine, these costs are expected to remain approximately constant over the life of the mine. Also, the annual forecast of U.S. steam coal prices prepared by Hill & Associates, Inc. predicts declining coal prices in the Midwest. In contrast, gas prices have recently been higher and are expected to remain far above coal. According to the 2002 edition of the Annual Energy Outlook of the U.S. Energy Information Agency (EIA), the average price for natural gas delivered to U.S. utilities during 2000 and 2001 was almost \$4.50 per million Btu. Because the EIA and others forecast the price of gas will average around \$3.50 per million Btu (in constant dollars) over the next 20 years, it appears that coal will continue to be a much lower cost fuel than natural gas. These fuel price differences account for the fact that states generating power

from gas have the highest electricity prices and states using coal have the lowest electricity prices.

There will also be non-economic benefits derived from a new coal plant. While gas generally offers environmental advantages over coal, it should be noted that a modern coal plant with a high thermal efficiency and equipped with state-of-the-art pollution control equipment will, because of its low operating costs, displace the output of old, small and less well-controlled coal plants that can be significant sources of pollution. The UFEM/NPM model used by Hill & Associates to model coal use and electricity dispatch across the U.S. consistently shows that modern coal plants in the Midwest will force some of the smaller/older plants to be shut down. Thus the environment will gain along with the economy.

Background and Approach to the Study

This study was prepared by Hill & Associates, Inc., a consulting firm specializing in energy industry economics and markets, with the assistance of the University of West Virginia's Bureau of Business and Economic Research. The two options analyzed were:

1. A 1,500 megawatt coal-fueled power plant equipped with the latest technology for emissions control. The coal for this plant would be supplied by a new mine sited near the power plant.
2. A plant of the same size burning natural gas and utilizing combined cycle technology. In all likelihood, a plant of this size would have to use gas produced outside the region and piped in via the interstate pipeline system.

The study team developed estimates of power plant construction and operating costs and employment from sources such as the Department of Energy, the International Energy Agency, the Electric Power Research Institute and internal company files of mine costs and staffing. These cost estimates were then fed into the IMPLAN model, a widely-used model that provides estimates of the full statewide impact of changes in economic inputs. The IMPLAN model calculates direct, indirect and induced economic activity. These measures capture the "ripple" effect that occurs when one element of new economic activity creates new employment and spending in related areas as well as additional employment and spending in economic sectors not directly related to the one where the initial new expenditures are made. The cost and staffing estimates used as inputs to the IMPLAN model are summarized in Appendix A.

Estimates of Economic Impacts

The results of the IMPLAN model analysis are shown in Tables 1 - 6 below. Tables 1 and 2 show the economic impacts of a coal-fueled power plant and the mine needed to supply the coal. Tables 3 and 4 show a similar analysis for a gas-fueled plant of the same size. Tables 5 and 6 summarize the differences. In each case, the first table of a pair shows the total life-of-

project numbers for the impact of the construction work and the second table shows the annual impacts (in millions of dollars per year and in equivalent jobs) of plant operations.

Before discussing the results as presented in the tables, it will be useful to review a few definitions of the major terms used in the study. These are:

- *Direct Economic Impacts* – The first round of spending on the project.
- *Indirect Impacts* – The second and later rounds of spending by the contractors and sub-contractors.
- *Induced Impacts* – Later rounds of business volume related to the consumption spending by the construction and operating employees of the project.
- *Business Volume* – Sales (or spending).
- *Employment* – Permanent jobs in the operation phase and "Job-years" during the construction phase (a job-year being one person employed for 12 months, two employed for 6 months, etc.)
- *Employee Compensation* – Wages and salaries plus employers' contributions for social security, unemployment insurance, workers' compensation, medical insurance, etc.

A review of the tables below shows the economic benefits of a coal-fueled plant are much greater than gas for the following three reasons:

1. The construction cost for a coal-fueled plant is almost three times that of a plant of the same size fueled by natural gas.
2. Employment at a coal plant and the mine that supplies it will be more than six times the employment at a gas plant.
3. Most of the money spent on fuel supply, which is a power plant's largest operating cost, stays in-state for a coal plant but goes out of the state for a gas plant.

Table 1
Economic Impact of a 1500 Mw Coal-Fueled Plant & Mine - Construction Phase

Type of Impact	Direct Impact	Indirect and Induced Impacts	Total Impact
Business Volume (Sales in millions)	\$2,113	\$2,411	\$4,524
Employment (Job-Years)	6,240	14,060	20,300
Employee Compensation (millions)	\$624	\$391	\$1,015
Assorted State Taxes (Based on Kentucky – in millions)	--	--	\$57.7

Table 2
Economic Impact of a 1500 Mw Coal-Fueled Plant & Mine - Operations Phase

Type of Impact	Direct Impact	Indirect and Induced Impacts	Total Impact
Business Volume (Sales in million \$/year	\$153.7	\$285.7	\$439.4
Employment (Jobs)	538 (1)	1,735	2,273
Employee Compensation (million \$/yr)	\$11.4	\$57.3	\$68.7
Assorted State Taxes (millions)	--	--	\$4.0

1. The 395 employees needed at the coal mine are included here in the "direct impact" column because the power plant and mine will be built and operated together as part of a new business venture.

Table 3
Economic Impact of a 1500 Mw Gas-Fueled Plant - Construction Phase

Type of Impact	Direct Impact	Indirect and Induced Impacts	Total Impact
Business Volume (Sales in millions)	\$750	\$855	\$1,605
Employment (Job-Years)	1,350	4,620	5,970
Employee Compensation (millions)	\$135	\$136	\$271
Assorted State Taxes (millions)	--	--	\$15.5

Table 4
Economic Impact of a 1500 Mw Gas-Fueled Plant - Operations Phase

Type of Impact	Direct Impact	Indirect and Induced Impacts	Total Impact
Business Volume (Sales in million \$/year)	\$52.2 (1)	\$92.3	\$144.5
Employment (Jobs)	78	790	868
Employee Compensation (million \$/year)	\$5.8	\$23.3	\$29.1
Assorted State Taxes (millions)	--	--	\$1.7

Note 1. If the majority of expenditures on the natural gas plant were spent in-state, the direct economic impact of the gas plant would be \$327.4 million per year. However, an estimated \$275.2 million is likely to be spent out-of-state for natural gas, an expenditure that will have no impact within the state.

Table 5
Additional Impacts of Coal (Compared to Gas) - Construction Phase

Type of Impact	Direct Impact	Indirect and Induced Impacts	Total Impact
Business Volume (Sales in millions)	\$1,363	\$1,556	\$2,919
Employment (Job-Years)	4,890	9,440	14,330
Employee Compensation (millions)	\$489	\$255	\$744
Assorted State Taxes - millions	--	--	\$42.2

Table 6
Additional Impacts of Coal (Compared to Gas) - Operations Phase - Excluding Out-of-State Purchases of Natural Gas

Type of Impact	Direct Impact	Indirect and Induced Impacts	Total Impact
Business Volume (Sales in million \$/year)	\$101.5	\$193.4	\$294.9
Employment (Jobs)	460	945	1,405
Employee Compensation (million \$/year)	\$5.6	\$34.0	\$39.6
Assorted State Taxes - million \$/year	--	--	\$2.3

In summary, these tables show that:

APPENDIX A

POWER PLANT and LOCAL COAL MINE COST SUMMARY

COAL-FUELED PLANT (PC with wet scrubber)

GAS-FUELED PLANT (Combined Cycle)

SIZE (MW)	1,500	1,500
CAPACITY FACTOR	90.00%	90.00%
ANNUAL GENERATION - MWHrs	11,826,000	11,826,000
TOTAL CAPITAL COST (Millions)	\$2,000.0	\$750.0
OF WHICH:		
Equipment Purchase	45.00% \$900.0	60.00% \$450.0
Labor & Material	34.00% \$680.0	23.00% \$172.5
Buildings, Eng., Land	14.00% \$280.0	8.00% \$60.0
Sales Taxes, Interest, Other	7.00% \$140.0	9.00% \$67.5
Total Coal Plant Capital	100.00% \$2,000.0	Total Gas Plant Capital 100.00% \$750.0

POWER PLANT OPERATING COSTS:

	\$/MWHr	\$/Year (Millions)		\$/MWHr	\$/Year (Millions)
Fuel @\$0.70/mmBtu *	\$7.00	\$82.8	@\$3.50/mmBtu	\$24.64	\$291.4
O&M, Labor, Services, Other	\$6.00	\$71.0		\$4.67	\$55.2
Total Coal Plant Oper. Cost	\$13.00	\$153.7	Total Gas Plant Oper. Cost	\$29.31	\$346.6

*\$12.52 cost + \$4.00 Depreciation and return on capital = \$16.52/ton profitable price = \$0.70/mmBtu

APPENDIX A – (Continued)

COAL REQUIREMENT

Tons/yr Required 5,011,017

COAL MINE CAPITAL AND PRODUCTION COSTS

TOTAL CAPITAL COST (Millions) \$125.3
At \$25/annual ton

OF WHICH:

Equipment Purchase	50.00%	\$62.6	50% in-state
Labor	39.00%	\$48.9	
Engineering & Land	2.00%	\$2.5	
Sales Taxes, Interest, Other	9.00%	\$11.3	
Total	100.00%	\$125.3	

COAL MINE PRODUCTION COSTS (all coal supplied by local mine):

	\$/Ton	\$/Year (Millions)
Labor & Benefits	\$4.15	\$20.8
Supplies & Parts	\$4.20	\$21.0
State & Local Taxes, Royalties	\$1.92	\$9.6
Admin. Costs	\$0.95	\$4.8
Fed Taxes	\$1.30	\$6.5
Total	\$12.52	\$62.7

EMPLOYMENT:

	<u>PLANT</u>	<u>COAL:</u> <u>MINE</u>	<u>TOTAL</u>	<u>GAS:</u> <u>PLANT</u>
Construction (Job-Years) (at \$100,000/const. Worker yr)	5800	439	6239	1350
Operations (No. Employees)	143	395	538	78

ATTACHMENT M2
PORTLAND GENERAL ELECTRIC
“FREQUENTLY ASKED QUESTIONS ABOUT PORT WESTWARD POWER PLANT”
2005

Portland General Electric

“Frequently Asked Questions about Port Westward Power Plant”

2005



Find a Job

Go

Search PGE:

Go

Sign In

Portland General
ElectricUpdate
Your InfoView
Your BillPay
Your BillGet Your
Bill OnlineAccount
BalanceStart, Stop
or Move
[PGE Home](#) >> [About PGE](#) >> [Current Issues](#)

About PGE

Current Issues

[Pricing Facts & Figures](#)
[Future Power Supply](#)
[Klondike II](#)
[Port Westward](#)
[Boardman Plant](#)
[Air Emissions](#)
[Job Opportunities](#)
[News Room](#)
[Corporate](#)
[Information](#)
[Wholesale Activities](#)
[Regulatory Affairs](#)

Port Westward

Announcements and progress reports about construction of Port Westward Power Plant

■ [Construction update](#)

Construction is near completion at PGE's new Port Westward Generating Plant, which will begin commercial operations in spring of 2007. It will be the most efficient natural gas-fired generator of its type in the West, providing enough electricity to power about 300,000 homes.

Port Westward will be powered by a Mitsubishi "G1" class combustion turbine, which is more efficient than the more common "F" class technology.

The new Port Westward Power Plant is Columbia County's first major industrial construction project in recent years. At the height of construction in the summer of 2006, up to 400 people were working at the site, many of them residents of nearby communities.

- [Project timeline](#)
- [Construction firms working on Port Westward](#)
- [Photo and video gallery](#)
- ["Frequently Asked Questions"](#)

The Port Westward site is located at 81566 Kallunki Road in Clatskanie. As we continue with construction, you may have questions, so PGE has created a special phone line just for this project. Feel free to call our toll-free number, 866-337-9905 any time of day, and a staff person will call you back as soon as possible.

Port Westward

Port Westward will be the most efficient plant of its type in the West.

It will produce enough power for about 300,000 homes.

Commercial operations will begin in spring of 2007.

Port Westward is sited next to PGE's Beaver Generating Plant, which has been in operation since 1974.

A new radial or generation lead has been built to PGE's Trojan switchyard to move the power to PGE's distribution system.

Port Westward will provide about 17 permanent jobs.

Port Westward is just one part of PGE's overall resource strategy in its [Integrated Resource Plan](#).

[PGE Home](#) [Site Map](#) [Contact Us](#) [Privacy](#) [Legal Notice](#) [En Español](#)


ATTACHMENT M3
PORTLAND GENERAL ELECTRIC
NEWS ROOM
“PORTLAND GENERAL ELECTRIC ANNOUNCES PORT WESTWARD PLANT
AVAILABLE FOR COMMERCIAL GENERATION”
(JUNE 12, 2007)

Portland General Electric

News Room

“Portland General Electric Announces Port Westward Plant Available For Commercial Generation”

June 12, 2007



The image shows the top portion of the Portland General Electric website. On the left is a sidebar with a grid of links: About PGE, Current Issues, Job Opportunities, News Room, News Archives, Corporate Information, Wholesale Activities, and Regulatory Affairs. The main header area contains a navigation bar with links like 'Find a Job', 'Search PGE:', and 'Sign In'. Below this is a row of service links: 'Update Your Info', 'View Your Bill', 'Pay Your Bill', 'Go Paperless', 'Account Balance', and 'Start, Stop or Move'. The Portland General Electric logo is also present. Below the header, a breadcrumb trail reads 'PGE Home >> About PGE >> News Room'.

News Room

June 12, 2007

Portland General Electric Announces that its Port Westward Plant is Available for Commercial Generation

Portland, Ore. — Portland General Electric Company (NYSE: POR) today announced that its Port Westward Generating Plant, a new 400 megawatt natural gas-fired power plant located near Clatskanie, Ore., is available for commercial generation. The plant is owned and operated by PGE, and is the first major new generating plant placed into service by the company since 1995. It has the capacity to serve approximately 300,000 homes.

"Port Westward is an important resource that will help meet our customers' current and future energy needs," said Peggy Fowler, CEO and President of PGE. "We're extremely pleased to have brought it online, on-budget and just in time to help meet customer demand during the hot summer months."

Fowler noted that the project required close collaboration between PGE, Black & Veatch Construction, Inc., Mitsubishi Power Systems, Inc., and Oregon regulators. Black & Veatch served as general contractor for the project. Mitsubishi Heavy Industries, Ltd. manufactured and supervised installation of the plant's turbines.

Port Westward will help reduce PGE's dependence on power purchases in the wholesale energy market. The plant serves as an important component of the company's diversified portfolio of energy resources, complementing new wind generation that PGE expects to bring online later this year with completion of the first phase of its Biglow Canyon wind farm in Sherman County. The Port Westward plant's state-of-the-art G-class turbine makes it one of the most efficient combined-cycle natural gas-fired generating plants in the United States.

The plant was completed on budget under fixed-price contracts, with final construction costs expected to be between \$280 million and \$290 million. Certification of commercial availability came just one month later than the May 2007 date that was initially projected when contracts were signed and engineering work started in October 2004. The plant successfully completed all required performance and functional testing before PGE took possession.

Earlier this year, the Oregon Public Utility Commission approved a price increase of 2.8 percent, to take effect when Port Westward became fully operational. The increase covers capital and operating costs of the new plant. PGE has submitted a tariff filing with the OPUC requesting that the increase be effective June 15, 2007.

###

About Portland General Electric

Portland General Electric, headquartered in Portland, Ore., is a fully integrated electric utility that serves more than 796,000 residential, commercial and industrial customers in Oregon.

Safe Harbor Statement

Statements in this news release that relate to future plans, objectives, expectations, performance, events and the like may constitute "forward-looking statements" within the meaning of the Private Securities Litigation Reform Act of 1995, Section 27A of the Securities Act of 1933, as amended, and Section 21E of the Securities Exchange Act of 1934, as amended.

Portland General Electric Company based these forward-looking statements on its current expectations and projections about future events in light of its knowledge of facts as of the date of this current report and its assumptions about future circumstances. Forward-looking statements in this news release include statements regarding the ability of Port Westward to help meet customer demand and reduce the company's dependence on power purchases in the wholesale energy market and statements regarding the expected effective date of the rate increase. Investors are cautioned that any such forward-looking statements are subject to risks and uncertainties, including actions by the OPUC and changes in power market conditions. As a result, actual results may differ materially from those projected in the forward-looking statements. The Company assumes no obligation to update any such forward-looking statement. Prospective investors should also review the risks and uncertainties listed in the Company's most recent Annual Report on Form 10-K and the Company's reports on Forms 8-K and 10-Q filed with the United States Securities and Exchange Commission, including Management's Discussion and Analysis of Financial Condition and Results of Operation and the risks described therein from time to time.

POR-F

Source: Portland General Electric Company

For more information, contact:
Steve Corson, PGE, 503-464-8444

[PGE Home](#) [Site Map](#) [Contact Us](#) [Privacy](#) [Legal Notice](#) [En Español](#)



[Find a Job](#) [Go](#) [Search PGE:](#) [Go](#) [Sign In](#)

[Update Your Info](#) [View Your Bill](#) [Pay Your Bill](#) [Go Paperless](#) [Account Balance](#) [Start, Stop or Move](#)

[PGE Home >> About PGE >> Current Issues](#)

About PGE

- Current Issues**
- Learn About Energy
- PGE Energy Strategy
- Increasing Our Renewable Resources
- BPA Bill Credit
- PGE Pricing
- Port Westward
- Boardman Plant
- Air Emissions
- Job Opportunities
- News Room
- Corporate Information
- Wholesale Activities
- Regulation Affairs

Port Westward

Port Westward Plant serves more than 300,000 homes.



PGE's natural gas-fired power plant in Columbia County went online June 2007. A key part of PGE's diverse mix of generating resources, it produces enough energy to serve about 300,000 homes. About 17 workers operate the plant.

Powered by a state-of-the-art Mitsubishi G-class combustion turbine, the 400-megawatt Port Westward Generating Plant is one of the most efficient combined-cycle natural gas-fired generating plants in the world.

Port Westward emission levels for nitrous oxide and carbon monoxide are below the strict requirements of the Oregon Department of Environmental Quality.

Thanks in part to fixed-bid construction contracts, Port Westward was completed on budget. It is owned and operated by PGE. Check out [photos of the plant](#).

[Video: Watch the plant get built in 51 seconds. Windows Media Player](#)

[PGE Home](#) [Site Map](#) [Contact Us](#) [Privacy](#) [Legal Notice](#) [En Español](#)

ATTACHMENT N
TENNESSEE VALLEY AUTHORITY
TOPOGRAPHIC MAP – DRY CREEK BASIN AND 630 FT. CONTOUR
MAY 2008

Tennessee Valley Authority

**Topographical Map Showing Dry Creek
Basin and 630 Ft. Elevation Contour**

May 2008

