

PMBelCOL PEmails

From: Tanya Simms
Sent: Tuesday, June 17, 2008 1:41 PM
To: rgrumbir@gmail.com; alsterdis@tva.gov; erg-xl@cox.net; pshastings@duke-energy.com; Ray, Phillip M; kslays@duke-energy.com
Cc: Joseph Sebrosky; PMBelCOL PEmails
Subject: Draft RAI 316 Related SRP Section 9.5.1 for Bellefonte Units 3 and 4
Attachments: RAI 316 draft.pdf

To All,

Attached is Draft RAI 316 related to SRP Section 9.5.1 for Bellefonte Units 3 and 4. Please contact me if you desire a phone conference regarding this RAI. If no response is heard by close of business June 20, 2008, the final RAI will be issued.

Tanya Simms
Project Manager
New Reactor Licensing
U.S. Nuclear Regulatory Commission
11555 Rockville Pike
Rockville, Maryland 20852-2738
301-415-1387
tanya.simms@nrc.gov

Hearing Identifier: Bellefonte_COL_Public_EX
Email Number: 310

Mail Envelope Properties (C4A4C9A16294FB4CBA5A36312D05FFAC0A9B1868A2)

Subject: Draft RAI 316 Related SRP Section 9.5.1 for Bellefonte Units 3 and 4
Sent Date: 6/17/2008 1:41:12 PM
Received Date: 6/17/2008 1:41:15 PM
From: Tanya Simms

Created By: Tanya.Simms@nrc.gov

Recipients:

"Joseph Sebrosky" <Joseph.Sebrosky@nrc.gov>
Tracking Status: None
"PMBelCOL PEmails" <PMBelCOL.PEmails@nrc.gov>
Tracking Status: None
"rgrumbir@gmail.com" <rgrumbir@gmail.com>
Tracking Status: None
"alsterdis@tva.gov" <alsterdis@tva.gov>
Tracking Status: None
"erg-xl@cox.net" <erg-xl@cox.net>
Tracking Status: None
"pshastings@duke-energy.com" <pshastings@duke-energy.com>
Tracking Status: None
"Ray, Phillip M" <pmray@tva.gov>
Tracking Status: None
"kslays@duke-energy.com" <kslays@duke-energy.com>
Tracking Status: None

Post Office: HQCLSTR02.nrc.gov

Files	Size	Date & Time
MESSAGE	524	6/17/2008 1:41:15 PM
RAI 316 draft.pdf	13790	

Options

Priority: Standard
Return Notification: No
Reply Requested: Yes
Sensitivity: Normal
Expiration Date:
Recipients Received:

Request for Additional Information No. 316 Revision 0
Bellefonte Units 3 and 4
TVA
Docket No. 52-014 and 52-015
SRP Section: 09.05.01 - Fire Protection Program
Application Section: 9.5.1

QUESTION Fire Protection Team (SFPT)

09.05.01-11

RG 1.189, Regulatory Position 1.6.1 states that the engineer in charge of the fire protection program (FPP) should have training and experience in fire protection and in nuclear plant safety to provide a comprehensive approach in directing the FPP for the nuclear plant. However, the Bellefonte COLA makes no reference to the nuclear plant safety training and experience requirement for the engineer in charge of fire protection. The applicant should include this requirement in FSAR Section 13.1.2.1.2.9 or justify why the fire protection engineer is not required to have nuclear safety knowledge, training, and/or experience.