Facility:Calvert Cliffs 1&2Job Performance Measure No.: 2008-CEDMTask Title:Respond to CEA(s) Misaligned by 8" or moreTask Number:202.007K/A Reference:CRDS- K4.01. K4/03, 2.1.19, 2.1.20Method of testing: $Actual Performance: \sqrt{}$ Simulated Performance: $\sqrt{}$ Plant: $\sqrt{}$ 

## READ TO THE APPLICANT:

I will explain the initial conditions, which steps to simulate or discuss, and provide initiating cues. When you complete the task successfully, the objective for this job performance measure will be satisfied.

#### Initial Conditions:

- 1. Unit 1 is at 80% power.
- An expeditious downpower was in progress. When Gp 5 CEAs were inserted, after ~ 1.5 inches of motion, CEA #35 slipped to its current position( ~ -8.5 inches). The CMI and secondary deviation alarms were received.
- 3. The alarms currently in are:
  - Secondary CEA Position Deviation <u>+</u> 4"
  - CEA Motion Inhibit
- 4. The plant has been stabilized and CEDS is in OFF

#### Initiating Cue:

You are directed to respond to the alarms in accordance with plant procedures as the RO, and realign CEA # 35. The CRS has directed the CRO to maintain Tcold on program and initiate any boration required to maintain Rx power.

Task Standard:

Realign CEA # 35 and respond to associated alarms in accordance with Alarm manual for D-31, D-32, and AOP-1B section VIIA

**Evaluation Criteria:** 

- 1. All critical steps completed.
- 2. All sequential steps completed in order.
- 3. All time-critical steps completed within allotted time.
- 4. JPM completed within validated time. Completion time may exceed the validated time if satisfactory progress is being made.

Required Materials:

1. **Procedures and manuals normally available in the control room** General References:

1. Alarm manual for 1C05

- 2. OI-42
- **3.** AOP-1B

Time Critical Task:

No

Validation Time:

#### 25 minutes

Simulator Setup:

- 1. Reset the simulator IC-19 (80% MOC)
- 2. Insert Malfunction CEDS 0009 (35) One CEA, movement failure with slippage
- 3. Place CEDS in MS mode and go to "LOWER" on 1-HS-5502
- 4. CEA # 35 should pulse down ~ 1.5 inches then slips down another 8.5"
- 5. After 5 seconds place CEDs to OFF
- 6. Acknowledge alarms
- 7. Verify plant is stable ( effects of CEA # 35 moving 9.5 inches is negligible)
- 8. If necessary, adjust turbine load to stabilize Tcold
- 9. Freeze simulator

# ELEMENT (\* = CRITICAL STEP)

(-CKIIICA		
TIME START		
	Locates Alarm Manual for 1C05	Same as element.
	Locates Alarm response for window D-31, and D-32.	Same as element
Examiner Not	e: Applicant may determine that realig with OI-42. CRS should say that rea Section VIIA	nment should be done in accordance lignment will be done per AOP 1-B,
CUE: Electric which has bee	Shop has determined that the cause of the n replaced	slippage was a defective power supply
	Attempt to realign the affected CEA(s):	Determine that CRO will maintain power and NO action is necessary
	Maintain Reactor Power as required by :	
	<ul> <li>Boration PER OI-2B, <u>CVCS BORATION,</u> <u>DILUTION AND</u> <u>MAKEUP</u> <u>OPERATIONS.</u></li> </ul>	
	OR	
	<ul> <li>Adjust Regulating CEAs.</li> </ul>	
*	Selects the desired group	Selects Group 5
*	Selects the desired CEA	Selects CEA 035
*	Select Manual Individual Mode	Selects Manual Individual Mode
*	IF CMI is in effect THEN override CMI as follows:	Determines CMI is in effect
NOTE: CMI	will be bypassed to the affected group a	and applied to all other groups, and
CM1	bypass annunciation will alarm. (1) Depress the Group Inhibit Bypass pushbutton.	Same as element.
	(2) Depress and hold the Motion Inhibit Bypass pushbutton for at least 5 seconds before AND 5 seconds after CEA	Same as element.

motion.

CAUTION: Do NOT allow Reactor Power to rise above the power the unit was stabilized at in Section IV. PRELIMINARY, Step A.2, while the CEA is being realigned. Turbine load shall NOT be raised until the CEA is within its alignment requirements. Realign the CEA: f.

- IF the CEA must be (1) withdrawn, THEN withdraw the CEA using the "Pull and Wait" method:
  - For shutdown Determines rates are not CEA's, pull 3.75 applicable. inches and wait 10 seconds

**IF** the CEA must be (2)inserted, THEN insert the CEA.

Determines step is N/A

CUE ): When CEA # 35 is moved ~ 2.5 inches Alarm D-29, Primary CEA Position **Deviation + 4 inches, alarms** 

Reviews Alarm manual for D-29

Determines that Alarm is

"Expected" for conditions.

\* Continues steps to align CEA # 35

* For regulating Sa	ame
CEAs, pull 5.25 sh	nim
inches and wait th	I <mark>an</mark>
15 seconds. Cl	EA

e as element using the CEA stick on 1C05. (Pull no more 6.75" on CEA #35 each time is withdrawn).

withdrawal

CUE ): When CEA # 35 is moved ~ 4 inches Alarm D-30, Primary CEA Position **Deviation + 8 inches, alarms** 

 Alarm 1C05, D-30, Primary CEA position Deviation <u>+</u> 8 inches:	Stops CEA withdrawal acknowledge alarm	
 Reviews Alarm manual for D-30	Determines that Alarm is "Expected" for conditions.	

\* Continues steps to align CEA # 35

CUE: Insert Malfunction to Stick CEA ,When Candidate attempts to move the CEA it will not move

*	f.1 IF the CEA will NOT move, THEN determine if the CEA is untrippable	Determines that CEA will not move informs CRS
	with input from:	
	System Engineer	

## **CUE: Electric Maintenance has determined that the CEA is trippable**

*	f.2 IF the CEA is untrippable, THEN PROCEED to Section V., UNTRIPPABLE CEAs OR TWO OR MORE CEAs MISALIGNED BY	Determines that this step is N/A
	GREATER THAN 15 INCHES, Page 18. f.3 IF the CEA will NOT move due to an electrical or control system malfunction, THEN initiate a CR AND notify electrical maintenance to perform repairs.	Same as element

# TIME STOP

Examiner Note:	The task is complete when the applicant has determined the CEA cannot be moved but is trippable and has determined that a CR must be written. The evaluator will end the JPM

# Verification of Completion

Job Performance Measure Number: 2008-CEDM
Applicant:
NRC Examiner:
Date Performed:
Facility Evaluator:
Number of Attempts:
Time to Complete:
Follow up Question:
Applicant Response:
Result: SAT UNSAT
Examiner's Signature and Date:

# APPLICANT'S CUE SHEET

# **INITIAL CONDITIONS:**

1. Unit 1 is at 80% power.

2. An expeditious downpower was in progress. When Gp 5 CEAs were inserted, after ~ 1.5 inches of motion, CEA #35 slipped to its current position( ~ -8.5 inches). The CMI and secondary deviation alarms were received.

- 3. The alarms currently in are:
- Secondary CEA Position Deviation + 4"
- CEA Motion Inhibit
- 4. The plant has been stabilized and CEDS is in OFF

# **INITIATING CUE:**

You are directed to respond to the alarms in accordance with plant procedures as the RO, and realign CEA # 35. The CRS has directed the CRO to maintain Tcold on program and initiate any boration required to maintain Rx power.

Facility: Calvert Cliffs 1&2	Job Performance Measure No.: 2008-SDC-1
Task Title: Respond to a loss of RCS inv	entory while SDC is in use
Task Number: 202.024	
K/A Reference: 025AA1.02 (3.8, 3.9)	
Method of testing:	
Simulated Performance:	Actual Performance:

Classroom: \_\_\_\_\_ Simulator: \_\_\_\_ Plant: \_\_\_\_\_

## READ TO THE APPLICANT:

I will explain the initial conditions, which steps to simulate or discuss, and provide initiating cues. When you complete the task successfully, the objective for this job performance measure will be satisfied.

Initial Conditions:

- 1. Unit 1 is in Mode 5 for maintenance with the PZR manway removed.
- 2. The RCS was being maintained at 38'.
- 3. SDC was aligned for service and RCS temperature was 105 °F.
- 4. The Reactor has been shutdown for 10 days.
- 5. A leak has resulted in RCS level lowered to 36', and resulted in a loss of SDC.
- 6. The running LPSI Pp has been secured due to cavitation and AOP-3B has been implemented.
- 7. You are performing the duties of the Unit 1 CRO.

Initiating Cue:

The CRS has directed you to restore SDC per AOP-3B, Step V.E.

Task Standard:

This JPM is complete when RCS level has been restored. No further actions are required. The evaluator is expected to end the JPM.

**Evaluation Criteria:** 

- 1. All critical steps completed.
- 2. All sequential steps completed in order.
- 3. All time-critical steps completed within allotted time.
- 4. JPM completed within validated time. Completion time may exceed the validated time if satisfactory progress is being made.

**Required Materials:** 

1. Procedures and manuals normally available in the control room General References:

1. AOP-3B

Time Critical Task:

No

Validation Time:

#### 20 minutes

Simulator Setup:

- 1. Reset the simulator IC-4 (Shutdown RX Vessel 37.4)
- 2. IC-4. Refueling cart available and connected for service.
- 3. Raise RCS level to 38' using LPSI suction from the RWT. Ensure suction valve is shut once level reached. Place a sticky over Refueling Level cart level indications with 36' indicated.
- 4. Ensure all 4 LPSI Header MOVs are throttled open to 800 gpm (with FIC-306 set point at 3400. Once MOVs are throttled, return FIC-306 set point to 3000 gpm.
- 5. Place both LPSI Pumps in PTL and allow temperature to rise to 105F

# ELEMENT (\* = CRITICAL STEP)

TIME START	
Locates and identifies AOP3B, Block Step VE	Same as element.
CUE: The CRS has directed you to perform block step I	V E of AOP-3B
1.Start CHG PPs as necessary to maintain	Determines that charging pumps are not available
<ul> <li>*1.1 IF the CHG PPs can NOT maintain RCS RCS level. level, THEN restore level PER ATTACHMENT (7), FILLING THE RCS.</li> <li>Note: (HPSI PP fill, Containment Spray PP fill, and gravity fi The method with the highest priority should be employed firs CUE: The CRS directs to us 11 HPSI pump for filling</li> </ul>	Refers to attachment 7 (11) are arranged in order of priority. t, based on equipment availability.
* 1. Fill the RCS with a HPSI PP.	Same as element
<ul> <li>* a. Verify the MINI FLOW RETURN TO RWT ISOL valves are open:</li> <li>1-SI-659-MOV</li> <li>1-SI-660-MOV</li> </ul>	Same as element
<ul> <li>* b. Place the SI PP RECIRC LOCKOUT handswitches in LOCKOUT.</li> <li>1-HS-3659A</li> <li>1-HS-3660A</li> </ul>	Same as element
CUE: CRS directs you to use 11 HPSI pump through the	e AUX Header
* c. IF 11 HPSI PP is to be used through the Main Header, THEN complete the following:	Determines that this step is Not applicable
* d. IF 11 HPSI PP is to be used through the Aux Header, THEN complete the following:	Determines that this step is applicable
<ul> <li>* (1) Open 11 RWT OUT valve, 1-SI-4142-MOV.</li> <li>(2) Open HPSI AUX HDR ISOL valve, 1-SI-656-MOV.</li> </ul>	Same as element
* (3) Shut EITHER HPSI HDR XCONN valves:: • 1-SI-653-MOV • 1-SI-655-MOV	Same as element
<ul> <li>* (4) Verify the AUX HPSI HDR valves are shut:</li> <li>1-SI-617-MOV</li> <li>1-SI-627-MOV</li> <li>1-SI-637-MOV</li> <li>1-SI-647-MOV</li> </ul>	Same as element
*(5) Start 11 HPSI PP.	Same as element

NUREG-1021, Revision 9

#### ELEMENT (\* = CRITICAL STEP)

CAUTION: Do NOT exceed the following cooldown limits in any one hour:

- greater than 256°F 100°F/hr
- 106°F to 256°F 40°F/hr
- less than 106°F 35°F/hr

#### CAUTION

When RCS temperature is less than 365°F AND the RCS vent opening is less than 2.6 square inches, flow into the RCS is limited to less than 210 GPM unless a leak exists. If a leak exists, flow may exceed 210 GPM as long as pressure is maintained less than 380 PSIA (or 260 PSIA if the SDC Header Return Isolation valves, 1-SI-651-MOV and 1-SI-652-MOV, are open).

<ul> <li>*(6) Throttle ONE AUX HPSI HDR valve to maintain flow between 150 and 200 GPM.</li> <li>1-SI-617-MOV</li> <li>1-SI-627-MOV</li> <li>1-SI-637-MOV</li> <li>1-SI-647-MOV</li> </ul>	Same as element		
*(7) IF a leak exists, THEN perform the following actions as required:	Determines that a leak exists		
<ul> <li>* Throttle the selected AUX HPSI HDR valve as necessary to maintain adequate level.</li> <li>(a) Maintain RCS pressure less than 380 PSIA (260 PSIA if the SDC Header Return Isolation valves, 1-SI-651-MOV and 1-SI-652-MOV, are open)</li> </ul>	MOVs should be jogged no more than 5 times within 2 minutes. Then allow at least 5 minutes before operating again. Same as element		
IF the leak is suspected on the associated Header, THEN shut the selected AUX HPSI HDR valve AND choose another AUX HPSI HDR valve PER Step (6).	Determines Not applicable		
(8) <b>IF</b> performing Once-Through-Cooling, <b>THEN</b> return to the appropriate section of this AOP.	Determines Not applicable		
CUE : Level is rising ( Remove sticky and inform candidate that level is rising and is at 38' feet, the leak has located and isolated, secure filling RCS			
(9) WHEN filling is NO longer desired,	Same as element		
* (a) Stop 11 HPSI PP.	Same as element		
(b) Shut the AUX HPSI HDR valve opened in Step	Same as element		
(c) <b>IF</b> HPSI HDR XCONN valve, 1-SI-655-MOV, was shut in Step 1.d.3, <b>THEN</b> open 1-SI-655-MOV.	Same as element		

TIME STOP

STANDARD

#### ELEMENT (\* = CRITICAL STEP)

1. Sec. 4. L

Examiner Note:	The JPM is complete when an increase in RCS level is noted and 11
	HPSI is secured and MOV shut

# Verification of Completion

Job Performance Measure Number <u>: 2008-SDC</u> Applicant:				
NRC Examiner:				
Date Performed:				-
Facility Evaluator:				-
Number of Attemp	ts:			
Time to Complete:				
Follow up Question	n:			
	· · · · · · · · · · · · · · · · · · ·			
 Applicant Respons	e:			
	<u></u>			
······································			······································	
Result:	SAT		UNSAT	

Appendix C	Ap	pendix	C
------------	----	--------	---

Examiner's Signature and Date:

1.1.1.1.1.1.1

# APPLICANT'S CUE SHEET

# **INITIAL CONDITIONS:**

i.

- 1. Unit 1 is in Mode 5 for maintenance with the PZR manway removed.
- 2. The RCS was being maintained at 38'.
- 3. SDC was aligned for service and RCS temperature was 105 °F
- 4. The Reactor has been shutdown for 10 days.
- 5. A leak has resulted in RCS level lowered to 36', and resulted in a loss of SDC.
- 6. The running LPSI Pp has been secured due to cavitation and AOP-3B has been implemented.
- 7. You are performing the duties of the Unit 1 CRO.

# **INITIATING CUE:**

The CRS has directed you to restore SDC per AOP-3B, Step V.E..

Facility: Calvert Cliffs 1&2	Job Performance Measure No.: 2008-PPCS	
Task Title: Respond to a Pressurizer Spr	ay Valve Failure	
Task Number: 064.036		
K/A Reference: 008-AA2.19		
Method of testing:		
Simulated Performance:	Actual Performance: $\underline{}$	
Classroom: Simulator:	_√ Plant:	

## READ TO THE APPLICANT:

I will explain the initial conditions, which steps to simulate or discuss, and provide initiating cues. When you complete the task successfully, the objective for this job performance measure will be satisfied.

#### Initial Conditions:

- 1. Unit 1 is at 100% power.
- 2. Pressurizer pressure channels indicate low pressurizer pressure
- 3. Proportional heaters indicate maximum current
- 4. All available backup heaters are energized
- 5. The alarms currently in are:
  - PZR PRESS CH 100
  - RCP Seal Pressure Low

Initiating Cue:

You are directed to respond to the alarms in accordance with plant procedures as the RO.

Task Standard:

Respond to the alarms and abnormal conditions in accordance with Alarm manual and recommend tripping the reactor and securing 11A RCP

Evaluation Criteria:

- 1. All critical steps completed.
- 2. All sequential steps completed in order.
- 3. All time-critical steps completed within allotted time.
- 4. JPM completed within validated time. Completion time may exceed the validated time if satisfactory progress is being made.

**Required Materials:** 

1. Procedures and manuals normally available in the control room <u>General References:</u>

1. Alarm manual for 1C06

Time Critical Task:

No

Validation Time:

## 10 minutes

Simulator Setup:

- 1. Reset the simulator IC-24 (100% MOC)
- 2. Insert Malfunction RCS-016
- 3. Run the simulator for ~ 11 Minutes or until ANN PZR Press CH 100 Alarm
- 4. Pressurizer Pressure should be approximately 2125 PSIA
- 5. Acknowledge alarms
- 6. Freeze simulator

# ELEMENT (\* = CRITICAL STEP)

TIME STAR	ſ	
	Locates Alarm Manual for 1C06	Same as element.
	Locates Alarm response for window E- 29,	Same as element
Examiner Not	te: Applicant may refer to other alarms a condition as well. Candidate may not to close before referring to the Alarm	ssociated with the low pressurizer e spray valve open initially and attempt Manual.
Cue - Spray	valve 1-RC-100E is open	
	Notes that pressurizer pressure is LOW, and checks the possible causes:	Same as element
	2. Perform the following:	Identifies 1-RC-100E is Open
	a. <b>CHECK</b> Pressurizer spray valves shut.	
· · ·	b. CHECK Pressurizer heaters energized.	Same as element
	c. IF required, THEN PERFORM any of the following: ENERGIZE Pressurizer heaters	Same as element
	SHIFT Pressurizer pressure control channels	Determines not applicable
	THEN attempt to SHUT Pressurizer spray valve by swapping 1-HS-100-8 to the opposite Pressurizer spray valve	Same as element
Cue- Spray	valve 1-RC-100E is still open	
* Cue- Spray	SHUT Pressurizer spray valves using 1-HIC-100 in manual valve 1-RC-100E is still open	Same as element
* Cue- Spray	IF one Pressurizer spray valve has failed OPEN, THEN attempt to SHUT Pressurizer spray valve by swapping 1-HS-100-8 to the opposite Pressurizer spray valve. valve 1-RC-100E is still open	Same as element

#### ELEMENT (\* = CRITICAL STEP)

<u> </u>	IF Pressurizer spray valves can	Determines that 1-RC-100E cannot
	NOT be shut,	de snut.
	THEN PERFORM the following:	
Ca. 20 20.	(1) TRIP the reactor.	Same as element.
*	(2) IMPLEMENT Reactivity	Same as element
	Control section of EOP-0,	
	Post-Trip Immediate Actions.	
	(3) STOP the RCP(s)	Secures 11 A RCP
	associated with the open	
	Pressurizer spray valve(s):	
	• 11A for 1-RC-100E-CV	
	• 11B for 1-RC-100F-CV	
Note: Candie	date may recommend tripping 11B RCP	as well.

# TIME STOP

Examiner Note:	The task is complete when the applicant has completed reactivity portion of the EOP-0 plaque and secured 11A RCP.
	the Let o plaque and secured TIT Ref.

# Verification of Completion

Job Perfo	ormance Measure Number: 2008-PPCS	
Applican	ıt:	
NRC Exa	aminer:	
Date Perf	formed:	
Facility E	Evaluator:	
Number of	of Attempts:	
Time to C	Complete:	
Follow uj	p Question:	
Applicant	it Response:	
<u></u>		
Result	SAT LINGAT	
Examiner	r's Signature and Date:	

# APPLICANT'S CUE SHEET

# **INITIAL CONDITIONS:**

- 1. Unit 1 is at 100% power.
- 2. Pressurizer pressure channels indicate low pressurizer pressure
- 3. Proportional heaters indicate maximum current
- 4. All available backup heaters are energized
- 5. The alarms currently in are:
- PZR PRESS CH 100
- RCP Seal Pressure Low

# **INITIATING CUE:**

You are directed to respond to the alarms in accordance with plant procedures as the RO. Do you have any questions? You may begin.

Facility: Calvert Cliffs 1&2	Job Performance Measure No.: 2008-MFW
Task Title: Respond to a feedwater rupt	ıre at power
Task Number: 202.035	
K/A Reference: 054- AA1.01	
Method of testing:	
Simulated Performance:	Actual Performance:
Classroom: Simulator:	Plant:
DEAD TO THE ADDI ICANT.	
READ TO THE APPLICANT:	the simulate or discuss and provide
initiating cues. When you complete the ta	steps to simulate or discuss, and provide ask successfully, the objective for this job
performance measure will be satisfied.	• * •
Initial Conditions:	
1. Unit 1 is at Mode 100% at NOP and N	OT.
<ol> <li>Due to a leak, the following alarms hav (Condensate Pumps Discharge Pressur C25 (SGFP Suction Pressure Low).</li> </ol>	ve come in over time on 1C03; C04 re Low), C16 (Condenser Hotwell Level), and
3. AOP-3G has been implemented. The reperforming reactivity control per EOP.	eactor has just been tripped and the RO is -0
4. You are performing the duties of the U	Init 1 CRO.
Initiating Cue:	
The CRS has directed you to perform AOP-3 questions?	3G, Block Step VIII.A. Are there any
Task Standard:	
This JPM is complete when the cond feedwater initiated per AOP-3G Step	ensate system has been secured and auxiliary VIII.A.

**Evaluation Criteria:** 

- 1. All critical steps completed.
- 2. All sequential steps completed in order.
- 3. All time-critical steps completed within allotted time.
- 4. JPM completed within validated time. Completion time may exceed the validated time if satisfactory progress is being made.

**Required Materials:** 

1. Procedures and manuals normally available in the control room

General References:

- 1. Alarm manual for 1C03
- 2. AOP 3G

Time Critical Task:

No

Validation Time:

# 10 minutes

Simulator Setup:

- a. IC-18, U-1 at 100% Power. .
- b. Initiate malfunction CD008 at 10% condensate booster pump common discharge header rupture.
- c. Insert malfunction AFW005 for 13 AFW Pump breaker failure.
- d. Run Simulator until alarms C04, C16 and C25 are in alarm (~1 min.) and freeze.

#### **CCNPP LICENSED OPERATOR**

#### JOB PERFORMANCE MEASURE AOP-3G-9F

#### ELEMENT **STANDARD** (\* = CRITICAL STEP)TIME START CUE: Begin at Step VIII.A.1. \_\_\_\_ 1. Determines step is applicable and IF a rapid unexplained reduction or starts performing the actions for a loss of Condensate or Feedwater condensate header rupture at power header pressure occurs simultaneously with a lowering of Hotwell level, OR other indications of a rupture are observed, THEN with the approval of the SM/CRS, perform the following actions: CUE: The RO has tripped the reactor and is performing reactivity control. Determines this step is being a. Trip the Reactor performed by RO b. Perform the Reactivity control Determines this step is being performed by RO portion of EOP-0 Pushes the trip pushbuttons for 11 c. Trip both SGFPs. and 12 SGFPs and verifies SGFP speeds are lowering on the OCS or SGFP HICs. Verifies HP and LP stop valves for both SGFPs are closed. CUE: When the handswitches for the Condensate and Booster pumps are operated they indicate stopped. Places HS for all Condensate and d. Secure the following pumps, and Condensate Booster Pumps in PTL. place their handswitches in PULL TO LOCK: Condensate Booster Pumps **Condensate Pumps** • Heater Drain Pumps CUE: When the FW isolation valve handswitches are operated the valves indicate closed. e. Shut the SG FW ISOL valves: Shuts FW MOVs using HS-4516 and HS-4517 1-FW-4516-MOV 1-FW-4517-MOV •

# **CCNPP LICENSED OPERATOR**

# JOB PERFORMANCE MEASURE AOP-3G-9F

ELEMENT (* = CRITICAL STEP)			STANDARD	
CUE: When 13 AFW pump is attempted to be started it does not start				
*	f. Start an AF	W PP.	Recognizes that 13 AFW pump did not start	
*	b. Open the S BYPASS valu (11 S( (11 S( (12 S( (12 S(	3G AFW STM SUPP & ′es: 3) 1-MS-4070-CV 3) 1-MS-4070A-CV 3) 1-MS-4071-CV 3) 1-MS-4071A-CV	Same as element	
TIME STOP				
TERMINATI	NG CUE:	This JPM is complete whe secured and an AFW pum The evaluator is expected required.	en the condensate system has been up has been started initiated per AOP-3G to end the JPM. No further actions are	

Appendix C

# Verification of Completion

Job Performance Measure Number: 2008-MFW	
Applicant:	
NRC Examiner:	
Date Performed:	
Facility Evaluator:	
Number of Attempts:	
Time to Complete:	
Follow up Question:	
Applicant Response:	
Result: SAT UNSAT	_
Examiner's Signature and Date:	

# APPLICANT'S CUE SHEET

# **INITIAL CONDITIONS:**

**Initial Conditions:** 

- 1. Unit 1 is at Mode 100% at NOP and NOT.
- Due to a leak, the following alarms have come in over time on 1C03; C04 (Condensate Pumps Discharge Pressure Low), C16 (Condenser Hotwell Level), and C25 (SGFP Suction Pressure Low).
- 3. AOP-3G has been implemented. The reactor has just been tripped and the RO is performing reactivity control per EOP-0
- 4. You are performing the duties of the Unit 1 CRO.

## INITIATING CUE:

.

The CRS has directed you to perform AOP-3G, Block Step VIII.A. Are there any questions? You may begin

Facility: Calvert Cliffs 1&2	Job Performance Measure No.: 2008-SDC-2
Task Title: Respond to a loss of Shutdow	vn with the RCS open
Task Number: 202.024	
K/A Reference: 025AA1.02 (3.8, 3.9)	
Method of testing:	

Simulated Performance: _		Actual Pe	erformance:	_√
Classroom:	Simulator:	√	Plant:	

## **READ TO THE APPLICANT:**

I will explain the initial conditions, which steps to simulate or discuss, and provide initiating cues. When you complete the task successfully, the objective for this job performance measure will be satisfied.

Initial Conditions:

- 1. Unit 1 is in Mode 5 for maintenance with the PZR manway removed.
- 2. The RCS was being maintained at 41.7'.
- 3. SDC was aligned for service and RCS temperature was 115 °F.
- 4. The Reactor has been shutdown for 10 days..
- 5. Fluctuations in 12 LPSI Motor amps, discharge pressure, flow and noise has been reported are noted
- 6. You are performing the duties of the Unit 1 CRO.

Initiating Cue:

The CRS has directed you to respond to these conditions per AOP-3B, IV.A.4.

Task Standard:

This JPM is complete when SDC has been restored. No further actions are required The evaluator is expected to end the JPM.

**Evaluation** Criteria:

- **1.** All critical steps completed.
- 2. All sequential steps completed in order.
- 3. All time-critical steps completed within allotted time.
- 4. JPM completed within validated time. Completion time may exceed the validated time if satisfactory progress is being made.

**Required Materials:** 

1. Procedures and manuals normally available in the control room General References:

1. AOP-3B

Time Critical Task:

No

Validation Time:

#### 25 minutes

Simulator Setup:

- 1. Reset the simulator IC-3 (Shutdown RX Vessel 41.7)
- 2. IC-3. Refueling cart available and connected for service.
- 3. Ensure all 4 LPSI Header MOVs are throttled open to 800 gpm (with FIC-306 set point at 3400. Once MOVs are throttled, return FIC-306 set point to 3000 gpm.
- 4. Ensure 12 LPSI pump is running and 11 LPSI is in PTL
- 5. Set up conditions for LPSI cavitation indications
  - a. Override green indicator light for 1-SI-651 MOV to indicate partial open
  - b. Use remote function for 1-SI-651-MOV to open its breaker and manually position it to  $\sim 20\%$  (.2). then reclose the MOV breaker.
  - c. Run Simulator until "LPSI PUMP SUCTION PRESS LO alarm in, then freeze the simulator.
- 6. Bring candidate into the simulator, brief the initial conditions and then put the simulator in run when the candidate is ready

Appendix	C Job Performance Measure Worksheet	Form ES-C-1	
TIME STA	ART		
	Locates AOP-3B, Step IV.A.4	Same as element.	
CUE: Fluc PUN the F	etuations in motor amps ,discharge pressure, pun AP SUCTION PRESS LO" alarm is in. Inform c ECCS has been reported coming from the area of	np discharge flow, "LPSI andidate that excessive noise in f 12 LPSI pump.	
*	<ul> <li>4. IF a LPSI PP is determined to be cavitating/gas bound by considering the following:</li> <li>Fluctuations in motor amps</li> <li>Fluctuations in discharge pressure</li> <li>Fluctuations in pump discharge flow</li> <li>Excessive pump noise</li> <li>"LPSI PUMP SUCTION PRESS LO" alarm actuation</li> <li>THEN complete the following actions:</li> </ul>	Determines step is applicable. Monitors 12 LPSI pump indications	
*	<ul> <li>a. IF the RCS is in reduced inventory,</li> <li>THEN perform the following actions:</li> <li>(1) IF RCS level is less than 37.6 feet,</li> <li>THEN verify flow is less than or equal to 1500 gpm</li> </ul>	Determines this step is not applicable	
*	(2) IF RCS level is greater than 37.6 feet,	Determines this step is applicable	
*	<ul> <li>equal to 2000 gpm.</li> <li>(3) IF the appropriate SDC Flow is Restored AND LPSI PP cavitation/gas binding stops,</li> <li>THEN IMPLEMENT the</li> </ul>	Determines this step is not applicable	
*	b. Stop the operating LPSI PP(s).	Same as element	
*	c. Place <b>BOTH</b> LPSI PP handswitches in PULL TO LOCK.	Place 12 LPSI pump in PTL	
Isolation	of the LPSI PP suction flow path can cause p	oump damage if the LPSI PPs are	
allowed to	o operate.		
*	<ul> <li>5. Check that the SDC HDR RETURN ISOL valves are open:</li> <li>1-SI-651-MOV</li> <li>1-SI-652-MOV</li> </ul>	Determines that 1-SI-651-MOV is not fully open	
	5.1 <b>IF ANY</b> of the SDC HDR RETURN ISOL valves are <b>NOT</b> fully open, <b>THEN</b> complete the following:	Same as element	

Appendix	C Job Performance Meas Worksheet	Sure Form ES-C-1
	a. Stop the operating LPSI PP(s).	Determines this step is not applicable
	b. Place <b>BOTH</b> LPSI PP handswitches in PULL TO LOCK.	Determines this step is not applicable
	c. Initiate Aux Spray as necessary <b>PER</b> Step C.5.b.1, to maintain RCS pressure less than 260 PSIA.	Determines this step is not applicable
CUE: Whe	n the candidate attempts to open 1-SI-651 file from the indicator lights.	rom the control room, it opens (Remove
*	<ul> <li>d. Attempt to open the affected SDC</li> <li>HDR RETURN ISOL valve(s) from the</li> <li>Control Room: <ul> <li>1-SI-651-MOV</li> <li>1-SI-652-MOV</li> </ul> </li> </ul>	Attempts to open 1-SI-651. Note candidate should hold the handswitch in open until SI-651 indicates full open (~40 seconds)
*	e. <b>IF BOTH</b> SDC HDR RETURN ISOL valves are open, <b>THEN</b> attempt to restore SDC <b>PER</b> ATTACHMENT (3), RETURNING SHUTDOWN COOLING TO SERVICE.	Observes that both valves are open and refers to attachment 3
	f. <b>IF</b> the affected SDC HDR RETURN ISOL valve(s) will <b>NOT</b> open from the Control Room, <b>THEN</b> assign an operator to perform Step B, Page 17, AND concurrently <b>PBOCEED</b> to Step C, Page 20	Determines this step is not applicable proceeds to attachment 3
	1. Ensure RCS pressure is less than 260	Same as element
	2. Ensure RCS temperature is less than 300°F.	Determines that RCS temperature is less than 300°F
*	<ul> <li>3. Ensure the SDC HDR RETURN ISOL valves are open:</li> <li>1-SI-651-MOV</li> <li>1-SI-652-MOV</li> </ul>	Same as element
CUE: Wh	en asked 1-SI-444 , and 1-SI-432 are lock	ed shut
CUE: Wh	<ul> <li>4. Ensure the LPSI PP NORM SUCT ISOL valves are Locked Shut:</li> <li>(11 LPSI PP) 1-SI-444</li> <li>(12 LPSI PP) 1-SI-432</li> <li>en asked 1-SI-441, and 1-SI-440 are locked</li> </ul>	Calls ABO to ensure valves are positioned ed open
Appendix	C Job Performance Measure Worksheet	Form ES-C-1
-----------	---	---
	<ul> <li>5. Ensure the LPSI PP SDC SUCT ISOL valves are Locked Open:</li> <li>(11 LPSI PP) 1-SI-441</li> <li>(12 LPSI PP) 1-SI-440</li> </ul>	Calls ABO to ensure valves are positioned
CUE: WI	ien asked 1-51-447, and 1-51-435 are locked	open
Cue: Whe	<ul> <li>6. Verify the LPSI PP DISCH ISOL valves are Locked Open:</li> <li>(11 LPSI PP) 1-SI-447</li> <li>(12 LPSI PP) 1-SI-435</li> <li>en asked air is not suspected of being trapped</li> </ul>	Calls ABO to ensure valves are positioned d in the SDC return header
Cue : Use	7. IF air is suspected of being trapped in the SDC Return Header THEN vent the SDC Return Header. remote function to vent 11 & 12 LPSI pump	Determines that this step is not applicable.
	Salety has been notified and AbO has vente	a pumps
	8. <b>IF</b> air is suspected in the LPSI PPs, <b>THEN</b> vent the LPSI PP casings:	Determine that pumps have been vented
	9. Shut the S/D COOLING TEMP CONTR valve, 1-SI-657-CV.	Verifies output of HIC-657 is zero or HS-3657 is in CLOSE. Checks position indication for SI-657.
*	10. Partially open the SDC FLOW CONTR valve, 1-SI-306-CV, as follows:	Same as element
*	a. Place the SDC FLOW CONTR, 1-FIC- 306, to MANUAL.	Same as element
*	b. Adjust the SDC FLOW CONTR, 1-FIC- 306, to 95% output.	Candidate should note that output must be increased to throttle 1-SI- 306-CV closed
	11. Verify LPSI HDR flowpath:	
*	<ul> <li>a. IF the RCS level is at or below the 37.6 foot elevation,</li> <li>THEN verify the following: <ul> <li>(1) Two LPSI HDR valves are shut and in PULL TO OVERRIDE.</li> <li>(2) The remaining two LPSI HDR valves are in PULL TO OVERRIDE,</li> <li>AND throttled to obtain between 800 and 850 GPM in each LPSI loop</li> <li>OR the remaining two LPSI HDR valves are open.</li> </ul> </li> </ul>	Determines this step is not applicable

Appendix	C Job Performance Measure Worksheet	Form ES-C-1
*	<ul> <li>b. IF the RCS level is between the 41 foot and the 37.6 foot elevation,</li> <li>THEN verify the following:</li> <li>(1) Two LPSI HDR valves are shut and in PULL TO OVERRIDE.</li> </ul>	Determines this step is not applicable
	(2) The remaining two LPSI HDR valves are in PULL TO OVERRIDE, <b>AND</b> throttled to obtain between 1050 and 1100 GPM in each LPSI loop <b>OR</b> the remaining two LPSI HDR valves are open.	
*	c. IF the RCS level is above the 41 foot	Determines this step IS applicable
	elevation, THEN verify ALL LPSI HDR valves are open: • 1-SI-615-MOV	Same as element
	<ul> <li>1-SI-625-MOV</li> <li>1-SI-635-MOV</li> <li>1-SI-645-MOV</li> </ul>	
CAUTIO	N : Do NOT operate the LPSI PPs at shutoff ]	head.
*	12. Start a LPSI PP.	Same as element. Starts 12 LPSI Pump
*	13. <b>IF</b> the RCS level is above the 41 foot elevation	Determines this step is applicable
	THEN slowly adjust the SDC FLOW CONTR, 1-FIC-306, to raise SDC flow to 3000 GPM.	Same as element
*	14. <b>IF</b> the RCS level is between the 41 foot and the 37.6 foot elevation, <b>THEN</b> slowly adjust the SDC FLOW CONTR, 1-FIC-306, to raise SDC flow to 2000 GPM	Determines this step is NOT applicable
*	15. IF the RCS level is at or below the 37.6 foot elevation, THEN slowly adjust the SDC FLOW CONTR, 1-FIC-306, to raise SDC flow to	Determines this step is NOT applicable
CUE: The	e CRS desires to have FIC-306 in Auto.	
*	16. Place the SDC FLOW CONTR, 1-FIC- 306, in AUTO if desired	Places FIC-306 in AUTO after matching setpoint to actual SDC flow.
CAUTION greater the 106°F to 2	Do NOT exceed the following cooldown lim an 256°F 100°F/hr 56°F 40°F/hr	its in any one hour:

less than 106°F 35°F/hr

 $a_{i} = \frac{1}{2} \left( -\frac{1}{2} \right)^{2} a_{i}$ 

Appendix C	Job Performance Measure	Form ES-C-1
	Worksheet	

# CAUTION Do NOT exceed a heatup rate of 14°F/MIN for the Shutdown Cooling Heat Exchanger as indicated on TI-303X and TI-303Y.

### CAUTION Do NOT exceed 4800 GPM flow through one SDC HX.

CUE: The CRS desires to restore RCS temperature to 115 °F. When checked, SI-657 indicates intermediate and SDC temperature is 1118°F and slowly lowering.

<ul> <li>* 17. Adjust the S/D COOLING TEMP CONTR, 1-HIC-3657, as necessary to maintain the desired temperature and current mode.</li> <li>(Mode 4) less than 300°F</li> <li>(Mode 5) less than 200°F</li> <li>(Mode 6) less than 140°F</li> </ul>		If HS-3657 is in CLOSE, places HS- 3657 to AUTO. Raises output of HIC-657. Checks SDC temperature slowly lowering (TR-351 on 1C09).
TERMINATING CUE:	This JPM is complete when S The evaluator is expected to actions are required.	SDC flow has been restored . end the JPM. No further

TIME STOP

Appendix	С
----------	---

# Verification of Completion

Job Performance Me	easure Number: 2008-SDC-2		
Applicant:			
NRC Examiner:			
Date Performed:			
Facility Evaluator:			
Number of Attempts:	:		
Time to Complete:			
Follow up Question:			
		and a second	
Applicant Response:	:		
Result: SA	AT	UNSAT	

Appendix C	Job Performance Measure	Form ES-C-1
	Worksheet	

Examiner's Signature and Date:

### APPLICANT'S CUE SHEET

### **INITIAL CONDITIONS:**

- 1. Unit 1 is in Mode 5 for maintenance with the PZR manway removed.
- 2. The RCS was being maintained at 41.7'.
- 3. SDC was aligned for service and RCS temperature was 115 °F.
- 4. The Reactor has been shutdown for 10 days..
- 5. Fluctuations in 12 LPSI Motor amps, discharge pressure, flow and noise has been reported are noted
- 6. You are performing the duties of the Unit 1 CRO.

### **INITIATING CUE:**

The CRS has directed you to respond to these conditions per AOP-3B, IV.A.4. Are there any questions? You may begin

Appendix C Job Performance Meas	ure
Facility: Calvert Cliffs 1&2	Job Performance Measure No.: 2008-480V
Task Title: Return 480V Bus # 11A to	Service Following Maintenance
Task Number: 005/006.001	
K/A Reference: A2.05 (2.9, 3.0)	
Method of testing:	
Simulated Performance:	Actual Performance:
Classroom: Simulator:	Plant:
READ TO THE APPLICANT:	

I will explain the initial conditions, which steps to simulate or discuss, and provide initiating cues. When you complete the task successfully, the objective for this job performance measure will be satisfied.

Initial Conditions:

- 1. 480 V unit bus 11A has been completely de-energized for bus maintenance.
- 2. The work has just been completed and safety tags cleared.
- 3. DC control power is available to the bus feeder breakers. 4KV bus #11 and transformer U-440-11A are energized.
- 4. All load breakers from bus 11A are open.
- 5. All alarms are clear on transformers U-4000-11 and U-440-11A.
- 6. You are performing the duties of a spare licensed operator.

Initiating Cue:

1. The CRS directs you to re-energize 480 V bus #11B from service transformer U-440-11B per the OI. Are there any questions? You may begin

Task Standard:

This JPM is complete when 480 V unit bus #11A is energized from 4.16 KV bus #11.

**Evaluation Criteria:** 

- **1.** All critical steps completed.
- 2. All sequential steps completed in order.
- 3. All time-critical steps completed within allotted time.
- 4. JPM completed within validated time. Completion time may exceed the validated time if satisfactory progress is being made.

**Required Materials:** 

1. Procedures and manuals normally available in the control room General References:

1. OI-27D

Time Critical Task:

No

Validation Time:

### 15 minutes

Simulator Setup:

- 1. IC-13, U1, 100%
- 2. Deenergize 11A 480 Volt bus

Appendix C	Job Performance Measure	Form ES-C-1
	Worksheet	

TIME START\_\_\_\_

CUE:	The General Precautions Step 6.6.B.3	s and Initial Condition	ns have been met. Begin at	
	Identify and locate OI- 6.6.B.3.	27D, Step	Same as element.	
*3.	<b>TURN</b> the control swi CLOSE position to clo breaker.	tch to the se the desired	[3]	
CUE:	Bus 11A voltage is 480	V and red breaker CL	OSE indicating light is lit.	
4.	VERIFY breaker close	e indication.	[4]	
CUE:	White potential indicating	ng light is lit, on 1C18	3, for Bus 11A.	
5.	<b>VERIFY</b> potential ind illuminated.	icating light is	Checks white potential indicating light illuminated on mimic for 486 Bus 11A, on 1C18.	; ov
CUE:	Each phase's voltage is a	approximately 480V.		
6.	IF bus voltage is <u>NOT</u> and 510 volts on each p <u>THEN</u> REFER to OI- <u>OPERATION OF 500</u> <u>SWITCHYARD.</u> [B01]	between 445 phase, 28, <u>KV</u> [ <b>20</b> ]	Checks each phase's voltage by rotating voltmeter selector switch and checks voltage on each phase	
TIME STOP				
TERMINAT	TING CUE: This JPI energize is check	M will be complete w ed from 4.16 KV bus ed. No further action	hen 480V unit bus #11A is #11 and unit bus 11A voltage is are required.	

Appendix C

### Verification of Completion

Job Performance Measure Number: 2008-480
Applicant:
NRC Examiner:
Date Performed:
Facility Evaluator:
Number of Attempts:
Time to Complete:
Follow up Question:
Applicant Response:
Result: SAT UNSAT
Examiner's Signature and Date:

### APPLICANT'S CUE SHEET

### **INITIAL CONDITIONS:**

**Initial Conditions:** 

- 7. 480 V unit bus 11A has been completely de-energized for bus maintenance.
- 8. The work has just been completed and safety tags cleared.
- 9. DC control power is available to the bus feeder breakers. KV bus #11 and transformer U-440-11A are energized.
- 10. All load breakers from bus 11A are open.
- 11. All alarms are clear on transformers U-4000-11 and U-440-11A.
- 12. You are performing the duties of a spare licensed operator.
- :

#### **INITIATING CUE:**

The CRS directs you to re-energize 480 V bus #11A from service transformer U-440-11A per the OI. Are there any questions? You may begin.

	Job Performance Measure Worksheet	Form ES-C-
Facility: Calvert Cliffs 1&2	Job Performance Measur	e No.: 2008-NIS
Task Title: Calculate Tq usin	ng the excore NIs	
Task Number: 204.129		
K/A Reference:		
Method of testing:		
Simulated Performance:	Actual Performance:	<u>√</u>
Classroom: S	imulator: <u> </u>	
READ TO THE APPLICANT:		
performance measure will be <u>Initial Conditions:</u> 1. Unit 1 is at 70% power been here for several w	satisfied. r and has been operating for mainten veeks.	ance and has
2. The plant computer ha	as "crashed" and is inoperable.	
<b>3 37 0 1</b> (1	e duties of the Unit-1 RO	
3. You are performing th		
3. You are performing th Initiating Cue:		
3. You are performing th <u>Initiating Cue:</u> AOP-7H has been implement power tilt (Tq) using the exco	ed and the CRS directs you to detern re NIs per Block Step IV.F.	nine the azimuthal
3. You are performing th <u>Initiating Cue:</u> AOP-7H has been implement power tilt (Tq) using the exco <u>Task Standard:</u>	ed and the CRS directs you to detern re NIs per Block Step IV.F.	nine the azimuthal

Appendix C	Job Performance Measure	Form ES-C-1
**	Worksheet	

**Evaluation Criteria:** 

- 1. All critical steps completed.
- 2. All sequential steps completed in order.
- 3. All time-critical steps completed within allotted time.
- 4. JPM completed within validated time. Completion time may exceed the validated time if satisfactory progress is being made.

**Required Materials:** 

1. Calculator

2. Blank AOP-7H Attachment 5

General References:

- 1. AOP-7H
- 2. NEOP-13

Time Critical Task:

No

Appendix C

Validation Time:

15 minutes

 $\cdot 1$ 

Simulator Setup:

None

#### ELEMENT (\* = CRITICAL STEP)

TIME START \_\_\_\_\_

Identify and locate AOP-7H	
Section IV.F.	

Same as element.

CUE: In the simulator, let the operator demonstrate how excore detector readings are taken from "RPS". For consistency, the following detector values should be provided to the operator rather than the operator using the detector readings at RPS. Provide the operator with Attachment (1). The attachment has the same excore detector readings as below.

(3) excore detectors are operable with the following readings:

- "A" upper: 98.3% "B" upper: 98.2% "C" upper: 98.5% "A" lower: 99.1% "B" lower: 98.9% "C" lower: 99.6%
- \_\_\_\_ 1. IF ALL four Linear Power Channels are operable, THEN perform the following:
  - 1.1. IF only 3 Linear Power Channels are operable AND Reactor Power is less than 75%, THEN calculate Tq using three Excore detectors as follows:
  - 1.2. **IF** only 3 Linear Power Channels are operable AND Reactor Power is greater than 75% .....

Record the readings on ATTACHMENT (5), <u>Tq</u> <u>CALCULATION USING</u> <u>EXCORE DETECTORS</u>.

Calculate an upper AND a lower Tq using the method in ATTACHMENT (5), <u>Tq</u> <u>CALCULATION USING</u> <u>EXCORE DETECTORS</u>. Determines only three (3) channels are operable and step is not applicable.

Determines this step is applicable

Determines this step is not applicable

Records Readings on Attachment 5.

Calculates Upper Tq to be 0.004 ( $\pm$  .0005) if using CUE values. Calculates Lower Tq to be 0.0056 ( $\pm$  .0005) if using CUE values. It is also acceptable if Ops Calc is used to determine Tq.

### \_\_\_\_\_2. **IF** Tq is greater than 0.03,

a company a

Determines Tq is less than 0.03.

#### TIME STOP

further actions are required. The operator is expected to end the JPM.	Examiner Note:	This JPM is complete when calculated azimuthal power tilt (Tq) is determined to be within acceptable limits per AOP-7H Step IV.F. No further actions are required. The operator is expected to end the JPM.
--	----------------	---

Appen	dix	C
-------	-----	---

and she was a set of the set of the

# Verification of Completion

Job Performance Measure Number:	2008-NIS
Applicant:	
NRC Examiner:	
Date Performed:	
Facility Evaluator:	
Number of Attempts:	
Time to Complete:	
Follow up Question:	
Applicant Response:	
Result: SAT	UNSAT
Examiner's Signature and Date:	

### APPLICANT'S CUE SHEET

### **INITIAL CONDITIONS:**

a. Unit 1 is at 100% power and has been operating at full power for seven weeks.

b. The plant computer has "crashed" and is inoperable.

c. You are performing the duties of the Unit-1 RO.

### **INITIATING CUE:**

Initiating Cue: AOP-7H has been implemented and the CRS directs you to determine the azimuthal power tilt (Tq) using the excore NIs per Block Step IV.F. Are there any questions? You may begin.

Facility:Calvert Cliffs 1&2Job Performance Measure No.: 2008-CCWTask Title:Respond to a CCW LeakTask Number:202.067K/A Reference:026-AA1.05Method of testing: $Actual Performance: _____Simulated Performance:<math>\sqrt{}$ Classroom:Simulator:  $\sqrt{}$ Plant:\_\_\_\_\_

#### **READ TO THE APPLICANT:**

I will explain the initial conditions, which steps to simulate or discuss, and provide initiating cues. When you complete the task successfully, the objective for this job performance measure will be satisfied.

#### Initial Conditions:

- 1. Unit 1 is at 100% power.
- 2. Component Cooling Head Tank LVL Alarm at 1C13
- 3. Component Cooling Head Tank LVL lowering at 1C13
- 4. CNTMT Normal Sump Level Hi Alarm at 1C10
- 5. AOP 7C is implemented

#### Initiating Cue:

CRS has directed you to perform block step V.C. on page 10 of AOP 7C

Task Standard:

Perform block step V.C. of AO7C, determine that CCW leak exist in the CNTMT, and isolate CCW to CNTMT and recommend tripping the reactor and securing RCPs.

**Evaluation Criteria:** 

- 1. All critical steps completed.
- 2. All sequential steps completed in order.
- 3. All time-critical steps completed within allotted time.
- 4. JPM completed within validated time. Completion time may exceed the validated time if satisfactory progress is being made.

**Required Materials:** 

1. Procedures and manuals normally available in the control room General References:

- 1. Alarm manual for 1C13
- 2. AOP 7C

Time Critical Task:

No

Validation Time:

15 minutes

Simulator Setup:

- 1. Reset the simulator IC-24 (100% MOC)
- 2. Insert Malfunction CCW-03 at  $\sim 4.5\%$
- 3. Run the simulator for ~ 2 Minutes or until Alarm K17 on 1C-13 comes in
- 4. Acknowledge alarms
- 5. Freeze simulator

#### ELEMENT (\* = CRITICAL STEP)

Same as element.

TIME START\_\_\_\_\_

\_\_\_\_ Locates AOP7C

ł

Locates Section V.C on page 10

CUE- RO has been assigned to monitor for Reactor Trip Criteria

	1. <b>IF</b> a CC pump is cavitating as indicated by <b>ANY</b> of the following:	Determines that CCW Pumps are not cavitating
• •	Fluctuation in pump motor AMPS Fluctuation in Normal and/or Standby header pressures Excessive pump noise	
	THEN stop the running pump(s).	Determines Not aplicable
	2. IF flooding is occurring,	Determines Not Applicable
	<b>THEN</b> , with the approval of the SM/CRS, perform the following actions:	Determines Not Applicable
	3. <b>IF NO</b> CC Pumps are operating, <b>THEN</b> , with the approval of the SM/CRS, take <b>ALL</b> of the following protective actions.	Determines Not Applicable
	<ul> <li>a. Trip the Reactor.</li> <li>b. Perform Reactivity Control immediate actions of EOP-0, POST TRIP IMMEDIATE ACTIONS.</li> <li>c. Stop ALL RCPs.</li> <li>d. Continue to IMPLEMENT EOP-0.</li> </ul>	Determines Not Applicable
	4. Place IX BYPASS valve, 1-CVC-520- CV,in BYPASS.	Same as element

#### NOTE

ATTACHMENT (2), COMPONENTS COOLED BY COMPONENT COOLING WATER, may be used as a guide to identify the leak.

#### NOTE

The location of the leakage may be indicated by sump alarms or room level alarms. **Cue- CNTMT Sump Hi Level Alarm is in** 

 -*	5. Attempt to identify the location of the Candidate determines that leak is in
	leak.

### ELEMENT (\* = CRITICAL STEP)

<ul> <li>6. IF the leak has NOT been located, THEN consider isolating one CC HX at a time to check for tube leaks.</li> <li>a. Secure Component Cooling Flow to the desired Component Cooling Heat Exchanger PER OI-16, COMPONENT COOLING SYSTEM.</li> <li>b. Shut the applicable CC HX Supply valves:</li> <li>11 CC HX</li> <li>11 CC HX STBY SUPP, 1-CC-147</li> <li>11 CC HX NORM SUPP, 1-CC-148</li> <li>12 CC HX D</li> <li>12 CC HX NORM SUPP, 1-CC-154</li> <li>12 CC HX STBY SUPP, 1-CC-155</li> </ul>	Determine Not applicable
<ul> <li>7. IF the leak can NOT be isolated, AND the SM determines that the leakage is excessive, THEN commence a normal Unit shutdown PER OP-3, NORMAL POWER OPERATION, and/or OP-4, PLANT SHUTDOWN FROM POWER OPERATION TO HOT STANDBY.</li> <li>*8. IF the leak has been located, AND Unit conditions permit the leak to be isolated, THEN isolate the leak.</li> </ul>	Determines Not applicable Recommends isolating CCW to containment and tripping the reactor then securing RCPs
TIME STOP	

Examiner Note:	The task is complete when the CCW to containment has been isolated AN	
	the CRO recommends tripping the reactor and securing the RCPs.	

÷

# Verification of Completion

Job Performance Measure Number: 2008-CCW
Applicant:
NRC Examiner:
Date Performed:
Facility Evaluator:
Number of Attempts:
Time to Complete:
Follow up Question:
Applicant Response:
Result: SAT UNSAT
Examiner's Signature and Date:

### APPLICANT'S CUE SHEET

### **INITIAL CONDITIONS:**

Initial Conditions:

- 1. Unit 1 is at 100% power.
- 2. Component Cooling Head Tank LVL Alarm at 1C13
- 3. Component Cooling Head Tank LVL lowering at 1C13
- 4. CNTMT Normal Sump Level Hi Alarm at 1C10
- 5. AOP 7C is implemented
- :

### **INITIATING CUE:**

CRS has directed you to respond to the loss of CCW by performing block step V.C. on page 10 of AOP 7C

Facility: Calvert Cliffs 1&2	Job Performance Measure No.: 2008-IA1
Task Title: Respond to loss of IA while s	shutdown
Task Number: 202.070	
K/A Reference: I/A- A-2.01	
Method of testing:	
Simulated Performance: $\underline{\checkmark}$	Actual Performance:
Classroom: Simulator: _	Plant:

#### **READ TO THE APPLICANT:**

I will explain the initial conditions, which steps to simulate or discuss, and provide initiating cues. When you complete the task successfully, the objective for this job performance measure will be satisfied.

Initial Conditions:

- 1. Unit One is in Mode 6 performing a core offload.
- 2. A loss of Instrument Air is occurring and AOP-7D has been implemented.
- 3. There are no temporary air compressors connected or available.
- 4. The CRS has directed you to assist with implementing AOP-7D.

#### Initiating Cue:

Initiating Cue: You have been directed by the Unit One CRS to investigate the cause of lowering Instrument Air header pressure IAW AOP-7D, Block Step VI.A.

Task Standard:

This JPM is complete when actions are taken to respond to an Instrument Air leak and 11 IA Dryer is bypassed and isolated.

**Evaluation Criteria:** 

- **1.** All critical steps completed.
- 2. All sequential steps completed in order.
- 3. All time-critical steps completed within allotted time.
- 4. JPM completed within validated time. Completion time may exceed the validated time if satisfactory progress is being made.

**Required Materials:** 

1. Procedures and manuals normally available in the plant

General References:

- 1. AOP-7D
- 2. OI-19

Time Critical Task:

No

· +

Validation Time:

30 minutes

Simulator Setup:

1. NONE

#### ELEMENT (\* = CRITICAL STEP)

1

TIME START			
	Locate AOP-7D step VI.A	Same as element.	
1.	IF Temporary Air Compressor is supplying air system,	Determines that this step is N/A.	
CUE: IA H comp AUT	eader pressure is 82 PSIG and slowly lowering, pressor (1-HS-2062 in SPEED) and 12 Compres O) but NOT running.	11 IA Compressor is running as the lead ssor is the standby compressor (1-HS-2064 in	
<u>NOTE</u> :	ATTACHMENT (1), CRITICAL VALVES CONTROLLED BY IA (B0078), lists the pressure required to control the critical valves.		
2.	WHEN IA header pressure lowers to 93 PSIG, THEN ensure that the standby Instrument Air Compressor is running.	Observes indications and determines that that only the lead Instrument Air Compressor (11) is running.	
CUE: After 12 IAC is placed in SPEED, it starts and runs properly. IA pressure is still slowly lowering though, even with both compressors now running.			
2.1	<b>IF</b> the standby IA Compressor fails to auto start, <b>THEN</b> place the standby Compressor handswitch to the SPEED position.	Determines step is applicable and places 1-HS-2064 in SPEED. Observes indications that 12 IAC is running.	
NOTE:	ATTACHMENT (2), <u>VALVES SUPPLIED E</u> Saltwater Air loads.	BY SALTWATER AIR, lists	
CUE:	The Control Room has performed step 3, continue.		
3.	IF IA pressure is less than 90 PSIG and lowering, THEN start 11 and 12 SALTWATER AIR COMPRs.	Determines step has been completed in Control Room.	
CUE:	11 IA Dryer is in service and appears to be inac	lvertently blowing down.	
<u>NOTE</u> :	The IA Dryer malfunction light will be brightly lit for the inservice IA Dryer and the dryer will de-energize with both chambers in service if IA Pressure has lowered to $93 \pm 1$ PSIG.		
4.	IF IA Dryer is the cause of the lowering IA pressure, THEN bypass the in service IA Dryer.	Determines step is applicable.	

#### ELEMENT (\* = CRITICAL STEP)

and the second second

CUE:	IA-148 indicates open.	
*	a. Open the IA Dryer Bypass valve, 1-IA-148.	Opens valve.
CUE:	IA-147 and IA-100 indicate shut.	
*	b. IF 11 Dryer is in service, THEN shut 11 Dryer Inlet and Outlet valves:	Shuts IA-147 and IA-100.
	<ul> <li>(Inlet Valve) 1-IA-147</li> <li>(Outlet valve) 1-IA-100</li> </ul>	
. <u></u>	c. <b>IF</b> 12 Dryer is in service, <b>THEN</b> shut 12 Dryer Inlet and Outlet valves:	Determines step is N/A
	<ul><li>(Inlet Valve) 1-IA-1100</li><li>(Outlet valve) 1-IA-1101</li></ul>	
CUE: IA	Header pressure is starting to rise.	
CUE: Th	ne CRS does not wish to place the standby IA Dryer	r in service at this time.
	d. Shift to the standby Air Dryer <b>PER</b> OI- 19. INSTRUMENT AIR, as desired.	Determines step is N/A

<b>TERMINATING CUE:</b>	The task is complete when 11 IA Dryer is bypassed and isolated.
	No further actions are required. The evaluator is expected to end
	the JPM.

TIME STOP

Appendix	С

# Verification of Completion

Job Performance Measure Number: 2008-IA1				
Applicant:				
NRC Examiner:				
Date Performed:				
Facility Evaluator:				
Number of Attempts:				
Time to Complete:				
Follow up Question:				
Applicant Response:				
Result:   SAT   UNSAT				
Examiner's Signature and Date:				

### APPLICANT'S CUE SHEET

### **INITIAL CONDITIONS:**

- 1. Unit One is in Mode 6 performing a core offload.
- 2. A loss of Instrument Air is occurring and AOP-7D has been implemented.
- 3. There are no temporary air compressors connected or available.
- 4. The CRS has directed you to assist with implementing AOP-7D.

### **INITIATING CUE:**

Initiating Cue: You have been directed by the Unit One CRS to investigate the cause of lowering Instrument Air header pressure IAW AOP-7D, Block Step VI.A. Are there any questions? You may begin..

Facility: Calvert Cliffs 1&2	Job Performance Measure No.: 2008-4KV					
Task Title: De-energize a 4 KV Bus during a control room evacuation						
Task Number: 004.001						
K/A Reference: 062-A4.04						
Method of testing:						
Simulated Performance: $\underline{}$	Actual Performance:					
Classroom: Simulator:	Plant:					

#### READ TO THE APPLICANT:

I will explain the initial conditions, which steps to simulate or discuss, and provide initiating cues. When you complete the task successfully, the objective for this job performance measure will be satisfied.

**Initial Conditions:** 

- 1. Unit One has implemented AOP9A due to a control room fire.
- 2. The CRS has assigned you to perform Block step IV BU, denergize 4KV Bus 12
- 3. All steps of AOP-9A up to step BU have been completed

Initiating Cue:

You are the U-1 RO and the CRS has directed you to perform step IV. BU of AOP-9A to de-energize 12 4KV Bus.

Task Standard:

This JPM is complete when 12 4KV Bus is de-energized.

į.

Evaluation Criteria:

- 1. All critical steps completed.
- 2. All sequential steps completed in order.
- 3. All time-critical steps completed within allotted time.
- 4. JPM completed within validated time. Completion time may exceed the validated time if satisfactory progress is being made.

#### Required Materials:

1. Procedures and manuals normally available in the plant

General References:

- **1. AOP-9**A
- 2. OI-27C
- 3. CCNPP Industrial Safety Manual

Time Critical Task:

No

+

Validation Time: 30 minutes

Simulator Setup:

1. NONE
#### ELEMENT (\* = CRITICAL STEP)

TIME START\_\_\_\_\_

CUE: CRS Directs performing AOP 9A step IV BU. All steps up to BU have been performed

Locate AOP-9A step IV.BU	Same as element.
* Determine PPE requirements per Industrial Safety Manual	Voltage Rated Gloves Leather Shoes FRCs – 8/ca/cm Hardhat Safety Glasses Face-shield – 8/cal/cm
1 Open the Feeder Breakers for 4KV Bus 12: as follows:	Hearing Protection
* a. Remove the CLOSE Fuses for SERVICE TRANSF. U-4000-11, Breaker 152-1201.	Opens the upper cabinet door for breaker 152-1201 and removes the close fuses
CUE: The close fuses for SERVICE TRANSF. U-4000-11, I from their holder	Breaker 152-1201 are removed
* b. Depress the TRIP pushbutton for breaker 152- 1201.	Locates breaker 152-1201 and opens the breaker verifies the breaker is open.
* c. Remove the CLOSE Fuses for SERVICE TRANSF. U-4000-21, Breaker 152-1209.	Open the upper cabinet door for breaker 152-1209 and removes the close fuses.
CUE: The close fuses for SERVICE TRANSF. U-4000-11, I from their holder	Breaker 152-1209 are removed
* d. Depress the TRIP pushbutton for breaker 152- 1209	Locates breaker 152-1209 and opens the breaker verifies the breaker is open.
2. Notify 1C43 that 4KV Bus 12 has been de-energized.	Notify the evaluator that 4KV Bus 12 has been de-energized
<b>TERMINATING CUE:</b> The task is complete when that the 12 4KV Bus is de-e	candidate has informed the evaluator energized

TIME STOP

# Verification of Completion

Job Performance Measure Number: 2008-4KV
Applicant:
NRC Examiner:
Date Performed:
Facility Evaluator:
Number of Attempts:
Time to Complete:
Follow up Question:
Applicant Response:
Result: SAT UNSAT
Examiner's Signature and Date:

## APPLICANT'S CUE SHEET

### **INITIAL CONDITIONS:**

- 1. Unit One has implemented AOP9A due to a control room fire.
- The CRS has assigned you to perform Block step IV BU, denergize
   4KV Bus 12.
- 3. All steps of AOP-9A up to BU have been completed.

**INITIATING CUE:** 

You are the U-1 RO and the CRS has directed you to perform step IV. BU of AOP-9A to de-energize 12 4KV Bus.

Appendix C Job Performance Measure

Facility: <b>Caivert Chiris 162</b> Job	D. C. Marana Marana No. A 2000 MCIN			
The Introduction of the marker MCIV about due to a	acility: Calvert Cliffs 1&2 Job Performance Measure No.: 2008-MISIV			
Task litle: Locally verify wish v shut due to a	Control Room Evacuation			
Task Number: 083.024				
K/A Reference: 039-A4.01				
Method of testing:				
Simulated Performance: Act	al Performance:			
Classroom: Simulator:	Plant: $\underline{\checkmark}$			
READ TO THE APPLICANT:				
I will explain the initial conditions, which step initiating cues. When you complete the task st performance measure will be satisfied.	s to simulate or discuss, and provide accessfully, the objective for this job			
Initial Conditions:				
1. Unit One has implemented AOP9A du	e to a control room fire.			
2. The CRS has assigned you to perform Block step IV AC of AOP 9A to verify locally that MSIVs are shut.				
locally that MSIVs are shut.	•			
locally that MSIVs are shut.	-			
locally that MSIVs are shut.				
locally that MSIVs are shut. <u>Initiating Cue:</u> Initiating Cue: You have been directed by the MSIVs are shut IAW AOP-9A, Block Step IV	Unit One CRS to locally verify that .AC.			
locally that MSIVs are shut. <u>Initiating Cue:</u> Initiating Cue: You have been directed by the MSIVs are shut IAW AOP-9A, Block Step IV <u>Task Standard:</u>	Unit One CRS to locally verify that .AC.			
Iocally that MSIVs are shut.         Initiating Cue:         Initiating Cue: You have been directed by the MSIVs are shut IAW AOP-9A, Block Step IV         Task Standard:         This JPM is complete when MSIV 11 & 12 have the evaluator.	Unit One CRS to locally verify that .AC. /e been verified shut and reported to			

Appendix C Job Performance Measure

**Evaluation Criteria:** 

- 1. All critical steps completed.
- 2. All sequential steps completed in order.
- 3. All time-critical steps completed within allotted time.
- 4. JPM completed within validated time. Completion time may exceed the validated time if satisfactory progress is being made.

Required Materials:

1. Procedures and manuals normally available in the plant

General References:

- 1. AOP-9A
- 2. OI-8E

Time Critical Task:

No

Appendix C Job Performance Measure

ł

Validation Time: 30 minutes

Simulator Setup:

1. NONE

#### ELEMENT (\* = CRITICAL STEP)

TIME START \_\_\_\_\_

CUE: CRS Directs performing	AOP 9A step IV C.	
Note: Candidate should comply	with all RP procedures and p	olicies for entering the RCA.
Note: Candidate should determin	ne stay time for heat stress fo	r entering the MSIV room.
Locate AOP-9A step IV.0	2	Same as element.
—* 1. Shut Instrument Air Iso Hydraulic Pump, 1-IA-10 CUE: 11 MSIV is open as indic	lation to 11 MSIV 069. cated	Same as element
* 2. IF 11 MSIV is open, THEN		Determines that 11 MSIV is open
* a. Remove the Dump Sole of the following: 11 MSIV Dump SV Chan OR	enoid Valve Cap on <b>ONE</b> nel A, 1-MSH-4042A-SV	Same as element
11 MSIV Dump SV Chan * b. Place a wrench on the stom put	nel B, 1-MSH-4042B-SV selected Dump Solenoid	Same as element
* c. Rotate the wrench in th (approximately five turns)	ne clockwise direction to bleed hydraulic fluid	Same as element
<ul> <li>* 3. Shut Instrument Air Isc Hydraulic Pump, 1-IA-107</li> <li>CUE: 12 MSIV is open as indic</li> </ul>	olation to 12 MSIV 70. cated	Same as element
* 4. IF 12 MSIV is open, THEN:		Determines that 12 MSIV is open
<pre>* a. Remove the Dump Sole     of the following:     12 MSIV Dump SV Chan     OR</pre>	enoid Valve Cap on <b>ONE</b> nel A, 1-MSH-4047A-SV	Same as element
12 MSIV Dump SV Chan * b. Place a wrench on the	nel B, 1-MSH-4047B-SV selected Dump Solenoid	Same as element
<pre>stem nut* c. Rotate the wrench in th     (approximately five turns) </pre>	e clockwise direction ) to bleed	Same as element
hydraulic fluid back to the 5. Notify 1C43 the MSIVs a	reservoir. Tre shut.	Notify evaluator that MSIVs shut
TERMINATING CUE:	The task is complete when that the MSIVs are verified	candidate has informed the evaluator shut.

TIME STOP

# Verification of Completion

Job Performance Measure Number: 2008-MSIV	
Applicant:	
NRC Examiner:	
Date Performed:	
Facility Evaluator:	
Number of Attempts:	
Time to Complete:	
Follow up Question:	
Applicant Response:	
Result: SAT UNSAT	
Examiner's Signature and Date:	

## APPLICANT'S CUE SHEET

## **INITIAL CONDITIONS:**

- 1. Unit One has implemented AOP9A due to a control room fire.
- The CRS has assigned you to perform Block step IV AC of AOP 9A to verify locally that MSIVs are shut.

### **INITIATING CUE:**

You have been directed by the Unit One CRS to locally verify that MSIVs are shut IAW AOP-9A, Block Step IV.AC Are there any questions? You may begin.