

Official Transcript of Proceedings
NUCLEAR REGULATORY COMMISSION

Title: Advisory Committee on Reactor Safeguards

Docket Number: (n/a)

Location: Rockville, Maryland

Date: Wednesday, June 4, 2008

Work Order No.: NRC-2223

Pages 1-274

NEAL R. GROSS AND CO., INC.
Court Reporters and Transcribers
1323 Rhode Island Avenue, N.W.
Washington, D.C. 20005
(202) 234-4433

DISCLAIMER

UNITED STATES NUCLEAR REGULATORY COMMISSION'S
ADVISORY COMMITTEE ON REACTOR SAFEGUARDS

June 4, 2008

The contents of this transcript of the proceeding of the United States Nuclear Regulatory Commission Advisory Committee on Reactor Safeguards, taken on June 4, 2008, as reported herein, is a record of the discussions recorded at the meeting held on the above date.

This transcript has not been reviewed, corrected and edited and it may contain inaccuracies.

1 UNITED STATES OF AMERICA
2 NUCLEAR REGULATORY COMMISSION

3 + + + + +

4 553nd MEETING

5 ADVISORY COMMITTEE ON REACTOR SAFEGUARDS

6 (ACRS)

7 + + + + +

8 WEDNESDAY

9 JUNE 4, 2008

10 + + + + +

11 ROCKVILLE, MARYLAND

12 + + + + +

13 The Advisory Committee meeting was held at
14 the Nuclear Regulatory Commission, Two White Flint
15 North, Room T2B3, 11545 Rockville Pike, at 8:30 a.m.,
16 Dr. William Shack, Chairman, presiding.

17 COMMITTEE MEMBERS PRESENT:

18 WILLIAM SHACK, Chairman

19 MARIO V. BONACA, Vice Chairman

20 JOHN D. SIEBER, Member-at-Large

21 SANJOY BANERJEE, Member

22 J. SAM ARMIJO, Member

23 DANA A. POWERS, Member

24 SAID ABDEL-KHALIK, Member

25 OTTO L. MAYNARD, Member

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 COMMITTEE MEMBERS PRESENT (Continued):

2 JOHN STETKAR, Member

3 DENNIS C. BLEY, Member

4 MICHAEL CORRADINI, Member

5 GEORGE E. APOSTOLAKIS, Member

6 NRC STAFF PRESENT:

7 MICHAEL SALAY

8 DAVID BESSETTE

9 RICHARD LEE

10 MARK CUNNINGHAM

11 MARK FRANOVICH

12 HAROLD VANDER MOLLEN

13 PETE APPIGNANI

14 GETACHEW TESFAYE

15 JOE COLACCINO

16 BONNIE SCHNETZLER

17 PATRICIA HOLOHAN

18 SCOTT MORRIS

19 TIM REED

20 NANETTE GILLES

21 LOU CABELLAS

22 FRANK GILLESPIE

23 BILL RACKLEY

24 JAKE ZIMMERMAN

25 SANDRA SLOAN

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 ALSO PRESENT:

2 MARTY PARESE

3 JEFF TUCKER

4 TODD OSWALD

5 VIC FREGONESE

6

7

8

9

10

11

12

13

14

15

16

17

18

19

20

21

22

23

24

25

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

TABLE OF CONTENTS

	<u>PAGE</u>
1	
2	
3	Introduction, Chairman Shack 5
4	ARTIST Test Program
5	Member Sam Armijo 8
6	Richard Lee 9
7	Michael Salay 10
8	Risk Assessment Standardization Project 79
9	Overview of the U.S. Evolutionary
10	Power Reactor Design 128
11	Status of the Development of Rules and
12	Regulatory Guidance in the areas of
13	Safeguards and Security 226
14	Adjourn
15	
16	
17	
18	
19	
20	
21	
22	
23	
24	
25	

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

P R O C E E D I N G S

(8:30 a.m.)

CHAIRMAN SHACK: The meeting will come to order.

This is the first day of the 553rd meeting of the Advisory Committee on Reactor Safeguards. During today's meeting, the Committee will consider the following: ARTIST test program; Risk Assessment Standardization Project; an overview of the Evolutionary Power Reactor, EPR, design; status of the development of rules and regulatory guidance in the area of safeguards and security; status of quality assessment of selected research projects; and preparation of ACRS reports.

The meeting is being conducted in accordance with provisions of the Federal Advisory Committee Act. Mr. Sam Duraiswamy is the Designated Federal Official for the initial portion of the meeting.

We have received no written comments or requests for time to make oral statements from members of the public regarding today's session. We have representatives of the State of Vermont on the phone bridge line listening to the discussion of the topics scheduled for today's meeting. To preclude

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 interruption of the meeting, the phone line will be
2 placed in a listen in mode during the presentations
3 and Committee discussion.

4 A transcript of portions of the meeting is
5 being kept, and it is requested that speakers use one
6 of the microphones, identify themselves, and speak
7 with sufficient clarity and volume so they can be
8 readily heard.

9 I will begin with some items of current
10 interest. I will point out you have a package of
11 items of interest that has been presented to you.
12 There are some speeches by the Commissioners of
13 particular interest for our educators on the
14 Committee, and an SRM on the integrated digital
15 instrument and control test facility in the United
16 States that you might want to look at.

17 I would also remind the members that we're
18 scheduled to interview two candidates during lunchtime
19 today. So don't run off without making arrangements
20 to get back for those interviews.

21 I'm also pleased to announce the
22 appointment of Dr. Hossein Hourbakhsh as Senior
23 Technical Advisory for Reactor Safety. This is a well
24 deserved promotion, and congratulations to Hossein.

25 (Applause.)

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 CHAIRMAN SHACK: We have the following
2 four summer interns who came on board recently. All
3 of them will be here until mid-August. Desiree Davis
4 is a senior at the University of Maryland, College
5 Park, studying psychology and French language and
6 literature. Desiree is a member of the Golden Key
7 International Honor Society --

8 MEMBER APOSTOLAKIS: We can't see here.
9 (Laughter.)

10 CHAIRMAN SHACK: -- and serves as the
11 Vice President of Community Service for the University
12 of Maryland Chapter of the National Society of
13 Collegiate Scholars.

14 James Clark, III, is a senior attending
15 Virginia Union University in Richmond, Virginia,
16 majoring in accounting. James is a member of Phi Beta
17 Lambda and the Accounting Club.

18 Kyle Thomas is a senior at the
19 Pennsylvania State University studying energy,
20 business, and finance, as well as economics. Kyle is
21 actively involved in planning and organizing the 2008
22 homecoming celebration at Penn State.

23 Eric DiGiovanni is a senior at Penn State
24 University majoring in finance with a minor in
25 psychology. He is currently the president of Phi

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 Gamma Nu professional fraternity and has overall
2 responsibility for planning and organizing the
3 homecoming celebration.

4 All of you, welcome aboard.

5 (Applause.)

6 CHAIRMAN SHACK: Our first topic this
7 morning will be the ARTIST test program, and Sam will
8 be leading us through that.

9 MEMBER ARMIJO: Thank you, Mr. Chairman.

10 The ARTIST test program was going to be
11 reviewed for us by a group of people from the Paul
12 Scherrer Institute, as well as the staff. There was
13 a mix-up in travel plans, and the PSI people will not
14 be here this morning. So the staff will try and cover
15 that entire scope.

16 The program is titled ARTIST is for
17 aerosol trapping in a steam generator, focused on
18 issues related to aerosols and steam generator tube
19 rupture.

20 The speakers will be first Richard Lee of
21 the staff, who will make some comments and introduce
22 the subject, and the Michael Salay will carry the
23 ball, I guess, both for the staff and for Paul
24 Scherrer Institute.

25 Richard.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 MEMBER POWERS: Before we get started, I
2 assisted the staff in this area. So I can certainly
3 answer questions of clarification in fact, but if I am
4 asked to provide an opinion, undoubtedly I will. You
5 can just discount it, as you usually do.

6 (Laughter.)

7 CHAIRMAN SHACK: Okay. With those
8 clarifying remarks, Richard.

9 MR. LEE: Thank you.

10 Richard Lee from the Office of Research.

11 The office has been participating in this
12 from ten conceptual design of this facility since
13 2000. We entered into a formal agreement around 2003,
14 participation in not all phases of this experiment
15 because they're about seven or eight phases of the
16 program. Mike will tell you what that are. We only
17 participated in the phase of regulatory significance
18 for use for us.

19 And also this program, the data from there
20 is also supposed to address one of the items under the
21 steam generator action plan Item 3.3(a), and that has
22 to do with getting enough information to look at the
23 sour term attenuation in the secondary side of a dry
24 steam generator, and that has related to the steam
25 generator tube rupture under severe accident

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 conditions, a lot of issues related to that that ACRS
2 was involved with the steam generator action plan.

3 That 3.3(a) is how we're supposed to
4 provide some information on that. That part has been
5 complete. The separate facts in the experiment has
6 been completed. So last year in November we
7 transmitted a letter to NRR telling what our findings
8 are, and I think Mike will tell you what it is today.

9 CHAIRMAN SHACK: Okay. Mike, can you just
10 hold for a second? We have to open the bridge line.

11 (Pause in proceedings.)

12 CHAIRMAN SHACK: I think we can proceed
13 now.

14 MR. SALAY: Thank you, Mike.

15 We'll start with NRC's findings on the
16 ARTIST test in aerosol, retention on the secondary
17 side of steam generators, and I'm first going to go
18 over some background and an overview of the program
19 and then discuss the ARTIST test program pertaining to
20 the steam generator action plan, our major
21 observations about the ARTIST program, modifications,
22 whom they're developed for based on the ARTIST tests,
23 and then I'll show some conclusions, and I guess for
24 that we'll hear from Paul Scherrer where they will
25 present more specifically and more detailed data and

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 some of the risk analyses just to maybe briefly go
2 over some of the data.

3 Steam generator tube rupture accidents,
4 it's an important bypass accident. It's a design
5 basis event. Plants are designed to cope, and they
6 have for all events to date. I think there have been
7 about a dozen events, and it addresses severe accident
8 only if something else happens, which is interpreted
9 as operator error.

10 Induced steam generator tube rupture is
11 also a concern. Plants regularly operate with
12 detectable flaws in tubes, and mostly these are stress
13 corrosion cracking, but there's also crevice corrosion
14 at the tube support plate where the chemistry is
15 somewhat different. So there's a limit on flaw size
16 at which plants are allowed to continue operating.

17 And in the event of a severe accident, the
18 heat transfer from the core to the primary pressure
19 boundary in this weakened structure, some of the
20 vulnerable locations are the hot leg nozzle, the surge
21 line depressurizer, and what we're interested in today
22 is the steam generator tubes.

23 We currently cannot reliably predict when
24 and where failure will occur.

25 MEMBER BANERJEE: This would only happen

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 if there was an operator error or in any case?

2 MR. SALAY: I think it's expected to be --
3 what are you asking?

4 MEMBER BANERJEE: The heat transfer from
5 core to primary --

6 MR. SALAY: Well, if you have an operator
7 error, but you have more heat transfer, if there is a
8 severe accident, you have release of --

9 MEMBER BANERJEE: Right, but without an
10 operator error, if it was just a steam generator
11 rupture, would it --

12 MR. SALAY: Plants are designed to cope,
13 and so without progression to severe accident. So you
14 do get heat transfer, but --

15 MEMBER BANERJEE: I'm talking about the
16 first point. Would the first point occur without
17 operator error or not?

18 MR. SALAY: I don't think the temperatures
19 will be that high to --

20 MEMBER BANERJEE: Won't happen without an
21 operator error.

22 MR. SALAY: We're ten for ten.

23 MR. BESSETTE: This is David Bessette.

24 This is like a station blackout. Oh,
25 sorry. This is like a station blackout scenario where

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 the secondary side dries out and the core overheats
2 and temperatures get very hot.

3 MEMBER BANERJEE: This is even if the
4 emergency cooling works?

5 MR. BESSETTE: No. There is no ECCS here.

6 MEMBER BANERJEE: Somebody clarify it.

7 MEMBER STETKAR: I'll try to clarify it.
8 The first slide, Slide No. 3, pertains to steam
9 generator tube rupture as the first event. That was
10 the initiating event. It can only progress to core
11 damage if, in simplified terms, if there's an operator
12 error. There could be a bunch of equipment failures,
13 but now he's talking about other scenarios in which
14 the tube rupture is a consequence of the progression
15 of other events.

16 Those tend to be high pressure scenarios
17 that are progressing in the direction of core damage.
18 So for example, a complete station blackout is an
19 example of that.

20 MEMBER BANERJEE: Okay.

21 MEMBER STETKAR: So that could involve
22 operator error. It could involve other equipment
23 failures, but these tend to be high pressure core
24 damage trajectory type scenarios.

25 MEMBER SIEBER: The important point is the

1 core's damage and the steam generator tubes are
2 ruptured.

3 MEMBER STETKAR: That's right, in the
4 second case. In the first case the tube rupture is
5 the first thing that happens to make core damage.

6 MEMBER BANERJEE: But this is a chain of
7 events.

8 MEMBER STETKAR: That's correct.

9 MEMBER BANERJEE: It's not just to --

10 MEMBER BLEY: The tail end of a chain of
11 events.

12 MEMBER BANERJEE: And the probability of
13 such a chain is pretty low, right?

14 MEMBER POWERS: No, you can't -- the issue
15 of induced steam generator is that it may be a natural
16 consequence of core damage.

17 MEMBER SIEBER: Right.

18 MEMBER POWERS: Okay? But it's not a
19 bunch of events with prescribed probability. Nobody
20 knows the answer to this right now, but it is a
21 subject of substantial analysis.

22 On steam generator initiated events, we're
23 ten for ten. There have been ten of them. The plants
24 have coped every time, and in fact, I mean, what we've
25 come to believe, as long as you just rupture one tube,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 it's very difficult for the plant not to cope because
2 the operators have typically lots of time to interact.

3 As the number of tubes have ruptured to
4 initiate the event goes up, you get to the point where
5 there's not enough time for the operator to act.
6 Okay? And we spent a lot of time in this Committee
7 looking at can you get rupture of a tube propagation
8 that cause ruptures to adjacent tubes, and no one has
9 successfully found a mechanism for that to happen.
10 Maybe it happens naturally, but --

11 MEMBER SIEBER: Who knows? .

12 MEMBER POWERS: So really interest in
13 steam generator tube ruptures is now focused very much
14 on the induced variety where maybe it's all accidents
15 progress naturally to a bypass accident. But, I mean,
16 that's the subject of research.

17 Here Mike is going to talk about, okay, if
18 you have this, what are the consequences.

19 MEMBER BANERJEE: So you fostered it. It
20 occurred.

21 MEMBER SIEBER: Yes.

22 CHAIRMAN SHACK: At last the potential, as
23 John said, every high pressure core damage sequence
24 where you get to this point, one of these is going to
25 fail. One of these locations will fail.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 MEMBER BANERJEE: Thank you. I think I've
2 got the picture.

3 MEMBER ABDEL-KHALIK: What does the first
4 bullet mean? The transfer in and of itself does not
5 weaken structures.

6 MR. LEE: Let me go back. Historically
7 what happened has to do with the station blackout
8 analysis that we have done. Remember all the heat
9 transfer of the Westinghouse 1-7 scale discussion, the
10 hot leg counter-current flow and the steam generator.
11 If you have a loop seal blockage, you will have
12 recirculation back, and this thing is related to that
13 issue.

14 So we are looking at whether -- you see,
15 we have done a lot of analysis looking at whether the
16 hot leg failed first. You fail at other location and
17 then the steam generator tube. Remember all of those
18 exercises we have done, calculations we have done.
19 Among those, this is sort of implying that the heat
20 transfer weakened the structure either at the hot leg
21 nozzles. It can be at the surge line. It could be at
22 the steam generator tube. So there's a range of
23 calculations. It's very high temperature.

24 MEMBER ARMIJO: All of this is beyond the
25 scope of this presentation. This presentation starts

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 with a damaged core and a ruptured tube, and you're
2 studying a particular phenomenon that's this aerosol,
3 transferred decontamination and whatever.

4 MR. LEE: Yes, and this is a dry steam
5 generator because in one of those analyses you
6 postulated one of steam generator secondary side. The
7 safety valve has lifted, and that will close. So you
8 have a drive steam generator scenario on the secondary
9 side.

10 And the question here is do you get the
11 entrainment of these aerosol and retention of fission
12 products that release from the steam generator tube
13 rupture to the secondary side. That's what he's
14 looking at. That is what this experiment is about.

15 CHAIRMAN SHACK: But these temperatures
16 are going like to six, to 800 C. at the peak. I mean,
17 so these things are heating up.

18 MEMBER ARMIJO: But as we get into it,
19 these experiments are conducted at low temperature,
20 and somewhere along the line I'd like the staff to
21 tell me that's important or not important or whatever.

22 MEMBER SIEBER: It's the chemical and
23 isotopic species that are important when you're
24 looking for the decontamination factor.

25 MEMBER ARMIJO: Right.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MR. LEE: We are looking at the aerosols.
2 So the size matters and so forth. So I'm sure Mike
3 will discuss this.

4 (Laughter.)

5 MR. SALAY: Okay. That's enough of that.

6 Anyway, there's a diagram of a few natural
7 circulation flows. There are two situations to
8 consider. One regular loop seals are intact and one
9 regular loop seals are open. You have much freer flow
10 when your loop seals are open. Flow can go through
11 the core, directly through your hot leg, through the
12 entire steam generator, back through your cold leg,
13 and back to the core again.

14 However, when your loop seals are intact,
15 there is more resistance. In the core you have flow
16 going down and up at the same time. You have counter-
17 current flow on your hot leg, and there's flow through
18 some tubes in one direction. In some generator tubes
19 the flow is in the other direction in other tubes.

20 MEMBER BANERJEE: The counter-current flow
21 in this scenario is just thermally stratified flow,
22 right?

23 MEMBER ARMIJO: Within one pipe.

24 MEMBER BANERJEE: within one pipe.

25 MR. SALAY: Yes.

1 MEMBER BANERJEE: So you've got the hot
2 stuff going on the top and the cold stuff at the
3 bottom.

4 MR. SALAY: Yeah, hot on top.

5 Okay. So in the event a steam generator
6 tube ruptures, the flow would come from the hot leg
7 into the lower plenum, through the tubes, out through
8 a break, up through the outside of the steam generator
9 tubes, passing some support plates, out through your
10 separators and through your dryers, and out by some
11 manner through secondary safety relief valve where
12 it's postulated.

13 And we look at where could aerosol
14 possibly get retained, and when your flow enters the
15 steam generator tube, there's a contraction in the
16 flow and aerosol can't follow the stream line, and
17 larger ones get preferentially removed and impact on
18 the top of the lower plenum surface.

19 And you can also get retention inside the
20 tubes themselves before you reach the break. That's
21 a turbulent deposition. It's postulated that
22 immediately in the vicinity of the break turbulent
23 deposition could enhance retention. It's postulated
24 that settling could occur on the top of support
25 plates, and we just have general attention far away

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 from the break.

2 Thermophoretic deposition on the steam
3 generator envelope was also considered.

4 MEMBER BANERJEE: Well, what are the
5 particle sizes?

6 MR. SALAY: I'll go in a second, two or
7 three, a few slides from here, and that's actually a
8 subject of discussion and psi, and we don't quite
9 agree on what --

10 MEMBER BANERJEE: Because turbine
11 deposition depends very much on the size spectrum.

12 MR. SALAY: Yeah, I'll go over in a few
13 slides.

14 And so anyway, they can settle perhaps on
15 top of the tube support plates, perhaps better
16 thermophoretic deposition on steam generator envelope,
17 perhaps retained in the separators and dryers, and
18 then you'd have another flow contraction at the safety
19 valve.

20 And aerosol retention processes, the
21 removable mechanisms are high size dependent, and for
22 laminar flow, the dominant ones are impacting where
23 particles can't fall. The stream line is going around
24 the flow obstacles, a flow obstacle settling, just
25 falling out, and interception, which just accounts for

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 the fact that the particle isn't a point, but actually
2 has a physical size.

3 And so if the center of mass goes near
4 enough to the particle, it can interact. For example,
5 acetylene is r-squared dependent. Internal velocity
6 goes up with r-squared.

7 MEMBER BANERJEE: Settling is?

8 MR. SALAY: Settling is just falling out.
9 Gravity can receive dust. It falls down.

10 MEMBER BANERJEE: This is in a laminar.

11 MR. SALAY: Yes.

12 MEMBER SIEBER: But the velocities are
13 fairly high.

14 MR. SALAY: Yes. There are certain
15 regions where velocities are low. So we're looking at
16 regions with high velocity and also regions at lower
17 velocity.

18 MEMBER SIEBER: Ten to the second or
19 something like that.

20 MR. SALAY: There's also impaction.

21 MEMBER BANERJEE: Well, the reason I say
22 this is if the flow is turbulent, settling is much
23 slower.

24 MEMBER SIEBER: Yes.

25 MR. SALAY: Yeah, and settling. Yeah,

1 there are regions where it is turbulent, most
2 definitely, and as your particle gets smaller, you get
3 to the point where they can be moved around by the
4 individual gas molecules and effectively diffused
5 through them, and so very small particles get moved
6 preferentially by fusion, and as your particles get
7 larger and larger, they can be removed by impaction or
8 settling or interception.

9 MEMBER ABDEL-KHALIK: Are we talking about
10 the primary side of the tubes or the secondary?

11 MR. SALAY: Just the general. I mean, we
12 are talking -- this is general, anywhere, but the
13 project will be on the secondary side. The primary
14 side, you're turbulent. Your flow is around 100
15 meters per second. So it's kind of fast.

16 MEMBER BANERJEE: So you can still get
17 removal by impaction.

18 MEMBER SIEBER: Yes.

19 MEMBER ARMIJO: The term "bounce," is
20 there form definition or is it just like bouncing a
21 particle off of a --

22 MR. SALAY: Well, it was noticed that I
23 think filter manufacturers, that at certain kinetic
24 energies, the particles below a certain kinetic
25 energy, the parties just tend to stick, but above

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 other kinetic energies they just hit and come right
2 off.

3 MEMBER BANERJEE: It depends on the
4 elasticity of the article and whether it's a dendritic
5 particle. What is it, I mean?

6 MR. SALAY: I'm just talking about what
7 was observed, and --

8 MEMBER BANERJEE: It comes up with real
9 aerosols that bounce?

10 MR. SALAY: yeah.

11 MEMBER SIEBER: Yeah.

12 MEMBER BANERJEE: It sounds enormous. I
13 mean, these are what, dendritic structures or what are
14 they?

15 MEMBER POWERS: It depends on which
16 particle it looks like.

17 MEMBER BANERJEE: I see. If they're
18 little, hard spheres, I can imagine.

19 MEMBER POWERS: And some particles are
20 like that. Some have structure to them, and instead
21 of bounce you get break-up when you have structure.
22 So there are really two phenomena, bounce and break-
23 up.

24 MEMBER BANERJEE: It's an interesting
25 problem.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 MEMBER POWERS: It's an intractable
2 problem.

3 MR. SALAY: And then if you use like olive
4 oil, they bounce less.

5 MEMBER POWERS: Have you ever noticed that
6 professors who tell you that something is interesting,
7 it's impossible? Why don't you ever get interesting
8 for something that's easy?

9 MR. SALAY: Then it wouldn't be
10 interesting.

11 Also, deposits can be re-entrained into
12 the flow, and if particles that have a high kinetic
13 energy cannot only come back off, but they can also
14 knock particles that have already been there, that
15 have already been deposited.

16 And one thing that these removal
17 processes, they are size dependent, and, therefore,
18 the removal of these particles alters the particle
19 size distribution. The smallest ones get removed
20 preferentially by diffusion and the larger ones get
21 increasingly removed by the other processes,
22 increasing with increasing size, and so you have sort
23 of a size region about tenths of microns that are very
24 hard to remove by any methods, and so your size
25 distribution tends to narrow around this low tenths of

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 micron size, what we call maximum penetration size.

2 If you do multiple experiments separately
3 and calculate the retention using the same size
4 distribution, you can't simply multiply these values
5 together because you end up double counting the
6 removal of double or triple or repeatedly counting the
7 removal of the largest particles, which are the
8 easiest to remove.

9 This was one of the reasons that the NRC
10 was very interested in seeing integral tests, and it
11 contained retention as a function of size for
12 individual sections --

13 MEMBER BANERJEE: Do you have sort of an
14 aerosol code for doing these calculations where you
15 have a size distribution and all of these mechanisms.

16 MR. SALAY: Typically MELCOR does.

17 MEMBER BANERJEE: But it's not like a
18 large simulation or anything?

19 MR. SALAY: No, we don't have it. PSI did
20 a lot of analyses that used some DNS mostly to get
21 coefficients, and they even modified some of their
22 turbulence flow models to account for anti-satrophly
23 (phonetic) near the boundary layer.

24 MEMBER POWERS: We spent quite a little
25 while setting up an LES model for this particle

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 deposition and the bend in the tube. And what you
2 learn from that are two things. One is that I never
3 want to see another LES calculation in my life, and
4 that typically we calculate from conventional
5 correlations the deposition about as accurately as you
6 can get it from an LES calculation if there's nothing
7 special.

8 MEMBER BANERJEE: Unless there's a vortex
9 which is --

10 MEMBER POWERS: Yes. You do get secondary
11 flows that come a little clearer to you physically in
12 these LES simulations, whereas they're kind of hand
13 weighty in the correlations that, you know, put a kink
14 in the curve when you get the secondary flows and
15 things like that.

16 But so far you have to have really
17 complicated geometry. I'm sure Mike will talk some
18 about flows through the separators and things like
19 that where you've got veins and stuff like that, and
20 we go to heroic efforts to calculate those in detail
21 and find out the deposition is zip, you know.

22 MR. SALAY: You know, actually I was
23 expecting PSI to talk about that.

24 (Laughter.)

25 MEMBER BANERJEE: Who at PSI is doing the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 modeling work?

2 MR. SALAY: Dehbi. I don't remember his
3 first name.

4 MEMBER BANERJEE: Are people like Brian
5 Smith at all involved in this?

6 MR. SALAY: Don't recognize that name.
7 Dehbi was the -- D-e-h-b-i.

8 MEMBER POWERS: A graduate of one of the
9 esteemed universities in America located in People's
10 Republic of Cambridge.

11 MEMBER BANERJEE: I thought you were going
12 to say in the Land of Fruits and Nuts.

13 MEMBER POWERS: There are no esteemed
14 aerosol businesses in the Land of Fruit and Nuts.

15 MEMBER BANERJEE: I thought there was one
16 where a guy name Abbott was at, but never mind.

17 MEMBER POWERS: He has some reputation in
18 that field.

19 MEMBER ARMIJO: All right. Let's keep
20 going.

21 MR. SALAY: And so what types of
22 impressions were raised? What types of aerosol size
23 would we get?

24 Well, a recommendation from IRSN did a
25 survey of some ACL, PBF and PHEBUS experiments, gave

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 this for the size distribution of the steam generator:
2 near log normal and D-1 micron or less, a geometric
3 standard deviation of two larger particles comprising
4 of agglomerates of small .1 micron, highly coordinated
5 clusters, and in two of these tests the aerosol sizes
6 were in the maximum penetration size range, and there
7 was a larger size distribution in the third.

8 MEMBER CORRADINI: So when you say survey,
9 you mean IRSN looked at aerosols used in those tests
10 or they generated aerosols and IRSN looked at the
11 aerosol machs that they generated?

12 I don't think I understand.

13 MR. SALAY: "Survey" is the word that they
14 used, and I'm using similar. They looked at the data
15 from different experiments and micrographs and --

16 MEMBER CORRADINI: Okay, fine. And then
17 the AMMD, that's aerodynamic something or other. What
18 is that?

19 MR. SALAY: That's why I say I've seen it.

20 MR. LEE: Aerodynamic mass mean.

21 MEMBER CORRADINI: Okay, fine. Mass mean
22 versus number mean versus whatever.

23 MR. SALAY: I have occasionally seen mass
24 mean instead of mass median, and so --

25 MEMBER CORRADINI: Okay. That's fine. I

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 just didn't remember what the acronym was.

2 MEMBER BANERJEE: This must depend very
3 much on the generation mechanism, right? I mean the
4 generation mechanism independent.

5 MEMBER POWERS: I suspect when you see
6 things like this with a sigma 2 and what not, what
7 you're looking at is the product of a nucleation
8 growth mechanism and then transport through some
9 removal process that smoothed up the distribution.
10 Because it's so close to the maximum penetration size,
11 I suspect that you've gone through structures and
12 whatnot knowing the tests. I happen to know that
13 that's the case, but just looking at it you'd say,
14 yeah, this is -- because it's not multi-modal, because
15 it's not broad, all of the details of generation have
16 been wiped out by getting to where --

17 MEMBER BANERJEE: So some sort of
18 equilibrium, something like a Boltzman distribution,
19 which is --

20 MEMBER POWERS: Something like that. It's
21 a log-normal distribution.

22 MEMBER POWERS: Everything's a log-normal
23 distribution if you plot it crudely enough.

24 MEMBER CORRADINI: I mean, another
25 analogue to this is if you look at essentially

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 particulate emissions from a combustion engine, after
2 you go through all of the manipulations there and they
3 pass into the whatever it is, the catalytic converter,
4 it's essentially like that. It almost has the same
5 general character. It may have a shift in the log
6 normal, but it looks kind of like that.

7 MEMBER BANERJEE: This is something which
8 is not near the generation point that has had the
9 change to reach sort of equilibrium of some sort.

10 MEMBER SIEBER: It's the PHEBUS
11 experiments, I think, that gives you the initial
12 composition. Then a lot of mechanical things happen
13 before it gets to the atmosphere, which gives you the
14 decontamination factor.

15 MR. LEE: Yeah, from PHEBUS it's basically
16 what my sighting is the size observed from looking at
17 the steam generator surfaces. That means the
18 generator in the core bundle and after the upper head
19 and pipings and then go through a single tube
20 stimulator, and they're looking at the size. That's
21 what you're talking about.

22 MR. SALAY: Okay.

23 MEMBER BANERJEE: What are the largest
24 particles there? I mean, I can see the mean is about
25 a micron.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 MR. SALAY: There's a distribution. So
2 you --

3 MEMBER BANERJEE: Right, but it's sort of
4 a log normal. So it is a long tail.

5 MR. SALAY: It is a long tail.

6 MEMBER BANERJEE: But what is the largest
7 size that you have?

8 MEMBER POWERS: The largest size you have
9 are samples about 20 microns.

10 MEMBER BANERJEE: Okay.

11 MEMBER POWERS: Okay? Now, in principle
12 there are even larger particles than that, but you
13 can't get them into a sampling device. So you really
14 don't know too much about it. But because it's a mass
15 median there are not very many of them.

16 MEMBER BANERJEE: So what you do is you do
17 isokinetic sampling.

18 MEMBER POWERS: You try to do isokinetic
19 sampling. Now, in core degradation tests, the problem
20 is your flows are not necessarily constant, but what
21 you want is a forgiven inlet nozzle, and people spend
22 a lot of time designing goosenecks that are forgiving
23 so that you get a good sampling, a good representative
24 sample, and I would guess what did it take PHEBUS,
25 three tries before they actually got decent samples

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 coming in?

2 It takes a while. I mean it's hard to do
3 in dynamic tests.

4 MEMBER ARMIJO: Okay. Just one question.
5 We've talked about size, but does the particle density
6 and the chemistry of the aerosol particle, do these
7 things make any difference in decontamination?

8 MR. SALAY: The aerosol mass mean diameter
9 is an indication of the size of a unit density sphere
10 that would fall at the same rate as the particle in
11 question. So, yes, there are shape factors. It
12 depends on they're agglomerates. There's questions
13 whether they're stringy or compact, and, yes, that
14 does affect them.

15 MEMBER POWERS: What we all deal with are
16 models everywhere saying an aerosol particle is an
17 aerosol particle, and there's really no chemistry
18 associated with it, and if you look back on the issue,
19 Bender is correct. It depends on the coefficient of
20 the institution on that and on the magnitude of the
21 Van Der Waals forces and things like that.

22 That's a level of detail below the
23 resolution of any severe accident. One of the issues
24 that's raised is do we need to go to another level of
25 detail to model things like that, break-up and things

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 like that, and we'd be interested in your comment on
2 that because it's very difficult.

3 MEMBER ARMIJO: I imagine so.

4 MEMBER POWERS: I mean, for 25 years the
5 assumption that this is a physical phenomenon and that
6 if a particle comes in and gets close to the surface,
7 little hands grab it and hold it to that surface
8 dearly, and it didn't do anything else. And as we go
9 through the discussion we'll see, well, got you, and
10 it's how much you want to explore that approximate
11 party. I think it's interesting.

12 MEMBER ARMIJO: All right, Michael.

13 MR. SALAY: Okay. So then the
14 consequences of improved rupture, nuclides went
15 directly to the environment of the auxiliary building
16 without any attenuation from generic safety features
17 in containment, and even though the accidents are of
18 very low probability, they are risk dominant.

19 MEMBER BANERJEE: Yeah, risk dominant.
20 That's interesting. This is actually an important
21 thing.

22 MR. SALAY: And from NUREG-1150, which is
23 risk analysis of five U.S. plants, three BWRs and
24 three PWRs and two BWRs, two of the PWRs had
25 significant probabilities of tube rupture and all were

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 found to or were determined to be able to suffer
2 induced steam generator tube rupture.

3 However, there was data -- data were
4 unavailable on retention on the secondary side of
5 steam generators and there weren't really any models
6 available. Essentially they wanted to credit some
7 retention, and they convened an expert panel to come
8 up with some values.

9 MEMBER BANERJEE: Don't go so fast there.
10 Expert panel to --

11 MR. SALAY: A source panel.

12 MEMBER BANERJEE: What is it?

13 MR. SALAY: A source panel to determine if
14 they come up with some values. There weren't models.
15 There wasn't any -- data were unavailable, and so
16 hence they convened a group of experts to say, well,
17 give us your opinion on the potential.

18 MEMBER BANERJEE: This seems a
19 deterministic problem for an expert panel to be able
20 to calculate this stuff badly.

21 MR. SALAY: Well, to complete their risk
22 analyses, they had to -- they wanted to come up with
23 an estimate because the release was --

24 MEMBER BANERJEE: Is this a way out every
25 time a calculation is difficult? You convene an

1 expert panel?

2 MR. SALAY: Well, and then to go back and
3 try to get data later.

4 MEMBER POWERS: I mean, all of them
5 whenever they came to an uncertainty, it's the only
6 one they challenge, and they lacked confidence in the
7 old source term crude package. They set up a panel,
8 and they said, "Okay. You guys are the experts. Do
9 your own calculations, communicate with the angels,
10 whatever it takes to give us a distribution on what
11 the likely outcomes are."

12 In the source term what were there, six,
13 seven questions, distinct questions that they posed?
14 You know, things like what are the release fractions,
15 what's the transport fractions, and things like that.

16 You know, in principle every one of those
17 can be calculated. They did it in the source term
18 code package. They lacked confidence they were doing
19 it very well, and so the issue came back. Okay, yeah.
20 We've been spending an enormous amount of time on each
21 one of these questions. Does it make any difference?

22 And of course, the conclusion was to spend
23 some time and, of course, that led to the genesis of
24 the first VICTORIA code and then the MELCOR code to
25 try to do these things better.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 This is just one of the questions that had
2 eventually to do with risk. I mean, there were
3 literally hundreds, but big panels were set up on
4 them.

5 MR. SALAY: And this is what they came up
6 with. In terms of a decontamination factor from DIA,
7 just simply mass coming in to mass going out, and for
8 the inlet efficiency for steam generator plenum in the
9 ruptured tubes, they came up with a decontamination
10 factor of two.

11 For the retention in tubes, they
12 calculated a decontamination factor of ten. However,
13 there were concerns about suspension, revaporization
14 and glomerate break-up, and therefore, no credit was
15 given for this.

16 For the secondary side, they came up with
17 a DF of about four to six with no deposition on the
18 opposite tube for viewer resisted by thermophoresis,
19 and no credit was given for the steam separators and
20 dryers because of the proprietary side of the
21 question. There was large uncertainty --

22 MEMBER BANERJEE: For what reason?

23 MR. SALAY: They were having difficulty to
24 get information on it was proprietary, the steam
25 generator. The vendors were not unwilling to release

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 information on the problem.

2 MEMBER POWERS: Yeah, the plant itself was
3 willing. For instance at Surry, they were willing to
4 give us anything. The vendor for the separators and
5 dryers, however, objected to release a sufficient
6 detail to do an aerosol analysis. In the end I don't
7 think it made very much difference, but it was a
8 challenge.

9 MR. SALAY: And there was a large
10 uncertainty in these estimates, and here the risk
11 break-up for surry, and as you notice the bypass
12 accident, which is shown in red, is dominant for early
13 fatalities and latent cancer fatalities.

14 Then industry came along and came up with
15 an alternate retention analysis, and that was much
16 higher. They came up with a decontamination factor on
17 the secondary side of the steam generator on the order
18 of 10,000 and a DF of 100 or more on the tube
19 depending on where the break was, several tens on the
20 secondary near the break, and about two to three far
21 from the break. And so very different analyses.

22 And NRC's attention on tube rupture bypass
23 accident is justified by risk, and there's a direct
24 connection between risk for bypass accidents and
25 source term attenuation on the same resized steam

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 generators. As the attenuation goes up, the fraction
2 on risk goes down, and the slice of the pie just
3 decreases.

4 MEMBER ARMIJO: In the industry analysis,
5 did they use different visits? How could they come up
6 with such big differences?

7 MR. SALAY: There was a lot of turbulent
8 deposition in the tube. They didn't -- I think above
9 a certain size they assumed that deposition was
10 constant. They didn't account for balance. They even
11 considered that perhaps the aerosols collected a clog
12 and --

13 VICE CHAIRMAN BONACA: Did they consider
14 steam dryers?

15 MR. SALAY: I don't think the industry
16 calculation did.

17 MEMBER BANERJEE: So there is no water in
18 this system at all.

19 MR. SALAY: No, it is assumed to be dry.
20 So they ended up with this big outstanding question:
21 are safety resources being misdirected to an unneeded
22 attention on containment bypass accidents because we
23 underestimate attenuation, and this resulted in steam
24 generator action plan Item 3.3(a), develop
25 experimental information on the source term

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 attenuation on the secondary side of steam generators.

2 And the ARTIST program came along, and
3 this is an international project conducted by Paul
4 Scherrer Institute, seven-phase project of which NRC
5 participated in five. It consisted of both separate
6 and integral tests, and you see the diagram here.

7 MEMBER BLEY: Is it complete now? The
8 seven phases are all complete?

9 MR. SALAY: Yes. I know they did a few
10 more tests earlier this spring, I think the most part
11 of it is.

12 And the retention was measured in
13 different locations. Each of these corresponds to a
14 phase -- in the steam generator tube prior to reaching
15 tube rupture, in the immediate vicinity of the break
16 where particles could impact on adjacent tubes, on
17 tubes far from the break --

18 MEMBER BANERJEE: Are those numbers in
19 brackets --

20 MR. SALAY: That's how many tests were
21 provided to us in January. I think two more tests
22 have been done.

23 MEMBER BANERJEE: When you mean separate,
24 what do you mean by "separate"?

25 MR. SALAY: Separate so that they take,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 for example the first one is a separate test. They
2 just take one tube and it actually -- just one big
3 long tube and they just look at the retention. They
4 don't actually use this facility. They just have one
5 tube and look at the retention inside.

6 MEMBER BANERJEE: So there are separate
7 effects.

8 MR. SALAY: Yeah, separate, and then they
9 have a bundle only. They have a completely different
10 facility for far field with a few different tube
11 support plates. So they have separate facilities and
12 then they have the whole.

13 And so one of the facilities was the in-
14 tube retention. They have separate tests for in the
15 immediate vicinity of the break, a separate test for
16 on the tubes, between one tube's support plate and
17 another, and also on top of the support plates, and
18 then they have tests, the steam separate and steam
19 dryers, and then they had combined tests with all of
20 the components.

21 And the other phase is that we're going to
22 participate on by the NRC where retention in the
23 flooded bundle and droplet retention in --

24 MEMBER BANERJEE: What does flooded bundle
25 mean?

1 MR. SALAY: When you're not assumed to be
2 dry, when your bundle actually does contain water and
3 so the aerosol --

4 MEMBER BANERJEE: Some amount of water or
5 a lot of water?

6 MR. SALAY: They tried different
7 submergences, and they sort of do this function of
8 submergence.

9 MR. LEE: NRC did not participate in the
10 flooded bundle part because we know that aerosol
11 retention in water is extremely good.

12 MR. SALAY: Very high.

13 MR. LEE: So we said we really don't need
14 to worry about that.

15 MEMBER CORRADINI: How do you have bypass
16 with water there? How do you even set up the
17 conditions? They seem counter. They seem
18 inconsistent.

19 MR. SALAY: I wasn't involved in the start
20 of the project, but that could be why we didn't buy
21 into those.

22 MR. LEE: So that part that we did not
23 produce, they will not give us those data because you
24 can see the southern part of it. So we produce the
25 part that are all dry.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 MEMBER CORRADINI: All right. Thank you.

2 MEMBER POWERS: Many, many of the European
3 plants have or contemplate accident management
4 strategies to avoid flooding the secondary side of the
5 steam generator. In fact, the Sizual (phonetic) plant
6 has a hard-engineered facility which would operate on
7 the secondary side. I don't know of any U.S. plant
8 that has that capability, and as Dr. Lee said, it's
9 not one that I would spend an enormous amount of time
10 calculating. If you'd flood the secondary side,
11 you're going to get very little aerosol through that.

12 MEMBER ARMIJO: If that's so effective,
13 why don't we do it?

14 MEMBER POWERS: well, you have a cost
15 associated with it.

16 MEMBER CORRADINI: It would be a dedicated
17 system

18 MEMBER POWERS: It would have to be
19 considered in light of the fact that the probability
20 of one of these events is about three times ten to the
21 minute six. Now, the consequences of it are enormous,
22 but so -- I mean, how much money do you want to spend
23 on a three times ten to the minus six event?

24 MEMBER BLEY: How much does it cost to
25 hook up a firewall?

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 (Laughter.)

2 MEMBER POWERS: If you have water, where
3 are you going to put it? Are you going to put it in
4 the core or are you going to put it in the secondary
5 side?

6 (Laughter.)

7 MR. SALAY: The ARTIST facility is based
8 on best now plants, and --

9 MEMBER CORRADINI: Did the NRC staff
10 participate in the scaling?

11 MEMBER POWERS: Yes.

12 MR. SALAY: I wasn't around at the time.
13 So I couldn't answer.

14 MEMBER CORRADINI: Thank you.

15 MEMBER SIEBER: The answer is it's almost
16 as bad as we thought it was.

17 MEMBER CORRADINI: But ARTIST is separate
18 from PANDA or is this a subcomponent of the PANDA
19 facility?

20 MR. LEE: A separate thing. This has
21 nothing to do with PANDA.

22 MEMBER BANERJEE: Completely different.

23 MEMBER CORRADINI: But I was just curious
24 about if it was a component of PANDA that they
25 essentially tested separate.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 MEMBER BANERJEE: I haven't seen this
2 facility. So it must be in a separate building.

3 MEMBER POWERS: An orgy of stainless
4 steel.

5 MR. SALAY: The facility is based on the
6 Beznau plant. It's 365 megawatt electric,
7 Westinghouse two-loop PWRs, 69 and 72. It's scaled
8 for the steam generator tube rupture accident, about
9 two centimeter tube diameter. It's approximately 120
10 by flow area, and the main facility or the bundle is
11 a short and narrow bundle. The total height is 10.5
12 versus 17, but for the tubes it's three-something
13 versus nine. It's somewhere on here.

14 MEMBER BANERJEE: What was the rationale
15 for this? Because I can see reducing the number of
16 tubes, but why would you reduce the height?

17 MR. SALAY: My guess is cost, but --

18 MEMBER POWERS: The height of the building
19 that's involved is huge.

20 MEMBER SIEBER: Now, the Beznau plant is
21 similar in design to Gennay (phonetic), two-loop.

22 MEMBER POWERS: Two-loop BWR, but
23 pertinent to this, it has brand new steam generators.

24 MEMBER SIEBER: Yeah. It doesn't make any
25 difference whether it's two, three or four.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 MR. SALAY: Okay, and the main facility
2 also contains a tube sheet and three support plates
3 and a full-scale separator and dryer. It contains one
4 of these, whereas the plant steam generators each
5 contain 12, and separate effectually is they're making
6 four of the facilities into at the break, following
7 the break in support plates and for separator and
8 dryer.

9 MEMBER BANERJEE: The surface area to
10 volume ratio is the same, or is it?

11 MR. SALAY: Surface area to volume, yeah.

12 MEMBER BANERJEE: In rough terms.

13 MR. SALAY: They're the same hydraulic
14 diameter, the same pitch.

15 MEMBER BANERJEE: You have the same
16 hydraulic diameter, same velocities, whatever.

17 MEMBER POWERS: The critical issue in the
18 scaling is if you have a break, you have a jet going
19 out, there is a jet through the tube and affect the
20 shroud that you use around the facility or is that
21 flow dissipated sufficiently to start moving all
22 upward. For quite a while -- and they're very quite
23 on there. They're not bad.

24 Now, as far as the height, steam
25 generators, we typically treat them as a bunch of

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 units with the tube support plate marking the boundary
2 of those units. All we need is a couple of those, and
3 it looks kind of the same. The tube ruptures that we
4 have seen are kind of uniformly distributed up and
5 down the tubes. You're as likely to break at the
6 bottom as you are at the top.

7 There was a lot of agonizing about whether
8 you got guillotine fractures or fish-mouth fractures,
9 and what we have learned especially from Dr. Shack is
10 the ones that are the biggest danger are the
11 guillotine breaks within the tube support plates. The
12 more likely ones are fish-mouth breaks within the
13 spans.

14 Okay. So you look at those things.

15 MR. LEE: In some of these break geometry
16 was actually prepared. Argonne with Dr. Shack's help
17 actually, and we should go back to --

18 PARTICIPANT: Operated fish-mouths.

19 MEMBER POWERS: You don't want to hold
20 that against the Swiss program. They did the best
21 they could. They saw the best offer they could for --

22 (Laughter.)

23 MR. SALAY: Okay. Test parameters for
24 those tests are guillotine break. They used a few
25 different aerosols, TI, titanium dioxide agglomerates,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 and they used two different manufacturers because they
2 were having difficulties controlling the size. The
3 agglomerates, they were having difficulties breaking
4 them up, and so they took a different brand, went to
5 a smaller size, but still couldn't reduce it to the
6 desired size, and so they ended up going to silicon
7 dioxide spheres, which are products as you can see,
8 and figured in the break.

9 MEMBER BANERJEE: Nothing like it.

10 MR. SALAY: They're really neat, and they
11 also used latex spheres. You have a titanium dioxide
12 agglomerates and silicon dioxide spheres. These two
13 figures are on the same scale.

14 And the types of concentrations they used
15 were on the order of .0 hundredths, two-hundredths of
16 the milligrams per meter tube, a flow rate of cold
17 nitrogen, and some tests had steam, and the flow rates
18 of a few tens to several hundred kilograms or hour
19 inside a tube because I mentioned before the
20 velocities ended up being hundreds of meters per
21 second.

22 And they performed scoping tests to
23 determine what parameter they should use before
24 settling on them, and they also repeated some tests to
25 determine experimental uncertainty.

1 MEMBER BLEY: So the highest temperature
2 is around 100 C. or a couple hundred at most?

3 Do we know if --

4 MEMBER POWERS: The highest temperature
5 was like 327 degrees Centigrade.

6 MEMBER BLEY: It wasn't steam? Did they
7 evacuate?

8 MEMBER POWERS: No, they didn't. There
9 may have been some water vapor.

10 MEMBER BLEY: But nothing high
11 temperature. Do we know if that makes a substantial
12 difference in any of this?

13 MEMBER POWERS: Well, your transport
14 properties change a little bit, I suppose.

15 MEMBER ABDEL-KHALIK: I can understand how
16 during a transient of this type you have high
17 temperature on the primary line, but could you explain
18 to me when during this transient the pressure on the
19 primary side will be higher than the pressure on the
20 secondary side?

21 MR. LEE: In the severe accident
22 stimulator, the secondary side is very low. That's
23 why you have very large damage index on this tube, and
24 that's why it failed, because of the high pressure to
25 the secondary side.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 MR. BESSETTE: But the primary pressure is
2 about the 2,500 psi?

3 MEMBER ABDEL-KHALIK: He's talking about
4 a guillotine break where, in a tube?

5 MR. SALAY: A tube, yes. This is for a
6 test.

7 MEMBER ABDEL-KHALIK: But the initial
8 event was what? What caused the primary to lose
9 inventory completely?

10 MEMBER SIEBER: Probably a hot leg break.

11 MR. LEE: It based on a station blackout
12 scenario.

13 MEMBER ABDEL-KHALIK: So you have a pump
14 seal failure.

15 MR. LEE: Yes, pump seal leaking and so
16 forth.

17 MEMBER ABDEL-KHALIK: And that's how you
18 lost inventory?

19 MEMBER POWERS: No. You get a secondary
20 side bypass. So you open up, say, a relief valve.
21 The primary side is still a full pressure. It's
22 leaking out at 2,500.

23 MEMBER ABDEL-KHALIK: Oh, is it?

24 CHAIRMAN SHACK: And no injection. You
25 have no feedwater.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 MEMBER POWERS: The core is just melting.
2 The temperature is high and the temperature is going
3 to six, seven, 800 C.

4 MEMBER STETKAR: The primary pressure
5 relief is through the break through the secondary
6 relief valve. So that's a driving process.

7 MEMBER MAYNARD: I thought the big problem
8 was with the secondary side being dried out.

9 CHAIRMAN SHACK: As Richard said, that
10 gives you the maximum pressure across the tube. You
11 know, you've got much higher stresses on the tube.

12 MEMBER MAYNARD: How are you getting it
13 dry around the tubes?

14 MEMBER POWERS: What happens is that you
15 rupture a tube. You're now putting in primary side
16 pressure on the secondary. The secondary side safety
17 relief valve is open, and it just blows the water
18 right out of the tubes. You don't have any feedwater
19 to make up. So you go dry, and it goes dry very
20 quickly. Twenty minutes and you're dry on the
21 secondary side.

22 In a station blackout, you can't have it
23 around the port or you go dry. There's no natural
24 convection of heat transfer. Until you go dry, you're
25 not melting the core.

1 MEMBER SIEBER: In a severe accident you
2 have to break that cool --

3 CHAIRMAN SHACK: Before you go dry on the
4 secondary side you don't have any problems.

5 PARTICIPANT: There's not much liquid
6 water left, I suppose.

7 PARTICIPANT: It's getting pretty hot.

8 CHAIRMAN SHACK: No, but I mean that's why
9 you keep trying to pump water into that secondary
10 side.

11 MEMBER POWERS: I mean, if you don't have
12 feedwater, you're not putting any water in there.

13 CHAIRMAN SHACK: Right.

14 MEMBER POWERS: Where you're trying to put
15 water in is to the primary side.

16 CHAIRMAN SHACK: No, but I mean in
17 scenarios where you have the auxiliary feedwater,
18 until that pump dies you're okay. Once that pump dies
19 then you're dog meat.

20 MEMBER POWERS: Yeah.

21 MR. SALAY: Okay. And here's some of the
22 primary measurement methods. They look at the size
23 distributions.

24 CHAIRMAN SHACK: You have a half an hour
25 left, right?

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 MR. SALAY: Heavy concentration, the
2 routine mass, and from that your decontamination
3 factor. They sampled at the inlet and outlet for all
4 tests, and occasionally you had other locations. They
5 determined the size distribution with cascade
6 impactors or low pressure impactors and optical
7 particle counters. Concentration of the filters,
8 odometers and optical particle counters.

9 They looked at the mass collection in
10 addition to concentrations in combination with flow to
11 determine its contaminating factor, and they measured
12 several other parameters.

13 The major observations from the test
14 program was that there were two forms of aerosol
15 deposition. There's always a fairly uniform layer of
16 fine aerosol on surfaces exposed to aerosol laden
17 flow.

18 MEMBER BANERJEE: Even with the little
19 spheres?

20 MR. SALAY: Yes, yes. And in some of the
21 tests there was also clumps of material.

22 MEMBER BANERJEE: This uses both the
23 titanium dioxide --

24 MR. SALAY: They had tests with titanium
25 dioxide, silica dioxide and latex. They used

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 silicon --

2 MEMBER BANERJEE: All of those formed this
3 tenacious list, even the latex.

4 MEMBER POWERS: Well, the latex is hard to
5 see it because latex is damned expensive they don't
6 run very much through. But, yeah, everything gets a
7 patina on it.

8 MEMBER BANERJEE: I have a way to generate
9 micron scales from seismic cheaply. They use it for
10 particle imaging velocity.

11 MR. SALAY: The in-tube retention seems to
12 vary from test to test significantly, and there was
13 also, and I guess I'll show later, that there's high
14 retention immediately upon when the aerosol flow was
15 started, but then the retention dropped off.
16 Resuspension was observed in experiments, indicated
17 that bounce and break-up were important. Break-up in
18 the tubes was noticeable. Large agglomerates didn't
19 survive the transport.

20 To high flows, particles larger than about
21 one micron would break down to submicron and have a
22 particle smaller than about one micron didn't break
23 up.

24 Near the tubes there was -- near the
25 rupture there wasn't a significant amount of retention

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 on the tubes.

2 MEMBER BANERJEE: You mean on the
3 secondary side.

4 MR. SALAY: On the secondary side, yes,
5 and sort of following the path of the flow.

6 And far away from the break most deposit
7 mass was on support plate, and the tube's floor plates
8 used broached holes which had a big flow area right
9 there, and so you'd have flow recirculation and a
10 region of low velocity where they could settle out.

11 And however, for most of the U.S. plants
12 they have drilled holes, and there's a lot less area
13 in between, and it could be filled with crud.

14 MEMBER CORRADINI: Were any of the test
15 results surprising? I assume people did pre-
16 calculations of what they expected in these tests
17 versus what they measured. So are there any surprises
18 in terms of the physics they saw versus the physics
19 they guesstimated?

20 MR. SALAY: I think it was pretty much
21 what they expected. The spread of the plume was
22 lighter than expected, but I think basically perhaps
23 the retention -- I wasn't around at the time, but
24 perhaps the initial behavior was complete in the tube.
25 The pressure drop actually dropped. The pressure

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 across the tubes as the flow was going across actually
2 dropped. So you started with some flow across there,
3 and you have some pressure drop. Then when you start
4 injecting the aerosol, the pressure drop increased
5 across the tube. So there was less resistance. It
6 sort of smoothed out.

7 MEMBER BANERJEE: But they didn't support
8 the industry position or did it support this?

9 MR. SALAY: No. The bottom line is it
10 supported the expert position.

11 MEMBER SIEBER: You could almost say we
12 didn't learn much new, but we learned enough to be
13 able to modify.

14 MR. SALAY: To be more confident about our
15 results, yeah, and that's really --

16 MEMBER SIEBER: For the answer.

17 MR. SALAY: There wasn't a lot of
18 retention even with large aerosols in the dryer and
19 separator, and things we're interested in learning
20 more about are bounce, break-up, and the adhesion
21 forces that cause them to hold together or not break
22 up.

23 Understanding resuspension, thermophoretic
24 deposition, and shapes and sizes of particles coming
25 from the grade in reactor core.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 MEMBER BANERJEE: So MELCOR uses a series
2 of is it a 1D model?

3 MR. SALAY: I think it is classified as
4 1D.

5 MEMBER BANERJEE: One D, and it has some
6 empirical correlations for deposition and
7 resuspension.

8 MR. SALAY: It actually calculates the
9 size distribution. I think, first of all, it emits
10 the fission products as vapors which condense and then
11 agglomerate, and --

12 MEMBER BANERJEE: And you come to this
13 sort of equilibrium size --

14 MR. SALAY: Yes. Actually it calculates
15 the individual processes that affect the size
16 distribution.

17 MEMBER BANERJEE: So that they do the
18 early stage, but now you've got this sort of log-
19 normal distribution coming out.

20 MR. SALAY: It's sort of how much
21 retention. I mean, MELCOR doesn't model the secondary
22 side in extreme detail. We found that even many of
23 the people in the honors project, they did model it in
24 very much detail with CFD codes and didn't --

25 MEMBER BANERJEE: CFD codes are not worth

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 the paper they're written on.

2 (Laughter.)

3 MEMBER POWERS: And I think we'd agree,
4 right?

5 MR. SALAY: Yeah. There are lots of
6 colorful plots.

7 MEMBER ARMIJO: I think we --

8 MR. SALAY: Should I?

9 MEMBER ARMIJO: Yes. How did it affect
10 your rating?

11 MR. SALAY: MELCOR for the secondary side
12 through the lambda factor based on the particle size
13 from the integral test, and we believe there's an
14 insufficient risk incentive to do more work, although
15 we're keeping our eye out on other models that are
16 being developed out there, as well as one developing.

17 MEMBER CORRADINI: Just that one point.
18 So to kind of follow up Sanjoy's point, when you model
19 with MELCOR on the secondary side of the steam
20 generator, I know the user has flexibility, but
21 historically people kind of just stumble and use the
22 previous model. So what is the typical model of a
23 steam generator with MELCOR relative to this? Are
24 they relatively large lumps in terms of essentially
25 the whole bundleous A node or do they actually break

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 it up?

2 Because the answer kind of to his question
3 is it's one dimensional if you force MELCOR to look at
4 it one dimensionally versus just a large lump of the
5 bundle.

6 MR. SALAY: Not your typical model.

7 MEMBER POWERS: If you pull MELCOR off the
8 shelf right now and say, "Okay. Tell me what the
9 decontamination is. Just run the code on the standard
10 problem," your decontamination is what?
11 Decontamination factor.

12 MEMBER CORRADINI: What goes in comes out.

13 MEMBER POWERS: Yeah, because nobody has
14 ever bothered to model it.

15 MEMBER BANERJEE: And what is it --

16 MEMBER POWERS: What they are proposing is
17 right now based on these experimental results is just
18 for the lambda factor.

19 MEMBER CORRADINI: And the lambda factor,
20 assuming you have this lumped model, would say based
21 on some set of conditions it's greater than one.

22 MEMBER BANERJEE: You can see that it's
23 based on the size distribution.

24 MR. SALAY: These are the three integral
25 tests that we have results from.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 MEMBER CORRADINI: And then that leads me
2 to the C-MAT results. If C-MAT learns something by
3 doing a more sophisticated model, is it open to you
4 guys or C-MAT essentially closed -- their results are
5 closed to the ARTIST community?

6 MR. SALAY: Well, they're developing a
7 model, and I assume they'd release it.

8 MEMBER CORRADINI: Well, they may and they
9 may not, I mean.

10 MEMBER POWERS: We have a very close
11 working relationship.

12 MEMBER CORRADINI: You do? Okay, fine.

13 MEMBER BANERJEE: You can participate in
14 that model development or not?

15 MEMBER POWERS: We do. I mean, there's an
16 active collaboration.

17 MEMBER BANERJEE: And it's sort of open
18 source code?

19 MEMBER POWERS: Very. Essentially data,
20 you know, actually.

21 MEMBER BANERJEE: In which way will it
22 differ from the other, the ARTIST model?

23 MEMBER POWERS: There is no ARTIST model.

24 MEMBER BANERJEE: ARTIST data.

25 MEMBER POWERS: What C-MAT is looking at

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 is can they take some fairly well known correlations
2 for flows or perpendicular to vertical feet and figure
3 them so that they predict this patina that's observed
4 and things like that, and they make extensive use of
5 fluid calculations and things like that.

6 MEMBER BANERJEE: That's terrible.

7 (Laughter.)

8 MEMBER POWERS: Only to understand what's
9 going on from the flow. They have limited confidence
10 in the ability to use fluid to predict aerosol
11 behavior.

12 What they would like to do is end up with
13 a correlation based decontamination factor for this
14 near field decontamination, and they're looking at
15 lots of inertial impacts and results that have been
16 obtained in the past and things like that. They've
17 done some interesting experiments in which they were
18 trying to understand the flow -- experimental in
19 nature -- understand the flow distribution around the
20 break, and they quickly found out that particles don't
21 come up to the speed of the gas very closely.

22 In fact, a surprisingly long time to
23 accelerate the particles, and it was frustrating.
24 What they built was a scaled down version of the
25 ARTIST experimental facility, did quite a lot of flow

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 mapping in this, discovered that the particles weren't
2 coming up to speed, and all of this added intuition on
3 how to apply some of these steady state models of this
4 contamination.

5 I mean, Mike has characterized it
6 correctly. We're paying attention to this. We're
7 helping them where we can, and if they come up with
8 something, you know, we can see going beyond the
9 lambda factor because it's compatible with the MELCOR
10 coding.

11 And in fact, they have the MELCOR coding
12 used to provide a model for the experiments.

13 MEMBER BANERJEE: So the bottom line here
14 that the industry has on contamination are way too
15 high.

16 MR. SALAY: Their calculations were, yeah.

17 MEMBER BANERJEE: And you're trying to
18 sort of capture some of the decontamination from these
19 integral tests which lie somewhere between one and,
20 say, 50, whatever, depending on particle size 20.

21 MR. SALAY: yeah.

22 MEMBER BANERJEE: And this includes the
23 dryers or everything?

24 MR. SALAY: Yes, separators, dryers.

25 MEMBER BANERJEE: And in the SOARCA or

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 whatever that is, what sort of estimates.

2 MEMBER CORRADINI: Funny. That's what
3 Dennis was about to ask.

4 MR. LEE: I think Charlie Tinker and
5 company knows about this results or they're looking at
6 it on the secondary side where retention is, yeah.

7 MEMBER BANERJEE: At the current time
8 SOARCA is using one.

9 MR. LEE: I do not know to answer that
10 one.

11 MEMBER BLEY: Or are they using the
12 industry average?

13 MR. LEE: I don't think they're using the
14 industry one because the industry one, I believe, was
15 using very large particle size. That's why they have
16 to use 10,000 and so forth. That is understandable.
17 So nothing wrong from the aerosol point of view.

18 MEMBER ARMIJO: So has this lambda factor
19 officially been incorporated into MELCOR if the staff
20 would do any analyses?

21 MR. LEE: I think that can be incorporated
22 into MELCOR secondary side very easily. You just put
23 a control function and you can calculate it any time
24 you want.

25 MEMBER ARMIJO: That's the final --

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 MR. LEE: That's correct.

2 MEMBER ARMIJO: -- output of this program
3 as far as NRC is concerned.

4 MR. LEE: Yes, that's correct.

5 MEMBER SIEBER: Well, I think the question
6 is the ARTIST program is finished now, right?

7 MR. LEE: Yes, it's finished. This phase
8 is finished.

9 MEMBER SIEBER: But there is a
10 continuation beyond that.

11 MR. LEE: I think that the ARTIST-2 that's
12 being proposed is under the -- they plan to present it
13 to us. They present it to Mike at these meetings many
14 times. So maybe Dana can discuss very briefly.

15 MEMBER SIEBER: Have you made any decision
16 about whether you're going to participate?

17 MR. LEE: I can tell you my view is not to
18 participate.

19 MEMBER SIEBER: Okay.

20 MR. LEE: I do not speak for our
21 management though.

22 MEMBER ARMIJO: So it's still under
23 consideration then.

24 MR. LEE: Yes, correct.

25 MEMBER SIEBER: What are they going to do

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 in the new part of it?

2 MR. LEE: I think the new part is, if I'm
3 not wrong, they're going to do some more in tube break
4 size, break stage, some flooded bundle tests and
5 flooded separator. So in other words, all of the
6 tests they propose to do are a further extension of
7 some of the things that we already participate in.
8 Our view is that giving the small particle, I think
9 the particle just stay with the flow. There's no
10 reason for the particles to do more work getting out
11 -- aerosol to get out of the flow stream and pack
12 itself onto something else. So we don't think this DF
13 factor going to change anything even if they do more
14 tests. That's our view.

15 They have to prove us wrong.

16 MEMBER SIEBER: Based on the low frequency
17 of occurrence.

18 MR. LEE: Yes.

19 MEMBER SIEBER: A decision in this area,
20 beyond that which we've already accomplished, probably
21 doesn't add too much to the picture.

22 MR. LEE: Correct. This is what is our
23 tentative view at this time, but it is under
24 discussion with us.

25 MEMBER BANERJEE: I suppose if all the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 particles were large, it would have an effect.

2 MR. LEE: Yes.

3 MEMBER BANERJEE: You would grow a
4 substantial tail.

5 MR. LEE: But as you move to every plate,
6 you know, you become smaller. The population becomes
7 smaller and smaller. So you just cannot keep on
8 counting on large particles every stage. Doesn't
9 exist. You can look at the physics itself, right? It
10 makes sense to you. You don't have to do an
11 experiment to find that out.

12 MEMBER ARMIJO: Well, you might as well
13 get your conclusion chart, Mike.

14 MR. SALAY: I think conclusions are
15 basically expert panel recommendations for the NUREG-
16 1150 risk analysis were by and large confirmed.
17 MELCOR predicts a contamination factor similar to
18 those that --

19 MEMBER ABDEL-KHALIK: Does the first
20 bullet include or exclude the factor of ten,
21 decontamination factor, in the tubes that was
22 excluded?

23 MR. SALAY: Well, it excluded the factor
24 of ten, but there was uncertainty there, and so the
25 uncertainty remains, and so even with these

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 experiments that uncertainty remains.

2 MEMBER BANERJEE: That is what is reducing
3 that uncertainty. That's a fairly substantial
4 decontamination.

5 MR. SALAY: We're interested in the
6 studies of break-up and agglomeration, and I don't
7 think their follow-on projects went in that
8 direction.

9 MEMBER BANERJEE: Now, that, the
10 decontamination factors are what, on the order of ten
11 or something? I've forgotten.

12 MR. SALAY: Oh, there were ten --

13 MEMBER BANERJEE: I have to go back and
14 look.

15 MR. SALAY: The prediction was ten or less
16 for the ARTIST test. I mean there were small periods
17 where it spiked very high, but then came back down,
18 and then some of it --

19 MEMBER SIEBER: The biggest thing I saw
20 was 1.3 for DF. I might not have seen all of them,
21 but that's the one that --

22 MR. SALAY: See, it actually went -- for
23 short periods of time it spiked quite high.

24 MEMBER BANERJEE: But then they were
25 resuspended.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 MR. SALAY: And there's also concern that
2 in the reactor you have heat deposition which actually
3 revaporize some of the material, you know.

4 MEMBER BANERJEE: But these are titanium
5 dioxide?

6 MR. SALAY: No, no, no. I was referring
7 to a real reactor accident.

8 MEMBER BANERJEE: What would be the
9 present reactor?

10 MR. SALAY: Fission products. They carry
11 with them their heat.

12 MEMBER BANERJEE: Like plutonium or
13 something?

14 MEMBER POWERS: Cesium iodide.

15 PARTICIPANT: There's a whole laundry
16 list.

17 MEMBER BLEY: Is it pretty well
18 established that these surrogates we're using in these
19 tests will behave similarly to the aerosols we'll get
20 out of a core as it degrades?

21 MEMBER POWERS: I would say the evidence
22 is here. We have never seen any aerosol behavior in
23 a reactor accident that suggests anything different
24 than this more mechanical modeling.

25 MEMBER BLEY: We don't have a lot of

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 experience on the reactor accident side.

2 MEMBER POWERS: That's right.

3 MEMBER BLEY: However, there used to be
4 people who said there would be chemical effects.
5 You'd get lots of agglomeration and stuff.

6 MEMBER POWERS: We do get lots of
7 agglomeration. It's not a chemical effect. It's a
8 mechanical effect.

9 MEMBER BLEY: Okay.

10 MEMBER POWERS: We've melted down a lot of
11 fuel assemblies now. We see aerosols coming out. The
12 assumption inherent in all of the aerosol codes at
13 anybody's, you know, NRC's, NOAA's, everybody used
14 that an aerosol protocol is an inert beast, and it
15 behaves inertly.

16 We know that's not true. We know that an
17 aerosol particle has a Vanderwol's attraction
18 (phonetic) to things. We have a very limited database
19 on Hamaker constants to calculate that, but we said
20 it's not important. You can come in and do it by
21 simply saying that it's a mechanical process, and you
22 can treat it as a mechanical process, and consequently
23 it didn't matter what aerosol particle you use as a
24 surrogate because it's an inert thing.

25 MEMBER BLEY: But it would be nice to have

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 the same kind of shapes and charge distributions.

2 MEMBER POWERS: You would like to and
3 especially if you knew what those things are. You
4 know, Mike mentioned some recent tests that have been
5 done. One of the issues is what happens when
6 particles are charged. Does that change things at
7 all?

8 And certainly Hans Jordan and Jim Geesik
9 will be looking at BWR separators and dryers. When
10 they failed to discharge the aerosols, they got
11 different deposition and when they did make sure that
12 the particles were uncharged, and some of the fallout
13 was, "hey, I've looked at these kinds of issues."

14 MEMBER CORRADINI: Can you repeat that
15 again about what they saw? I'm sorry.

16 MEMBER POWERS: Hans Jordan did one
17 experiment with a BWR separator and dryer where he
18 simply by omission failed to run things through his
19 electrostatic discharge unit. So the particles coming
20 in had a non-Boltzman charge distribution. He got
21 different deposition patterns in that separator and
22 dryer.

23 Now, he was using relatively large
24 particles, around five microns so they could carry a
25 charge in case there was no natural drive to a

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 Boltzman distribution in the experiments.

2 And so charging has always been an issue,
3 electrostatic charging, one of what we wrestle with
4 because the radiation field -- the reason particles
5 can get charged in a reactor accident is because of
6 the radiation field. It's not because they're
7 radioactive.

8 And typically what you argue is that in
9 close geometries there's a discharging off the
10 surfaces so that there's not much electrostatic
11 charging, and most of the concern about electrostatic
12 charging has been in the containment where things are
13 not closed.

14 But there have been some experiments. I
15 don't happen to have the results on electrostatic
16 charging in this ARTIST. I don't know what the
17 results are. That's another issue, but otherwise what
18 one does is in the aerosol codes is assume that the
19 particles are inert beasts. Okay? Any aerosol
20 particle will do for an aerosol experiment.

21 And my statement to you is we've never
22 found evidence that contradicts that assumption.

23 MEMBER BLEY: In any experiment?

24 MEMBER POWERS: In any experiment. Now,
25 there are some arguments that if you can get very

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 hydrophilic aerosols, that they become mushy, you
2 know, solution, sticky. They will behave a little
3 differently, and there will be less tendency to
4 bounce.

5 Silicon dioxide particles and the latex
6 spheres that have been used should have very high
7 coefficients of restitution. So they'll be bouncy.

8 Okay. The titanium dioxide particles
9 because of their structure won't be very bouncy, but
10 they'll have a tendency to break up.

11 Okay. Those are all interesting and
12 arcane issues, and it raises a question on how much
13 detail do you want to go to in your aerosol modeling
14 here because suppose somebody told me that it made an
15 absolute difference what the Hamaker constant of the
16 aerosol particle is. Then I'd be stuck in the problem
17 of, okay, what's the Hamaker constant for aerosols
18 coming from a reactor accident.

19 Well, that's a hopeless problem.

20 MEMBER BLEY: Let me ask something a
21 little different. I take it we're not going to go
22 through the Paul Scherrer slides, right?

23 PARTICIPANTS: No.

24 MEMBER BLEY: I found an interesting one.
25 If you open it up, page 19, the one at the bottom,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 what I wanted to ask you guys --

2 MR. LEE: It's 19 on the other one.

3 MEMBER BLEY: What I wanted to ask you
4 guys is given this kind of stuff you were talking
5 about and given the experiments we've had, if you had
6 to do what they did in 1150 as experts on a panel,
7 would you live with something closer to the kind of
8 distributions we see in the experiments or pretty much
9 stretch like the experts used back at that time based
10 on these uncertainties that still remain?

11 MR. SALAY: I didn't quite -- what was the
12 question again?

13 MEMBER BLEY: If you were asked to be on
14 an expert panel to do the next risk study, the bottom
15 slide, that compares the range of what the experts
16 laid forth against what the experiment saw, and what
17 I was asking is as an expert would you have that broad
18 distribution. Would it be broad on one end or would
19 you look more like what's in the experiments?

20 MR. SALAY: In my opinion, it's that it
21 would be the broad.

22 MEMBER BLEY: Too many things that we
23 don't know for sure. I mean, these are nice in that
24 they completely bracketed what the results showed,
25 which isn't always the case.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 MR. SALAY: Yeah, what they did with their
2 retention, they sort of did complying with the DFs
3 that we contend is not correct, and so they replaced
4 some of their integral results with this analysis.

5 MEMBER POWERS: I mean there are some
6 really remarkable things here that I don't presume to
7 quite understand what PSI is doing. Mike put up a
8 slide, and you saw the overall deal was 13. Somehow
9 when Paul Scherrer does the analysis, they analyze it
10 region by region by region, and they end up with 65.
11 Okay?

12 But we have the experimental result that
13 says it's 13. Okay. Now, how do they get those
14 numbers? I leave you to ask them because I can't
15 explain it. One of the observations we get from the
16 test is we put through a steam generator tube
17 conglomerate aerosol titanium dioxide, which behaves
18 like titanium dioxide. It does not necessarily behave
19 like a reactor accident aerosol. I don't know how a
20 reactor accident aerosol behaved, but okay. It's
21 going to look a little more like titanium dioxide than
22 it is a latex sphere. Okay?

23 When they put the titanium dioxide
24 aerosols they started with three micro aerosols. What
25 came out was .7. Okay. When Paul Scherrer does their

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 analysis they say, on the secondary side, they say,
2 "Well, we'll start with three micron aerosols."

3 But by their own experiments they'll never
4 have three micro aerosols, although they all break up
5 inside the tubes. I cannot defend their analysis.

6 MR. LEE: I think if any of you are
7 attending the Anaheim meeting next week, the PSI will
8 be there. There are two sessions on ARTIST. So they
9 will be presenting the ANS meeting.

10 MEMBER CORRADINI: Oh, the ANS meeting,
11 yeah.

12 MEMBER POWERS: I mean, you just have to
13 ask them. This has been the subject of more than a
14 little bit of confusion because like I say, from the
15 separate effects test, we know what kinds of
16 decontamination factors we get at each stage, and
17 we've done the integral test. Okay? And they don't
18 seem to be inconsistent with each other.

19 But somehow, by some mechanism that we
20 don't even begin to understand, when Paul Scherrer
21 does the analysis, they end up with these numbers, and
22 you can see them here: 65 DF, for a situation in
23 which experimental -- no bigger than 13 and probably
24 less, and some of it --

25 MEMBER BLEY: Almost worth a trip to

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 Anaheim.

2 MEMBER POWERS: -- some of it has to do
3 with saying, well, 1.2 DF is like 1.5, and 1.5 you
4 round off. It becomes two. Well, you start
5 multiplying these things together --

6 MEMBER BLEY: And you get 65.

7 MEMBER POWERS: -- you get big numbers
8 very quickly.

9 MEMBER BANERJEE: Well, they're getting
10 numbers around 65 to 70, right?

11 MEMBER POWERS: That's right, and I have
12 no idea how because as you saw from the experiments,
13 we never see those kinds of numbers.

14 MEMBER BANERJEE: which is very different
15 from one and three.

16 MEMBER POWERS: That's right, which we see
17 in the experiments. Now, do you believe the
18 experiments or do you believe the analysis?

19 MEMBER BANERJEE: That has to be
20 reconciled, don't you think?

21 MEMBER POWERS: No, I don't feel we need
22 to reconcile it. They can calculate anything they
23 want to.

24 MEMBER BANERJEE: Is it taking into
25 account that these are not full height for a lot of

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 it?

2 MEMBER POWERS: We do that because steam
3 generator, because its alleged tubes with a bunch of
4 tube support plans --

5 MEMBER BANERJEE: Yeah, right.

6 MEMBER POWERS: Yeah. So each span
7 between a pair of support plates can be treated pretty
8 much the same, not independently. You have to
9 recognize what's going on beforehand.

10 MEMBER BANERJEE: Yeah, but if you did a
11 history calculation of the particle sizes.

12 MEMBER POWERS: Yeah, and they've done
13 enough. When they did three spans for us, that was
14 enough to rest and say, okay, I bet you span number 4,
15 5, and 65 will be about, as it's say there, one, two
16 and three, and there's not much decontamination there.
17 Decontamination factor, 1.2 in three span, okay? That
18 means 20 percent of the material is being removed.

19 MEMBER BANERJEE: How do they get to the
20 65?

21 CHAIRMAN SHACK: I think we could ask
22 them.

23 MEMBER POWERS: You're going to have to
24 ask them because I've never understood that. I can't
25 say they're heated. Orthogonal discussions, how did

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 you get to 70? As you can see, the number is 70.

2 MEMBER CORRADINI: Where are you guys
3 looking? I'm sorry.

4 MEMBER BANERJEE: Slide 8 on page 19.

5 PARTICIPANTS: The top one.

6 MEMBER BLEY: Where they're getting those
7 big numbers.

8 MEMBER BANERJEE: They are getting a
9 decontamination factors of 65 and 70 in their
10 calculations. That's just the --

11 MEMBER CORRADINI: That's the calculation
12 above, huh?

13 MEMBER BANERJEE: And they look at it
14 cumulatively, and yet their experiments don't seem to
15 be in line with that.

16 MEMBER ARMIJO: I think it's something we
17 don't have to explain. We've got ten o'clock, and we
18 don't have --

19 MEMBER BANERJEE: We don't have to
20 explain, but if it's actually true, it gives you some
21 factor --

22 (Simultaneous conversation.)

23 CHAIRMAN SHACK: All right. Mike are you
24 finished with your presentation?

25 MR. SALAY: This is it. We're just on the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 last point --

2 MR. LEE: We are done, yes.

3 MR. SALAY: -- to say that we got our
4 data. We want to end the project with the
5 experimental data on the secondary side of steam
6 generators to fulfill the steam generator action plan
7 Item 3.3(a), and we consider that it's complete.

8 MEMBER ARMIJO: Okay. Any other questions
9 or comments?

10 MEMBER BANERJEE: How are we going to
11 present this and this in one and a half hours?

12 MEMBER ARMIJO: Well, it was impossible,
13 and so it may be fortuitous that they missed their
14 plane.

15 CHAIRMAN SHACK: That's one way to look at
16 it.

17 MEMBER ARMIJO: Mr. Chairman, the meeting
18 is all yours.

19 CHAIRMAN SHACK: Thank you very much.
20 Again, an interesting presentation, and we're ready
21 for a break until 10:20.

22 (Whereupon, the foregoing matter went off
23 the record at 10:03 a.m. and went back on
24 the record at 10:18 a.m.)

25 CHAIRMAN SHACK: Gentlemen, if we can come

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 back into session. Our next topic is Risk Assessment
2 Standardization Project and George will be leading us
3 through that.

4 MEMBER APOSTOLAKIS: Thank you, Bill. As
5 the members know, risk information is used routinely
6 by many groups in the Agency and in very important
7 processes such as the significance determination
8 process, the reactor oversight process, the accident
9 sequence precursor program and other areas. And these
10 risk information is produced by of course, some of the
11 groups using various approaches.

12 So the project we will hear about today,
13 standardization of operation and event risk
14 assessments, RASP, you have RASP, was initiated in
15 response to a user need from the Office of Nuclear
16 Reactor Regulation, which was issued in 2004 and the
17 idea is to standardize these risk assessments so
18 people will be using models that are more or less
19 standard so there will be some uniformity in the
20 information that is being produced and used by the
21 Agency.

22 This is an information meeting, I
23 understand. We --

24 MR. STUTZKE: We're not looking for a
25 letter.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 MEMBER APOSTOLAKIS: The staff is not
2 looking for a letter and we are not particularly
3 anxious to write one unless the members change their
4 mind after. So we'll start with Mr. Mark Cunningham,
5 an old friend that has disappeared for awhile but
6 showed up today. So, Mark.

7 MR. CUNNINGHAM: Thank you, it's nice to
8 be back.

9 MEMBER APOSTOLAKIS: Very good.

10 MR. CUNNINGHAM: I'm Mark Cunningham, the
11 Director of the Division of Risk Assessment in NRR.
12 Marty is going to talk to you today about work that we
13 requested as Dr. Apostolakis indicated in 2004 with a
14 supplemental request in 2006, and another supplemental
15 request that will come later on this year.

16 We are -- I guess I'm here to give you a
17 sense as customer or a user of the information that
18 Marty will talk about. In fact, there's really six
19 organizational units of the agency that are the
20 customers for this work, my Division in NRR, the
21 Division of Inspection and Regional Support in NRR,
22 and the four regional offices. So this has an impact
23 on a wide aspect, wide variety of people around the
24 Agency.

25 We're going to hear a variety of things.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 We have been very pleased with the progress. You'll
2 hear about the things -- some things that we're
3 already very happy with. You're going to hear about
4 some things that we're going to see coming in the
5 future that we've requested. Basically, this is a
6 real key piece of our work to improve the consistency
7 of the PRAs that are being used by the staff in the
8 significance determination process and in other areas
9 as well.

10 Again, we're very pleased with the type of
11 work that's happening here and with that kind of
12 introduction, I'll turn it over to Marty.

13 MR. STUTZKE: Good morning, I'm Marty
14 Stutzke, the Senior Technical Advisor for PRA
15 Technologies in the Division of Risk Analysis, Office
16 of Nuclear Regulatory Research. I'd also call your
17 attention in the audience is my boss, Christianna Lui,
18 who is the Director of DRA, and her Deputy, John
19 Monninger.

20 As George and Mark said, we're here to
21 talk about the standardization of operational event
22 risk assessment which is being done through the RASP
23 project. Turning quickly to the presentation outline,
24 you can see the topics we'll discuss. I call your
25 attention, there are some backup slides here that you

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 may find useful. We've tried to summarize previous
2 ACRS meetings we've had on topics related to RASP.
3 There's also a list of RASP contacts for specific
4 aspects of it, things like that.

5 So briefly, we'll talk about the purpose
6 of RASP, how we got started, the background, a quick
7 introduction to how operational event risk assessment
8 is done. There's several types of assessment.
9 They're done for different purposes. It's not my
10 intention to give you all a tutorial in any great
11 detail about how the assessments are actually done.

12 Then we'll talk about how we've
13 implemented tasks to help us standardize it, where we
14 are now and where we hope to go.

15 The origin of this briefing was the draft
16 report that you guys wrote on the review of the safety
17 research program. That's draft NUREG-1635, Volume 8,
18 back in Chapter 10. And it talks about projects to
19 improve the efficiency and accuracy of NRC's
20 significant assessments of findings and events. So
21 we're here to provide some background to tell you in
22 more detail specifically what we're doing in this
23 area.

24 MEMBER APOSTOLAKIS: What's the date of
25 this ACRS report?

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 MR. STUTZKE: The version I saw was
2 earlier this year. I think it's still in draft form.

3 MEMBER APOSTOLAKIS: Okay, I mean, this
4 one that you provided, NUREG-1635.

5 MR. STUTZKE: Right, that's the current
6 one.

7 MEMBER APOSTOLAKIS: Okay.

8 MR. STUTZKE: As far as I know, it hasn't
9 been formally issued yet.

10 MEMBER APOSTOLAKIS: It has not? It has?

11 MR. STUTZKE: It was in publication throws
12 last I saw.

13 MEMBER APOSTOLAKIS: Well, it has been
14 sent to the Commission.

15 MR. STUTZKE: Right, it was sent to the
16 Commission. But I'll emphasize that RASP is -- it's
17 focused on event assessment. It's not an effort to
18 standardize all PRA within the NRC.

19 MEMBER APOSTOLAKIS: I'm glad you said
20 that. I'm really glad.

21 MR. STUTZKE: The implication if we were
22 to standardize everything in PRA would mean that we
23 already know the answers to everything and we
24 obviously, don't. And if we did, I probably wouldn't
25 have a job.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 MEMBER APOSTOLAKIS: I don't understand
2 the second bullet. Can you explain it? "To provide
3 background", what does that mean?

4 MR. STUTZKE: Well, to be honest, I saw an
5 earlier version of this report that went out and it
6 implied that we were not doing sufficient work to
7 standardize our assessments.

8 MEMBER APOSTOLAKIS: Oh, we hurt your
9 feelings.

10 MR. STUTZKE: And I took exception to it.

11 MEMBER APOSTOLAKIS: Okay, very good.

12 MR. STUTZKE: And as a result, the report
13 got fixed.

14 MEMBER APOSTOLAKIS: Okay.

15 MR. STUTZKE: Okay. So RASP was a project
16 started back in 2004. I want to emphasize it's a true
17 collaborative effort. NRR didn't just send us a user
18 need and send us off into a black hole. There's
19 actually something we call the RUG, the RASP Users
20 Group that meets on an almost monthly -- it seems in
21 recent times it's been almost weekly, like this, but
22 the RUG is a composition of somebody at NRR, somebody
23 that works in Mark's Division, the Division of
24 Inspection and Regional Support as well as research.
25 So we have a large cooperative effort that's been

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 helpful. So the idea is to provide some consistent
2 methods for risk analysis of conditions in ASP and SDP
3 Phase 3 as well as the assessment of events and
4 conditions in ASP and MD 8.3 under --

5 MEMBER APOSTOLAKIS: What is MD 8.3?

6 MR. STUTZKE: I have a slide. In just the
7 next slide, I'll tell you a little bit.

8 MEMBER APOSTOLAKIS: Okay, fine, fine.

9 MR. STUTZKE: But we realize the programs
10 have different purposes and so it's hard to get your
11 arms around it all. We're looking for the common
12 denominator. To give you some -- a little bit of
13 background, as you probably know, SDP was initiated in
14 2001, okay. So you'll see RASP came along about three
15 years later.

16 And of course, the people that actually
17 make SDP evaluations are the regional SRAs as well as
18 participation from Mark's group like that. There are
19 15 SRAs now in the Agency, three per region and three
20 at headquarters like this. And what was observed over
21 time was that sometimes the analyses seemed like they
22 were inconsistent, mutually inconsistent, for the same
23 types of events. There seemed to be a lot of
24 duplicated effort sometimes. And so RASP was an
25 effort to try to get a handle on this, understanding

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 that now we have several years of SDP experience under
2 out belt.

3 Let me talk a little bit about operational
4 event assessment and what they are. There's basically
5 three here. There's the SDP that's part of the
6 reactor oversight. There's MD 8.3 which is the NRC's
7 incident investigation program and then there's
8 accident sequence precursors. As I said before, SDP
9 got started in about 2001. As I recall ASP was in the
10 late '70s, the recommendation, I think, coming out of
11 the WASH-1400 study. So it's been around for a long
12 time. Tens of thousands of events have been assessed
13 under ASP.

14 To give you a little flavor of the
15 differences, it's helpful to think about the concept
16 of the best available information. When the staff
17 does an MD 8.3 evaluation, we're talking about hours
18 or days. Okay.

19 MEMBER BLEY: This is actually done before
20 you'd send out a team to investigate an event?

21 MR. STUTZKE: Yeah, the idea of doing the
22 MD 8.3 investigations to decide the level of response.
23 You can send out an augmented inspection team, special
24 -- you know, what are you going to do? Okay, so
25 you're trying to -- I'll say it's quick, but it's not

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 dirty. You know, you can do the best you can with the
2 information you have to target the response.

3 SDP in contrast, is looking at inspection
4 findings, what's the reaction to an inspection
5 finding? Are you going to do more inspections? Are
6 you going to engage the licensee?

7 MEMBER APOSTOLAKIS: Are they don't still
8 one at a time?

9 MR. STUTZKE: Separate analysis for each
10 performance deficiency unless it's a common
11 deficiency. Yeah, the other distinction among them is
12 if there are multiple or concurrent events going on,
13 you treat those in ASP and MDA 8.3 as best you can.
14 So you're looking at the totality of the event. SDP
15 is fixated on inspection findings.

16 MEMBER BLEY: The MD 8.3, two things; how
17 long has it been around and two, does it also, in
18 addition to deciding the kind of response, does it
19 help decide the makeup of a team that would go out if
20 you do an augmented inspection?

21 MR. STUTZKE: I'm going to kick it to Mark
22 or John?

23 MR. FRANOVICH: This is Mark Franovich.
24 I'm Chief of the PRA Operations Branch in NRR. The
25 procedure dates back as far as 2001. Actually,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 earlier versions may exist prior to that. It uses a
2 framework that uses a set of deterministic criteria as
3 kind of entry conditions and it uses probalistic
4 criteria to try to gauge level of response. There is
5 an overlap region that's set up intentionally between
6 the levels of response because there's a great deal of
7 uncertainty.

8 You're doing this short-term assessment
9 with not a lot of facts. So we try to make some
10 bounding, reasonable bounding assumptions. The
11 composition of the teams will be dictated by the
12 complexity of the event. So for example, if you have
13 an event where there are operator performance issues
14 combined with equipment failures, you'll have both
15 examiners, operating licensing examiners, resident
16 inspector may be involved as well as specialists to
17 look at the component failure, so it depends on the
18 set of circumstances, and that's sort of a management
19 decision between the regional offices and NRR.

20 MR. STUTZKE: Okay, the concept of event
21 risk assessment is I find pretty straightforward. The
22 idea is to look at what else could have happened in an
23 event, an incident, that didn't actually or
24 necessarily happen and that has implications for core
25 damage or containment failures, these sorts of things

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 like that. So the point is that event risk assessment
2 is future-oriented. That's probably pretty obvious to
3 a PRA engineer. Probability is a description of the
4 future. Once an event happens, we know with certainty
5 whether there was core damage or not to some extent.

6 So we're trying -- the idea is to extract
7 what lessons we can get out of it, okay, the
8 implications for similar events into the future. And
9 it's done by manipulating the actual logic model. We
10 use two figures of merit, conditional core damage
11 probability for initiating events, so it's given the
12 initiating event and all the other failures, degraded
13 conditions that happen, what's the actual conditional
14 core damage probability.

15 For events or degraded conditions,
16 inspection findings this sort of thing, the figure of
17 merit is the change in the core damage probability
18 over the duration where the conditions existed, like
19 that. And the idea of something called the failure
20 memory concept, actual failures that were observed in
21 the event or modeled as failures in the PRA, you set
22 them to blue and true.

23 Okay, successes remain at their nominal
24 failure probability assuming analysis. Okay, so you
25 set up the RPA and basically turn the crank and you

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 regenerate the core damage frequency and from that,
2 you can calculate the other figures of merit that
3 you're interested in. The intention of RASP in one
4 way is to try to make this process consistent among
5 the analysts.

6 MEMBER APOSTOLAKIS: So essentially, we're
7 calculating how close -- how close --

8 MR. STUTZKE: Yeah, it gives you a
9 quantitative measure of how close to core damage you
10 were. The one thing that I didn't mention that I
11 probably should have is for the accident sequence
12 precursors. Of course, it's the full-blown analysis.
13 It's used to measure performance against the safety
14 goal and the NRC's strategic plan. There's an annual
15 SECY paper that the staff writes on it and the more
16 important precursor events are actually reported to
17 Congress.

18 MEMBER BLEY: There's one thing I've
19 always been interested in the ASP program, have we had
20 cases where the event doesn't quite fit the PRA model
21 you have such that we ought to let everybody know that
22 we've learned something that ought to be built into
23 our PRA models and is there a mechanism for doing such
24 a thing if it occurs?

25 MR. STUTZKE: Yes, there's actually --

1 that happens actually, quite often and those insights
2 are fed back into the baseline SPAR models that we
3 use.

4 MEMBER BLEY: Are they published more
5 generally so others who are doing risk assessment
6 might learn from them?

7 MR. STUTZKE: SPAR models aren't publicly
8 available.

9 MEMBER APOSTOLAKIS: That issue has come
10 up in the past when -- even when there was the AEOD
11 office.

12 MR. STUTZKE: Yes.

13 MEMBER APOSTOLAKIS: And the biggest
14 problem was -- I mean, they were issuing NUREG reports
15 but I don't think that practitioners outside the NRC
16 paid much attention to them.

17 MEMBER BLEY: They weren't issuing the
18 reports in a way that would have summarized this kind
19 of surprise, we need to -- "Here's something you ought
20 to build into your models". There wasn't a section
21 like that in the reports. You had to read through and
22 find it yourself.

23 MR. STUTZKE: To be honest, I think we've
24 made a lot of progress in recent years. We'll talk
25 about it a little bit later, but the staff has done

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 detailed and cutset-level reviews of the licensee's
2 PRAs to SPAR models to look at the differences.

3 MEMBER BLEY: So that a way to feed them?

4 MR. STUTZKE: That's one way to do it, and
5 it's not all the time we're changing our models.
6 Sometimes they're changing theirs. It also has
7 generated other sorts of research. You know, we're
8 looking at re-evaluating success criteria now as a
9 result of that.

10 MEMBER APOSTOLAKIS: But there could be
11 some finding that appears in the modified SPAR model
12 that the industry at large is not aware of.

13 MEMBER BLEY: There could be and if that
14 were a section of the annual ASP summary, those kind
15 of things, that could be a useful bit of information.
16 Sorry, go on.

17 MR. STUTZKE: Okay, as far as the
18 standardization approach, it breaks down into three
19 large areas; document methods and provide guidelines
20 for the risk analysis and you can look at the sub-
21 bullets and understand that we're talking about all
22 initiating events, all operating modes.

23 The other major sub-bullet is to improve
24 the fidelity of the SPAR model itself to try to better
25 model the as-built, as-operated plant. Extending SPAR

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 into external events, shut-down events and LERF Level
2 2 sorts of things.

3 The last bullet on enhancing analysis
4 methods and providing technical support, this is a
5 reference to the fact that what we do in RASP is to
6 encapsulate other sorts of research that's done, okay.
7 There are research activities that are within RASP
8 such as updating the parameter estimates, the common
9 cause failure methodology and things. But there are
10 other activities that NRR has or that RES has in place
11 that are driven by other types of user needs, okay.
12 And so we're trying to extract the best that we can
13 out of them and feed them into RASP.

14 MEMBER APOSTOLAKIS: So, Marty, this
15 brings up a related question. How often is this, I
16 don't know, project or report or approach supposed to
17 be updated? I mean, I assume it's a living document.
18 Is it a document?

19 MR. STUTZKE: Yes, there are handbooks.

20 MEMBER APOSTOLAKIS: It is a document
21 because all we got was a 10, 11-page summary. Is it
22 NUREG of some sort?

23 MR. STUTZKE: Well, they're not NUREGs.
24 They're RASP handbooks and they're available on --

25 MEMBER APOSTOLAKIS: Okay, how often are

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 these supposed to be updated to accommodated what you
2 just said?

3 MR. STUTZKE: Well, actually, we've issued
4 the first revision in January and we're already
5 revising them, fleshing them on.

6 MEMBER APOSTOLAKIS: Is that something on
7 an ad hoc basis?

8 MR. STUTZKE: It's an ad hoc, continuing
9 basis, like this.

10 MEMBER STETKAR: Marty, under the bullet
11 that says "Improve SPAR model fidelity", the second
12 sub-bullet for external events, shut-down events, in
13 particular, how are you doing that and in particular,
14 for external events, you typically require a lot of
15 plant-specific information about the location of
16 cables, walk-downs. How do you do that within the
17 SPAR model context and also for shut-down events, you
18 need to know an awful lot about how each facility
19 manages their outages, how they integrate testing,
20 maintenance activities, over the course of plant
21 operating states or whatever jargon you use for
22 breaking up the outage?

23 It's very, very, very plant specific
24 information and very different from facility to
25 facility. Do you propose to integrate that level of

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 detail into the SPAR models, and if not, how are you
2 going to go about it?

3 MR. STUTZKE: Well, you've jumped ahead.
4 We have another slide on 11 that talks --

5 MEMBER STETKAR: Okay, go.

6 MR. STUTZKE: -- but the quick and dirty
7 answer is we don't have external event models for
8 every plant but we have internal models. Okay, we've
9 built 15 so far. We've got five shutdown event
10 models, two LERF-type models, and we're trying to
11 decide where to go forward now.

12 MEMBER STETKAR: I'll wait till you get to
13 the more detailed slide, then.

14 MR. STUTZKE: Okay, so the actual user
15 needs that were specified for Office of Research was
16 to develop the guidelines for internal events, that
17 the guidelines and methods for external events, fire,
18 flood, shut-down low power events, LERF type of
19 analyses, enhancing the SPAR models and that actual
20 GEM/SAPHIRE code, as well as ongoing technical
21 support.

22 I look at this user need, sort of like a
23 task order vehicle that encompasses a lot of things.
24 It was supplemented in '06 to go after some success
25 criteria work for the SPAR models, some actual

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 thermohydraulic work like that. But it's been a
2 little confusing.

3 The next couple of slides are summarizing
4 what we've achieved and where we want to go. The
5 handbooks themselves were issued in January of 2008.
6 They are publicly available. The ADAMS accession
7 numbers are there. Volumes 1 and 2, that talk about
8 internal and external events are based on our existing
9 methods that we've used in SDP and ASP analyses.
10 Volume 3 is our guidance on how to review SPAR model
11 revisions. It's following NUREG CR 3485 and as best
12 we can the ASME PRA standard.

13 Okay, the handbooks are referenced inside
14 the inspection manual chapter 0609, so we've made that
15 link. They've had rather extensive internal review by
16 NRC and the contractors and the actual Volumes 1 and
17 2 have been in trial use for a couple of years now.
18 We've smoke-tested them pretty well. The other thing
19 that I'll point out is that licensees have, we feel,
20 ample opportunity to feedback on these handbooks.

21 For example, there are monthly meetings on
22 the reactor oversight process and they can complain
23 and make suggestions there. There's an SDP survey
24 that goes on. I think it's bi-annual like that, and
25 as well, if you read in the introduction, it talks

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 about if you have a comment on the book, here's how to
2 submit it.

3 MEMBER BLEY: Are you getting many
4 comments?

5 MR. STUTZKE: Not yet.

6 MEMBER BLEY: That's after two years.

7 MR. STUTZKE: Well, you know, the sorts of
8 comments, I mean, to be honest is that when we do an
9 SDP and we say it's yellow and they say it's green,
10 then we get a lot of comments.

11 MR. FRANOVICH: Marty, this is Mark
12 Franovich again, NRR, DRA. We're expecting some
13 feedback in the more formal structured feedback from
14 NEI. We learned yesterday actually that they're
15 interested in coming in or needing specific feedback
16 on CCF modeling and HRA as well. Lots of perceptions
17 of conservatism in our approach. So that's one view.

18 MEMBER MAYNARD: I'm just a little
19 confused and I think I'm getting some things mixed up
20 here. You say you're getting, or you have
21 opportunities for the industry feedback on some of
22 these and earlier you said, I think the SPAR models
23 are not publicly available. Am I getting some things
24 mixed up here or how are you getting feedback on --

25 MR. STUTZKE: Well, the models themselves

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 are not available for security issues like that. The
2 handbooks of how we do the analysis are available. So
3 the idea is, you know, if there's some event going on,
4 the licensee will, of course, make its own analysis.

5 MEMBER BLEY: Have the licensees looked
6 over your SPAR models? Do they get -- can they see
7 their own?

8 MR. STUTZKE: Yes.

9 MEMBER APOSTOLAKIS: Yeah, the individual
10 utilities --

11 MEMBER BLEY: Have the SPAR models, okay.

12 MR. STUTZKE: Yeah.

13 MEMBER APOSTOLAKIS: And there has been a
14 benchmarking, yeah. Harold, would it be worthwhile to
15 look at these volumes for us? I don't know.

16 MR. VANDER MOLLEN: We could ask to look
17 at them.

18 MEMBER APOSTOLAKIS: Would you send me a
19 CD with -- these are electronically available, right?

20 MR. STUTZKE: Yeah, they are
21 electronically available.

22 MEMBER APOSTOLAKIS: I don't know if
23 anybody else wants them. Do you want them?

24 MR. STUTZKE: I'll dispatch them.

25 MEMBER APOSTOLAKIS: Okay.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 MR. STUTZKE: I've tested these links at
2 home. They work.

3 (Laughter)

4 MEMBER BLEY: You mean, they did.

5 MR. STUTZKE: You know, you never know.
6 Well, as of a couple of days ago, they did. One never
7 knows.

8 MEMBER APOSTOLAKIS: You mean I can do it
9 from home?

10 MEMBER CORRADINI: Sure, if you know
11 CITRIX.

12 MR. STUTZKE: These are on the public
13 website. You don't need CITRIX for this.

14 CHAIRMAN SHACK: You can do the ADAMS base
15 public search.

16 MEMBER APOSTOLAKIS: Okay.

17 MR. STUTZKE: Okay, so to return a little
18 bit to John's question, we've done the cutset-level
19 reviews for almost all of the licensee's PRAs. I
20 think there's like four that are outstanding like
21 that. There have been updates to the SPAR models for
22 station blackout modeling like this. NUREG CR 6928
23 was issued that are the updated SPAR parameter models
24 that came out in January of last year.

25 This is the actual failure rate data okay,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 that you use to quantify PRA. Did I throw that hard
2 enough? The SPAR model QA plan has been updated and
3 according to the acting branch chief ruthlessly
4 implemented.

5 MEMBER APOSTOLAKIS: Now SPAR uses, when
6 it comes to human reliability SPAR-H. And I mean,
7 this is a very important activity of the Agency. We
8 use this I would say simple, maybe more than compared
9 to other models and at the same time, the Office of
10 Research has been working on other models like ATHEANA
11 that the industry, using the calculator and all that.

12 Is there an inconsistency there? I mean,
13 are there any plans to maybe look at SPAR-H and as you
14 said earlier, as more knowledge and models become
15 available, try to adapt it because we are spending a
16 lot of resources on research and yet, we're using
17 SPAR-H for important decisions.

18 MR. STUTZKE: Well, the way that I would
19 answer you is, and we all know what SPAR-H is and we
20 know what it is not as far as the HRA methodology. To
21 some extent, the staff is, in my mind, between a rock
22 and a hard place. We have to make the assessments now
23 with the imperfect tools that we have available. Part
24 of the last program was to publish the SPAR-H
25 handbook, so at least it was written down.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 Right now, we're not doing any development
2 work or additional work on SPAR-H. We're awaiting the
3 results of the international HRA bench marking
4 exercise that the staff was involved in and we'll
5 decide after that's over, where we want to go in this
6 area. I would anticipate changes and then we may
7 scrap SPAR-H all together, we may modify it. We may
8 decide that it's okay for our purposes, anything like
9 that, but we're well aware of the inadequacies of the
10 tool.

11 The other thing that I would point out is
12 that we have another task that's called RES Technical
13 Support and it's talked about on Slide 13, but let me
14 jump ahead. The idea of the task is that if we need
15 a real HRA analyst in the course of an event
16 assessment. Say NRR, the regional offices, they do an
17 event assessment and they say, "Gee, I'm confused",
18 they have access through this user need directly to
19 our experts. It's not like they need to come and
20 write us a new user need and go through the
21 bureaucracy. They can just call us up and we'll send
22 them to the right people. Not just HRA, Level 2, you
23 know, the full resources of the Agency are available
24 to them through this user need capability.

25 Now, as I've mentioned before, we have 15

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 external event models, about five shut-down event
2 models and two preliminary level 2 types of SPAR
3 models. We're not doing any more work on these right
4 now. They're on hold.

5 MEMBER STETKAR: Those models, Marty, now
6 I can ask the veto question because you have the right
7 slide. Those models, the external events models, are
8 they fully detailed models of the exact -- of the
9 actual plants, including cable routing and locations
10 of equipment?

11 MR. STUTZKE: No, they're simplified.

12 MEMBER STETKAR: How simplified?

13 MR. STUTZKE: Well, for example, in the
14 seismic model, there's only three seismic initiators.

15 MEMBER STETKAR: No, I'm asking about
16 locations of equipment inside the plant for fires and
17 things like that.

18 MR. STUTZKE: Well, the way the models
19 were constructed was to look at the major results that
20 were coming out of licensee's PRAs and to duplicate
21 them, put them back into the SPAR model, not full-
22 blown bottoms-up types of risk assessments.

23 MEMBER STETKAR: That's the same for the
24 shut-down events models, they're just hard-wired
25 cutsets?

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 MR. STUTZKE: They're not as hard-wired.

2 MEMBER STETKAR: What are they?

3 MR. STUTZKE: It's something I can -- they
4 model several plant operating --

5 MEMBER STETKAR: I mean, the term, 15
6 integrated Rev 3 SPAR models sounds pretty
7 sophisticated to me and from what I'm hearing, it
8 doesn't sound --

9 MR. STUTZKE: Well, they're integrated in
10 the sense that they're built on the internal events
11 models, so you pick up all the random failures from
12 the operator failures.

13 MEMBER BLEY: Well, were they based on
14 more detailed models that the plant had?

15 MR. STUTZKE: Yes, they're based on the
16 more detailed models that came out of the plants.

17 MEMBER BLEY: They're taking the most
18 important parts of --

19 MR. STUTZKE: Right.

20 MR. FRANOVICH: This is Mark Franovich
21 again, NRR DRA. Just a few comments on external
22 events. One thing that we're trying to work with
23 research here in the next few months actually is
24 trying to come up with an approach to capture the PRA
25 insights from NFPA 805 submittals that will be pending

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 here over the next few years and trying to use those
2 to develop some form of models. Don't know how to do
3 that yet. That's still a --

4 MEMBER STETKAR: The most important
5 insights from anyone who's ever done a shut-down risk
6 assessment, or an internal fire or a flooding
7 assessment is that you have to know what is located
8 inside the plant, where the cables are routed, what is
9 located in what cabinets and where those cabinets are
10 located inside the plant to do a fire analysis or a
11 flooding analysis and for a shut-down analysis you
12 need to know how that utility organizes its refueling
13 outages.

14 When do they do particular types of
15 maintenance at what stage in the outage as a function
16 of pressure in the vessel, status of isolation and
17 things like that. That's not a philosophical finding
18 about modeling fires it's how the plant is actually
19 configured. So it's not something you'd need to do
20 research. You need to go to the plant.

21 MR. FRANOVICH: I don't disagree and let
22 me comment on the shut-down piece for a moment.
23 You're right, no two outages are alike. You do need
24 to understand in model development what the operating
25 practices are at the plant, especially for

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 configuration risk management. The models that are
2 the five integrated models that Marty is referring to,
3 the way those were developed was an effort where the
4 analyst, both contractors, NRR, actually and also
5 research, all three, go to the plant and actually
6 conduct interviews with the outage planners,
7 understand what the station operating practices are,
8 to come up with some form of static model.

9 When you get a specific event to try to
10 model, it's not a matter of simply exercising the
11 static model. If it's a significant event by
12 practice, what we do is we actually send a small team
13 back to the site. Let's look at the specific
14 configuration, let's interview the operators, let's
15 understand if they have any rules of thumb they may be
16 applying that aren't proceduralized.

17 Those context are very important in doing
18 the assessment. But we have now are just five models
19 and actually, we're looking at doing another user need
20 or a modification of it to develop at least a model
21 for each type of reactor out there as a basic template
22 to start with because trying to develop 71 models is,
23 given our limited PRA resources, it's just not
24 practical. So we need to come up with some sort of
25 stop-gap approach.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 MEMBER STETKAR: Okay, you said some
2 things that are encouraging. You said for the five
3 that you have, at least what I heard was that you did
4 go to those plants and interview people in the outage
5 planning departments and recognizing that each outage
6 is slightly different, most plants, especially these
7 days, have a general outage plan. They're getting
8 much better at doing outages.

9 So that the deviations from outage to
10 outage are much smaller than they used to be. However
11 from plant to plant, there can be significant
12 variations. They're trying to standardize that across
13 a fleet, obviously nowadays. I'm not sure how useful
14 boiling water outages as a generic class versus
15 pressurized water outages as a generic class would be.
16 I'd have to think about that.

17 MR. FRANOVICH: I think we're looking at
18 more down in the level of BWR-2, 3, 4, 5, not just the
19 simple BWR template, PWR template, but there are some
20 configuration issues in mid-loop operations that have
21 some variability out there.

22 MEMBER STETKAR: What about, can you tell
23 me a little bit about the external events models,
24 because you have 15 of those. Did you also do a
25 similar type of exercise to go to the plant and

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 determine basic layouts of equipment anyway? You
2 know, where are the switch gear rooms, how many
3 different instrument control cabinet rooms, where are
4 they generally located so you could even make some
5 decent guesstimates of where cables were routed and
6 things like that?

7 MR. FRANOVICH: Unfortunately, the answer
8 is now, in general. Most of these models were
9 developed largely from the IPEEE submittals. So they
10 have an enormous amount of uncertainty. That's why
11 we're looking at for the population of 805 plants
12 trying to come with some process whereby 805 process
13 itself you have to do those plant walk-downs, the
14 cable routing, you do the circuit analysis and all
15 that. That's a much better set of information to
16 capture, but that's still a lot of work in progress.
17 We're talking years down the road.

18 MEMBER STETKAR: Okay, thanks.

19 MR. STUTZKE: Okay, so the third task was
20 actually improving software tools SAPHIRE and GEM. By
21 the way, I'll throw out, we can provide a demo if
22 you're interested in seeing the latest version of the
23 software. In fact, I think we had one scheduled and
24 it got postponed and things like that.

25 MEMBER STETKAR: That could be useful.

1 MR. STUTZKE: We're willing to set that
2 up. Let's see how it does it but new user interface
3 for the STP Phase 2 analysis, fixing up user
4 interfaces for Phase 3, ASP, more capabilities from
5 the SPAR model, trying to make the link between the
6 Level 1 and the Level 2, that's the reference to the
7 LERF modeling like this.

8 And, of course, the calculational methods,
9 the implementation of the common cause failure
10 assessment for operational events, some different
11 mission times. Beta testing is going to start
12 momentarily, within weeks, like that, culminating
13 towards by the end of 2009 to get the tool actually
14 out and up and using it. A nice user fix now, it
15 looks slick.

16 MEMBER BLEY: As far as -- I'm sorry, is
17 SAPHIRE pretty stable now? There was a time when it
18 was getting changed almost weekly.

19 MR. STUTZKE: I think it's reached a
20 certain level of maturity. I mean, you know, these
21 software designers always want to mess with things
22 like that.

23 MEMBER BLEY: Well, to help out their
24 clients.

25 MR. STUTZKE: And put a few dollars in

1 your pocket. But the other thing that I'll mention
2 for the beta testing, it's not just the staff. NASA
3 is involved in the beta testing because they use
4 SAPHIRE extensively.

5 MEMBER STETKAR: Marty, it's been awhile
6 and I don't want to get too far off track here. You
7 have the bullet about common cause modeling. It's
8 been awhile since I've played with SAPHIRE. Is there
9 now an automated generation of the -- you can specify
10 groups and --

11 MR. STUTZKE: Yes, right.

12 MEMBER STETKAR: Excellent.

13 MR. STUTZKE: Yes, you can find the groups
14 and it throws the events in for you.

15 MEMBER STETKAR: Wonderful.

16 MR. STUTZKE: I think it even calculates
17 them correctly now.

18 MEMBER STETKAR: Minor details. Minor
19 details.

20 MR. STUTZKE: Okay, so the tech support as
21 we had mentioned before, to the various NRR analysts
22 and SRAs as they need to. That includes -- part of
23 the tech support includes training of the SRA
24 counterpart meetings that are held every six months
25 about. In fact we just had one it was just last week

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 or so and all the SRAs were down in Bethesda with us.
2 As I'd said before, any time they need the expertise,
3 they can call us and we'll provide it for the user
4 need.

5 You can see, here's a list of the more
6 common sorts of areas of tech support that we will
7 provide. We've also summarized a lot of information
8 that's been compiled during the RASP process on
9 something we call the RASP toolbox. This web page is
10 not publicly available. It's only available on the
11 NRC intranet. It's basically a convenient summary, a
12 number of hot links to the various -- for example,
13 NUREG CR's you can pull up the actual handbook, et
14 cetera, like that.

15 Most of the information on that web page
16 is publicly available in other forms. I mean, you can
17 always get a NUREG. There are some things on there
18 that are proprietary like our link into the EPIX
19 system and things like that. One of the backup pages,
20 I've actually given you the URL, if you want to pull
21 it up and see what's there. I find that personally
22 it's a very useful page. My only problem is the font
23 size is too small. As I get older, I can't read it
24 any more.

25 But that's a good segue into this what I

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 call the work breakdown structure. There's a great
2 deal more to RASP and this interface than perhaps,
3 just the handbooks. The handbooks are part of it.
4 You can see the tech support, the SAPHIRE/GEM, SPAR
5 model updates and things like that. This kind of
6 breaks down and gives you a big picture sort of thing,
7 but there are other activities ongoing, for example,
8 SPAR model development, that are not under the
9 umbrella of RASP.

10 For example, we have a user need from the
11 Office of New Reactors to build SPAR models for new
12 plants. Okay, we just received it within the last
13 couple of weeks. It's three now, within the next
14 couple of years.

15 MEMBER APOSTOLAKIS: For new plants, what
16 does that mean. I mean --

17 MR. STUTZKE: AP 1000.

18 MEMBER APOSTOLAKIS: -- the design
19 certification part?

20 MR. STUTZKE: Right, as best we can.

21 MEMBER APOSTOLAKIS: I see. What would
22 they do with those, play -- do sensitivity analysis or
23 do --

24 MR. STUTZKE: Well, I think it's in
25 preparation for when a license is actually granted.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 You need to be able to get ready to implement the ROP,
2 Reactor Oversight Process. You need to begin to
3 regulate once the license is issued and --

4 MEMBER APOSTOLAKIS: So this is the first
5 step because --

6 MR. STUTZKE: This is the very first step.

7 MEMBER APOSTOLAKIS: We'd have to do a
8 more detailed --

9 MR. STUTZKE: Right, I mean, eventually --
10 I mean, I look at them almost like templates and so an
11 actual licensee that would build an AP-1000 you would
12 make it more plant specific. You know, there are
13 things that are not within the certified design
14 envelop.

15 MEMBER BLEY: So if you built a SPAR model
16 for one of the new plants, you'd just go to the
17 vendor's fault trees and put them into SPAR, into --

18 MEMBER STETKAR: Well, we haven't started
19 the work yet, but --

20 MEMBER BLEY: Is that what you anticipate
21 or something different.

22 MR. STUTZKE: No.

23 MEMBER APOSTOLAKIS: That's the only thing
24 that's available, isn't it?

25 MR. STUTZKE: No. That's the information

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 that's available.

2 MEMBER APOSTOLAKIS: Yeah.

3 MR. STUTZKE: Okay, but, you know, you
4 know enough about the design, you could develop fault
5 tree of entry from scratch.

6 MEMBER BLEY: Well, you could.

7 MEMBER CORRADINI: But why would you do
8 that?

9 MR. STUTZKE: It would be a check and the
10 reconciliation again for awhile. As I say, the user
11 need has just come through us. It's new. It's a
12 balance we're having trouble finding. We have
13 conflict of interest, contractual problems.

14 MEMBER CORRADINI: Now, wait a minute, I
15 don't understand. I'm sorry.

16 MR. STUTZKE: Between Idaho.

17 MEMBER APOSTOLAKIS: Idaho is doing all of
18 his work or most of it?

19 MR. STUTZKE: Well, Idaho is our
20 contractor for SAPHIRE and GEM and they are the
21 constructors of that. And they're related to Bechtel,
22 okay, and so there are issues like this.

23 MEMBER CORRADINI: They're related, but
24 they're not related.

25 MR. STUTZKE: It's an issue, it's an

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 issue. And to find other contracts is turning out to
2 be a challenge as well. So but the point here of this
3 slide is that there are other activities that go on
4 that are overlapping, RASP and that we're trying to
5 utilize like this.

6 Okay, so in the future, you know, we're
7 going to complete Volume 1 by adding the new guidance
8 for common cause failure modeling, the new parameter
9 estimates updates, work on sensitivity analysis, HRA,
10 simplified expert elicitation. All of these things
11 are yet to be done, okay.

12 MEMBER BLEY: What's in your head about
13 simplified expert elicitation?

14 MR. STUTZKE: Well, there is the report
15 from Idaho Labs that's been issued.

16 MEMBER BLEY: Current? I mean, it's just
17 come out or has it been out?

18 MR. STUTZKE: It's relatively current. I
19 haven't read it. I don't know what's in there yet.

20 MEMBER BLEY: Is it a NUREG or it's an
21 Idaho --

22 MR. STUTZKE: It's an Idaho Reg.

23 MEMBER BLEY: Is this publicly available?
24 We could get it.

25 MR. STUTZKE: Yeah, you could get it.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 MEMBER BLEY: We'd like to see it.

2 MEMBER APOSTOLAKIS: So, Marty, how
3 different is this RASP handbook from the ASME stuff,
4 or to put it differently, why can't --

5 MR. STUTZKE: I would characterize it --
6 you know, the ASME standard is here's what you need to
7 do. As RASP handbook is here's how you should do it.

8 MEMBER APOSTOLAKIS: So it takes off from
9 the ASME standard then.

10 MR. STUTZKE: Well, it's built on it.
11 It's built in part. In other words, Volume 3 of the
12 QA process is linked to the ASME standard. We went
13 through that to try to capture a process.

14 MEMBER CORRADINI: So it's a handbook that
15 actually tells you how to do it, a way to do it, not
16 the way.

17 MR. STUTZKE: Yeah, the specific
18 assumptions.

19 MEMBER CORRADINI: Yeah.

20 MR. STUTZKE: Well, it's the way in the --
21 to the extent we're trying to standardize the staff's
22 operational event risk analysis.

23 MEMBER CORRADINI: But it's for the staff.

24 MR. STUTZKE: For the staff and licensees
25 can do what licensees can do and they need to justify

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 it.

2 MEMBER CORRADINI: But if I were a
3 licensee, this might be used as a path of least
4 resistance.

5 MR. STUTZKE: Yes.

6 MEMBER CORRADINI: Thank you.

7 MEMBER SIEBER: I presume it's focused on
8 the SPAR model and ancillary models, so it's value to
9 a licensee is probably limited.

10 MR. STUTZKE: Yes. Well, the licensee can
11 gain things out of it. I mean, it will talk about
12 things like mission times and PRAs, what do we assume.

13 MEMBER SIEBER: And insights about the way
14 you do your business.

15 MR. STUTZKE: Right.

16 MEMBER SIEBER: How big is that Volume 1?
17 Is it available to me?

18 MR. STUTZKE: Yeah, again, that's
19 electronically available in ADAMS. We can give it to
20 you on disk if you want it.

21 MEMBER SIEBER: That would be good.

22 MR. STUTZKE: We can make arrangements
23 with Harold and provide some electronic copies. So
24 again, revising Volumes 1, 2 and 3 based on user
25 feedback, we needed to develop new models for shutdown

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 of low power and for LERF. We continue to look at the
2 enhancement of methodologies for common cause failure.
3 We have a draft NUREG CR that came out on that. It's
4 this thing that Dale Rasmussen published, was issued.
5 This is dated April of this year. Here's one on LOCA
6 pipe frequencies, expert elicitation.

7 MEMBER BLEY: Yeah, that's -- we've
8 reviewed that work. He'd good.

9 MEMBER APOSTOLAKIS: No, we didn't do the
10 LOCA.

11 MEMBER BLEY: That's where that came from,
12 right?

13 MEMBER APOSTOLAKIS: That was not
14 simplified. That was --

15 MR. STUTZKE: You're talking about the
16 full expert elicitation for --

17 MEMBER BLEY: Yes.

18 MR. STUTZKE: This is the reduction of
19 that to come up with initiating event frequencies for
20 SPAR. Okay.

21 MEMBER BLEY: Oh, great.

22 MEMBER APOSTOLAKIS: At some point, I
23 remember the ACRS recommended that the Commission or
24 the Staff develop a -- I mean, we recognized that
25 there were several approaches to expert opinion

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 elicitation that various groups within the Agency use
2 and we recommend that maybe one or two should be used
3 agency-wide. So these guys from Idaho now simply find
4 what was done for the LOCA frequencies and at the same
5 time we have the seismic people going back to the
6 Shock (phonetic) methodology and working on it? Is
7 there any effort to create a common methodology? Then
8 I think we have the Materials Office using its own
9 approach.

10 MR. STUTZKE: Yeah, I think what I would
11 expect, I mean, we haven't started the development of
12 the handbook chapters for the expert elicitation
13 method, okay? So it's in its infancy and what I would
14 envision -- I remembered your comment about a, you
15 know, more broad agency-wide --

16 MEMBER APOSTOLAKIS: Yeah.

17 MR. STUTZKE: -- method and I think we
18 ought to revisit it at that time.

19 MEMBER APOSTOLAKIS: Good.

20 MR. STUTZKE: One of the things that RASP
21 does, we don't just suck in the information, it also
22 helps us drive the research agenda to some extent, so
23 you know, we really need to look into this. There's
24 give and take in there.

25 MEMBER BLEY: And all of this stuff is in

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 the RASP website, the toolbox page?

2 MR. STUTZKE: Yes. If you look at the
3 website, you'll know what we know basically. They
4 keep it up to date. Okay, and then we talked earlier
5 about the HRA and we're waiting to see the
6 benchmarking results to decide where we want to go in
7 the future on that.

8 Okay, ongoing work, some issues here that
9 you might be interested in, enhancing the internal
10 events SPAR models, two years ago, we got an addendum
11 to our user need about success criteria re-evaluation
12 of thermohydraulic analysis. There were some cases
13 where the SPAR models appeared to be conservative to
14 the licensee's PRA and we wanted to go after them with
15 better thermohydraulic tools, be it MELCOR or TRAC,
16 whatever we have in our arsenal upstairs to do it.

17 Part of the interesting work that came out
18 of that was a work that Dr. Rick Cherry's been doing
19 on a phenomenological definition of core damage. The
20 idea is when a thermohydraulic analyst makes a
21 computer analysis, how does he know when core damage
22 has occurred? What are the actual parameters that
23 he's looking at? Is it collapsed level, is it
24 temperature? You know, what should it be and Rick's
25 been doing a lot of work in the are. It might be

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 something else you're interested in looked at.

2 MEMBER APOSTOLAKIS: Yeah, I'd like to see
3 that at some point.

4 MR. STUTZKE: There are some presentations
5 there.

6 MEMBER BLEY: We should fire up CITRIX.

7 MR. STUTZKE: None of that -- that work
8 will be on the RASP toolbox page, under the SRA
9 counterparts meeting. It will be in the handouts to
10 the counterparts meeting. We can show you later how
11 to access the page.

12 The other thing I would point out is that
13 we have a memorandum of understanding with the
14 Electric Power Research Institute for a variety of
15 research topics. It's one of the backup slides that
16 was the areas we're looking at. We're talking about
17 things like -- let me pull back here, support system,
18 initiating event, fault trees, how to draw those,
19 treatments of loss of offsite power, things like that.

20 And you inject in the containments and
21 BWRs after they fail?

22 MEMBER APOSTOLAKIS: So what does it mean,
23 Marty, you're doing it together or what?

24 MR. STUTZKE: Joint project. There are
25 working groups developed between industry and NRC

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 staff like this. Meetings -- you know, staff has gone
2 to meetings and travel and things like this. The
3 other thing is, I know that we're in the process of at
4 least two addenda to this MOU, one on seismic and
5 another one on HRA Erasmia sent me yesterday. I
6 haven't had a chance to look at it.

7 It's a good cooperative effort.

8 CHAIRMAN SHACK: Marty, somehow I would
9 have thought when you're reconciling SPAR model with
10 the PRA licensee model, the success criteria would be
11 almost the first place you'd look.

12 MR. STUTZKE: That's how a lot of these
13 were identified, in their cutset level review.

14 CHAIRMAN SHACK: Okay, and --

15 MR. STUTZKE: The differences.

16 CHAIRMAN SHACK: Oh, the differences,
17 okay. But I mean, you're not proposing that they re-
18 evaluate with a new core damage criterion for their
19 own success criterion or that may come out of this.

20 MR. STUTZKE: That may come out of this
21 eventually. I mean, it's real curious, when you look
22 at the ASME/PRA standard, they give you several
23 definitions of core damage, collapse level,
24 temperatures, different temperature limits, 1800, 2200
25 and it's not surprising, you get a variety of results.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 MEMBER APOSTOLAKIS: So if we ask now
2 officially the Agency what is the definition of core
3 damage, when we talk about core damage frequency, what
4 do we mean, is there such a definition?

5 MR. STUTZKE: I don't think there is right
6 now.

7 MEMBER APOSTOLAKIS: Oh, my God.

8 MR. STUTZKE: I think you will find a wide
9 variety and what you tend to find is what the Agency
10 has used as conservative. When we say it's core
11 damage, it may not be.

12 MEMBER APOSTOLAKIS: I thought the
13 definition had to do with the release of noble gases,
14 five or 10 percent of them, then you have core damage,
15 more than that is core damage, but that's not a valid
16 definition?

17 MEMBER BLEY: I think somewhere there's
18 that definition but I think operationally doing a PRA,
19 you set other surrogate criteria that may or may not
20 be --

21 MR. STUTZKE: Remember you're trying to
22 get down to how do you draw the logic structure. You
23 want to know what the success criteria are and I've
24 had the impression for quite some time, you know, the
25 difference between one out of three pumps and two out

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 of three pumps is like night and day in the
2 thermohydraulic analysis. I don't need a very precise
3 definition because I'll draw the fault tree that just
4 says all the pumps failed, end of discussion.

5 MEMBER APOSTOLAKIS: I think that's --

6 MEMBER BLEY: And then there's an issue of
7 timing when it happened.

8 MR. STUTZKE: Timing issue is another
9 thing and I used to be real interested in that because
10 we used time reliability correlations in HRA and you
11 wanted to know, but we don't do that any more.

12 MEMBER APOSTOLAKIS: So what obviates the
13 need for a precise definition is the discreditization
14 that PRA laments.

15 MR. STUTZKE: Right.

16 MEMBER APOSTOLAKIS: And we are never
17 going to say two pumps and one-third of a pump. It's
18 two pumps, three pumps, one pump and then the precise
19 definition is not needed, and especially if your
20 conservative, right?

21 MR. STUTZKE: Right, but it is of
22 interest. We were handing off this work to another
23 division in research and they wanted to know when to
24 stop calculating. That's basically --

25 MEMBER APOSTOLAKIS: That's interesting.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 MR. STUTZKE: But it's interesting. Okay,
2 so that's probably what it is. Let me -- you know
3 that the handbook is in wide use now by all the risk
4 analysts and the SRAs that do risk analysis of
5 operational events. So in that sense we have achieved
6 some measure of standardization. Something else that
7 needs to be pointed out is in -- I think it was
8 starting in June of 2006, there was a change to the
9 ASP program itself.

10 Used to be ASP always went off and did its
11 own analysis. Remember that there's a distinction.
12 The ASP analyses are done by the Office of Research.
13 These other ones, SDPs and MD 8.3, that's NRR's
14 responsibility to do that. And sometimes they didn't
15 agree, okay, for different reasons.

16 Well, and the other problem was, it's a
17 matter of resources, you know. We have limited
18 resources and so back in 2006, ASP was changed to say
19 if there's an SDP inspection and it's been analyzed
20 and we find that it's applicable and appropriate, we
21 can use it. We don't need to make an independent
22 study. You know, it obviously has some time savings
23 for us.

24 The point is that it also helps
25 standardize things, you know, to some extent because

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 the analyses that we would do under ASP would be done
2 with the same handbook that they're using for SDP.
3 The other thing that I would impress upon you is that
4 there is a large amount of communication now among the
5 analysts. There is a weekly telephone call among the
6 SRAs. That the headquarters participates in. There
7 are -- every six months there are SRA counterparts
8 meetings. I mean, there's a lot of communication
9 going on back and forth between the Office of research
10 and NRR and the Regional Offices like this.

11 Routinely, SRAs from Region call into
12 Research asking for guidance on how to do their
13 analyses and things like that. There's a lot of give
14 and take back and forth with Idaho Laboratory as well
15 on aspects of using SAPHIRE and GEM like this.

16 MEMBER BLEY: Do all of the SRAs spend
17 time in headquarters? I know a lot did in the
18 beginning, but I don't know if that's true now.

19 MR. STUTZKE: Yes. I'll tell you what I
20 know and feel free to jump in, but SRA's are formally
21 qualified. There's a qual card like this. All SRAs
22 are, in fact, used to be inspectors so they have to go
23 through all of that qualification as well. There are
24 required rotations to NRR, so they can go see what's
25 going on. I believe the suggestion was made rotate

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 into RAS for awhile. They have to rotate to another
2 region that's not their home region like this, so
3 there's a lot of cross-pollination going on here.

4 You know, to be fair, SRAs are not risk
5 experts. They're not the heavy gun PRA experts. They
6 know enough to be able to do their job and hopefully
7 they know enough to call us when they get in trouble.
8 We provide the mechanism for them. And we actually --
9 you know, SPAR models are getting better. They're
10 more representative of the as-built, as operated plant
11 that was the purpose of the cutset level reviews that
12 we did. So I said, you know, there was give and take
13 there. We modified SPAR models as we needed to.
14 Licensees modified their models as we needed to and
15 we're reaching a better convergence.

16 MEMBER MAYNARD: It looks to me like it
17 would be a real challenge to keep these up to date.
18 Licensees are always making changes to procedures in
19 their plant and everything. Do you get feedback on
20 those or what attempt is made to keep data in your
21 models current with all the changes that the licensees
22 are making?

23 MR. STUTZKE: I want to dump that off.

24 MEMBER APOSTOLAKIS: Please come to the
25 microphone and identify yourself and speak with

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 sufficient clarity and volume.

2 MR. APPIGNANI: My name is Pete Appignani.
3 I'm the SPAR Model Level 1 Program Manager in research
4 but most I prepare PREP at this time. We're almost
5 done with our initial cutset level reviews. There are
6 four plants that are in the process of changing the
7 software for their model and it's been delayed and so
8 at that point in time we finish them, we'll have all
9 77 models representing 104 plants.

10 Going forward, we look to updating about
11 12 models a year and that's based on the updates that
12 we've done in the past three or four years and we're
13 just going to plan on doing 12 updates per year to
14 keep the SPAR models up to date.

15 MR. STUTZKE: Good, any questions? Thank
16 you.

17 MEMBER APOSTOLAKIS: Any questions or
18 comments from the members? This was an information
19 meeting.

20 MEMBER BLEY: I really appreciate the
21 briefing because I didn't know much about what was
22 going on here and thanks very much. It was very
23 informative and I look forward to looking at your
24 website.

25 MEMBER APOSTOLAKIS: Okay, thank you very

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 much, Marty.

2 MR. STUTZKE: Thank you very much.

3 MEMBER APOSTOLAKIS: Back to you, Mr.
4 Chairman.

5 CHAIRMAN SHACK: Okay. We have interviews
6 scheduled at 11:45.

7 MEMBER APOSTOLAKIS: Is it legal to start
8 earlier?

9 CHAIRMAN SHACK: No. I believe we can if
10 we can find the candidate. We will be holding the
11 interviews in this room and I just noticed the
12 schedule here and I'm a little concerned about the
13 schedule on Friday because I suspect I'm going to be
14 losing people.

15 MEMBER CORRADINI: That one could be moved
16 up, I would assume.

17 CHAIRMAN SHACK: Right, and I would like
18 to say that a half an hour would be sufficient.

19 (A brief recess was taken.)

20 CHAIR SHACK: We can come back into
21 session now. Our next topic is an Overview of the
22 U.S. Evolutionary Power Reactor, the EPR design. And
23 Dr. Powers is leading us through that discussion.

24 MEMBER POWERS: Yes, we're going to do a
25 real reactor now instead of these passive, natural

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 convection -

2 CHAIR SHACK: Well, I notice we got some
3 converts.

4 (Laughter.)

5 MEMBER POWERS: Sooner or later the
6 Committee is going to have to plow into the EPR, and
7 it's useful to get an overview of all the things that
8 have to be done on a certification. Is that not
9 right, Mike?

10 MEMBER CORRADINI: You're going to do it
11 chapter by chapter, right?

12 MEMBER POWERS: This is a real reactor.
13 I mean, it's actually going to come in with a document
14 and design, a written document that we can look at and
15 printed pages on it, and things like that.

16 (Simultaneous speech.)

17 MEMBER POWERS: I mean, this reactor has
18 the advantage that they're actually building one, and
19 maybe even two, maybe even four, so it should be fun,
20 but it's going to take some understanding of the
21 approach and whatnot, and so we ought to get started
22 on that process.

23 So now on this, you're going to have to
24 forgive me a little bit on the nomenclature here.
25 I'll do my best. Getachew Tesfaye?

1 MR. TESFAYE: That's correct.

2 MEMBER POWERS: Who's going to start us
3 off, and then we'll progress on with Sandra Sloan.
4 That was an easy one. Already I like you a lot. And
5 then Marty Parese. Okay. Your floor.

6 MR. TESFAYE: Thank you, Mr. Chairman. My
7 name is, again, Getachew Tesfaye. I'm the NRC Project
8 Manager for Areva's design certification application.
9 I'm going to give you a very short background of our
10 project at the NRC, and then I'll let Areva present
11 the design.

12 The EPR project at the NRC is about over
13 three years old. We spent the first two years engaged
14 in pre-application activities. In that time period,
15 Areva made several presentations to familiarize the
16 NRC staff with the design. And also, during that
17 period they submitted several topic reports that were
18 referenced with the application that was submitted
19 last July.

20 MEMBER APOSTOLAKIS: Is it typical to
21 spend two years?

22 MR. TESFAYE: Two years, three years.

23 MEMBER APOSTOLAKIS: Really.

24 MR. COLACCINO: It's typical. This is Joe
25 Colaccino, the EPR Project Branch Chief. There's

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 nothing atypical about the pre-application period, if
2 you compare it with ESBWR it was probably shorter than
3 that. AP1000 I think -- AP600 is probably comparable.

4 MEMBER APOSTOLAKIS: And the main idea of
5 pre-application is, as you said, to familiarize the
6 staff.

7 MR. TESFAYE: Familiarize the staff and
8 submit topics, and have topical report forms so they
9 can approved and be referenced in the application.
10 Areva submitted 15 topical reports that were
11 referenced in the application.

12 MEMBER POWERS: I do not have a list of
13 those topical reports. I probably ought to.

14 MR. TESFAYE: I will get -

15 MS. SLOAN: Getachew, what I have is, I
16 have a list from the FSAR of all the topical reports
17 that are referenced in the FSAR, which includes the
18 ones that we submitted during the pre-application
19 review, as well as others that were already approved.
20 So if you want the whole list, we can give you that.
21 And then I can sort out the ones that were
22 specifically provided during the pre-application
23 review.

24 MEMBER POWERS: I haven't done anything to
25 you yet. Why do you want to ruin my life with this

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 long list of -- wait until I have harassed you good,
2 and then do those sorts of things.

3 MS. SLOAN: Okay. I will wait.

4 MEMBER SIEBER: Another question is, are
5 all these topicals on ADAMS?

6 MR. TEFAYE: Yes, they are on ADAMS.

7 MEMBER SIEBER: Okay. So we can get to
8 them.

9 MR. TEFAYE: They are also incorporated
10 by reference in the FSAR chapters.

11 MEMBER SIEBER: Yes, we know where to go.

12 MR. TEFAYE: Yes.

13 MEMBER SIEBER: Okay.

14 MEMBER POWERS: I think I need the list.
15 And having them in ADAMS is the same as having them
16 hidden somewhere in Siberia.

17 MR. TEFAYE: So this pre-application
18 phase ended back in December when Areva submitted the
19 application on December 11, 2007.

20 MEMBER BANERJEE: What is the difference
21 between a topical and a technical report?

22 MR. TEFAYE: A topical report is a stand-
23 alone topical report that the staff review and issue a
24 staff evaluation report. A technical report is
25 something that's referenced and reviewed as part of

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 the chapter in the FSAR. A separate SE is not going
2 to be written on the technical report, so that's the
3 difference. All technical reports are stand-alone.
4 They can be referenced with the other applications
5 theoretically.

6 MEMBER APOSTOLAKIS: From the practical
7 point of view, what difference does it make when you
8 say the pre-application period ended, now you have the
9 application? So what? You are not reviewing -

10 MEMBER POWERS: They can't be nice to each
11 other any more.

12 MEMBER APOSTOLAKIS: What?

13 MEMBER POWERS: They can't be nice to each
14 other any more.

15 MEMBER APOSTOLAKIS: Does it make any
16 difference?

17 MR. TESFAYE: Well, it does make a
18 difference. When you officially accept the
19 application, you create a docket, the official review
20 period starts. Before the pre-application period, it
21 was a topic-specific review, general finalization,
22 nothing is in-house for us to start a docket, and also
23 establish a schedule, so there is a big difference.

24 MEMBER APOSTOLAKIS: So it's a little more
25 formal now?

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 MR. TESFAYE: More formal, as I can show
2 you in this slide. Not only have separate
3 application, we have also set a schedule for review.

4 MEMBER APOSTOLAKIS: Okay.

5 MR. TESFAYE: So there's a big difference.
6 So the application was submitted in December, December
7 11, 2007, and we accepted it February 25, 2008. We
8 also issued a schedule which are the six-phase
9 milestone schedules on March 26. And the first phase
10 is, of course, the preliminary safety evaluation
11 report with RAI. And phase two is SER with open
12 items, and phase three is we're going to come back to
13 ACRS with SER with open items. In phase four we will
14 show advanced SER with no open items, and phase five
15 we come back to ACRS again with SER with no open
16 items. And the last phase before the rule making for
17 the certification is phase six, which is issuing the
18 final SER with no open items.

19 MEMBER CORRADINI: So if I might just ask
20 this question now that I see a schedule. So the first
21 time the ACRS will see anything formally, and I'm
22 asking I guess partly Dana and you, is Subcommittee
23 meetings prior to phase three, or in preparation for
24 phase three?

25 MR. TESFAYE: Well, at the beginning of

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 phase three.

2 MEMBER CORRADINI: So not before early
3 '10?

4 MR. TESFAYE: No, right now we have
5 established -- as soon as we complete phase two, we
6 plan to bring in those portions that we completed to
7 the Subcommittee. That's our plan right now.

8 MEMBER CORRADINI: Oh, okay. So after
9 Thanksgiving of '09.

10 MEMBER POWERS: And the first time that
11 you will be put to work on this particular application
12 will be November of this year.

13 MEMBER CORRADINI: Thank you, Dr. Powers.

14 MEMBER BANERJEE: Why so early, Dana?

15 MEMBER POWERS: Because Mike is a little
16 bit slow.

17 MEMBER BANERJEE: This is specially for
18 Mike.

19 MR. COLACCINO: If I could add to that;
20 this is Joe Colaccino, again. What we have been --
21 we've worked with ACRS staff on this. What we
22 thought would be a reasonable approach is to come in
23 as the chapters are completed, and we go through the
24 no open item phase. I see gentlemen giggling because
25 I heard the remark about coming in chapter by chapter

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 before. Coming in a series of waves so that you're
2 not waiting until the latter part of 2009 to see them
3 for the first time. So we've worked out a schedule to
4 do that. I think we looked at three waves of
5 meetings. And if anything changes, we'll make
6 adjustments to that schedule as we go forward in 2009.

7 MEMBER CORRADINI: Thank you.

8 MR. TESHAYE: The COL applications
9 referencing EPR, the reference COL application -- they
10 submitted Part One of the application which is the
11 environmental report back July 30, 2007, and was
12 accepted for review January 25th, 2008. It's
13 currently in Phase One of the review.

14 MEMBER APOSTOLAKIS: What is R-Cola and S-
15 Cola?

16 MR. TESHAYE: R-Cola is Reference Cola.
17 That's the first combined license application
18 referencing the EPRs.

19 MEMBER APOSTOLAKIS: S-Cola?

20 MR. TESHAYE: Subsequent Cola.

21 (Off the record comments.)

22 MEMBER APOSTOLAKIS: I understand the R,
23 but the S I didn't. Oh, you mean others have also
24 come in.

25 MR. TESHAYE: Yes.

1 MEMBER APOSTOLAKIS: Okay.

2 MR. TESFAYE: And that review is going to
3 be done concurrently with the design certification
4 review. So, again, it was submitted in two parts. I
5 think that's the first one that's submitted in two
6 parts, first application, first combined license
7 application that was submitted in two parts.

8 MR. COLACCINO: And, hopefully, the only.

9 MR. TESFAYE: Part Two was submitted on
10 March 14, and we just docketed it yesterday. We
11 accepted for review yesterday.

12 MEMBER CORRADINI: So just to help me
13 understand. How does the fact that it's in two parts
14 matter to the staff? You just stop looking until
15 you've got the second part in?

16 MR. TESFAYE: Well, originally, the plan
17 was to accept the environmental report and start
18 reviewing it, but it had so many problems, we didn't
19 get a chance to start the review. So it took about
20 six months to accept the first part, so there was
21 nothing net-gained by their submitting it in two
22 parts.

23 MR. COLACCINO: Really, in reality - this
24 is Joe Colaccino, again. This will be the last time
25 you'll hear us speak about two parts. It doesn't

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 matter now, the application is complete for the
2 Calvert R-Cola, so we'll be talking about the R-Cola
3 application, and you'll never see Part One or Part Two
4 again.

5 MR. TESFAYE: Again, the planned
6 submittals for the subsequent COLAs, combined license
7 applications that will be coming in after the
8 reference quota shown on this slide. And that's all
9 I have for brief background information, so we'll go
10 to Areva and Sandra.

11 MEMBER POWERS: I appreciate the schedule
12 information as far as the chaptering, we'll discuss
13 that a little bit. You're up. Okay. So now I can
14 start picking on you.

15 MS. SLOAN: Now is your turn. My name is
16 Sandra Sloan. I work out of Lynchburg, Virginia for
17 Areva NP, and my responsibility is Manager of
18 Regulatory Affairs and New Plants Deployment, which
19 gives me responsibility for EPR licensing in North
20 America.

21 Our goal for today -

22 MEMBER POWERS: Are you building a lot of
23 these in Canada and Mexico?

24 MS. SLOAN: We are talking about that.

25 MEMBER POWERS: Good luck.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 MS. SLOAN: We're exploring possibilities,
2 let's say.

3 MEMBER BANERJEE: How many of these are
4 being built right now and where?

5 MS. SLOAN: Two, one in Olkiluoto,
6 Finland, and one in Flamaville in France.

7 MR. PARESE: And they've just started
8 moving dirt at Tai Shan in China. Tai Shan in China,
9 it's just west of Hong Kong.

10 MEMBER BANERJEE: How many will be built
11 in China?

12 MR. PARESE: Well, right now our contract
13 is for two at Tai Shan.

14 MEMBER POWERS: What it suggests is that
15 a lot of the first-of-the-kind engineering issues that
16 we have on other reactors are hopefully ironed out.

17 MR. PARESE: We believe so.

18 MS. SLOAN: The benefit of not being
19 first.

20 MEMBER POWERS: Please continue.

21 MS. SLOAN: Okay. Our goal today was to
22 provide simply a broad overview. Again, we have two
23 hours on the agenda. We could talk forever on EPR as
24 long you want, really, but today we have two hours, so
25 it really is a broad high-level overview of the plant

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 design, and basically focused around comparing and
2 contrasting with current generation PWRs. And what we
3 decided to focus on were those features of particular
4 safety-significance, so that's what you'll see us
5 talking about.

6 And before I turn it over to my colleague,
7 Marty Parese, I did want to acknowledge and be very
8 open about the fact that in the letter providing Areva
9 the schedule for the design certification review, the
10 staff did identify five areas which were classified as
11 areas of potential schedule uncertainty for the design
12 certification review, and they're in the five topic
13 areas that are listed here.

14 The first one is post-accident containment
15 mixing, and it has to do with the extent of mixing
16 versus thermal stratification within the containment
17 after a LOCA event, and because EPR does not have
18 safety-related sprays or fan coolers. And Marty will
19 talk a little more about containment design in the
20 context of his presentation.

21 We've already gotten a set of RAIs related
22 to this. We've responded to some of those RAIs, and
23 there are two RAIs, in particular, related to two
24 topic areas that we are going to provide a technical
25 report to the staff to support their evaluations.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 MEMBER BANERJEE: Are there any
2 recombiners?

3 MS. SLOAN: Yes. There are passive auto
4 catalytic recombiners.

5 MEMBER BANERJEE: Catalytic?

6 MS. SLOAN: Yes.

7 MEMBER BANERJEE: But there's no
8 circulation, no forced circulation of any sort.

9 MS. SLOAN: No circular -

10 MEMBER BANERJEE: Either by spray -

11 MEMBER POWERS: We'll have to do a little
12 proselytizing on the virtues of the spray.

13 MEMBER BANERJEE: I am not in favor of
14 sprays or in favor of sprays.

15 MEMBER POWERS: So I've got lots of
16 proselytizing to do.

17 MEMBER BANERJEE: Okay. So you're going
18 to tell us one of the main issues under each of those
19 before we proceed?

20 MS. SLOAN: Well, these are the big
21 issues. All I'm trying to do - I'm not trying to
22 steal Marty's time, but just to tell you where we
23 stand on responding to or addressing each of the five
24 items identified by the staff. So I don't plan to go
25 into detail right now.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 VICE CHAIR BONACA: This is an overview.

2 MS. SLOAN: Right.

3 MEMBER ARMIJO: These issues -- now, this
4 plant has gone through regulatory review by the French
5 and also by the Finnish regulators. Have they
6 addressed these issues themselves and put them to bed?

7 MR. PARESE: Not that we know of.

8 MR. COLACCINO: This is Joe Colaccino,
9 again. The regulatory review that has been done for
10 LL3 I believe is what would be equivalent to a
11 construction permit in the United States. I'm not
12 familiar with what has been done with Flamaville-3,
13 but I believe it's a similar path, if that helps you.

14 MEMBER POWERS: Mr. Bonaca, you had a
15 question?

16 VICE CHAIR BONACA: Yes, I have a question
17 regarding axial growth in M5 guide tubes. This has
18 been experienced for Areva fuel?

19 MS. SLOAN: Yes. This has been
20 experienced at a U.S. operating plant. And,
21 consequently, because we're using M5 materials and
22 USEPR fuel, it's been raised by the staff as a
23 potential area that can cause schedule delays.

24 VICE CHAIR BONACA: You have the same
25 fuel.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 MS. SLOAN: Right. And I want to make
2 clear that that is M5 guide tube growth. It's not
3 cladding on the fuel rods. This was observed in the
4 guide tubes; which, for the purposes of understanding,
5 guide tubes for Areva reactors are much like thimble
6 tubes in other kinds of reactors. These guide tubes
7 extend throughout the core region and are part of the
8 skeleton of the fuel assembly.

9 VICE CHAIR BONACA: Now, this is also
10 being called the USEPR. You talked about other plants
11 being built right now, EPRs in France and in Finland.
12 How different are they? Will you tell us at some
13 point?

14 MR. PARESE: Oh, the difference between
15 the units themselves in the design features -

16 VICE CHAIR BONACA: I'm talking about the
17 U.S. -

18 MR. PARESE: -- in particular, or
19 regarding the fuel?

20 VICE CHAIR BONACA: This is a U.S. EPR.

21 MR. PARESE: Yes. There are differences
22 between the unit here, and I'll try and touch on some
23 of those as we go through.

24 VICE CHAIR BONACA: If you could at some
25 point, yes.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 MR. PARESE: Based on how we're doing on
2 time, but I'll try and touch on some of those.

3 MEMBER BANERJEE: And will you also touch
4 on a little bit more than just the topical reports on
5 how you plan to emergency -- give us a little bit of
6 an overview.

7 MR. PARESE: Sure. We'll go -

8 MS. SLOAN: Yes, Marty will talk hardware,
9 so he will talk about that. And mitigation, how it's
10 used to mitigate smaller -

11 MEMBER BANERJEE: Right. Right. Small,
12 and whatever size.

13 MEMBER ARMIJO: These four topical reports
14 that contribute to schedule uncertainty, are they yet
15 to be written, or yet to be reviewed?

16 MS. SLOAN: No, they were submitted and
17 under active review. And on some of them, we have
18 seen the RAIs or draft RAIs, so we're in the process
19 of addressing questions right now.

20 MEMBER ARMIJO: Okay.

21 MS. SLOAN: And so for the second item,
22 seismic and dynamic qualification of equipment, the
23 concern was that in our FSAR for the USEPR for design
24 certification, we have left open the option for COL
25 applicants to use earthquake or test experience for

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 equipment qualification. And based on feedback from
2 the staff and our own evaluation, we submitted a
3 letter last Friday to close that issue by taking that
4 option out of the USEPR FSAR. So, at this point, it's
5 our understanding that that is no longer on the list
6 of schedule uncertainty items. And that was that one.
7 We just talked about M5 guide tube growth, and Areva
8 does have an active root cause analysis underway to
9 look at that. That's in progress. We have committed
10 to and continue to keep the staff apprized. We're
11 doing post irradiation examinations. We've eliminated
12 a variety of causes that still haven't come up with a
13 single cause yet, but the root cause analysis is
14 ongoing, and we continue to communicate progress to
15 the staff.

16 MEMBER ABDEL-KHALIK: How did that issue
17 manifest itself? Was it bowing of the bundles?

18 MS. SLOAN: This was in the actual guide
19 tube growth up into the upper tie plate.

20 MEMBER ABDEL-KHALIK: But how did that
21 manifest itself?

22 MEMBER SIEBER: In other words, what's the
23 interference?

24 MS. SLOAN: Jeff Tucker is a Fuel America -

25 -

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 MR. TUCKER: This is Jeff Tucker. I'm
2 here with Fuel America. We first discovered this
3 issue doing routine post irradiation exam measurements
4 of discharged fuel at TMI-2 after cycle 15.

5 (Off the record comments.)

6 MR. TUCKER: During examination we found
7 that growth rates after two cycles were longer than
8 predicted, so we went back and did more examinations
9 on discharged fuel, and it's been predicted that the
10 fuel might grow to solid contact at reactor shutdown,
11 so we made arrangements for contingencies to evaluate
12 the fuel at shutdown, evaluate the internals, and
13 contingencies to modify the fuel if it was too long.
14 So at the shutdown, we did find out that there were
15 additional fuels in there. We've modified the fuel.
16 We're taking similar growth measurements on fuel at
17 other reactors with similar material and designs.
18 And, to-date, the TMI batch 16 fuel is the only fuel
19 that's got this anomalous growth, and that's the root
20 cause that Sandra is speaking about.

21 We've done hot cell examinations, we've
22 done post irradiated exams at the pool side, we've
23 done manufacturing reviews, design evaluation, so
24 that's the root cause -- it first manifested itself in
25 routine post irradiation exam and discharge flake

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 measurements.

2 MEMBER POWERS: We have a lot of evidence
3 to suggest Zirconium and Niobium alloys in reactor
4 environments are susceptible to relatively subtle
5 changes. I remind you of the Ell0 experience, and now
6 we have a single batch of material here which behaves
7 strangely. Is that a subject that perhaps the Reactor
8 Fuel Subcommittee might want to delve into in a little
9 more -- maybe have a little better understanding of
10 why we have this sensitivity, apparently, of Zirconium
11 and Niobium alloys that we've not experienced with
12 Zirconium -

13 MEMBER ARMIJO: Yes. We'd love to see
14 your root cause analysis results, and also learn a
15 little bit more about these particular materials. But
16 I'm just anticipating that you'll resolve that problem
17 either by design or material change, or something
18 else. But in the interim, we'd like to learn more
19 about it.

20 MEMBER POWERS: The trouble I'm having is
21 that each one of these things gets resolved, and then
22 the next one comes along.

23 MEMBER ARMIJO: Oh, yes, there's always --
24 well, you can always fall back.

25 MEMBER POWERS: And it seems to me that we

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 have a sensitivity here that I'm unfamiliar with in
2 the tin, Zirconium Tin alloys, that maybe we need a
3 little more understanding. And I, myself, have not
4 gone back and looked at the electronic structures on
5 Niobium alloy and Zirconium, but my perception is that
6 you're closer to changes in the band gap than you are
7 with the tin alloys, and maybe that's where we're
8 getting some sensitivity there. Anyway, I just
9 suggest that maybe the Fuel Subcommittee wants to go
10 into that.

11 MS. SLOAN: Okay. And as I said, Areva
12 has been committed to sharing information as we go, as
13 we get new information.

14 The next item on the list, as someone
15 alluded to, are four methodology-related topical
16 reports that have been submitted. And, as I
17 mentioned, we have received RAIs on these, or draft
18 RAIs, are in the process of addressing the questions.
19 The last item on the list was, I think, one familiar
20 to all of us. This was GSI-191 on sump strainer and
21 downstream effects. And with regard to that one,
22 Areva is following what's going on in the industry,
23 and is actively engaged. And, in addition, we have
24 our own global program within Areva to develop our own
25 technical solution for this, so that work is ongoing

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 at Areva.

2 MEMBER POWERS: And you're buffering your
3 sumps?

4 MS. SLOAN: Pardon?

5 MEMBER POWERS: And you buffer your sumps?

6 MS. SLOAN: Buffering the sumps?

7 MR. PARESE: It's not a sump, but, yes,
8 we're doing post-LOCA buffering with Trisodium
9 Phosphate. And we've eliminated any use of Calcil.
10 It's actually -- Calcil insulation is precluded in the
11 design of the plant, design guides. I'm sorry?

12 MEMBER BANERJEE: Also, anything to do
13 with Nucon.

14 MR. PARESE: Well, say that again.

15 MEMBER BANERJEE: Nucon.

16 MEMBER SIEBER: Fiberglass insulation.

17 MR. PARESE: Yes. No, right now we have
18 reflective metal insulation on the reactor coolant
19 system.

20 MEMBER BANERJEE: All of it.

21 MR. PARESE: All of it. And we're looking
22 at the zones of influence for the attached piping to
23 determine whether we want to continue -- what type of
24 insulation we want to use for that. But right now,
25 our goal would be to go to reflective metal for the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 zones of influence. And one of the advantages of the
2 EPR, you won't see it any of the layout drawings I
3 have to show, but we have concrete walls between the
4 loops and between the hot and cold legs of the loops,
5 so breaks -- the zone of influence is limited to
6 relatively small areas.

7 MEMBER BANERJEE: Now, your steam
8 generators will be what, insulated by?

9 MR. PARESE: Reflective metal insulation.

10 MEMBER BANERJEE: And all the pipes?

11 MR. PARESE: The entire reactor coolant
12 system and components will be reflective metal.

13 MEMBER SIEBER: A lot of cool water pipes
14 typically are -

15 MR. PARESE: So what you have is, you have
16 attached pipes that you have to insulate to a certain
17 length. Okay? Like your let-down lines, those are
18 heat losses, your ECCS line release for a certain
19 distance will have wicking of heat down those lines,
20 and you want to -- all those are fins, and those
21 become places where heat can be released to the
22 containment, so we will have insulation for a certain
23 distance on many of those attached -

24 MEMBER BANERJEE: And what will that --
25 because even small amounts -

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 MEMBER POWERS: Let me suggest that though
2 we'd love to plunge deeply into the details, I can
3 assure you there's going to be more than adequate
4 opportunity to do this. Maybe at this point, we could
5 get the width or the breadth of the material, and then
6 the strategy for plunging deeper into the details.

7 VICE CHAIR BONACA: In the USEPR, the
8 methodology that you refer to, the four questions of
9 methodology, evidently, it must be Areva methodology
10 that you use in the States.

11 MS. SLOAN: Yes.

12 VICE CHAIR BONACA: How different is the
13 licensing package from the one that you have to
14 license in France and in Finland? I mean, is it a
15 different package? Is it different -

16 MS. SLOAN: Typically, what we've used for
17 the -- not typically, we have used for the EPR codes,
18 like RELAP-5.

19 VICE CHAIR BONACA: Yes.

20 MS. SLOAN: And GOTHIC, and NEEM-OK that
21 are already approved for our use, Areva's use in the
22 U.S. to support operating plants.

23 VICE CHAIR BONACA: Okay.

24 MS. SLOAN: And, of course, what's being
25 used in the other countries are things their

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 regulators are -- the regulatory regime over there is
2 more familiar with.

3 MR. PARESE: So, for example, for
4 Flamaville, the LOCA analysis, small LOCA analysis
5 will be done with CATHR, and here we're using COF-5,
6 so we did not rely on work that was done using codes
7 approved in Europe here. We used our own codes.

8 VICE CHAIR BONACA: Okay.

9 MR. PARESE: Used US-approved codes. Now,
10 that doesn't mean we didn't learn a lot from
11 everything that had already been done, of course.

12 MS. SLOAN: And so these are the general
13 topic areas that we had hoped to touch on today. And
14 there's a lot of overlap between these various topic
15 areas. I would encourage you to ask questions as we
16 go along. I know no one is shy to do that.

17 MEMBER POWERS: Oh, you don't need to do
18 that.

19 MS. SLOAN: I know.

20 MEMBER POWERS: That's waving a flag in
21 front of a bull. No. Let's hold your questions and
22 get through this.

23 MS. SLOAN: And I'll turn it over to Marty
24 Parese. Marty is the Chief Engineer for Areva NP,
25 Inc., and as one of his many responsibilities as Chief

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 Engineer, he's responsible for technology integration
2 for new plants deployment.

3 MR. PARESE: Okay. So today, based on
4 your request, we're going to talk about the
5 differences between the EPR and a standard PWR,
6 because I think everyone realizes we're an
7 evolutionary design. But as we go through it, we're
8 going to do some comparisons with existing PWRs, as
9 well. And, generally, a standard four-loop type unit
10 that you'll find in the U.S.

11 So the important thing about EPR is that
12 the development objectives were clearly to make it
13 evolutionary. And that decision was made at the
14 beginning of the development phase in 1989-1990, and
15 so we built on all of the experience that existed on
16 current PWRs and the plant performance and equipment
17 performance would be predictable. So that was
18 purposely selected.

19 The French and German regulators were
20 involved in the developed of the EPR design
21 objectives, and the licensing guides that would be
22 used for EPR. So, consequently, increased safety of
23 the unit as measured by increased design margins,
24 increased redundancy, and diversity and physical
25 separation at multiple levels, as measured by a

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 reduced core damage frequency, as a Generation 3-plus
2 unit should have. And accommodate severe accidents
3 and external hazards with no long-term local
4 population effect. And we'll talk about those design
5 features, in particular, and also from an occupational
6 standpoint, to reduced occupational dose to the
7 workers in the plant, and so there are design features
8 aimed specifically at that.

9 And then, of course, the utilities wanted
10 to get -- obviously, they're going to be buying and
11 using the units. Many utilities in Europe were
12 involved in the original development. They developed
13 a utility requirements document, the EUR. Also, the
14 EPRI URD was also used for guidance, as well as other
15 operator experience with the units. And they wanted
16 to improve the operations by reducing the generation
17 cost by at least 10 percent. And this generally is
18 measured as regulated utilities tended to do that, as
19 a lifetime generation cost.

20 MEMBER BANERJEE: Is this basically like
21 the German Siemens design?

22 MR. PARESE: We're going to talk about in
23 just a moment. But, yes, the EPR is an evolutionary
24 design based on the features of the N4 in France, and
25 the Convoy design in Germany. And those designs were

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 based on the previous designs as they moved forward.
2 And those designs were based originally on licensed
3 technology from the United States.

4 So to meet these economic and safety
5 objectives then, certain design features were
6 developed through the 1990s, and so we'll be talking
7 about many of these features. The nuclear island,
8 we're using a proven four-loop reactor coolant system
9 design; the reason being, the four-loop design can
10 generate large power output, and that large power
11 output when put in the denominator of any O&M cost, of
12 any fuel cost, of any kind of operating cost lowers
13 the dollars per megawatt hour, so you get an economy
14 of scale when you have a larger power output.

15 MEMBER SIEBER: Gross megawatts?

16 MR. PARESE: I'm sorry?

17 MEMBER SIEBER: What the gross megawatt
18 output?

19 MR. PARESE: Gross megawatt output of the
20 -- the gross output of the units in Europe is over
21 1750 megawatts electric.

22 MEMBER SIEBER: That's three LPs and one
23 HP?

24 MR. PARESE: Yes. In the U.S., we can't
25 use open loop cooling as they do in Europe. And,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 also, the French have coined the term for us called
2 "tropicalization". That's what we did when we
3 converted the unit to U.S. temperatures. So, whereas,
4 tropicalization - so I'll give you a perfect example.
5 The temperature from the Baltic Sea or even if we look
6 at the English Channel in the summertime, they can
7 pull cooling water in that's 72 degrees Fahrenheit,
8 and so they have in the summertime a back-pressure in
9 the condenser of about 1.8 inches, 1.7 inches of
10 Mercury. And we will have -- we have to use a cooling
11 tower, and we'll expect wet bulb temperatures of 70
12 some degrees, which will give us a condenser inlet
13 temperature of 84 degrees Fahrenheit, and so we won't
14 produce 1750, we'll produce 1711.

15 MEMBER SIEBER: Okay. So you can't make
16 it up on the condenser -

17 MR. PARESE: No. What we did do is we
18 increased the power level, so one of your differences
19 right off the top, the EPR in Europe is generally 4300
20 megawatts thermal, and here in the U.S. we're 4590.

21 MEMBER SIEBER: You get the same megawatt
22 --

23 MR. PARESE: The first heat balance we did
24 on the USEPR in the spring of 2005, we were delivering
25 a net output with house load, so a net output of 1505,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 and so by increasing the thermal power, optimizing the
2 condenser, and using ultrasonic heat water measurement
3 to reduce the calometric uncertainty, we got the
4 output up to 1711 gross, 1580 net. And that's at 2-
5 1/2 inches of back-pressure. We expect the average
6 output throughout the year to be about 1595 -

7 MEMBER SIEBER: So your station service is
8 122 megs?

9 MR. PARESE: 130 megawatts, approximately,
10 is our house -

11 MEMBER SIEBER: A lot. Do you have
12 electric feed pumps?

13 MR. PARESE: We have electric feedwater
14 pumps. We have electric condensate pumps. We have
15 mechanical draft cooling towers.

16 MEMBER SIEBER: Natural draft -

17 MR. PARESE: You can use natural draft
18 towers, but it generally takes two 500-foot natural
19 draft towers.

20 MEMBER SIEBER: Right.

21 MR. PARESE: Because we're such high
22 power. Whereas, you can use one much smaller
23 mechanical draft tower with 48 cells and produce a
24 little bit better approach temperature, and get a
25 little more megawatts out.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 MEMBER SIEBER: Yes, but do you get -

2 MR. PARESE: Yes.

3 MEMBER SIEBER: I'm sure you guys have
4 figured that -

5 MR. PARESE: It turns out to be a wash.

6 MEMBER SIEBER: If I were buying one, I'd
7 ask that it be -

8 MEMBER POWERS: Unless you've become a
9 good deal more wealthy than you were last week, you're
10 not buying one.

11 MEMBER SIEBER: Well, I'd have to change
12 employment anyway.

13 MR. PARESE: To increase the redundancy of
14 the unit, we use generally four-train safety systems
15 for all the front line safety system. We'll talk
16 about the advantages that that gives us later.

17 MEMBER POWERS: How about the
18 disadvantages?

19 MR. PARESE: Well, the disadvantage is,
20 obviously, cost, but you have to offset by putting
21 that big power level in the denominator.

22 MEMBER ARMIJO: Another thing that goes
23 kind of in your denominator is the design life. You
24 picked 60 years, but is there a fundamental limitation
25 at 60 years, or do you think there's more capability

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 in the system?

2 MR. PARESE: Oh, there's more capability
3 after that.

4 MEMBER ARMIJO: You're anticipating there
5 might be a plant life extension.

6 MR. PARESE: Yes. But right now, 60 is
7 what goes into the design. And there's some equipment
8 that you can't design to 60 years. First of all,
9 there's some suppliers that won't supply equipment
10 with that design life. They just won't do it. And
11 then you have other equipment that has a very short
12 lifetime, anyway, like certain -- and, obviously, all
13 your consumables, like o-rings, and gaskets, and wear
14 parts.

15 MEMBER SIEBER: But your active equipment
16 is going to be periodically inspected and deficiencies
17 corrected, and parts renewed.

18 MR. PARESE: That's right.

19 MEMBER SIEBER: To get this kind of
20 output, what's the size of the core, it's overall
21 dimensions?

22 MR. PARESE: I knew you were going to ask
23 that. It's 241 fuel -- we're going to get there.
24 It's 241 fuel assemblies. I believe the diameter is
25 100 -

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 MS. SLOAN: We'll make it. There is a
2 section on the -

3 MR. PARESE: Yes, we'll get there.

4 MEMBER SIEBER: Okay. Good enough. How
5 long?

6 MR. PARESE: Fourteen foot.

7 MEMBER SIEBER: Okay.

8 MEMBER BANERJEE: And you're going to tell
9 us what pressures these safety systems come in as they
10 pass -

11 MR. PARESE: If we can get to it.

12 MEMBER POWERS: We are not going to at
13 this rate.

14 MR. PARESE: To help this out, we're
15 taking suction on the safety injection system from an
16 in-containment refueling water storage tank, and so
17 it's used for refueling operations, as well as for
18 safety, and it's inside containment, so that
19 simplifies a lot of the connections. And it gets rid
20 of the switch over during LOCAs and the operator
21 actions, which we'll talk about later. One of the
22 objectives of this design is to reduce operator action
23 and give long operating times for response, so a
24 minimum design requirement was any action that's
25 required within 30 minutes must be -

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 MEMBER BANERJEE: These are low pressure
2 injection systems.

3 MR. PARESE: We have medium head safety
4 injection, and low pressure safety injection. We'll
5 get to that.

6 MEMBER BANERJEE: There's no high pressure
7 injection.

8 MR. PARESE: No high pressure safety
9 injection. We'll get to that, too.

10 MEMBER SIEBER: Containment is a steel
11 shell with concrete?

12 MR. PARESE: We're going to get to that,
13 too. So we've included severe accident mitigation to
14 meet those requirements we talked about, no long-term
15 effect on the population with separate safeguard
16 buildings to house those four different divisions.
17 And we're using digital I&C and advanced control room.

18 In electrical, each of those four
19 divisions is supported by its own emergency diesel
20 generator. And to back those up in case of station
21 blackout, we have two smaller diverse station blackout
22 diesels. The emergency diesels are water-cooled. The
23 SPO diesels are air-cooled. And based on their size,
24 it's very likely they'll be by different
25 manufacturers, so that's where we're going to have our

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 diversity. And then we also allow for island-mode
2 operation for the unit, so we can take a full load
3 rejection and transition to delivering our --
4 disconnecting from the grid if the grid goes down,
5 and delivering our power to the switch yard, and then
6 running the unit off those loads. And that gives us
7 an advantage, at least for some period of time while
8 the grid is down, the reactor can stay operating
9 producing power. And it could provide the ability to
10 black start the power through the units around it, as
11 long as it's not a sustained loss of the grid.

12 And then site characteristics in regard to
13 we have airplane crash protection, and we also have
14 protection against explosion pressure waves, and we're
15 going to discuss that today.

16 So quickly, here's generally the layout of
17 the USEPR. I'll point to one of these screens, but
18 the reactor building, obviously, you can see that in
19 the center. That reactor building is a system. It is
20 a post-tension concrete containment building with a
21 steel liner surrounded by reinforced concrete shield.
22 Arranged around the reactor building, we have four
23 safeguard buildings, Safeguard Building One, Two, and
24 Three, and Safeguard Building Four are radially
25 arranged, and I'll talk about the advantages of that.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 The main control room is in Safeguard Building Two,
2 and the Safe Shutdown Facility is in Building Three.

3 A fuel building, we have external storage
4 of fuel in its own fuel building. That includes new
5 fuel acceptance, spent fuel storage, and it also
6 includes simplified methods to take irradiated fuel
7 and put it into casks either for shipment off-site, or
8 for placement in an independent spent fuel storage
9 installation.

10 And then you can see we have a nuclear
11 auxiliary building which contains all the systems that
12 you would normally expect to keep your reactor coolant
13 water clean, and keep your secondary water clean, and
14 account for changes in volume and boration of the
15 system. And then we have a rad waste building, which
16 is a dual-purpose design right now. If the utility
17 wants to process its radioactive waste in its
18 entirety, we have the equipment and the systems to do
19 that. If they choose to, especially for liquid waste,
20 if they choose to contract with subcontractors like
21 many are now, then we have the ability for the
22 subcontractor to come in and valve up their
23 demineralizers, and process, and then take it off-
24 site, so we basically allow for them to approach.

25 We have an access building here that

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 controls all the access to the nuclear island and the
2 radiological controlled area that's set up to handle
3 over 300 people every 30 minutes during an outage.
4 And then you see the turbine island and the switch
5 gear building. Here we have the emergency power
6 generation buildings. Each of these buildings has one
7 EVG in it, and has fuel tanks to support that EVG.
8 And you can see for Safeguard Buildings One and Two,
9 it's on one side of the plant nearest to those
10 buildings, and Three and Four is on the other side of
11 the plant. Again, we'll talk about our separation of
12 these structures for hazards.

13 What's different about the USEPR and
14 European designs are the ultimate heat sink. These
15 essential service water cooling structures, those are
16 mechanical draft cooling towers with faces, one for
17 each of the divisions. In Europe, they use open-loop
18 cooling, and here it's sometimes impractical to do
19 that with permits with the EPA and whatnot. Also,
20 that means that these structures are inside the
21 protected area.

22 VICE CHAIR BONACA: Why did you list
23 airplane crash protection as a site characteristic?

24 MR. PARESE: Because of the way that we
25 approach the protection, which I'll talk about.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 VICE CHAIR BONACA: Okay.

2 MR. PARESE: And that's separation, as
3 well as shield buildings.

4 VICE CHAIR BONACA: All right.

5 MR. PARESE: So here, just looking down on
6 it, then what I -- the main point of this slide is
7 simply to point out that everything that's required
8 for protection within the security plan is inside the
9 protected area. And that's about all we'll talk about
10 that today.

11 So these concepts are shown together,
12 actually, there's three concepts on the slide.
13 There's one in particular I want to talk about, two I
14 want to talk about. The radial design, we have in the
15 four division approach, where we have injection to
16 individual loop, we set it up so that each division,
17 the medium head safety injection, the low head safety
18 injection, the emergency feedwater injects into one
19 loop, and so Division One, Two, Three, Four, each one
20 connects to its own loop. Each takes suction off of
21 the IRWST, what you see here, the In-Containment
22 Refueling Water Storage Tank, takes suction, goes
23 through its heat exchanger and reinjects. The
24 emergency feedwater, obviously, has a tank in the
25 building that it takes suction from to inject. The

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 point is, this radial design then keeps all the links
2 of pipe short, and by minimizing any inter-connections
3 we reduce the number of valves, and complexities.
4 There's no requirement for operators to balance flows
5 during design-basis accidents.

6 The other thing then, you can see the
7 separation of the buildings. Each of these buildings
8 then, if you have a calamity in one of these
9 buildings, say a fire, then the other buildings aren't
10 affected by the fire due to the separation, the radial
11 design.

12 Then the N+2 approach allows us for these
13 front line safety systems to have one system in
14 preventative maintenance, so you can do on-line
15 maintenance of a system. We can also then have our
16 single failure criterion on a system. So, for
17 example, you could take loss of off-site power and the
18 failure of an emergency diesel generator, and then all
19 the powered equipment on that division is assumed out.
20 And that leaves us two divisions to mitigate the
21 event. So for those events that could affect the
22 delivery of the cooling water, for example, a loss of
23 coolant accident, one of our active divisions could be
24 in a broken leg, and it could be falling on the floor.
25 That allows one division to deliver water into the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 vessel and mitigate the event. For those events where
2 that's not possible, we have two divisions out there.

3 MEMBER SIEBER: Each of the four divisions
4 is full capacity?

5 MR. PARESE: Essentially, all you need is
6 one.

7 MEMBER SIEBER: Well, tell me why you use
8 the words -

9 MR. PARESE: Well, the reason I used
10 essentially is that we took credit for the fact that
11 generally -- well, under these assumptions, two RHR
12 systems would be operated. So even if one is dumping
13 on the floor and running into the IRWST, it's taking
14 suction out of the IRWST and it's running through a
15 heat exchanger, and it's reinjecting it back to the
16 either the floor or the IRWST. So, in reality, during
17 a loss of coolant accident, I have two divisions
18 taking heat out of the building. Okay? That's why I
19 said "essentially". There's some -- and we're going
20 to talk about -- in just a few minutes, we're going to
21 talk about systems that are 2X100, not 4X100.

22 And then the other thing that shows here,
23 which we'll talk about in a moment. This blue
24 building is the reinforced concrete building that goes
25 around the reactor building. It goes around the fuel

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 building, and safeguard buildings. So on slide 12
2 then, what this does for us is it allows us to lower
3 the cost of the unit in some ways. We increased the
4 cost because we have four divisions, but we reduced
5 the cost, or at least we improved the economics of the
6 unit because we can do on-line maintenance.

7 Because you can do on-line maintenance,
8 you take EDG maintenance, MHSI, EFW pumps, heat
9 exchangers, component cooling water, you take
10 surveillances and maintenance out of the outage, and
11 so you can shorten the outage time to 15 days.
12 Current plants are running about 35, the best PWR
13 outage I think is still Byron at 15 days something
14 hours. So if you shorten your outages by 17 to 20
15 days, you're going to improve the economics, because
16 you're going to produce power during those days.
17 That's one thing.

18 Second, because we can do the preventative
19 maintenance on line, we can have a higher availability
20 of the equipment. But, also, we can use equipment
21 that's literally the same size or capacities that
22 we're used to now. This is a 4590 megawatt unit. Our
23 MHSI pumps are about 600 gallons per minute, at around
24 600 psi. What's the size of MHSI pumps now on current
25 units? It's the same. Our LHSI pumps are 2200

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 gallons per minute at around 200 psi. That's the
2 same, so we're using equipment that we're used to
3 operating. We're not using special or newly developed
4 equipment. And also then we know the Lessons Learned
5 on all the existing fleet and materials of
6 construction, and problems.

7 MEMBER POWERS: You might actually be able
8 to estimate reliability on these things.

9 MR. PARESE: That's our expectations. So
10 on slide, I guess it's 13, it's cut off a little bit.
11 For the main safety systems, as we've said, we have
12 four-train ECCS, so we have four medium head safety
13 injection pumps. We have four combined LHSI RHR
14 pumps. They're one per division.

15 MEMBER ABDEL-KHALIK: What is the shut-off
16 head of your SI pumps?

17 MR. PARESE: The shut-off head of the SI
18 pumps is around 1380 to 14 psi. And we're going to
19 get into that later in the presentation.

20 Obviously, we have charging pumps, non-
21 safety charging pumps. And it's pretty interesting
22 how some of the changes that were made even to a
23 subtle system like that; for example, current units
24 vary the charging flow to adjust pressurized flow and
25 account for changes in density of the coolant system.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 Right?

2 MEMBER ABDEL-KHALIK: Right.

3 MR. PARESE: Well, that causes variations
4 in flow of those nozzles. And because those nozzles
5 are in the stream of the cold leg, that cold leg water
6 goes in and comes out, and causes thermal penetration,
7 and causes cyclic fatigue of a nozzle. Well, we
8 solved that. We control pressurizer level by varying
9 let-down. And by varying the let-down flow, you're
10 just changing the flow of a relatively hot system 570
11 degrees, and so there's very little fatigue on that
12 nozzle due to variations in flow. So we solved one of
13 those big problems with make-up nozzle cracking, and
14 other problems, and thermal sleeve cracking by just
15 making a simple adjustment to how we run the unit. So
16 that's an example of how lessens were incorporated.

17 MEMBER SIEBER: By using the let-down flow
18 you charge back in, I take it, your EG trains or
19 arrangement is such that you don't have a big
20 temperature differential in -

21 MR. PARESE: Right. We're using a
22 combination of regenerative and non-regenerative heat
23 exchangers to warm the charge -

24 MEMBER SIEBER: Okay. The resulting
25 temperature is usually lower because you're affecting

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 the non-regenerative part.

2 MR. PARESE: Right. And it is lower, but
3 it continuously injects; and, therefore, we don't get
4 the thermal transients on the nozzle.

5 VICE CHAIR BONACA: What is there, the
6 shut-off head of your charging pumps?

7 MR. PARESE: Shut-off head of the charging
8 pump, I believe approaches 2750 psi.

9 VICE CHAIR BONACA: Okay.

10 MR. PARESE: So one part of the flow curve
11 we're still getting a flow of 2680 psi.

12 VICE CHAIR BONACA: Okay.

13 MEMBER SIEBER: And it's a centrifugal -

14 MR. PARESE: It's a centrifugal, it's two
15 centrifugal pumps in parallel, one normally
16 operational, the other one is in standby. We do have
17 two positive displacement pumps in that extra borating
18 system, and they deliver about 40 gallons per minute.
19 And we use those with hydro tests on the reactor
20 coolant system, but they have a safety function, as
21 well.

22 MEMBER SIEBER: And you can put boron in
23 for shutdown insurance. Right?

24 MR. PARESE: That's right. So our extra
25 borating system is manually actuated, it's not

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 automatic. It's manually actuated. We have two of
2 them, so we can take a single failure, and it injects
3 7700 ppm boron of enriched B-10, 37 percent enriched
4 B-10.

5 MEMBER SIEBER: That's safety-related?

6 MR. PARESE: It's safety-related, and so
7 to meet Branch Technical position, used to 5.1, it's
8 now 5.4, I think. To get to cold shutdown, we can
9 borate to cold shutdown using those pumps.

10 MEMBER ARMIJO: Your two non-safety-
11 related charging pumps, are they on different power
12 supplies or the same? If you've got two in parallel,
13 normally one running.

14 MR. PARESE: I don't know the answer to
15 that. I'd have to look if they're on the normal power
16 bus, and I don't know if they're on the same or
17 different buses.

18 All right. And then for severe accident
19 mitigation, we have a non-safety-related containment
20 spray system that has a dedicated component cooling
21 water and central service water train that goes out to
22 one of those mechanical draft cooling towers. And
23 we'll talk about severe accident mitigation.

24 MEMBER STETKAR: You're selling -- does it
25 have a containment vent?

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 MR. PARESE: I'm sorry?

2 MEMBER STETKAR: Does the USEPR have a
3 containment vent system?

4 MR. PARESE: Well, the answer is we have
5 it, but it's not part of our normal severe accident
6 mitigation. In other words, it will be in the SAMGs
7 as a last resort, but we've designed -

8 MEMBER STETKAR: It's part of the design.

9 MR. PARESE: It's part of the design, but
10 we've designed the plant so you won't need to use it.

11 On the secondary side, as we said, each
12 steam generator has its own EFW supply for safety
13 assured water, and that tank is in the safeguard
14 building. And there's one pump, and one tank, and it
15 discharges to the steam generator. It has suction
16 valves, and discharge valves so that we can, after the
17 early stages of the event, whatever event you might
18 have, and what single failures you might have, later
19 in the event, the operator can get access to any tank
20 of water to deliver to any steam generator, depending
21 on what's failed and what's not failed, so we have
22 that capability. But when the event begins, each
23 injection line goes to each steam generator.

24 MEMBER SIEBER: What's the capacity of
25 each steam water tank in terms of hour, decay heat

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 removal hours?

2 MR. PARESE: We've got decay heat removal
3 capability of at least 24 hours hot.

4 MEMBER SIEBER: Single tank.

5 MR. PARESE: A single tank is -- well,
6 it's approximately -- they're not equal in size, but
7 it's approximately one-fourth of that.

8 MEMBER SIEBER: Six hours or so.

9 MR. PARESE: The four of them together
10 give us 24 hours hot, or allow us to cool down to cold
11 shutdown, or to get to RHR. I should say to get to
12 RHR actuation, and at 250 degrees Fahrenheit.

13 MEMBER SIEBER: If you only have one train
14 of emergency feedwater, you have to cross-tie tanks to
15 get to 24 hours.

16 MR. PARESE: Yes. You would open up --
17 you would take suction from those other tanks to get
18 there.

19 MEMBER ABDEL-KHALIK: Can the steam
20 generator inventory itself, how much worth of decay
21 heat can -

22 MR. PARESE: We've got almost 30 units of
23 decay heat removal in the steam generators post
24 reactor trip. There's 182,000 pounds of water, and
25 we're going to show that in a comparison slide in just

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 a second.

2 Also on the system, each steam generator
3 has, besides the turbine bypass system, on each steam
4 generator we have two spring-loaded main steam safety
5 valves that are worth 25 percent each, and we have one
6 main steam relief train, which is safety-related, ASME
7 qualified. And it's made up of an isolation valve,
8 and of a control valve, and it's seismically
9 qualified, redundantly powered, and we can use that to
10 depressurize the plant to cold shutdown using those
11 safety-related atmospheric dumps. So this is
12 something a lot of the current units wish they had, so
13 that they could take credit for depressurization of
14 the steam generators. We built it into the design.
15 It's 50 percent total flow at full pressure.

16 It turns out in our -- it doesn't turn
17 out, the plant was designed so that for the limiting
18 over-pressure event for the secondary side, either the
19 main steam relief train by itself, or the two spring-
20 loaded safety valves by themselves can prevent the
21 system from exceeding 110 percent.

22 So Slide 15, checking my time, slide 15,
23 this is just an example where you can see in a
24 division, say the safeguard building, let's pick
25 Safeguard Building Four, the residual heat removal

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 system which would take -- would drop off the hot leg,
2 or take suction out of the IRWST if it's an accident,
3 goes through a heat exchanger, the RHR heat exchanger,
4 and reinjects back into the reactor coolant system.
5 That's inside the safeguard building. Also, a
6 component cooling water pump is inside the safeguard
7 building. And with a heat exchanger there, the
8 component cooling water heat exchanger, all of that is
9 self-contained in the safeguard building. And then
10 the essential service water system connects, and so
11 one division has its own RHR component cooling water,
12 and essential service water, and alternate heat sink.
13 And that's consistent in the design. And in that
14 safeguard building, we have everything to control that
15 system, so we have the mechanicals in there, we have
16 the electrical power supplies, we have the I&C
17 control, and we have the HVAC in that building to keep
18 that building cool from all the heat loads that could
19 be deposited in the building.

20 MEMBER ABDEL-KHALIK: Are there structural
21 differences between the Safeguard Buildings One, Four,
22 versus Two and Three?

23 MR. PARESE: Yes. Well, partially. The
24 actual building itself, no. They're all seismically
25 qualified safety-related buildings, but One and Four

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealgross.com

1 do not have a shield building for external hazards
2 from airplane crash. The reason for that is, they are
3 separated by the reactor building, which does have a
4 shield building. Consequently, if there's a calamity
5 on one side of the plant, it can only affect one
6 safeguard building, and can't affect both. So even if
7 we had an aircraft hazard or an external explosion
8 that damages some of the equipment in the safeguard
9 building, you still have three divisions available to
10 perform functions and get the cold shutdown.

11 And so this just shows exactly what we
12 were talking about, where everything is self-contained
13 in one building. You can see the mechanicals are the
14 low level in case of line breaks or flooding. Here's
15 our pool that's inside the building, so the tank is
16 inside the seismic structure. Then we've got our
17 cable spray for -- we've got some cable spraying
18 force, and our electrical floor that has our I&C
19 cabinets inside this shear wall, and our electrical
20 switch gear in the outside of the shear wall. And
21 here you can see the main control room. And above
22 that, our HVAC equipment, so it's all logically
23 aligned inside a building.

24 Now one of the differences between the
25 USEPR and the European version is that these

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 electrical cabinets, when you go to IEEE cabinets,
2 they're much bigger. We needed much more space, and
3 so we had to make room outside the shear wall. So all
4 the safeguard buildings are three meters longer in the
5 radial direction, 9.9 feet in a radial direction,
6 which costs money to do that, but it also gave us the
7 advantage of having some room for some of this other
8 equipment, because in our tropicalization discussion,
9 we had to improve the heat transfer and the component
10 cooling water to help us jump to a higher heat sink in
11 the cooling towers. So that gave us the possibility
12 to increase the sizes.

13 MEMBER SIEBER: Where did you say the
14 control room was?

15 MR. PARESE: The main control room is
16 right there. So, as we said, our front line safety
17 systems, the protection system, which includes reactor
18 protection and ESF functions, so the protection
19 system, the emergency power supplies, emergency core
20 cooling, component cooling water, essential service
21 water, EFW, those are 4X100, but not all systems are
22 4X100, so we wanted to point that out so that there
23 wasn't confusion. And you can see, much of our iodine
24 filtration, annulus ventilation, safeguards and fuel
25 building filtration, control room iodine filtration is

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 2X100, largely because those systems can't be affected
2 by an accident. And maintenance on those systems are
3 pretty straightforward. All we have are fans and
4 filters, so maintenance can often be done on line on
5 the systems, but they can easily be done during an
6 outage. It's not a critical path item.

7 Containment isolation by its nature,
8 there's a valve on each side of containment, and you
9 power one off division one, and one off division four.
10 Well, then it's a two division system, whether you
11 like it or not, unless you put in extra valves, and
12 that didn't seem appropriate with a single-failure
13 criterion.

14 Our extra borating system is two
15 divisions. It's actuated manually, so we felt two met
16 our single-failure criterion, and that was
17 appropriate. And then spent fuel pool cooling is
18 2X100. Again, it is not affected by an accident.

19 MEMBER APOSTOLAKIS: You said earlier that
20 the ECCS essentially, you used the word essentially,
21 what -

22 MR. PARESE: Right. The ECCS, if you have
23 a small or large loss of coolant accident, the ECCS,
24 one division will function to mitigate the event. But
25 because the divisions are actually running, we take

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 credit for the functions that they perform that might
2 not be injection functions.

3 Another way of putting it is if I have two
4 RHR systems operating, which I always will under the
5 N+2 assumption, I can always cool the unit down in a
6 relatively short time. I think our target is 34 hours
7 or something like that. If I only have one, it takes
8 much longer. Can I get there? Yes, but it takes
9 longer with one, but I always have two. So we
10 credited the fact that I always have two. But for the
11 injection into the vessel for flooding the core, we
12 take credit for the one -

13 MEMBER BANERJEE: So without an HPIS you
14 have to do something else to bring the pressure down,
15 I mean in a SB LOCA.

16 MR. PARESE: Well, you're jumping ahead in
17 the homework. We'll get there. You're right. You're
18 exactly right, and we're going to talk about this.

19 MEMBER STETKAR: You're not going to talk
20 about -- I looked ahead. The extra borating system,
21 does that ATWS, direct ATWS mitigation capability, or
22 is just a cold shutdown?

23 MR. PARESE: It has that ability, but we
24 handled ATWS completely different.

25 MEMBER STETKAR: Okay. That's fine.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 MR. PARESE: I'll tell you.

2 MEMBER STETKAR: No, that's okay. I just
3 want to make sure -

4 MR. PARESE: We handled ATWS through
5 diverse actuation, but you can use it for that. No
6 doubt about it.

7 MEMBER ABDEL-KHALIK: If your component
8 cooling and service water are 4X100, wouldn't that
9 imply that you can do the cooling with one set of heat
10 exchangers? Why would you need to take credit for the
11 cooling provided by the affected loop?

12 MR. PARESE: Well, we take credit for it
13 because it's there, simply because it's available.
14 Whether that leg is broken or not, I'm cooling the
15 water in the IRWST -

16 MEMBER ABDEL-KHALIK: I understand, but if
17 you're implying that your component cooling and
18 service water are four times one hundred, that means
19 you can do it with one set of heat exchangers.

20 MR. PARESE: It could. It could. That's
21 not how we applied it in our safety case. For
22 injection into the vessel, it's one division. Okay?
23 It's one division, and for your large and small break
24 analysis to show peak clad temperature and cladding
25 oxidation and whatnot, that analysis is a certain

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 length when you hit your stable condition and you
2 quench the core and cover the heat. You show the
3 continued cool down of the unit to cold shutdown, we
4 take credit for the equipment, for the safety-related
5 equipment that's available. Would it take longer if
6 we only had one division? Yes, it would take longer,
7 but we credit two because we have two. That's all.

8 Protection against external hazards, as we
9 said, we use two basic philosophies to protect
10 structures from external hazards. One is with
11 shielding, a shield building, a concrete shield
12 building, and the other is with physical separation.
13 So as you see, for example, our emergency power supply
14 buildings that have our emergency diesel generators
15 are on opposite sides of the building so a calamity on
16 one side of the plant can't affect both. The same as
17 for the essential service water, they're protected by
18 separation. Building One and Four, the ultimate
19 safety response of the unit is protected by
20 separation. These other items, access building, rad
21 waste building, turbine island, they're not protected.
22 That's simply a commercial risk depending on what
23 calamity you might postulate. So that's the general
24 philosophy of the approach, and that's why some of the
25 buildings don't have the shield buildings.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 MEMBER SIEBER: Your main unit
2 transformers and auxiliaries are in a building?

3 MR. PARESE: No, they're up here.

4 MEMBER SIEBER: They're outside then.

5 MR. PARESE: Just outside the turbine
6 island up here. The switch yard is usually up here.

7 MEMBER SIEBER: Far enough away that when
8 they explode and burn, they aren't going to burn the
9 turbine building down. Right?

10 MR. PARESE: Yes.

11 MEMBER SIEBER: Okay.

12 MR. PARESE: And, also, for further
13 separation, our two station blackout diesel generators
14 are in the switch gear building. And that's also
15 close to where they connect to those buses and give us
16 power, separation there. So a calamity to the turbine
17 building isn't -- and it could affect the switch yard,
18 isn't likely to affect our power generation. A
19 calamity that could affect our emergency power
20 generation is unlikely to affect the switch yard, and
21 so on.

22 MEMBER SIEBER: On your main unit
23 transformer, is it a single three-phase transformer,
24 or three one-phase transformers?

25 MR. PARESE: We're using three normal

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 auxiliary transformers.

2 MEMBER SIEBER: Main unit transformers,
3 three.

4 MR. PARESE: Three.

5 MEMBER SIEBER: One per phase.

6 MR. PARESE: And, also, we have two
7 emergency power supply transformers. It meets the
8 emergency -

9 MEMBER SIEBER: About 100 megawatts
10 apiece?

11 MR. PARESE: I don't know.

12 MR. FRANKANESE: Excuse me?

13 MR. PARESE: He asked if they're 100
14 megawatts apiece?

15 MR. FRANKANESE: The GS used, generation
16 up transformers?

17 COURT REPORTER: You need to identify
18 yourself.

19 MR. FRANKANESE: I'm sorry. I'm Dick
20 Frankanese, Electrical I&C Manager.

21 MEMBER BANERJEE: Microphone, you have to
22 use the microphone.

23 MR. FRANKANESE: Okay. The question was?

24 MEMBER SIEBER: How many auxiliary or
25 station transformers do you have? What's their

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 capacity?

2 MR. FRANKANESE: I don't know the
3 capacities. I believe we have, we consider we have
4 five, three plus two, and there's three single-phase
5 generators to up transformers, 500 kV. They're at the
6 end of the turbine building, and the rest of the
7 electrical equipment is in the switch gear building,
8 which is to the left of the turbine building.

9 MEMBER SIEBER: So you probably have two
10 station service transformer chains with probably 120
11 megawatts apiece?

12 MR. PARESE: I couldn't tell you the size.

13 MEMBER SIEBER: I'll find out later, I'll
14 bet.

15 MR. PARESE: Here you can see on the
16 reactor building, you can see the reinforced concrete
17 in these buildings, and it's decompartmented from the
18 containment building. In other words, they don't
19 touch in their design in case of an aircraft hazard,
20 aircraft impact that they don't touch, the deflection
21 won't cause the outer building to touch the inner
22 building, so that any affect of the impact is driven
23 through vibrations down to the basement and back up,
24 but no direct contact.

25 MEMBER SIEBER: Is that a negative

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 pressure in-between?

2 MR. PARESE: That is a negative pressure.
3 It's small and large in short filtration.

4 MEMBER SIEBER: Okay.

5 MR. PARESE: So that's one of the design
6 features of the containment, is that this annular
7 region is filtered so that any leakage during the
8 design basis event that could get into that annulus is
9 filtered before release. And that's done by a safety-
10 related system, 2X100.

11 The free volume is about 2.8 million cubic
12 feet, and the design pressure is 62 pounds, and the
13 in-containment refueling water storage tank is about
14 500,000 gallons per minute, so we've also included
15 severe accident features.

16 Now, as we said before, the containment
17 does not have safety-related spray, and it doesn't
18 have safety-related fan cooler units. Normal cooling
19 of the containment is done with standard HVAC
20 equipment which is in these equipment spaces. Well,
21 on this one it's C, are in these equipment spaces.
22 And it was designed so that you can access these
23 equipment spaces and any of these spaces above the
24 bio-shield during power operation, and the atmosphere
25 is maintained at less than 86 degrees Fahrenheit. So

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 during a loss of coolant accident, the discharge from
2 the vessel or from the break goes up through these
3 cubicles, both the pump, or the pump and the steam
4 generator cubicles, and exhausts into the building
5 where then steam begins to condense on all the
6 concrete and steel structures. And that's typical of
7 a current containment, for example.

8 MEMBER SIEBER: HVAC.

9 MR. PARESE: Yes.

10 MEMBER SIEBER: To avoid overload on all
11 the fixtures.

12 MR. PARESE: Yes. And it's all non-safety
13 anyway, so -

14 MEMBER SIEBER: Yes, but you -

15 MR. PARESE: Yes. You don't want to ruin
16 it.

17 (Off the record comments.)

18 MR. PARESE: So generally then during a
19 loss of coolant accident, circulation patterns are up
20 through these compartments into the main containment
21 where we condense on all these surfaces. We have a
22 little over 700,000 square feet of sealant and
23 concrete surface area in this unit.

24 MS. SLOAN: We should mention that these
25 are not -- this is a backup slide that Marty jumped

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 to, so you won't find it in our slide packet.

2 MR. PARESE: And I jumped here because you
3 asked if we were going to discuss it, so we'll discuss
4 it. So that condensation path then allows the water
5 to run down to the lower levels of the containment,
6 all of these floors are lined with drains so all water
7 drowns down, and then goes into the IRWST where it can
8 be reused for injection and cooling by the ECCS, so
9 the ECCS system will take suction out of the IRWST,
10 it'll cool it in a heat exchanger. It'll inject some
11 of it back into the vessel, most of it, and it'll
12 recirc some of it to the IRWST to cool the IRWST.
13 Also, some of the fluid is injected across the sump
14 screens or the IRWST screens, we'll call them sump
15 screens for now, to provide flushing of the screen.

16 MEMBER MAYNARD: Are each of the four
17 steam generators enclosed individually?

18 MR. PARESE: Yes.

19 MEMBER MAYNARD: Okay.

20 MR. PARESE: It's like current D-rings but
21 with a wall between.

22 MEMBER ABDEL-KHALIK: Could you just mark
23 the boundary of the area that's accessible during
24 operation?

25 MR. PARESE: I had a better slide. I

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 didn't provide it. Accessible -- let's do the
2 unaccessible area. That's easy. The unaccessible area
3 is inside this shield wall right here, basically this
4 area right here, what we call the equipment center.
5 Outside the shield wall we have rooms and other
6 compartments of equipment that you might want to
7 access during operation or getting ready for an
8 outage. The design for OL-3 is that even on the
9 operating deck -

10 MEMBER STETKAR: Marty, come back to the

11 -

12 MR. PARESE: I'm sorry, the microphone.

13 MEMBER STETKAR: Yes.

14 MR. PARESE: Even at the operating deck at
15 OL-3, the design is to maintain the dose rate to less
16 than 2 MR per hour. Clearly, it wouldn't be a
17 requirement in the United States to be 2 MR per hour,
18 but we do have shielding in place to protect workers
19 who have to enter containment, or we might want to
20 enter containment. It also allows us to do certain
21 calibration of the refueling equipment, the heavy
22 crane, maintenance on the stud tensioner if we leave
23 it inside containment. All that can be done while the
24 power plant is down-powering for the outage.

25 MEMBER ABDEL-KHALIK: So even though these

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 areas are accessible during operation, there is --
2 they're physically separated, and yet during an
3 accident you allow steam to escape into the accessible
4 area?

5 MR. PARESE: Yes. And so now you've hit
6 on one of the design features. This steam generator
7 cubicle is covered with a metal foil. That metal foil
8 helps us keep the air separated between the two
9 compartments during operation and controlling to
10 different temperatures. Obviously, all this zone out
11 here is 86 degrees Fahrenheit, and here our limitation
12 is concrete temperature, so it's 140 Fahrenheit.

13 During an event, the over pressure for the
14 loss of coolant accident ruptures the foils and just
15 opens up. Also, on top of the pump we have dampers,
16 metal dampers that due to the pressure open up. Also,
17 down here to allow water to drain to the IRWST, we
18 have radial dampers around the IRWST that open and let
19 the water flow in, and so what happens is it becomes
20 one large containment. So the heat source here act
21 like chimneys and cause the steam to rise. It causes
22 a lower pressure, the condensation is going down
23 around the outside, so we've got liquid going up, or
24 vapor going up, and liquid coming down. But it also
25 allows us to pull an air vapor mixture through the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 IRWST through these holes, and back up through the
2 chimney, so you get a circulation effect that is one
3 of the features of severe accident mitigation, and
4 allowing our hydrogen -- our passive auto recombiners
5 to reduce the hydrogen content.

6 MEMBER BLEY: What opens the dampers at
7 the bottom?

8 MR. PARESE: The dampers at the bottom, I
9 believe they are opened by -- those are held shut I
10 think by springs, and they are opened by an actuation
11 of the protection system.

12 MEMBER BLEY: Like releasing a catch or
13 something like that?

14 MR. PARESE: And so then they'll open, the
15 failsafe has to open.

16 MEMBER SIEBER: I take it it's an
17 atmospheric containment?

18 MR. PARESE: Yes.

19 MEMBER SIEBER: Maximum temperature
20 occurring, the number --

21 MR. PARESE: I think we did -- I don't
22 know the exact number. I thought we did our analysis
23 at 86 Fahrenheit plus. I'm uncertain -

24 MEMBER SIEBER: Well, that's the outside
25 area, inside containment is usually well over -

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 MR. PARESE: No. What I'm saying is, we
2 control this air inside containment, but outside the
3 equipment space at less than 86 degrees Fahrenheit.
4 And then inside has to be less than 140. But in our
5 containment analysis, we applied some uncertainty on
6 the initial condition. I don't remember what that is.

7 MEMBER BLEY: Up in the upper corner of
8 the inside shell compared to the outer one, kind of
9 nubbins where they come together.

10 MR. PARESE: Right here?

11 MEMBER BLEY: Yes. How close is that? In
12 a bad seismic event, maybe beyond the design basis,
13 can they bump? Have you done a seismic PRA or
14 anything like that?

15 MR. PARESE: No, I can say we haven't.
16 What we've looked at is our design aircraft impact,
17 and they don't touch. I don't know the answer to
18 that.

19 MEMBER ABDEL-KHALIK: What's the gap -

20 MR. PARESE: We haven't done any
21 calculations, I think. And I don't remember what that
22 space is. The space of this annulus here is
23 approximately 6 feet.

24 MEMBER BLEY: I knew that was -- it's hard
25 to tell how close -

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MR. PARESE: This wall is 5.8 feet, and
2 5.8 feet, but -- 4.3, so right there.

3 MEMBER MAYNARD: For the U.S. regulations,
4 is it the inside one that you're taking credit for for
5 containment?

6 MR. PARESE: Yes. That's exactly right.
7 So the inside one keeps what's inside in, and the
8 shield building keeps what's outside out.

9 VICE CHAIR BONACA: Could you show me what
10 is the ground elevation?

11 MR. PARESE: Ground elevation is like
12 right in here.

13 VICE CHAIR BONACA: Okay. So it's mostly
14 out above ground.

15 (Off mic comment.)

16 MR. PARESE: Yes, right near that
17 equipment hatch.

18 All right. So here's a place where we can
19 save time. The reactor coolant system is a
20 conventional four-loop PWR, and we built in a lot of
21 Lessons Learned, or experience gained, as our
22 marketing people expect us to say. And we've
23 increased the grace period for a lot of transients by
24 increasing the capacities of sizes of a lot of the
25 equipment.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 MEMBER SIEBER: What materials are the
2 welds made from?

3 MR. PARESE: Well, that's a good question.
4 All of the materials, the hot legs and cold legs are
5 all forged stainless steel, and the -

6 MEMBER SIEBER: Forged, not cast.

7 MR. PARESE: Forged, not cast. And the
8 service line is made of stainless steel, as well.

9 MEMBER SIEBER: Joining welds, are they
10 nickle welds?

11 MR. PARESE: I don't know the answer to
12 that right now. I'm sure we said something in the
13 SAR, but there's debate between using an I-52 type
14 weld, or using stainless material to weld them
15 together, so that's a good question. I don't think I
16 know the answer to that.

17 The use of forgings does reduce the number
18 of welds that we have to inspect, obviously, and
19 that's pretty standard. And the heavy components are
20 SA-508, and we use stainless 308 and 309. That's all
21 pretty standard use.

22 MEMBER SIEBER: Okay. Thank you.

23 MR. PARESE: Slide 21 just shows a
24 comparison of some of the data to an existing four
25 unit. And the main thing to point out is an increase

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 in reactor coolant volume will increase power level,
2 and there's a significant increase in steam generator
3 secondary -- even on a per megawatt basis, so we
4 extended how much the heating level -- and
5 significantly larger pressure at volume; 2650 cubic
6 feet. Again, on a per megawatt or on a volume basis,
7 it's significantly larger, and that slows down the
8 transient response. And then the operating pressure
9 to this unit is 1109 psi at the exit of the steam
10 generator nozzle, and that raises the efficiency of
11 the unit.

12 MEMBER SIEBER: 33 percent.

13 MR. PARESE: From 33 up to 35.

14 MEMBER SIEBER: Oh, it does?

15 MR. PARESE: Yes.

16 MEMBER SIEBER: Somewhere in your list
17 it's 33.

18 MR. PARESE: This unit has a efficiency of
19 35 percent.

20 MEMBER SIEBER: Okay. Got it.

21 MR. PARESE: And what allows us to do that
22 is we've raised the design pressure of the steam
23 generator to 1450 psi. So what that means is from
24 1150 or 1250, and that allows us to for certain
25 transients absorb a lot more energy as you get closer

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 to the design pressure, and that then energy is a
2 large thermal inertia, so -

3 MEMBER SIEBER: And you do that by raising
4 T-h to 618 or more.

5 MR. PARESE: To get the 1109 psi, we have
6 T-hot of 624, and we can do that because we've gotten
7 it out of the unit. And also, the steam generators
8 use an economizer design which is another extra 40
9 pounds.

10 (Off the record comment.)

11 MR. PARESE: And the advantage of our
12 component designs and our steam generator designs is
13 that these steam generators are very similar to the N4
14 steam generators already operating.

15 MEMBER ARMIJO: Same temperatures and
16 pressures, though?

17 MR. PARESE: The N4 runs at 622-1/2, we're
18 running at 624, and they operate at right around 1090
19 psi. The N4 units have a pretty good output. They're
20 4250 thermal, and I think they're 1490 or 1480
21 electric. And they also use 14 foot cords.

22 MEMBER SIEBER: So 628 that precludes
23 nickel-based alloys -

24 MEMBER POWERS: Mr. Parese, you're lagging
25 seriously here, so -

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 MR. PARESE: Okay. We're going to move.

2 MEMBER POWERS: Keep trucking.

3 MR. PARESE: The core design, you can see
4 the evolution of the design from typical four-loop
5 unit to the N4s in France and the USEPR. We use 241
6 fuel assemblies, 17X17, and our active link is 13.78
7 feet. The reason it's 13.78 instead of 14 is that
8 gives us a little more annulus area to handle it. And
9 we have 265 pins per assembly -

10 MEMBER BLEY: I'm sorry. Would you say
11 that last one again? I didn't get that. The reason
12 you're at 13.78 -

13 MR. PARESE: A standard design -- well, I
14 should have prefaced that, the N4s and the P4s in
15 France are 14 foot active stacks, and we're 13.78, so
16 that .22 gives us more area in the annulus above the
17 active stack to absorb --

18 MEMBER ARMIJO: It's kind of the other way
19 around, isn't it?

20 MR. PARESE: I'm sorry?

21 MEMBER ARMIJO: You have plenum volume if
22 you have a shorter fuel -

23 MR. PARESE: The total overall height, I'm
24 talking about the active fuel stack.

25 MEMBER ARMIJO: Oh, this is a fuel -

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 (Simultaneous speech.)

2 MEMBER ARMIJO: Okay.

3 MEMBER BLEY: And that difference does
4 what for you?

5 MR. PARESE: Well, it allows us to build
6 a higher -

7 (Simultaneous speech.)

8 MR. PARESE: It's substantial enough to
9 give us the margin we want, which also one of the
10 margin improvements that was in the average linear
11 heat rate for this design. We went up to 4590
12 megawatts, but if I have 241 assemblies, we've
13 decreased the average rate, and we've increased the
14 cubic feet so that gives us some additional margin.

15 MEMBER ARMIJO: Just a quick question. Is
16 your vessel diameter pretty much standard, or you've
17 got more fuel in there, larger diameter vessel?

18 MR. PARESE: This is a larger diameter
19 vessel.

20 MEMBER ARMIJO: More than the N4s?

21 MR. PARESE: Yes, I believe it is.

22 MEMBER ARMIJO: So that is a step.

23 MR. PARESE: It's a step, but we don't
24 think that's a dramatic step.

25 MEMBER SIEBER: Sixteen, 18 inches wide.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 VICE CHAIR BONACA: The 205 and 241 are
2 really standard designs, are they?

3 MR. PARESE: I guess you would know.

4 VICE CHAIR BONACA: Yes, I used to work
5 for them, and 241 was -

6 MR. PARESE: I remember seeing your name
7 on a lot of stuff. So yes, those are pretty -

8 VICE CHAIR BONACA: 241, I mean, was there
9 in 1973.

10 MEMBER POWERS: This is what you'd call
11 proven technology.

12 MEMBER ARMIJO: You have a big reflector.

13 MR. PARESE: A heavy reflector.

14 MEMBER ARMIJO: In-between the core and
15 the vessel.

16 MR. PARESE: It basically replaces the
17 baffle and former plates on current designs, and we
18 get rid of all those bolts that can crack from
19 radiation, and it prevent baffle jetting because
20 there's no way water can get through there. And it
21 reduces the fluence on the vessel.

22 For the EPR, we're going to capitalize on
23 the digital I&C operating experience in Europe, the
24 N4s that have digital controls.

25 (Off the record comments.)

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 MR. PARESE: And so the digital I&C
2 architecture that we're using, we're using two
3 systems. We're using the Teleperm XS system for the
4 safety I&C protection system, and ESF functions, and
5 we're suing the Teleperm T200 system for the
6 distributed control system. So, generally, we would
7 have the operators operate the plant from the process
8 information and control system, what we call the PICS,
9 and that would be his main interface. But, if for some
10 reason, that interface isn't available, he can go to
11 his qualified display system and actuate safety
12 functions from the other system, safety information
13 control system.

14 And the one thing I wanted to say about
15 that slide is that our safety functions, like
16 protection system and ESI are 4X100, so each division
17 is processing the protection system signals. All
18 right. So the safety system are 4X100. That also
19 means that if each division is comparing for pressure
20 signal say from the pressurizer and doing two by four,
21 each division is doing two by four, so that's an
22 increase in redundancies.

23 The distributed control system is 2X100,
24 so we get our redundancy there and better diversity,
25 so we get better reliability that way. Except for

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 what we talked about, diverse automatic system, it's
2 really not a system. It's a collection of functions
3 to mitigate ATWS. We put certain reactor trip
4 functions and other ESF functions on the T3000, so
5 that if we take an ATWS failure, we have a diverse
6 method of actuating it on a diverse platform. So that
7 is our mitigation for ATWS. And we've increased
8 protection and automation on the unit, so we have a
9 hot channel DNVR trip. We have a high linear power
10 density trip. Those trips are -

11 MEMBER BANERJEE: Well, how do you --
12 DNVR?

13 MR. PARESE: I'm sorry?

14 MEMBER BANERJEE: What do you trip on,
15 power?

16 MR. PARESE: On DNVR, we actually measure
17 the power in the floor and the flow rate, and the
18 pressures and temperatures, and we calculate the DNVR,
19 and we approach the trip set point, we trip the
20 reactor.

21 MEMBER BANERJEE: Is the reactor DNVR, or
22 large break LOCA limits within power? Appendix K?

23 MR. PARESE: I don't think it's -- our
24 realistic LOCA output right now is predicting a
25 temperature of 1425 for the peak UO2 pin, and 1513 for

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 the peak gad pin, so right now I don't think we're
2 LOCA-limited. I think we've been DNVR limited.

3 MEMBER SIEBER: Have you done an Appendix
4 K-type calculation?

5 MR. PARESE: No.

6 MEMBER BANERJEE: So this is what, a best
7 estimate?

8 MEMBER SIEBER: Yes, that's about right
9 for -- that would be about 2,000 degrees on Appendix
10 K. There's some margin there.

11 MEMBER BANERJEE: Oh, it just tripped
12 itself. Okay.

13 MR. PARESE: So we've implemented those
14 trip functions using self-powered neutron detectors in
15 the floor and protection system. We put in a high
16 steam generator pressure trip, so if we get an upset
17 that exceeds certain pressure and we trip the reactor,
18 that helps us with pressure mitigation. And we've
19 included other systems, like computer-controlled heat-
20 up and cool-down.

21 MEMBER BANERJEE: So this protection, I
22 mean, the -- since we've lost that, what you call it,
23 the protection system SG depressurization, this is how
24 you get your low pressure, I mean, your medium
25 pressure in.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 MR. PARESE: Yes. And we need to get
2 there.

3 MS. SLOAN: Yes. There's a section that
4 talks about getting to that, and how that's applied.

5 MEMBER BANERJEE: What is -- you're going
6 to tell us what this protection system SG
7 depressurization is?

8 MR. PARESE: Yes. Core monitoring, we use
9 fixed and movable system.

10 MEMBER: We have books, so maybe you can
11 -

12 (Off the record comments.)

13 MEMBER POWERS: There is not a requirement
14 that we have a transcriber, so would you please go
15 ahead.

16 MR. PARESE: Okay. We're using self-
17 powered neutron detectors to continuously monitor the
18 core. They're cobalt-based so that makes them fast
19 responding, but we calibrate those SP&Ds every 15 days
20 approximately by using a moveable system called
21 Aeroball Measurement System. It's extensively used in
22 Germany. It's very reliable, and it gives us 3-D
23 power map. It does each quadrant in 15 minutes, and
24 so it gives us a full-core quadrant map, a full-core
25 map in an hour, about an hour. And you do that every

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 15 days.

2 MEMBER SIEBER: You do not use any
3 external NIs. Right?

4 MR. PARESE: No, we have external NIs.

5 MEMBER SIEBER: That's your high power
6 trip?

7 MR. PARESE: Well, coupled with we also
8 have a power trip on primary heat, calometric.

9 MEMBER SIEBER: I'm surprised you don't
10 use the self-powered neutron detectors.

11 MR. PARESE: Well, they're used for high
12 linear power density and for --

13 CHAIR SHACK: Better let him go on. He's
14 got a number of important features to get to.

15 MR. PARESE: The reason we wanted to point
16 it out is that it's not new. It's used a lot in
17 Germany for decades, but it's new to people in the
18 United States.

19 Slide 28 shows the locations where those
20 Aeroball probes go into the fuel assembly into one of
21 the thimble tubes, and we have about 40 locations.
22 And that just shows how they work. Vanadium balls get
23 irradiated and then they're sent by high helium gas
24 off to a counting table, and then it counts them.

25 For severe accident mitigation features,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 to prevent high pressure melt-through scenarios, we've
2 installed primary depressurization valves on top of
3 the pressurizer. There's two of them. They're in
4 parallel, not in series. And each one is about 1.9
5 million pounds per hour, so it can depressurize the
6 plant from full pressure to less than 200 psi in about
7 20 minutes. Okay? So if core exit temperatures exceed
8 1200 degrees Fahrenheit, the EOPs will have them open
9 those valves and drive them below pressure.

10 MEMBER SIEBER: Are they squib valves?

11 MR. PARESE: No. These are power operated
12 valves.

13 MEMBER SIEBER: Okay.

14 MEMBER ARMIJO: Are they qualified for
15 steam, water, and two-phase flow?

16 MR. PARESE: Yes, but they are not safety-
17 related valves, so they're not seismically qualified.
18 They're qualified to two over one. In other words, if
19 I have a seismic event, I can't have these valves
20 affect my safety valves.

21 MEMBER SIEBER: Right.

22 MEMBER MAYNARD: They have block valves in
23 it?

24 MR. PARESE: Yes.

25 MEMBER MAYNARD: Are the block valves

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 safety valves, or safety-related?

2 MR. PARESE: No. These valves are
3 normally left closed, and there's no automatic
4 function that opens them. They're manual. And it's
5 based solely on core-exit thermal couple temperatures.

6 MEMBER ABDEL-KHALIK: Isn't 1200 a bit too
7 far? It's way beyond the thermodynamic critical
8 temperature.

9 MR. PARESE: I don't know how to answer
10 that. We don't think it's too far, because we think
11 if we actuate by the time we get 1200 degrees, then we
12 prevent any other downstream failures, for example,
13 temperatures on the tubing that could cause a failure
14 of the tubing, or failure of the pressure boundary.

15 MEMBER SIEBER: You're in severe accident
16 space anyway. Right?

17 MR. PARESE: Right. But the way we do it
18 is, you would enter -- you would open the valves and
19 depressurize, and you could have accumulators or LHSI
20 quench the core. Then you don't enter your SAMGs.
21 But if you continue with high temperatures, then you'd
22 enter SAMGs at that point, and then we would preclude
23 safety injection to avoid a vapor export.

24 Then the method we used for stabilizing
25 the melt and cooling is ex-vessel stabilization, so we

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 have a reactor pit that will collect any melt from the
2 vessel, and then allow it to distribute to a spreading
3 area where we will cool it passively for at least 12
4 hours or longer, and then actively after that point.
5 And then we control the hydrogen concentration inside
6 containment by using passive autocatalytic
7 recombiners. We have 47 of those distributed around
8 the containment.

9 So most notably, this reactor pit area is
10 always kept dry. We haven't talked about the heavy
11 reflector, but the heavy reflector will control how
12 the material collects, and it will have to melt first.
13 And then it will collect in the lower head, and then
14 as your oxidic and your metallic melt separate out,
15 you get different heat transfer capacities, and you
16 could get different melt scenarios, like through the
17 side of the vessel in a partial core, or you could
18 then get heating from above and below, and get a
19 catastrophic failure of the head. Those uncertainties
20 are handled by having a special concrete inside here
21 that ablates and mixes with the material while holding
22 it, and lowers the viscosity of the material.

23 MEMBER CORRADINI: Are you allowed to say
24 what that is?

25 MR. PARESE: It's concrete, and I don't

1 know if -

2 MEMBER POWERS: I'm going to be fascinated
3 to find a concrete that will lower the viscosity of
4 core debris.

5 MEMBER CORRADINI: Of what?

6 MEMBER POWERS: Core debris.

7 MEMBER CORRADINI: I think you meant to
8 say lower the solid's temperature, I assume you meant
9 to say.

10 MR. PARESE: Yes.

11 MEMBER CORRADINI: Okay.

12 MEMBER POWERS: But it's not going -- all
13 that's going to do is raise the viscosity.

14 MR. PARESE: Yes, it will separate the
15 liquidous and solidus temperature.

16 MEMBER POWERS: That is -

17 MR. PARESE: Also, this is lined with --
18 the plutonium elements are behind the concrete,
19 except for this melt plug here which has concrete, and
20 then it has a steel and aluminum, so this is the
21 failure point of the system.

22 MEMBER CORRADINI: So it's designed to
23 basically cook -- a special cooking mechanism which
24 then releases in force?

25 MR. PARESE: That's exactly it. And we

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 make this the weak link so that this will fail first,
2 and then we'll get a pour and a spread into the
3 spreading area. The large spreading area, then once
4 it spreads into the spreading area, we activate
5 passive valves. That's thermally actuated valves,
6 that's another way of saying it, spring-loaded valves
7 with chains, the chains melt and the spring-loaded
8 valve will -- so there's nothing fancy about that.
9 And what it does is, it allows water from the IRWST to
10 flow underneath the spreading area, which cools it
11 from the bottom. And then up over the top of the weir
12 and on top, and cools it on top. The flow rate is
13 restricted, so that we don't generate too much steam
14 -

15 MEMBER BANERJEE: How does the water flow
16 underneath there?

17 MR. PARESE: Well -

18 MEMBER BANERJEE: It's not clear to me.

19 MEMBER CORRADINI: It's just a European -

20 MEMBER POWERS: We will have an
21 opportunity to explore this in enormous detail.

22 MR. PARESE: There's a line - those valves
23 a line that allows water to go under the cooling
24 channel, and these have cast iron plates with cooling
25 channels, and the water runs underneath. And the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 IRWST level is above the spillover on the WIR, so that
2 promotes the flow.

3 MEMBER CORRADINI: This is, I guess, a
4 small question, if the Chair will allow me. What is
5 the elevation of the bottom of the IRWST? It shows
6 here that it's below the vessel bottom. Is that
7 correct?

8 MR. PARESE: Yes.

9 MEMBER CORRADINI: Okay. All right.

10 MEMBER POWERS: We've got not passage
11 stuff in there, we've got pumps.

12 MEMBER CORRADINI: I just wanted to know
13 the elevation. I was just curious.

14 MR. PARESE: We can passively cool, the
15 steam will go up in the containment, condense in the
16 methods we talked about for the loss of coolant
17 accident. The condensation will go back into the
18 IRWST, and at least for 12 hours, we can do that
19 without exceeding the containment design pressure.

20 MEMBER BANERJEE: What does IRWST stand
21 for?

22 MR. PARESE: In Containment Refueling
23 Water Storage -

24 MEMBER POWERS: We should tell him in
25 French what it stands for.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 MR. PARESE: All right. So at 12 hours,
2 the operator is credited to turn on the severe
3 accident heat removal system, which can then use those
4 non-safety-related sprays to depressurize the
5 containment system. And at any time after that, he
6 can also switch to active cooling of the melt, and
7 that active cooling then will pump up that cabin and
8 fill up the vessel, and to chimney up to the top, so
9 now you have active flow and cool.

10 MEMBER BANERJEE: Now we don't have to
11 look at -

12 MEMBER SIEBER: Not today.

13 MEMBER CORRADINI: Dr. Powers will.

14 MEMBER BANERJEE: Dr. Powers, are you
15 going to have to look at this in detail in the future?

16 MEMBER POWERS: Exhaustive.

17 MEMBER ABDEL-KHALIK: You indicated that
18 you are using 35 percent enriched boron.

19 MR. PARESE: Yes.

20 MEMBER ABDEL-KHALIK: What sets the
21 isotopic enrichment that you need?

22 MEMBER POWERS: Water solubility.

23 MEMBER ABDEL-KHALIK: Isotopic.

24 MEMBER POWERS: Yes, water solubility,
25 more than anything else.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 MR. PARESE: Yes. The solubility limit is
2 important for our post-LOCA mitigation, and that
3 affects the time at which you must turn on hot leg
4 injection. I don't know if you noticed in the
5 pictures that showed the injections, we can open
6 valves to inject into the hot leg, and that's our
7 primary method to prevent boron played out in the
8 vessel, and exceeding the solubility limit.

9 The other issue is if you saw -- this unit
10 operates at 624 degrees, even at a lower kilowatt-per-
11 foot, we have to always be wary of crud-induced power
12 shift, and so having the enriched boron allows us to
13 have a critical boron concentration of only 1400 ppm
14 for an 18-month cycle.

15 MEMBER POWERS: And again, this is an area
16 that you want to pay very close attention to because
17 boron shifting in these kinds of high power reactors
18 are going to be an issue.

19 MR. PARESE: And so the other thing is
20 once you decide you're going to go to enriched boron,
21 you make sure that's what you use everywhere, and you
22 don't allow anything else on the site.

23 MEMBER ABDEL-KHALIK: But are you sure
24 enriched boron is going to help you with axial offset
25 anomaly?

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 MR. PARESE: Critical boron concentration
2 is extremely important, as well as the -

3 MEMBER BANERJEE: What was the reason for
4 making the core longer?

5 MR. PARESE: Fourteen feet, to get the
6 power out of it.

7 MEMBER SIEBER: I guess you made it
8 bigger, so you had to make it longer.

9 MR. PARESE: We made it longer -- if you
10 want to get -- the original design of the EPR was to
11 handle 4900 megawatts, and if you're going to do that,
12 you either have to have a much wider -- a bigger
13 diameter core, or a taller core, or -

14 MEMBER BANERJEE: So it's a foot and
15 something longer than the current full rate operated
16 design.

17 MR. PARESE: Yes. But it's the same basic
18 fuel that's operating in the French units in the P4s
19 and the N4s for decades. Areva has a lot of 14-foot
20 experience. We need to get on to your main topic, is
21 SGTR mitigation and small break LOCA mitigation. This
22 is your depressurization.

23 For SGTR mitigation, medium head injection
24 pumps were purposely selected. The view from the
25 utilities that were helping design the unit and from

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 Areva at the time was that the event that is most
2 likely to cause radiation release to the environment
3 and to the public was a steam generator tube rupture.
4 And even though we've improved the materials, we use
5 Alloy 690 in our steam generators, the German
6 generators have Alloy 800. You could have a loose
7 card or something else. You can't say what could
8 cause damage in a steam generator. It's not just
9 stress corrosion cracking.

10 Consequently, the way to keep the iodine
11 in the plant is not to vent liquid that contains that
12 iodine outside the plant. So the medium head safety
13 injection pumps were perfectly selected so that even
14 if they went to their dead head, a shutoff head is
15 below the main steam safety valve set point on the
16 steam generators.

17 MEMBER BANERJEE: But this is the German -
18 - the Siemens, from what I -

19 MR. PARESE: I would agree that that was
20 originally the driving philosophy, but I think it was
21 embraced entirely by the whole design team. Now
22 you're getting into other issues between French and
23 Germans, and French and German regulators, and we
24 don't need to talk about that today. But the point
25 is, consensus was reached, to keep from venting liquid

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 that contains iodine outside the steam generators.
2 And regardless of your regulatory assumptions on
3 Partition factors, the reality is from a physical
4 point of view, most of the iodine is going to stay in
5 the liquid phase, so keep that liquid phase inside the
6 plant. So that insures there's no challenges to your
7 safety valve in the affected steam -- there's no
8 operator action required.

9 (Announcements.)

10 (Off the record comments.)

11 MEMBER SIEBER: Do you want us to
12 continue?

13 MEMBER POWERS: Please.

14 MR. PARESE: All right. So we meet our
15 dose consequences from a regulatory standpoint -

16 MEMBER POWERS: Can we please close the
17 door?

18 MR. PARESE: And also from a design
19 standpoint, we meet those goals by minimizing bypass.
20 So now that gives you the interesting problem that you
21 jumped on right away at the beginning, was for very
22 small loss of coolant accidents, the energy discharged
23 through the break isn't sufficient to remove all the
24 energy. You have to dump some of the energy to the
25 generators, so for small breaks you're coupled to the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 steam generator pressure. Primary pressure couples to
2 the steam generator pressure. If those steam
3 generator pressures are above the dead head on the
4 MHSI, then for those smaller breaks you will not get
5 any significant MHSI flow until you can completely
6 drain the loops and open the loops seals, and get
7 steam to the break. And now you're in a race for
8 depressurization versus water coming in.

9 MEMBER ABDEL-KHALIK: What's your T-ave?

10 MR. PARESE: Our T-ave is 594 degrees
11 Fahrenheit.

12 MEMBER ABDEL-KHALIK: And what is the
13 saturation pressure at T-ave?

14 MR. PARESE: I don't have my steam table
15 with me.

16 MEMBER ABDEL-KHALIK: Is it greater than
17 or lower than the shutoff head of your SI pumps?

18 MR. PARESE: It's greater than -- let's
19 see. The shutoff head is 1400 - I don't have my steam
20 table with me. Anybody have a steam table? I don't
21 know.

22 MEMBER ABDEL-KHALIK: That's okay.
23 Continue, please.

24 MEMBER BANERJEE: So you use the can-do
25 method, basically. That's what they've been doing for

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 years.

2 MR. PARESE: And it turns out that every
3 EOP ever written for mitigating small break tells the
4 operator to depressurize the steam generators and keep
5 them below the saturation temperature of the primary.
6 In other words, keep them at heat sink

7 MEMBER BANERJEE: The only thing that it
8 requires then is that you have sufficient flow area
9 that you don't get flooding during reflux
10 condensation. Because if you do, then you don't get
11 any steam in.

12 MR. PARESE: That would be true.

13 MEMBER CORRADINI: Where is the reflux
14 condensation coming from, Sanjoy? I don't think I
15 understand.

16 MEMBER BANERJEE: Because they have to
17 pull the heat out of the steam generators. Therefore,
18 if you get water condensing, it runs back counter-
19 current to the steam flow going. And, therefore,
20 there's a chance of flooding at this tube sheet.

21 MEMBER CORRADINI: Oh, in the tube sheet.

22 MEMBER BANERJEE: Just at the entrance.

23 MEMBER ABDEL-KHALIK: Did you say your
24 primary TM at full power is 590?

25 MR. PARESE: 594.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 MEMBER ABDEL-KHALIK: 594. Saturation
2 pressure is roughly 1475, so if you have a small break
3 on the high end of it, and the primary saturates, your
4 SI pumps will be dead headed.

5 MR. PARESE: If it happened that way, but
6 it doesn't happen that way, because you get a core
7 shutdown which reduces the heat production in the
8 core. Zero power temperature is more indicative of
9 where you'd go once you've dumped the sensible heat to
10 the steam generators, and that's 577 Fahrenheit.

11 So we're down to five minutes, so let's
12 punch through this. So the plant has a safety-related
13 function that's driven by the protection system that
14 depressurizes the steam generators, and that signal is
15 a low-low pressurizer pressure signal which starts the
16 safety injection system. So we start this
17 depressurizer when there's still water in the steam
18 generators. We depressurize the steam generators at
19 180 F per hour, 100 C per hour, to about 870 psi,
20 where then the valves control to that set point.

21 MEMBER BANERJEE: Just blowing steam.

22 MR. PARESE: Blowing steam. We're blowing
23 down the steam generators, we're feeding with
24 emergency feedwater, and we're just depressurizing the
25 steam generators. And then at 870 psi, we hold the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 pressure constant. So what we do is we lower that
2 pressure so that for those breaks that couple to the
3 steam generator, they couple to a lower pressure, and
4 we insure then that we have adequate MHSI flow.

5 MEMBER ABDEL-KHALIK: What are you blowing
6 down the steam generators with, atmospheric dumps?

7 MR. PARESE: The main steam relief train
8 that we discussed, which is safety-related,
9 seismically qualified. It's 50 percent steam flow.
10 We're using that system, and it's got redundant power
11 supplies. It's actuated by the protection system. So
12 we've developed a safety-related depressurization
13 system. We're looking at some power uprates for some
14 units in the U.S., and putting the same kind of
15 safety-related system on to get this credit.

16 MEMBER BANERJEE: Is this plant peak-clad
17 temperature? Is this occurring for the largest LB-
18 LOCA or is it shifted to a smaller break?

19 MR. PARESE: It's shifted to a small
20 break. If you looked in our FSAR, our peak clad
21 temperature is for a 6-1/2 inch break, and it's --
22 it's in the FSAR.

23 MEMBER BANERJEE: But your FSAR is in now.
24 Right?

25 MR. PARESE: Yes.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 MEMBER BANERJEE: So we can take a look at
2 it.

3 MR. PARESE: You can see it in Chapter 15.
4 There's a table, and the 6-1/2 inch break. There's
5 actually a plot of PCT versus break size for the small
6 breaks.

7 MEMBER BANERJEE: Okay. Thank you.

8 MR. PARESE: So, in fact, what this does
9 is for one and two inch breaks, there's no core
10 uncovering, and for three and four inch breaks, and five
11 inch breaks that require loop seal clearing, anyway,
12 this helps a little, but -

13 MEMBER BANERJEE: Are your steam
14 generators fairly large, is there a large flow area?

15 MR. PARESE: Yes.

16 MEMBER BANERJEE: Then I'm much less
17 worried.

18 MEMBER POWERS: In exhaustive detail.

19 MEMBER BANERJEE: No, it's a question of
20 whether that has enough flow area during the
21 condensation part.

22 MR. PARESE: Well, and a big part of the
23 depressurization -- for the breaks that matter, which
24 are the smaller breaks like two inches, and three
25 inches, the depressurization is occurring early in the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 vent before you even get much boiling, so they're
2 ready to go when you produce some vapor.

3 MEMBER BANERJEE: Okay.

4 MR. PARESE: All right. I'm going to
5 zoom, I know that people are interested in the PRA.
6 It's in Chapter 19. I'm going to zoom through this,
7 because we're almost out of time. What I will say is
8 our design target was to a core melt frequency from
9 all plant states and initiators to be less than 10 to
10 the minus 5. We wanted the at-power states to be less
11 than 10 to the minus 6, and the shutdown states to be
12 less than the power states, and so when we went
13 through the PRA, our core damage frequency from at-
14 power and shutdown events is less than 5.8 times 10 to
15 the minus 7, so that's well below our design goal.

16 MEMBER STETKAR: Does that include any
17 contribution from seismic events?

18 MR. PARESE: No.

19 MEMBER STETKAR: Okay. Thank you.

20 MR. PARESE: So, Todd, we're back to
21 seismic margins again. I'm going to leave the slides
22 on operating experience for you to take with you,
23 because we're really out of time, so you can see that
24 the built-in -- the operating experience on the
25 existing units to help with materials, event

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 materials, to reduce the degradation from materials,
2 to ease the outages, make the outages faster and
3 easier to do. I think everyone is going to tell a
4 story.

5 MEMBER APOSTOLAKIS: Did you say you could
6 do a margins analysis -

7 MR. PARESE: No, I don't believe we have.
8 We did?

9 MEMBER APOSTOLAKIS: What did you say?

10 MR. PARESE: All right. I need to ask
11 Todd Oswald to step up to the microphone then.

12 MEMBER APOSTOLAKIS: Oh.

13 MR. OSWALD: Yes. This is Todd Oswald,
14 the Manager of the Civil Structural Group. Actually,
15 we did do seismic margins assessment to demonstrate
16 the 1.67 heat capacities.

17 MEMBER STETKAR: What's the SSE for this
18 plant?

19 MR. OSWALD: 0.3g is the -

20 MEMBER STETKAR: .3.

21 MR. OSWALD: Is the PGA.

22 MEMBER STETKAR: .3g.

23 MR. OSWALD: That's correct.

24 MEMBER APOSTOLAKIS: Then it's very hard
25 to demonstrate that you met your target, isn't it?

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 The targets on slide 30 something, 35. Anyway, we'll
2 come to this at some other time. And the fire is also
3 a margins kind of analysis, like the EPRI fire thing?
4 Although, in your case it's probably very low because
5 of the preventive separation.

6 MR. PARESE: Yes, but the number is so low
7 that fire still has a contribution. It's like an
8 operating unit, instead of fire events being 30 some
9 percent of 5E to the minus 5, or maybe a similar
10 fraction of 6E to minus 7, so we drastically reduced
11 the -

12 MEMBER APOSTOLAKIS: It has been submitted
13 already?

14 MR. PARESE: Yes. Chapter 19 is there.
15 In fact, this slide -

16 MEMBER POWERS: It's the orange on his
17 segment there. Fire is the orange.

18 MR. PARESE: And that's a whole range of
19 different fire events, fire in the control room, fire
20 in the switch gear, fire in the different safety
21 buildings, so there's -- it all in Chapter 19. And
22 one of our safety goals is to reduce the occupational
23 dose, and our design goal is to put features in the
24 plant to reduce the dose to less than 50 person-rem
25 per year. And we've had 50 utilities estimate that

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 number based on their activities, and they think
2 they'll be seeing a number average including refueling
3 outages, a two-year running average of around 38. But
4 that proof isn't in the pudding, it's in the -- so in
5 the time we had, we didn't get to answer all the
6 questions, but -

7 MEMBER POWERS: Oh, you'll get the
8 opportunity.

9 MR. PARESE: I'm sure we will. But EPR is
10 an evolutionary design. The features that you saw are
11 very much like features you've seen. We took the
12 maximum benefit from the operating experience, and R&D
13 of the existing units, and so most of the features are
14 typical PWRs. And, as we've discussed, we included
15 features to improve safety, enhance reliability, and
16 protect critical systems from external events, which
17 were some of the major design goals of the unit at the
18 very beginning. And with that, you've gotten the rapid
19 fire overview of the EPR.

20 MEMBER POWERS: That's what we asked for.

21 MEMBER ABDEL-KHALIK: The 1400 ppm boron
22 that you mentioned earlier, what is that value
23 exactly? Is that the -

24 MR. PARESE: The number I mentioned,
25 that's the range of the initial critical boron

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 concentration in the reactor coolant at the beginning
2 of a cycle.

3 MEMBER ABDEL-KHALIK: So this is the
4 critical boron concentration at the beginning of
5 cycle.

6 MR. PARESE: Right. And since the boron
7 concentration goes down with burn-up, it's that
8 initial critical boron that can lead to boron plate-
9 out if you have a high --

10 MEMBER ABDEL-KHALIK: So you need 1400 ppm
11 with 35 percent enrichment in boron-10 to do this job.

12 MR. PARESE: Correct. Otherwise, your
13 critical boron concentration will be over 2000.

14 MEMBER POWERS: The portion of the
15 material you did not ever suggest, your materials from
16 metallurgy, the Subcommittee will have to contribute,
17 as well, here. So you're going to carry a big load
18 again.

19 What can I say except thank you. That was
20 good. We asked for a whirlwind, we got a whirlwind.
21 We asked for a schedule, we got a schedule. You're
22 putting all together too much on us, we'll be all very
23 grouchy next time, and probably interrogate you must
24 more closely on all these things, but I appreciate it
25 very much. If the members have any other questions on

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 this, now I have taken notes on where the questions
2 were asked. and I will be assigning each one of you to
3 report on what you asked about here in detail for the
4 August Subcommittee meeting we'll schedule.

5 (Off the record comments.)

6 MEMBER POWERS: Other than that, thank you
7 very much. We'll turn it back to you, Mr. Chairman.

8 CHAIR SHACK: Okay. We will recess for 15
9 minutes.

10 (Whereupon, the proceedings went off the
11 record at 3:48 p.m., and went back on the record at
12 4:06 p.m.)

13 CHAIR SHACK: Time to come back into
14 session. Our next topic is essentially a briefing in
15 the safeguard and security area, and Mario will lead
16 us through that.

17 BRIEFING ON SAFEGUARDS AND SECURITY

18 VICE CHAIR BONACA: Yes, good afternoon.
19 And thank you for coming.

20 For the information of the committee,
21 there are many activities or developments of the rules
22 and regulations under the security rulemaking. And so
23 they are all coming together pretty much in the month
24 of July.

25 There are four rules as far as I

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 understand, the security interface, cyber security,
2 the contingency mitigative measures, large fires, and
3 explosions rule, and the aircraft impact rulemaking.

4 In addition to those there are a list of,
5 I could see two reg guides, one cyber security, and
6 the other one the safety-security interface.

7 And of course then there is NEI 404, then
8 also is the reference, I believe that's 5.2, cyber
9 security.

10 Now what is happening is that I believe
11 the Commission is expecting all these rules to be
12 completed by the month of July. And we are in a
13 squeeze because, if I understand it, all these rules
14 will not be ready in final form until the end of the
15 month, and they are supposed to write a letter in
16 July.

17 So we are in a squeeze that -

18 VOICE: Are we supposed to be here on the
19 4th of July?

20 VICE CHAIR BONACA: No, what happened is
21 that I invited this gentleman, Andrew Pahlevi, to come
22 and tell us about their plan, and when we can expect
23 to see material to review and see how we can work
24 around it and see if we can support them.

25 MEMBER APOSTOLAKIS: We have a subcommittee

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 meeting.

2 VICE CHAIR BONACA: The committee meeting
3 will take place in the July meeting. So it will be
4 probably the first day of the meeting in July. We
5 have no materials to go there.

6 MEMBER CORRADINI: But you're not going to
7 have anything that earlier part of the week on the 7th
8 or the 8th.

9 MEMBER APOSTOLAKIS: On the 8th is already
10 another -

11 (Simultaneous voices)

12 VICE CHAIR BONACA: We are going to hear
13 now when they believe that they can deliver to us some
14 information so we can review, clearly, we are looking
15 typically for finalized documents, because we don't
16 want to comment on documents which are still in flux.

17 So we will hear about that. And I wanted
18 to make this introduction, because at the end of this
19 presentation we should spend a few minutes to do some
20 planning.

21 First of all, determine what can be done,
22 and second, within that, see how we can do it.

23 So with that I'll turn it over to you, and
24 we'll have the presentation.

25 MS. BANERJEE: This is Maitri Banerjee.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 Can I add something to answer George's question on the
2 subcommittee meeting. We did plan a subcommittee
3 meeting with the committee, but because of the
4 compressed schedule that the staff was under it was
5 very difficult for them to support it.

6 VICE CHAIR BONACA: But furthermore on
7 security and safeguards, we don't have a subcommittee;
8 we have a full committee. The whole committee is
9 being - because we never - we'd do well to redouble
10 the efforts.

11 Anyway that's where we are.

12 MS. SCHNETZLER: Good afternoon. My name
13 is Bonnie Schnetzler. I work for the office or NSIR,
14 and I'm the project manager for the security
15 rulemaking for nuclear power plants.

16 Today I'd like to talk to you a little bit
17 about the status of the security rulemaking. We came
18 here last year about this time and kind of gave you a
19 brief of what we were doing, and the complexity and
20 large pieces of rulemaking that we had, and then focus
21 on the parts of this rulemaking that will need ACRS
22 review.

23 And then give you a status of the
24 regulatory guidance that supports the regulation that
25 we have in the proposal and now in final draft.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 Next, please.

2 MEMBER APOSTOLAKIS: Well, just to go back.

3 MS. SCHNETZLER: Go back.

4 MEMBER APOSTOLAKIS: Which one are you
5 using now?

6 MS. SCHNETZLER: Right, the - in actuality
7 the part that was in appendix charley which you spoke
8 of, sir, was rolled into - and moved to 50.54(hh),
9 which is the imminent attack and mitigative measures.

10 MS. HOLOHAN: He did mention the aircraft
11 impact rules, which is separate, that's a separate
12 track. It's not part of this.

13 MEMBER APOSTOLAKIS: Yes, but the aircraft
14 rule is going to come to us in July too.

15 MS. HOLOHAN: Yes, but it's not going to
16 be part of this.

17 MEMBER APOSTOLAKIS: I understand. It's
18 got to be on our table for review anyway.

19 MS. SCHNETZLER: This is - following is a
20 list of the rulemaking that we are currently engaged
21 in, 50.54(hh), mitigative strategies and response
22 procedures for potential or actual aircraft attacks.

23 73.54, protection of digital computer
24 communication systems and networks.

25 55, which is physical security for power

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 reactors.

2 56, which is personnel access
3 authorization requirements.

4 MEMBER APOSTOLAKIS: Is the fact that one
5 of them is under five-fifty and the other is five-
6 seventy-two, does it make any difference in real life?

7 MS. HOLOHAN: No, it was originally part of
8 Part 73, and one of the comments we got was, it would
9 be better served to be in Part 50, so we moved it into
10 Part 50. But it's going to be part of the final
11 rulemaking.

12 MEMBER APOSTOLAKIS: Why is it better
13 served?

14 MR. MORRIS: Because, if I could take it,
15 Part 73 is what you have to do to respond to, within
16 design basis, threat attacks. And everything in
17 50.54(h) is outside of design basis threat.

18 That's the short answer. The long answer
19 is a lot more complicated.

20 MR. REED: Dr. Apostolakis, in addition to
21 that, 50.54 also would place it in as a license
22 condition on the licensee. So it goes over to Part
23 50. These are broad actions. They are operator
24 actions. Emergency preparedness and fire protection,
25 okay. They are much broader than security force; they

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 involve security. So in that context it makes more
2 sense to go to Part 50 and it works in licensing space
3 better two.

4 MR. MORRIS: Most of the things that need
5 to be done in response to aircraft attacks and
6 mitigation strategies are all - they are not generally
7 done by the security organization. They are done by
8 operators, emergency responders, things like that.
9 That's the other big reason on this.

10 Thanks.

11 MEMBER CORRADINI: A question just for my
12 edification. I understand what you said. So that
13 separates us, so that's in the 50.54 side.

14 MR. MORRIS: It's analogous to how it's
15 been treated with the operating reactors right now.
16 The mitigation measures piece is really interim
17 compensatory measure b-5-b actions, which have all
18 been handled as a condition of the license, the
19 operating license.

20 So we are just mimicking that in the rule.

21 VICE CHAIR BONACA: Now the question I have
22 is, if I go back to the previous slides I see
23 50.54(hh), I see 73, for cyber security. Now there
24 are two more actors here. Could you go through the
25 next slide?

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 One is 73.55, physical security - we have
2 not reviewed that, have we?

3 MS. HOLOHAN: That is correct. I just want
4 to give you the pack that we're working on.

5 VICE CHAIR BONACA: And then 356 also we
6 don't review?

7 MS. HOLOHAN: That's correct.

8 MEMBER APOSTOLAKIS: How was this decided?

9 VICE CHAIR BONACA: That was decided a long
10 time ago because really each of those persons et
11 cetera from which review were excluded from
12 participation. So I wanted to keep track as we move
13 through.

14 MS. HOLOHAN: Right, and I'll narrow it
15 down as we go along.

16 MS. BANERJEE: This is Maitri again. I
17 believe there is a commission SRM that sort of directs
18 ACRS to stay outside of physical security.

19 VICE CHAIR BONACA: Yes, so those areas -

20 MS. SCHNETZLER: And this follows that SRM.

21 The next parts of the rulemaking, 75.38,
22 safety-security interface requirements, Appendix B,
23 which is training and qualifications for security
24 personnel, in Appendix C, which is safeguards
25 contingency plans.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 VICE CHAIR BONACA: But now again, here,
2 this involves most of the first part, which is set the
3 security interface.

4 MS. SCHNETZLER: Correct.

5 So where we're at right now as of today is
6 that we are in the stages of the development of the
7 FRN. That is being put together, being reviewed by
8 OGC and other offices before we place it into formal
9 concurrence which we plan to do on 6/16 of this month.

10 Our goal is to have it to the EDO on 6/30,
11 so we're moving along very quickly.

12 VICE CHAIR BONACA: What is FRN?

13 MS. SCHNETZLER: Federal Register Notice.

14 VICE CHAIR BONACA: Federal Register
15 Notice. So it would not be however complete or
16 approved until 6/30?

17 MS. SCHNETZLER: That's correct.

18 MR. MORRIS: The plan is to deliver it to
19 the executive director by the end of this month by
20 which time the EDO's office will have an opportunity
21 to provide their input. Ultimately the commission and
22 the OMB and - so we're projecting that probably if all
23 goes well probably the early part of 2009 the rule
24 would be effective.

25 MS. HOLOHAN: EDO has told us they want to

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 move it to the commission as quickly as possible on
2 June 30th.

3 MEMBER APOSTOLAKIS: What is it that would
4 be introduced?

5 VICE CHAIR BONACA: Well, they will deliver
6 to the EDO the part of the rule package.

7 MEMBER APOSTOLAKIS: And then what happens?

8 VICE CHAIR BONACA: Aircraft impact rule.

9 MS. HOLOHAN: No, we don't have anything to
10 do with that.

11 MR. MORRIS: NRO has - and I think NRO has
12 the lead on that. There she is.

13 MS. GILLES: This is Nanette Gilles from
14 the Office of New Reactors. The aircraft impact rule
15 is on a separate schedule from the security rule. The
16 aircraft impact rule has been provided to the ACRS,
17 and we will be discussing that in the July full
18 committee meeting.

19 And our schedule is to deliver that rule
20 to the commission in September.

21 MEMBER APOSTOLAKIS: But again, the
22 question is, the final rule you say will be submitted
23 to the Commission in July? And then what happens?
24 Because you said it's going to be in fact a year - so
25 what happens during that year?

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 MS. HOLOHAN: No.

2 MEMBER APOSTOLAKIS: So what happens during
3 the year?

4 MS. HOLOHAN: It won't be a full year
5 later. When we get a Commission SRM, and Tim may deal
6 with it, then we'll have to go through OMB clearance
7 with the final rule package, and that takes 60 days.

8 MEMBER APOSTOLAKIS: Is there a period of
9 public comment here at some point?

10 MS. HOLOHAN: No, we have already had
11 public comment.

12 MR. REED: George, it's pretty much the
13 standard rulemaking process at this point. In other
14 words, the Commission has to deliberate. They are
15 going to take some time. Then they issue a staff
16 requirements memorandum. I'll give you an idea, the
17 proposed rule had 300 items in it. It was
18 substantial. It took many months for us to address
19 that down. We have to address that; make those fixes;
20 go back to SECY, okay, then start the OMB clock for 60
21 days. So what it is, it runs you all the way through
22 the end of the year into the very beginning of next
23 year if you start running the calendar time. And
24 that's 30 days effective when you get into the Federal
25 Register. It adds up; it's pretty amazing.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 So we build in roughly about two months
2 for the Commission in there, which is pretty
3 aggressive. This thing is going to be a very very
4 large package.

5 VICE CHAIR BONACA: The question I have is,
6 what time does the ACRS have to comment on these
7 rules?

8 MEMBER APOSTOLAKIS: July, right? That's
9 what you are saying.

10 MR. MORRIS: Essentially.

11 MEMBER APOSTOLAKIS: Essentially means
12 what.

13 VICE CHAIR BONACA: If I understand your
14 comment in July, on giving us a presentation on this
15 on the final documents, and you expect to have us turn
16 around the letter immediately. We will have to
17 discuss whether or not ACRS can do this.

18 MR. MORRIS: Our intent was to deliver the
19 package to the EDO's office, and then nearly
20 simultaneously provide that to the ACRS for their
21 review, and knowing how big this package is, and how
22 long it's likely to take the Commission to deliberate
23 on it, it was our expectation and hope that the ACRS
24 could complete whatever review they work that you all
25 decided to conduct in parallel but preferably early on

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 before the Commission gets too far down - this thing
2 is on an incredibly fast track as you have sensed.
3 And there are a number of reasons for that, and we can
4 go into that if you'd like.

5 But the net result is that the staff was
6 provided very little time to conduct the business that
7 we would ordinarily conduct, particularly for a
8 project of this scope.

9 MR. REED: I would also say, Dr.
10 Apostolakis, is that in July certainly you can inform
11 the Commission, and I think this committee can provide
12 good input with regard to the requirements themselves,
13 the new language requirements themselves, the
14 implementation guidance will still be in draft form,
15 and I think the committee can get involved with that
16 through some period of time, because that has to be
17 finalized, that's going to take much longer. And I
18 don't know if we have any detailed schedules for that.

19 MR. MORRIS: Well, what I can say about
20 that is, with respect to the cyber-security piece, we
21 will be - in fact it just came back from publication
22 today, the draft reg guide that supports the 73.54
23 rule, so we are going to put that out for a 45-day
24 public comment period, have a meeting. That won't
25 obviously be finalized for some time, and we'll have

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 plenty of time to discuss some of the implications of
2 that regulatory guidance.

3 Similarly, the 50.54(h) guidance will
4 likely not be issued for stakeholder comment until the
5 July timeframe.

6 And then what's the third piece? The
7 third piece was the safety-security interface which
8 has been out. We actually put a draft of that out for
9 comment, and had a public meeting on it last August.
10 Since that time the industry has indicated a desire to
11 provide their own guidance, and let us comment on
12 that.

13 That guidance from industry has not yet
14 been forthcoming. So we are kind of at the point
15 right now where we are almost ready to go back to what
16 we started with.

17 MEMBER APOSTOLAKIS: So all these things,
18 we have time to get involved with later. So what Tim
19 is saying that we are going to review only the
20 requirements of the rule in July?

21 MR. REED: Obviously I'm not going to
22 direct the committee. I mean it's up to the
23 committee. I'm just making a suggestion that in July
24 you certainly will have sufficient information to make
25 a judgment whether you think requirements in these

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 three areas are adequate, and we'll probably be able
2 to give you as much as we can in terms of
3 implementation guidance at that time to start that
4 review.

5 MR. MORRIS: And additionally where we are
6 in terms of the language, and Bonnie is going to get
7 to this, but the language of the rule that we are
8 asking ACRS to take a look at is available right now,
9 and in fact we are going to provide that to you.

10 VICE CHAIR BONACA: But it's available in
11 not-Internet file form. Only documents in hands for
12 the past few days, okay. And on a rule there is one
13 page. On other rules, there are two pages. There is
14 no support to information.

15 I spent a lot of time on cyber security
16 guidance, 404, NEI-0404 in thinking that that would be
17 the actual reg guide, and now I come here and I
18 discover there is a reg guide that supercedes the NEIA
19 guidance.

20 So everything is so in flux and ACRS does
21 not typically review and comment on a document which
22 is still in flux, because we may make a recommendation
23 that is inappropriate, because the rule changes or the
24 guidelines change.

25 So what I'm trying to do including for the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 aircraft attack rule, is to understand when we can
2 expect to have something finalized enough so that even
3 if we jump on it, we can at least start to review it.

4 The reason why I also mention the aircraft
5 impact rule is because the version I have I think is
6 articulate, et cetera. However it's not titled. The
7 pages are out of order. The members are not there, et
8 cetera. That's not final, what I've seen.

9 And so anyway, we can proceed now. But I
10 wanted to make sure before we proceed that we first of
11 all understand the pieces that are going to be
12 presented to us, and the challenge we are having in
13 providing you with any comments.

14 With that proceed.

15 MS. BANERJEE: This is Maitri again. I was
16 wondering if the members may want to see the draft
17 guides in whatever form they are together with
18 reviewing the rulemaking, because otherwise reviewing
19 the rulemaking under rule language is going to be kind
20 of in a vacuum.

21 The regulatory guides might provide a
22 little bit better perspective.

23 VICE CHAIR BONACA: Well, I'll tell you, in
24 receiving the pieces that are being received for the
25 record, it takes a long time to review. And then at

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 the end, you compress that because things are
2 changing.

3 So before anything else let's understand
4 when can we expect to have some documents in a
5 finalized form. Then we can talk about reviewing
6 them.

7 MEMBER APOSTOLAKIS: But can we review
8 these documents at home?

9 MS. HOLOHAN: Guidance are OUO-SRI, so -

10 MR. MORRIS: Safety-security interface is
11 public, and the other two are OUO.

12 (Simultaneous voices)

13 MS. BANERJEE: As long as there is no SGI.

14 MR. MORRIS: No.

15 VICE CHAIR BONACA: But you want to
16 receive, George, something that is final. Again,
17 otherwise, you know you say that is the rule. So you
18 are searching for the rule, and you find there's a
19 page with four bullets, that's a rule. That's not a
20 rule. It's a space that would be contained in the
21 rule. And you don't want to spend your time on that.

22 So okay.

23 MS. SCHNETZLER: So this focuses us down to
24 the pieces that we need ACRS review in our rulemaking
25 package. And as we have discussed, it's 50.54(hh),

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 mitigative strategies, and this is basically what
2 everybody calls Brave Five Bravo. And it also
3 includes imminent threat.

4 And the draft guidance for that has not
5 been finalized. It is in production, and we're
6 anticipating completing it in about a month.

7 MEMBER APOSTOLAKIS: So that's an
8 interesting fact. Potential or actual?

9 VICE CHAIR BONACA: We could say that about
10 everything we do.

11 MEMBER APOSTOLAKIS: Why did you think you
12 can say that?

13 VICE CHAIR BONACA: I mean everything we do
14 here is with potential.

15 Potentially it's really pre-warning the
16 communication. Actually is - yes.

17 MS. SCHNETZLER: And we have technical
18 people here that are ready to jump on this.

19 CHAIR SHACK: Lou.

20 (Whereupon at 4:28 p.m. the proceeding
21 entered a Closed Session to return to
22 open session at 4:32 p.m)

23 MEMBER ABDEL-KHALIK: The determination as
24 to what is appropriate and what is inappropriate to
25 answer or question will be determined by the staff?

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 MR. GILLESPIE: NSIR is the security
2 experts for the industry, yes. If we have to go into
3 closed session we can arrange that.

4 (Remarks off the record)

5 MR. GILLESPIE: By and large we keep
6 everything open unless it needs to be closed.

7 MEMBER APOSTOLAKIS: Didn't we write a
8 letter on the digital stuff? We reviewed something?

9 MR. MORRIS: What you reviewed was part of
10 the digital INC steering committee effort in which
11 they were - and still are - a number of subgroups
12 looking at a variety of issues. And cyber security
13 was one of them. But you all took a look at the
14 interim staff guidance associated with cyber security
15 for safety related system. This rulemaking goes
16 beyond safety related.

17 MS. SCHNETZLER: So the second part of the
18 rulemaking that we need ACRS review for is 73.54,
19 protection of digital computer and communications
20 systems.

21 We do have a draft guidance, and actually
22 it's just being published today. The draft guide is
23 OVO-safety related, and we can provide you copies of
24 this. There are some control measures that need to be
25 taken with it, but we can provide those for you so you

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 can look at those and read it.

2 MEMBER APOSTOLAKIS: Are we going to have
3 this in a binder?

4 MS. BANERJEE: I can put in a CD.

5 MEMBER APOSTOLAKIS: Maybe you can do that
6 before we leave.

7 MS. BANERJEE: I will do that.

8 (Simultaneous voices)

9 MR. MORRIS: Somebody had mentioned NEI-
10 404, which as you know is the industry's program to
11 implement cyber security and nuclear power reactor
12 sites, and that came up in the context of the digital
13 IMC steering committee as well.

14 This draft reg guide recognizes and draws
15 on a lot of what is already in NEI-404, but it takes
16 it a step or two past that.

17 MEMBER APOSTOLAKIS: I guess I missed that.
18 What you are saying is that we are reviewing both the
19 rule and the corresponding guide.

20 MR. MORRIS: Correct.

21 MEMBER APOSTOLAKIS: I was wondering
22 whether we would have too little to do.

23 (Laughter)

24 MS. SCHNETZLER: The last piece of
25 regulation is 73.58, safety security interface. And

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 there is guidance with this. It has been published,
2 and it is public. It's not classified in any
3 methodology. Not controlled.

4 Next, please.

5 VICE CHAIR BONACA: Going back to the NEI-
6 0404.

7 MR. MORRIS: I'm sorry?

8 VICE CHAIR BONACA: Going back to NEI-0404,
9 there was an extra tension it seemed to me when I read
10 the NEI-0404, extra tension, and that would be really
11 the reg guide in a way. Or the reg guide would be a
12 very brief reference in the NEI-0404.

13 MR. MORRIS: Industry has, NEI in
14 particular has indicated a desire for the NRC to
15 formally endorse NEI-0404, the latest revision of NEI-
16 0404, in our regulatory guidance document.

17 What I have said to them was, we will
18 publish our own guide - because NEI-0404 is
19 specifically for power reactors. 73.54 and this reg
20 guide are not. It could be adopted by - what I said
21 was when we open this up for public comment, which
22 will be in the very near term obviously that we would
23 be willing to accept that comment or request in that
24 comment period, and we'll take it on then.

25 VICE CHAIR BONACA: Okay, I thought there

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 was some conflict there. You are telling me there is
2 complementarity.

3 MR. MORRIS: They are very complementary.
4 It's just that our guidance document is generic, it
5 doesn't specifically focus on power reactors. And it
6 goes into not just the what but the how, how to. Not
7 just what you have to do, but how to do it.

8 MEMBER ARMIJO: Would it apply to a fuel
9 facility?

10 MR. MORRIS: It could. Whatever we would
11 ultimately allow. 73.54 is silent on the type of
12 facility.

13 MS. HOLOHAN: But right now it's only upon
14 the tower reactors to probably do a separate
15 rulemaking. To do anything with the facility.

16 MS. SCHNETZLER: Right, we need a
17 conforming change to make it applicable to other
18 facilities right now.

19 MS. HOLOHAN: But the guide applies to
20 everything.

21 MS. SCHNETZLER: And basically I kind of
22 moved us, as long as we're talking about digital
23 security, I moved us to this slide just to let you
24 know that it does lay out the programmatic
25 requirements for cyber security. It treats cyber

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 security much like physical security in that you need
2 a cyber security plan. It needs to be reviewed and
3 approved by us. It's a condition of license.

4 So those things are being applied. It is
5 also tied to the piece in the DBT, the Design Basis
6 Threat, 73.1, that was issued earlier this year - last
7 year, sorry - that specifically lays out the cyber
8 threat.

9 Like I said we have just issued 5022,
10 cyber security program and that is being distributed
11 to, as it is OUO, it is being distributed to the
12 licensees.

13 MEMBER APOSTOLAKIS: So a condition of
14 licensing -

15 MR. MORRIS: Yes, essentially what we are
16 saying, we are intending to treat cyber security
17 programs in the same fashion that we treat physical
18 security, treating security officer training plans.
19 They are formally reviewed, submitted and reviewed and
20 approved, safety evaluation written, and an operating
21 license condition established for those plants. And
22 we're doing the same thing for this.

23 MEMBER APOSTOLAKIS: But my question is,
24 when this becomes the rule, the existing plants will
25 have to comply with it.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 MR. MORRIS: Exactly. Yes, no we are still
2 talking about implementation period. We are still
3 talking about the licensing mechanism to make that
4 happen. But yes.

5 MEMBER APOSTOLAKIS: why is this outside
6 1.09?

7 MR. MORRIS: 51.09?

8 MR. REED: This is a back fit, you are
9 correct. And it's a back fit that we are justifying
10 as a safety enhancement under 51.09(a)(3). We're
11 saying this is substantial additional protection of
12 public health and safety, and the costs are justified.

13 MEMBER APOSTOLAKIS: It's an added
14 protection kind of thing.

15 MR. REED: No, added protection would be
16 the top exception. If you got 51.09(3), this is the
17 classic rule where you have to go and see, okay, what
18 in fact does this do for the good side. How much
19 enhancement does this make? And then look at the
20 cost?

21 This is the classic back-fit analysis.

22 MR. MORRIS: There is more to the story
23 though. We issued cyber security requirements under
24 - by order under adequate protection after 9/11. We
25 also did a formal notice and comment rulemaking on the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 design basis threat, which we completed early last
2 year in which we added as a specific adversary
3 characteristic external cyber attack.

4 Current licensees are currently required
5 as of last April, and in fact before that when we
6 issued the DBT order back in 2003, they are required
7 today to be able to defend against an external cyber
8 attack with high assurance. That is an added
9 protection requirement.

10 What we are talking about in these rules
11 are specific programmatic elements that we believe are
12 necessary, prudent and necessary to be able to
13 demonstrate consistently that you can provide that
14 high assurance of added protection.

15 So if you look at the elements of the
16 rule, it's a very high level programmatic elements.
17 You have to do a complete digital systems inventory of
18 all the systems on your site, and determine which ones
19 are critical and which ones are not. You have to have
20 a training program. You have to have a number of
21 different programmatic elements to be able to meet the
22 design basis threat requirement, and the order
23 requirement.

24 So Tim's right, there are some specific
25 things in here that I think would arguably would fit

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 the 1.09(a)(3) kinds of things. And we put that in
2 the Federal Register notice that advanced the proposed
3 rule back in 2006. And we got comment on it, and we
4 have addressed the comments. And they are reflected
5 in the final comments language that we are about to
6 send to media.

7 MEMBER APOSTOLAKIS: But the final word is
8 we are not subjecting these to 51.09?

9 MEMBER MAYNARD: They are saying they did
10 a 51.09 evaluation.

11 MEMBER APOSTOLAKIS: They do get one? They
12 are evaluating -

13 MR. REED: Yes, we are. Scott is right,
14 it's adequate protection in the order which is in
15 place, and this goes beyond the order. So we are
16 costing this thing out. And it's substantial,
17 substantial cost on reg analysis, and we are making a
18 judgment that this one, as well as a bunch of others
19 in this entire package -

20 MEMBER APOSTOLAKIS: I understand.

21 MEMBER MAYNARD: Do these rules, other than
22 programmatic elements of changing some programs, do
23 they impose substantial additional requirements over
24 and above what came out in the orders and stuff after
25 9/11? There have been 50.54(f) orders and stuff come

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 out. I'm trying without having seen some of this
2 stuff -

3 MR. MORRIS: The answer is, in short, yes.
4 Because the order requirements that we issued were
5 very, very, very high level, and frankly, nebulous in
6 terms of the details of how to, and even the what in
7 some cases.

8 So what we are trying to do is narrow in
9 what we really meant when we issued those requirements
10 by order. To reflect what we learned over the years,
11 and what -

12 MS. SCHNETZLER: And provide a regulatory
13 framework so that you would have a document that would
14 be in place for every site, explaining how that site
15 is addressing cyber security, that is a document that
16 is a licensing document that we would review so
17 everybody has a good understanding of where we're at.

18 MR. MORRIS: Right now we - I won't go any
19 further. That's accurate. I don't need to say more.

20 MS. SCHNETZLER: Well, let's go back a
21 little bit, if you could go back to the last slide, I
22 just wanted to give ACRS an opportunity to talk a
23 little bit about 50.54(hh) which we did. It was
24 originally contained in Appendix Charley of the
25 proposed rule. We moved it to 50.54 conditions of

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 license which we have explained.

2 I just wanted to cue you that there was a
3 supplemental rule published in the Federal Register on
4 4-10-2008, some of the expansion from the proposed
5 rule was the imminent threat requirements as we've
6 discussed a little bit.

7 So we've received comments back on that,
8 and those have been incorporated into this Federal
9 Register notice that we are pulling together now.

10 So I just wanted to make you aware of
11 that. We do have guidance that is being developed,
12 and is a little further along than I expected
13 actually, and I have good news today that it should be
14 ready early next month.

15 VICE CHAIR BONACA: This is piece by piece?

16 MS. SCHNETZLER: Yes.

17 MR. MORRIS: It's two pieces, it's B-5-A
18 and B-5-B. B-5-A was an imminent attack; B-5-B is
19 now that you've been attacked what are you going to do
20 about it?

21 MS. SCHNETZLER: Right, and the guidance
22 has the required guidance for imminent threat. But it
23 also takes and puts into one guide the documentation
24 and the advisories that we had issued before on how to
25 meet Bravo-Five-Bravo and put that into a guide so

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 that we have a formal document from our agency that
2 puts it altogether.

3 Questions on that? Okay, if we could skip
4 then the next one and go to safety-security interface.

5 The safety-security interface 70.358, is
6 a requirement for coordination of security and
7 operations and other plant groups to make sure that
8 there are no adverse interactions; that something
9 security does on a regular or irregular basis doesn't
10 adversely affect operations and vice versa.

11 This also addresses in part a petition for
12 rulemaking that we received and specifically on this
13 topic we have issued guidance on this, draft guidance,
14 50.21. It was published in the Federal Register, July
15 24th, 2007. We had a public meeting in September of
16 last year. We received several comments on it, and
17 the comments are under consideration for incorporation
18 into the title and guide.

19 VICE CHAIR BONACA: A comment from NEI
20 seems to me, if I remember, is the concern that by
21 putting those check lists of questions, a la 50.59,
22 you are expanding or you are going beyond really what
23 the plants already have implemented, which seems to be
24 a problem to them at least.

25 MS. SCHNETZLER: And it's not mentioned,

1 the NEI said they were going to submit their version
2 of the safety-security guidance, and we haven't
3 received that yet.

4 MR. REED: And they, NEI actually took
5 that, I think that is what NEI did. They did not
6 actually provide a document. I don't think they are
7 going to. They, from what I could tell, they
8 translated that document into another of comments that
9 we just got here recently. And we are looking at
10 those comments in addition to the original comments.

11 But you are correct, Dr. Bonaca, that I
12 think the original concern was a concern that we were
13 imposing broad programmatic - a new broad programmatic
14 change control system to the whole facility. Clearly
15 we want them to rely on using what's there to the
16 maximum extent possible.

17 MEMBER MAYNARD: What I got out of the NEI
18 comments was, all that was being said in some of the
19 public meetings and discussions with them was
20 different from the way they were reading the draft
21 guidance documents coming out, and as to whether the
22 current programs are or are not there I think is what
23 I read -

24 MS. SCHNETZLER: And that is our intent in
25 the final guidance to clarify that and make sure that

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 the licensee can take credit for the programs that
2 they already have in place.

3 VICE CHAIR BONACA: A question I have of
4 you, do you expect one letter from the ACRS at some
5 point, or do you expect multiple letters? Because I
6 mean some of these issues, I noted this earlier, they
7 are separate. Each one of them would deserve a
8 review.

9 MEMBER APOSTOLAKIS: Well, that is up to
10 us.

11 VICE CHAIR BONACA: Yes, I understand.

12 MR. MORRIS: I guess what I would say about
13 that, and I'll let Tim comment as well, is that
14 because of the unfortunate but real time crunch that
15 we are under, I would prefer to get comments as they
16 are available as opposed to waiting until all at the
17 end when you get all your comments.

18 I don't know how that works out in a
19 practical sense, but the longer we wait unfortunately
20 the more untenable it gets.

21 MEMBER APOSTOLAKIS: I am confused now. I
22 thought the last time we were going to see these
23 things is July.

24 MR. MORRIS: That's the intent. The
25 guidance document.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 MEMBER APOSTOLAKIS: So how can we give you

2 -

3 MR. MORRIS: A week right now seems like -

4 MEMBER APOSTOLAKIS: Oh, you mean before -

5 MR. MORRIS: A week to me right now seems
6 like forever.

7 MEMBER ABDEL-KHALIK: How about comments on
8 the reg guides? I thought those can be delayed much
9 further than July?

10 MR. MORRIS: They can, absolutely.

11 VICE CHAIR BONACA: So what you need by
12 July means comments on the rulings mostly?

13 MR. REED: Yes, I think I would - if I
14 could - my preference would be if it's possible for
15 the Committee to make a decision on the requirements,
16 based on everything we can provide you in July.
17 Basically we can provide you all the pieces of the
18 roll-up package that go with those requirements, the
19 draft guides, everything that can help you to make a
20 decision why you think the requirements are adequate.
21 And then the guidance, I think that can continue on,
22 on a longer timeframe.

23 But we are trying, and the Commission is
24 obviously pushing hard, we are trying to get these
25 requirements in place in the Code of Federal

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 Regulations, okay. So that is the major goal right
2 now.

3 Implementation guidance obviously is
4 important for that in reality, so that has to be done
5 too.

6 So that's how I would - I'd love for the
7 Committee to deal with it that way, but obviously it's
8 up to the Committee to decide.

9 MEMBER MAYNARD: I understand that, and may
10 be able to do that after we see the documents. But
11 sometimes it's difficult to understand what the real
12 requirements are until you see how it's really going
13 to be implemented and what the guidance documents say.

14 MS. HOLOHAN: But we are providing you with
15 the guidance documents as they stand now, the draft
16 guidance.

17 MR. MORRIS: This has been a particularly
18 challenging exercise, not necessarily because of the
19 time pressure, but because in many cases we are trying
20 to translate what we issued by order under safeguards
21 into publicly available notice and comment language.

22 And what happens as a result is, a lot of
23 the guidance then as to move into OUO and safeguard
24 space.

25 So you are absolutely right. In many

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 cases it's very helpful to have the guidance
2 documents, although we have been very careful to
3 explain to the public and the stakeholders that having
4 the guidance document was not essential nor required
5 or necessary in order to provide meaningful comment on
6 the publicly available language.

7 So it's an interesting -

8 MEMBER CORRADINI: That is a very
9 interested description you just gave. So you'll need
10 it to understand it, but we made sure we wrote it so
11 you don't really need it.. That's kind of what you
12 just said.

13 MR. MORRIS: Well, what I'm trying to say
14 is, what I'm trying to indicate to you is that in
15 response to the comment is that the publicly available
16 rule language should and does stand on its own. What
17 we need in order to conduct sufficient licensing work
18 and ultimately write a safety evaluation that gives us
19 high assurance that they are actually able to meet the
20 language - there is a different level of information
21 that we need, and that is not information we can
22 necessarily put in the public domain. That is what we
23 are trying to say.

24 MEMBER ABDEL-KHALIK: It is quite possible
25 that you get your most insightful comments without the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 detailed guidance.

2 MS. SCHNETZLER: And I will say in the
3 whole rule package we received over 600 pages of
4 comments, and they were very detailed and very
5 insightful, and we spent a lot of staff time going
6 through those, and trying to ensure that the final
7 rule really explains to a licensee what is expected,
8 and at a level that they can understand what we need
9 to do.

10 MR. MORRIS: This is clearly not the ideal
11 way to do business, by issuing a draft guidance of the
12 final rulemaking phase. I would have much preferred
13 to issue draft guidance with the proposed rule, but it
14 didn't work out that way.

15 MS. SCHNETZLER: So that leave us with,
16 we're a rulemaking proceeding. The guidance for
17 50.54(hh) is not developed, and by that I mean really
18 not published. It is in development, and we expect to
19 have it the 1st of July.

20 The guidance for 73.58 is publicly
21 available. The guidance for 73.54 is developed and is
22 being distributed today, so we'll be able to provide
23 the Committee with copies of that as they need.

24 Then the last thing I have attached on
25 your program is the rule text itself. And this is the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 text that has not been through final concurrence yet,
2 which will happen the week of the 16th, but it's what
3 we have as of today. And that is a draft final
4 ruling.

5 VICE CHAIR BONACA: I understand. Again,
6 I saw this before. And was - now it's changed, and
7 it's not final. When do you think we will have a
8 final language of the rule?

9 MR. MORRIS: I guess when the Commission
10 SRM comes out.

11 MS. HOLOHAN: Yes, when the Commission SRM
12 comes out. But we'll have a final when it's concurred
13 on by the EDO to go to the Commission. But it won't
14 be final language until the Commission votes on it.

15 VICE CHAIR BONACA: All we can do is
16 distribute it to the members, and to the members to
17 review it. I certainly would dedicate my time to
18 that, try to see if I could also develop some thoughts
19 on how to do it definitely will help.

20 And then when we come to the July meeting
21 we will decide whether or not we have sufficient basis
22 to write a letter. With the realization again that if
23 things are still in flux they are not going to make a
24 determination, because things are changing.

25 So one item that I still need to bring up

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 is the aircraft impact rule, and the rule that goes -
2 I'd like to know on what kind of track - is it a
3 separate track that we are working on? And what's the
4 timing for our review? What are the expectations? I
5 thought that was coming in July too?

6 MS. GILLES: We have provided the ACRS with
7 a version of the rule that has been concurred in by
8 the first level of our management.

9 VICE CHAIR BONACA: Well, they have
10 actually - it's not complete. Actually paging - pages
11 that I remember directly and things of that kind.

12 MS. GILLES: I'll get with the staff,
13 because I don't believe that should be what you have.
14 So I will see if perhaps you don't have what we
15 thought you had. But yes, you should have a complete
16 Federal Register notice for the draft final rule for
17 the aircraft impact rule.

18 VICE CHAIR BONACA: So we'll need to get
19 that.

20 MS. BANERJEE: This is Maitri Banerjee
21 again. The Federal Register notice if I remember
22 right does not have the exact words of the rule. It
23 talks about - is this a supplemental notice? Oh, I'm
24 sorry.

25 MS. GILLES: No.

1 MS. BANERJEE: Okay. This is in the CD
2 that you - I think may be relevant to the members.
3 This is what it looks like.

4 MEMBER SIEBER: Could you state your name
5 for the record, please?

6 MS. GILLES: I'm sorry, Nanette Gilles,
7 Office of New Reactors.

8 MS. BANERJEE: So I will check and see what
9 you have, and bear with any error we make in copies,
10 and I'll correct it.

11 VICE CHAIR BONACA: Now and that comes to
12 the meeting of July 2?

13 MS. HOLOHAN: It is I believe scheduled for
14 the meeting in July, yes.

15 VICE CHAIR BONACA: So we would have a
16 separate letter?

17 MS. GILLES: Yes, it would be a separate
18 letter.

19 MS. HOLOHAN: But our rule is one rule,
20 three pieces of one rule. So the aircraft impact rule
21 is a separate rule. So you are really seeing two
22 rules total.

23 VICE CHAIR BONACA: Right.

24 MEMBER ABDEL-KHALIK: Well, the July
25 meeting will be closed.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 MR. MORRIS: Yes, the aircraft impact rule
2 - I mean I'm now asking a question. But it's my
3 understanding, that's more aimed at the design
4 certification applicants, whereas our rules, whereas
5 the rules we're talking about are really aimed at the
6 Combined Operating License and existing operating
7 reactor licenses.

8 So it's a little, slightly different
9 audience.

10 VICE CHAIR BONACA: But there are three
11 rules.

12 MS. SCHNETZLER: Well, three parts or
13 pieces of the one rule. So there are really two
14 separate rules.

15 MS. BANERJEE: This is Maitri again. Can
16 I ask you about the status of the comments resolution
17 package? Are they available yet?

18 MS. SCHNETZLER: For these pieces?

19 MS. BANERJEE: For these pieces.

20 (Comments off the record)

21 MR. REED: We have comment responses for
22 73.58, 50.54(hh). I don't - I'm not sure on cyber.

23 MS. SCHNETZLER: Cyber is not final yet.

24 MR. REED: Yes, and all of them, they are
25 all drafts final. I mean all those have been only at

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 the very lowest technical level. So I would be a
2 little reluctant at this point until we get some more
3 review - fortunately, the way this is going to work,
4 or unfortunately depending on your point of view,
5 since we are going to give this thing to the EDO on
6 June 30th, what we give to the Committee will have
7 been through an awful lot of review, and it won't be
8 in flux anymore, because we will have handed it off.

9 So you will have the same version that is
10 with the EDO in a sense. I know what you're going -
11 Meredith, address your concerns about things changing.
12 It will be out of our hands and with the EDO at least,
13 and maybe even with the Commission, by the time we
14 meet with you.

15 VICE CHAIR BONACA: Well, I mean as I said
16 already, we will see what comes in July. We will
17 spend the time in June to look at whatever we get.

18 MR. REED: Yes.

19 VICE CHAIR BONACA: You have to realize it
20 is very unusual. We don't normally review documents
21 unless they are finalized. And we give ourselves time
22 to review it, to have the Committee talk about it.

23 Here when you present us with this
24 information, and at the meeting we have to make a
25 decision on whether or not to write.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 MR. REED: I understand.

2 MS. HOLOHAN: But I would like to say again
3 it's not really a final rule until the Commission puts
4 it -

5 VICE CHAIR BONACA: I don't want to belabor
6 it, but you keep calling it all one rule. One of them
7 is called 50.54(hh); another one is 73.54. And then
8 there is 73 Federal Register --

9 MS. HOLOHAN: It's all part of the same
10 Federal Register notice. It's all one piece of the
11 same Federal Register notice.

12 MEMBER CORRADINI: Now what is that?

13 MR. REED: This is the current FRN.

14 MEMBER CORRADINI: So what we have is the
15 rule?

16 MR. REED: You just have three small pieces
17 of a very very big rule.

18 CHAIR SHACK: We have the rule. He has the
19 rulemaking package.

20 MR. REED: This has got section by section
21 analysis in it; substantive changes; the significant
22 comments portion of it. It's got a lot more to it,
23 but all of this stuff is, I didn't want to give that
24 to the committee at this point. Again the flux issue,
25 and reg analysis, and a lot of other things in here,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 okay.

2 The fact is this is going to be very
3 substantial, and what Bonnie was going through a
4 little earlier was trying to identify all those things
5 in the package, the biggest pieces being physical
6 security, 73.55, access authorization, 73.56, and
7 appendix B, I think those are the three biggest ones.
8 The rest of them get a little bit smaller, but they
9 are all pretty substantial when you add them together.

10 Again, back to this Committee, though,
11 this Committee only being involved with the safety-
12 security interface, 50.54(hh) and cyber.

13 So I mean we wanted to give you the whole
14 context, and that's why we call it one rule, because
15 we call it the power regs Security requirements rule.
16 So that's what Curtis is talking about. It's one
17 rulemaking.

18 VICE CHAIR BONACA: All right. So I guess
19 we will get these packages from you over the next
20 couple of weeks. And we will communicate and see how
21 we can transmit them and send them.

22 MR. GILLESPIE: I have to say, the problem
23 the staff has is the same one you have, Mario, is if
24 you change a piece of this you can go back and it can
25 affect actually your comment answers on all comments.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 So getting this too piecemeal to the
2 committee I think is just going to frustrate everyone
3 further. So I think it really is going to be far more
4 efficient to just get it from the staff when they say
5 it is in fact final. Because there is going to be
6 tier domino changes through the whole package.

7 So one small sentence change in one
8 section actually could change 30-40 pages in the rule,
9 I mean just little pieces here and there. But it'll
10 change page numbering. It'll do everything that you
11 said.

12 VICE CHAIR BONACA: You suggest that we
13 wait?

14 MR. GILLESPIE: I'd suggest that you wait.
15 Because otherwise you are going to be re-reading the
16 same material again multiple times.

17 MS. HOLOHAN: We will get it to you, I
18 think what Frank is saying, after we go through
19 concurrence before we send it back to EDO.

20 MR. GILLESPIE: Yes, we're looking at 220 -
21 250 pages of information. And just the version
22 control by sending it to each one of the members.
23 Because each time you go through a major revision.
24 I'm going to guess, Tim, once a week you probably end
25 up printing it out and rezeroing yourselves.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 MR. REED: Yes, it's pretty bad. There are
2 a lot of people doing a lot of things right now. It's
3 pretty crazy.

4 MR. GILLESPIE: So I think it's really
5 going to be more efficient for the committee to just
6 bite the bullet, get the final package that is final,
7 and really not frustrate yourself. Because it's going
8 to be, I've been through this before. There are
9 numerous little changes through it.

10 MS. SCHNETZLER: Would you like us to
11 supply the guidance that is available now, now, or as
12 a package at the end of the month?

13 MR. GILLESPIE: I think that is a good
14 questions for the committee. Is the committee willing
15 to look at the rule as a stand-alone rule much as the
16 public was asked to do, and write a letter on that,
17 and then deal with the guidance in a more orderly way
18 through the fall, because there is time to deal with
19 the guidance.

20 CHAIR SHACK: WE can get the guidance now
21 and deal with it.

22 MS. SCHNETZLER: I'm saying it is
23 available. I can make it available.

24 CHAIR SHACK: The draft guidance isn't
25 going to change between now and then. The draft reg

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 guides. Not the aircraft impact one; not the one
2 that's in preparation.

3 MR. GILLESPIE: The ones that are ready to
4 go out for public comment, or comment to the approved
5 audience.

6 MS. SCHNETZLER: So I have two guides that
7 are currently available for comment or have been
8 commented on. So I'll provide those for ACRS so you
9 can look at those. They won't change. And then the
10 very first part of next month we'll have the other
11 guide.

12 MEMBER CORRADINI: Just - I have been
13 trying to listen and not ask questions. So what you
14 waved is public, the thing you held up?

15 MR. REED: Oh, yes, this is a rulemaking
16 document, so everything here will obviously be public.
17 It will be public, of course.

18 MEMBER CORRADINI: All right, and the reg
19 guides will be in draft form still OUO, whatever you
20 call it.

21 MS. HOLOHAN: OUO, only two of them.

22 MEMBER CORRADINI: That's fine. Don't try
23 to explain it to me. I'll forget it. There's no
24 point. But in particular the rule itself is what we
25 have in front of us, and all the - I'll call it

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 justification. You used other language. All the
2 associated stuff is there. Thank you.

3 MR. MORRIS: So let me just get
4 clarification on something. So is the committee
5 interested in getting the complete package that we
6 send to the EDO, or the complete package that the EDO
7 sends to the Commission, because they could be two
8 different things?

9 MR. GILLESPIE: Traditionally on a
10 rulemaking the committee would get a complete package
11 that goes to the EDO. Normally they would get it when
12 the office director signs it out. Normally the EDO
13 does not significantly change it, and any editor
14 changes that do get made are easy to deal with.

15 MS. SCHNETZLER: We have one other person
16 here.

17 MR. RACKLEY: Bill Rackley, Office of New
18 Reactors. I did just want to clarify for the aircraft
19 impact rule. Maitri is going to give you the CD; it
20 has the draft final rule.

21 Also accompanying it will be a draft NEI
22 guidance document, NE 0713. We plan ultimately to
23 endorse, assuming we can work out the last details,
24 that in a reg guide, and we'll be coming back to the
25 ACRS for the reg guide.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 However, just to provide additional
2 information such that you could see in that particular
3 rule how it was implemented or likely to be
4 implemented, we gave you the current version of that
5 guidance. It's a work in progress; we are continuing
6 to work within NEI to do some details. But it will
7 give you a good impression of how the industry plans
8 to implement that particular assessment.

9 MS. BANERJEE: I distributed this aircraft
10 impact rule and draft guide at the last meeting. The
11 draft guide is the January version. I will give you
12 another copy with a May version if you want me to so
13 that you can destroy that one, and this is OUO also.

14 MR. GILLESPIE: A one-for-one replacement;
15 that way there is no confusion.

16 MR. ZIMMERMAN: Dr. Bonaca, if I could
17 just add one last comment. I'm Jake Zimmerman. I'm
18 from the office of NRR.

19 From a process standpoint this is clearly
20 not the way that we would like to continue doing
21 business with the ACRS as far as rulemaking, or even
22 with our external stakeholders. We would like to have
23 the proposed language and the regulatory guides
24 available simultaneously.

25 In this case we weren't able to accomplish

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 that just due to the knowledge and skills available
2 also needed to be working on these same documents.
3 And so the resources had to be carefully scheduled.

4 It is something that we have discussed
5 with the Commission on how we can do better on
6 rulemaking, and in our streamlining initiative. But
7 clearly going forward we intend to try to do a better
8 job, and I think the aircraft rule is a model now that
9 we want to continue to follow, which is to give you
10 those documents at the same time so that when there is
11 cases of high level language you will have the
12 regulatory guidance available that would show you how
13 we intend it to be implemented.

14 MS. SCHNETZLER: So I have that. I'm going
15 to, when the EDO package is final, and ready to go to
16 the EDO, we will provide that to you. But in lieu of
17 that ahead of time I will put the draft guidance on
18 disk for Maitri to distribute to everybody.

19 MEMBER ABDEL-KHALIK: Can we get that
20 before we leave?

21 MS. BANERJEE: It would be possible, if you
22 give it to me tomorrow.

23 MR. GILLESPIE: Yes, Bonnie, give her until
24 - I'm going to guess the hearing until about 11:30 to
25 12:00 on Friday. So if we can get it by Friday

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 morning, we will be all set to distribute it.

2 MS. SCHNETZLER: That would be perfect. I
3 was thinking tonight. So that's okay, thank you very
4 much.

5 (Laughter)

6 MEMBER APOSTOLAKIS: Are we done, Mr.
7 Chairman?

8 CHAIR SHACK: No, but we will go off the
9 record.

10 (Whereupon at 5:11 p.m. the proceeding in
11 the above-entitled matter was adjourned)

12

13

14

15

16

17

18

19

20

21

22

23

24

25

CERTIFICATE


This is to certify that the attached proceedings
before the United States Nuclear Regulatory Commission
in the matter of: Open Session

Name of Proceeding: Advisory Committee on
 Reactor Safeguards

Docket Number: n/a

Location: Rockville, MD

were held as herein appears, and that this is the
original transcript thereof for the file of the United
States Nuclear Regulatory Commission taken by me and,
thereafter reduced to typewriting by me or under the
direction of the court reporting company, and that the
transcript is a true and accurate record of the
foregoing proceedings.


Charles Morrison
Official Reporter
Neal R. Gross & Co., Inc.

NEAL R. GROSS
COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com



Security Rulemaking for Nuclear Power Plants

ACRS Presentation
June 4, 2008

1



Discussion Topics

- Status of Power Reactor Security Rulemaking
- Staff Draft Final Rule Text needing ACRS review
 - 50.54(hh) Imminent Attack/Mitigative Measures
 - 73.54 Cyber Security
 - 73.58 Safety/Security Interface
- Status of Regulatory Guidance

2



Security Rulemaking

- **Part 73 Power Reactor Security Rulemaking**
(proposed rule published 10/06)
 - 50.54 (hh) Mitigative Strategies and Response Procedures for Potential or Actual Aircraft Attacks
 - 73.54 Protection of Digital Computer and Communication Systems and Networks
 - 73.55 Physical Security for Power Reactors
 - 73.56 Personnel Access Authorization Requirements for Nuclear Power Plants

3



Security Rulemaking (cont.)

- **Part 73 Power Reactor Security Rulemaking**
(proposed rule published 10/06)
 - 73.58 Safety/Security Interface Requirements for Nuclear Power Plants
 - Appendix B to Part 73 – Section VI, Nuclear Power Reactor Training and Qualification for Personnel Performing Security Program Duties
 - Appendix C to Part 73 – Licensee Safeguards Contingency Plans

4



Security Rulemaking for Nuclear Power Plants

ACRS Presentation
June 4, 2008

1



Discussion Topics

- Status of Power Reactor Security Rulemaking
- Staff Draft Final Rule Text needing ACRS review
 - 50.54(hh) Imminent Attack/Mitigative Measures
 - 73.54 Cyber Security
 - 73.58 Safety/Security Interface
- Status of Regulatory Guidance

2



Status of Rulemaking

- FRN developed
- Begin formal concurrence on 6/16/2008
- Provide to EDO on 6/30/2008

5



ACRS Review for Rulemaking

- 50.54 (hh) Mitigative Strategies and Response Procedures for Potential or Actual aircraft Attacks
 - DG-50XX (July 2008)
- 73.54 Protection of Digital Computer and Communication Systems and Networks
 - DG 5022
- 73.58 Safety/Security Interface Requirements for Nuclear Power Plants
 - DG 5021 Safety/Security Interface

6



**Draft Final Rule Text for 50.54 (hh)
as of 6/4/2008**

- Mitigative Strategies and Response Procedures for Potential or Actual aircraft Attacks
 - Contained in Appendix C of proposed rule
 - Moved to 50.54, Conditions of License
 - Supplemental rule published in Federal Register 4/10/2008
 - Comments received; incorporated into FRN
- Guidance to be developed from existing advisories, information (DG 50XX)

7



**Draft Final Rule Text for 73.54
as of 6/4/2008**

- Protection of Digital Computer and Communication Systems and Networks
 - Programmatic requirements for addressing cyber security
 - Included as part of DBT 73.1 issued March 2008
- DG 5022 Cyber Security Programs for Nuclear Facilities
 - Completed 6/1/08 (OUO)
 - In process of distribution to appropriate licensees (by 6/6/2008)

8



Draft Final Rule Text for 73.58 as of 6/4/2008

- **Safety/Security Interface Requirements for Nuclear Power Plants**
 - Requires coordination of potential adverse interactions between security activities and other plant activities
 - Addresses PRM 50-80, in part
- **DG 5021 Safety/Security Interface**
 - Published in Federal Register July 24, 2007
 - Public Meeting held; comments received & under consideration

9



Summary

- Security Rulemaking proceeding
- Supporting Regulatory Guidance for 50.54(hh) not developed
- Supporting Regulatory Guidance for 73.58 and 73.54 developed and drafts published or distributed

10

SECURITY RULEMAKING

STAFF DRAFT FINAL RULE LANGUAGE

As of 6/4/2008

§ 50.54(hh) Mitigative Strategies and Response Procedures for Potential or Actual Aircraft Attacks.

- (1) Each licensee shall develop, implement and maintain procedures that describe how the licensee will address the following areas if the licensee is notified of a potential aircraft threat:
- (i) Verification of the authenticity of threat notifications;
 - (ii) Maintenance of continuous communication with threat notification sources;
 - (iii) Contacting all onsite personnel and applicable offsite response organizations;
 - (iv) Onsite actions to enhance the capability of the facility to mitigate the consequences of an aircraft impact;
 - (v) Measures to reduce visual discrimination of the site relative to its surroundings or individual buildings within the protected area;
 - (vi) Dispersal of equipment and personnel, as well as rapid entry into site protected areas for essential onsite personnel and offsite responders who are necessary to mitigate the event; and
 - (vii) Recall of site personnel.
- (2) Each licensee shall develop and implement guidance and strategies intended to maintain or restore core cooling, containment, and spent fuel pool cooling capabilities under the circumstances associated with loss of large areas of the plant due to explosions or fire, to include strategies in the following areas:
- (i) Fire fighting;
 - (ii) Operations to mitigate fuel damage; and
 - (iii) Actions to minimize radiological release.
- (3) This section does not apply to a nuclear power plant for which the certifications required under § 50.82(a) or § 52.100(a)(1) of this chapter have been submitted.

§73.54 "Protection of digital computer and communication systems and networks"

- (a) Each licensee subject to the requirements of this section shall provide high assurance that digital computer and communication systems and networks are adequately protected against cyber attacks, up to and including the design basis threat as described in Title 10 of the Code of Federal Regulations (10 CFR) Part 73, Section 73.1.
- (a)(1) The licensee shall protect digital computer and communication systems and networks associated with:
- (a)(1)(i) safety-related and important-to-safety functions,
 - (a)(1)(ii) security functions,
 - (a)(1)(iii) emergency preparedness functions, including offsite communications,
 - (a)(1)(iv) support systems and equipment which, if compromised, would adversely impact safety, security or emergency preparedness functions.
- (a)(2) The licensee shall protect the systems and networks identified in paragraph (a)(1) of this section from cyber attacks that would:
- (a)(2)(i) adversely impact the integrity or confidentiality of data and/or software;
 - (a)(2)(ii) deny access to systems, services, and/or data, and;
 - (a)(2)(iii) adversely impact the operation of systems, networks, and associated equipment.
- (b) To accomplish this, the licensee shall:
- (b)(1) analyze digital computer and communication systems and networks and identify those assets that must be protected against cyber attacks to satisfy paragraph (a) of this section,
 - (b)(2) establish, implement, and maintain a cyber security program for the protection of the assets identified in (b)(1) of this section, and;

SECURITY RULEMAKING
STAFF DRAFT FINAL RULE LANGUAGE
As of 6/4/2008

- (b)(3) incorporate the cyber security program as a component of the physical protection program.
- (c) The cyber security program must be designed to:
 - (c)(1) implement security controls to protect the assets identified by paragraph (b)(1) of this section from cyber attacks,
 - (c)(2) apply and maintain defense-in-depth protective strategies to ensure the capability to detect and respond to cyber attacks,
 - (c)(3) mitigate the adverse affects of cyber attacks, and;
 - (c)(4) ensure that the functions of protected assets identified by paragraph (b)(1) of this section are not adversely impacted due to cyber attacks.
- (d) As part of the cyber security program, the licensee shall:
 - (d)(1) ensure that appropriate facility personnel, including contractors, are aware of cyber security requirements and receive the training necessary to perform their assigned duties and responsibilities effectively.
 - (d)(2) evaluate and manage cyber risks.
 - (d)(3) ensure that modifications to assests identified by paragraph (b)(1) of this section, are evaluated prior to implementation to ensure that the cyber security performance objectives identified in (a)(1) are maintained.
- (e) The licensee shall establish, implement, and maintain a cyber security plan that implements the cyber security program requirements of this section.
 - (e)(1) The cyber security plan must describe how the requirements of this section will be implemented and must account for the site-specific conditions that affect implementation.
 - (e)(2) The cyber security plan must include measures for incident response and recovery for cyber attacks. The cyber security plan must describe how the licensee will:
 - (e)(2)(i) maintain the capability for timely detection and response to cyber attacks,
 - (e)(2)(ii) mitigate the consequences of cyber attacks,
 - (e)(2)(iii) correct exploited vulnerabilities, and;
 - (e)(2)(iv) restore affected systems, networks, and/or equipment affected by cyber attacks.
- (f) The licensee shall develop and maintain written policies and implementing procedures to implement the cyber security plan.
 - (f)(1) Policies, implementing procedures, site-specific analysis, and other supporting technical information used by the licensee need not be submitted for Commission review and approval as part of the cyber security plan; but are subject to inspection by NRC staff on a periodic basis.
- (g) The cyber security program shall be audited as a component of the physical security program and will be subject to the same requirements and controls.
- (h) The licensee shall retain records and supporting technical documentation required to satisfy the requirements of this section until the Commission terminates the license for which the records were developed, and shall maintain superseded portions of these records for at least three (3) years after the record is superseded, unless otherwise specified by the Commission.

**SECURITY RULEMAKING
STAFF DRAFT FINAL RULE LANGUAGE
As of 6/4/2008**

§ 73.58 Safety/Security Interface Requirements for Nuclear Power Reactors

(a) Each operating nuclear power reactor licensee with a license issued under part 50 or 52 of this chapter shall comply with the requirements of this section.

(a)(1) The licensee shall assess and manage the potential for adverse affects on safety and security, including the site emergency plan, before implementing changes to plant configurations, facility conditions, or security.

(a)(2) The scope of changes to be assessed and managed must include planned and emergent activities (such as, but not limited to, physical modifications, procedural changes, changes to operator actions or security assignments, maintenance activities, system reconfiguration, access modification or restrictions, and changes to the security plan and its implementation).

(b) Where potential adverse interactions are identified, the licensee shall communicate them to appropriate licensee personnel and take compensatory and/or mitigative actions to maintain safety and security under applicable Commission regulations, requirements, and license conditions.

Synthesis on the findings from the ARTIST tests on aerosol retention in the secondary side of steam generators

**Presented to the ACRS
June 4, 2008**

**M. Salay
U.S. Nuclear Regulatory Commission
Washington, D.C., USA**

Overview

- **Steam Generator Tube Ruptures (SGTR)
background and NRC interest-SGAP**
- **ARTIST test program pertaining to
SGAP**
- **Major Observations**
- **MELCOR modifications**
- **Conclusions**

Steam generator tube rupture accidents

- **Design basis event**
 - Plants designed to cope
 - Have for all events to date
- **Progresses to severe accident only if something else happens**
 - Operator error

3

Induced steam generator tube rupture


- **Induced rupture greater concern**
 - Plants operate with detectable flaws in tubes
 - Limit on flaw size
 - Stress corrosion cracking is the cause of most flaws
 - Crevice corrosion at tube support plates of concern

4

Induced steam generator tube rupture


- Heat transfer from core to primary pressure boundary weakens structures
- Vulnerable locations
 - Hot leg nozzle
 - Surge line to pressurizer
 - Steam generator tubes
- Codes do not reliably predict failure location and depressurization timing

5



Aerosol retention in SGTR SA

- at tube inlet from steam generator plenum (inlet efficiency)
- in the steam generator tube prior to reaching the tube rupture
- in the immediate vicinity of the break where particles could impact on adjacent tubes
- in tubes between one tube support plate and another
- on top of tube support plates
- on envelope by thermophoretic deposition
- in the steam separators and steam dryers at the top of the steam generator.
- at steam generator safety relief valve (inlet efficiency)



7

Aerosol retention processes

- Removal mechanisms particle size dependent
 - Laminar
 - large – impaction, settling, interception
 - small – diffusion
 - Turbulent
 - turbulent deposition
 - bounce
 - flow resuspension
 - saltation
- Removal of particles alters particle size distribution
 - maximum penetration size
 - retention of individual sections can not be simply combined to obtain overall retention
 - integral tests
 - SETs obtain individual section retention as function of size

8

Aerosol size

- **A recommendation of prototypic aerosol size based on an IRSN survey of AECL, PBF-SFD and PHÉBUS experiments:**
 - **“size distribution at SG: near-lognormal, AMMD $\sim 1\mu\text{m}$ or less, $\sigma \sim 2$; larger particles comprise agglomerates of small ($\sim 0.1\mu\text{m}$) highly coordinated clusters”**
 - **Sizes in two of the facilities were in the maximum penetration size range**
 - **Larger size range in third facility**

9

Consequences of tube rupture

- **Radionuclides vent directly to environment or to auxiliary building without any attenuation from engineered safety features in containment**
- **Accidents have sufficiently high consequences that they are risk dominant despite low probability**

10

NUREG-1150


- **Risk analysis of five US plants**
 - Two PWRs had significant probabilities of steam generator tube rupture
 - All three PWRs could suffer induced steam generator tube rupture
- **Limited modeling of aerosol behavior on secondary side of steam generators**
 - None in the Source Term Code Package
 - Data unavailable

11

NUREG-1150 expert opinion elicitation

- **Inlet efficiency from steam generator plenum to ruptured tubes – DF (mass in/mass out) ~2**
- **Retention in tubes - DF <~10 - no credit given**
 - resuspension
 - revaporization
 - agglomerate breakup
- **Retention in secondary side - DF ~4 to 6**
 - deposition on outside of tubes resisted by thermophoresis
- **No credit for steam dryer/separators**
 - proprietary design information
- **Large uncertainty in estimates**

12



Alternate retention analysis

- Industry analyses provided far different estimates of retention in the secondary side of steam generator
 - Calculated steam generator DF on the order of 10,000
 - >100 in tube, depending on break location
 - 10s secondary near break
 - 2-3 far from break

Focus on SGTR bypass accident

- **attention to SGTR bypass accidents justified by risk**
- **Direct connection between risk and source term attenuation**
- **“are safety resources being misdirected to an unneeded attention on containment bypass accidents because we underestimate attenuation”**

15


SGAP ITEM 3.3a

- **STEAM GENERATOR ACTION PLAN (SGAP) ITEM 3.3a – DEVELOP EXPERIMENTAL INFORMATION ON SOURCE TERM ATTENUATION ON THE SECONDARY SIDE OF STEAM GENERATORS**

16

ARTIST Project

- AeRosol Trapping In a Steam generator
 - International project conducted by the Paul Scherrer Institut (PSI)
 - seven phase project (NRC participated in 5)
 - separate and integral tests (38)
- retention measured:
 - in the steam generator tube prior to reaching the tube rupture (15)
 - in the immediate vicinity of the break where particles could impact on adjacent tubes (9)
 - in tubes between one tube support plate and another and on top of tube support plates (6) (1 stage, 2 stage)
 - in the steam separators and steam dryers at the top of the steam generator. (5)
 - overall with all steam generator components (3)
- Other phases (not NRC)
 - retention in flooded bundle
 - droplets in dryers and separators



ARTIST facilities

- ARTIST
 - based on Beznau plant: 365 MWe Westinghouse 2 loop PWR (1969,1972)
 - scaled for SGTR
 - 19.08 mm tube diameter
 - approx 1:20 flow area and number of tubes
- Main facility
 - shortened and narrowed bundle with U-bend tube section
 - a tube sheet
 - 3 support plates
 - full scale separator and dryer
- SET facilities
 - in tube
 - at break
 - rods far from break and support plates
 - separator and dryer


	Beznau	ARTIST
Number of tubes	3238	270 (89)*
Dryers	12	1
Separators	12	1
Bundle dia. (m)	2.68	0.57
Max tube height (m)	9	3.8 (9)**
Flow area (m ²)	3.79	0.185
Sup. plate flow area (m ²)	1.288	0.052
Bundle D _h (cm)	3.1	3.1
Total height (m)	17	10.5

*separate test section for assessing retention far from break

**in tube retention tests

Test Parameters

- Guillotine break
- Aerosol particles (composition/size)
 - TiO_2 agglomerates (AMMD 1-5 μm)
 - Degussa
 - Nanophase
 - SiO_2 spheres, $D_{50} = 0.7, 1.4, 3.7 \mu\text{m}$
 - Latex spheres, $D_{50} = 0.4 \mu\text{m}$
- Concentrations
 - 0.01 to 100s of mg/m^3
- Flow rate:
 - nitrogen (steam)
 - few 10s – several 100s kg/h
- scoping tests to determine suitable parameters precede experiments
- tests to determine experimental uncertainty



TEM micrographs: Dr. Jerry Egeland / PSI
SEM micrograph: Dr. Unto Tapper / VTT

19

Primary Measurement Methods

- Size distribution, concentration, retained mass, and DF
 - sampling at inlet, outlet, and other locations
- Size distribution:
 - Berner Impactor
 - Electrical Low Pressure Impactor
 - Optical Particle Counter
- Concentration:
 - Filter
 - Photometer
 - Optical Particle Counter
- Mass collection, concentrations with flow used to determine DF
- Flow rates at inlet and outlet and at all sampling devices, gauge pressures at inlet and outlet, gas T

20

Major observations

- **Two forms of aerosol deposition:**
 - Always a fairly uniform layer of fine aerosol on surfaces exposed to the aerosol-laden flow. "tenacious"
 - A second form of deposit noticed in some tests consists of 'clumps' of deposited material.
- **Widely varying retention in tubes**
 - from test to test
 - high retention over short periods of time
- **Resuspension can occur for deposits in tubes**
 - bounce and break-up of aerosol important
- **Large agglomerates did not survive transport at high flows**
 - uniform size distribution leaving tube
 - particles smaller than $\sim 1 \mu\text{m}$ don't break up but larger particles do
- **No major retention at rupture site**
 - Expected based on studies of rupture propagation

21

Major observations

- **Away from break, most of deposited mass on support plate**
 - May be flow recirculation at broached holes for steam generator tubes
 - May not occur for US plants with drilled tube support plates
 - Flow occurs through larger holes; jets
 - Gaps around tubes usually filled with "crud"
- **Dryer/Separator not a major source of aerosol retention even for relatively coarse aerosols**
 - Fin spacing large and little aerosol diffusion

22

Outstanding issues

- **Understanding “bounce”**
- **Understanding breakup**
 - specific to test aerosol?
- **Understanding resuspension**
 - effect of vibrations
- **Features of steam generator**
 - Thermophoretic deposition on envelope
- **Shapes and sizes of particles coming from the degrading reactor core reaching SG**


23

Changes to MELCOR

- **include a “lambda” factor based directly on the ARTIST results**
 - based on particle size
 - insufficient risk change incentive to do more in the face of other pressing work
- **monitoring 1D model being developed at Ciemat in Spain**

24

ARTIST integral test results




25

Conclusions

- Expert panel recommendations made for NUREG 1150 risk analyses by and large confirmed
- MELCOR predicts decontamination factors similar to those obtained from ARTIST data.
- Modifications made to MELCOR based on ARTIST data
- ARTIST provides experimental data on source term attenuation on the secondary side of steam generators
 - Steam Generator Action Plan (SGAP) item 3.3a complete

26



Aerosol Trapping in Steam Generator ARTIST: Findings and Potential Effects on SGTR Risk Profile

ARTIST team:

Salih Güntay, Abdel Dehbi, Steffen Danner, Ralf Kapulla,
Terttaliisa Lind, Hauke Schütt, Detlef Suckow
Paul Scherrer Institut, Switzerland

Outline

- History
- Aims of ARTIST
- ARTIST International Consortium Project
- Facility and scaling
- Model aerosol particles
- Experimental Program and results
- Conclusions
- A new SGTR risk assessment methodology and use of ARTIST data
- Final remarks

History


- Motivation and support from Utility: Large contribution of SGTR in CDF and Risk in NPP-Beznau due to excessive tube problems in 1997
- Design and Procurement: 1998-2000
- EU 5. Framework Project SGTR: 2000-2002: PSI (Vertical SG without Dryer/separator), VTT (Exp: horizontal SG), NRG, Rez, CIEMAT
- ARTIST International Consortium Project
 - Phase I: 2002-2007
 - Phase II: 2008-2011
- Potential continuation >2011: in form of Fundamental Studies (PhD), model development efforts at PSI

NRC-ACRS Meeting, June 5, 2008

June 05 2008 (3)

Aims of the ARTIST International Consortium project

- o Provide an international forum to develop new information and share among partners
- o Produce high quality data for:
 - Development of fundamental and detailed to simplified and application oriented models
 - Facilitate evaluation of effectiveness of SAM6
- o Develop methodology for SGTR Risk Assessment
 - Re-assessment of SGTR induced environmental risk
 - Provoke international consensus about the risk significance of SGTR events during DBA and SA
- o Initiate fundamental investigations in form of PhDs/Masters




NRC-ACRS Meeting, June 5, 2008

June 05 2008 (4)

ARTIST Consortium (in alphabetical order)

- o AVN (Belgium)
- o Ciemat (Spain)
- o CSN (Spain)
- o HSK (Switzerland)
- o IRSN (France)
- o JNES (Japan)
- o KK Gösigen-Däniken (Switzerland)
- o NOK, KK Beznau (Switzerland)
- o Nuclear Safety Directorate (UK)
- o Ringhals NPP (Sweden)
- o Universidad Politecnica de Madrid (Spain)
- o University of Newcastle (UK)
- o US Nuclear Regulatory Commission (USA)
- o VTT (Finland)



NRC-ACRS Meeting, June 5, 2008

June 05.2008 (5)

ARTIST Facilities



Break stage Larger scale-bundle Droplet retention Integral mock-up facility

NRC-ACRS Meeting, June 5, 2008

June 05.2008 (6)

Scaling

Design basis: Framatome 33/19 Design

- Separator: 1:1 (steel or mostly transparent)
- Dryer: 1:1 (with actual Chevron panels) (all steel or inlet transparent)
- Bundle: 264 straight tubes, height: 1:0.42, with 1:1 layout
 - Broached support plates with 1:1 layout
- Single tube length: 1:1 with smallest and medium curvatures
- Tube dimensions: 1:1

Flow rates: 40 kg/h to 800 kg/h (fully representative)

Pressure: < 5 bar in primary, ~ 1 bar secondary

Dry conditions (except 1 in-tube test with slight steam condensation)

Model Aerosol Particles

- Evaporation and Condensation generated single/multi component Particles ($\text{SnO}/\text{CsI}/\text{CsOH}$, etc) (not used for ARTIST due to high costs)
- Fluidization of mono/polydisperse powders (TiO_2 (two types), SiO_2)
- Dispersion of suspended material (Latex, SiO_2 in solution) and drying droplets
 - . Monodisperse particles (SiO_2 /Latex): well known size
 - . Polydisperse particles (TiO_2): lots of problems due to unknown surface finish characteristics affecting deposition and no size control due to de agglomeration at high velocity/sonic front

Particle Morphology and Size in PWR Hot leg

- Working group: M. Kissane (IRSN), D. Powers (SNL), M. Reeks (NC)
- Very complicated and not resolved issue since many parameters (pressure, core degradation, etc) influence
- Hot leg conditions based on Phébus and other tests
- Phébus:
 - 15-40 % control rod metals, similar amount of oxides, and rest FPs
 - implies an "onion-skin" type of structure where the kernel rich in highly refractory materials and on top condensed species of more volatile species containing cesium and rubidium and perhaps migrated into and interact chemically with the substrate
 - For practical purpose AMMD at SG inlet or in SG based on impactor data
 - 3 μm (gsd 2) at 150 °C, 1.7 μm (gsd 2) at 730 °C, 0.1 μm at 930 °C following an exponential increase along inverse temperature

ARTIST experimental program

<u>BDBA source term quantification</u>		<u>ARTIST</u>
Phase I:	In tube	15
Phase II:	Break stage	9(+2)
Phase III:	Far field	8(+2)
Phase IV:	Separator&dryer	5
Phase V:	Flooded bundle	2(+3)
Phase VII:	Integral mock-up	3
Total		42(+7)

DBA source term quantification


Phase VI: Droplets (in separator & dryer) yes

(x): EU-SGTR

Phase I, In-tube retention (1:3)

o 15 tests


- 225 - 364 kg/h, with pressure ratio of 3.5:1
- Straight tube and
- U-tube with two bend diameters (83 and 384 mm)
- Dry conditions, except 1 test with slight steam condensation
- Mono/Polydisperse particles
- Very low to modest concentrations



NRC-ACRS Meeting, June 5, 2008

June 05.2008 (11)

Phase I, In-tube retention (2:3)



- 2*9 m with 83.2 mm curvature
- 70 -240 m/s velocity in Tube
- Dry TiO_2 (2-3 μm inlet/<1 μm outlet)


- Very dynamic aerosol processes (turbulent deposition/resuspension, de-agglomeration of TiO_2)
- Challenge for modeling (PhD Pamela Longmire/SNL)
- Effect on flow re-distribution among intact tubes in inlet plenum

NRC-ACRS Meeting, June 5, 2008

June 05.2008 (12)


Phase I, In-tube retention (2:3)

DF	Conc.	Particles
< 65	medium	SiO ₂
1.0 - 2.2	medium	TiO ₂
8.2	Slight steam cond.	TiO ₂
< 100	very low	SiO ₂ , latex




Aerosol (SiO₂) fragments collected in the outlet plenum

NRC-ACRS Meeting, June 5, 2008



June 05.2008 (13)

Phase II: Break-Stage Retention: Dry conditions (1:6)



➤ Choked flow at the break

➤ Guillotine Break

➤ Dry conditions

9 tests

- 360 kg/h,
- Monodisperse SiO₂ particles
- AMMD: 1.4 to 3.8 μm

2 tests with full bundle


- 600 kg/h
- Polydisperse TiO₂ particles
- AMMD: 2.3 μm before break

NRC-ACRS Meeting, June 5, 2008

June 05.2008 (14)

Phase II: Break-Stage Retention: Velocity profiles (2:6)

Measured velocity profile: Guillotine Break, 360 kg/h




➤ Very 3D flow

NRC-ACRS Meeting, June 5, 2008

June 05.2008 (15)

Phase II: Break-Stage Retention: Velocity profiles (3:6)



- Measured velocity profile
- FLUENT Simulations by Ringhals/EPISILON
- with $k-\epsilon$
- with Reynolds Stress Model (RSM)

NRC-ACRS Meeting, June 5, 2008

June 05.2008 (16)

Phase II, Break stage (4:6): Aerosol material type dependent local deposition pattern



TiO₂, Dae = 2.3 μm




SiO₂, Dae = 1.4 μm



SiO₂, Dae = 3.7 μm

➤ Flow rate: 600 kg/h for TiO₂, 360 kg/h for SiO₂ tests



Phase II, Break stage (5:6): Deposition pattern



Tube to tube aerosol deposition profile (SiO₂, 3.8 μm)


Phase II, Break stage (6:6): Retention

- o Highest retention potential among other retention stages
- o Decontamination Factor =
 - increases with increasing inlet concentration
 - increases with increasing D_p



Phase III, Far field stage (1:1)

- o 8 (+2 EU-SGTR) tests
- o Mass flow rate 33 & 105 kg/h
- o TiO_2 : deposition everywhere
- o Collected mass on certain tubes indicates roughly constant DF per stage
- o SiO_2 : mostly on support plates
- o SiO_2 (d_{pm} 3.7 μm) DF: ~1.07
- o DF might be higher at higher inlet concentration




TiO₂ Bundle test

SiO₂ Far field stage test


Phase IV: Separator & Dryer (1:2)

- o 5 tests (2 only separator)
- o Mass flow rate 100, 360 and 650 kg/h
- o Local turbulence initiated agglomeration and hence sedimentation
- o Decontamination Factor

DF	Particles	D_{ae}
1.2 - 1.4	TiO ₂	3 μm , aggl.
1.5 - 1.6	SiO ₂	integral mock-up



Aerosol collected in Condensate collector below the panels



NRC-ACRS Meeting, June 5, 2008

June 05.2008 (21)


Phase VII: Integral mock-up tests

Aim: verify consistency of separate effect data at certain conditions

Decontamination Factor =

- Consistent with Break Stage Tests
- DF increases with concentration
- DF increases with particle size

Effect of model aerosol particle material/surface treatment



NRC-ACRS Meeting, June 5, 2008

June 05.2008 (22)

Conclusions #1, aerosol tests

- o **In-tube retention**
 - o Dynamic, depends on particle size and concentration
 - o Steam condensation increases DF significantly
 - => the effect of particle concentration?
 - => the effect of bounce/resuspension?
- o **Retention largest in the break stage**
 - o Depends on particle size and concentration
 - => the effect of particle concentration?
 - => fish-mouth break leading to higher gas/particle momentum and deeper penetration in Bundle?
 - => data with minimized bounce/resuspension needed for modeling

Conclusions #2, aerosol tests

- o **Retention in the far field**
 - => the effect of particle concentration?
 - => Effect of aerosol composition?
- o **Retention in the flooded bundle**
 - => High DF (50 - 2000) with submersion 1.2 - 3.8 m
 - => retention close to the break (?) with smaller submersion
- o **Retention in Separator & Dryer**
 - => ~ 30-40 % of incoming mass retained independent of Flow Rate
- o **Retention in the integral mock-up facility**
 - o Dominated by retention in the break stage
 - o Consistency of separate effect data demonstrated


Transport/Removal of Activity in Steam Generator

- SGTR concurrent with core damage involves:
 - Major activity in vapour form at SG inlet
 - Rest of activity and inactive material in aerosol form
- Transformation of activity in vapour form by vapour condensation dependent on local temperature
- Removal of some fraction of vapour by condensation on structure surface
- Transport/removal of Rest of vapour of condensed on particles or form new particles dependent on aerosol removal/transport process

ARTIST addresses only aerosol removal/transport process in SG

Motivation for a new SGTR risk assessment methodology

- MELCOR contains models for vapor/aerosol behavior but lacks specific aerosol transport/removal in SG complex structures at relevant thermal-hydraulic conditions
- For risk assessment with many hundred variations to consider uncertainties: MELCOR is too expensive
- A fast running lump parameter model including Monte-Carlo sampling for uncertainties under development
- Preliminary sample analysis demonstrates the strength and provides feasibility of SGTR risk reduction



A new SGTR risk assessment methodology

- Lump Parameter Model tracking vapor/aerosol phases in each release path in SG secondary side with:
 - T/H and Vapor/aerosol boundary conditions and uncertainties from SA code predictions
 - Temperature dependent ultimate particle size based on Phébus tests
 - Temperature dependent vapor fractions of released classes including all species from SOPHAEROS code (IRSN/FR) analysis
 - Release path dependent ARTIST DFs (d_p , c)
- Monte-Carlo sampling for all uncertainties
- APET for all SGTR sequences
- Running Model for each APET branches for determination of risk

NRC-ACRS Meeting, June 5, 2008

June 05 2008 (27)




Lump Parameter Model: Key Aspects

- Accounts for aerosol behavior in complex structures of SG at hydrodynamic conditions by use of ARTIST data for each SG retention stage
- Accounts for vapor conversation using temperature dependent vapor fraction data base generated from SOPHAEROS code runs
- Accounts for vapor fraction condensed on structure and converted to particles by user input including its uncertainty
- Accounts for temperature dependent aerosol size determined by measured sizes in hot leg in all Phébus tests with AgInCd
- Neglects other processes playing a secondary role: thermophoresis, diffusiophoresis,...

NRC-ACRS Meeting, June 5, 2008

June 05 2008 (28)

Lump Parameter Model Description



$$\dot{m}_2 = \frac{1 - x_1(1 - \alpha)}{DF_a - x_2(DF_a - \alpha)} \dot{m}_1$$

α : Vapour split fraction on walls/
particles = 0.5 (0.1-0.9)

DFa: ARTIST DF

m: mass flow of release class (I, Cs, ..)


X: vapor fraction of the mass flow

T: Gas temperature


1: donor volume

2: current volume

Lump Parameter Model Data Base (1:3)




Vapor fraction data base
generated from SOPHAEROS
code runs



Particle size as measured in all
Phébus tests with AgInCd

Lump Parameter Model Data Base (2:3)



ARTIST Break Stage Particle Size Dependent DF

NRC-ACRS Meeting, June 5, 2008

June 05 2008 (31)

Lump Parameter Model Data Base (3:3)


Retention Stage	DF	Error Factor	Source
Reactor vessel	1.2 (I), 1.8 (Cs)	1.06 (I), 1.04 (Cs)	Phébus
Primary circuit	1.1 (I), 1.2 (Cs)	1.09 (I), 1.2 (Cs)	Expert judgment
In-tube retention	Time variant	1.5	ARTIST
Break stage	Aerosol-size variant	1.5	ARTIST
Far-field stage I-VII	1.05	1.21	ARTIST
Top of shroud	1.20	1.09	Expert judgment
Separator	1.20	1.06	ARTIST
Recirculation	Model	Model	MELCOR, SR5
Downcomer	1.10	1.05	Expert judgment
Intra-volume	1.10	1.07	Expert judgment
Dryer	1.20	1.09	ARTIST
Dome	1.10	1.05	ARTIST

NRC-ACRS Meeting, June 5, 2008

June 05 2008 (32)

Multiple SA Code Analyses for Model Uncertainties for the same APET Branch

SGTR Frequency	Category	Rupture Size	Rupture Location		Accident Mitigation		
	No SA-Induced SGTR	No Multiple-Tubes	No U-Bend Rupture	No Cold-Leg Rupture	No Reclosed RV	No Refilled SG	
Node A	B	C	D	E	F	G	H




NRC-ACRS Meeting, June 5, 2008

June 05 2008 (33)

Retention Stages from Core to SG Steam Outlet

- For each APET sequence, consider a series of retention stages in the fission product release path from the core to the environment
- For retention stages of the SG, the lumped parameter model is used



NRC-ACRS Meeting, June 5, 2008

June 05 2008 (34)

Multiple SA Code Results: An example

Temperature predictions from MELCOR and SCDAP/RELAP5

Running multiple cases to estimate the temperature distribution

- S6TR sequence from NPP - Beznau PSA L2

- SRV stuck-open at the affected SG
- SRV opened manually at the intact SG
at core exit temperature > 923K

- Calculation stops at lower head failure


(a) MELCOR

(b) SR5, $\Delta t = 0.1$



SCDAP/RELAP5, max. time step = 0.1s

(c) SR5, $\Delta t = 0.01$


SCDAP/RELAP5, max. time step = 0.01s




Monte-Carlo Simulation: Examples of 90% confidence interval of Particle Diameter and Decontamination Factor in Break Stage



Presentation not given.



Only slide referred to →




Assessment of Methodology (1:2)

- MELCOR 1.8.6 runs for point estimates of source term
 - use of ARTIST data through „filter function“
 - Superimposing user input „aerosol size“ to overwrite MAEROS
- Three MELCOR runs
 - Standard MELCOR 1.8.6 for the same SGTR sequence
 - MELCOR 1.8.6 with ARTIST DFs
 - MELCOR 1.8.6 with ARTIST DFs + PHÉBUS inferred temperature dependent particle size

With MELCOR default vapor and aerosol physics


Assessment of Methodology (1:2)

Comparison of PSI-Risk Model Results to MELCOR Point Value Estimates



APET: branching fractions

SGTR Frequency	Category	Rupture Size	Rupture Location		Accident Mitigation		
	No SA-induced SGTR	No Multiple-Tubes	No U-Bend Rupture	No Cold-Leg Rupture	No Reclosed RV	No Refilled SG	
Node A	B	C	D	E	F	G	H




NRC-ACRS Meeting, June 5, 2008

June 05.2008 (41)

Preliminary Risk Profile of NPP-Beznau Spontaneous SGTR

Comparison of the SGTR (without SG Reflooding) Risk significance to
other internal initiating events for the Beznau NPP



NPP Beznau: PSA L2 BERA: 2002

NRC-ACRS Meeting, June 5, 2008

June 05.2008 (42)

Conclusions

- Methodology consistent with Point values from MELCOR
- Further development for inclusion of other dependencies and their uncertainties (e.g., DF (dp, ϵ))
- Generic model requires user to input from plant specific SA analysis
- APET to be revised with plant specific information (frequencies, split fractions)

Final Remarks

- PSI data supported by additional data from CIEMAT (Spain) for break stage retention and from VTT (Finland) for in-tube deposition/resuspension, both at low flows
- CFD Simulations of flow¹ and particles² by CFD (FLUENT) by Ringhals, AVN¹, CIEMAT¹, JNES^{1,2} and NRC^{1,2} (Sandia)
- Model development for aerosol removal in flooded bundle (IRSN) and in break stage (CIEMAT)
- 4 PhDs (de-agglomeration, aerosol motion through DNS+LES, bubble hydrodynamics in bundle) at PSI
- 3 PhDs (removal in far field, break stage hydrodynamics, aerosols) at UPM and CIEMAT
- 1 PhD (particle motion in SG pipe) at Sandia
- 1 masters (flow fields by CFD in Separator) at AVN
 - with involvement of 7 Universities

PSI thanks for all supporting and participating organizations in ARTIST


Phases V and VI: Flooded Bundle and Droplet Retention in Separator & Dryer

NRC does not participate in ARTIST Project Phases V and VI, however, the following information is introduced for those in ACRS who have interest in the Aerosol Scrubbing in Bundle Environment from High Jet Flows and Dissolved Activity (Iodine, mostly) Retention/Release by Droplets during the initiation of a SGTR event

Phase V: retention in the flooded bundle (1:2)


- o 2 tests (+3 EU-SGTR)
- o Decontamination Factor
- o Determined for relatively large submersion

DF	flow rate	submersion
2 100	45 kg/h	3.8 m
335	640 kg/h	3.2 m



Phase V: retention in the flooded bundle (2:2)

- o Very high DF due to bundle-hydrodynamic interactions, especially at the break; models not able to reproduce DF
- o Aerosol removal in hot pools without bundle: ~ DF 20 (PSI - POSEIDON, 1991- 1996)



tests	Main features	Submergence m	Experimental DF	PSN Model DF
A82	Steam, hot, medium flow rate	1.3	88-100	362
A83	NC, cold, low flow rate	1.2	134	37
		2.3	1291	64
		3.6	6739	69
E84	NC, cold, low flow rate	3.60	2897	46
E86	NC, cold, high flow rate	3.20	271-486	67

NRC-ACRS Meeting, June 5, 2008

June 05.2008 (47)


Iodine Source Term during Steam Generator Tube Rupture Initiated Design Basis Accidents: Introduction

- o Spontaneous or initiated Steam Generator Tube Rupture
 - => activity release until the operators can reduce the RCS pressure to the secondary side level
 - => activity release at least 30-40 minutes (so-called "grace period")
 - o SGTR event is a design basis event
 - o The amount of activity release controlled by:
 - a) amount of dissolved activity in the primary system (leaking rods, iodine spiking (reactor trip) and pressure change)
 - b) the submergence of the leak; single or multiple tube ruptures; total break flow
 - c) pH and iodine chemistry in the secondary side
 - d) iodine mass transfer from the boiling pool
 - e) The break at the tube bend
 - <= 80-85 % of primary water in droplet form as a result of flashing
 - => efficiency of separator and dryer to retain droplets
- ➔ ARTIST - Phase VI

NRC-ACRS Meeting, June 5, 2008

June 05.2008 (48)

Phase VI: Droplet retention in Separator and Dryer






- Non-evaporating DEHS as droplet medium
- Spraying DEHS producing droplets
- Constant gas flow (10-800 kg/h)
- Known droplet inlet flux
- Known droplet size distribution at inlet (AMMD 10-50 μ m)
- LDA, PDA, PIV
- Liquid Collection for DF


NRC-ACRS Meeting, June 5, 2008

June 05.2008 (49)

Flow velocity distribution



Mean axial velocity




Mean transverse velocity

NRC-ACRS Meeting, June 5, 2008

June 05.2008 (50)

JNES FLUENT Simulations




- RSM turbulence model much better than $k-\epsilon$ model for rotating flow.
- Mesh resolution at lid controls quality of velocity profile above Lid plane
- Importance of adequate resolution of wall boundary layer

NRC-ACRS Meeting, June 5, 2008

June 05.2008 (51)

Integral retention across the separator & dryer




NRC-ACRS Meeting, June 5, 2008

June 05.2008 (52)


```

graph TD
    A[3D flow simulation at whole separator & dryer] --> B[Velocity field]
    A --> C[Inlet velocities]
    B --> D[3D aerosol tracking at separator & dryer]
    C --> E[2D flow simulation at chevron vane]
    E --> F[2D aerosol tracking at chevron vane]
    F --> G[Integration with velocities]
    D --> H[Aerosol deposition at whole separator & dryer]
    G --> H
  
```



NRC-ACRS Meeting, June 5, 2008

June 05, 2008 (53)

DF (300kg/h)

	1 μm	3 μm	10 μm
Separator	1.25	1.32	1.35
Dryer	1.09	1.14	1.25
Total	1.36	1.51	1.68

- Capturing hydrodynamic behavior is crucial prerequisite for aerosol behavior
- PSI discrete-particle tracing considers particle turbulence based on DNS simulations
- JNES predicted Overall retention is in agreement with Phase IV test results

NRC-ACRS Meeting, June 5, 2008

June 05.2008 (54)



Standardization of Operational Event Risk Assessments

Marty Stutzke
Senior Technical Advisor for PRA Technologies
Division of Risk Analysis
Office of Nuclear Regulatory Research

June 4, 2008

Presentation Outline

- Purpose
- Background
- Concepts of operational event risk assessment
- Implementation of standardization tasks
- Ongoing and future work
- Conclusions

Purpose

- To describe the activities undertaken by RES and NRR to standardize the risk assessment of operational events.
- To provide background to findings in draft NUREG-1635, Vol. 8, “Review and Evaluation of the Nuclear Regulatory Commission Safety Research Program,” Chapter 10, “Operational Experience.”
- To summarize the status of completed and ongoing RES activities in support of the standardization of operational event risk assessments.

Background

- In 2004, the staff initiated the Risk Assessment Standardization Project (RASP) as a collaborative effort between NRR, RES, and regional Senior Reactor Analysts (SRAs).
- The purpose of RASP is to provide consistent methods for risk analysis of conditions in the ASP and SDP Phase 3 programs and the risk analysis of events/conditions in the ASP and MD 8.3 programs, while recognizing differences in purpose among the programs.

Risk Assessment of Operational Events at NRC

- ***Significance Determination Process (SDP)***: Risk analysis of inspection findings (e.g., conditions with performance deficiencies) to determine the safety significance of inspection findings. (Regions, NRR)
- ***NRC Incident Investigation Program (MD 8.3)***: Risk analysis of initiating events and conditions to determine the appropriate level of reactive inspection in response to a significant event. (Regions, NRR)
- ***Accident Sequence Precursor (ASP) Program***: Risk analysis of initiating events and conditions to identify significant precursors, adverse trends, and insights. (RES)

Event Risk Assessment – Introduction

- The aim of event risk assessment is to identify what else could have happened in an incident, which did not necessarily happen during the incident, and that would lead to core damage.
- The event risk assessment is *future-oriented*
 - What is probability that a similar event, occurring in the future, would lead to core damage?

Event Risk Assessment – Basic Concepts

- The figures of merit are conditional core damage probability (CCDP) for initiating events and change in core damage probability (Δ CDP) for degraded conditions.
 - The CCDP given the event and the nominal or adjusted failure probabilities of the components and operator actions that did not fail, yields a measure of how close we came to core damage.
- The “failure memory concept”
 - All *failures* observed in the event are modeled as failures in the risk analysis:
 - Basic events representing failed components and operator actions are modeled as failed (e.g., with TRUE house events).
 - System and operator action *successes* receive a different treatment:
 - Basic events representing successes are ignored (i.e., successes are not set to FALSE house events).
 - These basic events remain at their nominal failure probability, or adjusted to represent complications observed during the event.

Standardization Approach

- Document methods and guides for event risk analysis
 - Internal event analysis
 - External event analysis, including internal fire and flood events
 - Low-power/shutdown (LP/SD) event analysis
 - Large early release frequency (LERF) calculation
- Improve SPAR model fidelity
 - Enhance Rev. 3 internal events SPAR models to better reflect the risk of the as-built, as-operated plant
 - SPAR models for external events, shutdown events, and LERF/Level 2
- Enhance analysis methods; provide technical support

User Need Tasks for RES

- Task 1: Develop guides for the analysis of internal events during power operations.
- Task 2: Develop new methods and guides for the analysis of the following events:
 - External events, including internal fire and flood
 - Internal events during low-power and shutdown (LP/SD) operations
 - Calculation of large early release frequency (LERF) for containment-related events
- Task 3: Make enhancements to SPAR models and SAPHIRE/GEM code
- Task 4: Provide ongoing technical support.

Tasks 1 & 2 – Guides for Event Risk Analysis

- RASP handbook (Rev. 1) issued January 2008 (publically available):
 - Volume 1, Internal Events (ML080070303)
 - Volume 2, External Events (ML080300179)
 - Volume 3, SPAR Model Reviews (ML080300182)
- Volumes 1 and 2 based on existing methods used in previous SDP and ASP analyses; Vol. 3 based in part on PRA Review Guide (NUREG/CR-3485) and PRA Standard (ASME RA-Sb-2005).
- Inspection Manual Chapter (IMC) 0609, “Significance Determination Process,” references use of handbook.
- Internal reviews by NRC and contractor staffs; Rev. 0 of Vols. 1 and 2 been in trial use for 2 to 3 years.

Task 3 – SPAR Model Development

- Internal events models:
 - Detailed cut-set-level reviews against most licensee's PRAs
 - Updates to station blackout/loss of offsite power models
 - Updates to SPAR model parameters based on NUREG/CR-6928¹
 - Updates to SPAR model QA plan for Rev. 3 SPAR models
 - Other enhancements based on staff and licensee feedback
- External events models: 15 integrated Rev. 3 SPAR models
- Shutdown events models: 5 integrated Rev. 3 SPAR models
- LERF/Level II models: 2 preliminary Level II SPAR models


¹. NUREG/CR-6928, "Industry-Average Performance for Components and Initiating Events at U.S. Commercial Nuclear Power Plants," February 2007 (<http://www.nrc.gov/reading-rm/doc-collections/nuregs/contract/cr6928/>)

Task 3 – SAPHIRE and GEM

- A new version of SAPHIRE code being developed to meet requirements for:
 - New user interface for conducting SDP Phase 2 assessments
 - Improved user interface for conducting SDP Phase 3 and ASP analyses
 - Improved features and capabilities for SPAR model development and use (e.g., LERF modeling approach, support integrated models)
 - New modeling and calculation methods (e.g., common-cause failure analysis, phase mission time analysis)
- Beta testing and peer review to be performed during 2008 and 2009 to support release of SAPHIRE Version 8 by end of 2009.

Task 4 – RES Technical Support

- Technical support provided to NRR analysts and Senior Reactor Analysts on methods, models, and analysis.
- Training provided at SRA counterpart meetings.
- Areas of support for event risk analysis include:
 - Common-cause failure modeling, parameter estimation
 - HRA and simplified expert elicitation applications
 - Uncertainty and sensitivity analyses
 - Internal event analysis guidance and SPAR model application
 - External event analysis guidance and SPAR model application
 - LP/SD event analysis guidance and SPAR model application
 - LERF calculation guidance
 - SAPHIRE/GEM code
- RASP Tool Box Web page developed for analysts.



Ongoing and Future Work – Methods and Guides

- RASP Handbook
 - Complete Volume 1: Guides for CCF modeling, parameter estimation and updates, uncertainty/sensitivity analysis, HRA, simplified expert elicitation, convolution analysis).
 - Revise Volumes 1, 2, and 3 based on user feedback.
 - Develop new volume for analysis of LP/SD events.
 - Develop new volume for LERF analysis of containment events.
- Technical support
 - Enhance methods
 - CCF methodology for event assessment (draft NUREG/CR)
 - HRA (based on results of international HRA benchmarking project)
 - Update pipe break LOCA frequencies (draft NUREG/CR)
 - Provide training support.
 - Provide on-call SDP analysis assistance.

Ongoing and Future Work – SPAR Models

- Internal events SPAR model enhancements
 - Success criteria re-evaluation of key sequences based on thermal hydraulic analyses.
 - Work with industry to resolve key technical issues affecting SPAR and licensee PRA models (through NRC/EPRI Memorandum of Understanding).
 - Complete detailed cut-set-level reviews for 4 remaining models.
- Shutdown SPAR model development
 - Continue model development for shutdown events.
- SAPHIRE/GEM Version 8 development
 - Complete beta testing.

Conclusions

- RASP handbook widely in use by risk analysts and SRAs in the risk analysis of operational events in NRC programs:
 - Conditions in the ASP and SDP Phase 3 programs
 - Initiating events and conditions in the ASP and MD 8.3 programs
- ASP Program changed to eliminate duplicative analysis of SDP inspection findings.
- Communications and documented guidance improved consistency among analysts and enhanced knowledge transfer.
- Enhanced SPAR models better reflect the risk of the as-built, as-operated plant.



Backup Slides

Past Briefings to the ACRS (Full and Subcommittees) on RES Risk Activities

- SPAR model development (10/10/2003)
 - Internal events (9/9/2005, 9/15/2005, 11/17/2005)
 - External events, including internal fire and flooding (11/18/2005)
 - shutdown event (11/11/2002, 10/10/2003, 11/18/2005)
 - Large early release frequency (LERF) (11/18/2005)
- SAPHIRE development (1/25/2002, 10/10/2003)
- Risk methods and databases
 - SPAR-H human reliability analysis method (10/09/2003, 12/15/2005, 3/22/2007)
 - Common-cause failure method, RADS/EPIX (12/15/1999, 04/6/2000)
 - Uncertainty (10/10/2003, 11/16/2004, 12/19/2007)
- Accident Sequence Precursor (ASP) Program (12/15/1999, 3/10/2006)

NRR User Need Requests

- “User Need Request for Support in the Development of Standard Procedures and Methods for Risk Assessments of Inspection Findings and Reactor Incidents,” J. Dyer Memo to A. Thadani, February 17, 2004 (NRR-2004-005)
 - Task 1: Guides for risk analysis of internal events
 - Task 2: Guides for risk analysis of external events, LP/SD, and LERF
 - Task 3: SPAR model and SAPHIRE/GEM enhancements
 - Task 4: Technical support (methods, models, SDP analyses, handbook updates)
- “Supplement to User Need Request for Support in the Development of Standard Procedures and Methods for Risk Assessments of Inspection Findings and Reactor Incidents,” Dyer Memo to B. Sheron, June 22, 2006 (NRR-2004-005)
 - Initiating event fault trees for cooling water systems (e.g. service water)
 - Revised models of success criteria for specific sequences using thermal hydraulic analyses

NRC/EPRI MOU

- **SPAR model/industry PRA key technical issues:**
 - Support system initiating event analysis
 - Treatment of loss of offsite power
 - Standard guidance for event tree development
 - Treatment of injection following containment failure (BWRs)
 - Treatment of containment sump recirculation during small and very small loss of coolant accident
 - Human reliability analysis dependencies and recovery modeling issues
- **Other NRC/industry technical issues:**
 - Treatment of uncertainty in risk analyses
 - Aggregation of risk metrics
 - Human reliability analysis
 - Digital instrumentation & control risk methods
 - Advanced reactor PRA methods

RASP Tool Box Web Page


- <http://www.internal.nrc.gov/RES/RASP/index.html>
(*Internal to NRC*)
- Provide web links to tools and access to references for Senior Reactor Analysts and risk analysts, e.g.,
 - RASP handbook volumes
 - Handbook references
 - SPAR models
 - SAPHIRE/GEM codes and manuals
 - Parameter estimation references (NUREG/CRs)
 - Databases and calculators (ASP, CCF, EPIX, LERs, RADS)
 - Plant information
 - PRA training manuals
 - PRA related references (NUREG/CRs)
- RASP Handbook kept current in the Tool Box.

Point-of-Contacts

- Accident Sequence Precursor Program: Chris Hunter (RES/DRA)
- RASP Handbooks
 - Vol. 1, Internal Event Analysis: See-Meng Wong (NRR/DRA), Don Marksberry (RES/DRA), Paul Bonnett (NRR/DIRS)
 - Vol. 2, External Event Analysis: Selim Sancaktar (RES/DRA)
 - Vol. 3, SPAR Model Reviews: Pete Appignani (RES/DRA)
- Risk Analysis Methods for Event Risk Analysis
 - CCF, parameter estimation, and RADS and CCF calculators: Jack Foster (RES/DRA)
 - SPAR-H HRA enhancements: Pete Appignani (RES/DRA)
 - Uncertainty/sensitivity analysis, simplified expert elicitation: Gary DeMoss (RES/DRA)
- Risk Databases (EPIX, LER, RADS, CCF): Bennett Brady (RES/DRA)
- SAPHIRE/SDP User Interface: Dan O'Neal (RES/DRA)
- Significant Determination Process: Paul Bonnett (NRR/DIRS)
- SPAR Models: Pete Appignani (RES/DRA)
- SPAR Model Success Criteria Re-Evaluation: Rick Sherry (RES/DRA)

Abbreviations

• ASP	accident sequence precursor
• CCDP	conditional core damage probability
• CCF	common-cause failure
• EPIX	Equipment Performance and Information Exchange System
• EPRI	Electric Power Research Institute
• GEM	Graphical Evaluation Module
• HRA	human reliability analysis
• LER	Licensee Event Report
• LERF	large early release frequency
• LP/SD	Low-power/shutdown
• MD	Management Directive
• NRR	Office of Nuclear Reactor Regulation
• NRR/DIRS	Division of Inspection and Regional Support, NRR
• NRR/DRA	Division of Risk Assessment, NRR
• PRA	probabilistic risk assessment
• QA	quality assurance
• RADS	Reliability and Availability Data System
• RASP	Risk Assessment Standardization Project
• RES	Office of Nuclear Regulatory Research
• RES/DRA	Division of Risk Analysis, RES
• SAPHIRE	System Analysis Programs for Hands-on Integrated Reliability Evaluations
• SDP	Significance Determination Process
• SPAR	Standardized Plant Analysis Risk (model)
• SRA	Senior Reactor Analyst



U.S. NRC

UNITED STATES NUCLEAR REGULATORY COMMISSION

Protecting People and the Environment

**U.S. EPR OVERVIEW
PRESENTATION
553rd ACRS MEETING**

JUNE 4, 2008

Getachew Tesfaye



EPR Project Background

- Three years of pre-application activities: December 2, 2004 to December 11, 2007
 - Several public meetings were held to familiarize the NRC staff with the EPR design
 - 15 topical reports and 4 technical reports were submitted in preparation for the design certification application



AREVA EPR Design Certification

- **Application submitted: December 11, 2007**
- **Accepted for review: February 25, 2008**
- **Review schedule issued: March 26, 2008**
- **Currently in Phase 1 review**
- **Review Milestones:**
 - Phase 1, PSER and RAI
 - Target date for completion 1/29/2009
 - Phase 2, SER with open items
 - Target date for completion 11/20/2009
 - Phase 3, ACRS review of SER with open items
 - Target date for completion 3/05/2010
 - Phase 4, Advanced SER with no open items
 - Target date for completion 11/2010
 - Phase 5, ACRS review of advanced SER with no open items
 - Target date for completion 03/2011
 - Phase 6, Final SER with no open items
 - Target date for completion 05/2011



COL Applications Referencing EPR

- R-COLA
 - Calvert Cliffs COL Application
 - Part I – Environmental review
 - Submitted July 13, 2007
 - Docketed January 25, 2008
 - Currently in Phase 1 review
 - Part II – Balance of the COL Application
 - Submitted March 14, 2008
 - Docketed June 3, 2008
 - Currently review schedule is being developed
- S-COLA planned submittals
 - AmerenUE, Callaway Plant Unit 2: August 4, 2008
 - PPL, Bell Bend: September 2008
 - UniStar/Constellation, Nine Mile Point: September 2008
 - UniStar/Amarillo Power, site TBD: 4Q 2009
 - Alternate Energy Holdings, Bruneau, ID: TBD




ACRS Meeting: U.S. EPR Design Overview

June 4, 2008



AREVA NP, INC.

ACRS Meeting 4 June 2008



Introduction

***Sandra M. Sloan
Manager, Regulatory Affairs
New Plants Deployment***



AREVA NP, INC.

ACRS Meeting 4 June 2008

2

Presentation Goal

To provide an overview of the U.S. EPR design, identifying the relationship to currently operating PWRs and different features, especially those of particular safety significance.

NRC-Identified Areas of Potential Schedule Uncertainty

- Post-accident containment mixing
- Seismic and dynamic qualification of mechanical and electrical equipment
- Unanticipated axial growth in M5™ guide tubes
- Four methodology-related topical reports
 - ◆ Realistic Large Break LOCA
 - ◆ Reactivity Insertion Accident
 - ◆ Incore Trip Setpoint and Transient Methodology
 - ◆ Fuel Assembly Mechanical Analysis
- Emergency Core Cooling System (ECCS) strainer downstream effects (GSI-191)




Presentation Topic Areas

- General design objectives
- Plant layout
- Safety systems
- Core design
- Instrumentation and controls
- Severe accident mitigation
- SGTR and SBLOCA mitigation
- Probabilistic risk assessment
- Operating experience feedback



U.S. EPR Design Overview




***Marty Parece
Chief Engineer
Manager, Technology Integration
New Plants Deployment***



EPR Development Objectives

- **Evolutionary design** based on existing PWR construction experience, R&D, operating experience and "lessons learned"
- **Safer**
 - Reduce occupational exposure and LLW
 - Increase design margins
 - Increase redundancy & physical separation of safety trains
 - Reduce core damage frequency (CDF)
 - Accommodate severe accidents and external hazards with no long-term local population effect
- **Improved Operations**
 - Reduce generation cost by at least 10%
 - Simplify operations and maintenance
 - 60-year design life




Major Design Features

- | | |
|--|---|
| <ul style="list-style-type: none"> ➤ Nuclear Island <ul style="list-style-type: none"> ▪ Proven Four-Loop RCS Design ▪ Four-Train Safety Systems ▪ Containment & Shield Bldg ▪ In-Containment Borated Water Storage ▪ Severe Accident Mitigation ▪ Separate Safety Buildings ▪ Advanced Control Room | <ul style="list-style-type: none"> ➤ Electrical <ul style="list-style-type: none"> ▪ Island Mode Operation ▪ Four Emergency D/Gs ▪ Two Smaller, Diverse SBO D/Gs ➤ Site Characteristics <ul style="list-style-type: none"> ▪ Airplane Crash Protection (military and commercial) ▪ Explosion Pressure Wave |
|--|---|


Reflects full benefit of operating experience and 21st century requirements.

The U.S. EPR




U.S. EPR General Plant Layout

- UAA Switchyard
- UBA Switchgear Building
- UBP Emergency Power Generating Building
- UFA Fuel Building
- UGC Demineralized Water Storage Area
- UJA Reactor Building
- UJH Safeguard Building Mechanical
- UJK Safeguard Building Electrical
- UKA Nuclear Auxiliary Building
- UKE Access Building
- UKH Vent Stack
- UKS Radioactive Waste Processing Building
- UMA Turbine Building
- URA Cooling Tower Structure
- URB Essential Service Water Cooling Tower Structure
- USG Fire Protection Storage Tanks and Building
- UST Workshop & Warehouse Building
- UTG Central Gas Supply Building
- UYF Security Access Facility




Not To Scale

Radial Design N+2 Approach




The Four Train Concept




Main Safety Systems

- Four train Safety Injection System (SIS)
 - Medium head SI pumps
 - Combined Residual Heat Removal System / Low Head Safety Injection
- In-Containment refueling water storage tank
- Extra Borating System (two trains not shown)

- Non-safety containment spray for severe accident




Main Safety Systems Secondary Side



- Safety-related main steam relief train
- Four separate Emergency Feed Water Systems (EFWS)
- Separate power supply for each
- 2/4 EFWS also powered by Station Black Out (SBO) diesels
- Interconnecting headers at EFWS pump suction & discharge


Example: RHR Systems

- Each Train Connects to Different RCS Loop
- 1 RHR pump in each Safeguards Building (SB)
 - 1 RHR heat exchanger in each SB
 - 1 CCW heat exchanger in each SB
 - 1 CCW pump in each SB
 - 1 ESW train incl. mech draft cooling towers



Safeguard Building Layout

Safeguard Building Division 2



Divisional Approach Four Versus Two


➤ Front-line safety systems 4 x 100%

- ♦ Protection System
- ♦ Emergency Power Supply System
- ♦ ECCS
- ♦ CCWS
- ♦ ESWS
- ♦ EFWS

➤ Many 2 x 100%


- ♦ Annulus Ventilation
- ♦ Safeguards & Fuel Building Iodine Filtration
- ♦ Control Room Iodine Filtration
- ♦ Containment Isolation
- ♦ Extra Borating System
- ♦ Spent Fuel Pool Cooling

Protection From External Hazards




EPR Reactor Building

- > Containment wall post-tensioned concrete with steel liner
- > Shield wall reinforced concrete
- > Free volume = 2.8 Mft³
- > Design pressure = 62 psig
- > Annulus filtered to reduce radioisotope release
- > In-Containment Refueling Water Storage Tank (~500,000 gal)
- > Severe accident mitigation features
- > The design leak-rate at design pressure for a 24-hour period is less than 0.25 percent by volume



Reactor Coolant System



- > Conventional 4-loop PWR design, proven by decades of design, licensing & operating experience.
- > NSSS component volumes increased compared to existing PWRs, increasing operator grace period for many transients and accidents


A solid foundation of operating experience.

U.S. EPR Plant Parameter Comparison

Parameter	4-Loop (Upated)	U.S. EPR
Design Life	40	60
Thermal Power, MW	3565	4590
Electrical Power (Net), MW	1170	1595
Plant Efficiency, Percent	33	35
Hot Leg Temperature, F	618	624
Cold Leg Temperature, F	558	564
Reactor Coolant Flow Per Loop, gpm	100,500	124,700
Primary System Design Pressure, psia	2500	2550
Secondary System Design Pressure, psia	1200	1450
Primary System Operating Pressure, psia	2250	2250
Steam Pressure, psia	1000	1109
Steam Flow Per Loop, Mlb/hr	4.1	5.2
Total RCS Volume, cu.ft.	12,265	16,245
Pressurizer Volume, cu.ft.	1800	2650
SG Secondary Inventory at Full Power, lbm	101,000	182,000

EPR Core Design Parameters


Parameter	Current 4-Loop (Upated)	EPR
Core Thermal Power, MW	3565	4590
Number of Fuel Assemblies	193	241
Fuel Lattice	17x17	17x17
Active Fuel Length, ft	12	13.78
Rods Per Assembly	264	265
Average Linear Heat Rate, kw/ft	5.8	5.2
Peak Linear Heat Rate, kw/ft	14.6	13.8
Number of Control Rods	53	89



Type of Plant	No of Fuel Assy	
4-loop 1300 MWe	193	
4-loop N4	205	
U.S. EPR	241	

Comparison of EPR Design Margins to Typical 4-loop Unit

Margin Comparison of EPR to Current 4-Loop Plant



Digital Controls Operator-Friendly Man-Machine Interface




N4 Control Room



EPR Control Room

**Capitalizing on nuclear digital I&C
operating experience and feedback.**



AREVA

Increased Protection & Automation

- Hot-channel DNBR trip
- High linear power density trip
- High SG pressure trip
- Protection System SG depressurization
- Automatic boron dilution detection
- Computer-controlled heat-up & cooldown
- On-line procedures
- Electronic tagging
- Self-checking

EPR


AREVA NP, INC. ACRS Meeting 4 June 2008 26

In-Core Monitoring

- Fixed and moveable core monitoring systems
- Self-Powered Neutron Detectors continuously monitor core power
 - ☐ Provide input signals to POWERTRAX/E* software
 - ☐ Safety and non-safety functions are generated by SPNDs
 - ☐ SPND signal drift with burnup compensated by calibration
- The Aeroball Measurement System is used to calibrate SPNDs
 - ☐ About every 15 EFPD, the SPNDs are calibrated to the AMS reference signal
 - ☐ AMS is a moveable system that provides accurate 3-D core power maps
 - ☐ The AMS provides no signals to any protection or monitoring functions


* POWERTRAX/E provides a comprehensive system for on-line 3-D power distribution monitoring and for reactor operation support calculations

Nuclear Instrumentation





- ☐ 241 ASSEMBLIES
- ☒ 12 SPND FINGERS
- ☐ 40 AEROBALL PROBES

Aeroball Probe Schematic



Severe Accident Mitigation

- Prevention of high-pressure melt-through using Primary Depressurization System
- Passive ex-vessel melt stabilization, conditioning and cooling
- Long-term melt cooling and containment protection using active cooling system
- Control of H₂ concentration using passive autocatalytic recombiners



Severe Accident Mitigation Melt Conditioning and Stabilization

➤ **Reactor cavity temporarily retains molten core debris prior to spreading and stabilization processes**


- Limits uncertainties associated with RPV release states
- Corium/concrete interaction within reactor cavity lowers melting temperature of corium and promotes spreading

➤ **Melt spreading and relocation**

- After melt plug failure, conditioned melt will relocate into spreading area (shallow crucible)
- Large spreading area promotes cooling
- Spreading area is dry at time of melt relocation to preclude ex-vessel steam explosion

➤ **Stabilization**


- Water from IRWST passively cools melt for up to 12 hours
- Thereafter, severe accident heat removal system actively cools the melt and depressurizes containment



SGTR Mitigation Safety Injection System


➤ **Medium Head Injection selected for SGTR mitigation:**

- Shutoff head below MSSV setpoint
- Ensures no challenge to MSSVs during SGTR (no operator action required to throttle safety injection)
- SGTR dose consequences meet safety goal by minimizing containment bypass (eliminate possibility of discharging reactor coolant)




SGTR & SBLOCA Mitigation SBLOCA Spectrum Studies

- For very small LOCAs, RCS pressure "couples" to SG pressure because SG heat removal is maintained
- SI flow begins when RCS/SG pressure falls below the MHSI shut-off head



SBLOCA Mitigation Partial Cooldown


- Safety-related function (Protection System)
- Depressurizes SGs to reduce T_{sat} at 180 F/hr
- Ensures adequate MHSI flow for SBLOCA



Probabilistic Objectives And Targets

- **Safety objective for integral core melt frequency (all plant states, all types of initiators):** $< 10^{-5}$ per year
- **Design target for core damage frequency for internal events**
 - ◆ **from power states:** $< 10^{-6}$ per year
 - ◆ **from shutdown states:** less than power states
- **Design target for core damage with large and early releases from containment:** $< 10^{-7}$ /year


U.S. EPR CDF (At-Power Events)




Level 1 At-Power, Internal Events CDF = 5.3×10^{-7} /yr
CDF For All Events < 5.8×10^{-7} /yr

Operating Experience Feedback


Martensitic CRDM housing. Forced convection cooling of coils not req'd.



RCP stand-still seal eliminates leakage during SBO.



No penetrations in RV lower head.




Operating Experience Feedback

Extensive use of forgings with integral nozzles.


Materials resistant to corrosion and cracking

- 304L SS hot/cold legs
- 316L SS surge line
- 304L/316L RV internals
- 308/309 SS cladding
- Alloy 690 SG tubes
- 410 SS TSPs
- 405 SS AVBs




Conventional core baffle replaced by heavy reflector.

- Eliminates bolting
- Improves neutron economy
- Reduces vessel fluence




Two normal pwr spray (ea. from different CL) plus one aux spray



Operating Experience Feedback

Reduction of single-point vulnerabilities

- Partial trip function
- Three 50% condensate pumps
- Bypass components for maintenance




Facilitate maintenance

- Access room
- Permanent platforms
- Permanent maintenance power and air
- Pre-engineered haul routes & rigging points for component replacement




ALARA central in design

- Minimize cobalt
- Minimize deposits
- Use of "harsh" and "mild" zones



U.S. Industry-Average Dose Per Reactor 1973-2004, (Person-rem)



Source: Nuclear Regulatory Commission Occupational Radiation Exposure at Commercial Nuclear Power Reactors and Other Facilities 2004
Updated: 4/06

Design Summary

- **U.S. EPR is evolutionary**
- **Most features are typical of operating PWRs**
- **Features included to**
 - ◆ **Improve safety**
 - ◆ **Protect critical systems from external events**
 - ◆ **Improve human factors**
 - ◆ **Enhance reliability**



Backup Slides





Security Rulemaking for Nuclear Power Plants

ACRS Presentation
June 4, 2008

1



Discussion Topics

- Status of Power Reactor Security Rulemaking
- Staff Draft Final Rule Text needing ACRS review
 - 50.54(hh) Imminent Attack/Mitigative Measures
 - 73.54 Cyber Security
 - 73.58 Safety/Security Interface
- Status of Regulatory Guidance

2



Security Rulemaking

- **Part 73 Power Reactor Security Rulemaking**
(proposed rule published 10/06)
 - 50.54 (hh) Mitigative Strategies and Response Procedures for Potential or Actual Aircraft Attacks
 - 73.54 Protection of Digital Computer and Communication Systems and Networks
 - 73.55 Physical Security for Power Reactors
 - 73.56 Personnel Access Authorization Requirements for Nuclear Power Plants

3



Security Rulemaking (cont.)

- **Part 73 Power Reactor Security Rulemaking**
(proposed rule published 10/06)
 - 73.58 Safety/Security Interface Requirements for Nuclear Power Plants
 - Appendix B to Part 73 – Section VI, Nuclear Power Reactor Training and Qualification for Personnel Performing Security Program Duties
 - Appendix C to Part 73 – Licensee Safeguards Contingency Plans

4



Security Rulemaking for Nuclear Power Plants

ACRS Presentation
June 4, 2008

1



Discussion Topics

- Status of Power Reactor Security Rulemaking
- Staff Draft Final Rule Text needing ACRS review
 - 50.54(hh) Imminent Attack/Mitigative Measures
 - 73.54 Cyber Security
 - 73.58 Safety/Security Interface
- Status of Regulatory Guidance

2



Status of Rulemaking

- FRN developed
- Begin formal concurrence on 6/16/2008
- Provide to EDO on 6/30/2008

5



ACRS Review for Rulemaking

- 50.54 (hh) Mitigative Strategies and Response Procedures for Potential or Actual aircraft Attacks
 - DG-50XX (July 2008)
- 73.54 Protection of Digital Computer and Communication Systems and Networks
 - DG 5022
- 73.58 Safety/Security Interface Requirements for Nuclear Power Plants
 - DG 5021 Safety/Security Interface

6



**Draft Final Rule Text for 50.54 (hh)
as of 6/4/2008**

- Mitigative Strategies and Response Procedures for Potential or Actual aircraft Attacks
 - Contained in Appendix C of proposed rule
 - Moved to 50.54, Conditions of License
 - Supplemental rule published in Federal Register 4/10/2008
 - Comments received; incorporated into FRN
- Guidance to be developed from existing advisories, information (DG 50XX)

7



**Draft Final Rule Text for 73.54
as of 6/4/2008**

- Protection of Digital Computer and Communication Systems and Networks
 - Programmatic requirements for addressing cyber security
 - Included as part of DBT 73.1 issued March 2008
- DG 5022 Cyber Security Programs for Nuclear Facilities
 - Completed 6/1/08 (OUO)
 - In process of distribution to appropriate licensees (by 6/6/2008)

8



Draft Final Rule Text for 73.58 as of 6/4/2008

- Safety/Security Interface Requirements for Nuclear Power Plants
 - Requires coordination of potential adverse interactions between security activities and other plant activities
 - Addresses PRM 50-80, in part
- DG 5021 Safety/Security Interface
 - Published in Federal Register July 24, 2007
 - Public Meeting held; comments received & under consideration

9



Summary

- Security Rulemaking proceeding
- Supporting Regulatory Guidance for 50.54(hh) not developed
- Supporting Regulatory Guidance for 73.58 and 73.54 developed and drafts published or distributed

10

SECURITY RULEMAKING

STAFF DRAFT FINAL RULE LANGUAGE

As of 6/4/2008

§ 50.54(hh) Mitigative Strategies and Response Procedures for Potential or Actual Aircraft Attacks.

- (1) Each licensee shall develop, implement and maintain procedures that describe how the licensee will address the following areas if the licensee is notified of a potential aircraft threat:
- (i) Verification of the authenticity of threat notifications;
 - (ii) Maintenance of continuous communication with threat notification sources;
 - (iii) Contacting all onsite personnel and applicable offsite response organizations;
 - (iv) Onsite actions to enhance the capability of the facility to mitigate the consequences of an aircraft impact;
 - (v) Measures to reduce visual discrimination of the site relative to its surroundings or individual buildings within the protected area;
 - (vi) Dispersal of equipment and personnel, as well as rapid entry into site protected areas for essential onsite personnel and offsite responders who are necessary to mitigate the event; and
 - (vii) Recall of site personnel.
- (2) Each licensee shall develop and implement guidance and strategies intended to maintain or restore core cooling, containment, and spent fuel pool cooling capabilities under the circumstances associated with loss of large areas of the plant due to explosions or fire, to include strategies in the following areas:
- (i) Fire fighting;
 - (ii) Operations to mitigate fuel damage; and
 - (iii) Actions to minimize radiological release.
- (3) This section does not apply to a nuclear power plant for which the certifications required under § 50.82(a) or § 52.100(a)(1) of this chapter have been submitted.

§73.54 "Protection of digital computer and communication systems and networks"

- (a) Each licensee subject to the requirements of this section shall provide high assurance that digital computer and communication systems and networks are adequately protected against cyber attacks, up to and including the design basis threat as described in Title 10 of the Code of Federal Regulations (10 CFR) Part 73, Section 73.1.
- (a)(1) The licensee shall protect digital computer and communication systems and networks associated with:
- (a)(1)(i) safety-related and important-to-safety functions,
 - (a)(1)(ii) security functions,
 - (a)(1)(iii) emergency preparedness functions, including offsite communications,
 - (a)(1)(iv) support systems and equipment which, if compromised, would adversely impact safety, security or emergency preparedness functions.
- (a)(2) The licensee shall protect the systems and networks identified in paragraph (a)(1) of this section from cyber attacks that would:
- (a)(2)(i) adversely impact the integrity or confidentiality of data and/or software;
 - (a)(2)(ii) deny access to systems, services, and/or data, and;
 - (a)(2)(iii) adversely impact the operation of systems, networks, and associated equipment.
- (b) To accomplish this, the licensee shall:
- (b)(1) analyze digital computer and communication systems and networks and identify those assets that must be protected against cyber attacks to satisfy paragraph (a) of this section,
 - (b)(2) establish, implement, and maintain a cyber security program for the protection of the assets identified in (b)(1) of this section, and;

SECURITY RULEMAKING

STAFF DRAFT FINAL RULE LANGUAGE

As of 6/4/2008

- (b)(3) incorporate the cyber security program as a component of the physical protection program.
- (c) The cyber security program must be designed to:
 - (c)(1) implement security controls to protect the assets identified by paragraph (b)(1) of this section from cyber attacks,
 - (c)(2) apply and maintain defense-in-depth protective strategies to ensure the capability to detect and respond to cyber attacks,
 - (c)(3) mitigate the adverse affects of cyber attacks, and;
 - (c)(4) ensure that the functions of protected assets identified by paragraph (b)(1) of this section are not adversely impacted due to cyber attacks.
- (d) As part of the cyber security program, the licensee shall:
 - (d)(1) ensure that appropriate facility personnel, including contractors, are aware of cyber security requirements and receive the training necessary to perform their assigned duties and responsibilities effectively.
 - (d)(2) evaluate and manage cyber risks.
 - (d)(3) ensure that modifications to assests identified by paragraph (b)(1) of this section, are evaluated prior to implementation to ensure that the cyber security performance objectives identified in (a)(1) are maintained.
- (e) The licensee shall establish, implement, and maintain a cyber security plan that implements the cyber security program requirements of this section.
 - (e)(1) The cyber security plan must describe how the requirements of this section will be implemented and must account for the site-specific conditions that affect implementation.
 - (e)(2) The cyber security plan must include measures for incident response and recovery for cyber attacks. The cyber security plan must describe how the licensee will:
 - (e)(2)(i) maintain the capability for timely detection and response to cyber attacks,
 - (e)(2)(ii) mitigate the consequences of cyber attacks,
 - (e)(2)(iii) correct exploited vulnerabilities, and;
 - (e)(2)(iv) restore affected systems, networks, and/or equipment affected by cyber attacks.
- (f) The licensee shall develop and maintain written policies and implementing procedures to implement the cyber security plan.
 - (f)(1) Policies, implementing procedures, site-specific analysis, and other supporting technical information used by the licensee need not be submitted for Commission review and approval as part of the cyber security plan; but are subject to inspection by NRC staff on a periodic basis.
- (g) The cyber security program shall be audited as a component of the physical security program and will be subject to the same requirements and controls.
- (h) The licensee shall retain records and supporting technical documentation required to satisfy the requirements of this section until the Commission terminates the license for which the records were developed, and shall maintain superseded portions of these records for at least three (3) years after the record is superseded, unless otherwise specified by the Commission.

**SECURITY RULEMAKING
STAFF DRAFT FINAL RULE LANGUAGE
As of 6/4/2008**

§ 73.58 Safety/Security Interface Requirements for Nuclear Power Reactors

(a) Each operating nuclear power reactor licensee with a license issued under part 50 or 52 of this chapter shall comply with the requirements of this section.

(a)(1) The licensee shall assess and manage the potential for adverse affects on safety and security, including the site emergency plan, before implementing changes to plant configurations, facility conditions, or security.

(a)(2) The scope of changes to be assessed and managed must include planned and emergent activities (such as, but not limited to, physical modifications, procedural changes, changes to operator actions or security assignments, maintenance activities, system reconfiguration, access modification or restrictions, and changes to the security plan and its implementation).

(b) Where potential adverse interactions are identified, the licensee shall communicate them to appropriate licensee personnel and take compensatory and/or mitigative actions to maintain safety and security under applicable Commission regulations, requirements, and license conditions.

Synthesis on the findings from the ARTIST tests on aerosol retention in the secondary side of steam generators

**Presented to the ACRS
June 4, 2008**

**M. Salay
U.S. Nuclear Regulatory Commission
Washington, D.C., USA**

Overview

- **Steam Generator Tube Ruptures (SGTR)
background and NRC interest-SGAP**
- **ARTIST test program pertaining to
SGAP**
- **Major Observations**
- **MELCOR modifications**
- **Conclusions**

Steam generator tube rupture accidents

- **Design basis event**
 - Plants designed to cope
 - Have for all events to date
- **Progresses to severe accident only if something else happens**
 - Operator error

3

Induced steam generator tube rupture


- **Induced rupture greater concern**
 - Plants operate with detectable flaws in tubes
 - Limit on flaw size
 - Stress corrosion cracking is the cause of most flaws
 - Crevice corrosion at tube support plates of concern

4

Induced steam generator tube rupture


- Heat transfer from core to primary pressure boundary weakens structures
- Vulnerable locations
 - Hot leg nozzle
 - Surge line to pressurizer
 - Steam generator tubes
- Codes do not reliably predict failure location and depressurization timing

5



Aerosol retention in SGTR SA

- at tube inlet from steam generator plenum (inlet efficiency)
- in the steam generator tube prior to reaching the tube rupture
- in the immediate vicinity of the break where particles could impact on adjacent tubes
- in tubes between one tube support plate and another
- on top of tube support plates
- on envelope by thermophoretic deposition
- in the steam separators and steam dryers at the top of the steam generator.
- at steam generator safety relief valve (inlet efficiency)



7

Aerosol retention processes

- Removal mechanisms particle size dependent
 - Laminar
 - large – impaction, settling, interception
 - small – diffusion
 - Turbulent
 - turbulent deposition
 - bounce
 - flow resuspension
 - saltation
- Removal of particles alters particle size distribution
 - maximum penetration size
 - retention of individual sections can not be simply combined to obtain overall retention
 - integral tests
 - SETs obtain individual section retention as function of size

8

Aerosol size

- **A recommendation of prototypic aerosol size based on an IRSN survey of AECL, PBF-SFD and PHÉBUS experiments:**
 - **“size distribution at SG: near-lognormal, AMMD $\sim 1\mu\text{m}$ or less, $\sigma \sim 2$; larger particles comprise agglomerates of small ($\sim 0.1\mu\text{m}$) highly coordinated clusters”**
 - **Sizes in two of the facilities were in the maximum penetration size range**
 - **Larger size range in third facility**

9

Consequences of tube rupture

- **Radionuclides vent directly to environment or to auxiliary building without any attenuation from engineered safety features in containment**
- **Accidents have sufficiently high consequences that they are risk dominant despite low probability**

10

NUREG-1150


- **Risk analysis of five US plants**
 - Two PWRs had significant probabilities of steam generator tube rupture
 - All three PWRs could suffer induced steam generator tube rupture
- **Limited modeling of aerosol behavior on secondary side of steam generators**
 - None in the Source Term Code Package
 - Data unavailable

11

NUREG-1150 expert opinion elicitation

- **Inlet efficiency from steam generator plenum to ruptured tubes – DF (mass in/mass out) ~2**
- **Retention in tubes - DF <~10 - no credit given**
 - resuspension
 - revaporization
 - agglomerate breakup
- **Retention in secondary side - DF ~4 to 6**
 - deposition on outside of tubes resisted by thermophoresis
- **No credit for steam dryer/separators**
 - proprietary design information
- **Large uncertainty in estimates**

12



Alternate retention analysis

- Industry analyses provided far different estimates of retention in the secondary side of steam generator
 - Calculated steam generator DF on the order of 10,000
 - >100 in tube, depending on break location
 - 10s secondary near break
 - 2-3 far from break

Focus on SGTR bypass accident

- **attention to SGTR bypass accidents justified by risk**
- **Direct connection between risk and source term attenuation**
- **“are safety resources being misdirected to an unneeded attention on containment bypass accidents because we underestimate attenuation”**

15


SGAP ITEM 3.3a

- **STEAM GENERATOR ACTION PLAN (SGAP) ITEM 3.3a – DEVELOP EXPERIMENTAL INFORMATION ON SOURCE TERM ATTENUATION ON THE SECONDARY SIDE OF STEAM GENERATORS**

16

ARTIST Project

- AeRosol Trapping In a Steam generator
 - International project conducted by the Paul Scherrer Institut (PSI)
 - seven phase project (NRC participated in 5)
 - separate and integral tests (38)
- retention measured:
 - in the steam generator tube prior to reaching the tube rupture (15)
 - in the immediate vicinity of the break where particles could impact on adjacent tubes (9)
 - in tubes between one tube support plate and another and on top of tube support plates (6) (1 stage, 2 stage)
 - in the steam separators and steam dryers at the top of the steam generator. (5)
 - overall with all steam generator components (3)
- Other phases (not NRC)
 - retention in flooded bundle
 - droplets in dryers and separators



ARTIST facilities

- ARTIST
 - based on Beznau plant: 365 MWe Westinghouse 2 loop PWR (1969,1972)
 - scaled for SGTR
 - 19.08 mm tube diameter
 - approx 1:20 flow area and number of tubes
- Main facility
 - shortened and narrowed bundle with U-bend tube section
 - a tube sheet
 - 3 support plates
 - full scale separator and dryer
- SET facilities
 - in tube
 - at break
 - rods far from break and support plates
 - separator and dryer


	Beznau	ARTIST
Number of tubes	3238	270 (89)*
Dryers	12	1
Separators	12	1
Bundle dia. (m)	2.68	0.57
Max tube height (m)	9	3.8 (9)**
Flow area (m ²)	3.79	0.185
Sup. plate flow area (m ²)	1.288	0.052
Bundle D _h (cm)	3.1	3.1
Total height (m)	17	10.5

*separate test section for assessing retention far from break

**in tube retention tests

Test Parameters

- Guillotine break
- Aerosol particles (composition/size)
 - TiO_2 agglomerates (AMMD 1-5 μm)
 - Degussa
 - Nanophase
 - SiO_2 spheres, $D_{50} = 0.7, 1.4, 3.7 \mu\text{m}$
 - Latex spheres, $D_{50} = 0.4 \mu\text{m}$
- Concentrations
 - 0.01 to 100s of mg/m^3
- Flow rate:
 - nitrogen (steam)
 - few 10s – several 100s kg/h
- scoping tests to determine suitable parameters precede experiments
- tests to determine experimental uncertainty



TEM micrographs: Dr. Jerry Egeland / PSI
SEM micrograph: Dr. Unto Tapper / VTT

19

Primary Measurement Methods

- Size distribution, concentration, retained mass, and DF
 - sampling at inlet, outlet, and other locations
- Size distribution:
 - Berner Impactor
 - Electrical Low Pressure Impactor
 - Optical Particle Counter
- Concentration:
 - Filter
 - Photometer
 - Optical Particle Counter
- Mass collection, concentrations with flow used to determine DF
- Flow rates at inlet and outlet and at all sampling devices, gauge pressures at inlet and outlet, gas T

20

Major observations

- **Two forms of aerosol deposition:**
 - Always a fairly uniform layer of fine aerosol on surfaces exposed to the aerosol-laden flow. "tenacious"
 - A second form of deposit noticed in some tests consists of 'clumps' of deposited material.
- **Widely varying retention in tubes**
 - from test to test
 - high retention over short periods of time
- **Resuspension can occur for deposits in tubes**
 - bounce and break-up of aerosol important
- **Large agglomerates did not survive transport at high flows**
 - uniform size distribution leaving tube
 - particles smaller than $\sim 1 \mu\text{m}$ don't break up but larger particles do
- **No major retention at rupture site**
 - Expected based on studies of rupture propagation

21

Major observations

- **Away from break, most of deposited mass on support plate**
 - May be flow recirculation at broached holes for steam generator tubes
 - May not occur for US plants with drilled tube support plates
 - Flow occurs through larger holes; jets
 - Gaps around tubes usually filled with "crud"
- **Dryer/Separator not a major source of aerosol retention even for relatively coarse aerosols**
 - Fin spacing large and little aerosol diffusion

22

Outstanding issues

- **Understanding “bounce”**
- **Understanding breakup**
 - specific to test aerosol?
- **Understanding resuspension**
 - effect of vibrations
- **Features of steam generator**
 - Thermophoretic deposition on envelope
- **Shapes and sizes of particles coming from the degrading reactor core reaching SG**


23

Changes to MELCOR

- **include a “lambda” factor based directly on the ARTIST results**
 - based on particle size
 - insufficient risk change incentive to do more in the face of other pressing work
- **monitoring 1D model being developed at Ciemat in Spain**

24

ARTIST integral test results



25

Conclusions

- Expert panel recommendations made for NUREG 1150 risk analyses by and large confirmed
- MELCOR predicts decontamination factors similar to those obtained from ARTIST data.
- Modifications made to MELCOR based on ARTIST data
- ARTIST provides experimental data on source term attenuation on the secondary side of steam generators
 - Steam Generator Action Plan (SGAP) item 3.3a complete

26



Aerosol Trapping in Steam Generator ARTIST: Findings and Potential Effects on SGTR Risk Profile

ARTIST team:

Salih Güntay, Abdel Dehbi, Steffen Danner, Ralf Kapulla,
Terttaliisa Lind, Hauke Schütt, Detlef Suckow
Paul Scherrer Institut, Switzerland

Outline

- History
- Aims of ARTIST
- ARTIST International Consortium Project
- Facility and scaling
- Model aerosol particles
- Experimental Program and results
- Conclusions
- A new SGTR risk assessment methodology and use of ARTIST data
- Final remarks

History


- Motivation and support from Utility: Large contribution of SGTR in CDF and Risk in NPP-Beznau due to excessive tube problems in 1997
- Design and Procurement: 1998-2000
- EU 5. Framework Project SGTR: 2000-2002: PSI (Vertical SG without Dryer/separator), VTT (Exp: horizontal SG), NRG, Rez, CIEMAT
- ARTIST International Consortium Project
 - Phase I: 2002-2007
 - Phase II: 2008-2011
- Potential continuation >2011: in form of Fundamental Studies (PhD), model development efforts at PSI

NRC-ACRS Meeting, June 5, 2008

June 05 2008 (3)

Aims of the ARTIST International Consortium project

- o Provide an international forum to develop new information and share among partners
- o Produce high quality data for:
 - Development of fundamental and detailed to simplified and application oriented models
 - Facilitate evaluation of effectiveness of SAM6
- o Develop methodology for SGTR Risk Assessment
 - Re-assessment of SGTR induced environmental risk
 - Provoke international consensus about the risk significance of SGTR events during DBA and SA
- o Initiate fundamental investigations in form of PhDs/Masters




NRC-ACRS Meeting, June 5, 2008

June 05 2008 (4)

ARTIST Consortium (in alphabetical order)


- o AVN (Belgium)
- o Ciemat (Spain)
- o CSN (Spain)
- o HSK (Switzerland)
- o IRSN (France)
- o JNES (Japan)
- o KK Gösigen-Däniken (Switzerland)
- o NOK, KK Beznau (Switzerland)
- o Nuclear Safety Directorate (UK)
- o Ringhals NPP (Sweden)
- o Universidad Politecnica de Madrid (Spain)
- o University of Newcastle (UK)
- o US Nuclear Regulatory Commission (USA)
- o VTT (Finland)



NRC-ACRS Meeting, June 5, 2008

June 05.2008 (5)

ARTIST Facilities



Break stage Larger scale-bundle Droplet retention Integral mock-up facility

NRC-ACRS Meeting, June 5, 2008

June 05.2008 (6)

Scaling

Design basis: Framatome 33/19 Design

- Separator: 1:1 (steel or mostly transparent)
- Dryer: 1:1 (with actual Chevron panels) (all steel or inlet transparent)
- Bundle: 264 straight tubes, height: 1:0.42, with 1:1 layout
 - Broached support plates with 1:1 layout
- Single tube length: 1:1 with smallest and medium curvatures
- Tube dimensions: 1:1

Flow rates: 40 kg/h to 800 kg/h (fully representative)

Pressure: < 5 bar in primary, ~ 1 bar secondary

Dry conditions (except 1 in-tube test with slight steam condensation)

Model Aerosol Particles

- Evaporation and Condensation generated single/multi component Particles ($\text{SnO}/\text{CsI}/\text{CsOH}$, etc) (not used for ARTIST due to high costs)
- Fluidization of mono/polydisperse powders (TiO_2 (two types), SiO_2)
- Dispersion of suspended material (Latex, SiO_2 in solution) and drying droplets
 - Monodisperse particles (SiO_2 /Latex): well known size
 - Polydisperse particles (TiO_2): lots of problems due to unknown surface finish characteristics affecting deposition and no size control due to de agglomeration at high velocity/sonic front

Particle Morphology and Size in PWR Hot leg

- Working group: M. Kissane (IRSN), D. Powers (SNL), M. Reeks (NC)
- Very complicated and not resolved issue since many parameters (pressure, core degradation, etc) influence
- Hot leg conditions based on Phébus and other tests
- Phébus:
 - 15-40 % control rod metals, similar amount of oxides, and rest FPs
 - implies an "onion-skin" type of structure where the kernel rich in highly refractory materials and on top condensed species of more volatile species containing cesium and rubidium and perhaps migrated into and interact chemically with the substrate
 - For practical purpose AMMD at SG inlet or in SG based on impactor data
 - 3 μm (gsd 2) at 150 °C, 1.7 μm (gsd 2) at 730 °C, 0.1 μm at 930 °C following an exponential increase along inverse temperature

ARTIST experimental program

<u>BDBA source term quantification</u>		<u>ARTIST</u>
Phase I:	In tube	15
Phase II:	Break stage	9(+2)
Phase III:	Far field	8(+2)
Phase IV:	Separator&dryer	5
Phase V:	Flooded bundle	2(+3)
Phase VII:	Integral mock-up	3
Total		42(+7)

DBA source term quantification


Phase VI: Droplets (in separator & dryer) yes

(x): EU-SGTR

Phase I, In-tube retention (1:3)

o 15 tests


- 225 - 364 kg/h, with pressure ratio of 3.5:1
- Straight tube and
- U-tube with two bend diameters (83 and 384 mm)
- Dry conditions, except 1 test with slight steam condensation
- Mono/Polydisperse particles
- Very low to modest concentrations



NRC-ACRS Meeting, June 5, 2008

June 05.2008 (11)

Phase I, In-tube retention (2:3)



- 2*9 m with 83.2 mm curvature
- 70 -240 m/s velocity in Tube
- Dry TiO₂ (2-3 μ m inlet/<1 μ m outlet)


- Very dynamic aerosol processes (turbulent deposition/resuspension, de-agglomeration of TiO₂)
- Challenge for modeling (PhD Pamela Longmire/SNL)
- Effect on flow re-distribution among intact tubes in inlet plenum

NRC-ACRS Meeting, June 5, 2008

June 05.2008 (12)


Phase I, In-tube retention (2:3)

DF	Conc.	Particles
< 65	medium	SiO ₂
1.0 - 2.2	medium	TiO ₂
8.2	Slight steam cond.	TiO ₂
< 100	very low	SiO ₂ , latex



Aerosol (SiO₂) fragments collected in the outlet plenum


NRC-ACRS Meeting, June 5, 2008



1.4 μm SiO₂, high concentration

June 05.2008 (13)

Phase II: Break-Stage Retention: Dry conditions (1:6)



➤ Chocked flow at the break

➤ Guillotine Break

➤ Dry conditions

9 tests

- 360 kg/h,
- Monodisperse SiO₂ particles
- AMMD: 1.4 to 3.8 μm

2 tests with full bundle


- 600 kg/h
- Polydisperse TiO₂ particles
- AMMD: 2.3 μm before break

NRC-ACRS Meeting, June 5, 2008

June 05.2008 (14)

Phase II: Break-Stage Retention: Velocity profiles (2:6)

Measured velocity profile: Guillotine Break, 360 kg/h




➤ Very 3D flow

NRC-ACRS Meeting, June 5, 2008

June 05.2008 (15)

Phase II: Break-Stage Retention: Velocity profiles (3:6)



- Measured velocity profile
- FLUENT Simulations by Ringhals/EPISILON
- with $k-\epsilon$
- with Reynolds Stress Model (RSM)

NRC-ACRS Meeting, June 5, 2008

June 05.2008 (16)

Phase II, Break stage (4:6): Aerosol material type dependent local deposition pattern



TiO₂, Dae = 2.3 μm




SiO₂, Dae = 1.4 μm



SiO₂, Dae = 3.7 μm

➤ Flow rate: 600 kg/h for TiO₂, 360 kg/h for SiO₂ tests



Phase II, Break stage (5:6): Deposition pattern



Tube to tube aerosol deposition profile (SiO₂, 3.8 μm)


Phase II, Break stage (6:6): Retention

- o Highest retention potential among other retention stages
- o Decontamination Factor =
 - increases with increasing inlet concentration
 - increases with increasing D_p



Phase III, Far field stage (1:1)

- o 8 (+2 EU-SGTR) tests
- o Mass flow rate 33 & 105 kg/h
- o TiO_2 : deposition everywhere
- o Collected mass on certain tubes indicates roughly constant DF per stage
- o SiO_2 : mostly on support plates
- o SiO_2 (d_{pm} 3.7 μm) DF: ~1.07
- o DF might be higher at higher inlet concentration




TiO₂ Bundle test

SiO₂ Far field stage test


Phase IV: Separator & Dryer (1:2)

- o 5 tests (2 only separator)
- o Mass flow rate 100, 360 and 650 kg/h
- o Local turbulence initiated agglomeration and hence sedimentation
- o Decontamination Factor

DF	Particles	D_{ae}
1.2 - 1.4	TiO ₂	3 μ m, aggl.
1.5 - 1.6	SiO ₂	integral mock-up



Aerosol collected in Condensate collector below the panels



NRC-ACRS Meeting, June 5, 2008

June 05.2008 (21)


Phase VII: Integral mock-up tests

Aim: verify consistency of separate effect data at certain conditions

Decontamination Factor =

- Consistent with Break Stage Tests
- DF increases with concentration
- DF increases with particle size

Effect of model aerosol particle material/surface treatment



NRC-ACRS Meeting, June 5, 2008

June 05.2008 (22)

Conclusions #1, aerosol tests

- o **In-tube retention**
 - o Dynamic, depends on particle size and concentration
 - o Steam condensation increases DF significantly
 - => the effect of particle concentration?
 - => the effect of bounce/resuspension?
- o **Retention largest in the break stage**
 - o Depends on particle size and concentration
 - => the effect of particle concentration?
 - => fish-mouth break leading to higher gas/particle momentum and deeper penetration in Bundle?
 - => data with minimized bounce/resuspension needed for modeling

Conclusions #2, aerosol tests

- o **Retention in the far field**
 - => the effect of particle concentration?
 - => Effect of aerosol composition?
- o **Retention in the flooded bundle**
 - => High DF (50 - 2000) with submersion 1.2 - 3.8 m
 - => retention close to the break (?) with smaller submersion
- o **Retention in Separator & Dryer**
 - => ~ 30-40 % of incoming mass retained independent of Flow Rate
- o **Retention in the integral mock-up facility**
 - o Dominated by retention in the break stage
 - o Consistency of separate effect data demonstrated


Transport/Removal of Activity in Steam Generator

- SGTR concurrent with core damage involves:
 - Major activity in vapour form at SG inlet
 - Rest of activity and inactive material in aerosol form
- Transformation of activity in vapour form by vapour condensation dependent on local temperature
- Removal of some fraction of vapour by condensation on structure surface
- Transport/removal of Rest of vapour of condensed on particles or form new particles dependent on aerosol removal/transport process

ARTIST addresses only aerosol removal/transport process in SG

Motivation for a new SGTR risk assessment methodology

- MELCOR contains models for vapor/aerosol behavior but lacks specific aerosol transport/removal in SG complex structures at relevant thermal-hydraulic conditions
- For risk assessment with many hundred variations to consider uncertainties: MELCOR is too expensive
- A fast running lump parameter model including Monte-Carlo sampling for uncertainties under development
- Preliminary sample analysis demonstrates the strength and provides feasibility of SGTR risk reduction



A new SGTR risk assessment methodology

- Lump Parameter Model tracking vapor/aerosol phases in each release path in SG secondary side with:
 - T/H and Vapor/aerosol boundary conditions and uncertainties from SA code predictions
 - Temperature dependent ultimate particle size based on Phébus tests
 - Temperature dependent vapor fractions of released classes including all species from SOPHAEROS code (IRSN/FR) analysis
 - Release path dependent ARTIST DFs (d_p , c)
- Monte-Carlo sampling for all uncertainties
- APET for all SGTR sequences
- Running Model for each APET branches for determination of risk

NRC-ACRS Meeting, June 5, 2008

June 05 2008 (27)




Lump Parameter Model: Key Aspects

- Accounts for aerosol behavior in complex structures of SG at hydrodynamic conditions by use of ARTIST data for each SG retention stage
- Accounts for vapor conversation using temperature dependent vapor fraction data base generated from SOPHAEROS code runs
- Accounts for vapor fraction condensed on structure and converted to particles by user input including its uncertainty
- Accounts for temperature dependent aerosol size determined by measured sizes in hot leg in all Phébus tests with AgInCd
- Neglects other processes playing a secondary role: thermophoresis, diffusiophoresis,...

NRC-ACRS Meeting, June 5, 2008

June 05 2008 (28)

Lump Parameter Model Description



$$\dot{m}_2 = \frac{1 - x_1(1 - \alpha)}{DF_a - x_2(DF_a - \alpha)} \dot{m}_1$$

α : Vapour split fraction on walls/
particles = 0.5 (0.1-0.9)

DFa: ARTIST DF

m: mass flow of release class (I, Cs, ..)


X: vapor fraction of the mass flow

T: Gas temperature


1: donor volume

2: current volume

Lump Parameter Model Data Base (1:3)




Vapor fraction data base
generated from SOPHAEROS
code runs



Particle size as measured in all
Phébus tests with AgInCd

Lump Parameter Model Data Base (2:3)



ARTIST Break Stage Particle Size Dependent DF

NRC-ACRS Meeting, June 5, 2008

June 05 2008 (31)

Lump Parameter Model Data Base (3:3)


Retention Stage	DF	Error Factor	Source
Reactor vessel	1.2 (I), 1.8 (Cs)	1.06 (I), 1.04 (Cs)	Phébus
Primary circuit	1.1 (I), 1.2 (Cs)	1.09 (I), 1.2 (Cs)	Expert judgment
In-tube retention	Time variant	1.5	ARTIST
Break stage	Aerosol-size variant	1.5	ARTIST
Far-field stage I-VII	1.05	1.21	ARTIST
Top of shroud	1.20	1.09	Expert judgment
Separator	1.20	1.06	ARTIST
Recirculation	Model	Model	MELCOR, SR5
Downcomer	1.10	1.05	Expert judgment
Intra-volume	1.10	1.07	Expert judgment
Dryer	1.20	1.09	ARTIST
Dome	1.10	1.05	ARTIST

NRC-ACRS Meeting, June 5, 2008

June 05 2008 (32)

Multiple SA Code Analyses for Model Uncertainties for the same APET Branch

SGTR Frequency	Category	Rupture Size	Rupture Location		Accident Mitigation		
	No SA-Induced SGTR	No Multiple-Tubes	No U-Bend Rupture	No Cold-Leg Rupture	No Reclosed RV	No Refilled SG	
Node A	B	C	D	E	F	G	H




NRC-ACRS Meeting, June 5, 2008

June 05 2008 (33)

Retention Stages from Core to SG Steam Outlet

- For each APET sequence, consider a series of retention stages in the fission product release path from the core to the environment
- For retention stages of the SG, the lumped parameter model is used



NRC-ACRS Meeting, June 5, 2008

June 05 2008 (34)

Multiple SA Code Results: An example

Temperature predictions from MELCOR and SCDAP/RELAP5

Running multiple cases to estimate the temperature distribution

- S6TR sequence from NPP - Beznau PSA L2

- SRV stuck-open at the affected SG
- SRV opened manually at the intact SG
at core exit temperature > 923K

- Calculation stops at lower head failure


(a) MELCOR

(b) SR5, $\Delta t = 0.1$



SCDAP/RELAP5, max. time step = 0.1s

(c) SR5, $\Delta t = 0.01$


SCDAP/RELAP5, max. time step = 0.01s




Monte-Carlo Simulation: Examples of 90% confidence interval of Particle Diameter and Decontamination Factor in Break Stage



Presentation not given.



Only slide
referred
to →




Assessment of Methodology (1:2)

- MELCOR 1.8.6 runs for point estimates of source term
 - use of ARTIST data through „filter function“
 - Superimposing user input „aerosol size“ to overwrite MAEROS
- Three MELCOR runs
 - Standard MELCOR 1.8.6 for the same SGTR sequence
 - MELCOR 1.8.6 with ARTIST DFs
 - MELCOR 1.8.6 with ARTIST DFs + PHÉBUS inferred temperature dependent particle size

With MELCOR default vapor and aerosol physics


Assessment of Methodology (1:2)

Comparison of PSI-Risk Model Results to MELCOR Point Value Estimates



APET: branching fractions

SGTR Frequency	Category	Rupture Size	Rupture Location		Accident Mitigation		
	No SA-induced SGTR	No Multiple-Tubes	No U-Bend Rupture	No Cold-Leg Rupture	No Redclosed RV	No Refilled SG	
Node A	B	C	D	E	F	G	H




NRC-ACRS Meeting, June 5, 2008

June 05.2008 (41)

Preliminary Risk Profile of NPP-Beznau Spontaneous SGTR

Comparison of the SGTR (without SG Reflooding) Risk significance to
other internal initiating events for the Beznau NPP



NPP Beznau: PSA L2 BERA: 2002

NRC-ACRS Meeting, June 5, 2008

June 05.2008 (42)

Conclusions

- Methodology consistent with Point values from MELCOR
- Further development for inclusion of other dependencies and their uncertainties (e.g., DF (dp, ϵ))
- Generic model requires user to input from plant specific SA analysis
- APET to be revised with plant specific information (frequencies, split fractions)

Final Remarks

- PSI data supported by additional data from CIEMAT (Spain) for break stage retention and from VTT (Finland) for in-tube deposition/resuspension, both at low flows
- CFD Simulations of flow¹ and particles² by CFD (FLUENT) by Ringhals, AVN¹, CIEMAT¹, JNES^{1,2} and NRC^{1,2} (Sandia)
- Model development for aerosol removal in flooded bundle (IRSN) and in break stage (CIEMAT)
- 4 PhDs (de-agglomeration, aerosol motion through DNS+LES, bubble hydrodynamics in bundle) at PSI
- 3 PhDs (removal in far field, break stage hydrodynamics, aerosols) at UPM and CIEMAT
- 1 PhD (particle motion in SG pipe) at Sandia
- 1 masters (flow fields by CFD in Separator) at AVN
- with involvement of 7 Universities

PSI thanks for all supporting and participating organizations in ARTIST

Phases V and VI: Flooded Bundle and Droplet Retention in Separator & Dryer

NRC does not participate in ARTIST Project Phases V and VI, however, the following information is introduced for those in ACRS who have interest in the Aerosol Scrubbing in Bundle Environment from High Jet Flows and Dissolved Activity (Iodine, mostly) Retention/Release by Droplets during the initiation of a SGTR event


NRC-ACRS Meeting, June 5, 2008

June 05.2008 (45)

Phase V: retention in the flooded bundle (1:2)

- o 2 tests (+3 EU-SGTR)
- o Decontamination Factor
- o Determined for relatively large submersion

DF	flow rate	submersion
2 100	45 kg/h	3.8 m
335	640 kg/h	3.2 m




NRC-ACRS Meeting, June 5, 2008

June 05.2008 (46)

Phase V: retention in the flooded bundle (2:2)

- o Very high DF due to bundle-hydrodynamic interactions, especially at the break; models not able to reproduce DF
- o Aerosol removal in hot pools without bundle: ~ DF 20 (PSI - POSEIDON, 1991- 1996)



tests	Main features	Submergence m	Experimental DF	IFSN Model DF
A62	Steam, hot, medium flow rate	1.3	88-100	362
A63	NC, cold, low flow rate	1.2	134	37
		2.3	1291	64
		3.6	6739	69
E64	NC, cold, low flow rate	3.60	2897	46
E66	NC, cold, high flow rate	3.20	271-486	67

NRC-ACRS Meeting, June 5, 2008

June 05.2008 (47)


Iodine Source Term during Steam Generator Tube Rupture Initiated Design Basis Accidents: Introduction

- o Spontaneous or initiated Steam Generator Tube Rupture
 - => activity release until the operators can reduce the RCS pressure to the secondary side level
 - => activity release at least 30-40 minutes (so-called "grace period")
 - o SGTR event is a design basis event
 - o The amount of activity release controlled by:
 - a) amount of dissolved activity in the primary system (leaking rods, iodine spiking (reactor trip) and pressure change)
 - b) the submergence of the leak; single or multiple tube ruptures; total break flow
 - c) pH and iodine chemistry in the secondary side
 - d) iodine mass transfer from the boiling pool
 - e) The break at the tube bend
 - <= 80-85 % of primary water in droplet form as a result of flashing
 - => efficiency of separator and dryer to retain droplets
- ➔ ARTIST - Phase VI

NRC-ACRS Meeting, June 5, 2008

June 05.2008 (48)

Phase VI: Droplet retention in Separator and Dryer






- Non-evaporating DEHS as droplet medium
- Spraying DEHS producing droplets
- Constant gas flow (10-800 kg/h)
- Known droplet inlet flux
- Known droplet size distribution at inlet (AMMD 10-50 μ m)
- LDA, PDA, PIV
- Liquid Collection for DF


NRC-ACRS Meeting, June 5, 2008

June 05.2008 (49)

Flow velocity distribution



Mean axial velocity




Mean transverse velocity

NRC-ACRS Meeting, June 5, 2008

June 05.2008 (50)

JNES FLUENT Simulations




- RSM turbulence model much better than $k-\epsilon$ model for rotating flow.
- Mesh resolution at lid controls quality of velocity profile above Lid plane
- Importance of adequate resolution of wall boundary layer

NRC-ACRS Meeting, June 5, 2008

June 05.2008 (51)

Integral retention across the separator & dryer




NRC-ACRS Meeting, June 5, 2008

June 05.2008 (52)


```

graph TD
    A[3D flow simulation at whole separator & dryer] --> B[Velocity field]
    A --> C[Inlet velocities]
    B --> D[3D aerosol tracking at separator & dryer]
    C --> E[2D flow simulation at chevron vane]
    E --> F[2D aerosol tracking at chevron vane]
    F --> G[Integration with velocities]
    D --> H[Aerosol deposition at whole separator & dryer]
    G --> H
  
```



NRC-ACRS Meeting, June 5, 2008

June 05, 2008 (53)

DF (300kg/h)

	1 μm	3 μm	10 μm
Separator	1.25	1.32	1.35
Dryer	1.09	1.14	1.25
Total	1.36	1.51	1.68

- Capturing hydrodynamic behavior is crucial prerequisite for aerosol behavior
- PSI discrete-particle tracing considers particle turbulence based on DNS simulations
- JNES predicted Overall retention is in agreement with Phase IV test results

NRC-ACRS Meeting, June 5, 2008

June 05.2008 (54)

