

May 12, 2008

**UNITED STATES OF AMERICA
NUCLEAR REGULATORY COMMISSION**
Before the Atomic Safety and Licensing Board

In the Matter of)
)
Entergy Nuclear Vermont Yankee, LLC) Docket No. 50-271-LR
and Entergy Nuclear Operations, Inc.) ASLBP No. 06-849-03-LR
)
(Vermont Yankee Nuclear Power Station))

**EXHIBITS TO ENTERGY'S DIRECT TESTIMONY
ON NEC CONTENTION 4 – FLOW-ACCELERATED CORROSION**

INCLUDES EXHIBITS E4-30 THROUGH E4-42

VOLUME 2

Vermont Yankee

Piping Flow Accelerated Corrosion (FAC)

Inspection Program

EPRI CHECWORKS
WEAR RATE ANALYSIS RESULTS

(CHECWORKS Version 1.0F Build 52)

Cycle 25 with Inspection Data up to RFO 25.

DRAFT

Page 1 of 186

JCR 9/28/06

 *** FAC Database: Component Inspection Summary Report ***

SELECTION CRITERIA:

Line Name: *
 Drawing Name: *
 Comp. Service Status: *

Line Name : 001-16*-FDW-01

Component Name	Previous Name	Period Name	Period Start Date
FD01RD01		RFO 14	09-01-1990
		RFO 16	08-28-1993
		RFO 19	03-21-1998
		RFO 21	04-28-2001
		RFO 24	04-03-2004
FD01EL01		RFO 14	09-01-1990
		RFO 16	08-28-1993
		RFO 18	09-07-1996
		RFO 19	03-21-1998
		RFO 21	04-28-2001
FD01TE05		RFO 24	04-03-2004
		RFO 14	09-01-1990
		RFO 16	08-28-1993
		RFO 18	09-07-1996
		RFO 19	03-21-1998
FD01EL02		RFO 21	04-28-2001
		RFO 24	04-03-2004
		RFO 14	09-01-1990
		RFO 19	03-21-1998
		RFO 14	09-01-1990
FD01SP02 US		RFO 19	03-21-1998
FD01SP02 DS		RFO 14	09-01-1990
FD01EL03		RFO 21	04-28-2001
		RFO 14	09-01-1990
FD01SP03 US		RFO 21	04-28-2001
FD01EL04		RFO 14	09-01-1990
		RFO 21	04-28-2001
FD01SP04 US		RFO 18	09-07-1996
		RFO 24	04-03-2004
FD01SP05 DS		RFO 13	02-12-1989

DRAFT

Line Name : 002-16*-FDW-02

Component Name	Previous Name	Period Name	Period Start Date
OUTLET P-1-1B		RFO 13	02-12-1989
		RFO 17	03-18-1995
		RFO 18	09-07-1996
		RFO 20	10-30-1999
FD02RD01		RFO 17	03-18-1995
		RFO 18	09-07-1996
		RFO 20	10-30-1999
		RFO 24	04-03-2004
FD02EL01		RFO 13	02-12-1989
		RFO 17	03-18-1995
		RFO 18	09-07-1996
		RFO 20	10-30-1999
FD02TE01		RFO 24	04-03-2004
		RFO 17	03-18-1995
		RFO 18	09-07-1996
		RFO 20	10-30-1999
FD02EL02		RFO 24	04-03-2004
		RFO 15	03-07-1992
FD02SP02 US		RFO 20	10-30-1999
		RFO 15	03-07-1992
FD02SP02 DS		RFO 20	10-30-1999
		RFO 13	02-12-1989
FD02EL03		RFO 14	09-01-1990
		RFO 15	03-07-1992
		RFO 13	02-12-1989
FD02SP03 US		RFO 14	09-01-1990
		RFO 15	03-07-1992
		RFO 18	09-07-1996
FD02SP04 DS		RFO 18	09-07-1996
		RFO 18	09-07-1996
FD02EL05		RFO 18	09-07-1996
FD02SP05 US		RFO 18	09-07-1996
FD02SP05 DS		RFO 16	08-28-1993
		RFO 17	03-18-1995

Line Name : 003-16*-FDW-03

Component Name	Previous Name	Period Name	Period Start Date
OUTLET P-1-1C		RFO 13	02-12-1989

2

FD03RD01	RFO 16	08-28-1993
	RFO 20	10-30-1999
	RFO 13	02-12-1989
	RFO 16	08-28-1993
FD03EL01	RFO 20	10-30-1999
	RFO 13	02-12-1989
	RFO 16	08-28-1993
FD03TE01	RFO 20	10-30-1999
	RFO 13	02-12-1989
	RFO 16	08-28-1993
	RFO 18	09-07-1996
FD03SP01	RFO 20	10-30-1999
FD03EL02	RFO 24	04-03-2004
FD03SP02 US	RFO 17	03-18-1995
FD03SP02 DS	RFO 17	03-18-1995
	RFO 13	02-12-1989
FD03EL03	RFO 14	09-01-1990
	RFO 13	02-12-1989
	RFO 14	09-01-1990
FD03SP03	RFO 21	04-28-2001
	RFO 13	02-12-1989
	RFO 14	09-01-1990
	RFO 21	04-28-2001
FD03EL04	RFO 13	02-12-1989
	RFO 14	09-01-1990
	RFO 15	03-07-1992
FD03SP04 US	RFO 21	04-28-2001
	RFO 13	02-12-1989
	RFO 14	09-01-1990
	RFO 15	03-07-1992
FD03SP04 DS	RFO 21	04-28-2001
FD03EL05	RFO 17	03-18-1995
	RFO 16	08-28-1993
FD03SP05	RFO 17	03-18-1995
	RFO 16	08-28-1993
FD03EL06	RFO 17	03-18-1995
	RFO 16	08-28-1993
FD03SP06	RFO 17	03-18-1995
	RFO 16	08-28-1993
FD03EL07	RFO 17	03-18-1995
FD03SP07 US	RFO 20	10-30-1999
FD03SP07 DS	RFO 20	10-30-1999
	RFO 14	09-01-1990
	RFO 15	03-07-1992

DATA

Line Name : 004-24*-FDW-01

Component Name	Previous Name	Period Name	Period Start Date
FD01TE01		RFO 13	02-12-1989
		RFO 14	09-01-1990
		RFO 15	03-07-1992
FD01SP06 DS		RFO 13	02-12-1989
FD01SP06 US		RFO 16	08-28-1993
		RFO 17	03-18-1995
FD01TE02		RFO 16	08-28-1993
		RFO 17	03-18-1995
FD01SP07 US		RFO 16	08-28-1993
		RFO 17	03-18-1995
FD01SP10 DS		RFO 14	09-01-1990
		RFO 15	03-07-1992
FD01TE04		RFO 14	09-01-1990
		RFO 15	03-07-1992
FD01EL08		RFO 14	09-01-1990
		RFO 15	03-07-1992
FD01SP11		RFO 14	09-01-1990
		RFO 15	03-07-1992
		RFO 18	09-07-1996
		RFO 20	10-30-1999
		RFO 23	10-06-2002

Line Name : 005-18*-FDW-07

Component Name	Previous Name	Period Name	Period Start Date
FD07RD01		RFO 13	02-12-1989
FD07EL01		RFO 13	02-12-1989
		RFO 19	03-21-1998
		RFO 20	10-30-1999
FD07SP01 US		RFO 13	02-12-1989
		RFO 19	03-21-1998
		RFO 20	10-30-1999
FD07SP01 DS		RFO 18	09-07-1996
FD07EL02		RFO 18	09-07-1996
FD07SP02 US		RFO 18	09-07-1996
FD07SP02 DS		RFO 24	04-03-2004
FD07EL03		RFO 24	04-03-2004
FD07RD02		RFO 16	08-28-1993
		RFO 17	03-18-1995
		RFO 18	09-07-1996
FD07RD03		RFO 14	09-01-1990
		RFO 16	08-28-1993
		RFO 17	03-18-1995
		RFO 21	04-28-2001
FD07SP03		RFO 14	09-01-1990
		RFO 16	08-28-1993
		RFO 17	03-18-1995
		RFO 21	04-28-2001
FD07EL04		RFO 14	09-01-1990

FD07SP04	RFO 19	03-21-1998
	RFO 14	09-01-1990
FD07EL06	RFO 19	03-21-1998
FD07SP07	RFO 19	03-21-1998
FD07EL07	RFO 19	03-21-1998
FD07SP08 US	RFO 19	03-21-1998
FD07SP09	RFO 17	03-18-1995
FD07EL09	RFO 17	03-18-1995
FD07SP10 US	RFO 17	03-18-1995

Line Name : 007-18*-FDW-12

Component Name	Previous Name	Period Name	Period Start Date
FD12SP07		RFO 25	10-08-2005
FD12EL06		RFO 25	10-08-2005
FD12SP08		RFO 25	10-08-2005
FD12SP10 DS		RFO 19	03-21-1998
FD12EL08		RFO 19	03-21-1998
FD12EL09		RFO 19	03-21-1998

Line Name : 008-16*-FDW-14

Component Name	Previous Name	Period Name	Period Start Date
FD14SP02		RFO 14	09-01-1990
FD14EL03		RFO 14	09-01-1990
		RFO 15	03-07-1992
		RFO 20	10-30-1999
		RFO 25	10-08-2005
FD14SP03 US		RFO 14	09-01-1990
		RFO 15	03-07-1992
		RFO 20	10-30-1999
		RFO 25	10-08-2005
FD14SP06 US		RFO 13	02-12-1989
FD14SP06 DS		RFO 23	10-06-2002
FD14EL05		RFO 23	10-06-2002
FD14TE02		RFO 23	10-06-2002
FD14SP07 US		RFO 23	10-06-2002

Line Name : 008-18*-FDW-14

Component Name	Previous Name	Period Name	Period Start Date
FD14TE01		RFO 14	09-01-1990
FD14RD01		RFO 14	09-01-1990

Line Name : 009-16*-FDW-14

Component Name	Previous Name	Period Name	Period Start Date
FD14SP08 DS		RFO 24	04-03-2004
FD14EL07		RFO 24	04-03-2004

Line Name : 009-16*-FDW-16

Component Name	Previous Name	Period Name	Period Start Date
FD16SP05		RFO 19	03-21-1998
FD16EL01		RFO 19	03-21-1998

Line Name : 010-10*-FDW-19

Component Name	Previous Name	Period Name	Period Start Date
FD19SP04		RFO 14	09-01-1990
		RFO 16	08-28-1993
		RFO 20	10-30-1999
		RFO 24	04-03-2004

Line Name : 010-10*-FDW-21

Component Name	Previous Name	Period Name	Period Start Date
FD21SP01 US		RFO 14	09-01-1990
		RFO 16	08-28-1993
		RFO 20	10-30-1999
		RFO 24	04-03-2004

Line Name : 010-16*-FDW-19

Component Name	Previous Name	Period Name	Period Start Date
FD19SP03 DS		RFO 14	09-01-1990
		RFO 16	08-28-1993
		RFO 20	10-30-1999

FD19TE01	RFO 24	04-03-2004
	RFO 14	09-01-1990
	RFO 16	08-28-1993
	RFO 20	10-30-1999
FD19RD01	RFO 24	04-03-2004
	RFO 14	09-01-1990
	RFO 16	08-28-1993
	RFO 20	10-30-1999
	RFO 24	04-03-2004

Line Name : 011-18*-FDW-08

Component Name	Previous Name	Period Name	Period Start Date
FD08RD01		RFO 18	09-07-1996
		RFO 20	10-30-1999
		RFO 23	10-06-2002
FD08EL01		RFO 18	09-07-1996
		RFO 20	10-30-1999
		RFO 23	10-06-2002
FD08SP01 US		RFO 18	09-07-1996
		RFO 20	10-30-1999
		RFO 23	10-06-2002
FD08RD02		RFO 17	03-18-1995
FD08VA02		RFO 13	02-12-1989
		RFO 17	03-18-1995
FD08RD03		RFO 17	03-18-1995
		RFO 18	09-07-1996
		RFO 20	10-30-1999
		RFO 25	10-08-2005
FD08SP02		RFO 13	02-12-1989
		RFO 17	03-18-1995
		RFO 18	09-07-1996
		RFO 20	10-30-1999
		RFO 25	10-08-2005
FD08EL03		RFO 13	02-12-1989
FD08SP03 US		RFO 13	02-12-1989
FD08EL04		RFO 20	10-30-1999
FD08SP04		RFO 20	10-30-1999
FD08EL05		RFO 20	10-30-1999
FD08SP05 US		RFO 20	10-30-1999

Line Name : 012-18*-FDW-08

Component Name	Previous Name	Period Name	Period Start Date
FD08EL06		RFO 19	03-21-1998
FD08SP06 US		RFO 19	03-21-1998

Line Name : 013-18*-FDW-13

Component Name	Previous Name	Period Name	Period Start Date
FD13EL05		RFO 18	09-07-1996
FD13SP06		RFO 18	09-07-1996

Line Name : 014-16*-FDW-15

Component Name	Previous Name	Period Name	Period Start Date
FD15SP02		RFO 13	02-12-1989
FD15EL03		RFO 13	02-12-1989
FD15SP09		RFO 13	02-12-1989
FD15EL04		RFO 13	02-12-1989
		RFO 19	03-21-1998
FD15SP10		RFO 13	02-12-1989
		RFO 19	03-21-1998
FD15EL05		RFO 19	03-21-1998
FD15SP03		RFO 19	03-21-1998

Line Name : 014-18*-FDW-15

Component Name	Previous Name	Period Name	Period Start Date
FD15TE01		RFO 13	02-12-1989
FD15RD01		RFO 13	02-12-1989

Line Name : 015-16*-FDW-15

Component Name	Previous Name	Period Name	Period Start Date
FD15EL07		RFO 19	03-21-1998
FD15SP08 US		RFO 19	03-21-1998

Line Name : 016-10*-FDW-18

Component Name	Previous Name	Period Name	Period Start Date
FD18SP04 US		RFO 13	02-12-1989

5

RFO 17 03-18-1995
RFO 21 04-28-2001

Line Name : 016-10"-FDW-20

Component Name	Previous Name	Period Name	Period Start Date
FD20RD01		RFO 13 RFO 17 RFO 21	02-12-1989 03-18-1995 04-28-2001
FD20SP01		RFO 13 RFO 17 RFO 21	02-12-1989 03-18-1995 04-28-2001

Line Name : 016-16"-FDW-18

Component Name	Previous Name	Period Name	Period Start Date
FD18SP01 DS		RFO 23	10-06-2002
FD18EL01		RFO 23	10-06-2002
FD18SP02 US		RFO 23	10-06-2002
FD18TE01		RFO 13 RFO 17 RFO 21	02-12-1989 03-18-1995 04-28-2001

Line Name : 017-04"-FDW-04

Component Name	Previous Name	Period Name	Period Start Date
FD04RD01		RFO 19 RFO 20	03-21-1998 10-30-1999

Line Name : 018-04"-FDW-05

Component Name	Previous Name	Period Name	Period Start Date
FD05SP01		RFO 13	02-12-1989
FD05EL01		RFO 13	02-12-1989
FD05SP02 US		RFO 13	02-12-1989
FD05SP03		RFO 15 RFO 18	03-07-1992 09-07-1996
FD05VA02		RFO 15	03-07-1992
FD05SP04		RFO 15	03-07-1992
FD05EL02		RFO 15 RFO 18	03-07-1992 09-07-1996
FD05SP05 US		RFO 15 RFO 18	03-07-1992 09-07-1996
FD05RD01		RFO 15 RFO 16	03-07-1992 08-28-1993
FD05TE01		RFO 15 RFO 16	03-07-1992 08-28-1993
INLET COND A		RFO 15	03-07-1992
FD05CP01		RFO 16 RFO 15	08-28-1993 03-07-1992

DRILL

Line Name : 019-04"-FDW-06

Component Name	Previous Name	Period Name	Period Start Date
FD06SP01 DS		RFO 13	02-12-1989
FD06EL01		RFO 13	02-12-1989
FD06SP02 US		RFO 13	02-12-1989
FD06RD01		RFO 20	10-30-1999

Line Name : 020-06"-FDW-09

Component Name	Previous Name	Period Name	Period Start Date
FD09SP06		RFO 15	03-07-1992

Line Name : 021-10"-FDW-11

Component Name	Previous Name	Period Name	Period Start Date
FD11SP12 DS		RFO 13	02-12-1989
FD11SP13 DS		RFO 14	09-01-1990

Line Name : 022-08"-FDW-22A

Component Name	Previous Name	Period Name	Period Start Date
FD22SP02 DS		RFO 13	02-12-1989
FD22EL01		RFO 13	02-12-1989
FD22SP03 US		RFO 13	02-12-1989
FD22SP05		RFO 15	03-07-1992
FD22EL04		RFO 15	03-07-1992

FD22SP06	RFO 15	03-07-1992
FD22EL05	RFO 15	03-07-1992

Line Name : 023-05*-FDW ORIFICE RO63-3C

Component Name	Previous Name	Period Name	Period Start Date
FD22OR06A		RFO 15	03-07-1992
FD22OR06		RFO 15	03-07-1992
FD22OR06B		RFO 15	03-07-1992

Line Name : 023-08*-FDW-22B

Component Name	Previous Name	Period Name	Period Start Date
FD22SP13		RFO 15	03-07-1992
		RFO 16	08-28-1993
		RFO 17	03-18-1995
FD22TE04		RFO 15	03-07-1992
		RFO 16	08-28-1993
		RFO 17	03-18-1995

Line Name : 023-10*-FDW-23B

Component Name	Previous Name	Period Name	Period Start Date
FD23CP02		RFO 15	03-07-1992
FD23TE04		RFO 15	03-07-1992

Line Name : 032-20*-C-27

Component Name	Previous Name	Period Name	Period Start Date
CD27EL12		RFO 21	04-28-2001
CD27EL13		RFO 21	04-28-2001

Line Name : 034-20*-C-29

Component Name	Previous Name	Period Name	Period Start Date
CD29EL02		RFO 13	02-12-1989
		RFO 14	09-01-1990
CD29SP02 US		RFO 13	02-12-1989
CD29EL03		RFO 13	02-12-1989
CD29SP03 US		RFO 13	02-12-1989
CD29SP03 DS		RFO 13	02-12-1989

Line Name : 035-20*-C-30

Component Name	Previous Name	Period Name	Period Start Date
CD30EL02		RFO 21	04-28-2001
CD30EL03		RFO 21	04-28-2001
CD30SP01 US		RFO 21	04-28-2001

Line Name : 036-24*-C-30

Component Name	Previous Name	Period Name	Period Start Date
CD30SP03DS		RFO 24	04-03-2004
CD30TE02		RFO 24	04-03-2004
CD30SP04 US		RFO 24	04-03-2004
CD30SP04 DS		RFO 13	02-12-1989
CD30TE03		RFO 13	02-12-1989
CD30SP05 US		RFO 13	02-12-1989
CD30SP06		RFO 18	09-07-1996
CD30EL06		RFO 18	09-07-1996
CD30SP07		RFO 18	09-07-1996
CD30TE04		RFO 18	09-07-1996
CD30RD02		RFO 18	09-07-1996

Line Name : 037-20*-C-30

Component Name	Previous Name	Period Name	Period Start Date
CD30SP08 US		RFO 18	09-07-1996
CD30FE01A		RFO 13	02-12-1989
		RFO 25	10-08-2005
CD30EL11		RFO 13	02-12-1989
		RFO 25	10-08-2005
CD30SP12		RFO 13	02-12-1989
		RFO 25	10-08-2005
CD30EL12		RFO 13	02-12-1989

Line Name : 038-16*-C-31

Component Name	Previous Name	Period Name	Period Start Date
CD31EL06		RFO 18	09-07-1996

Line Name : 038-20"-C-31

Component Name	Previous Name	Period Name	Period Start Date
CD31FE01A		RFO 25	10-08-2005
CD31EL04		RFO 25	10-08-2005
CD31SP04		RFO 25	10-08-2005
CD31RD01		RFO 18	09-07-1996

Line Name : 039-20"-C-32

Component Name	Previous Name	Period Name	Period Start Date
CD30SP05		RFO 24	04-03-2004
CD32SP04		RFO 24	04-03-2004
CD32EL02		RFO 24	04-03-2004
CD32FE01		RFO 21	04-28-2001
CD32FE01A		RFO 21	04-28-2001
CD32EL04		RFO 21	04-28-2001
CD32SP02		RFO 21	04-28-2001
CD32EL05		RFO 21	04-28-2001

Line Name : 043-10"-HD-18A

Component Name	Previous Name	Period Name	Period Start Date
HD18RD02		RFO 16	08-28-1993
HD18SP02		RFO 16	08-28-1993

Line Name : 043-10"-HD-22A

Component Name	Previous Name	Period Name	Period Start Date
HD1ARD03		RFO 15	03-07-1992
HD1ASP14		RFO 15	03-07-1992
INLET E-2-1A		RFO 15	03-07-1992

Line Name : 044-10"-HD-03A

Component Name	Previous Name	Period Name	Period Start Date
HD3AEL01		RFO 23	10-06-2002
HD3ASP03 US		RFO 23	10-06-2002

Line Name : 044-16"-HD-19A

Component Name	Previous Name	Period Name	Period Start Date
HD19RD02		RFO 16	08-28-1993
HD19SP06		RFO 16	08-28-1993

Line Name : 044-16"-HD-23A

Component Name	Previous Name	Period Name	Period Start Date
HD3ARD03 (replacement)	HD3ASP06	RFO 14	09-01-1990
		RFO 14	09-01-1990

Line Name : 045-14"-HD-05A

Component Name	Previous Name	Period Name	Period Start Date
HD5AVA01		RFO 14	09-01-1990

Line Name : 045-14"-HD-06A

Component Name	Previous Name	Period Name	Period Start Date
HD6AVA01		RFO 14	09-01-1990

Line Name : 045-18"-HD-20A

Component Name	Previous Name	Period Name	Period Start Date
HD20VA01B		RFO 14	09-01-1990
HD20RD01		RFO 14	09-01-1990
HD20SP01		RFO 14	09-01-1990

X

Line Name : 045-20*-HD-24A

Component Name	Previous Name	Period Name	Period Start Date
(replacement)	HD5ARD03	RFO 14	09-01-1990
(replacement)	HD5ASP07	RFO 14	09-01-1990

Line Name : 046-16*-HD-07A

Component Name	Previous Name	Period Name	Period Start Date
HD7AEL04		RFO 23	10-06-2002
HD7ASP04		RFO 23	10-06-2002
HD7AVA02		RFO 14	09-01-1990

Line Name : 046-20*-HD-25A

Component Name	Previous Name	Period Name	Period Start Date
HD25VA02B		RFO 14	09-01-1990
HD25RD01		RFO 14	09-01-1990
HD25SP01		RFO 14	09-01-1990

Line Name : 050-06*-HD-01B

Component Name	Previous Name	Period Name	Period Start Date
HD1BEL03		RFO 23	10-06-2002
HD1BSP05		RFO 23	10-06-2002

Line Name : 050-10*-HD-18B

Component Name	Previous Name	Period Name	Period Start Date
HD18RD05		RFO 16	08-28-1993
HD18SP05		RFO 16	08-28-1993

Line Name : 050-10*-HD-22B

Component Name	Previous Name	Period Name	Period Start Date
HD1BRD03		RFO 16	08-28-1993
HD1BSP10		RFO 16	08-28-1993

Line Name : 052-14*-HD-05B

Component Name	Previous Name	Period Name	Period Start Date
HD5BSP01		RFO 23	10-06-2002
HD5BSP06 DS		RFO 23	10-06-2002
HD5BTE01		RFO 23	10-06-2002
HD5BSP07		RFO 23	10-06-2002

Line Name : 057-06*-HD-11A

Component Name	Previous Name	Period Name	Period Start Date
OUTLET MS-1-1A		RFO 14	09-01-1990
HD11RD01A		RFO 14	09-01-1990
HD11SP01		RFO 14	09-01-1990
HD11EL01		RFO 13	02-12-1989
		RFO 14	09-01-1990
HD11SP03		RFO 13	02-12-1989
		RFO 14	09-01-1990
HD11EL02		RFO 13	02-12-1989
HD11SP05 DS		RFO 13	02-12-1989
HD11EL04		RFO 14	09-01-1990
		RFO 13	02-12-1989
HD11EL05		RFO 14	09-01-1990
		RFO 13	02-12-1989
HD11EL06		RFO 14	09-01-1990
		RFO 13	02-12-1989
HD11SP06A		RFO 14	09-01-1990
HD11TE01		RFO 13	02-12-1989
HD11SP06B		RFO 13	02-12-1989

Line Name : 057-06*-HD-13A

Component Name	Previous Name	Period Name	Period Start Date
HD13EL01		RFO 13	02-12-1989
		RFO 17	03-18-1995
HD13SP02 DS		RFO 14	09-01-1990
HD13RD01		RFO 14	09-01-1990
		RFO 17	03-18-1995

HD13SP10 (replacement)	HD13SP10	RFO 17 RFO 14	03-18-1995 09-01-1990
---------------------------	----------	------------------	--------------------------

Line Name : 057-06*-HD-16A

Component Name	Previous Name	Period Name	Period Start Date
(replacement)	HD16SP01	RFO 13 RFO 14	02-12-1989 09-01-1990
(replacement)	HD16RD01	RFO 13 RFO 14	02-12-1989 09-01-1990
(replacement)	HD16TE01	RFO 13 RFO 14	02-12-1989 09-01-1990
(replacement)	HD16SP02 DS	RFO 13 RFO 14	02-12-1989 09-01-1990
(replacement)	HD16EL01	RFO 13 RFO 14	02-12-1989 09-01-1990
(replacement)	HD16SP03	RFO 13 RFO 14	02-12-1989 09-01-1990

Line Name : 058-06*-HD-11B

Component Name	Previous Name	Period Name	Period Start Date
HD11RD03A		RFO 15	03-07-1992
HD11SP07		RFO 15	03-07-1992
HD11RD03		RFO 15	03-07-1992

Line Name : 058-06*-HD-12B

Component Name	Previous Name	Period Name	Period Start Date
HD12EL06		RFO 13	02-12-1989
HD12SP07 US		RFO 13	02-12-1989

Line Name : 058-06*-HD-13B

Component Name	Previous Name	Period Name	Period Start Date
HD13SP04 DS		RFO 13	02-12-1989
HD13SP05 DS		RFO 14	09-01-1990
HD13RD02		RFO 14	09-01-1990
(replacement)	HD13SP11	RFO 14	09-01-1990

Line Name : 058-06*-HD-16B

Component Name	Previous Name	Period Name	Period Start Date
(replacement)	HD16SP04	RFO 14	09-01-1990
(replacement)	HD16RD02	RFO 14	09-01-1990
(replacement)	HD16TE02	RFO 14	09-01-1990
(replacement)	HD16SP05 US	RFO 14	09-01-1990
(replacement)	HD16EL02	RFO 14	09-01-1990
(replacement)	HD16SP06	RFO 14	09-01-1990

Line Name : 059-06*-HD-13C

Component Name	Previous Name	Period Name	Period Start Date
HD13SP07 DS		RFO 14	09-01-1990
HD13RD03		RFO 14	09-01-1990
(replacement)	HD13SP12	RFO 14	09-01-1990

Line Name : 059-06*-HD-16C

Component Name	Previous Name	Period Name	Period Start Date
(replacement)	HD16SP07	RFO 14	09-01-1990
(replacement)	HD16RD03	RFO 14	09-01-1990
(replacement)	HD16TE03	RFO 14	09-01-1990
(replacement)	HD16SP08 US	RFO 14	09-01-1990
(replacement)	HD16EL03	RFO 13	02-12-1989
(replacement)		RFO 14	09-01-1990
(replacement)	HD16SP09	RFO 14	09-01-1990

Line Name : 060-06*-HD-12D

Component Name	Previous Name	Period Name	Period Start Date
HD12EL20		RFO 23	10-06-2002
HD12SP20		RFO 23	10-06-2002
		RFO 17	03-18-1995
HD12EL22		RFO 23	10-06-2002
		RFO 13	02-12-1989
		RFO 17	03-18-1995
HD12SP21 US		RFO 13	02-12-1989
		RFO 17	03-18-1995

Line Name : 060-06*-HD-13D

Component Name	Previous Name	Period Name	Period Start Date
HD13SP09 DS		RFO 14	09-01-1990
HD13RD04		RFO 14	09-01-1990
(replacement)	HD13SP13	RFO 14	09-01-1990

Line Name : 060-06*-HD-16D

Component Name	Previous Name	Period Name	Period Start Date
(replacement)	HD16SP10	RFO 14	09-01-1990
(replacement)	HD16RD04	RFO 14	09-01-1990
(replacement)	HD16TE04	RFO 14	09-01-1990
(replacement)	HD16SP11 US	RFO 14	09-01-1990
(replacement)	HD16EL04	RFO 14	09-01-1990
(replacement)	HD16SF12	RFO 14	09-01-1990

Line Name : 061-06*-HD-12A

Component Name	Previous Name	Period Name	Period Start Date
HD12EL03		RFO 13	02-12-1989
HD12SP04		RFO 13	02-12-1989
		RFO 17	03-18-1995
HD12EL04		RFO 13	02-12-1989
		RFO 17	03-18-1995
HD12SP04A		RFO 13	02-12-1989
		RFO 17	03-18-1995
HD12VA01A		RFO 17	03-18-1995

Line Name : 061-14*-HD-15B

Component Name	Previous Name	Period Name	Period Start Date
HD15RD03		RFO 14	09-01-1990
HD15RD04		RFO 14	09-01-1990
HD15TE02		RFO 14	09-01-1990
HD15SP04 US		RFO 14	09-01-1990
HD15EL06		RFO 14	09-01-1990
HD15SP05		RFO 14	09-01-1990

Line Name : 062-06*-HD-12D

Component Name	Previous Name	Period Name	Period Start Date
HD12SP23		RFO 17	03-18-1995
HD12EL25		RFO 17	03-18-1995
HD12VA04A		RFO 17	03-18-1995

Line Name : 063-12*-ES-01A

Component Name	Previous Name	Period Name	Period Start Date
ES1ASP01 US		RFO 18	09-07-1996
		RFO 24	04-03-2004
ES1AEL01		RFO 18	09-07-1996
ES1AEL06		RFO 13	02-12-1989
ES1ASP08 DS		RFO 15	03-07-1992
ES1AEL08		RFO 15	03-07-1992
		RFO 19	03-21-1998
ES1ASP09		RFO 15	03-07-1992
		RFO 19	03-21-1998
ES1ARD01		RFO 15	03-07-1992
ES1ASP10		RFO 15	03-07-1992

Line Name : 064-12*-ES-01B

Component Name	Previous Name	Period Name	Period Start Date
ES1BEL01		RFO 13	02-12-1989
		RFO 18	09-07-1996
ES1BEL02		RFO 13	02-12-1989
		RFO 19	03-21-1998

Line Name : 065-10*-ES-02A

Component Name	Previous Name	Period Name	Period Start Date
(replacement)	ES2ASP01	RFO 15	03-07-1992
		RFO 16	08-28-1993
ES2ASP09 DS		RFO 15	03-07-1992
ES2AEL06		RFO 15	03-07-1992
ES2ASP10		RFO 15	03-07-1992

Line Name : 066-10*-ES-02B

Component Name	Previous Name	Period Name	Period Start Date
(replacement)	ES2BSP01	RFO 15	03-07-1992
		RFO 16	08-28-1993

Line Name : 068-20*-ES-03B

Component Name	Previous Name	Period Name	Period Start Date
ES3BEL05		RFO 13	02-12-1989
ES3BSP08		RFO 13	02-12-1989
ES3BEL06		RFO 13	02-12-1989
ES3BSP09 US		RFO 13	02-12-1989

Line Name : 070-20*-ES-04B

Component Name	Previous Name	Period Name	Period Start Date
(replacement)	ES4BSP02	RFO 15	03-07-1992
ES4BSP11		RFO 15	03-07-1992
ES4BEL08		RFO 15	03-07-1992
ES4BSP12		RFO 15	03-07-1992
ES4BSP13		RFO 15	03-07-1992
ES4BEL09		RFO 15	03-07-1992
ES4BSP14		RFO 15	03-07-1992

Line Name : 070-30*-ES-04B

Component Name	Previous Name	Period Name	Period Start Date
ES4BTE02		RFO 15	03-07-1992

Line Name : 071-26*-ES-05D

Component Name	Previous Name	Period Name	Period Start Date
(replacement)	ES5DSP01 US	RFO 15	03-07-1992
		RFO 16	08-28-1993
(replacement)	ES5DSP01 DS	RFO 15	03-07-1992
		RFO 16	08-28-1993

Line Name : 072-26*-ES-05E

Component Name	Previous Name	Period Name	Period Start Date
(replacement)	ES5ESP01 US	RFO 15	03-07-1992
(replacement)	INLET E-5-1B	RFO 13	02-12-1989

Line Name : 072-26*-ES-05F

Component Name	Previous Name	Period Name	Period Start Date
(replacement)	INLET E-5-1B	RFO 13	02-12-1989

Line Name : 073-12*-ES-06

Component Name	Previous Name	Period Name	Period Start Date
ES06EL01		RFO 16	08-28-1993
ES06SP01 US		RFO 16	08-28-1993
ES06TE01		RFO 16	08-28-1993
ES06SP03		RFO 16	08-28-1993
ES06EL03		RFO 16	08-28-1993
ES06SP04 US		RFO 16	08-28-1993
ES06EL06		RFO 15	03-07-1992
ES06SP08 US		RFO 15	03-07-1992
ES06SP08 DS		RFO 15	03-07-1992
ES06EL07		RFO 15	03-07-1992
ES06SP09		RFO 15	03-07-1992
ES06EL08		RFO 15	03-07-1992

Line Name : 074-18*-MS-07A

Component Name	Previous Name	Period Name	Period Start Date
MS7ASP09		RFO 16	08-28-1993
MS7AEL06		RFO 16	08-28-1993

Line Name : 080-18*-MS-01D

Component Name	Previous Name	Period Name	Period Start Date
----------------	---------------	-------------	-------------------

MS1DSP12 DS RFO 25 10-08-2005
MS1DEL07 RFO 25 10-08-2005

Line Name : 086-04*-CUW-55

Component Name Previous Name Period Name Period Start Date

CU55SP03 DS RFO 16 08-28-1993

Line Name : 086-04*-RCIC-08A

Component Name Previous Name Period Name Period Start Date

CU55SP05 DS RFO 16 08-28-1993
CU55TE01 RFO 16 08-28-1993
CU55SP04 US RFO 16 08-28-1993

DRAFT

 *** FAC Database: Plant Period Report ***

Period Name	Period Start Date	Period End Date	Period Type	Water Treatment Name	Power Level (%)	Operating Hours	Period Notes
Cycle 1	09-20-1972	01-17-1973	Operating	Normal 30 ppb	100.00	1082.2	Memo VY96-035.RPG Dated 5/2/96
45.09 EFP Days							
RFO 1	01-18-1973	02-28-1973	Maintenance	----	----	----	Memo VY96-035.RPG Dated 5/2/96
Cycle 1A	03-01-1973	09-29-1973	Operating	Normal 30 ppb	100.00	3086.2	Memo VY96-035.RPG Dated 5/2/96
128.59 EFP Days							
RFO 1A	09-30-1973	11-17-1973	Maintenance	----	----	----	Memo VY96-035.RPG Dated 5/2/96
Cycle 2	11-18-1973	10-12-1974	Operating	Normal 30 ppb	100.00	5420.4	Memo VY96-035.RPG Dated 5/2/96
225.85 EFP Days							
RFO 2	10-13-1974	12-11-1974	Maintenance	----	----	----	Memo VY96-035.RPG Dated 5/2/96
Cycle 3	12-12-1974	08-07-1975	Operating	Normal 30 ppb	100.00	4644.5	Memo VY96-035.RPG Dated 5/2/96
193.52 EFP Days							
RFO 3	08-08-1975	08-24-1975	Maintenance	----	----	----	Memo VY96-035.RPG Dated 5/2/96
Cycle 3A	08-25-1975	06-19-1976	Operating	Normal 30 ppb	100.00	6008.2	Memo VY96-035.RPG Dated 5/2/96
250.34 EFP Days							
RFO 3A	06-20-1976	08-06-1976	Maintenance	----	----	----	Memo VY96-035.RPG Dated 5/2/96
Cycle 4	08-07-1976	08-20-1977	Operating	Normal 30 ppb	100.00	8233.7	Memo VY96-035.RPG Dated 5/2/96
343.07 EFP Days							
RFO 4	08-21-1977	10-04-1977	Maintenance	----	----	----	Memo VY96-035.RPG Dated 5/2/96
Cycle 5	10-05-1977	09-16-1978	Operating	Normal 30 ppb	100.00	6650.2	Memo VY96-035.RPG Dated 5/2/96
277.09 EFP Days							
RFO 5	09-17-1978	10-09-1978	Maintenance	----	----	----	Memo VY96-035.RPG Dated 5/2/96
Cycle 6	10-10-1978	03-17-1979	Operating	Normal 30 ppb	100.00	3290.2	Memo VY96-035.RPG Dated 5/2/96
137.09 EFP Days							
RFO 6	03-18-1979	04-02-1979	Maintenance	----	----	----	Memo VY96-035.RPG Dated 5/2/96
Cycle 6A	04-03-1979	09-22-1979	Operating	Normal 30 ppb	100.00	3734.6	Memo VY96-035.RPG Dated 5/2/96
155.61 EFP Days							
RFO 6A	09-23-1979	11-02-1979	Maintenance	----	----	----	Memo VY96-035.RPG Dated 5/2/96
Cycle 7	11-03-1979	09-27-1980	Operating	Normal 30 ppb	100.00	7173.8	Memo VY96-035.RPG Dated 5/2/96
298.91 EFP Days							
RFO 7	09-28-1980	12-22-1980	Maintenance	----	----	----	Memo VY96-035.RPG Dated 5/2/96
Cycle 8	12-23-1980	10-16-1981	Operating	Normal 30 ppb	100.00	6614.6	Memo VY96-035.RPG Dated 5/2/96
275.61 EFP Days							
RFO 8	10-17-1981	11-30-1981	Maintenance	----	----	----	Memo VY96-035.RPG Dated 5/2/96
Cycle 9	12-01-1981	03-05-1983	Operating	Normal 30 ppb	100.00	9993.4	Memo VY96-035.RPG Dated 5/2/96
416.39 EFP Days							
RFO 9	03-06-1983	06-16-1983	Maintenance	----	----	----	Memo VY96-035.RPG Dated 5/2/96
Cycle 10	06-17-1983	06-15-1984	Operating	Normal 30 ppb	100.00	8201.0	Memo VY96-035.RPG Dated 5/2/96
341.71 EFP Days							
RFO 10	06-16-1984	08-05-1984	Maintenance	----	----	----	Memo VY96-035.RPG Dated 5/2/96
Cycle 11	08-06-1984	09-20-1985	Operating	Normal 30 ppb	100.00	8798.6	Memo VY96-035.RPG Dated 5/2/96
366.61 EFP Days							
RFO 11	09-21-1985	07-01-1986	Maintenance	----	----	----	Memo VY96-035.RPG Dated 5/2/96
Cycle 12	07-02-1986	08-07-1987	Operating	Normal 30 ppb	100.00	9116.9	Memo VY96-035.RPG Dated 5/2/96
379.87 EFP Days							
RFO 12	08-08-1987	10-01-1987	Maintenance	----	----	----	Memo VY96-035.RPG Dated 5/2/96
Cycle 13	10-02-1987	02-11-1989	Operating	Normal 30 ppb	100.00	10927.4	Memo VY96-035.RPG Dated 5/2/96
455.31 EFP Days							
RFO 13	02-12-1989	04-07-1989	Maintenance	----	----	----	Memo VY96-035.RPG Dated 5/2/96
Cycle 14	04-08-1989	08-31-1990	Operating	Normal 30 ppb	100.00	11638.6	Memo VY96-035.RPG Dated 5/2/96
484.94 EFP Days							
RFO 14	09-01-1990	10-13-1990	Maintenance	----	----	----	Memo VY96-035.RPG Dated 5/2/96
Cycle 15	10-14-1990	03-06-1992	Operating	Normal 30 ppb	100.00	11296.8	Memo VY96-035.RPG Dated 5/2/96
470.70 EFP Days							
RFO 15	03-07-1992	04-18-1992	Maintenance	----	----	----	Memo VY96-035.RPG Dated 5/2/96
Cycle 16	04-19-1992	08-27-1993	Operating	Normal 30 ppb	100.00	11359.4	Memo VY96-035.RPG Dated 5/2/96
473.31 EFP Days							
RFO 16	08-28-1993	10-23-1993	Maintenance	----	----	----	Memo VY96-035.RPG Dated 5/2/96
Cycle 17	10-24-1993	03-17-1995	Operating	35 ppb	100.00	11511.8	Memo VY96-035.RPG Dated 5/2/96
479.66 EFP Days							
RFO 17	03-18-1995	05-01-1995	Maintenance	----	----	----	Memo VY96-035.RPG Dated 5/2/96
Cycle 18	05-02-1995	09-06-1996	Operating	45 ppb	100.00	11570.0	Operating Hours taken from "N
RFO 18	09-07-1996	10-31-1996	Maintenance	----	----	----	
Cycle 19	11-01-1996	03-20-1998	Operating	Normal 30 ppb	100.00	11387.8	Operating hours taken from VYI
RFO 19	03-21-1998	05-31-1998	Maintenance	----	----	----	
Cycle 20	06-01-1998	10-29-1999	Operating	35 ppb	100.00	11878.2	Operating hours taken from VYI
RFO 20	10-30-1999	12-03-1999	Maintenance	----	----	----	
Cycle 21	12-04-1999	04-27-2001	Operating	35 ppb	100.00	12000.0	HRs estimated from VYAPF 0145.0
RFO 21	04-28-2001	05-18-2001	Maintenance	----	----	----	
Cycle 22	05-19-2001	05-11-2002	Operating	Normal 30 ppb	100.00	8300.0	Actual run 22A VYAPF 0145.02
RFO 22A	05-12-2002	05-20-2002	Maintenance	----	----	----	
Cycle 22B	05-21-2002	10-05-2002	Operating	35 ppb	100.00	3200.0	HRS estimated from VYAPF 0145.
RFO 23	10-06-2002	10-25-2002	Maintenance	----	----	----	
Cycle 23	11-01-2002	04-02-2004	Operating	35ppb NM-HWC	100.00	11500.0	
RFO 24	04-03-2004	05-03-2004	Maintenance	----	----	----	
Cycle 24	05-04-2004	10-07-2005	Operating	35ppb NM-HWC	100.00	11500.0	
RFO 25	10-08-2005	11-02-2005	Maintenance	----	----	----	
Cycle 25	11-03-2005	03-09-2007	Operating	35ppb NM-HWC	100.00	11500.0	
RFO 26	03-10-2007	04-04-2007	Maintenance	----	----	----	
Cycle 26	04-05-2007	10-24-2008	Operating	35ppb NM-HWC	100.00	11500.0	
RFO 27	10-25-2008	11-19-2008	Maintenance	----	----	----	
Cycle 27	11-20-2008	03-19-2010	Operating	35ppb NM-HWC	100.00	11500.0	
RFO 28	03-20-2010	04-14-2010	Maintenance	----	----	----	
Cycle 28	04-15-2010	10-07-2011	Operating	35ppb NM-HWC	100.00	11500.0	
RFO 29	10-08-2011	11-02-2011	Maintenance	----	----	----	
Cycle 29	11-03-2011	04-03-2013	Operating	35ppb NM-HWC	100.00	11500.0	

 *** FAC Database: Steam Cycle Report ***

Description	Flow Rate (Mlbm/hr)	Quality (%)	Enthalpy (Btu/lb)	Temp (F)	Pressure (psia)	Vent Rate (%)

==>Power Level (%): 100.00						
Feed Water Heater 1	----	----	----	373.10	----	0.50
Feed Water Heater 2	----	----	----	327.70	----	0.50
Feed Water Heater 3	----	----	----	294.70	----	0.50
Feed Water Heater 4	----	----	----	229.00	----	0.20
Feed Water Heater 5	----	----	----	163.10	----	0.16
Moisture Separator 1	0.7124	0.000	352.900	0.00	193.40	----
HP Extraction Steam Line1	0.3853	0.000	1094.900	0.00	203.40	----
LP Extraction Steam Line1	0.1545	0.000	1157.200	0.00	112.80	----
LP Extraction Steam Line2	0.3766	0.000	1114.500	0.00	70.30	----
LP Extraction Steam Line3	0.3714	0.000	993.600	0.00	23.60	----
LP Extraction Steam Line4	0.3265	0.000	722.000	0.00	6.05	----

DRAFT



Wear Rate Analysis Run Definition

Run Name: FDW06 2 P1s to Hdr.
Run Title: Feed Pump Disch. 2 pumps running

Ending Period: CYCLE 25
Total Oper. Hrs.: 241618.44
Duty Factor: 1.000

Analysis Options:
 Ignore NFA Results
 NFA Results 1st Priority
 User Input 1st Priority
 Do Not Use Measured Wear

Database Lines	Add	Line to Analyze
002-16"-FDW-02	>	001-16"-FDW-01
004-24"-FDW-01	>>	003-16"-FDW-03
005-18"-FDW-07	>>>	
006-18"-FDW-07	>>>	
007-18"-FDW-12	>>>	
008-16"-FDW-14	>>>	
008-18"-FDW-14	>>>	
009-16"-FDW-14	>>>	

Run Definitions:
 4th Pt Extract Steam
 4th Pt Heater Drain
 4th Pt High Level
 5th Pt Extract Steam
 5th Pt Heater Drains
 Cond LP Htr Bypass
 Cond Minimum Flow
 Cond2006 E3 to 3 FWP
 Cond2006 E4 to E3
 Condensate
 FDW 2006 E1s to Rx
 FDW 2006 Hdr to E2s
FDW06 2 P1s to Hdr.
 FDW06 3 P1s to Hdr
 FDW2006 E2s to E1s
 Feed Pump Recirc
 Feedwater
 Feedwater Flush
 Feedwater Low Flow

Buttons: < Prev, Next >, Add, Reset, Save, Copy, Delete, Print..., Help, Done, Advanced Run Def...


List of Defined Wear Rate Runs

6




DRAFT

Comparison of Wear Predictions



Comparison of Thickness Predictions



Company: Vermont Yankee Nuclear Power Corporation Report Date: 28-SEP-2006 Time: 08:17:42
 Plant: Vermont Yankee Analysis Date: 28-SEP-2006 Time: 08:08:51
 Unit: CHECWORKS FAC Version 1.0F (Build 52)
 OB Name: VY

 *** Wear Rate Analysis: Combined Summary Report ***

Run Name: FDW06 2 Pls to Hdr.
 Ending Period: CYCLE 25
 Total Plant Operating Hours: 241618 Duty Factor (Global): 1.000
 WRA Data Option: Ignore NFA Exclude Measure Wear: No
 Line Correction Factor: 0.175

Component Name	Geom. Code	Average Wear Rate (mils/year)	Current Wear Rate (mils/year)	Thickness (in)			Component Predict[1] Time to Tcrit (hrs)		Total Lifetime Wear (mils)		In-Service Cmp. Wear (mils)		In-Service Cmp. Tmeas Method Time		Time (hrs) Last Inspected	
				Init.	Prd.[1]	Thoop	Tcrit	Non-Insp.	Insp.	Prd.[2]	Meas.	Prd.[2]	Meas.	(in) [4]		[3] (hrs) [4]
====Grouped by Line: 001-16*-FDW-01, No Sorting.																
GUTLET P-1-1A	31	7.524	5.712	1.000	0.792	0.769	0.769	36668	-----	---	---	---	---	1.000	-- 0	
FD01RD01 (L/E)	18	3.370	2.559	1.219	1.024	0.964	0.964	204792	-----	---	---	---	---	1.031	MT 218618	
FD01RD01 (S/E)	18	4.213	3.199	1.000	0.898	0.769	0.769	353382	-----	---	---	---	---	0.906	MT 218618	
FD01EL01	4	4.157	3.156	1.219	1.066	0.964	0.964	-----	-----	281065	106.4	79.0	106.4	79.0	1.074	MT 218618 218618
FD01TE05 (U/S)	15	3.370	2.559	1.219	1.107	0.964	0.964	-----	-----	488964	86.2	122.0	86.2	122.0	1.114	MT 218618 218618
FD01TE05 (D.S)	15	3.370	2.559	1.219	1.003	0.964	0.964	-----	-----	132893	86.2	133.0	86.2	133.0	1.010	MT 218618 218618
FD01SP01	58	2.471	1.876	1.219	1.151	0.964	0.964	870091	-----	-----	---	---	---	1.219	-- 0	
FD01EL02	4	4.157	3.156	1.219	1.111	0.964	0.964	-----	-----	407759	88.0	88.0	88.0	88.0	1.138	MT 171740 171740
FD01SP02 US	54	3.595	2.729	1.219	1.096	0.964	0.964	422044	-----	-----	---	---	---	1.119	MT 171740	
FD01SP02 DS	54	3.595	2.729	1.219	1.104	0.964	0.964	-----	-----	449132	83.5	74.0	83.5	74.0	1.120	GW 195618 195618
FD01EL03	2	4.157	3.156	1.219	1.509	0.964	0.964	1511508	-----	-----	---	---	---	1.527	MT 195618	
FD01SP03 US	52	2.808	2.132	1.219	1.057	0.964	0.964	-----	-----	379381	65.3	48.0	65.3	48.0	1.069	MT 195618 195618
FD01SP03 DS	52	2.808	2.132	1.219	1.142	0.964	0.964	727489	-----	-----	---	---	---	1.219	-- 0	
FD01EL04	2	4.157	3.156	1.219	1.102	0.964	0.964	-----	-----	381002	106.4	19.0	106.4	19.0	1.110	MT 218618 218618
FD01SP04 US	52	2.808	2.132	1.219	1.059	0.964	0.964	-----	-----	390040	71.9	14.0	71.9	14.0	1.065	MT 218618 218618
FD01SP04 DS	52	2.808	2.132	1.219	1.142	0.964	0.964	727489	-----	-----	---	---	---	1.219	-- 0	
FD01EL05	2	4.157	3.156	1.219	1.104	0.964	0.964	388327	-----	-----	---	---	---	1.219	-- 0	
FD01SP05 US	52	2.808	2.132	1.219	1.142	0.964	0.964	727489	-----	-----	---	---	---	1.219	-- 0	
FD01SP05 DS	52	2.808	2.132	1.219	1.164	0.964	0.964	819621	-----	-----	---	---	---	1.204	MT 102975	

====Grouped by Line: 003-16*-FDW-03, No Sorting.

GUTLET P-1-1C	31	7.524	5.712	1.000	0.879	0.769	0.769	-----	-----	168617	167.0	112.0	167.0	112.0	0.919	MT 183618 183618
FD03RD01 (L/E)	18	3.370	2.559	1.219	1.040	0.964	0.964	-----	-----	258140	74.8	96.0	74.8	96.0	1.058	MT 183618 183618
FD03RD01 (S/E)	18	4.213	3.199	1.000	0.969	0.769	0.769	-----	-----	549800	93.5	139.0	93.5	139.0	0.992	MT 183618 183618
FD03EL01	4	4.157	3.156	1.219	1.204	0.964	0.964	-----	-----	663927	92.3	103.0	92.3	103.0	1.226	MT 183618 183618
FD03TE01 (U/S)	15	3.370	2.559	1.219	1.054	0.964	0.964	-----	-----	306073	74.8	37.0	74.8	37.0	1.072	GW 183618 183618
FD03TE01 (D.S)	15	3.370	2.559	1.219	1.071	0.964	0.964	-----	-----	364277	74.8	52.0	74.8	52.0	1.089	MT 183618 183618
FD03SP01	58	2.471	1.876	1.219	1.068	0.964	0.964	-----	-----	483714	63.2	146.0	63.2	146.0	1.073	GW 218618 218618
FD03EL02	4	4.157	3.156	1.219	1.115	0.964	0.964	418812	-----	-----	---	---	---	1.152	MT 148782	
FD03SP02 US	54	3.595	2.729	1.219	1.063	0.964	0.964	-----	-----	317199	67.4	118.0	67.4	118.0	1.095	GW 148782 148782
FD03SP02 DS	54	3.595	2.729	1.219	1.061	0.964	0.964	-----	-----	310375	53.3	109.0	53.3	109.0	1.107	MT 114614 114614
FD03EL03	1	3.707	2.814	1.219	1.432	0.964	0.964	-----	-----	1454905	86.2	38.0	86.2	38.0	1.348	MT 195618 195618
FD03SP03	51	2.471	1.876	1.219	1.166	0.964	0.964	-----	-----	943185	36.7	82.0	36.7	82.0	1.198	MT 114614 114614
FD03EL04	4	4.157	3.156	1.219	1.405	0.964	0.964	-----	-----	1222802	96.6	91.0	96.6	91.0	1.423	MT 195618 195618
FD03SP04 US	54	3.595	2.729	1.219	1.052	0.964	0.964	-----	-----	282223	83.5	33.0	83.5	33.0	1.068	MT 195618 195618
FD03SP04 DS	54	3.595	2.729	1.219	1.057	0.964	0.964	-----	-----	297940	67.4	130.0	67.4	130.0	1.089	MT 148782 148782
FD03EL05	2	4.157	3.156	1.219	1.234	0.964	0.964	-----	-----	749159	78.0	48.0	78.0	48.0	1.271	MT 148782 148782
FD03SP05	52	2.808	2.132	1.219	1.051	0.964	0.964	-----	-----	356452	52.7	33.0	52.7	33.0	1.076	MT 148782 148782
FD03EL06	4	4.157	3.156	1.219	1.441	0.964	0.964	-----	-----	1323795	78.0	96.0	78.0	96.0	1.478	MT 148782 148782
FD03SP06	54	3.595	2.729	1.219	0.972	0.964	0.964	-----	-----	25109	67.4	144.0	67.4	144.0	1.004	MT 148782 148782
FD03EL07	2	4.157	3.156	1.219	1.511	0.964	0.964	1516165	-----	-----	---	---	---	1.533	MT 183618	
FD03SP07 US	52	2.808	2.132	1.219	1.153	0.964	0.964	-----	-----	774123	62.4	69.0	62.4	69.0	1.168	GW 183618 183618
FD03SP07 DS	52	2.808	2.132	1.219	1.042	0.964	0.964	319761	-----	-----	---	---	---	1.074	MT 125911	

Notes:

- [1] Predictions are based on last Tmeas to analysis ending period.
- [2] Predictions are for the time of last inspection (last known meas. wear).
- [3] GW = Tmeas is minimum thickness from Band, Blanket or Area Method of greatest wear.
 MT = Tmeas is component minimum thickness.
 PW = Tmeas is Tinit - predicted wear.
 US = Tmeas is user specified.
- [4] If no Tmeas has been determined from measured data, then Tmeas = Tinit and Time = current component installation time.
 Tmeas is used to determine Predicted Thickness and Component Predicted Time to Tcrit.

 *** Wear Rate Analysis: Wear Predictions Report ***

Run Name: FDW06 2 P1s to Hdr.
 Ending Period: CYCLE 25
 Total Plant Operating Hours: 241618 Duty Factor (Global): 1.000
 WRA Data Option: Ignore NFA Exclude Measure Wear: No
 Line Correction Factor: 0.175

Component Name	Total Lifetime Wear (mils)		In-Service Wear (mils)		In-Service Tmeas, Method, Time			In-Service Thickness (mils) [4]		Incremental Wear (mils) [5] PRWEAR	Time (hrs) Last Inspected
	Prd. [1]	Meas.	Prd. [1]	Meas.	(in) [3]	[2]	(hrs) [3]	Th	Tm		
===>Grouped by Line: 001-16*-FDW-01, No Sorting.											
FD01EL01	106.4	79.0	106.4	79.0	1.074	MT	218618	1112.6	1074.0	8.3	218618
FD01TE05 (U/S)	86.2	122.0	86.2	122.0	1.114	MT	218618	1132.8	1114.0	6.7	218618
FD01TE05 (D/S)	86.2	133.0	86.2	133.0	1.010	MT	218618	1132.8	1010.0	6.7	218618
FD01EL02	88.0	88.0	88.0	88.0	1.138	MT	171740	1131.0	1138.0	26.6	171740
FD01SP02 DS	83.5	74.0	83.5	74.0	1.120	GW	195618	1135.5	1120.0	15.6	195618
FD01SP03 US	65.3	48.0	65.3	48.0	1.069	MT	195618	1153.7	1069.0	12.2	195618
FD01EL04	106.4	19.0	106.4	19.0	1.110	MT	218618	1112.6	1110.0	8.3	218618
FD01SP04 US	71.9	14.0	71.9	14.0	1.065	MT	218618	1147.1	1065.0	5.6	218618

===>Grouped by Line: 003-16*-FDW-03, No Sorting.											
OUTLET P-1-1C	167.0	112.0	167.0	112.0	0.919	MT	183618	833.0	919.0	40.5	183618
FD03RD01 (L/E)	74.8	96.0	74.8	96.0	1.058	MT	183618	1144.2	1058.0	18.1	183618
FD03RD01 (S/E)	93.5	139.0	93.5	139.0	0.992	MT	183618	906.5	992.0	22.7	183618
FD03EL01	92.3	103.0	92.3	103.0	1.226	MT	183618	1126.7	1226.0	22.4	183618
FD03TE01 (U/S)	74.8	37.0	74.8	37.0	1.072	GW	183618	1144.2	1072.0	18.1	183618
FD03TE01 (D/S)	74.8	52.0	74.8	52.0	1.089	MT	183618	1144.2	1089.0	18.1	183618
FD03SP01	63.2	146.0	63.2	146.0	1.073	GW	218618	1155.8	1073.0	4.9	218618
FD03SP02 US	67.4	118.0	67.4	118.0	1.095	GW	148782	1151.6	1095.0	31.7	148782
FD03SP02 DS	53.3	109.0	53.3	109.0	1.107	MT	114614	1165.7	1107.0	45.8	114614
FD03EL03	86.2	38.0	86.2	38.0	1.448	MT	195618	1132.8	1448.0	16.1	195618
FD03SP03	36.7	82.0	36.7	82.0	1.198	MT	114614	1182.3	1198.0	31.5	114614
FD03EL04	96.6	91.0	96.6	91.0	1.423	MT	195618	1122.4	1423.0	18.0	195618
FD03SP04 US	83.5	33.0	83.5	33.0	1.068	MT	195618	1135.5	1068.0	15.6	195618
FD03SP04 DS	67.4	130.0	67.4	130.0	1.089	MT	148782	1151.6	1089.0	31.7	148782
FD03EL05	78.0	48.0	78.0	48.0	1.271	MT	148782	1141.0	1271.0	36.7	148782
FD03SP05	52.7	33.0	52.7	33.0	1.076	MT	148782	1166.3	1076.0	24.8	148782
FD03EL06	78.0	96.0	78.0	96.0	1.478	MT	148782	1141.0	1478.0	36.7	148782
FD03SP06	67.4	144.0	67.4	144.0	1.004	MT	148782	1151.6	1004.0	31.7	148782
FD03SP07 US	62.4	69.0	62.4	69.0	1.168	GW	183618	1156.6	1168.0	15.1	183618

Notes:

- [1] Predictions are for the time of last inspection (last known meas. wear).
- [2] GW = Tmeas is minimum thickness from Band, Blanket or Area Method of greatest wear.
 MT = Tmeas is component minimum thickness.
 PW = Tmeas is Tinit - predicted wear.
 US = Tmeas is user specified.
- [3] If no Tmeas has been determined from measured data, then Tmeas = Tinit and Time = current component installation time. Tmeas is used to determine Predicted Thickness and Component Predicted Time to Tcrit.
- [4] These two values are used for thickness plot.
 Tp = Predicted thickness at Tmeas.
 Tm = Last measured thickness (Tmeas).
- [5] PRWEAR = Incremental wear from last Tmeas time to analysis ending period.

 *** Wear Rate Analysis: Combined Rankings for Inspection ***

Run Name: FDW06 2 Pls to Hdr.
 Ending Period: CYCLE 25
 Total Plant Operating Hours: 241618 Duty Factor (Global): 1.000
 WRA Data Option: Ignore NFA Exclude Measure Wear: No
 Line Correction Factor: 0.175

Component Name	Geometry Code	Average Wear Rate (mils/year)	Component Predicted Time to Tcrit (hrs)	
			Non-Inspected	Inspected
FD03EL03	1	3.707	-----	1454905
FD03EL04	4	4.157	-----	1222802
FD01RD01(S/E)	18	4.213	353382	-----
FD01SP02 US	54	3.595	422044	-----
OUTLET P-1-1C	31	7.524	-----	168617
OUTLET P-1-1A	31	7.524	36668	-----
FD03SP06	54	3.595	-----	25109
FD03RD01(S/E)	18	4.213	-----	549800
FD01TE05(D/S)	15	3.370	-----	132893
FD01EL01	4	4.157	-----	281065
FD01RD01(L/E)	18	3.370	204792	-----
FD01EL03	2	4.157	1511508	-----
FD03RD01(L/E)	18	3.370	-----	258140
FD03EL02	4	4.157	418812	-----
FD01EL02	4	4.157	-----	407759
FD03SP04 US	54	3.595	-----	282223
FD03EL07	2	4.157	1516165	-----
FD03SP04 DS	54	3.595	-----	297940
FD03EL05	2	4.157	-----	749159
FD03TE01(U/S)	15	3.370	-----	306073
FD03EL01	4	4.157	-----	663927
FD03SP02 DS	54	3.595	-----	310375
FD03SP02 US	54	3.595	-----	317199
FD01EL05	2	4.157	388327	-----
FD03SP07 DS	52	2.808	319761	-----
FD01EL04	2	4.157	-----	381002
FD03EL06	4	4.157	-----	1323795
FD03SP05	52	2.808	-----	356452
FD03TE01(D/S)	15	3.370	-----	364277
FD01SP03 US	52	2.808	-----	379381
FD01SP02 DS	54	3.595	-----	449132
FD01SP04 US	52	2.808	-----	390040
FD01TE05(U/S)	15	3.370	-----	488964
FD03SP01	58	2.471	-----	483714
FD01SP04 DS	52	2.808	727489	-----
FD01SP05 US	52	2.808	727489	-----
FD01SP03 DS	52	2.808	727489	-----
FD03SP07 US	52	2.808	-----	774123
FD01SP05 DS	52	2.808	819621	-----
FD01SP01	58	2.471	870091	-----
FD03SP03	51	2.471	-----	943185

 *** Wear Rate Analysis: Thickness/Service Time Report ***

Run Name: FDW06 2 Pls to Hdr.
 Ending Period: CYCLE 25
 Total Plant Operating Hours: 241618
 WRA Data Option: Ignore NFA
 Line Correction Factor: 0.175
 Duty Factor (Global): 1.000
 Exclude Measure Wear: No

Component Name	Thickness (in)				Component Predicted[1] Time to Tcrit (hrs)		Component Actual Service Time (hrs)
	Init.	Prd.[1]	Thoop	Tcrit	Non-Inspected	Inspected	
===>Grouped by Line: 001-16*-FDW-01, No Sorting.							
OUTLET P-1-1A	1.000	0.792	0.769	0.769	36668	-----	241618
FD01RD01(L/E)	1.219	1.024	0.964	0.964	204792	-----	241618
FD01RD01(S/E)	1.000	0.898	0.769	0.769	353382	-----	241618
FD01EL01	1.219	1.066	0.964	0.964	-----	281065	241618
FD01TE05(U/S)	1.219	1.107	0.964	0.964	-----	488964	241618
FD01TE05(D/S)	1.219	1.003	0.964	0.964	-----	132893	241618
FD01SP01	1.219	1.151	0.964	0.964	870091	-----	241618
FD01EL02	1.219	1.111	0.964	0.964	-----	407759	241618
FD01SP02 US	1.219	1.096	0.964	0.964	422044	-----	241618
FD01SP02 DS	1.219	1.104	0.964	0.964	-----	449132	241618
FD01EL03	1.219	1.509	0.964	0.964	1511508	-----	241618
FD01SP03 US	1.219	1.057	0.964	0.964	-----	379381	241618
FD01SP03 DS	1.219	1.142	0.964	0.964	727489	-----	241618
FD01EL04	1.219	1.102	0.964	0.964	-----	381002	241618
FD01SP04 US	1.219	1.059	0.964	0.964	-----	390040	241618
FD01SP04 DS	1.219	1.142	0.964	0.964	727489	-----	241618
FD01EL05	1.219	1.104	0.964	0.964	-----	388327	241618
FD01SP05 US	1.219	1.142	0.964	0.964	727489	-----	241618
FD01SP05 DS	1.219	1.164	0.964	0.964	819621	-----	241618

===>Grouped by Line: 003-16*-FDW-03, No Sorting.							
OUTLET P-1-1C	1.000	0.879	0.769	0.769	-----	168617	241618
FD03RD01(L/E)	1.219	1.040	0.964	0.964	-----	258140	241618
FD03RD01(S/E)	1.000	0.969	0.769	0.769	-----	549800	241618
FD03EL01	1.219	1.204	0.964	0.964	-----	663927	241618
FD03TE01(U/S)	1.219	1.054	0.964	0.964	-----	306073	241618
FD03TE01(D/S)	1.219	1.071	0.964	0.964	-----	364277	241618
FD03SP01	1.219	1.068	0.964	0.964	-----	483714	241618
FD03EL02	1.219	1.115	0.964	0.964	418812	-----	241618
FD03SP02 US	1.219	1.063	0.964	0.964	-----	317199	241618
FD03SP02 DS	1.219	1.061	0.964	0.964	-----	310375	241618
FD03EL03	1.219	1.432	0.964	0.964	-----	1454905	241618
FD03SP03	1.219	1.166	0.964	0.964	-----	943185	241618
FD03EL04	1.219	1.405	0.964	0.964	-----	1222802	241618
FD03SP04 US	1.219	1.052	0.964	0.964	-----	282223	241618
FD03SP04 DS	1.219	1.057	0.964	0.964	-----	297940	241618
FD03EL05	1.219	1.234	0.964	0.964	-----	749159	241618
FD03SP05	1.219	1.051	0.964	0.964	-----	356452	241618
FD03EL06	1.219	1.441	0.964	0.964	-----	1323795	241618
FD03SP06	1.219	0.972	0.964	0.964	-----	25109	241618
FD03EL07	1.219	1.511	0.964	0.964	1516165	-----	241618
FD03SP07 US	1.219	1.153	0.964	0.964	-----	774123	241618
FD03SP07 DS	1.219	1.042	0.964	0.964	319761	-----	241618

Note:
 [1] Predictions are based on last Tmeas to analysis ending period.

*** Wear Rate Analysis: Inspection History Report ***

Run Name: FDW06 2 Pls to Hdr.
 Ending Period: CYCLE 25
 Total Plant Operating Hours: 241618 Duty Factor (Global): 1.000
 WRA Data Option: Ignore NFA Exclude Measure Wear: No
 Line Correction Factor: 0.175

Component Name	Geom. Code	No.	Material				Sigma (psi)	Time (hrs)		Analysis Option	Measured Wear (mils)
			Cr. (%)	Cu. (%)	Mo. (%)	Last Inspected		Replaced			
===>Grouped by Line: 001-16*-FDW-01, No Sorting.											
OUTLET P-1-1A	31	5	0.00	0.00	0.00	15000	-----	-----		---	
FD01RD01 (L/E)	18	21	0.00	0.00	0.00	15000	-----	-----	Excl LCF	---	
FD01RD01 (S/E)	18	21	0.00	0.00	0.00	15000	-----	-----	Excl LCF	---	
FD01EL01	4	21	0.00	0.00	0.00	15000	218618	-----		79	
FD01TE05 (U/S)	15	5	0.00	0.00	0.00	15000	218618	-----		121	
FD01TE05 (D/S)	15	5	0.00	0.00	0.00	15000	218618	-----		133	
FD01SP01	58	5	0.00	0.00	0.00	15000	-----	-----		---	
FD01EL02	4	21	0.00	0.00	0.00	15000	171740	-----		88	
FD01SP02 US	54	5	0.00	0.00	0.00	15000	-----	-----	Excl LCF	---	
FD01SP02 DS	54	5	0.00	0.00	0.00	15000	195618	-----		73	
FD01EL03	2	21	0.00	0.00	0.00	15000	-----	-----	Excl LCF	---	
FD01SP03 US	52	5	0.00	0.00	0.00	15000	195618	-----		48	
FD01SP03 DS	52	5	0.00	0.00	0.00	15000	-----	-----		---	
FD01EL04	2	21	0.00	0.00	0.00	15000	218618	-----		19	
FD01SP04 US	52	5	0.00	0.00	0.00	15000	218618	-----		14	
FD01SP04 DS	52	5	0.00	0.00	0.00	15000	-----	-----		---	
FD01EL05	2	21	0.00	0.00	0.00	15000	-----	-----		---	
FD01SP05 US	52	5	0.00	0.00	0.00	15000	-----	-----		---	
FD01SP05 DS	52	5	0.00	0.00	0.00	15000	-----	-----		---	

===>Grouped by Line: 003-16*-FDW-03, No Sorting.											
OUTLET P-1-1C	31	5	0.00	0.00	0.00	15000	183618	-----		112	
FD03RD01 (L/E)	18	21	0.00	0.00	0.00	15000	183618	-----		96	
FD03RD01 (S/E)	18	21	0.00	0.00	0.00	15000	183618	-----		139	
FD03EL01	4	21	0.00	0.00	0.00	15000	183618	-----		103	
FD03TE01 (U/S)	15	5	0.00	0.00	0.00	15000	183618	-----		37	
FD03TE01 (D/S)	15	5	0.00	0.00	0.00	15000	183618	-----		52	
FD03SP01	58	5	0.00	0.00	0.00	15000	218618	-----		146	
FD03EL02	4	21	0.00	0.00	0.00	15000	-----	-----		---	
FD03SP02 US	54	5	0.00	0.00	0.00	15000	148782	-----		117	
FD03SP02 DS	54	5	0.00	0.00	0.00	15000	114614	-----		109	
FD03EL03	1	21	0.00	0.00	0.00	15000	195618	-----		38	
FD03SP03	51	5	0.00	0.00	0.00	15000	114614	-----		82	
FD03EL04	4	21	0.00	0.00	0.00	15000	195618	-----		91	
FD03SP04 US	54	5	0.00	0.00	0.00	15000	195618	-----		33	
FD03SP04 DS	54	5	0.00	0.00	0.00	15000	148782	-----		129	
FD03EL05	2	21	0.00	0.00	0.00	15000	148782	-----		48	
FD03SP05	52	5	0.00	0.00	0.00	15000	148782	-----		33	
FD03EL06	4	21	0.00	0.00	0.00	15000	148782	-----		96	
FD03SP06	54	5	0.00	0.00	0.00	15000	148782	-----		144	
FD03EL07	2	21	0.00	0.00	0.00	15000	-----	-----		---	
FD03SP07 US	52	5	0.00	0.00	0.00	15000	183618	-----		69	
FD03SP07 DS	52	5	0.00	0.00	0.00	15000	-----	-----		---	

 *** Wear Rate Analysis: Wear Rates/ Input Data Report ***

Run Name: FDW06 2 Pls to Hdr.
 Ending Period: CYCLE 25
 Total Plant Operating Hours: 241618 Duty Factor (Global): 1.000
 WRA Data Option: Ignore NFA Exclude Measure Wear: No
 Line Correction Factor: 0.175


Component Name	Geom. Code	Average Wear Rate (mils/year)	Current Wear Rate (mils/year)	Temp. (F)	Velocity (ft/s)	Steam Quality	Diameter (in)
===>Grouped by Line: 001-16*-FDW-01, No Sorting.							
OUTLET P-1-1A	31	7.524	5.712	296.9	24.599	0.000	12.750
FD01RD01(L/E)	18	3.370	2.559	296.9	15.456	0.000	16.000
FD01RD01(S/E)	18	4.213	3.199	296.9	24.599	0.000	12.750
FD01EL01	4	4.157	3.156	296.9	15.456	0.000	16.000
FD01TE05(U/S)	15	3.370	2.559	296.9	15.456	0.000	16.000
FD01TE05(D/S)	15	3.370	2.559	296.9	15.456	0.000	16.000
FD01SP01	58	2.471	1.876	296.9	15.456	0.000	16.000
FD01EL02	4	4.157	3.156	296.9	15.456	0.000	16.000
FD01SP02 US	54	3.595	2.729	296.9	15.456	0.000	16.000
FD01SP02 DS	54	3.595	2.729	296.9	15.456	0.000	16.000
FD01EL03	2	4.157	3.156	296.9	15.456	0.000	16.000
FD01SP03 US	52	2.808	2.132	296.9	15.456	0.000	16.000
FD01SP03 DS	52	2.808	2.132	296.9	15.456	0.000	16.000
FD01EL04	2	4.157	3.156	296.9	15.456	0.000	16.000
FD01SP04 US	52	2.808	2.132	296.9	15.456	0.000	16.000
FD01SP04 DS	52	2.808	2.132	296.9	15.456	0.000	16.000
FD01EL05	2	4.157	3.156	296.9	15.456	0.000	16.000
FD01SP05 US	52	2.808	2.132	296.9	15.456	0.000	16.000
FD01SP05 DS	52	2.808	2.132	296.9	15.456	0.000	16.000

===>Grouped by Line: 003-16*-FDW-03, No Sorting.							
OUTLET P-1-1C	31	7.524	5.712	296.9	24.599	0.000	12.750
FD03RD01(L/E)	18	3.370	2.559	296.9	15.456	0.000	16.000
FD03RD01(S/E)	18	4.213	3.199	296.9	24.599	0.000	12.750
FD03EL01	4	4.157	3.156	296.9	15.456	0.000	16.000
FD03TE01(U/S)	15	3.370	2.559	296.9	15.456	0.000	16.000
FD03TE01(D/S)	15	3.370	2.559	296.9	15.456	0.000	16.000
FD03SP01	58	2.471	1.876	296.9	15.456	0.000	16.000
FD03EL02	4	4.157	3.156	296.9	15.456	0.000	16.000
FD03SP02 US	54	3.595	2.729	296.9	15.456	0.000	16.000
FD03SP02 DS	54	3.595	2.729	296.9	15.456	0.000	16.000
FD03EL03	1	3.707	2.814	296.9	15.456	0.000	16.000
FD03SP03	51	2.471	1.876	296.9	15.456	0.000	16.000
FD03EL04	4	4.157	3.156	296.9	15.456	0.000	16.000
FD03SP04 US	54	3.595	2.729	296.9	15.456	0.000	16.000
FD03SP04 DS	54	3.595	2.729	296.9	15.456	0.000	16.000
FD03EL05	2	4.157	3.156	296.9	15.456	0.000	16.000
FD03SP05	52	2.808	2.132	296.9	15.456	0.000	16.000
FD03EL06	4	4.157	3.156	296.9	15.456	0.000	16.000
FD03SP06	54	3.595	2.729	296.9	15.456	0.000	16.000
FD03EL07	2	4.157	3.156	296.9	15.456	0.000	16.000
FD03SP07 US	52	2.808	2.132	296.9	15.456	0.000	16.000
FD03SP07 DS	52	2.808	2.132	296.9	15.456	0.000	16.000


DO NOT

Cumulative % of Comp. Time to Tcrit

FDW06 2 P1s to Hdr.



Tpred/Tcrit Ratio Plot



Flow Accelerated Corrosion (FAC)

File Edit Analysis Tasks Preferences Window Help

- [] X



Wear Rate Analysis Run Definition

Run Name: **FDW06 3-P1s to Hdr**

Run Title: **Feed Pump Disch. 3 pumps running**

Ending Period: **CYCLE 25**

Total Oper. Hrs.: **241618.44**

Duty Factor: **1.000**

Analysis Options

- Ignore NFA Results
- NFA Results 1st Priority
- User Input 1st Priority
- Do Not Use Measured Wear

Database Lines	Add	Lines to Analyze
001-24"-FDW-01	>	001-16"-FDW-01
005-18"-FDW-07	>>	003-16"-FDW-03
006-18"-FDW-07	>>	002-16"-FDW-02
007-18"-FDW-12	>>	
008-16"-FDW-14	>>	
008-18"-FDW-14	>>	
009-16"-FDW-14	>>	
009-16"-FDW-16	>>	

Run Definitions

- Cond Minimum Flow
- Condensate
- FDW 2006 E1s to Rx
- FDW 2006 Hdr to E2s
- FDW06 2 P1s to Hdr.
- FDW06 3-P1s to Hdr**
- FDW2006 E2s to E1s
- Feed Pump Recirc
- Feedwater
- Feedwater Flush
- Feedwater Low Flow
- Heater Drain Pumps
- Main Steam 2006
- Moist Sep High Level
- Moist Separator Drn
- Reactor Cleanup
- Steam Seal Regulator
- TEST - FDWpumpsto E2
- XP Test Feedwater

< Prev Next > Add Reset Save


Copy Delete Print... Help Done

Advanced Run Def...


12

Wear [] X

Comparison of Wear Predictions



Comparison of Wear Predictions



Company: Vermont Yankee Nuclear Power Corporation Report Date: 27-SEP-2006 Time: 12:47:05
 Plant: Vermont Yankee Analysis Date: 27-SEP-2006 Time: 12:40:33
 Unit: CHECWORKS FAC Version 1.0F (Build 52)
 Db Name: VY

 *** Wear Rate Analysis: Combined Summary Report

Run Name: FDW06 3-Pls to Hdr
 Ending Period: CYCLE 25
 Total Plant Operating Hours: 241618 Duty Factor (Global): 1.000
 NFA Data Option: Ignore NFA Exclude Measure Wear: No
 Line Correction Factor: 0.170

Component Name	Geom. Code	Average Wear Rate (mils/year)	Current Wear Rate (mils/year)	Thickness (in)			Component Predict(1) Time to Tcrit (hrs)		Total Lifetime Wear (mils)		In-Service Cmp. Wear (mils)		In-Service Cmp. Tmeas, Method, Time (in) [4] [3] (hrs) [4]		Time (hrs) Last Inspected
				Init.	Prd. [1]	Thoop	Tcrit	Non-Insps.	Insps.	Prd. [2]	Meas.	Prd. [2]	Meas.	(in) [4]	
=== Grouped by Line: 001-16*-FDW-01, No Sorting.															
OUTLET P-1 1A	31	7.306	5.547	1.000	0.798	0.769	0.769	47266	-----	---	---	---	1.000	--	0
FD01RD01 (L/E)	18	3.272	2.484	1.219	1.024	0.964	0.964	211594	-----	---	---	---	1.031	MT	218618
FD01ED01 (S/E)	18	4.091	3.106	1.000	0.898	0.769	0.769	364620	-----	---	---	---	0.906	MT	218618
FD01EL01	4	4.036	3.064	1.219	1.066	0.964	0.964	290144	103.3	79.0	103.3	79.0	1.074	MT	218618
FD01TE05 (U/S)	15	3.272	2.484	1.219	1.107	0.964	0.964	504251	83.7	122.0	83.7	122.0	1.114	MT	218618
FD01TE05 (D/S)	15	3.272	2.484	1.219	1.003	0.964	0.964	137548	83.7	133.0	83.7	133.0	1.010	MT	218618
FD01SP01	58	2.400	1.822	1.219	1.153	0.964	0.964	905575	-----	---	---	---	1.219	--	0
FD01EL02	4	4.036	3.064	1.219	1.112	0.964	0.964	422143	85.4	88.0	85.4	88.0	1.138	MT	171740
FD01SP02 US	54	3.491	2.650	1.219	1.097	0.964	0.964	436854	-----	---	---	---	1.119	MT	171740
FD01SP02 DS	54	3.491	2.650	1.219	1.105	0.964	0.964	464038	81.1	74.0	81.1	74.0	1.120	GW	195618
FD01EL03	2	4.036	3.064	1.219	1.509	0.964	0.964	1558136	-----	---	---	---	1.527	MT	195618
FD01SP03 US	52	2.727	2.070	1.219	1.057	0.964	0.964	392205	63.4	48.0	63.4	48.0	1.069	MT	195618
FD01SP03 DS	52	2.727	2.070	1.219	1.144	0.964	0.964	758714	-----	---	---	---	1.219	--	0
FD01EL04	2	4.036	3.064	1.219	1.102	0.964	0.964	393065	103.3	19.0	103.3	19.0	1.110	MT	218618
FD01SP04 US	52	2.727	2.070	1.219	1.060	0.964	0.964	402373	69.8	14.0	69.8	14.0	1.065	MT	218618
FD01SP04 DS	52	2.727	2.070	1.219	1.144	0.964	0.964	758714	-----	---	---	---	1.219	--	0
FD01EL05	2	4.036	3.064	1.219	1.108	0.964	0.964	409425	-----	---	---	---	1.219	--	0
FD01SP05 US	52	2.727	2.070	1.219	1.144	0.964	0.964	758714	-----	---	---	---	1.219	--	0
FD01SP05 DS	52	2.727	2.070	1.219	1.165	0.964	0.964	849006	-----	---	---	---	1.204	MT	102975

=== Grouped by Line: 003-16*-FDW-03, No Sorting.

OUTLET P-1-1C	31	7.306	5.547	1.000	0.880	0.769	0.769	175505	162.2	112.0	162.2	112.0	0.919	MT	183618
FD03RD01 (L/E)	18	3.272	2.484	1.219	1.040	0.964	0.964	267702	72.7	96.0	72.7	96.0	1.058	MT	183618
FD03ED01 (S/E)	18	4.091	3.106	1.000	0.970	0.769	0.769	568071	90.8	139.0	90.8	139.0	0.992	MT	183618
FD03EL01	4	4.036	3.064	1.219	1.204	0.964	0.964	685605	89.6	103.0	89.6	103.0	1.226	MT	183618
FD03TE01 (U/S)	15	3.272	2.484	1.219	1.054	0.964	0.964	317066	72.7	37.0	72.7	37.0	1.072	GW	183618
FD03TE01 (D/S)	15	3.272	2.484	1.219	1.071	0.964	0.964	377008	72.7	52.0	72.7	52.0	1.089	MT	183618
FD03SP01	58	2.400	1.822	1.219	1.068	0.964	0.964	498844	61.4	146.0	61.4	146.0	1.073	GW	218618
FD03EL02	4	4.036	3.064	1.219	1.116	0.964	0.964	434357	-----	---	---	---	1.152	MT	148782
FD03SP02 US	54	3.491	2.650	1.219	1.064	0.964	0.964	329709	65.5	118.0	65.5	118.0	1.095	GW	148782
FD03SP02 DS	54	3.491	2.650	1.219	1.062	0.964	0.964	324035	51.8	109.0	51.8	109.0	1.107	MT	114614
FD03EL03	1	3.600	2.733	1.219	1.432	0.964	0.964	1499843	83.7	38.0	83.7	38.0	1.448	MT	195618
FD03SP03	51	2.400	1.822	1.219	1.167	0.964	0.964	975741	35.6	82.0	35.6	82.0	1.198	MT	114614
FD03EL04	4	4.036	3.064	1.219	1.405	0.964	0.964	1260810	93.8	91.0	93.8	91.0	1.423	MT	195618
FD03SP04 US	54	3.491	2.650	1.219	1.053	0.964	0.964	292146	81.1	33.0	81.1	33.0	1.068	MT	195618
FD03SP04 DS	54	3.491	2.650	1.219	1.058	0.964	0.964	309875	65.5	130.0	65.5	130.0	1.089	MT	148782
FD03EL05	2	4.036	3.064	1.219	1.235	0.964	0.964	774567	75.7	48.0	75.7	48.0	1.271	MT	148782
FD03SP05	52	2.727	2.070	1.219	1.052	0.964	0.964	370134	51.2	33.0	51.2	33.0	1.076	MT	148782
FD03EL06	4	4.036	3.064	1.219	1.442	0.964	0.964	1366361	75.7	96.0	75.7	96.0	1.478	MT	148782
FD03SP06	54	3.491	2.650	1.219	0.973	0.964	0.964	28898	65.5	144.0	65.5	144.0	1.004	MT	148782
FD03EL07	2	4.036	3.064	1.219	1.511	0.964	0.964	1563290	-----	---	---	---	1.533	MT	183618
FD03SP07 US	52	2.727	2.070	1.219	1.153	0.964	0.964	799092	60.5	69.0	60.5	69.0	1.168	GW	183618
FD03SP07 DS	52	2.727	2.070	1.219	1.043	0.964	0.964	333198	-----	---	---	---	1.074	MT	125911

=== Grouped by Line: 002-16*-FDW-02, No Sorting.


OUTLET P-1-1B	31	7.306	5.547	1.000	0.830	0.769	0.769	96538	162.2	199.0	162.2	199.0	0.869	MT	183618
FD02RD01 (L/E)	18	3.272	2.484	1.219	1.019	0.964	0.964	193964	72.7	10.0	72.7	10.0	1.026	MT	218618
FD02ED01 (S/E)	18	4.091	3.106	1.000	1.044	0.769	0.769	776381	90.8	8.0	90.8	8.0	1.052	MT	218618
FD02EL01	4	4.036	3.064	1.219	1.179	0.964	0.964	613201	-----	---	---	---	1.187	MT	218618
FD02TE01 (U/S)	15	3.272	2.484	1.219	1.079	0.964	0.964	405523	61.4	12.0	61.4	12.0	1.086	MT	218618
FD02TE01 (D/S)	15	3.272	2.484	1.219	0.979	0.964	0.964	52925	61.4	12.0	61.4	12.0	0.986	MT	218618
FD02SP01	58	2.400	1.822	1.219	1.153	0.964	0.964	905575	-----	---	---	---	1.219	--	0
FD02EL02	4	4.036	3.064	1.219	1.102	0.964	0.964	393996	89.6	132.0	89.6	132.0	1.124	MT	183618
FD02SP02 US	54	3.491	2.650	1.219	1.046	0.964	0.964	270230	77.5	39.0	77.5	39.0	1.065	MT	183618
FD02SP02 DS	54	3.491	2.650	1.219	1.026	0.964	0.964	207067	56.8	30.0	56.8	30.0	1.065	MT	125911

FDG2EL03	3	4.036	3.064	1.219	1.402	0.964	0.964	-----	1252120	65.8	100.0	65.8	100.0	1.148	MT	125911	125911
FDG2SP03 US	52	2.727	2.070	1.219	1.060	0.964	0.964	-----	405128	44.4	7.0	44.4	7.0	1.091	MT	125911	125911
FDG2SP03 DS	52	2.727	2.070	1.219	1.144	0.964	0.964	758714	-----	---	---	---	---	1.219	--	0	-----
FDG2EL04	2	4.036	3.064	1.219	1.108	0.964	0.964	409425	-----	---	---	---	---	1.219	--	0	-----
FDG2SP04 US	52	2.727	2.070	1.219	1.144	0.964	0.964	758714	-----	---	---	---	---	1.219	--	0	-----
FDG2SP04 DS	52	2.727	2.070	1.319	1.139	0.964	0.964	-----	740592	53.7	100.0	53.7	100.0	1.161	GW	160352	160352
FDG2EL05	2	4.036	3.064	1.219	1.387	0.964	0.964	1208492	-----	---	---	---	---	1.419	MT	160352	-----
FDG2SP05 US	52	2.727	2.070	1.219	1.162	0.964	0.964	-----	837909	53.7	93.0	53.7	93.0	1.184	GW	160352	160352
FDG2SP05 DS	52	2.727	2.070	1.219	1.044	0.964	0.964	-----	336284	51.2	95.0	51.2	95.0	1.068	MT	148782	148782

Notes:

- [1] Predictions are based on last Tmeas to analysis ending period.
- [2] Predictions are for the time of last inspection (last known meas. wear).
- [3] GW = Tmeas is minimum thickness from Band, Blanket or Area Method of greatest wear.
 MT = Tmeas is component minimum thickness.
 PW = Tmeas is Tinit - predicted wear.
 US = Tmeas is user specified.
- [4] If no Tmeas has been determined from measured data, then Tmeas = Tinit and Time = current component installation time.
 Tmeas is used to determine Predicted Thickness and Component Predicted Time to Tcrit.

Comparison of Thickness Predictions



 *** Wear Rate Analysis: Wear Predictions Report ***

Run Name: FDW06 3-Pls to Hdr
 Ending Period: CYCLE 25
 Total Plant Operating Hours: 24161R Duty Factor (Global): 1.000
 WRA Data Option: Ignore NFA Exclude Measure Wear: No
 Line Correction Factor: 0.170

Component Name	Total Lifetime In-Service Cmp. Wear (mils)		In-Service Cmp. Tmeas, Method, Time		In-Service Cmp. Thickness(mils) [4]		Incremental PRWEAR	Time (hrs) Last Inspected
	Prd. [1]	Meas.	Prd. [1]	Meas.	TP	Tm		

====>Grouped by Line: 001-16*-FDW-01. No Sorting.

FD01EL01	103.3	79.0	103.3	79.0	1.074	MT	218618	1115.7	1074.0	8.0	218618
FD01TE05 (U/S)	83.7	122.0	83.7	122.0	1.114	MT	218618	1135.3	1114.0	6.5	218618
FD01TE05 (D/S)	83.7	133.0	83.7	133.0	1.010	MT	218618	1135.3	1010.0	6.5	218618
FD01EL02	85.4	88.0	85.4	88.0	1.138	MT	171740	1133.6	1138.0	25.9	171740
FD01SP02 DS	81.1	74.0	81.1	74.0	1.120	GW	195618	1137.9	1120.0	15.2	195618
FD01SP03 US	63.4	48.0	63.4	48.0	1.069	MT	195618	1155.6	1069.0	11.8	195618
FD01EL04	103.3	19.0	103.3	19.0	1.110	MT	218618	1115.7	1110.0	8.0	218618
FD01SP04 US	69.8	14.0	69.8	14.0	1.065	MT	218618	1149.2	1065.0	5.4	218618

====>Grouped by Line: 003-16*-FDW-03. No Sorting.

OUTLET P-1-1C	162.2	112.0	162.2	112.0	0.919	MT	183618	837.8	919.0	39.3	183618
FD03RD01 (L/E)	72.7	96.0	72.7	96.0	1.058	MT	183618	1146.3	1058.0	17.6	183618
FD03RD01 (S/E)	90.8	139.0	90.8	139.0	0.992	MT	183618	909.2	992.0	22.0	183618
FD03EL01	89.6	103.0	89.6	103.0	1.226	MT	183618	1129.4	1226.0	21.7	183618
FD03TE01 (U/S)	72.7	37.0	72.7	37.0	1.072	GW	183618	1146.3	1072.0	17.6	183618
FD03TE01 (D/S)	72.7	52.0	72.7	52.0	1.089	MT	183618	1146.3	1089.0	17.6	183618
FD03SP01	61.4	146.0	61.4	146.0	1.073	GW	218618	1157.6	1073.0	4.8	218618
FD03SP02 US	65.5	118.0	65.5	118.0	1.095	GW	148782	1153.5	1095.0	30.8	148782
FD03SP02 DS	51.8	109.0	51.8	109.0	1.107	MT	114614	1167.2	1107.0	44.5	114614
FD03EL03	83.7	38.0	83.7	38.0	1.448	MT	195618	1135.3	1448.0	15.6	195618
FD03SP03	35.6	82.0	35.6	82.0	1.198	MT	114614	1183.4	1198.0	30.6	114614
FD03EL04	93.8	91.0	93.8	91.0	1.423	MT	195618	1125.2	1423.0	17.5	195618
FD03SP04 US	81.1	33.0	81.1	33.0	1.068	MT	195618	1137.9	1068.0	15.2	195618
FD03SP04 DS	65.5	130.0	65.5	130.0	1.089	MT	148782	1153.5	1089.0	30.8	148782
FD03EL05	75.7	48.0	75.7	48.0	1.271	MT	148782	1143.3	1271.0	35.6	148782
FD03SP05	51.2	33.0	51.2	33.0	1.076	MT	148782	1167.8	1076.0	24.1	148782
FD03EL06	75.7	96.0	75.7	96.0	1.478	MT	148782	1143.3	1478.0	35.6	148782
FD03SP06	65.5	144.0	65.5	144.0	1.004	MT	148782	1153.5	1004.0	30.8	148782
FD03SP07 US	60.5	69.0	60.5	69.0	1.168	GW	183618	1158.5	1168.0	14.7	183618

====>Grouped by Line: 002-16*-FDW-02. No Sorting.

OUTLET P-1-1B	162.2	199.0	162.2	199.0	0.869	MT	183618	837.8	869.0	39.3	183618
FD02RD01 (L/E)	72.7	10.0	72.7	10.0	1.026	MT	218618	1146.3	1026.0	6.5	183618
FD02RD01 (S/E)	90.8	8.0	90.8	8.0	1.052	MT	218618	909.2	1052.0	8.2	183618
FD02TE01 (U/S)	61.4	12.0	61.4	12.0	1.086	MT	218618	1157.6	1086.0	6.5	148782
FD02TE01 (D/S)	61.4	12.0	61.4	12.0	0.986	MT	218618	1157.6	986.0	6.5	148782
FD02EL02	89.6	132.0	89.6	132.0	1.124	MT	183618	1129.4	1124.0	21.7	183618
FD02SP02 US	77.5	39.0	77.5	39.0	1.065	MT	183618	1141.5	1065.0	18.8	183618
FD02SP02 DS	56.9	30.0	56.9	30.0	1.065	MT	125911	1162.1	1065.0	39.4	125911
FD02EL03	65.8	100.0	65.8	100.0	1.448	MT	125911	1153.2	1448.0	45.6	125911
FD02SP03 US	44.4	7.0	44.4	7.0	1.091	MT	125911	1174.6	1091.0	30.8	125911
FD02SP04 DS	53.7	100.0	53.7	100.0	1.161	GW	160352	1165.3	1161.0	21.5	160352
FD02SP05 US	53.7	93.0	53.7	93.0	1.184	GW	160352	1165.3	1184.0	21.5	160352
FD02SP05 DS	51.2	95.0	51.2	95.0	1.068	MT	148782	1167.8	1068.0	24.1	148782

- Notes:
- [1] Predictions are for the time of last inspection (last known meas. wear).
 - [2] GW = Tmeas is minimum thickness from Band, Blanket or Area Method of greatest wear.
 MT = Tmeas is component minimum thickness.
 PW = Tmeas is Tinit - predicted wear.
 US = Tmeas is user specified.
 - [3] If no Tmeas has been determined from measured data, then Tmeas = Tinit and Time = current component installation time.
 Tmeas is used to determine Predicted Thickness and Component Predicted Time to Tcrit.
 - [4] These two values are used for thickness plot.
 Tp = Predicted thickness at Tmeas.
 Tm = Last measured thickness (Tmeas).
 - [5] PRWEAR = Incremental wear from last Tmeas time to analysis ending period.

 *** Wear Rate Analysis: Combined Rankings for Inspection ***

Run Name: FDW06 3-P1s to Hdr
 Ending Period: CYCLE 25
 Total Plant Operating Hours: 241618 Duty Factor (Global): 1.000
 WRA Data Option: Ignore NFA Exclude Measure Wear: No
 Line Correction Factor: 0.175

Component Name	Geometry Code	Average Wear Rate (mils./year)	Component Predicted Time to Tcrit (hrs)	
			Non-Inspected	Inspected
FD03EL03	1	3.600	-----	1499843
FD03EL04	4	4.036	-----	1260810
FD02RD01 (S/E)	18	4.091	-----	776381
FD02SP02 US	54	3.491	-----	270230
OUTLET P-1-1C	31	7.306	-----	175505
OUTLET P-1-1A	31	7.306	47266	-----
FD03SP06	54	3.491	-----	28898
OUTLET P-1-1B	31	7.306	-----	96538
FD02TE01 (D/S)	15	3.272	-----	52925
FD03RD01 (S/E)	18	4.091	-----	568071
FD01TE05 (D/S)	15	3.272	-----	137548
FD01RD01 (S/E)	18	4.091	364620	-----
FD01EL01	4	4.036	-----	290144
FD02RD01 (L/E)	18	3.272	-----	193964
FD02SP02 DS	54	3.491	-----	202067
FD02EL05	2	4.036	1208492	-----
FD01RD01 (L/E)	18	3.272	211594	-----
FD02EL04	2	4.036	409425	-----
FD03RD01 (L/E)	18	3.272	-----	267702
FD01EL02	4	4.036	-----	422143
FD03EL07	2	4.036	1563290	-----
FD03EL05	2	4.036	-----	774567
FD03SP04 US	54	3.491	-----	292146
FD01EL03	2	4.036	1558136	-----
FD03SP04 DS	54	3.491	-----	309875
FD02EL01	4	4.036	613201	-----
FDG3TE01 (U/S)	15	3.272	-----	317066
FD03EL01	4	4.036	-----	685605
FD03SP02 DS	54	3.491	-----	324035
FD01EL05	2	4.036	409425	-----
FD03SP02 US	54	3.491	-----	329709
FD02EL02	4	4.036	-----	393996
FD03SP07 DS	52	2.727	333198	-----
FD03EL02	4	4.036	434357	-----
FD02SP05 DS	52	2.727	-----	336284
FD03EL06	4	4.036	-----	1366361
FD02EL03	2	4.036	-----	1252120
FD03SF05	52	2.727	-----	370134
FD01EL04	2	4.036	-----	393065
FD03TE01 (D/S)	15	3.272	-----	377008
FD01SP03 US	52	2.727	-----	392205
FD01SP02 DS	54	3.491	-----	464038
FD01SP04 US	52	2.727	-----	402373
FD01SP02 US	54	3.491	436854	-----
FDG2SP03 US	52	2.727	-----	405128
FD02TE01 (U/S)	15	3.272	-----	405523
FDG3SP01	58	2.400	-----	498844
FD01TE05 (U/S)	15	3.272	-----	504251
FD02SP04 DS	52	2.727	-----	740592
FD01SP05 US	52	2.727	758714	-----
FD02SP04 US	52	2.727	758714	-----
FD01SF03 DS	52	2.727	758714	-----
FD01SP04 DS	52	2.727	758714	-----
FD02SP03 DS	52	2.727	758714	-----
FD03SP07 US	52	2.727	-----	799092
FD01SP05 DS	52	2.727	849006	-----
FD02SP05 US	52	2.727	-----	837909
FD01SP01	58	2.400	905575	-----
FD02SP01	58	2.400	905575	-----
FD03SP03	51	2.400	-----	975741

*** Wear Rate Analysis: Thickness/Service Time Report ***

Run Name: FDW06 3-Pls to Hdr
 Ending Period: CYCLE 25
 Total Plant Operating Hours: 241618 Duty Factor (Global): 1.000
 WRA Data Option: Ignore NFA Exclude Measure Wear: No
 Line Correction Factor: 0.170

Component Name	----- Thickness (in) -----				Component Predicted(1)		Component Actual Service Time (hrs)
	Init.	Prd. (1)	Thoop	Tcrit	Time to Tcrit (hrs)	Non-Inspected Inspected	
===>Grouped by Line: 001-16*-FDW-01, No Sorting.							
OUTLET P-1-1A	1.000	0.798	0.769	0.769	47266	-----	241618
FD01RD01 (L/E)	1.219	1.024	0.964	0.964	211594	-----	241618
FD01RD01 (S/E)	1.000	0.898	0.769	0.769	364620	-----	241618
FD01EL01	1.219	1.066	0.964	0.964	-----	290144	241618
FD01TE05 (U/S)	1.219	1.107	0.964	0.964	-----	504251	241618
FD01TE05 (D/S)	1.219	1.003	0.964	0.964	-----	137548	241618
FD01SP01	1.219	1.153	0.964	0.964	905575	-----	241618
FD01EL02	1.219	1.112	0.964	0.964	-----	422143	241618
FD01SP02 US	1.219	1.097	0.964	0.964	436854	-----	241618
FD01SP02 DS	1.219	1.105	0.964	0.964	-----	464038	241618
FD01EL03	1.219	1.509	0.964	0.964	1558136	-----	241618
FD01SP03 US	1.219	1.057	0.964	0.964	-----	392205	241618
FD01SP03 DS	1.219	1.144	0.964	0.964	758714	-----	241618
FD01EL04	1.219	1.102	0.964	0.964	-----	393065	241618
FD01SP04 US	1.219	1.060	0.964	0.964	-----	402373	241618
FD01SP04 DS	1.219	1.144	0.964	0.964	758714	-----	241618
FD01EL05	1.219	1.108	0.964	0.964	409425	-----	241618
FD01SP05 US	1.219	1.144	0.964	0.964	758714	-----	241618
FD01SP05 DS	1.219	1.165	0.964	0.964	849006	-----	241618

===>Grouped by Line: 003-16*-FDW-03, No Sorting.							
OUTLET P-1-1C	1.000	0.880	0.769	0.769	-----	176505	241618
FD03RD01 (L/E)	1.219	1.040	0.964	0.964	-----	267702	241618
FD03RD01 (S/E)	1.000	0.970	0.769	0.769	-----	568071	241618
FD03EL01	1.219	1.204	0.964	0.964	-----	685605	241618
FD03TE01 (U/S)	1.219	1.054	0.964	0.964	-----	317066	241618
FD03TE01 (D/S)	1.219	1.071	0.964	0.964	-----	377008	241618
FD03SP01	1.219	1.068	0.964	0.964	-----	498844	241618
FD03EL02	1.219	1.116	0.964	0.964	434357	-----	241618
FD03SP02 US	1.219	1.064	0.964	0.964	-----	329709	241618
FD03SP02 DS	1.219	1.062	0.964	0.964	-----	324035	241618
FD03EL03	1.219	1.432	0.964	0.964	-----	1499843	241618
FD03SP03	1.219	1.167	0.964	0.964	-----	975741	241618
FD03EL04	1.219	1.405	0.964	0.964	-----	1260810	241618
FD03SP04 US	1.219	1.053	0.964	0.964	-----	292146	241618
FD03SP04 DS	1.219	1.058	0.964	0.964	-----	309875	241618
FD03EL05	1.219	1.235	0.964	0.964	-----	774567	241618
FD03SP05	1.219	1.052	0.964	0.964	-----	370134	241618
FD03EL06	1.219	1.442	0.964	0.964	-----	1366361	241618
FD03SP06	1.219	0.973	0.964	0.964	-----	28898	241618
FD03EL07	1.219	1.511	0.964	0.964	1563290	-----	241618
FD03SP07 US	1.219	1.153	0.964	0.964	-----	799092	241618
FD03SP07 DS	1.219	1.043	0.964	0.964	333198	-----	241618

===>Grouped by Line: 002-16*-FDW-02, No Sorting.							
OUTLET P-1-1B	1.000	0.830	0.769	0.769	-----	96538	241618
FD02RD01 (L/E)	1.219	1.019	0.964	0.964	-----	193964	241618
FD02RD01 (S/E)	1.000	1.044	0.769	0.769	-----	776381	241618
FD02EL01	1.219	1.179	0.964	0.964	613201	-----	241618
FD02TE01 (U/S)	1.219	1.079	0.964	0.964	-----	405523	241618
FD02TE01 (D/S)	1.219	0.979	0.964	0.964	-----	52925	241618
FD02SP01	1.219	1.153	0.964	0.964	905575	-----	241618
FD02EL02	1.219	1.102	0.964	0.964	-----	393996	241618
FD02SP02 US	1.219	1.046	0.964	0.964	-----	270230	241618
FD02SP02 DS	1.219	1.026	0.964	0.964	-----	302067	241618
FD02EL03	1.219	1.402	0.964	0.964	-----	1252120	241618
FD02SP03 US	1.219	1.060	0.964	0.964	-----	405128	241618
FD02SP03 DS	1.219	1.144	0.964	0.964	758714	-----	241618
FD02EL04	1.219	1.108	0.964	0.964	409425	-----	241618
FD02SP04 US	1.219	1.144	0.964	0.964	758714	-----	241618
FD02SP04 DS	1.219	1.139	0.964	0.964	-----	740592	241618
FD02EL05	1.219	1.387	0.964	0.964	1208492	-----	241618
FD02SP05 US	1.219	1.162	0.964	0.964	-----	337909	241618
FD02SP05 DS	1.219	1.044	0.964	0.964	-----	336284	241618

Note:
 (1) Predictions are based on last Tmeas to analysis ending period.

 *** Wear Rate Analysis: Inspection History Report ***

Fun Name: FDW06 3-Pls no Hdr
 Ending Period: CYCLE 25
 Total Plant Operating Hours: 241618 Duty Factor (Global): 1.000
 WRA Data Option: Ignore MFA Exclude Measure Wear: No
 Line Correction Factor: 0.170

Component Name	Geom. Code	Material				Sigma (psi)	Time (hrs)		Analysis Option	Measured Wear (mils)
		Cr. No.	Cr. (%)	Cu. (%)	Mo. (%)		Last Inspected	Replaced		
===>Grouped by Line: 001-16*-FDW-01, No Sorting.										
OUTLET P-1-1A	31	5	0.00	0.00	0.00	15000	-----	-----	---	---
FD01RD01 (L/E)	18	21	0.00	0.00	0.00	15000	-----	-----	Excl LCF	---
FD01RD01 (S/E)	18	21	0.00	0.00	0.00	15000	-----	-----	Excl LCF	---
FD01EL01	4	21	0.00	0.00	0.00	15000	218618	-----	-----	79
FD01TE05 (U/S)	15	5	0.00	0.00	0.00	15000	218618	-----	-----	121
FD01TE05 (D/S)	15	5	0.00	0.00	0.00	15000	218618	-----	-----	133
FD01SP01	58	5	0.00	0.00	0.00	15000	-----	-----	-----	---
FD01EL02	4	21	0.00	0.00	0.00	15000	171740	-----	-----	88
FD01SP02 US	54	5	0.00	0.00	0.00	15000	-----	-----	Excl LCF	---
FD01SP02 DS	54	5	0.00	0.00	0.00	15000	195618	-----	-----	73
FD01EL03	2	21	0.00	0.00	0.00	15000	-----	-----	Excl LCF	---
FD01SP03 US	52	5	0.00	0.00	0.00	15000	195618	-----	-----	48
FD01SP03 DS	52	5	0.00	0.00	0.00	15000	-----	-----	-----	---
FD01EL04	2	21	0.00	0.00	0.00	15000	218618	-----	-----	19
FD01SP04 US	52	5	0.00	0.00	0.00	15000	218618	-----	-----	14
FD01SP04 DS	52	5	0.00	0.00	0.00	15000	-----	-----	-----	---
FD01EL05	2	21	0.00	0.00	0.00	15000	-----	-----	-----	---
FD01SP05 US	52	5	0.00	0.00	0.00	15000	-----	-----	-----	---
FD01SP05 DS	52	5	0.00	0.00	0.00	15000	-----	-----	-----	---

===>Grouped by Line: 003-16*-FDW-03, No Sorting.										
OUTLET P-1-1C	31	5	0.00	0.00	0.00	15000	183618	-----	-----	112
FD03RD01 (L/E)	18	21	0.00	0.00	0.00	15000	183618	-----	-----	96
FD03RD01 (S/E)	18	21	0.00	0.00	0.00	15000	183618	-----	-----	139
FD03EL01	4	21	0.00	0.00	0.00	15000	183618	-----	-----	103
FD03TE01 (U/S)	15	5	0.00	0.00	0.00	15000	183618	-----	-----	37
FD03TE01 (D/S)	15	5	0.00	0.00	0.00	15000	183618	-----	-----	52
FD03SP01	58	5	0.00	0.00	0.00	15000	218618	-----	-----	146
FD03EL02	4	21	0.00	0.00	0.00	15000	-----	-----	-----	---
FD03SP02 US	54	5	0.00	0.00	0.00	15000	148782	-----	-----	117
FD03SP02 DS	54	5	0.00	0.00	0.00	15000	114614	-----	-----	109
FD03EL03	1	21	0.00	0.00	0.00	15000	195618	-----	-----	38
FD03SP03	51	5	0.00	0.00	0.00	15000	114614	-----	-----	82
FD03EL04	4	21	0.00	0.00	0.00	15000	195618	-----	-----	91
FD03SP04 US	54	5	0.00	0.00	0.00	15000	195618	-----	-----	33
FD03SP04 DS	54	5	0.00	0.00	0.00	15000	148782	-----	-----	129
FD03EL05	2	21	0.00	0.00	0.00	15000	148782	-----	-----	48
FD03SP05	52	5	0.00	0.00	0.00	15000	148782	-----	-----	33
FD03EL06	4	21	0.00	0.00	0.00	15000	148782	-----	-----	96
FD03SP06	54	5	0.00	0.00	0.00	15000	148782	-----	-----	144
FD03EL07	2	21	0.00	0.00	0.00	15000	-----	-----	-----	---
FD03SP07 US	52	5	0.00	0.00	0.00	15000	183618	-----	-----	69
FD03SP07 DS	52	5	0.00	0.00	0.00	15000	-----	-----	-----	---

===>Grouped by Line: 002-16*-FDW-02, No Sorting.										
OUTLET P-1-1B	31	5	0.00	0.00	0.00	15000	183618	-----	-----	198
FD02RD01 (L/E)	18	21	0.00	0.00	0.00	15000	183618	-----	-----	10
FD02RD01 (S/E)	18	21	0.00	0.00	0.00	15000	183618	-----	-----	8
FD02EL01	4	21	0.00	0.00	0.00	15000	-----	-----	Excl LCF	---
FD02TE01 (U/S)	15	5	0.00	0.00	0.00	15000	148782	-----	-----	12
FD02TE01 (D/S)	15	5	0.00	0.00	0.00	15000	148782	-----	-----	12
FD02SP01	58	5	0.00	0.00	0.00	15000	-----	-----	-----	---
FD02EL02	4	21	0.00	0.00	0.00	15000	183618	-----	-----	132
FD02SP02 US	54	5	0.00	0.00	0.00	15000	183618	-----	-----	39
FD02SP02 DS	54	5	0.00	0.00	0.00	15000	125911	-----	-----	30
FD02EL03	2	21	0.00	0.00	0.00	15000	125911	-----	-----	100
FD02SP03 US	52	5	0.00	0.00	0.00	15000	125911	-----	-----	6
FD02SP03 DS	52	5	0.00	0.00	0.00	15000	-----	-----	-----	---
FD02EL04	2	21	0.00	0.00	0.00	15000	-----	-----	-----	---
FD02SP04 US	52	5	0.00	0.00	0.00	15000	-----	-----	-----	---
FD02SP04 DS	52	5	0.00	0.00	0.00	15000	160352	-----	-----	100
FD02EL05	2	21	0.00	0.00	0.00	15000	-----	-----	-----	---
FD02SP05 US	52	5	0.00	0.00	0.00	15000	160352	-----	-----	93
FD02SP05 DS	52	5	0.00	0.00	0.00	15000	148782	-----	-----	95

 *** Wear Rate Analysis: Wear Rates/Input Data Report ***


Run Name: FDW06 3-Pls to Hdr
 Ending Period: CYCLE 25
 Total Plant Operating Hours: 241618 Duty Factor (Global): 1.000
 WPA Data Option: Ignore NFA Exclude Measure Wear: No
 Line Correction Factor: 3.170

Component Name	Geom. Code	Average Wear Rate (mils/year)	Current Wear Rate (mils/year)	Temp. (F)	Velocity (ft/s)	Steam Quality	Diameter (in)
===>Grouped by Line: 001-16*-FDW-01, No Sorting.							
OUTLET P-1-1A	31	7.306	5.547	296.9	24.599	0.000	12.750
FD01RD01 (L/E)	18	3.272	2.484	296.9	15.456	0.000	16.000
FD01RD01 (S/E)	18	4.091	3.106	296.9	24.599	0.000	12.750
FD01EL01	4	4.036	3.064	296.9	15.456	0.000	16.000
FD01TE05 (U/S)	15	3.272	2.484	296.9	15.456	0.000	16.000
FD01TE05 (D/S)	15	3.272	2.484	296.9	15.456	0.000	16.000
FD01SP01	58	2.400	1.822	296.9	15.456	0.000	16.000
FD01EL02	4	4.036	3.064	296.9	15.456	0.000	16.000
FD01SP02 US	54	3.491	2.650	296.9	15.456	0.000	16.000
FD01SP02 DS	54	3.491	2.650	296.9	15.456	0.000	16.000
FD01EL03	2	4.036	3.064	296.9	15.456	0.000	16.000
FD01SP03 US	52	2.727	2.070	296.9	15.456	0.000	16.000
FD01SP03 DS	52	2.727	2.070	296.9	15.456	0.000	16.000
FD01EL04	2	4.036	3.064	296.9	15.456	0.000	16.000
FD01SP04 US	52	2.727	2.070	296.9	15.456	0.000	16.000
FD01SP04 DS	52	2.727	2.070	296.9	15.456	0.000	16.000
FD01EL05	2	4.036	3.064	296.9	15.456	0.000	16.000
FD01SP05 US	52	2.727	2.070	296.9	15.456	0.000	16.000
FD01SP05 DS	52	2.727	2.070	296.9	15.456	0.000	16.000

===>Grouped by Line: 003-16*-FDW-03, No Sorting.							
OUTLET P-1-1C	31	7.306	5.547	296.9	24.599	0.000	12.750
FD03RD01 (L/E)	18	3.272	2.484	296.9	15.456	0.000	16.000
FD03RD01 (S/E)	18	4.091	3.106	296.9	24.599	0.000	12.750
FD03EL01	4	4.036	3.064	296.9	15.456	0.000	16.000
FD03TE01 (U/S)	15	3.272	2.484	296.9	15.456	0.000	16.000
FD03TE01 (D/S)	15	3.272	2.484	296.9	15.456	0.000	16.000
FD03SP01	58	2.400	1.822	296.9	15.456	0.000	16.000
FD03EL02	4	4.036	3.064	296.9	15.456	0.000	16.000
FD03SP02 US	54	3.491	2.650	296.9	15.456	0.000	16.000
FD03SP02 DS	54	3.491	2.650	296.9	15.456	0.000	16.000
FD03EL03	1	3.600	2.733	296.9	15.456	0.000	16.000
FD03SP03	51	2.400	1.822	296.9	15.456	0.000	16.000
FD03EL04	4	4.036	3.064	296.9	15.456	0.000	16.000
FD03SP04 US	54	3.491	2.650	296.9	15.456	0.000	16.000
FD03SP04 DS	54	3.491	2.650	296.9	15.456	0.000	16.000
FD03EL05	2	4.036	3.064	296.9	15.456	0.000	16.000
FD03SP05	52	2.727	2.070	296.9	15.456	0.000	16.000
FD03EL06	4	4.036	3.064	296.9	15.456	0.000	16.000
FD03EP06	54	3.491	2.650	296.9	15.456	0.000	16.000
FD03EL07	2	4.036	3.064	296.9	15.456	0.000	16.000
FD03SP07 US	52	2.727	2.070	296.9	15.456	0.000	16.000
FD03SP07 DS	52	2.727	2.070	296.9	15.456	0.000	16.000


===>Grouped by Line: 002-16*-FDW-02, No Sorting.							
OUTLET P-1-1B	31	7.306	5.547	296.9	24.599	0.000	12.750
FD02RD01 (L/E)	18	3.272	2.484	296.9	15.456	0.000	16.000
FD02RD01 (S/E)	18	4.091	3.106	296.9	24.599	0.000	12.750
FD02EL01	4	4.036	3.064	296.9	15.456	0.000	16.000
FD02TE01 (U/S)	15	3.272	2.484	296.9	15.456	0.000	16.000
FD02TE01 (D/S)	15	3.272	2.484	296.9	15.456	0.000	16.000
FD02SP01	58	2.400	1.822	296.9	15.456	0.000	16.000
FD02EL02	4	4.036	3.064	296.9	15.456	0.000	16.000
FD02SP02 US	54	3.491	2.650	296.9	15.456	0.000	16.000
FD02SP02 DS	54	3.491	2.650	296.9	15.456	0.000	16.000
FD02EL03	2	4.036	3.064	296.9	15.456	0.000	16.000
FD02SP03 US	52	2.727	2.070	296.9	15.456	0.000	16.000
FD02SP03 DS	52	2.727	2.070	296.9	15.456	0.000	16.000
FD02EL04	2	4.036	3.064	296.9	15.456	0.000	16.000
FD02SP04 US	52	2.727	2.070	296.9	15.456	0.000	16.000
FD02SP04 DS	52	2.727	2.070	296.9	15.456	0.000	16.000
FD02EL05	2	4.036	3.064	296.9	15.456	0.000	16.000
FD02SP05 US	52	2.727	2.070	296.9	15.456	0.000	16.000
FD02SP05 DS	52	2.727	2.070	296.9	15.456	0.000	16.000

Tpred/Tcrit Ratio Plot



Cumulative % of Comp. Time to Tcrit

FDW06 3-P1s to Hdr





Wear Rate Analysis Run Definition

Run Name: FDW 2006 Hdr to E2s
 Run Title: Feedwater Header to E2A and E2B

Ending Period: CYCLE 25
 Total Oper. Hrs.: 241618.44
 Duty Factor: 1.000

Analysis Options

- Ignore IFA Results
- IFA Results 1st Priority
- User Input 1st Priority
- Do Not Use Measured Wear

Database Lines	Add	Lines to Analyze
001-16"-FDW-01	>	004-24"-FDW-01
002-16"-FDW-02	>>	005-18"-FDW-07
003-16"-FDW-03	>>>	006-18"-FDW-07
007-18"-FDW-12	>>>	011-18"-FDW-08
008-16"-FDW-14	>>>	012-18"-FDW-08
008-18"-FDW-14	<	
009-16"-FDW-14	<<	
009-16"-FDW-16	<<<	

Run Definitions

- 3rd Pt High Level
- 4th Pt Extract Steam
- 4th Pt Heater Drain
- 4th Pt High Level
- 5th Pt Extract Steam
- 5th Pt Heater Drains
- Cond LP Htr Bypass
- Cond Minimum Flow
- Condensate
- FDW 2006 E1s to Rx
- FDW 2006 Hdr to E2s**
- FDW06 2 P1s to Hdr.
- FDW06 3-P1s to Hdr
- FDW2006 E2s to E1s
- Feed Pump Recirc
- Feedwater
- Feedwater Flush
- Feedwater Low Flow
- Heater Drain Pumps

< Prev Next > Add Reset Save


Copy Delete Print... Help Done

Advanced Run Def...


ch



Comparison of Wear Predictions



Comparison of Thickness Predictions



 *** Wear Rate Analysis: Combined Summary Report

Run Name: FDW 2006 Hdr to E2s
 Loading Period: CYCLE 25
 Total Plant Operating Hours: 241618 Duty Factor (Global): 1.000
 WMA Data Option: Ignore NFA Exclude Measure Wear: No
 Line Correction Factor: 0.222

Component Name	Geom. Code	Average		Current		Thickness (in)			Component Predict[1]		Total Lifetime		In-Service Cmp.		In-Service Cmp.		Time (hrs) Last Inspected	
		Wear Rate (mils/year)	Wear Rate (mils/year)	Wear Rate (mils/year)	Wear Rate (mils/year)	Init.	Prd. [1]	Thoop	Tcrit	Time to Tcrit (hrs) Non-Insp.	Time to Tcrit (hrs) Insp.	Wear (mils) Prd. [2]	Wear (mils) Meas.	Wear (mils) Prd. [2]	Wear (mils) Meas.	Tmeas, Method, Time (in) [4] [3] (hrs) [4]		
====Grouped by Line: 004-24*-FDW-01, No Sorting.																		
FD01TE01 (U.S)	12	5.135	3.898	1.812	1.912	1.447	1.447	1045746	-----	---	---	---	---	1.970	MT	125911	-----	
FD01TE01 (D.S)	12	3.440	2.612	1.812	2.039	1.447	1.447	1987315	-----	---	---	---	---	2.078	MT	125911	-----	
FD01TE01 (BR.)	12	4.842	3.676	1.219	1.085	0.964	0.964	288256	-----	---	---	---	---	1.219	--	0	-----	
FD01SP06 DS	62	1.678	1.274	1.812	1.552	1.447	1.447	724603	-----	---	---	---	---	1.576	MT	102975	-----	
FD01SP06 US	62	1.678	1.274	1.812	1.480	1.447	1.447	-----	230341	31.5	112.0	31.5	112.0	1.495	MT	148782	148782	
FD01TE02 (U.S)	12	5.135	3.898	1.812	1.662	1.447	1.447	483184	-----	---	---	---	---	1.707	MT	148782	-----	
FD01TE02 (D.S)	12	3.440	2.612	1.812	1.648	1.447	1.447	674066	-----	---	---	---	---	1.678	MT	148782	-----	
FD01TE02 (BR.)	12	4.842	3.676	1.219	1.664	0.964	0.964	1667572	-----	---	---	---	---	1.707	MT	148782	-----	
FD01SP07 US	62	1.678	1.274	1.812	1.551	1.447	1.447	-----	718560	31.5	136.0	31.5	136.0	1.566	MT	148782	148782	
FD01SP07 DS	62	1.678	1.274	1.812	1.766	1.447	1.447	2193656	-----	---	---	---	---	1.812	--	0	-----	
FD01EL06	2	3.104	2.357	1.812	1.725	1.447	1.447	1039532	-----	---	---	---	---	1.812	--	0	-----	
FD01SP08	52	2.098	1.592	1.812	1.754	1.447	1.447	1691273	-----	---	---	---	---	1.812	--	0	-----	
FD01EL07	4	3.104	2.357	1.812	1.726	1.447	1.447	1039532	-----	---	---	---	---	1.812	--	0	-----	
FD01SP09	54	2.685	2.038	1.812	1.738	1.447	1.447	1251687	-----	---	---	---	---	1.812	--	0	-----	
FD01TE03 (U.S)	15	2.517	1.911	1.812	1.743	1.447	1.447	1356350	-----	---	---	---	---	1.812	--	0	-----	
FD01TE03 (D.S)	15	2.517	1.911	1.812	1.743	1.447	1.447	1356350	-----	---	---	---	---	1.812	--	0	-----	
FD01SP10 US	65	1.678	1.274	1.812	1.766	1.447	1.447	2193656	-----	---	---	---	---	1.812	--	0	-----	
FD01SP10 DS	65	1.678	1.274	1.812	1.526	1.447	1.447	-----	545683	27.3	50.0	27.3	50.0	1.545	MT	125911	125911	
FD01TE04 (U.S)	12	5.135	3.898	1.812	2.750	1.447	1.447	2928970	-----	---	---	---	---	2.808	US	125911	-----	
FD01TE04 (D.S)	12	3.440	2.612	1.812	2.714	1.447	1.447	4251470	-----	---	---	---	---	2.753	US	125911	-----	
FD01TE04 (BR.)	12	4.842	3.676	1.219	1.085	0.964	0.964	288256	-----	---	---	---	---	1.219	--	0	-----	
FD01EL08	4	3.104	2.357	1.812	1.890	1.447	1.447	1647550	-----	---	---	---	---	1.925	US	125911	-----	
FD01SP11	54	2.685	2.038	1.812	1.543	1.447	1.447	-----	413748	66.0	48.0	66.0	48.0	1.551	MT	207118	207118	

====Grouped by Line: 005-18*-FDW-07, No Sorting.

FD07RD01 (L/E)	7	2.937	2.229	1.812	1.601	1.447	1.447	606823	-----	---	---	---	---	1.643	MT	102975	-----
FD07RD01 (S/E)	7	3.932	2.985	1.375	1.247	1.085	1.085	475121	-----	---	---	---	---	1.303	MT	102975	-----
FD07EL01	4	4.547	3.452	1.375	1.192	1.085	1.085	-----	270300	100.9	101.0	100.9	101.0	1.216	MT	183618	183618
FD07SP01 US	54	3.932	2.985	1.375	1.210	1.085	1.085	-----	366253	87.3	40.0	87.3	40.0	1.231	MT	183618	183618
FD07SP01 DS	54	3.932	2.985	1.375	1.237	1.085	1.085	-----	445944	77.5	107.0	77.5	107.0	1.268	GW	160352	160352
FD07EL02	2	4.547	3.452	1.375	1.292	1.085	1.085	525658	-----	---	---	---	---	1.328	MT	160352	-----
FD07SP02 US	52	3.072	2.332	1.375	1.201	1.085	1.085	434772	-----	---	---	---	---	1.225	MT	160352	-----
FD07SP02 DS	52	3.072	2.332	1.375	1.134	1.085	1.085	183485	-----	---	---	---	---	1.140	MT	218618	-----
FD07EL03	2	4.547	3.452	1.375	1.312	1.085	1.085	575868	-----	---	---	---	---	1.321	US	218618	-----
FD07RD02 (L/E)	7	4.301	3.265	1.375	1.235	1.085	1.085	402605	-----	---	---	---	---	1.269	US	160352	-----
FD07RD02 (S/E)	7	7.568	5.746	0.844	0.709	0.648	0.648	93498	-----	---	---	---	---	0.769	MT	160352	-----
FD07RD03 (L/E)	18	3.686	2.799	1.375	1.207	1.085	1.085	-----	381770	85.7	113.0	85.7	113.0	1.223	MT	195618	195618
FD07RD03 (S/E)	18	6.622	5.028	0.844	0.731	0.648	0.648	-----	145051	153.9	79.0	153.9	79.0	0.760	MT	195618	195618
FD07SP03	68	3.072	2.332	1.375	1.218	1.085	1.085	-----	498190	71.4	46.0	71.4	46.0	1.231	MT	195618	195618
FD07EL04	2	4.547	3.452	1.375	1.289	1.085	1.085	-----	517283	96.3	130.0	96.3	130.0	1.318	MT	171740	171740
FD07SP04	52	3.072	2.332	1.375	1.194	1.085	1.085	-----	410460	65.0	117.0	65.0	117.0	1.214	MT	171740	171740
FD07EL05	4	4.547	3.452	1.375	1.250	1.085	1.085	417651	-----	---	---	---	---	1.375	--	0	-----
FD07SP05	54	3.932	2.985	1.375	1.267	1.085	1.085	532638	-----	---	---	---	---	1.375	--	0	-----
FD07SP06	9	1.582	1.201	1.375	1.331	1.085	1.085	1796562	-----	---	---	---	---	1.375	--	0	-----
FD07EL06	2	4.547	3.452	1.375	1.201	1.085	1.085	293952	-----	---	---	---	---	1.230	GW	171740	-----
FD07SP07	52	3.072	2.332	1.375	1.318	1.085	1.085	-----	876207	65.0	65.0	65.0	65.0	1.338	GW	171740	171740
FD07EL07	2	4.547	3.452	1.375	1.159	1.085	1.085	187362	-----	---	---	---	---	1.188	MT	171740	-----
FD07SP08 DS	52	3.072	2.332	1.375	1.233	1.085	1.085	-----	556945	65.0	122.0	65.0	122.0	1.253	MT	171740	171740
FD07SP08 US	52	3.072	2.332	1.375	1.290	1.085	1.085	779890	-----	---	---	---	---	1.375	--	0	-----
FD07EL08	1	4.055	3.079	1.375	1.263	1.085	1.085	506853	-----	---	---	---	---	1.375	--	0	-----
FD07SP09	51	2.703	2.052	1.375	1.232	1.085	1.085	-----	627973	50.7	118.0	50.7	118.0	1.256	MT	148782	148782
FD07EL09	4	4.547	3.452	1.375	1.195	1.085	1.085	278831	-----	---	---	---	---	1.235	MT	148782	-----
FD07SP10 US	54	3.932	2.985	1.375	1.186	1.085	1.085	-----	297220	73.8	83.0	73.8	83.0	1.221	MT	148782	148782

====Grouped by Line: 006-18*-FDW-07, No Sorting.

43

FDG7SP10 DS	54	3.932	2.985	1.375	1.267	1.085	1.085	532638	-----	---	---	---	---	1.375	--	0	-----
FDG7TE01 (U/S)	15	3.686	2.799	1.375	1.273	1.085	1.085	589364	-----	---	---	---	---	1.375	--	0	-----
FDG7TE01 (D/S)	15	3.686	2.799	1.375	1.273	1.085	1.085	589364	-----	---	---	---	---	1.375	--	0	-----
FDG7EL10	4	4.547	3.452	1.375	1.250	1.085	1.085	417651	-----	---	---	---	---	1.375	--	0	-----
FDG7SP11	54	3.932	2.985	1.375	1.267	1.085	1.085	532638	-----	---	---	---	---	1.375	--	0	-----
FDG7EL11	2	4.547	3.452	1.375	1.250	1.085	1.085	417651	-----	---	---	---	---	1.375	--	0	-----
FDG7EL12	4	4.547	3.452	1.375	1.250	1.085	1.085	417651	-----	---	---	---	---	1.375	--	0	-----
INLET E 2-1A	30	4.915	3.732	1.375	1.239	1.085	1.085	362458	-----	---	---	---	---	1.375	--	0	-----

====Grouped by Line: 011-18*-FDW-08, No Sorting.

FDG8RD01 (L/E)	7	2.937	2.229	1.812	1.569	1.447	1.447	-----	481418	65.2	62.0	55.2	62.0	1.578	MT	207118	183618
FDG8RD01 (S/E)	7	3.932	2.985	1.375	1.166	1.085	1.085	-----	237140	87.3	18.0	87.3	18.0	1.187	MT	183618	183618
FDG8EL01	4	4.547	3.452	1.375	1.312	1.085	1.085	-----	577058	111.8	56.0	111.8	56.0	1.326	MT	207118	207118
FDG8SP01 US	54	3.932	2.985	1.375	1.212	1.085	1.085	-----	373305	96.7	30.0	96.7	30.0	1.224	MT	207118	207118
FDG8SP01 DS	54	3.932	2.985	1.375	1.267	1.085	1.085	532638	-----	---	---	---	---	1.375	--	0	-----
FDG8EL02	2	4.547	3.452	1.375	1.250	1.085	1.085	417651	-----	---	---	---	---	1.375	--	0	-----
FDG8RD02 (L/E)	7	1.301	3.265	1.375	1.194	1.085	1.085	292532	-----	---	---	---	---	1.232	MT	148782	-----
FDG8RD02 (S/E)	7	7.568	5.746	0.844	1.337	0.648	0.648	1050805	-----	---	---	---	---	1.404	MT	148782	-----
FDG8EL03 (L/E)	18	3.686	2.799	1.375	1.250	1.085	1.085	-----	517393	98.0	29.0	98.0	29.0	1.254	MT	230118	230118
FDG8RD03 (S/E)	18	6.622	5.028	0.844	0.787	0.648	0.648	-----	242886	176.1	28.0	176.1	28.0	0.794	MT	230118	230118
FDG8SP02	68	3.072	2.332	1.375	1.188	1.085	1.085	-----	386542	81.7	45.0	81.7	45.0	1.191	MT	230118	230118
FDG8EL03	2	4.547	3.452	1.375	1.319	1.085	1.085	594251	-----	---	---	---	---	1.384	MT	102975	-----
FDG8SP03 US	52	3.072	2.332	1.375	1.251	1.085	1.085	-----	624167	40.9	137.0	40.9	137.0	1.295	MT	102975	102975
FDG8SP03 DS	52	3.072	2.332	1.375	1.290	1.085	1.085	770890	-----	---	---	---	---	1.375	--	0	-----
FDG8EL04	4	4.547	3.452	1.375	1.280	1.085	1.085	493632	-----	---	---	---	---	1.304	GW	183618	-----
FDG8SP04	54	3.932	2.985	1.375	1.202	1.085	1.085	-----	342778	87.3	72.0	87.3	72.0	1.223	MT	183618	183618
FDG8EL05	2	4.547	3.452	1.375	1.301	1.085	1.085	546927	-----	---	---	---	---	1.325	MT	183618	-----
FDG8SP05 US	52	3.072	2.332	1.375	1.164	1.085	1.085	298389	-----	---	---	---	---	1.181	MT	183618	-----

====Grouped by Line: 012-18*-FDW-08, No Sorting.

FDG8SP05 US	52	3.072	2.332	1.375	1.290	1.085	1.085	770890	-----	---	---	---	---	1.375	--	0	-----
FDG8TE01 (U/S)	15	3.686	2.799	1.375	1.273	1.085	1.085	589364	-----	---	---	---	---	1.375	--	0	-----
FDG8TE01 (D/S)	15	3.686	2.799	1.375	1.273	1.085	1.085	589364	-----	---	---	---	---	1.375	--	0	-----
FDG8EL06	4	4.547	3.452	1.375	1.299	1.085	1.085	542662	-----	---	---	---	---	1.328	MT	171740	-----
FDG8SP06 US	54	3.932	2.985	1.375	1.257	1.085	1.085	-----	504029	83.3	93.0	83.3	93.0	1.282	GW	171740	171740
FDG8SP06 DS	54	3.932	2.985	1.375	1.267	1.085	1.085	532638	-----	---	---	---	---	1.375	--	0	-----
FDG8EL07	2	4.547	3.452	1.375	1.250	1.085	1.085	417651	-----	---	---	---	---	1.375	--	0	-----
FDG8EL08	4	4.547	3.452	1.375	1.250	1.085	1.085	417651	-----	---	---	---	---	1.375	--	0	-----
INLET E-2-1B	30	4.915	3.732	1.375	1.239	1.085	1.085	362458	-----	---	---	---	---	1.375	--	0	-----

Notes:

- [1] Predictions are based on last Tmeas to analysis ending period.
- [2] Predictions are for the time of last inspection (last known meas. wear).
- [3] GW = Tmeas is minimum thickness from Band, Blanket or Area Method of greatest wear.
 MT = Tmeas is component minimum thickness.
 PW = Tmeas is Tinit - predicted wear.
 US = Tmeas is user specified.
- [4] If no Tmeas has been determined from measured data, then Tmeas = Tinit and Time = current component installation time.
 Tmeas is used to determine Predicted Thickness and Component Predicted Time to Tcrit.

777

*** Wear Rate Analysis: Wear Rates/Input Data Report ***

Run Name: FDW 2006 Hdr to E2s
 Ending Period: CYCLE 25
 Total Plant Operating Hours: 241618 Duty Factor (Global): 1.000
 WPA Data Option: Ignore NFA Exclude Measure Wear: No
 Line Correction Factor: 0.222

Component Name	Geom. Code	Average Wear Rate (mils/year)	Current Wear Rate (mils/year)	Temp. (F)	Velocity (ft/s)	Steam Quality	Diameter (in)
===>Grouped by Line: 004-24*-FDW-01, No Sorting.							
FD01TE01 (U/S)	12	5.135	3.898	294.7	13.741	0.000	24.000
FD01TE01 (D/S)	12	3.440	3.612	296.9	6.847	0.000	24.000
FD01TE01 (BR.)	12	4.842	3.676	296.9	15.456	0.000	16.000
FD01SP06 DS	62	1.678	1.274	296.9	6.847	0.000	24.000
FD01SP06 US	62	1.678	1.274	296.9	6.847	0.000	24.000
FD01TE02 (U/S)	12	5.135	3.898	294.7	13.741	0.000	24.000
FD01TE02 (D/S)	12	3.440	2.612	296.9	6.847	0.000	24.000
FD01TE02 (BR.)	12	4.842	3.676	296.9	15.456	0.000	16.000
FD01SP07 US	62	1.678	1.274	296.9	6.847	0.000	24.000
FD01SP07 DS	62	1.678	1.274	296.9	6.847	0.000	24.000
FD01EL06	2	3.104	2.357	296.9	6.847	0.000	24.000
FD01SP08	52	2.098	1.592	296.9	6.847	0.000	24.000
FD01EL07	4	3.104	2.357	296.9	6.847	0.000	24.000
FD01SP09	54	2.685	2.038	296.9	6.847	0.000	24.000
FD01TE03 (U/S)	15	2.517	1.911	296.9	6.847	0.000	24.000
FD01TE03 (D/S)	15	2.517	1.911	296.9	6.847	0.000	24.000
FD01SP10 US	65	1.678	1.274	296.9	6.847	0.000	24.000
FD01SP10 DS	65	1.678	1.274	296.9	6.847	0.000	24.000
FD01TE04 (U/S)	12	5.135	3.898	294.7	13.741	0.000	24.000
FD01TE04 (D/S)	12	3.440	2.612	296.9	6.847	0.000	24.000
FD01TE04 (BR.)	12	4.842	3.676	296.9	15.456	0.000	16.000
FD01EL08	4	3.104	2.357	296.9	6.847	0.000	24.000
FD01SP11	54	2.685	2.038	296.9	6.847	0.000	24.000

===>Grouped by Line: 005-18*-FDW-07, No Sorting.							
FD07RD01 (L/E)	7	2.937	2.229	296.9	6.847	0.000	24.000
FD07RD01 (S/E)	7	3.932	2.985	296.9	12.224	0.000	18.000
FD07EL01	4	4.547	3.452	296.9	12.224	0.000	18.000
FD07SP01 US	54	3.932	2.985	296.9	12.224	0.000	18.000
FD07SP01 DS	54	3.932	2.985	296.9	12.224	0.000	18.000
FD07EL02	2	4.547	3.452	296.9	12.224	0.000	18.000
FD07SP02 US	52	3.072	2.332	296.9	12.224	0.000	18.000
FD07SP02 DS	52	3.072	2.332	296.9	12.224	0.000	18.000
FD07EL03	2	4.547	3.452	296.9	12.224	0.000	18.000
FD07RD02 (L/E)	7	4.301	3.265	296.9	12.224	0.000	18.000
FD07RD02 (S/E)	7	7.568	5.746	296.9	34.617	0.000	10.750
FD07RD03 (L/E)	18	3.686	2.799	296.9	12.224	0.000	18.000
FD07RD03 (S/E)	18	6.622	5.028	296.9	34.617	0.000	10.750
FD07SP03	68	3.072	2.332	296.9	12.224	0.000	18.000
FD07EL04	2	4.547	3.452	296.9	12.224	0.000	18.000
FD07SP04	52	3.072	2.332	296.9	12.224	0.000	18.000
FD07EL05	4	4.547	3.452	296.9	12.224	0.000	18.000
FD07SP05	54	3.932	2.985	296.9	12.224	0.000	18.000
FD07SP06	9	1.582	1.201	296.9	12.224	0.000	18.000
FD07EL06	2	4.547	3.452	296.9	12.224	0.000	18.000
FD07SP07	52	3.072	2.332	296.9	12.224	0.000	18.000
FD07EL07	2	4.547	3.452	296.9	12.224	0.000	18.000
FD07SP08 US	52	3.072	2.332	296.9	12.224	0.000	18.000
FD07SP08 DS	52	3.072	2.332	296.9	12.224	0.000	18.000
FD07EL08	1	4.055	3.079	296.9	12.224	0.000	18.000
FD07SP09	51	2.703	2.052	296.9	12.224	0.000	18.000
FD07EL09	4	4.547	3.452	296.9	12.224	0.000	18.000
FD07SP10 US	54	3.932	2.985	296.9	12.224	0.000	18.000

===>Grouped by Line: 006-18*-FDW-07, No Sorting.							
FD07SP10 DS	54	3.932	2.985	296.9	12.224	0.000	18.000
FD07TE01 (U/S)	15	3.686	2.799	296.9	12.224	0.000	18.000
FD07TE01 (D/S)	15	3.686	2.799	296.9	12.224	0.000	18.000
FD07EL10	4	4.547	3.452	296.9	12.224	0.000	18.000
FD07SP11 DS	54	3.932	2.985	296.9	12.224	0.000	18.000
FD07EL11	2	4.547	3.452	296.9	12.224	0.000	18.000
FD07EL12	4	4.547	3.452	296.9	12.224	0.000	18.000
INLET E-2-1A	30	4.315	3.732	296.9	12.224	0.000	18.000

===>Grouped by Line: 011-18*-FDW-08, No Sorting.							
FD08RD01 (L/E)	7	2.937	2.229	296.9	6.847	0.000	24.000
FD08RD01 (S/E)	7	3.932	2.985	296.9	12.224	0.000	18.000
FD08EL01	4	4.547	3.452	296.9	12.224	0.000	18.000
FD08SP01 US	54	3.932	2.985	296.9	12.224	0.000	18.000
FD08SP01 DS	54	3.932	2.985	296.9	12.224	0.000	18.000
FD08EL02	2	4.547	3.452	296.9	12.224	0.000	18.000
FD08RD02 (L/E)	7	4.301	3.265	296.9	12.224	0.000	18.000
FD08RD02 (S/E)	7	7.568	5.746	296.9	34.617	0.000	10.750
FD08RD03 (L/E)	18	3.686	2.799	296.9	12.224	0.000	18.000
FD08RD03 (S/E)	18	6.622	5.028	296.9	34.617	0.000	10.750
FD08SP02	68	3.072	2.332	296.9	12.224	0.000	18.000
FD08EL03	2	4.547	3.452	296.9	12.224	0.000	18.000
FD08SP03 US	52	3.072	2.332	296.9	12.224	0.000	18.000
FD08SP03 DS	52	3.072	2.332	296.9	12.224	0.000	18.000

FD0REL04	4	4.547	3.452	296.9	12.224	0.000	18.000
FD0RSP04	54	3.932	2.985	296.9	12.224	0.000	18.000
FD0REL05	2	4.547	3.452	296.9	12.224	0.000	18.000
FD0RSP05 US	52	3.072	2.332	296.9	12.224	0.000	18.000

===Grouped by Line: 012-1A*-FDW-08, No Sorting.

FD0RSP05 DS	52	3.072	2.332	296.9	12.224	0.000	18.000
FD0RTE01(U/S)	15	3.686	2.799	296.9	12.224	0.000	18.000
FD0RTE01(D/S)	15	3.686	2.799	296.9	12.224	0.000	18.000
FD0REL06	4	4.547	3.452	296.9	12.224	0.000	18.000
FD0RSP06 US	54	3.932	2.985	296.9	12.224	0.000	18.000
FD0RSP06 DS	54	3.932	2.985	296.9	12.224	0.000	18.000
FD0REL07	2	4.547	3.452	296.9	12.224	0.000	18.000
FD0REL08	4	4.547	3.452	296.9	12.224	0.000	18.000
INLET E-2-1B	30	4.915	3.732	296.9	12.224	0.000	18.000

*** Wear Rate Analysis: Inspection History Report ***

Run Name: FDW 2006 Hdr to E2s
Ending Period: CYCLE 25
Total Plant Operating Hours: 241618 Duty Factor (Global): 1.000
WRA Data Option: Ignore NFA Exclude Measure Wear: No
Line Correction Factor: 0.222

Component Name	Material					Time (hrs)		Analysis Option	Measured Wear (mils)
	Geom. Code	No.	Cr. (%)	Cu. (%)	Mo. (%)	Sigma (psi)	Last Inspected Replaced		
===>Grouped by Line: 004-24*-FDW-01, No Sorting.									
FD01TE01(U/S)	12	21	0.00	0.00	0.00	15000	-----	Excl LCF	---
FD01TE01(D/S)	12	21	0.00	0.00	0.00	15000	-----	Excl LCF	---
FD01TE01(BR.)	12	21	0.00	0.00	0.00	15000	-----	Excl LCF	---
FD01SP06 DS	62	5	0.00	0.00	0.00	15000	-----	-----	---
FD01SP06 US	62	5	0.00	0.00	0.00	15000	148782	-----	112
FD01TE02(U/S)	12	21	0.00	0.00	0.00	15000	-----	Excl LCF	---
FD01TE02(D/S)	12	21	0.00	0.00	0.00	15000	-----	Excl LCF	---
FD01TE02(BR.)	12	21	0.00	0.00	0.00	15000	-----	Excl LCF	---
FD01SP07 US	62	5	0.00	0.00	0.00	15000	148782	-----	136
FD01SP07 DS	62	5	0.00	0.00	0.00	15000	-----	-----	---
FD01EL06	2	21	0.00	0.00	0.00	15000	-----	-----	---
FD01SP08	52	5	0.00	0.00	0.00	15000	-----	-----	---
FD01EL07	4	21	0.00	0.00	0.00	15000	-----	-----	---
FD01SP09	54	5	0.00	0.00	0.00	15000	-----	-----	---
FD01TE03(U/S)	15	21	0.00	0.00	0.00	15000	-----	-----	---
FD01TE03(D/S)	15	21	0.00	0.00	0.00	15000	-----	-----	---
FD01SP10 US	65	5	0.00	0.00	0.00	15000	-----	-----	---
FD01SP10 DS	65	5	0.00	0.00	0.00	15000	125911	-----	50
FD01TE04(U/S)	12	21	0.00	0.00	0.00	15000	-----	-----	---
FD01TE04(D/S)	12	21	0.00	0.00	0.00	15000	-----	-----	---
FD01TE04(BR.)	12	21	0.00	0.00	0.00	15000	-----	-----	---
FD01EL08	4	21	0.00	0.00	0.00	15000	-----	Excl LCF	---
FD01SP11	54	5	0.00	0.00	0.00	15000	207118	-----	48

===>Grouped by Line: 005-18*-FDW-07, No Sorting.

FD07RD01(L/E)	7	21	0.00	0.00	0.00	15000	-----	Excl LCF	---
FD07RD01(S/E)	7	21	0.00	0.00	0.00	15000	-----	Excl LCF	---
FD07EL01	4	21	0.00	0.00	0.00	15000	183618	-----	100
FD07SP01 US	54	5	0.00	0.00	0.00	15000	183618	-----	40
FD07SP01 DS	54	5	0.00	0.00	0.00	15000	160352	-----	107
FD07EL02	2	21	0.00	0.00	0.00	15000	-----	-----	---
FD07SP02 US	52	5	0.00	0.00	0.00	15000	-----	-----	---
FD07SP02 DS	52	5	0.00	0.00	0.00	15000	-----	-----	---
FD07EL03	2	21	0.00	0.00	0.00	15000	-----	-----	---
FD07RD02(L/E)	7	21	0.00	0.00	0.00	15000	-----	Excl LCF	---
FD07RD02(S/E)	7	21	0.00	0.00	0.00	15000	-----	Excl LCF	---
FD07RD03(L/E)	18	21	0.00	0.00	0.00	15000	195618	-----	113
FD07RD03(S/E)	18	21	0.00	0.00	0.00	15000	195618	-----	79
FD07SP03	68	5	0.00	0.00	0.00	15000	195618	-----	46
FD07EL04	2	21	0.00	0.00	0.00	15000	171740	-----	130
FD07SP04	52	5	0.00	0.00	0.00	15000	171740	-----	117
FD07EL05	4	21	0.00	0.00	0.00	15000	-----	-----	---
FD07SP05	54	5	0.00	0.00	0.00	15000	-----	-----	---
FD07SP06	9	5	0.00	0.00	0.00	15000	-----	-----	---
FD07EL06	2	21	0.00	0.00	0.00	15000	-----	-----	---
FD07SP07	52	5	0.00	0.00	0.00	15000	171740	-----	65
FD07EL07	2	21	0.00	0.00	0.00	15000	-----	-----	---
FD07SP08 US	52	5	0.00	0.00	0.00	15000	171740	-----	122
FD07SP08 DS	52	5	0.00	0.00	0.00	15000	-----	-----	---
FD07EL08	1	21	0.00	0.00	0.00	15000	-----	-----	---
FD07SP09	51	5	0.00	0.00	0.00	15000	148782	-----	118
FD07EL09	4	21	0.00	0.00	0.00	15000	-----	-----	---
FD07SP10 US	54	5	0.00	0.00	0.00	15000	148782	-----	83

===>Grouped by Line: 006-18*-FDW-07, No Sorting.

FD07SP10 DS	54	5	0.00	0.00	0.00	15000	-----	-----	---
FD07TE01(U/S)	15	21	0.00	0.00	0.00	15000	-----	-----	---
FD07TE01(D/S)	15	21	0.00	0.00	0.00	15000	-----	-----	---
FD07EL10	4	21	0.00	0.00	0.00	15000	-----	-----	---
FD07SP11	54	5	0.00	0.00	0.00	15000	-----	-----	---
FD07EL11	2	21	0.00	0.00	0.00	15000	-----	-----	---
FD07EL12	4	21	0.00	0.00	0.00	15000	-----	-----	---
INLET E-2-1A	30	5	0.00	0.00	0.00	15000	-----	-----	---

===>Grouped by Line: 011-18*-FDW-08, No Sorting.

FD08RD01(L/E)	7	21	0.00	0.00	0.00	15000	183618	-----	62
FD08RD01(S/E)	7	21	0.00	0.00	0.00	15000	183618	-----	18
FD08EL01	4	21	0.00	0.00	0.00	15000	207118	-----	55
FD08SP01 US	54	5	0.00	0.00	0.00	15000	207118	-----	29
FD08SP01 DS	54	5	0.00	0.00	0.00	15000	-----	-----	---
FD08EL02	2	21	0.00	0.00	0.00	15000	-----	-----	---
FD08RD02(L/E)	7	21	0.00	0.00	0.00	15000	-----	-----	---
FD08RD02(S/E)	7	21	0.00	0.00	0.00	15000	-----	-----	---
FD08RD03(L/E)	18	21	0.00	0.00	0.00	15000	230118	-----	29
FD08RD03(S/E)	18	21	0.00	0.00	0.00	15000	230118	-----	27
FD08SP02	68	5	0.00	0.00	0.00	15000	230118	-----	45
FD08EL03	2	21	0.00	0.00	0.00	15000	-----	-----	---
FD08SP03 US	52	5	0.00	0.00	0.00	15000	103975	-----	177
FD08SP03 DS	52	5	0.00	0.00	0.00	15000	-----	-----	---

FDORELC4	4	21	0.00	0.00	0.00	15000	-----	-----	---
FDOASP04	54	5	0.00	0.00	0.00	15000	183618	-----	72
FDORELC5	2	21	0.00	0.00	0.00	15000	-----	-----	---
FDOASP05 US	52	5	0.00	0.00	0.00	15000	-----	-----	---

====>Grouped by Line: 012-18*-FEW-08, No Sorting.

FDOASP05 DS	52	5	0.00	0.00	0.00	15000	-----	-----	---
FDOATE01(U/S)	15	21	0.00	0.00	0.00	15000	-----	-----	---
FDOATE01(D,S)	15	21	0.00	0.00	0.00	15000	-----	-----	---
FDORELC6	4	21	0.00	0.00	0.00	15000	-----	-----	---
FDOASP06 US	54	5	0.00	0.00	0.00	15000	171740	-----	93
FDOASP06 DS	54	5	0.00	0.00	0.00	15000	-----	-----	---
FDORELC7	2	21	0.00	0.00	0.00	15000	-----	-----	---
FDORELC8	4	21	0.00	0.00	0.00	15000	-----	-----	---
INLET E-2-1B	30	5	0.00	0.00	0.00	15000	-----	-----	---

48

*** Wear Rate Analysis: Thickness/Service Time Report ***

Run Name: FDW 2006 Hdr to E2s
 Ending Period: CYCLE 25
 Total Plant Operating Hours: 241618 Duty Factor (Global): 1.000
 WRA Data Option: Ignore NFA Exclude Measure Wear: No
 Line Correction Factor: 0.222

Component Name	Thickness (in)				Component Predicted[1] Time to Tcrit (hrs)		Component Actual Service Time (hrs)
	Init.	Prd. [1]	Thoop	Tcrit	Non-Inspected	Inspected	
===>Grouped by Line: 004-24*-FDW-01, No Sorting.							
FD01TE01 (U/S)	1.812	1.912	1.447	1.447	1045746	-----	241618
FD01TE01 (D/S)	1.812	2.039	1.447	1.447	1987315	-----	241618
FD01TE01 (BR.)	1.219	1.085	0.964	0.964	288256	-----	241618
FD01SP06 DS	1.812	1.552	1.447	1.447	724603	-----	241618
FD01SP06 US	1.812	1.480	1.447	1.447	-----	230341	241618
FD01TE02 (U/S)	1.812	1.662	1.447	1.447	483184	-----	241618
FD01TE02 (D/S)	1.812	1.648	1.447	1.447	674066	-----	241618
FD01TE02 (BR.)	1.219	1.664	0.964	0.964	1667572	-----	241618
FD01SP07 US	1.812	1.551	1.447	1.447	-----	718560	241618
FD01SP07 DS	1.812	1.766	1.447	1.447	2193656	-----	241618
FD01EL06	1.812	1.726	1.447	1.447	1039532	-----	241618
FD01SP08	1.812	1.754	1.447	1.447	1691273	-----	241618
FD01EL07	1.812	1.726	1.447	1.447	1039532	-----	241618
FD01SP09	1.812	1.738	1.447	1.447	1251687	-----	241618
FD01TE03 (U/S)	1.812	1.743	1.447	1.447	1356350	-----	241618
FD01TE03 (D/S)	1.812	1.743	1.447	1.447	1356350	-----	241618
FD01SP10 US	1.812	1.766	1.447	1.447	2193656	-----	241618
FD01SP10 DS	1.812	1.526	1.447	1.447	-----	545683	241618
FD01TE04 (U/S)	1.812	2.750	1.447	1.447	2928970	-----	241618
FD01TE04 (D/S)	1.812	2.714	1.447	1.447	4251470	-----	241618
FD01TE04 (BR.)	1.219	1.085	0.964	0.964	288256	-----	241618
FD01EL08	1.812	1.890	1.447	1.447	1647550	-----	241618
FD01SP11	1.812	1.543	1.447	1.447	-----	413748	241618

===>Grouped by Line: 005-18*-FDW-07, No Sorting.							
FD07RD01 (L/E)	1.812	1.601	1.447	1.447	606823	-----	241618
FD07RD01 (S/E)	1.375	1.247	1.085	1.085	475121	-----	241618
FD07EL01	1.375	1.192	1.085	1.085	-----	270200	241618
FD07SP01 US	1.375	1.210	1.085	1.085	-----	366253	241618
FD07SP01 DS	1.375	1.237	1.085	1.085	-----	445944	241618
FD07EL02	1.375	1.292	1.085	1.085	525658	-----	241618
FD07SP02 US	1.375	1.201	1.085	1.085	434772	-----	241618
FD07SP02 DS	1.375	1.134	1.085	1.085	183485	-----	241618
FD07EL03	1.375	1.312	1.085	1.085	575868	-----	241618
FD07RD02 (L/E)	1.375	1.235	1.085	1.085	402605	-----	241618
FD07RD02 (S/E)	0.844	0.709	0.648	0.648	93498	-----	241618
FD07RD03 (L/E)	1.375	1.207	1.085	1.085	-----	381770	241618
FD07RD03 (S/E)	0.844	0.731	0.648	0.648	-----	145051	241618
FD07SP03	1.375	1.218	1.085	1.085	-----	498190	241618
FD07EL04	1.375	1.289	1.085	1.085	-----	517283	241618
FD07SP04	1.375	1.194	1.085	1.085	-----	410460	241618
FD07EL05	1.375	1.250	1.085	1.085	417651	-----	241618
FD07SP05	1.375	1.267	1.085	1.085	532638	-----	241618
FD07SP06	1.375	1.331	1.085	1.085	1796562	-----	241618
FD07EL06	1.375	1.201	1.085	1.085	293952	-----	241618
FD07SP07	1.375	1.318	1.085	1.085	-----	876207	241618
FD07EL07	1.375	1.159	1.085	1.085	187362	-----	241618
FD07SP08 US	1.375	1.233	1.085	1.085	-----	556945	241618
FD07SP08 DS	1.375	1.230	1.085	1.085	770890	-----	241618
FD07EL08	1.375	1.263	1.085	1.085	506853	-----	241618
FD07SP09	1.375	1.232	1.085	1.085	-----	627973	241618
FD07EL09	1.375	1.195	1.085	1.085	278831	-----	241618
FD07SP10 US	1.375	1.186	1.085	1.085	-----	397220	241618

===>Grouped by Line: 006-18*-FDW-07, No Sorting.							
FD07SP10 DS	1.375	1.267	1.085	1.085	532638	-----	241618
FD07TE01 (U/S)	1.375	1.273	1.085	1.085	589364	-----	241618
FD07TE01 (D/S)	1.375	1.273	1.085	1.085	589364	-----	241618
FD07EL10	1.375	1.250	1.085	1.085	417651	-----	241618
FD07SP11	1.375	1.267	1.085	1.085	532638	-----	241618
FD07EL11	1.375	1.250	1.085	1.085	417651	-----	241618
FD07EL12	1.375	1.250	1.085	1.085	417651	-----	241618
INLET E-2-1A	1.375	1.239	1.085	1.085	362458	-----	241618

===>Grouped by Line: 011-18*-FDW-08, No Sorting.							
FD08RD01 (L/E)	1.812	1.569	1.447	1.447	-----	481418	241618
FD08RD01 (S/E)	1.375	1.156	1.085	1.085	-----	237140	241618
FD08EL01	1.375	1.312	1.085	1.085	-----	577058	241618
FD08SP01 US	1.375	1.212	1.085	1.085	-----	373305	241618
FD08SP01 DS	1.375	1.267	1.085	1.085	532638	-----	241618
FD08EL02	1.375	1.250	1.085	1.085	417651	-----	241618
FD08RD02 (L/E)	1.375	1.194	1.085	1.085	232532	-----	241618
FD08RD02 (S/E)	0.844	0.737	0.648	0.648	1050805	-----	241618
FD08RD03 (L/E)	1.375	1.250	1.085	1.085	-----	517393	241618
FD08RD03 (S/E)	0.844	0.747	0.648	0.648	-----	242486	241618
FD08SP02	1.375	1.188	1.085	1.085	-----	386542	241618
FD08EL03	1.375	1.319	1.085	1.085	594251	-----	241618
FD08SP03 US	1.375	1.251	1.085	1.085	-----	623167	241618
FD08SP03 DS	1.375	1.230	1.085	1.085	770890	-----	241618

FD08EL04	1.375	1.290	1.085	1.085	403632	-----	241618
FD08SP04	1.375	1.202	1.085	1.085	-----	342778	241618
FD08EL05	1.375	1.301	1.085	1.085	546327	-----	241618
FD08SP05 US	1.375	1.164	1.085	1.085	228389	-----	241618

====>Grouped by Line: 012-18*-FDW-08, No Sorting.

FD08SP05 DS	1.375	1.290	1.085	1.085	770890	-----	241618
FD08TE01 (U/S)	1.375	1.273	1.085	1.085	589364	-----	241618
FD08TE01 (D/S)	1.375	1.373	1.085	1.085	589364	-----	241618
FD08EL06	1.375	1.299	1.085	1.085	542662	-----	241618
FD08SP06 US	1.375	1.257	1.085	1.085	-----	504029	241618
FD08SP06 DS	1.375	1.267	1.085	1.085	532638	-----	241618
FD08EL07	1.375	1.250	1.085	1.085	417651	-----	241618
FD08EL08	1.375	1.250	1.085	1.085	417651	-----	241618
INLET E-2-1B	1.375	1.239	1.085	1.085	362458	-----	241618

Note:

[1] Predictions are based on last Tmeas to analysis ending period.

 *** Wear Rate Analysis: Combined Rankings for Inspection ***

Pen Name: FDW 2006 Hdr to E2s
 Ending Period: CYCLE 25
 Total Plant Operating Hours: 241618 Duty Factor (Global): 1.000
 WRA Data Option: Ignore NFA Exclude Measure Wear: No
 Line Correction Factor: 0.322

Component Name	Geometry Code	Average Wear Rate (mils/year)	Component Predicted Time to Tcrit (hrs)	
			Non-Inspected	Inspected
FD07EL08	1	4.055	506853	-----
FD07EL07	2	4.547	187362	-----
FD08RD02(S/E)	7	7.568	1050805	-----
FD07SP10 DS	54	3.932	532638	-----
FD01TE02(U/S)	12	5.135	483184	-----
FD07RD02(S/E)	7	7.568	93498	-----
FD07RD03(S/E)	18	6.622	-----	145051
FD08RD03(S/E)	18	6.622	-----	242886
FD07SP02 DS	52	3.072	183485	-----
FD01TE01(U/S)	12	5.135	1045746	-----
FD01SP06 US	62	1.678	-----	230341
FD01TE04(U/S)	12	5.135	2928970	-----
FD08RD01(S/E)	7	3.932	-----	237140
INLET E-2-1A	30	4.915	362458	-----
FD07EL01	4	4.547	-----	270300
INLET E-2-1B	30	4.915	362458	-----
FD07EL09	4	4.547	278831	-----
FD01TE01(BR.)	12	4.842	288256	-----
FD01TE04(BR.)	12	4.842	288256	-----
FD01TE02(BR.)	12	4.842	1667572	-----
FD08RD02(L/E)	7	4.301	292532	-----
FD07ELG6	2	4.547	293952	-----
FD07SP10 US	54	3.932	-----	297220
FD08EL04	4	4.547	493632	-----
FD08SP05 US	52	3.072	298389	-----
FD07EL11	2	4.547	417651	-----
FD08SP04	54	3.932	-----	342778
FD07EL04	2	4.547	-----	517283
FD08EL06	4	4.547	542662	-----
FD07EL02	2	4.547	525658	-----
FD07SP01 US	54	3.932	-----	366253
FD08EL07	2	4.547	417651	-----
FD08SP01 US	54	3.932	-----	373305
FD07EL03	2	4.547	575860	-----
FD07RD02(L/E)	18	3.686	-----	381770
FD07EL10	4	4.547	417651	-----
FD08SP02	68	3.072	-----	386542
FD07RD02(L/E)	7	4.301	402605	-----
FD07EL12	4	4.547	417651	-----
FD07SP04	52	3.072	-----	410460
FD07EL05	4	4.547	417651	-----
FD01SP11	54	2.685	-----	413748
FD08EL03	2	4.547	594251	-----
FD08EL02	2	4.547	417651	-----
FD08EL08	4	4.547	417651	-----
FD08EL01	4	4.547	-----	577058
FD08EL05	2	4.547	546927	-----
FD07SP02 US	52	3.072	434772	-----
FD07SP01 DS	54	3.932	-----	445944
FD07RD01(S/E)	7	3.932	475121	-----
FD07SP11	54	3.932	532638	-----
FD08RD01(L/E)	7	2.937	-----	481418
FD07SP03	68	3.072	-----	498190
FD08SP06 US	54	3.932	-----	504029
FD08RD03(L/E)	18	3.686	-----	517393
FD07SP05	54	3.932	532638	-----
FD08SP01 DS	54	3.932	532638	-----
FD08SP06 DS	54	3.932	532638	-----
FD08TE01(D.S)	15	3.686	589364	-----
FD07TE01(U.S)	15	3.686	589364	-----
FD01SP10 DS	65	1.678	-----	545683
FD07TE01(D.S)	15	3.686	589364	-----
FD08TE01(U.S)	15	3.686	589364	-----
FD07SP08 US	52	3.072	-----	556945
FD01TE01(D.S)	12	3.440	1987315	-----
FD01TE04(D.S)	12	3.440	4251470	-----
FD01TE02(D.S)	12	3.440	674066	-----
FD01EL07	4	3.104	1039532	-----
FD01EL08	4	3.104	1647550	-----
FD01EL06	2	3.104	1039532	-----
FD08SP05 ES	52	3.072	770890	-----
FD07PD01(L 2)	7	2.937	606823	-----
FEC08SP03 DS	52	3.072	770890	-----
FD08SP03 DS	52	3.072	-----	624167
FD07SP09	51	2.793	-----	527973
FD01SP07 US	62	1.678	-----	718560
FEC07SP07	52	3.072	-----	878207
FD01SP05 DS	62	1.678	724603	-----
FD07SP08 DS	52	3.072	770890	-----
FD01SP09	54	2.685	1251687	-----
FD01TE03(U.S)	15	2.517	1356350	-----
FD01TE03(D.S)	15	2.517	1356350	-----
FD01SP08	52	2.688	1691271	-----
ED01SP06	9	1.582	1796562	-----
FD01SP07 DS	62	1.678	2133656	-----


*** Wear Rate Analysis: Wear Predictions Report ***

Run Name: FDW 2006 Hdr to E2s
 Ending Period: CYCLE 25
 Total Plant Operating Hours: 241618 Duty Factor (Global): 1.000
 WRA Data Option: ignore NFA Exclude Measure Wear: No
 Line Correction Factor: 0.322

Component Name	Total Lifetime In-Service Cmp. Wear (mils)		In-Service Cmp. Tmeas, Method, Time (in) [3] [2] (hrs) [3]		In-Service Cmp. Thickness (mils) [4] Tm Tp		Incremental Wear (mils) [5] PRWEAR	Time (hrs) Last Inspected			
	Prd. [1]	Meas.	Prd. [1]	Meas.							
==>Grouped by Line: 004-24*-FDW-01, No Sorting.											
FD01SP06 US	31.5	112.0	31.5	112.0	1.495	MT	148782	1780.5	1495.0	14.8	148782
FD01SP07 US	31.5	136.0	31.5	136.0	1.566	MT	148782	1780.5	1566.0	14.9	148782
FD01SP10 DS	27.3	50.0	27.3	50.0	1.545	MT	125911	1784.7	1545.0	18.9	125911
FD01SP11	66.0	48.0	66.0	48.0	1.551	MT	207118	1746.0	1551.0	8.0	207118
==>Grouped by Line: 005-18*-FDW-07, No Sorting.											
FD07EL01	100.9	101.0	100.9	101.0	1.216	MT	183618	1274.1	1216.0	24.5	183618
FD07SP01 US	87.3	40.0	87.3	40.0	1.231	MT	183618	1287.7	1231.0	21.2	183618
FD07SP01 DS	77.5	107.0	77.5	107.0	1.268	GW	160352	1297.5	1268.0	31.0	160352
FD07RD03 (L/E)	85.7	113.0	85.7	113.0	1.223	MT	195618	1289.3	1223.0	16.0	195618
FD07RD03 (S/E)	153.9	79.0	153.9	79.0	0.760	MT	195618	690.1	760.0	28.7	195618
FD07SP03	71.4	46.0	71.4	46.0	1.231	MT	195618	1303.6	1231.0	13.3	195618
FD07EL04	96.3	130.0	96.3	130.0	1.318	MT	171740	1278.7	1318.0	29.1	171740
FD07SP04	65.0	117.0	65.0	117.0	1.214	MT	171740	1310.0	1214.0	19.7	171740
FD07SP07	65.0	65.0	65.0	65.0	1.338	GW	171740	1310.0	1338.0	19.7	171740
FD07SP08 US	65.0	122.0	65.0	122.0	1.253	MT	171740	1310.0	1253.0	19.7	171740
FD07SP09	50.7	118.0	50.7	118.0	1.256	MT	148782	1324.3	1256.0	23.8	148782
FD07SP10 US	73.8	83.0	73.8	83.0	1.221	MT	148782	1301.2	1221.0	34.7	148782
==>Grouped by Line: 006-18*-FDW-07, No Sorting.											
==>Grouped by Line: 011-18*-FDW-08, No Sorting.											
FD08FD01 (L/E)	65.2	62.0	65.2	62.0	1.578	MT	207118	1746.8	1578.0	8.8	183618
FD08RD01 (S/E)	87.3	18.0	87.3	18.0	1.187	MT	183618	1287.7	1187.0	21.2	183618
FD08EL01	111.8	56.0	111.8	56.0	1.326	MT	207118	1263.2	1326.0	13.6	207118
FD08SP01 US	96.7	30.0	96.7	30.0	1.224	MT	207118	1278.3	1224.0	11.8	207118
FD08RD03 (L/E)	98.0	29.0	98.0	29.0	1.254	MT	230118	1277.0	1254.0	3.7	230118
FD08RD03 (S/E)	176.1	28.0	176.1	28.0	0.794	MT	230118	667.9	794.0	6.6	230118
FD08SP02	81.7	45.0	81.7	45.0	1.191	MT	230118	1293.3	1191.0	3.1	230118
FD08SP03 US	40.9	137.0	40.9	137.0	1.295	MT	102975	1334.1	1295.0	43.8	102975
FD08SP04	87.3	72.0	87.3	72.0	1.223	MT	183618	1287.7	1223.0	21.2	183618
==>Grouped by Line: 012-18*-FDW-08, No Sorting.											
FD08SP06 US	83.3	93.0	83.3	93.0	1.282	GW	171740	1291.7	1282.0	25.2	171740


- Notes:
- [1] Predictions are for the time of last inspection (last known meas. wear).
 - [2] GW = Tmeas is minimum thickness from Band, Blanket or Area Method of greatest wear.
 MT = Tmeas is component minimum thickness.
 PW = Tmeas is Tinit - predicted wear.
 US = Tmeas is user specified.
 - [3] If no Tmeas has been determined from measured data, then Tmeas = Tinit and Time = current component installation time.
 Tmeas is used to determine Predicted Thickness and Component Predicted Time to Tcrit.
 - [4] These two values are used for thickness plot.
 Tp = Predicted thickness at Tmeas.
 Tm = Last measured thickness (Tmeas).
 - [5] PRWEAR = Incremental wear from last Tmeas time to analysis ending period.

Tpred/Tcrit Ratio Plot



Cumulative % of Comp. Time to Tcrit

FDW 2006 Hdr to E2s



5

Flow Accelerated Corrosion (FAC)

File Edit Analysis Tasks Preferences Window Help



Wear Rate Analysis Run Definition

Run Name: FDW2006 2P1s to E2s
Run Title: 2 Feed Pumps running to E2A & E2B

Ending Period: CYCLE 25
Total Oper. Hrs.: 241618.44
Duty Factor: 1.000

Analysis Options:
 Ignore IFA Results
 IFA Results 1st Priority
 User Input 1st Priority
 Do Not Use Measured Wear

Database Lines	Add	Lines to Analyze
002-16"-FDW-02	>	001-16"-FDW-01
007-18"-FDW-12	>>	003-16"-FDW-03
008-16"-FDW-14	>>>	004-2.5"-FDW-01
008-18"-FDW-14	>>>	005-18"-FDW-07
009-16"-FDW-14	>>>	006-18"-FDW-07
009-16"-FDW-16	>>>	011-18"-FDW-08
010-10"-FDW-19	>>>	012-18"-FDW-08
010-10"-FDW-21	>>>	

Run Definitions:
 Condensate
 FDW 2006 E1s to Rx
 FDW 2006 Hdr to E2s
 FDW06 2 P1s to Hdr.
FDW2006 2P1s to E2s
 FDW2006 E2s to E1s
 Feed Pump Recirc
 Feedwater
 Feedwater Flush
 Feedwater Low Flow
 Heater Drain Pumps
 Main Steam 2006
 Moist Sep High Level
 Moist Separator Drn
 Reactor Cleanup
 Steam Seal Regulator
 TEST- FDWpumpsto E2
 XP Test Feedwater


Navigation: < Prev, Next >, Add, Remove, Reset, Save, Copy, Delete, Print..., Help, Done

Advanced Run Def...


Handwritten initials



Comparison of Wear Predictions



Comparison of Thickness Predictions



Company: Vermont Yankee Nuclear Power Corporation Report Date: 28-SEP-2006 Time: 10:04:53
 Plant: Vermont Yankee Analysis Date: 28-SEP-2006 Time: 10:03:33
 Unit: CHECWORKS FAC Version 1.0F (Build 52)
 DS Name: VY

 *** Wear Rate Analysis: Combined Summary Report

Run Name: FD4/2006 EPls to E2s
 Ending Period: CYCLE 25
 Total Plant Operating Hours: 241618 Duty Factor (Global): 1.000
 NFA Data Option: Ignore NFA Exclude Measure Wear: No
 Line Correction Factor: 0.196

Component Name	Geom. Code	Average Wear Rate (mils/year)	Current Wear Rate (mils/year)	Init.	Thickness (in)		Tcrit	Component Predict[1]		Total Lifetime Wear (mils)		In-Service Cmp. Wear (mils)		In-Service Cmp. Tmeas. Method, Time		Time (hrs) Last Inspected
					Prd. [1]	Thoop		Non-Insp.	Insp.	Prd. [2]	Meas.	Prd. [2]	Meas.	(in) [4]	[3]	
===Grouped by Line: 001-16*-FDW-01, No Sorting.																
OUTLET P-1-1A	31	8.398	6.376	1.000	0.768	0.769	0.769	-275	-----	---	---	---	---	1.000	--	0
FD01RE01 (L/E)	18	3.762	2.856	1.219	1.024	0.964	0.964	181082	-----	---	---	---	---	1.031	MT	218618
FD01RD01 (S/E)	18	4.703	3.570	1.000	0.897	0.769	0.769	314205	-----	---	---	---	---	0.906	MT	218618
FD01EL01	4	4.639	3.522	1.219	1.065	0.964	0.964	-----	249415	118.7	79.0	118.7	79.0	1.074	MT	218618 218618
FD01TE05 (U/S)	15	3.762	2.856	1.219	1.107	0.964	0.964	-----	435674	96.3	122.0	96.3	122.0	1.114	MT	218618 218618
FD01TE05 (D/S)	15	3.762	2.856	1.219	1.003	0.964	0.964	-----	116667	96.3	133.0	96.3	133.0	1.010	MT	218618 218618
FD01SP01	58	2.759	2.094	1.219	1.143	0.964	0.964	746397	-----	---	---	---	---	1.219	--	0
FD01EL02	4	4.639	3.522	1.219	1.108	0.964	0.964	-----	357616	98.2	88.0	98.2	88.0	1.138	MT	171740 171740
FD01SP02 US	54	4.013	3.046	1.219	1.093	0.964	0.964	370414	-----	---	---	---	---	1.119	MT	171740
FD01SP02 DS	54	4.013	3.046	1.219	1.103	0.964	0.964	-----	397168	93.3	74.0	93.3	74.0	1.120	GW	195618 195618
FD01EL03	2	4.639	3.522	1.219	1.507	0.964	0.964	1348963	-----	---	---	---	---	1.527	MT	195618
FD01SP03 US	52	3.135	2.380	1.219	1.055	0.964	0.964	-----	334677	72.9	48.0	72.9	48.0	1.069	MT	195618 195618
FD01SP03 DS	52	3.135	2.380	1.219	1.133	0.964	0.964	618638	-----	---	---	---	---	1.219	--	0
FD01EL04	2	4.639	3.522	1.219	1.101	0.964	0.964	-----	338950	118.7	19.0	118.7	19.0	1.110	MT	218618 218618
FD01SP04 US	52	3.135	2.380	1.219	1.059	0.964	0.964	-----	347047	80.2	14.0	80.2	14.0	1.065	MT	218618 218618
FD01SP04 DS	52	3.135	2.380	1.219	1.133	0.964	0.964	618638	-----	---	---	---	---	1.219	--	0
FD01EL05	2	4.639	3.522	1.219	1.091	0.964	0.964	314779	-----	---	---	---	---	1.219	--	0
FD01SP05 US	52	3.135	2.380	1.219	1.133	0.964	0.964	618638	-----	---	---	---	---	1.219	--	0
FD01SP05 DS	52	3.135	2.380	1.219	1.159	0.964	0.964	717185	-----	---	---	---	---	1.204	MT	102975
===Grouped by Line: 003-16*-FDW-03, No Sorting.																
OUTLET P-1-1C	31	8.398	6.376	1.000	0.874	0.769	0.769	-----	144602	186.4	112.0	186.4	112.0	0.919	MT	183618 183618
FD03RD01 (L/E)	18	3.762	2.856	1.219	1.038	0.964	0.964	-----	224808	83.5	96.0	83.5	96.0	1.058	MT	183618 183618
FD03RD01 (S/E)	18	4.703	3.570	1.000	0.967	0.769	0.769	-----	486109	104.4	139.0	104.4	139.0	0.992	MT	183618 183618
FD03EL01	4	4.639	3.522	1.219	1.201	0.964	0.964	-----	588356	103.0	103.0	103.0	103.0	1.226	MT	183618 183618
FD03TE01 (U/S)	15	3.762	2.856	1.219	1.052	0.964	0.964	-----	267751	83.5	37.0	83.5	37.0	1.072	GW	183618 183618
FD03TE01 (D/S)	15	3.762	2.856	1.219	1.069	0.964	0.964	-----	319897	83.5	52.0	83.5	52.0	1.089	MT	183618 183618
FD03SP01	58	2.759	2.094	1.219	1.068	0.964	0.964	-----	430970	70.6	146.0	70.6	146.0	1.073	GW	218618 218618
FD03EL02	4	4.639	3.522	1.219	1.111	0.964	0.964	364624	-----	---	---	---	---	1.152	MT	148782
FD03SP02 US	54	4.013	3.046	1.219	1.060	0.964	0.964	-----	273587	75.3	118.0	75.3	118.0	1.095	GW	148782 148782
FD03SP02 DS	54	4.013	3.046	1.219	1.056	0.964	0.964	-----	262754	59.5	109.0	59.5	109.0	1.107	MT	114614 114614
FD03EL03	1	4.138	3.141	1.219	1.430	0.964	0.964	-----	1298252	96.2	38.0	96.2	38.0	1.448	MT	195618 195618
FD03SP03	51	2.759	2.094	1.219	1.163	0.964	0.964	-----	829696	40.9	82.0	40.9	82.0	1.198	MT	114614 114614
FD03EL04	4	4.639	3.522	1.219	1.403	0.964	0.964	-----	1090308	107.8	91.0	107.8	91.0	1.423	MT	195618 195618
FD03SP04 US	54	4.013	3.046	1.219	1.051	0.964	0.964	-----	247633	93.3	33.0	93.3	33.0	1.068	MT	195618 195618
FD03SP04 DS	54	4.013	3.046	1.219	1.054	0.964	0.964	-----	256333	75.3	130.0	75.3	130.0	1.089	MT	148782 148782
FD03EL05	2	4.639	3.522	1.219	1.230	0.964	0.964	-----	660586	87.0	48.0	87.0	48.0	1.371	MT	148782 148782
FD03SP05	52	3.135	2.380	1.219	1.048	0.964	0.964	-----	308755	58.8	33.0	58.8	33.0	1.076	MT	148782 148782
FD03EL06	4	4.639	3.522	1.219	1.437	0.964	0.964	-----	1175408	87.0	96.0	87.0	96.0	1.478	MT	148782 148782
FD03SP06	54	4.013	3.046	1.219	0.969	0.964	0.964	-----	11901	75.3	144.0	75.3	144.0	1.004	MT	148782 148782
FD03EL07	2	4.639	3.522	1.219	1.508	0.964	0.964	1351886	-----	---	---	---	---	1.533	MT	183618
FD03SP07 US	52	3.135	2.380	1.219	1.151	0.964	0.964	-----	687082	69.6	69.0	69.6	69.0	1.168	GW	183618 183618
FD03SP07 DS	52	3.135	2.380	1.219	1.039	0.964	0.964	272920	-----	---	---	---	---	1.074	MT	125911
===Grouped by Line: 004-24*-FDW-01, No Sorting.																
FD01TE01 (U/S)	12	4.521	3.432	1.812	1.919	1.447	1.447	1205476	-----	---	---	---	---	1.970	MT	125911
FD01TE01 (D/S)	12	3.029	2.299	1.812	2.044	1.447	1.447	2274932	-----	---	---	---	---	2.078	MT	125911
FD01TE01 (BR.)	12	4.263	3.237	1.219	1.101	0.964	0.964	370535	-----	---	---	---	---	1.219	--	0
FD01SP05 DS	62	1.477	1.122	1.812	1.555	1.447	1.447	845365	-----	---	---	---	---	1.576	MT	102975
FD01SP05 US	62	1.477	1.122	1.812	1.482	1.447	1.447	-----	275451	27.7	112.0	27.7	112.0	1.495	MT	148782 148782
FD01TE03 (U/S)	12	4.521	3.432	1.812	1.667	1.447	1.447	562637	-----	---	---	---	---	1.707	MT	148782
FD01TE03 (D/S)	12	3.029	2.299	1.812	1.651	1.447	1.447	779445	-----	---	---	---	---	1.678	MT	148782
FD01TE03 (BR.)	12	4.263	3.237	1.219	1.669	0.964	0.964	1907893	-----	---	---	---	---	1.707	MT	148782
FD01SP07 US	62	1.477	1.122	1.812	1.553	1.447	1.447	-----	829982	27.7	136.0	27.7	136.0	1.566	MT	148782 148782
FD01SP07 DS	62	1.477	1.122	1.812	1.771	1.447	1.447	7638835	-----	---	---	---	---	1.817	--	0

FLOWSEGS DS	52	3.705	2.053	1.375	1.300	1.085	1.085	918823	-----	---	---	---	---	1.375	--	0	-----
FLOWSEGS1 (U/S)	15	3.246	2.464	1.375	1.285	1.085	1.085	712642	-----	---	---	---	---	1.375	--	0	-----
FLOWSEGS1 (D/S)	15	3.246	2.464	1.375	1.285	1.085	1.085	712642	-----	---	---	---	---	1.375	--	0	-----
FLOWSEGS6	4	4.003	3.039	1.375	1.302	1.085	1.085	626415	-----	---	---	---	---	1.328	NT	171740	-----
FLOWSEGS6 US	54	3.462	2.628	1.375	1.260	1.085	1.085	-----	582535	73.3	93.0	73.3	93.0	1.282	GW	171740	171740
FLOWSEGS6 DS	54	3.462	2.628	1.375	1.280	1.085	1.085	648210	-----	---	---	---	---	1.375	--	0	-----
FLOWSEGS7	2	4.003	3.039	1.375	1.265	1.085	1.085	517606	-----	---	---	---	---	1.375	--	0	-----
FLOWSEGS8	4	4.003	3.039	1.375	1.265	1.085	1.085	517606	-----	---	---	---	---	1.375	--	0	-----
INLET E-1-1B	30	4.328	3.285	1.375	1.256	1.085	1.085	454916	-----	---	---	---	---	1.375	--	0	-----

Notes:

- [1] Predictions are based on last Tmeas to analysis ending period.
- [2] Predictions are for the time of last inspection (last known meas. wear).
- [3] GW = Tmeas is minimum thickness from Band, Blanket or Area Method of greatest wear.
 MP = Tmeas is component minimum thickness.
 PW = Tmeas is Tinit - predicted wear.
 US = Tmeas is user specified.
- [4] If no Tmeas has been determined from measured data, then Tmeas = Tinit and Time = current component installation time.
 Tmeas is used to determine Predicted Thickness and Component Predicted Time to Tcrit.

101

 *** Wear Rate Analysis: Combined Rankings for Inspection ***

Run Name: FDW2006 2Pis to E2s
 Ending Period: CYCLE 25
 Total Plant Operating Hours: 241618 Duty Factor (Global): 1.000
 WRA Data Option: Ignore NFA Exclude Measure Wear: No
 Line Correction Factor: 0.196

Component Name	Geometry Code	Average Wear Rate (mils/year)	Component Predicted Time to Texit (hrs)	
			Non-Inspected	Inspected
FD03EL03	1	4.138	-----	1298252
FD03EL07	2	4.639	1351886	-----
FD08RD02 (S/E)	7	6.663	1207354	-----
FD03SP04 DS	54	4.013	-----	256333
OUTLET P-1-1A	31	8.398	-275	-----
OUTLET P-1-1C	31	8.398	-----	144602
FD03SP06	54	4.013	-----	11901
FD07RD02 (S/E)	7	6.663	118553	-----
FD01TE05 (D/S)	15	3.762	-----	116667
FD08RD03 (S/E)	18	5.830	-----	277438
FD07RD03 (S/E)	18	5.830	-----	171557
FD01RD01 (S/E)	18	4.703	314205	-----
FD01RD01 (L/E)	18	3.762	181082	-----
FD03RD01 (S/E)	18	4.703	-----	486109
FD07SP02 DS	52	2.705	211531	-----
FD01EL01	4	4.639	-----	249415
FD07EL07	2	4.003	222858	-----
FD03EL06	4	4.639	-----	1175408
FD03RD01 (L/E)	18	3.762	-----	224808
FD03EL04	4	4.639	-----	1090308
FD03SP04 US	54	4.013	-----	247633
FD01EL05	2	4.639	314779	-----
FD03EL05	2	4.639	-----	660586
FD01EL03	2	4.639	1348963	-----
FD03SP02 DS	54	4.013	-----	262754
FD01EL02	4	4.639	-----	357616
FD03TE01 (U/S)	15	3.762	-----	267751
FD03SP07 DS	52	3.135	272920	-----
FD03EL02	4	4.639	364624	-----
FD03SP02 US	54	4.013	-----	273587
FD01EL04	2	4.639	-----	338950
FD01SP06 US	62	1.477	-----	275451
FD03EL01	4	4.639	-----	588356
FD01TE04 (U/S)	12	4.521	3344486	-----
FD08RD01 (S/E)	7	3.462	-----	277783
FD01TE02 (U/S)	12	4.521	562637	-----
FD03SP05	52	3.135	-----	308755
FD01TE01 (U/S)	12	4.521	1205476	-----
INLET E-2-1B	30	4.328	454916	-----
INLET E-2-1A	30	4.328	454916	-----
FD07EL01	4	4.003	-----	315448
FD01TE02 (BR.)	12	4.263	1907893	-----
FD03TE01 (D/S)	15	3.762	-----	319897
FD01TE04 (BR.)	12	4.263	370635	-----
FD07EL09	4	4.003	330527	-----
FD01TE01 (BR.)	12	4.263	370635	-----
FD01SP03 US	52	3.135	-----	334677
FD07EL06	2	4.003	343925	-----
FD08RD02 (L/E)	7	3.787	346089	-----
FD01SP02 DS	54	4.013	-----	397168
FD01SP04 US	52	3.135	-----	347047
FD08SP05 US	52	2.705	347351	-----
FD07SP10 US	54	3.462	-----	351414
FD01SP02 US	54	4.013	370414	-----
FD07EL04	2	4.003	-----	597590
FD08EL04	4	4.003	569113	-----
FD08EL05	2	4.003	629646	-----
FD08SP04	54	3.462	-----	397769
FD08EL03	2	4.003	697308	-----
FD07SP01 US	54	3.462	-----	424433
FD08EL01	4	4.003	-----	660122
FD08SP01 US	54	3.462	-----	428695
FD08EL02	2	4.003	517606	-----
FD03SP01	58	2.759	-----	430970
FD08EL06	4	4.003	626415	-----
FD01TE05 (U/S)	15	3.762	-----	435674
FD07EL12	4	4.003	517606	-----
FD07RD03 (L/E)	18	3.246	-----	440427
FD08SP02	68	2.705	-----	440606
FD07EL10	4	4.003	517606	-----
FD07EL02	2	4.003	699412	-----
FD07EL05	4	4.003	517606	-----
FD07RD02 (L/E)	7	3.787	469645	-----
FD01SP11	54	2.364	-----	474631
FD07EL03	2	4.003	657209	-----
FD07SP04	52	2.705	-----	476257
FD07EL11	2	4.003	517606	-----
FD08EL08	4	4.003	517606	-----
FD07SP02 US	52	2.705	536181	-----
FD08EL07	2	4.003	517606	-----
FD07SP01 DS	54	3.462	-----	518876
FD08RD01 (L/E)	7	2.585	-----	551432
FD07EL09	1	3.570	619323	-----
FD07RD01 (S/E)	7	3.462	561397	-----
FD07SP10 DS	54	3.462	438210	-----

62

FD07SP03	58	2.705	-----	572650
FD08SP06 US	54	3.462	-----	542535
FD07SP05	54	3.462	648210	-----
FD08RD03 (L/E)	18	3.246	-----	589229
FD08SP01 DS	54	3.462	544210	-----
FD01SP05 US	52	3.135	618638	-----
FD08SP06 DS	54	3.462	648210	-----
FD01SP03 DS	52	3.135	618638	-----
FD01SP04 DS	52	3.135	618638	-----
FD07SP11	54	3.462	648210	-----
FD08TE01 (U/S)	15	3.246	712642	-----
FD08TE01 (D/S)	15	3.246	712642	-----
FD01SP10 DS	65	1.477	-----	637492
FD07TE01 (D/S)	15	3.246	712642	-----
FD07SP08 US	52	2.705	-----	642638
FD07TE01 (U/S)	15	3.246	712642	-----
FD01SP05 DS	52	3.135	717185	-----
FD03SP07 US	52	3.135	-----	687082
FD07RD01 (L/E)	7	2.585	711588	-----
FD01TE02 (D/S)	12	3.029	779445	-----
FD01TE01 (D/S)	12	3.029	2274932	-----
FD01TE04 (D/S)	12	3.029	4846614	-----
FD03SP03	51	2.759	-----	829696
FD07SP09	51	2.380	-----	727091
FD01SP01	58	2.759	746297	-----
FD08SP03 US	52	2.705	-----	731287
FD01EL06	2	2.733	1223953	-----
FD01EL08	4	2.733	1889019	-----
FD01EL07	4	2.733	1223953	-----
FD01SP07 US	62	1.477	-----	829982
FD01SP06 DS	62	1.477	845365	-----
FD07SP08 DS	52	2.705	918823	-----
FD08SP03 DS	52	2.705	918823	-----
FD08SP05 DS	52	2.705	918823	-----
FD07SP07	52	2.705	-----	1005264
FD01SP09	54	2.364	1464924	-----
FD01TE03 (D/S)	15	2.216	1583803	-----
FD01TE03 (U/S)	15	2.216	1583803	-----
FD01SP08	52	1.847	1964216	-----
FD01SP10 US	65	1.477	2534835	-----
FD07SP06	9	1.393	2083806	-----
FD01SP07 DS	62	1.477	2534835	-----

63

 *** Wear Rate Analysis: Thickness, Service Time Report ***

Run Name: FDW2006 RP1s to RP2s
 Ending Period: CYCLE 25
 Total Plant Operating Hours: 241618 Duty Factor (Global): 1.000
 WRA Data Option: Ignore NFA Exclude Measure Wear: No
 Line Correction Factor: 0.196

Component Name	----- Thickness (in) -----				Component Predicted[1]		Component Actual Service Time (hrs)
	Init.	Prd.[1]	Thoop	Terit	Time to Terit (hrs)	Non-Inspected	
===>Grouped by Line: 001-16"-FDW-01. No Sorting.							
OUTLET P-1-IA	1.000	0.768	0.769	0.769	-275	-----	241618
FD01RD01(L/E)	1.219	1.024	0.964	0.964	181082	-----	241618
FD01RD01(S/E)	1.000	0.897	0.769	0.769	314205	-----	241618
FD01EL01	1.219	1.065	0.964	0.964	-----	249415	241618
FD01TE05(U/S)	1.219	1.107	0.964	0.964	-----	435674	241618
FD01TE05(D/S)	1.219	1.003	0.964	0.964	-----	116667	241618
FD01SP01	1.219	1.143	0.964	0.964	746397	-----	241618
FD01EL02	1.219	1.108	0.964	0.964	-----	357616	241618
FD01SP02 US	1.219	1.093	0.964	0.964	370414	-----	241618
FD01SP02 DS	1.219	1.103	0.964	0.964	-----	397168	241618
FD01EL03	1.219	1.507	0.964	0.964	1348963	-----	241618
FD01SP03 US	1.219	1.055	0.964	0.964	-----	334677	241618
FD01SP03 DS	1.219	1.133	0.964	0.964	618638	-----	241618
FD01EL04	1.219	1.101	0.964	0.964	-----	338950	241618
FD01SP04 US	1.219	1.059	0.964	0.964	-----	347047	241618
FD01SP04 DS	1.219	1.133	0.964	0.964	618638	-----	241618
FD01EL05	1.219	1.091	0.964	0.964	314779	-----	241618
FD01SP05 US	1.219	1.133	0.964	0.964	618638	-----	241618
FD01SP05 DS	1.219	1.159	0.964	0.964	717185	-----	241618

===>Grouped by Line: 003-16"-FDW-03. No Sorting.							
OUTLET P-1-1C	1.000	0.874	0.769	0.769	-----	144602	241618
FD03RD01(L/E)	1.219	1.038	0.964	0.964	-----	224808	241618
FD03RD01(S/E)	1.000	0.967	0.769	0.769	-----	486109	241618
FD03EL01	1.219	1.201	0.964	0.964	-----	588356	241618
FD03TE01(U/S)	1.219	1.052	0.964	0.964	-----	267751	241618
FD03TE01(D/S)	1.219	1.069	0.964	0.964	-----	319897	241618
FD03SP01	1.219	1.068	0.964	0.964	-----	430970	241618
FD03EL02	1.219	1.111	0.964	0.964	364624	-----	241618
FD03SP02 US	1.219	1.060	0.964	0.964	-----	273587	241618
FD03SP02 DS	1.219	1.056	0.964	0.964	-----	262754	241618
FD03EL03	1.219	1.430	0.964	0.964	-----	1298252	241618
FD03SP03	1.219	1.163	0.964	0.964	-----	829696	241618
FD03EL04	1.219	1.403	0.964	0.964	-----	1090308	241618
FD03SP04 US	1.219	1.051	0.964	0.964	-----	247633	241618
FD03SP04 DS	1.219	1.054	0.964	0.964	-----	256333	241618
FD03EL05	1.219	1.230	0.964	0.964	-----	660586	241618
FD03SP05	1.219	1.048	0.964	0.964	-----	308755	241618
FD03EL06	1.219	1.437	0.964	0.964	-----	1175408	241618
FD03SP06	1.219	0.969	0.964	0.964	-----	11901	241618
FD03EL07	1.219	1.508	0.964	0.964	1351886	-----	241618
FD03SP07 US	1.219	1.151	0.964	0.964	-----	687082	241618
FD03SP07 DS	1.219	1.039	0.964	0.964	272920	-----	241618

===>Grouped by Line: 004-24"-FDW-01. No Sorting.							
FD01TE01(U/S)	1.812	1.919	1.447	1.447	1205476	-----	241618
FD01TE01(D/S)	1.812	2.044	1.447	1.447	3274932	-----	241618
FD01TE01(BR.)	1.219	1.101	0.964	0.964	370635	-----	241618
FD01SP06 DS	1.812	1.555	1.447	1.447	845365	-----	241618
FD01SP06 US	1.812	1.482	1.447	1.447	-----	275451	241618
FD01TE02(U/S)	1.812	1.667	1.447	1.447	562637	-----	241618
FD01TE02(D/S)	1.812	1.651	1.447	1.447	779445	-----	241618
FD01TE02(BR.)	1.219	1.669	0.964	0.964	1907893	-----	241618
FD01SP07 US	1.812	1.553	1.447	1.447	-----	829982	241618
FD01SP07 DS	1.812	1.771	1.447	1.447	2534835	-----	241618
FD01EL06	1.812	1.737	1.447	1.447	1223953	-----	241618
FD01SP08	1.812	1.761	1.447	1.447	1264216	-----	241618
FD01EL07	1.812	1.737	1.447	1.447	1223953	-----	241618
FD01SP09	1.812	1.747	1.447	1.447	1464924	-----	241618
FD01TE03(U/S)	1.812	1.751	1.447	1.447	1583803	-----	241618
FD01TE03(D/S)	1.812	1.751	1.447	1.447	1583803	-----	241618
FD01SP10 US	1.812	1.771	1.447	1.447	2534835	-----	241618
FD01SP10 DS	1.812	1.528	1.447	1.447	-----	637492	241618
FD01TE04(U/S)	1.812	2.757	1.447	1.447	3344486	-----	241618
FD01TE04(D/S)	1.812	2.719	1.447	1.447	4846614	-----	241618
FD01TE04(BR.)	1.219	1.101	0.964	0.964	370635	-----	241618
FD01EL08	1.812	1.894	1.447	1.447	1889019	-----	241618
FD01SP11	1.812	1.544	1.447	1.447	-----	474631	241618

===>Grouped by Line: 005-18"-FDW-07. No Sorting.							
FD07RD01(L/E)	1.812	1.606	1.447	1.447	711588	-----	241618
FD07RD01(S/E)	1.375	1.254	1.085	1.085	551997	-----	241618
FD07EL01	1.375	1.194	1.085	1.085	-----	315448	241618
FD07SP01 US	1.375	1.212	1.085	1.085	-----	424433	241618
FD07SP01 DS	1.375	1.241	1.085	1.085	-----	518870	241618
FD07EL02	1.375	1.296	1.085	1.085	609412	-----	241618
FD07SP02 US	1.375	1.204	1.085	1.085	506181	-----	241618
FD07SP02 DS	1.375	1.125	1.085	1.085	21521	-----	241618
FD07EL03	1.375	1.313	1.085	1.085	657209	-----	241618

64

FD07RD02 (L/E)	1.375	1.233	1.085	1.085	463645	-----	241618
FD07RD02 (S/E)	0.844	0.716	0.648	0.648	118553	-----	241618
FD07RD03 (L/E)	1.375	1.209	1.085	1.085	-----	440427	241618
FD07RD03 (S/E)	0.844	0.735	0.648	0.648	-----	171557	241618
FD07SP03	1.375	1.219	1.085	1.085	-----	572660	241618
FD07EL04	1.375	1.292	1.085	1.085	-----	597590	241618
FD07SP04	1.375	1.197	1.085	1.085	-----	476257	241618
FD07EL05	1.375	1.265	1.085	1.085	517606	-----	241618
FD07SP05	1.375	1.290	1.085	1.085	648210	-----	241618
FD07SP06	1.375	1.337	1.085	1.085	3983806	-----	241618
FD07EL06	1.375	1.204	1.085	1.085	343925	-----	241618
FD07SP07	1.375	1.321	1.085	1.085	-----	1005264	241618
FD07EL07	1.375	1.162	1.085	1.085	222858	-----	241618
FD07SP08 US	1.375	1.236	1.085	1.085	-----	642638	241618
FD07SP08 DS	1.375	1.300	1.085	1.085	918823	-----	241618
FD07EL08	1.375	1.277	1.085	1.085	618923	-----	241618
FD07SP09	1.375	1.235	1.085	1.085	-----	727091	241618
FD07EL09	1.375	1.200	1.085	1.085	330527	-----	241618
FD07SP10 US	1.375	1.190	1.085	1.085	-----	351414	241618

==>Grouped by Line: 006-18*-FDW-07, No Sorting.

FD07SP10 DS	1.375	1.280	1.085	1.085	648210	-----	241618
FD07TE01 (U/S)	1.375	1.285	1.085	1.085	712642	-----	241618
FD07TE01 (D/S)	1.375	1.285	1.085	1.085	712642	-----	241618
FD07EL10	1.375	1.265	1.085	1.085	517606	-----	241618
FD07SP11	1.375	1.280	1.085	1.085	648210	-----	241618
FD07EL11	1.375	1.265	1.085	1.085	517606	-----	241618
FD07EL12	1.375	1.265	1.085	1.085	517606	-----	241618
INLET E-2-1A	1.375	1.256	1.085	1.085	454916	-----	241618

==>Grouped by Line: 011-18*-FDW-08, No Sorting.

FD08RD01 (L/E)	1.812	1.570	1.447	1.447	-----	551492	241618
FD08RD01 (S/E)	1.375	1.168	1.085	1.085	-----	277783	241618
FD08EL01	1.375	1.314	1.085	1.085	-----	660122	241618
FD08SP01 US	1.375	1.214	1.085	1.085	-----	428695	241618
FD08SP01 DS	1.375	1.280	1.085	1.085	648210	-----	241618
FD08EL02	1.375	1.265	1.085	1.085	517606	-----	241618
FD08RD02 (L/E)	1.375	1.199	1.085	1.085	346089	-----	241618
FD08RD02 (S/E)	0.844	1.345	0.648	0.648	1207354	-----	241618
FD08RD03 (L/E)	1.375	1.251	1.085	1.085	-----	589229	241618
FD08RD03 (S/E)	0.844	0.788	0.648	0.648	-----	277438	241618
FD08SP02	1.375	1.188	1.085	1.085	-----	440606	241618
FD08EL03	1.375	1.327	1.085	1.085	697308	-----	241618
FD08SP03 US	1.375	1.256	1.085	1.085	-----	731287	241618
FD08SP03 DS	1.375	1.300	1.085	1.085	918823	-----	241618
FD08EL04	1.375	1.282	1.085	1.085	569113	-----	241618
FD08SP04	1.375	1.204	1.085	1.085	-----	397769	241618
FD08EL05	1.375	1.303	1.085	1.085	629646	-----	241618
FD08SP05 US	1.375	1.166	1.085	1.085	347351	-----	241618

==>Grouped by Line: 012-18*-FDW-08, No Sorting.

FD08SP05 DS	1.375	1.300	1.085	1.085	918823	-----	241618
FD08TE01 (U/S)	1.375	1.285	1.085	1.085	712642	-----	241618
FD08TE01 (D/S)	1.375	1.285	1.085	1.085	712642	-----	241618
FD08EL06	1.375	1.302	1.085	1.085	626415	-----	241618
FD08SP06 US	1.375	1.260	1.085	1.085	-----	582535	241618
FD08SP06 DS	1.375	1.280	1.085	1.085	648210	-----	241618
FD08EL07	1.375	1.265	1.085	1.085	517606	-----	241618
FD08EL08	1.375	1.265	1.085	1.085	517606	-----	241618
INLET E-2-1B	1.375	1.256	1.085	1.085	454916	-----	241618

Note:
 [1] Predictions are based on last Tmeas to analysis ending period.

65

*** Wear Rate Analysis: Inspection History Report ***

Run Name: FDW2006 2E1s to E2s
 Ending Period: CYCLE 25
 Total Plant Operating Hours: 241618 Duty Factor (Global): 1.000
 WPA Data Option: Ignore NFA Exclude Measure Wear: No
 Line Correction Factor: 0.196

Component Name	Geom. Code	Material				Sigma (psi)	Time (hrs)		Analysis Option	Measured Wear (mils)
		Cr. No.	Cr. (%)	Cu. (%)	Mo. (%)		Last Inspected	Replated		
===>Grouped by Line: 001-16*-FDW-01, No Sorting.										
OUTLET P-1-1A	31	5	0.00	0.00	0.00	15000	-----	-----	---	
FD01RD01(L/E)	18	21	0.00	0.00	0.00	15000	-----	Excl LCF	---	
FD01RD01(S/E)	18	21	0.00	0.00	0.00	15000	-----	Excl LCF	---	
FD01EL01	4	21	0.00	0.00	0.00	15000	218618	-----	79	
FD01TE05(U/S)	15	5	0.00	0.00	0.00	15000	218618	-----	121	
FD01TE05(D/S)	15	5	0.00	0.00	0.00	15000	218618	-----	133	
FD01SP01	58	5	0.00	0.00	0.00	15000	-----	-----	---	
FD01EL02	4	21	0.00	0.00	0.00	15000	171740	-----	88	
FD01SP02 US	54	5	0.00	0.00	0.00	15000	-----	Excl LCF	---	
FD01SP02 DS	54	5	0.00	0.00	0.00	15000	195618	-----	73	
FD01EL03	2	21	0.00	0.00	0.00	15000	-----	Excl LCF	---	
FD01SP03 US	52	5	0.00	0.00	0.00	15000	195618	-----	48	
FD01SP03 DS	52	5	0.00	0.00	0.00	15000	-----	-----	---	
FD01EL04	2	21	0.00	0.00	0.00	15000	218618	-----	19	
FD01SP04 US	52	5	0.00	0.00	0.00	15000	218618	-----	14	
FD01SP04 DS	52	5	0.00	0.00	0.00	15000	-----	-----	---	
FD01EL05	2	21	0.00	0.00	0.00	15000	-----	-----	---	
FD01SP05 US	52	5	0.00	0.00	0.00	15000	-----	-----	---	
FD01SP05 DS	52	5	0.00	0.00	0.00	15000	-----	-----	---	
===>Grouped by Line: 003-16*-FDW-03, No Sorting.										
OUTLET P-1-1C	31	5	0.00	0.00	0.00	15000	183618	-----	112	
FD03RD01(L/E)	18	21	0.00	0.00	0.00	15000	183618	-----	96	
FD03RD01(S/E)	18	21	0.00	0.00	0.00	15000	183618	-----	139	
FD03EL01	4	21	0.00	0.00	0.00	15000	183618	-----	103	
FD03TE01(U/S)	15	5	0.00	0.00	0.00	15000	183618	-----	37	
FD03TE01(D/S)	15	5	0.00	0.00	0.00	15000	183618	-----	52	
FD03SP01	58	5	0.00	0.00	0.00	15000	218618	-----	146	
FD03EL02	4	21	0.00	0.00	0.00	15000	-----	-----	---	
FD03SP02 US	54	5	0.00	0.00	0.00	15000	148782	-----	117	
FD03SP02 DS	54	5	0.00	0.00	0.00	15000	114614	-----	109	
FD03EL03	1	21	0.00	0.00	0.00	15000	195618	-----	38	
FD03SP03	51	5	0.00	0.00	0.00	15000	114614	-----	82	
FD03EL04	4	21	0.00	0.00	0.00	15000	195618	-----	91	
FD03SP04 US	54	5	0.00	0.00	0.00	15000	195618	-----	33	
FD03SP04 DS	54	5	0.00	0.00	0.00	15000	148782	-----	129	
FD03EL05	2	21	0.00	0.00	0.00	15000	148782	-----	48	
FD03SP05	52	5	0.00	0.00	0.00	15000	148782	-----	33	
FD03EL06	4	21	0.00	0.00	0.00	15000	148782	-----	96	
FD03SP06	54	5	0.00	0.00	0.00	15000	148782	-----	144	
FD03EL07	2	21	0.00	0.00	0.00	15000	-----	-----	---	
FD03SP07 US	52	5	0.00	0.00	0.00	15000	183618	-----	69	
FD03SP07 DS	52	5	0.00	0.00	0.00	15000	-----	-----	---	
===>Grouped by Line: 004-24*-FDW-01, No Sorting.										
FD01TE01(U/S)	12	21	0.00	0.00	0.00	15000	-----	Excl LCF	---	
FD01TE01(D/S)	12	21	0.00	0.00	0.00	15000	-----	Excl LCF	---	
FD01TE01(BR.)	12	21	0.00	0.00	0.00	15000	-----	Excl LCF	---	
FD01SP06 DS	62	5	0.00	0.00	0.00	15000	-----	-----	---	
FD01SP06 US	62	5	0.00	0.00	0.00	15000	148782	-----	112	
FD01TE02(U/S)	12	21	0.00	0.00	0.00	15000	-----	Excl LCF	---	
FD01TE02(D/S)	12	21	0.00	0.00	0.00	15000	-----	Excl LCF	---	
FD01TE02(BR.)	12	21	0.00	0.00	0.00	15000	-----	Excl LCF	---	
FD01SP07 US	62	5	0.00	0.00	0.00	15000	148782	-----	136	
FD01SP07 DS	62	5	0.00	0.00	0.00	15000	-----	-----	---	
FD01EL06	2	21	0.00	0.00	0.00	15000	-----	-----	---	
FD01SP08	52	5	0.00	0.00	0.00	15000	-----	-----	---	
FD01EL07	4	21	0.00	0.00	0.00	15000	-----	-----	---	
FD01SP09	54	5	0.00	0.00	0.00	15000	-----	-----	---	
FD01TE03(U/S)	15	21	0.00	0.00	0.00	15000	-----	-----	---	
FD01TE03(D/S)	15	21	0.00	0.00	0.00	15000	-----	-----	---	
FD01SP10 US	65	5	0.00	0.00	0.00	15000	-----	-----	---	
FD01SP10 DS	65	5	0.00	0.00	0.00	15000	125911	-----	50	
FD01TE04(U/S)	12	21	0.00	0.00	0.00	15000	-----	-----	---	
FD01TE04(D/S)	12	21	0.00	0.00	0.00	15000	-----	-----	---	
FD01TE04(BR.)	12	21	0.00	0.00	0.00	15000	-----	-----	---	
FD01EL04	4	21	0.00	0.00	0.00	15000	-----	Excl LCF	---	
FD01SP11	54	5	0.00	0.00	0.00	15000	207118	-----	48	
===>Grouped by Line: 005-1A*-FDW-07, No Sorting.										
FD07RD01(L/E)	7	21	0.00	0.00	0.00	15000	-----	Excl LCF	---	
FD07RD01(S/E)	7	21	0.00	0.00	0.00	15000	-----	Excl LCF	---	
FD07EL01	4	21	0.00	0.00	0.00	15000	183618	-----	100	
FD07SP01 US	54	5	0.00	0.00	0.00	15000	243618	-----	40	
FD07SP01 DS	54	5	0.00	0.00	0.00	15000	150352	-----	107	
FD07EL02	2	21	0.00	0.00	0.00	15000	-----	-----	---	
FD07SP02 US	52	5	0.00	0.00	0.00	15000	-----	-----	---	
FD07SP02 DS	52	5	0.00	0.00	0.00	15000	-----	-----	---	
FD07EL03	2	21	0.00	0.00	0.00	15000	-----	-----	---	

66

FD07PD02(L,E)	7	21	0.00	0.00	0.00	15000	-----	-----	Excl LCP	---
FD07RD02(S,E)	7	21	0.00	0.00	0.00	15000	-----	-----	Excl LCP	---
FD07RD03(L/E)	18	21	0.00	0.00	0.00	15000	195618	-----		113
FD07RD03(S/E)	18	21	0.00	0.00	0.00	15000	195618	-----		79
FD07SP03	68	5	0.00	0.00	0.00	15000	195618	-----		46
FD07ELC4	2	21	0.00	0.00	0.00	15000	171740	-----		130
FD07SP04	52	5	0.00	0.00	0.00	15000	171740	-----		117
FD07EL05	4	21	0.00	0.00	0.00	15000	-----	-----		---
FD07SP05	54	5	0.00	0.00	0.00	15000	-----	-----		---
FD07SP06	9	5	0.00	0.00	0.00	15000	-----	-----		---
FD07EL06	2	21	0.00	0.00	0.00	15000	-----	-----		---
FD07SP07	52	5	0.00	0.00	0.00	15000	171740	-----		65
FD07EL07	2	21	0.00	0.00	0.00	15000	-----	-----		---
FD07SP08 US	52	5	0.00	0.00	0.00	15000	171740	-----		122
FD07SP08 DS	52	5	0.00	0.00	0.00	15000	-----	-----		---
FD07EL08	1	21	0.00	0.00	0.00	15000	-----	-----		---
FD07SP09	51	5	0.00	0.00	0.00	15000	148782	-----		118
FD07EL09	4	21	0.00	0.00	0.00	15000	-----	-----		---
FD07SP10 US	54	5	0.00	0.00	0.00	15000	148782	-----		83

==>Grouped by Line: 006-18--FDW-07, No Sorting.

FD07SP10 DS	54	5	0.00	0.00	0.00	15000	-----	-----		---
FD07TE01(U/S)	15	21	0.00	0.00	0.00	15000	-----	-----		---
FD07TE01(D/S)	15	21	0.00	0.00	0.00	15000	-----	-----		---
FD07EL10	4	21	0.00	0.00	0.00	15000	-----	-----		---
FD07SP11	54	5	0.00	0.00	0.00	15000	-----	-----		---
FD07EL11	2	21	0.00	0.00	0.00	15000	-----	-----		---
FD07EL12	4	21	0.00	0.00	0.00	15000	-----	-----		---
INLET E-2-1A	30	5	0.00	0.00	0.00	15000	-----	-----		---

==>Grouped by Line: 011-18--FDW-08, No Sorting.

FD08RD01(L/E)	7	21	0.00	0.00	0.00	15000	183618	-----		62
FD08RD01(S/E)	7	21	0.00	0.00	0.00	15000	183618	-----		18
FD08EL01	4	21	0.00	0.00	0.00	15000	207118	-----		55
FD08SP01 US	54	5	0.00	0.00	0.00	15000	207118	-----		29
FD08SP01 DS	54	5	0.00	0.00	0.00	15000	-----	-----		---
FD08EL02	2	21	0.00	0.00	0.00	15000	-----	-----		---
FD08RD02(L/E)	7	21	0.00	0.00	0.00	15000	-----	-----		---
FD08RD02(S/E)	7	21	0.00	0.00	0.00	15000	-----	-----		---
FD08RD03(L/E)	18	21	0.00	0.00	0.00	15000	230118	-----		29
FD08RD03(S/E)	18	21	0.00	0.00	0.00	15000	230118	-----		27
FD08SP02	68	5	0.00	0.00	0.00	15000	230118	-----		45
FD08EL03	2	21	0.00	0.00	0.00	15000	-----	-----		---
FD08SP03 US	52	5	0.00	0.00	0.00	15000	102975	-----		137
FD08SP03 DS	52	5	0.00	0.00	0.00	15000	-----	-----		---
FD08EL04	4	21	0.00	0.00	0.00	15000	-----	-----		---
FD08SP04	54	5	0.00	0.00	0.00	15000	183618	-----		72
FD08EL05	2	21	0.00	0.00	0.00	15000	-----	-----		---
FD08SP05 US	52	5	0.00	0.00	0.00	15000	-----	-----		---

==>Grouped by Line: 012-18--FDW-08, No Sorting.

FD08SP05 DS	52	5	0.00	0.00	0.00	15000	-----	-----		---
FD08TE01(U/S)	15	21	0.00	0.00	0.00	15000	-----	-----		---
FD08TE01(D/S)	15	21	0.00	0.00	0.00	15000	-----	-----		---
FD08EL06	4	21	0.00	0.00	0.00	15000	-----	-----		---
FD08SP06 US	54	5	0.00	0.00	0.00	15000	171740	-----		93
FD08SP06 DS	54	5	0.00	0.00	0.00	15000	-----	-----		---
FD08EL07	2	21	0.00	0.00	0.00	15000	-----	-----		---
FD08EL08	4	21	0.00	0.00	0.00	15000	-----	-----		---
INLET E-2-1B	30	5	0.00	0.00	0.00	15000	-----	-----		---

 *** Wear Rate Analysis: Wear Rates/Input Data Report ***

Rur Name: FDW2006 2P1s to E2s
 Ending Period: CYCLE 25
 Total Plant Operating Hours: 241518 Duty Factor (Global): 1.000
 WRA Data Option: Ignore NFA Exclude Measure Wear: No
 Line Correction Factor: 0.196

Component Name	Geom. Code	Average Wear Rate (mils/year)	Current Wear Rate (mils/year)	Temp. (F)	Velocity (ft/s)	Steam Quality	Diameter (in)
===>Grouped by Line: 001-16*-FDW-01, No Sorting.							
OUTLET P-1-1A	31	8.398	6.376	296.9	24.599	0.000	12.750
FD01RD01(L/E)	18	3.762	2.856	296.9	15.456	0.000	16.000
FD01RD01(S/E)	18	4.703	3.570	296.9	24.599	0.000	12.750
FD01EL01	4	4.639	3.522	296.9	15.456	0.000	16.000
FD01TE05(U/S)	15	3.762	2.856	296.9	15.456	0.000	16.000
FD01TE05(D/S)	15	3.762	2.856	296.9	15.456	0.000	16.000
FD01SP01	58	2.759	2.094	296.9	15.456	0.000	16.000
FD01EL02	4	4.639	3.522	296.9	15.456	0.000	16.000
FD01SP02 US	54	4.013	3.046	296.9	15.456	0.000	16.000
FD01SP02 DS	54	4.013	3.046	296.9	15.456	0.000	16.000
FD01EL03	2	4.639	3.522	296.9	15.456	0.000	16.000
FD01SP03 US	52	3.135	2.380	296.9	15.456	0.000	16.000
FD01SP03 DS	52	3.135	2.380	296.9	15.456	0.000	16.000
FD01EL04	2	4.639	3.522	296.9	15.456	0.000	16.000
FD01SP04 US	52	3.135	2.380	296.9	15.456	0.000	16.000
FD01SP04 DS	52	3.135	2.380	296.9	15.456	0.000	16.000
FD01EL05	2	4.639	3.522	296.9	15.456	0.000	16.000
FD01SP05 US	52	3.135	2.380	296.9	15.456	0.000	16.000
FD01SP05 DS	52	3.135	2.380	296.9	15.456	0.000	16.000

===>Grouped by Line: 003-16*-FDW-03, No Sorting.							
OUTLET P-1-1C	31	8.398	6.376	296.9	24.599	0.000	12.750
FD03RD01(L/E)	18	3.762	2.856	296.9	15.456	0.000	16.000
FD03RD01(S/E)	18	4.703	3.570	296.9	24.599	0.000	12.750
FD03EL01	4	4.639	3.522	296.9	15.456	0.000	16.000
FD03TE01(U/S)	15	3.762	2.856	296.9	15.456	0.000	16.000
FD03TE01(D/S)	15	3.762	2.856	296.9	15.456	0.000	16.000
FD03SP01	58	2.759	2.094	296.9	15.456	0.000	16.000
FD03EL02	4	4.639	3.522	296.9	15.456	0.000	16.000
FD03SP02 US	54	4.013	3.046	296.9	15.456	0.000	16.000
FD03SP02 DS	54	4.013	3.046	296.9	15.456	0.000	16.000
FD03EL03	1	4.138	3.141	296.9	15.456	0.000	16.000
FD03SP03	51	2.759	2.094	296.9	15.456	0.000	16.000
FD03EL04	4	4.639	3.522	296.9	15.456	0.000	16.000
FD03SP04 US	54	4.013	3.046	296.9	15.456	0.000	16.000
FD03SP04 DS	54	4.013	3.046	296.9	15.456	0.000	16.000
FD03EL05	2	4.639	3.522	296.9	15.456	0.000	16.000
FD03SP05	52	3.135	2.380	296.9	15.456	0.000	16.000
FD02EL06	4	4.639	3.522	296.9	15.456	0.000	16.000
FD03SP06	54	4.013	3.046	296.9	15.456	0.000	16.000
FD03EL07	2	4.639	3.522	296.9	15.456	0.000	16.000
FD03SP07 US	52	3.135	2.380	296.9	15.456	0.000	16.000
FD03SP07 DS	52	3.135	2.380	296.9	15.456	0.000	16.000

===>Grouped by Line: 004-24*-FDW-01, No Sorting.							
FD01TE01(U/S)	12	4.521	3.432	294.7	13.741	0.000	24.000
FD01TE01(D/S)	12	3.029	2.299	296.9	6.847	0.000	24.000
FD01TE01(BR.)	12	4.263	3.237	296.9	15.456	0.000	16.000
FD01SP06 DS	62	1.477	1.122	296.9	6.847	0.000	24.000
FD01SP06 US	62	1.477	1.122	296.9	6.847	0.000	24.000
FD01TE02(U/S)	12	4.521	3.432	294.7	13.741	0.000	24.000
FD01TE02(D/S)	12	3.029	2.299	296.9	6.847	0.000	24.000
FD01TE02(BR.)	12	4.263	3.237	296.9	15.456	0.000	16.000
FD01SP07 US	62	1.477	1.122	296.9	6.847	0.000	24.000
FD01SP07 DS	62	1.477	1.122	296.9	6.847	0.000	24.000
FD01EL06	2	2.733	2.075	296.9	6.847	0.000	24.000
FD01SP08	52	1.847	1.402	296.9	6.847	0.000	24.000
FD01EL07	4	2.733	2.075	296.9	6.847	0.000	24.000
FD01SP09	54	2.364	1.795	296.9	6.847	0.000	24.000
FD01TE03(U/S)	15	2.216	1.682	296.9	6.847	0.000	24.000
FD01TE03(D/S)	15	2.216	1.682	296.9	6.847	0.000	24.000
FD01SP10 US	65	1.477	1.122	296.9	6.847	0.000	24.000
FD01SP10 DS	65	1.477	1.122	296.9	6.847	0.000	24.000
FD01TE04(U/S)	12	4.521	3.432	294.7	13.741	0.000	24.000
FD01TE04(D/S)	12	3.029	2.299	296.9	6.847	0.000	24.000
FD01TE04(BR.)	12	4.263	3.237	296.9	15.456	0.000	16.000
FD01EL08	4	2.733	2.075	296.9	6.847	0.000	24.000
FD01SP11	54	2.364	1.795	296.9	6.847	0.000	24.000

===>Grouped by Line: 005-18*-FDW-07, No Sorting.							
FD07RD01(C/E)	7	2.585	1.953	296.9	6.847	0.000	24.000
FD07RD01(S/E)	7	3.463	2.628	296.9	12.224	0.000	18.000
FD07EL01	4	4.033	3.033	296.9	12.224	0.000	18.000
FD07SP01 US	54	3.462	2.628	296.9	12.224	0.000	18.000
FD07SP01 DS	54	3.462	2.628	296.9	12.224	0.000	18.000
FD07EL02	2	4.033	3.033	296.9	12.224	0.000	18.000
FD07SP02 US	52	2.705	2.053	296.9	12.224	0.000	18.000
FD07SP02 DS	52	2.705	2.053	296.9	12.224	0.000	18.000
FD07EL03	2	4.003	3.033	296.9	12.224	0.000	18.000

68

FD07PD02(L/E)	7	3.787	2.875	296.9	12.224	0.000	18.000
FD07RD02(S/E)	7	6.663	5.059	296.9	34.617	0.000	10.750
FD07RD03(L/E)	18	3.246	2.464	296.9	12.224	0.000	18.000
FD07RD03(S/E)	18	5.830	4.426	296.9	34.617	0.000	10.750
FD07SP03	68	2.705	2.053	296.9	12.224	0.000	18.000
FD07EL04	2	4.003	3.039	296.9	12.224	0.000	18.000
FD07SP04	52	2.705	2.053	296.9	12.224	0.000	18.000
FD07EL05	4	4.003	3.039	296.9	12.224	0.000	18.000
FD07SP05	54	3.462	2.628	296.9	12.224	0.000	18.000
FD07SP06	9	1.393	1.057	296.9	12.224	0.000	18.000
FD07EL06	2	4.003	3.039	296.9	12.224	0.000	18.000
FD07SP07	52	2.705	2.053	296.9	12.224	0.000	18.000
FD07EL07	2	4.003	3.039	296.9	12.224	0.000	18.000
FD07SP08 US	52	2.705	2.053	296.9	12.224	0.000	18.000
FD07SP08 DS	52	2.705	2.053	296.9	12.224	0.000	18.000
FD07EL08	1	3.570	2.710	296.9	12.224	0.000	18.000
FD07SP09	51	2.380	1.807	296.9	12.224	0.000	18.000
FD07EL09	4	4.003	3.039	296.9	12.224	0.000	18.000
FD07SP10 US	54	3.462	2.628	296.9	12.224	0.000	18.000

====>Grouped by Line: 006-18*-FDW-07, No Sorting.

FD07SP10 DS	54	3.462	2.628	296.9	12.224	0.000	18.000
FD07TE01(U/S)	15	3.246	2.464	296.9	12.224	0.000	18.000
FD07TE01(D/S)	15	3.246	2.464	296.9	12.224	0.000	18.000
FD07EL10	4	4.003	3.039	296.9	12.224	0.000	18.000
FD07SP11	54	3.462	2.628	296.9	12.224	0.000	18.000
FD07EL11	2	4.003	3.039	296.9	12.224	0.000	18.000
FD07EL12	4	4.003	3.039	296.9	12.224	0.000	18.000
INLET E-2-1A	30	4.328	3.285	296.9	12.224	0.000	18.000

====>Grouped by Line: 011-18*-FDW-08, No Sorting.

FD08RD01(L/E)	7	2.585	1.963	296.9	6.847	0.000	24.000
FD08RD01(S/E)	7	3.462	2.628	296.9	12.224	0.000	18.000
FD08EL01	4	4.003	3.039	296.9	12.224	0.000	18.000
FD08SP01 US	54	3.462	2.628	296.9	12.224	0.000	18.000
FD08SP01 DS	54	3.462	2.628	296.9	12.224	0.000	18.000
FD08EL02	2	4.003	3.039	296.9	12.224	0.000	18.000
FD08RD02(L/E)	7	3.787	2.875	296.9	12.224	0.000	18.000
FD08RD02(S/E)	7	6.663	5.059	296.9	34.617	0.000	10.750
FD08RD03(L/E)	18	3.246	2.464	296.9	12.224	0.000	18.000
FD08RD03(S/E)	18	5.830	4.426	296.9	34.617	0.000	10.750
FD08SP02	68	2.705	2.053	296.9	12.224	0.000	18.000
FD08EL03	2	4.003	3.039	296.9	12.224	0.000	18.000
FD08SP03 US	52	2.705	2.053	296.9	12.224	0.000	18.000
FD08SP03 DS	52	2.705	2.053	296.9	12.224	0.000	18.000
FD08EL04	4	4.003	3.039	296.9	12.224	0.000	18.000
FD08SP04	54	3.462	2.628	296.9	12.224	0.000	18.000
FD08EL05	2	4.003	3.039	296.9	12.224	0.000	18.000
FD08SP05 US	52	2.705	2.053	296.9	12.224	0.000	18.000

====>Grouped by Line: 012-18*-FDW-08, No Sorting.

FD08SP05 DS	52	2.705	2.053	296.9	12.224	0.000	18.000
FD08TE01(U/S)	15	3.246	2.464	296.9	12.224	0.000	18.000
FD08TE01(D/S)	15	3.246	2.464	296.9	12.224	0.000	18.000
FD08EL06	4	4.003	3.039	296.9	12.224	0.000	18.000
FD08SP06 US	54	3.462	2.628	296.9	12.224	0.000	18.000
FD08SP06 DS	54	3.462	2.628	296.9	12.224	0.000	18.000
FD08EL07	2	4.003	3.039	296.9	12.224	0.000	18.000
FD08EL08	4	4.003	3.039	296.9	12.224	0.000	18.000
INLET E-2-1B	30	4.328	3.285	296.9	12.224	0.000	18.000

69

Company: Vermont Yankee Nuclear Power Corporation Report Date: 28-SEP-2006 Time: 10:04:44
 Plant: Vermont Yankee Analysis Date: 28-SEP-2006 Time: 10:03:33
 Unit: CHECWORKS FAC Version 1.0F (Build 52)
 EB Name: VT

 *** Wear Rate Analysis: Combined Rankings for Inspection ***

Run Name: FWR2006 E1s to E2s
 Ending Period: CYCLE 25
 Total Plant Operating Hours: 241618 Duty Factor (Global): 1.000
 WRA Data Option: Ignore NFA Exclude Measure Wear: No
 Line Correction Factor: 0.196

Component Name	Geometry Code	Average Wear Rate (mils/year)	Component Predicted Time to Tcrit (hrs)	
			Non-Inspected	Inspected
FD03EL01	1	4.138	-----	1298252
FD03EL07	2	4.639	1351886	-----
FD03RD02 (S/E)	7	6.663	1207354	-----
FD03SP04 DS	54	4.013	-----	256333
OUTLET P-1-1A	31	8.398	-275	-----
OUTLET P-1-1C	31	8.398	-----	144602
FD03SP06	54	4.013	-----	11901
FD07K002 (S/E)	7	6.663	118553	-----
FD01TE05 (D/S)	15	3.762	-----	116667
FD03RD03 (S/E)	18	5.830	-----	277438
FD07RD03 (S/E)	18	5.830	-----	171557
FD03RD01 (S/E)	18	4.703	314205	-----
FD03RD01 (L/E)	18	3.762	181082	-----
FD03FD01 (S/E)	18	4.703	-----	486109
FD07SP02 DS	52	2.705	211531	-----
FD03EL01	4	4.639	-----	249415
FD07EL07	2	4.003	222858	-----
FD03EL06	4	4.639	-----	1175408
FD03RD01 (L/E)	18	3.762	-----	224808
FD03EL04	4	4.639	-----	1090308
FD03SP04 US	54	4.013	-----	247633
FD01EL05	2	4.639	314779	-----
FD03EL05	2	4.639	-----	660586
FD01EL03	2	4.639	1348963	-----
FD03SP02 DS	54	4.013	-----	262754
FD01EL02	4	4.639	-----	357616
FD02TE01 (U/S)	15	3.762	-----	267751
FD03SP07 DS	52	3.135	272920	-----
FD03EL02	4	4.639	364624	-----
FD03SP02 US	54	4.013	-----	273587
FD01EL04	2	4.639	-----	338950
FD01SP06 US	62	1.477	-----	275451
FD03EL01	4	4.639	-----	588356
FD01TE04 (U/S)	12	4.521	3344486	-----
FD03RD01 (S/E)	7	3.462	-----	277783
FD01TE02 (U/S)	12	4.521	562637	-----
FD03SP05	52	3.135	-----	308755
FD01TE01 (U/S)	12	4.521	1205476	-----
INLET E-1-1B	30	4.328	454916	-----
INLET E-2-1A	30	4.328	454916	-----
FD07EL01	4	4.003	-----	315448
FD01TE02 (BR.)	12	4.263	1907893	-----
FD03TE01 (D/S)	15	3.762	-----	319897
FD01TE04 (BR.)	12	4.263	370635	-----
FD07EL09	4	4.003	330527	-----
FD01TE01 (BR.)	12	4.263	370635	-----
FD01SP03 US	52	3.135	-----	334677
FD07EL06	2	4.003	343925	-----
FD03RD02 (L/E)	7	3.787	346089	-----
FD01SP02 DS	54	4.013	-----	397168
FD01SP04 US	52	3.135	-----	347047
FD03SP05 US	52	2.705	347351	-----
FD07SP10 US	54	3.462	-----	351414
FD01SP02 US	54	4.013	370414	-----
FD07EL04	2	4.003	-----	597590
FD08EL04	4	4.003	569113	-----
FD08EL05	2	4.003	629646	-----
FD08SP04	54	3.462	-----	397769
FD08EL03	2	4.003	697308	-----
FD07SP01 US	54	3.462	-----	424422

78

FD08EL01	4	4.003	-----	660122
FD08SP01 US	54	3.462	-----	428695
FD08EL02	2	4.003	517606	-----
FD03SP01	58	2.759	-----	430970
FD08EL06	4	4.003	826415	-----
FD01TE05 (U/S)	15	3.782	-----	435674
FD07EL13	4	4.003	517606	-----
FD07KD03 (L/E)	18	3.246	-----	440427
FD08SP02	88	2.705	-----	440606
FD07EL10	4	4.003	517606	-----
FD07EL02	2	4.003	609412	-----
FD07EL05	4	4.003	517606	-----
FD07KD02 (L/E)	7	3.787	469845	-----
FD01SP11	54	2.364	-----	474631
FD07EL03	2	4.003	657209	-----
FD07SP04	52	2.705	-----	476257
FD07EL11	2	4.003	517606	-----
FD08EL08	4	4.003	517606	-----
FD07SP02 US	52	2.705	506181	-----
FD08EL07	2	4.003	517606	-----
FD07SP01 DS	54	3.462	-----	518870
FD08KD01 (L/E)	7	2.585	-----	551492
FD07EL08	1	3.570	618923	-----
FD07PD01 (S/E)	7	3.462	561997	-----
FD07SP10 DS	54	3.462	648210	-----
FD07SP03	68	2.705	-----	572660
FD08SP06 US	54	3.462	-----	582535
FD07SP05	54	3.462	648210	-----
FD08PD03 (L/E)	18	3.246	-----	589229
FD08SP01 DS	54	3.462	648210	-----
FD01SP05 US	52	3.135	618638	-----
FD08SP06 DS	54	3.462	648210	-----
FD01SP03 DS	52	3.135	618638	-----
FD01SP04 DS	52	3.135	618638	-----
FD07SP11	54	3.462	648210	-----
FD08TE01 (U/S)	15	3.246	712642	-----
FD08TE01 (D/S)	15	3.246	712642	-----
FD01SP10 DS	65	1.477	-----	637492
FD07TE01 (D/S)	15	3.246	712642	-----
FD07SP08 US	52	2.705	-----	642638
FD07TE01 (U/S)	15	3.246	712642	-----
FD01SP05 DS	52	3.135	717185	-----
FD03SP07 US	52	3.135	-----	687082
FD07KD01 (L/E)	7	2.585	711588	-----
FD01TE02 (D/S)	12	3.029	779445	-----
FD01TE01 (D/S)	12	3.029	2274932	-----
FD01TE04 (D/S)	12	3.029	4846614	-----
FD01SP03	51	2.759	-----	829696
FD07SP09	51	2.380	-----	727091
FD01SP01	58	2.759	746397	-----
FD08SP03 US	52	2.705	-----	731287
FD01EL06	2	2.733	1223953	-----
FD01EL08	4	2.733	1889019	-----
FD01EL07	4	2.733	1223953	-----
FD01SP07 US	62	1.477	-----	829982
FD01SP06 DS	52	1.477	845365	-----
FD07SP08 DS	52	2.705	918823	-----
FD08SP03 DS	52	2.705	918823	-----
FD08SP05 DS	52	2.705	918823	-----
FD07SP07	52	2.705	-----	1005264
FD01SP09	54	2.384	1464924	-----
FD01TE03 (D/S)	15	2.216	1583803	-----
FD01TE03 (U/S)	15	2.216	1583803	-----
FD01SP08	52	1.847	1964216	-----
FD01SP10 US	65	1.477	2534835	-----
FD07SP06	9	1.393	2083806	-----
FD01SP07 DS	62	1.477	2534835	-----

12

Company: Vermont Yankee Nuclear Power Corporation Report Date: 28-SEP-2006 Time: 10:04:48
 Plant: Vermont Yankee Analysis Date: 28-SEP-2006 Time: 10:03:33
 Unit: CHECWORKS FAC Version 1.0F (Build 52)
 DB Name: VY

 *** Wear Rate Analysis: Wear Predictions Report ***

Run Name: FDW2006 2P1s to E2s
 Ending Period: CYCLE 25
 Total Plant Operating Hours: 241618 Duty Factor (Global): 1.000
 WRA Data Option: Ignore NFA Exclude Measure Wear: No
 Line Correction Factor: 0.196

Component Name	Total Lifetime In-Service Cmp.		In-Service Cmp.		In-Service Cmp.		Incremental Wear (mils) [5]	Time (hrs) Last Inspected			
	Wear (mils) Prd. [1]	Meas. Meas.	Wear (mils) Prd. [1]	Meas.	Tmeas, Method, Time (in) [3] [2] (hrs) [3]	Thickness (mils) [4] Tp Tm					
===>Grouped by Line: 001-16*-FDW-01, No Sorting.											
FD01EL01	118.7	79.0	118.7	79.0	1.074	MT	218618	1100.3	1074.0	9.2	218618
FD01TE05 (U/S)	96.3	122.0	96.3	122.0	1.114	MT	218618	1122.7	1114.0	7.5	218618
FD01TE05 (D/S)	96.3	133.0	96.3	133.0	1.010	MT	218618	1122.7	1010.0	7.5	218618
FD01EL02	98.2	88.0	98.2	88.0	1.138	MT	171740	1120.8	1138.0	29.7	171740
FD01SP02 DS	93.3	74.0	93.3	74.0	1.120	GW	195618	1125.7	1120.0	17.4	195618
FD01SP03 US	72.9	48.0	72.9	48.0	1.069	MT	195618	1146.1	1069.0	13.6	195618
FD01EL04	118.7	19.0	118.7	19.0	1.110	MT	218618	1100.3	1110.0	9.2	218618
FD01SP04 US	80.2	14.0	80.2	14.0	1.065	MT	218618	1138.8	1065.0	6.2	218618
===>Grouped by Line: 003-16*-FDW-03, No Sorting.											
OUTLET P-1-1C	186.4	112.0	186.4	112.0	0.919	MT	183618	813.6	919.0	45.2	183618
FD03RD01 (L/E)	83.5	96.0	83.5	96.0	1.058	MT	183618	1135.5	1058.0	20.2	183618
FD03RD01 (S/E)	104.4	139.0	104.4	139.0	0.992	MT	183618	895.6	992.0	25.3	183618
FD03EL01	103.0	103.0	103.0	103.0	1.226	MT	183618	1116.0	1226.0	25.0	183618
FD03TE01 (U/S)	83.5	37.0	83.5	37.0	1.072	GW	183618	1135.5	1072.0	20.2	183618
FD03TE01 (D/S)	83.5	52.0	83.5	52.0	1.089	MT	183618	1135.5	1089.0	20.2	183618
FD03SP01	70.6	146.0	70.6	146.0	1.073	GW	218618	1148.4	1073.0	5.5	218618
FD03SP02 US	75.3	118.0	75.3	118.0	1.095	GW	148782	1143.7	1095.0	35.4	148782
FD03SP02 DS	59.5	109.0	59.5	109.0	1.107	MT	114614	1159.5	1107.0	51.2	114614
FD03EL03	96.2	38.0	96.2	38.0	1.448	MT	195618	1122.8	1448.0	18.0	195618
FD03SP03	40.9	82.0	40.9	82.0	1.198	MT	114614	1178.1	1198.0	35.2	114614
FD03EL04	107.8	91.0	107.8	91.0	1.423	MT	195618	1111.2	1423.0	20.1	195618
FD03SP04 US	93.3	33.0	93.3	33.0	1.068	MT	195618	1125.7	1068.0	17.4	195618
FD03SP04 DS	75.3	130.0	75.3	130.0	1.089	MT	148782	1143.7	1089.0	35.4	148782
FD03EL05	87.0	48.0	87.0	48.0	1.271	MT	148782	1132.0	1271.0	40.9	148782
FD03SP05	58.8	33.0	58.8	33.0	1.076	MT	148782	1160.2	1076.0	27.7	148782
FD03EL06	87.0	96.0	87.0	96.0	1.478	MT	148782	1132.0	1478.0	40.9	148782
FD03SP06	75.3	144.0	75.3	144.0	1.004	MT	148782	1143.7	1004.0	35.4	148782
FD03SP07 US	69.6	69.0	69.6	69.0	1.168	GW	183618	1149.4	1168.0	16.9	183618
===>Grouped by Line: 004-24*-FDW-01, No Sorting.											
FD01SP06 US	27.7	112.0	27.7	112.0	1.495	MT	148782	1784.3	1495.0	13.0	148782
FD01SP07 US	27.7	136.0	27.7	136.0	1.566	MT	148782	1784.3	1566.0	13.0	148782
FD01SP10 DS	24.1	50.0	24.1	50.0	1.545	MT	125911	1787.9	1545.0	16.7	125911
FD01SP11	58.1	48.0	58.1	48.0	1.551	MT	207118	1753.9	1551.0	7.1	207118
===>Grouped by Line: 005-18*-FDW-07, No Sorting.											
FD07EL01	88.9	101.0	88.9	101.0	1.216	MT	183618	1286.1	1216.0	21.5	183618
FD07SP01 US	76.9	40.0	76.9	40.0	1.231	MT	183618	1298.1	1231.0	18.6	183618
FD07SP01 DS	68.2	107.0	68.2	107.0	1.268	GW	160352	1306.8	1268.0	27.3	160352
FD07RD03 (L/E)	75.4	113.0	75.4	113.0	1.223	MT	195618	1299.6	1223.0	14.1	195618
FD07RD03 (S/E)	115.5	79.0	115.5	79.0	0.760	MT	195618	708.5	760.0	25.3	195618
FD07SP03	62.9	46.0	62.9	46.0	1.231	MT	195618	1312.1	1231.0	11.7	195618
FD07EL04	84.7	130.0	84.7	130.0	1.318	MT	171740	1290.3	1318.0	25.7	171740
FD07SP04	57.3	117.0	57.3	117.0	1.214	MT	171740	1317.7	1214.0	17.3	171740
FD07SP07	57.3	65.0	57.3	65.0	1.338	GW	171740	1317.7	1338.0	17.3	171740
FD07SP08 US	57.3	122.0	57.3	122.0	1.253	MT	171740	1317.7	1253.0	17.3	171740
FD07SP09	44.7	118.0	44.7	118.0	1.256	MT	148782	1330.3	1256.0	21.0	148782
FD07SP10 US	65.0	83.0	65.0	83.0	1.221	MT	148782	1310.0	1221.0	30.5	148782

===>Grouped by Line: 006-18*-FDW-07, No Sorting.

===>Grouped by Line: 011-18*-FDW-02, No Sorting.

22

FD08RDD1 (L/E)	57.4	62.0	57.4	62.0	1.578	MT	207118	1754.6	1578.0	7.7	183618
FD08RDD1 (S/E)	76.9	18.0	76.9	18.0	1.187	MT	183618	1298.1	1187.0	18.6	183618
FD08REL01	98.4	56.0	98.4	56.0	1.326	MT	207118	1276.6	1326.0	12.0	207118
FD08SP01 US	85.1	30.0	85.1	30.0	1.224	MT	207118	1289.9	1224.0	10.4	207118
FD08RDD03 (L/E)	86.3	29.0	86.3	29.0	1.254	MT	230118	1288.7	1254.0	3.2	230118
FD08RDD03 (S/E)	155.0	28.0	155.0	28.0	0.794	MT	230118	689.0	794.0	5.8	230118
FD08SP02	71.9	45.0	71.9	45.0	1.191	MT	230118	1303.1	1191.0	2.7	230118
FD08SP03 US	36.0	137.0	36.0	137.0	1.295	MT	102975	1339.0	1295.0	38.6	102975
FD08SP04	76.9	72.0	76.9	72.0	1.223	MT	183618	1298.1	1223.0	18.6	183618


=== Grouped by Line: 013-18*-FDW-08, No Sorting.

FD08SP06 US	73.3	93.0	73.3	93.0	1.282	GW	171740	1301.7	1282.0	22.2	171740
-------------	------	------	------	------	-------	----	--------	--------	--------	------	--------


Notes:

- [1] Predictions are for the time of last inspection (last known meas. wear).
- [2] GW = Tmeas is minimum thickness from Band, Blanket or Area Method of greatest wear.
 MT = Tmeas is component minimum thickness.
 PW = Tmeas is Tinit - predicted wear.
 US = Tmeas is user specified.
- [3] If no Tmeas has been determined from measured data, then Tmeas = Tinit and Time = current component installation time.
 Tmeas is used to determine Predicted Thickness and Component Predicted Time to Tcrit.
- [4] These two values are used for thickness plot.
 Tp = Predicted thickness at Tmeas.
 Tm = Last measured thickness (Tmeas).
- [5] PRWEAR = Incremental wear from last Tmeas time to analysis ending period.

Cumulative % of Comp. Time to Tcrit



Tpred/Tcrit Ratio Plot



75



Wear Rate Analysis Run Definition

Run Name: FDW2006 E2s to E1s

Run Title: Feedwater E2A to E1A and E2B to E1B

Ending Period: CYCLE 25

Total Oper. Hrs.: 241618.43

Duty Factor: 1.000

Analysis Options

- Ignore IFA Results
- IFA Results 1st Priority
- User Input 1st Priority
- Do Not Use Measured Wear

Database Lines		Add	Remove	Lines to Analyze
001-16"-FDW-01		>	<	007-18"-FDW-12
002-16"-FDW-02		>>	<<	013-18"-FDW-13
003-16"-FDW-03				
004-24"-FDW-01				
005-18"-FDW-07				
006-18"-FDW-07				
008-16"-FDW-14				
008-18"-FDW-14				


Run Definitions

- 3rd Pt High Level
- 4th Pt Extract Steam
- 4th Pt Heater Drain
- 4th Pt High Level
- 5th Pt Extract Steam
- 5th Pt Heater Drains
- Cond LP Htr Bypass
- Cond Minimum Flow
- Condensate
- FDW 2006 E1s to Rx
- FDW 2006 Hdr to E2s
- FDW06 2 P1s to Hdr
- FDW06 3-P1s to Hdr
- FDW2006 E2s to E1s**
- Feed Pump Recirc
- Feedwater
- Feedwater Flush
- Feedwater Low Flow
- Heater Drain Pumps


< Prev	Next >	Add	Reset	Save	
Copy	Delete	Print...	Help	Done	Advanced Run Def...

List of Defined Wear Rate Runs

76




Comparison of Thickness Predictions



22

Comparison of Wear Predictions



◆ Current Component



82

Company: Vermont Yankee Nuclear Power Corporation
 Plant: Vermont Yankee
 Unit:
 DR Name: VY

Report Date: 13-SEP-2006 Time: 19:32:04
 Analysis Date: 13-SEP-2006 Time: 19:29:27
 CHECWORKS FAC Version 1.0F (Build 52)

*** Wear Rate Analysis: Combined Summary Report ***

Run Name: FDW2006 E2s to Els
 Ending Period: CYCLE 15
 Total Plant Operating Hours: 241618
 WRA Data Option: Ignore NFA
 Line Correction Factor: 0.446

Duty Factor (Global): 1.000
 Exclude Measure Wear: No

Component Name	Geom. Code	Average Wear Rate (mils/year)	Current Wear Rate (mils/year)	Thickness (in)				Component Predict[1]		Total Lifetime		In-Service Cmp.		In-Service Cmp.		Time (hrs) Last Inspected	
				Init.	Prd.[1]	Thoop	Tcrit	Time to Tcrit (hrs) Non-Insp.	Insp.	Wear (mils) Prd.[2]	Meas.	Wear (mils) Prd.[2]	Meas.	Tmeas. Method	Time (hrs) [4]		
==>Grouped by Line: 007-18*-FDW-12, No Sorting.																	
OUTLET E-2-1A	31	8.482	6.440	1.375	1.141	1.085	1.085	76194						1.375	--	0	
FD12EL01	4	6.277	4.765	1.375	1.202	1.085	1.085	214787						1.375	--	0	
FD12SP01 US	54	5.429	4.121	1.375	1.225	1.085	1.085	298076						1.375	--	0	
FD12SP01 DS	54	5.429	4.121	1.375	1.225	1.085	1.085	298076						1.375	--	0	
FD12EL02	2	6.277	4.765	1.375	1.202	1.085	1.085	214787						1.375	--	0	
FD12SP02	52	4.241	3.220	1.375	1.258	1.085	1.085	470651						1.375	--	0	
FD12EL03	2	6.277	4.765	1.375	1.202	1.085	1.085	214787						1.375	--	0	
FD12SP03	52	4.241	3.220	1.375	1.258	1.085	1.085	470651						1.375	--	0	
FD12SP04	9	2.196	1.667	1.375	1.314	1.085	1.085	1205306						1.375	--	0	
FD12EL04	2	6.277	4.765	1.375	1.202	1.085	1.085	214787						1.375	--	0	
FD12SP05 US	52	4.241	3.220	1.375	1.258	1.085	1.085	470651						1.375	--	0	
FD12SP05 DS	52	4.241	3.220	1.375	1.258	1.085	1.085	470651						1.375	--	0	
FD12EL05	2	6.277	4.765	1.375	1.202	1.085	1.085	214787						1.375	--	0	
FD12SP06	52	4.241	3.220	1.375	1.258	1.085	1.085	470651						1.375	--	0	
FD12SP07	9	2.196	1.667	1.375	1.302	1.085	1.085	-----	1139023	58.4	71.0	58.4	71.0	1.304	US	230118	230118
FD12EL06	2	6.277	4.765	1.375	1.373	1.085	1.085	-----	528901	166.9	132.0	166.9	132.0	1.379	US	230118	230118
FD12SP08	52	4.241	3.220	1.375	1.274	1.085	1.085	-----	513511	112.8	97.0	112.8	97.0	1.278	US	230118	230118
FD12EL07	2	6.277	4.765	1.375	1.202	1.085	1.085	214787						1.375	--	0	
FD12SP09	52	4.241	3.220	1.375	1.258	1.085	1.085	470651						1.375	--	0	
FD12TE01 (U/S)	15	5.089	3.864	1.375	1.235	1.085	1.085	339165						1.375	--	0	
FD12TE01 (D/S)	15	5.089	3.864	1.375	1.235	1.085	1.085	339165						1.375	--	0	
FD12SP10 US	65	3.393	2.576	1.375	1.281	1.085	1.085	667878						1.375	--	0	
FD12SP10 DS	65	3.393	2.576	1.375	1.285	1.085	1.085	-----	680915	71.8	68.0	71.8	68.0	1.307	US	171740	171740
FD12EL08	2	6.277	4.765	1.375	1.313	1.085	1.085	-----	418635	132.9	100.0	132.9	100.0	1.353	MT	171740	171740
FD12EL09	4	6.277	4.765	1.375	1.521	1.085	1.085	-----	800993	132.9	240.0	132.9	240.0	1.561	US	171740	171740
INLET E-1-1A	30	6.786	5.152	1.375	1.188	1.085	1.085	174808						1.375	--	0	

==>Grouped by Line: 013-18*-FDW-13, No Sorting.

OUTLET E-2-1B	31	8.482	6.440	1.375	1.141	1.085	1.085	76194						1.375	--	0	
FD13EL01	4	6.277	4.765	1.375	1.202	1.085	1.085	214787						1.375	--	0	
FD13SP01 US	54	5.429	4.121	1.375	1.225	1.085	1.085	298076						1.375	--	0	
FD13SP01 DS	54	5.429	4.121	1.375	1.225	1.085	1.085	298076						1.375	--	0	
FD13EL02	2	6.277	4.765	1.375	1.202	1.085	1.085	214787						1.375	--	0	
FD13SP02 US	52	4.241	3.220	1.375	1.258	1.085	1.085	470651						1.375	--	0	
FD13SP02 DS	52	4.241	3.220	1.375	1.258	1.085	1.085	470651						1.375	--	0	
FD13EL03	2	6.277	4.765	1.375	1.202	1.085	1.085	214787						1.375	--	0	
FD13SP03	52	4.241	3.220	1.375	1.258	1.085	1.085	470651						1.375	--	0	
FD13SP04	9	2.196	1.667	1.375	1.314	1.085	1.085	1205306						1.375	--	0	
FD13EL04	2	6.277	4.765	1.375	1.202	1.085	1.085	214787						1.375	--	0	
FD13SP05 US	52	4.241	3.220	1.375	1.258	1.085	1.085	470651						1.375	--	0	
FD13SP05 DS	52	4.241	3.220	1.375	1.258	1.085	1.085	470651						1.375	--	0	
FD13EL05	2	6.277	4.765	1.375	1.309	1.085	1.085	-----	410823	123.6	150.0	123.6	150.0	1.358	US	160352	160352
FD13SP06	52	4.241	3.220	1.375	1.265	1.085	1.085	-----	488448	83.5	88.0	83.5	88.0	1.298	GW	160352	160352
FD13SP07	9	2.196	1.667	1.375	1.314	1.085	1.085	1205306						1.375	--	0	
FD13EL06	1	5.598	4.250	1.375	1.221	1.085	1.085	279399						1.375	--	0	
FD13EL07	4	6.277	4.765	1.375	1.202	1.085	1.085	214787						1.375	--	0	
FD13TE01 (U/S)	15	5.089	3.864	1.375	1.235	1.085	1.085	339165						1.375	--	0	
FD13TE01 (D/S)	15	5.089	3.864	1.375	1.235	1.085	1.085	339165						1.375	--	0	
FD13SP08 US	65	3.393	2.576	1.375	1.281	1.085	1.085	667878						1.375	--	0	
FD13SP08 DS	65	3.393	2.576	1.375	1.281	1.085	1.085	667878						1.375	--	0	
FD13EL08	2	6.277	4.765	1.375	1.202	1.085	1.085	214787						1.375	--	0	

67


FD13ELO9	4	6.277	4.765	1.375	1.202	1.085	1.085	214787	-----	---	---	---	---	1.375	--	0	-----
INLET E-1-1B	30	6.786	5.152	1.375	1.188	1.085	1.085	174808	-----	---	---	---	---	1.375	--	0	-----

Notes:

- [1] Predictions are based on last Tmeas to analysis ending period.
- [2] Predictions are for the time of last inspection (last known meas. wear).
- [3] CW = Tmeas is minimum thickness from Band, Blanket or Area Method of greatest wear.
 MT = Tmeas is component minimum thickness.
 PW = Tmeas is Tinit - predicted wear.
 US = Tmeas is user specified.
- [4] If no Tmeas has been determined from measured data, then Tmeas = Tinit and Time = current component installation time.
 Tmeas is used to determine Predicted Thickness and Component Predicted Time to Tcrit.


SP

Tpred/Tcrit Ratio Plot



Cumulative % of Comp. Time to Tcrit

FDW2006 E2s to E1s



78



% of Fittings



% of Fittings Added



Company: Vermont Yankee Nuclear Power Corporation Report Date: 13-SEP-2006 Time: 19:31:48
 Plant: Vermont Yankee Analysis Date: 13-SEP-2006 Time: 19:29:27
 Unit: CHECWORKS FAC Version 1.0F (Build 52)
 DB Name: VY

 *** Wear Rate Analysis: Combined Rankings for Inspection ***

Run Name: FDW2006 E2s to Els
 Ending Period: CYCLE 25
 Total Plant Operating Hours: 241618 Duty Factor (Global): 1.000
 WRA Data Option: Ignore NFA Exclude Measure Wear: No
 Line Correction Factor: 0.448

Component Name	Geometry Code	Average Wear Rate (mils/year)	Component Predicted Time to Tcrit (hrs)	
			Non-Inspected	Inspected
FD13EL06	1	5.598	279399	-----
FD12EL05	2	6.277	214787	-----
FD12SP01 US	54	5.429	298076	-----
OUTLET E-2-1B	31	8.482	76194	-----
OUTLET E-2-1A	31	8.482	76194	-----
INLET E-1-1B	30	6.786	174808	-----
INLET E-1-1A	30	6.786	174808	-----
FD12EL06	2	6.277	-----	528901
FD12EL04	2	6.277	214787	-----
FD14EL02	2	6.277	214787	-----
FD12EL03	2	6.277	214787	-----
FD12EL02	2	6.277	214787	-----
FD13EL03	2	6.277	214787	-----
FD13EL09	4	6.277	214787	-----
FD13EL04	2	6.277	214787	-----
FD13EL07	4	6.277	214787	-----
FD13EL01	4	6.277	214787	-----
FD12EL07	2	6.277	214787	-----
FD12EL01	4	6.277	214787	-----
FD12EL09	4	6.277	-----	800993
FD13EL08	2	6.277	214787	-----
FD13EL05	2	6.277	-----	410823
FD13SP01 US	54	5.429	298076	-----
FD12EL08	2	6.277	-----	418635
FD12SP01 DS	54	5.429	298076	-----
FD13SP01 DS	54	5.429	298076	-----
FD12TE01 (U/S)	15	5.089	339165	-----
FD13TE01 (D/S)	15	5.089	339165	-----
FD12TE01 (D/S)	15	5.089	339165	-----
FD13TE01 (U/S)	15	5.089	339165	-----
FD12SP05 US	52	4.241	470651	-----
FD12SP03	52	4.241	470651	-----
FD13SP03	52	4.241	470651	-----
FD12SP06	52	4.241	470651	-----
FD13SP02 US	52	4.241	470651	-----
FD13SP08	52	4.241	-----	513511
FD13SP05 US	52	4.241	470651	-----
FD12SP02	53	4.241	470651	-----
FD13SP06	52	4.241	-----	488448
FD12SP09	52	4.241	470651	-----
FD12SP05 DS	52	4.241	470651	-----
FD13SP02 DS	52	4.241	470651	-----
FD13SP05 DS	52	4.241	470651	-----
FD12SP10 US	65	3.393	667878	-----
FD13SP08 DS	65	3.393	667878	-----
FD13SP08 US	65	3.393	667878	-----
FD12SP10 DS	65	3.393	-----	680915
FD12SP07	9	2.196	-----	1139023
FD13SP07	9	2.196	1205306	-----
FD12SP04	9	2.196	1205306	-----
FD13SP04	9	2.196	1205306	-----

83

Company: Vermont Yankee Nuclear Power Corporation Report Date: 13-SEP-2006 Time: 19:31:57
 Plant: Vermont Yankee Analysis Date: 13-SEP-2006 Time: 19:29:27
 Unit: CHECWORKS FAC Version 1.0F (Build 52)
 EB Name: VY

 *** Wear Rate Analysis: Wear Predictions Report ***

Run Name: FDW2006 E2s to E1s
 Ending Period: CYCLE 25
 Total Plant Operating Hours: 241618 Duty Factor (Global): 1.000
 WRA Data Option: Ignore NFA Exclude Measure Wear: No
 Line Correction Factor: 0.448

Component Name	Total Lifetime Wear (mils)		In-Service Cmp. Wear (mils)		In-Service Cmp. Tmeas, Method, Time		In-Service Cmp. Thickness (mils) [4]		Incremental Wear (mils) [5] PRWEAR	Time (hrs) Last Inspected	
	Prd. [1]	Meas.	Prd. [1]	Meas.	(in) [3]	[2] (hrs) [3]	Tp	Tm			
==>Grouped by Line: 007-18*-FDW-12, No Sorting.											
FD12SP07	58.4	71.0	58.4	71.0	1.304	US	230118	1316.6	1304.0	2.2	230118
FD12EL06	166.9	132.0	166.9	132.0	1.379	US	230118	1208.1	1379.0	6.3	230118
FD12SP08	112.8	97.0	112.8	97.0	1.278	US	230118	1262.2	1278.0	4.2	230118
FD12SPI0 DS	71.8	68.0	71.8	68.0	1.307	US	171740	1303.2	1307.0	21.8	171740
FD12EL08	132.9	100.0	132.9	100.0	1.353	MT	171740	1242.1	1353.0	40.2	171740
FD12EL09	132.9	240.0	132.9	240.0	1.561	US	171740	1242.1	1561.0	40.2	171740

==>Grouped by Line: 013-18*-FDW-13, No Sorting.

FD13EL05	123.6	150.0	123.6	150.0	1.358	US	160352	1251.4	1358.0	49.5	160352
FD13SP06	83.5	88.0	83.5	88.0	1.298	GW	160352	1291.5	1298.0	33.4	160352

Notes:

- [1] Predictions are for the time of last inspection (last known meas. wear).
- [2] GW = Tmeas is minimum thickness from Band, Blanket or Area Method of greatest wear.
 MT = Tmeas is component minimum thickness.
 FW = Tmeas is Tinit - predicted wear.
 US = Tmeas is user specified.
- [3] If no Tmeas has been determined from measured data, then Tmeas = Tinit and Time = current component installation time.
 Tmeas is used to determine Predicted Thickness and Component Predicted Time to Tcrit.
- [4] These two values are used for thickness plot.
 Tp = Predicted thickness at Tmeas.
 Tm = Last measured thickness (Tmeas).
- [5] PRWEAR = Incremental wear from last Tmeas time to analysis ending period.

h2

Company: Vermont Yankee Nuclear Power Corporation Report Date: 13-SEP-2006 Time: 19:31:43
 Plant: Vermont Yankee Analysis Date: 13-SEP-2006 Time: 19:29:27
 Unit: CHECWORKS FAC Version 1.0F (Build 52)
 DB Name: VY

 *** Wear Rate Analysis: Thickness/Service Time Report ***

Run Name: FDW2006 E2s to E1s
 Ending Period: CYCLE 25
 Total Plant Operating Hours: 241618 Duty Factor (Global): 1.000
 WRA Data Option: Ignore NFA Exclude Measure Wear: No
 Line Correction Factor: 0.448

Component Name	Thickness (in)				Component Predicted[1] Time to Tcrit (hrs)		Component Actual Service Time (hrs)
	Init.	Prd.[1]	Thoop	Tcrit	Non-Inspected	Inspected	
===Grouped by Line: 007-18*-FDW-12, No Sorting.							
OUTLET E-2-1A	1.375	1.141	1.085	1.085	76194	-----	241618
FD12EL01	1.375	1.202	1.085	1.085	214787	-----	241618
FD12SP01 US	1.375	1.225	1.085	1.085	298076	-----	241618
FD12SP01 DS	1.375	1.225	1.085	1.085	298076	-----	241618
FD12EL02	1.375	1.202	1.085	1.085	214787	-----	241618
FD12SP02	1.375	1.258	1.085	1.085	470651	-----	241618
FD12EL03	1.375	1.202	1.085	1.085	214787	-----	241618
FD12SP03	1.375	1.258	1.085	1.085	470651	-----	241618
FD12SP04	1.375	1.314	1.085	1.085	1205306	-----	241618
FD12EL04	1.375	1.202	1.085	1.085	214787	-----	241618
FD12SP05 US	1.375	1.258	1.085	1.085	470651	-----	241618
FD12SP05 DS	1.375	1.258	1.085	1.085	470651	-----	241618
FD12EL05	1.375	1.202	1.085	1.085	214787	-----	241618
FD12SP06	1.375	1.258	1.085	1.085	470651	-----	241618
FD12SP07	1.375	1.302	1.085	1.085	-----	1139023	241618
FD12EL06	1.375	1.373	1.085	1.085	-----	528990	241618
FD12SP08	1.375	1.274	1.085	1.085	-----	513511	241618
FD12EL07	1.375	1.202	1.085	1.085	214787	-----	241618
FD12SP09	1.375	1.258	1.085	1.085	470651	-----	241618
FD12TE01 (U/S)	1.375	1.235	1.085	1.085	339165	-----	241618
FD12TE01 (D/S)	1.375	1.235	1.085	1.085	339165	-----	241618
FD12SP10 US	1.375	1.281	1.085	1.085	667878	-----	241618
FD12SP10 DS	1.375	1.285	1.085	1.085	-----	680915	241618
FD12EL08	1.375	1.313	1.085	1.085	-----	418635	241618
FD12EL09	1.375	1.521	1.085	1.085	-----	800993	241618
INLET E-1-1A	1.375	1.188	1.085	1.085	174808	-----	241618

===Grouped by Line: 013-18*-FDW-13, No Sorting.


OUTLET E-2-1B	1.375	1.141	1.085	1.085	76194	-----	241618
FD13EL01	1.375	1.202	1.085	1.085	214787	-----	241618
FD13SP01 US	1.375	1.225	1.085	1.085	298076	-----	241618
FD13SP01 DS	1.375	1.225	1.085	1.085	298076	-----	241618
FD13EL02	1.375	1.202	1.085	1.085	214787	-----	241618
FD13SP02 US	1.375	1.258	1.085	1.085	470651	-----	241618
FD13SP02 DS	1.375	1.258	1.085	1.085	470651	-----	241618
FD13EL03	1.375	1.202	1.085	1.085	214787	-----	241618
FD13SP03	1.375	1.258	1.085	1.085	470651	-----	241618
FD13SP04	1.375	1.314	1.085	1.085	1205306	-----	241618
FD13EL04	1.375	1.202	1.085	1.085	214787	-----	241618
FD13SP05 US	1.375	1.258	1.085	1.085	470651	-----	241618
FD13SP05 DS	1.375	1.258	1.085	1.085	470651	-----	241618
FD13EL05	1.375	1.309	1.085	1.085	-----	410823	241618
FD13SP06	1.375	1.265	1.085	1.085	-----	488448	241618
FD13SP07	1.375	1.314	1.085	1.085	1205306	-----	241618
FD13EL06	1.375	1.221	1.085	1.085	279399	-----	241618
FD13EL07	1.375	1.202	1.085	1.085	214787	-----	241618
FD13TE01 (U/S)	1.375	1.235	1.085	1.085	339165	-----	241618
FD13TE01 (D/S)	1.375	1.235	1.085	1.085	339165	-----	241618
FD13SP08 US	1.375	1.281	1.085	1.085	667878	-----	241618
FD13SP08 DS	1.375	1.281	1.085	1.085	667878	-----	241618
FD13EL08	1.375	1.202	1.085	1.085	214787	-----	241618

25

FD13EL09	1.375	1.202	1.085	1.085	214787	-----	241618
INLET E-1-1B	1.375	1.188	1.085	1.085	174808	-----	241618

Note:
[1] Predictions are based on last Tmeas to analysis ending period.

86



Company: Vermont Yankee Nuclear Power Corporation Report Date: 13-SEP-2006 Time: 19:31:39
 Plant: Vermont Yankee Analysis Date: 13-SEP-2006 Time: 19:29:27
 Unit: CHECWORKS FAC Version 1.0F (Build 52)
 DB Name: VY

 *** Wear Rate Analysis: Inspection History Report ***

Run Name: FDW3006 E2s to E1s
 Ending Period: CYCLE 25
 Total Plant Operating Hours: 241618 Duty Factor (Global): 1.000
 WRA Data Option: Ignore NFA Exclude Measure Wear: No
 Line Correction Factor: 0.448

Component Name	Geom. Code	No.	Material				Sigma (psi)	Time (hrs)		Analysis Option	Measured Wear (mils)
			Cr. (%)	Cu. (%)	Mo. (%)	Last Inspected		Replaced			

====>Grouped by Line: 007-18*-FDW-12, No Sorting.

OUTLET E-2-1A	31	5	0.00	0.00	0.00	15000	-----	-----	---
FD12EL01	4	21	0.00	0.00	0.00	15000	-----	-----	---
FD12SP01 US	54	5	0.00	0.00	0.00	15000	-----	-----	---
FD12SP01 DS	54	5	0.00	0.00	0.00	15000	-----	-----	---
FD12EL02	2	21	0.00	0.00	0.00	15000	-----	-----	---
FD12SP02	52	5	0.00	0.00	0.00	15000	-----	-----	---
FD12EL03	2	21	0.00	0.00	0.00	15000	-----	-----	---
FD12SP03	52	5	0.00	0.00	0.00	15000	-----	-----	---
FD12SP04	9	5	0.00	0.00	0.00	15000	-----	-----	---
FD12EL04	2	21	0.00	0.00	0.00	15000	-----	-----	---
FD12SP05 US	52	5	0.00	0.00	0.00	15000	-----	-----	---
FD12SP05 DS	52	5	0.00	0.00	0.00	15000	-----	-----	---
FD12EL05	2	21	0.00	0.00	0.00	15000	-----	-----	---
FD12SP06	52	5	0.00	0.00	0.00	15000	-----	-----	---
FD12SP07	9	5	0.00	0.00	0.00	15000	230118	-----	71
FD12EL06	2	21	0.00	0.00	0.00	15000	230118	-----	132
FD12SP08	52	5	0.00	0.00	0.00	15000	230118	-----	97
FD12EL07	2	21	0.00	0.00	0.00	15000	-----	-----	---
FD12SP09	52	5	0.00	0.00	0.00	15000	-----	-----	---
FD12TE01 (U/S)	15	21	0.00	0.00	0.00	15000	-----	-----	---
FD12TE01 (D/S)	15	21	0.00	0.00	0.00	15000	-----	-----	---
FD12SP10 US	65	5	0.00	0.00	0.00	15000	-----	-----	---
FD12SP10 DS	65	5	0.00	0.00	0.00	15000	171740	-----	68
FD12EL08	2	21	0.00	0.00	0.00	15000	171740	-----	100
FD12EL09	4	21	0.00	0.00	0.00	15000	171740	-----	240
INLET E-1-1A	30	5	0.00	0.00	0.00	15000	-----	-----	---

====>Grouped by Line: 013-18*-FDW-13, No Sorting.

OUTLET E-2-1B	31	5	0.00	0.00	0.00	15000	-----	-----	---
FD13EL01	4	21	0.00	0.00	0.00	15000	-----	-----	---
FD13SP01 US	54	5	0.00	0.00	0.00	15000	-----	-----	---
FD13SP01 DS	54	5	0.00	0.00	0.00	15000	-----	-----	---
FD13EL02	2	21	0.00	0.00	0.00	15000	-----	-----	---
FD13SP02 US	52	5	0.00	0.00	0.00	15000	-----	-----	---
FD13SP02 DS	52	5	0.00	0.00	0.00	15000	-----	-----	---
FD13EL03	2	21	0.00	0.00	0.00	15000	-----	-----	---
FD13SP03	52	5	0.00	0.00	0.00	15000	-----	-----	---
FD13SP04	9	5	0.00	0.00	0.00	15000	-----	-----	---
FD13EL04	2	21	0.00	0.00	0.00	15000	-----	-----	---
FD13SP05 US	52	5	0.00	0.00	0.00	15000	-----	-----	---
FD13SP05 DS	52	5	0.00	0.00	0.00	15000	-----	-----	---
FD13EL05	2	21	0.00	0.00	0.00	15000	160352	-----	150
FD13SP06	52	5	0.00	0.00	0.00	15000	160352	-----	88
FD13SP07	9	5	0.00	0.00	0.00	15000	-----	-----	---
FD13EL06	1	21	0.00	0.00	0.00	15000	-----	-----	---
FD13EL07	4	21	0.00	0.00	0.00	15000	-----	-----	---
FD13TE01 (U/S)	15	21	0.00	0.00	0.00	15000	-----	-----	---
FD13TE01 (D/S)	15	21	0.00	0.00	0.00	15000	-----	-----	---
FD13SP08 US	65	5	0.00	0.00	0.00	15000	-----	-----	---
FD13SP08 DS	65	5	0.00	0.00	0.00	15000	-----	-----	---
FD13EL08	2	21	0.00	0.00	0.00	15000	-----	-----	---

27

FD138L09
INLET E-1-1B

4	21	0.00	0.00	0.00	15000	----	----	---
30	5	0.00	0.00	0.00	15000	----	----	---

8



Company: Vermont Yankee Nuclear Power Corporation Report Date: 13-SEP-2006 Time: 19:31:34
 Plant: Vermont Yankee Analysis Date: 13-SEP-2006 Time: 19:29:27
 Unit: CHECWORKS FAC Version 1.0F (Build 52)
 DB Name: VY

 *** Wear Rate Analysis: Wear Rates/Input Data Report ***

Run Name: FDW2006 E3s to E1s
 Ending Period: CYCLE 25
 Total Plant Operating Hours: 241618 Duty Factor (Global): 1.000
 WRA Data Option: Ignore NFA Exclude Measure Wear: No
 Line Correction Factor: 0.448

Component Name	Geom. Code	Average Wear Rate (mils/year)	Current Wear Rate (mils/year)	Temp. (F)	Velocity (ft/s)	Steam Quality	Diameter (in)
----------------	------------	-------------------------------	-------------------------------	-----------	-----------------	---------------	---------------

===>Grouped by Line: 007-18*-FDW-12, No Sorting.

OUTLET E-2-1A	31	8.482	6.440	327.7	12.446	0.000	18.000
FD12EL01	4	6.277	4.765	327.7	12.446	0.000	18.000
FD12SP01 US	54	5.429	4.121	327.7	12.446	0.000	18.000
FD12SP01 DS	54	5.429	4.121	327.7	12.446	0.000	18.000
FD12EL02	2	6.277	4.765	327.7	12.446	0.000	18.000
FD12SP02	52	4.241	3.220	327.7	12.446	0.000	18.000
FD12EL03	2	6.277	4.765	327.7	12.446	0.000	18.000
FD12SP03	52	4.241	3.220	327.7	12.446	0.000	18.000
FD12SP04	9	2.196	1.667	327.7	12.446	0.000	18.000
FD12EL04	2	6.277	4.765	327.7	12.446	0.000	18.000
FD12SP05 US	52	4.241	3.220	327.7	12.446	0.000	18.000
FD12SP05 DS	52	4.241	3.220	327.7	12.446	0.000	18.000
FD12EL05	2	6.277	4.765	327.7	12.446	0.000	18.000
FD12SP06	52	4.241	3.220	327.7	12.446	0.000	18.000
FD12SP07	9	2.196	1.667	327.7	12.446	0.000	18.000
FD12EL06	2	6.277	4.765	327.7	12.446	0.000	18.000
FD12SP08	52	4.241	3.220	327.7	12.446	0.000	18.000
FD12EL07	2	6.277	4.765	327.7	12.446	0.000	18.000
FD12SP09	52	4.241	3.220	327.7	12.446	0.000	18.000
FD12TE01 (U/S)	15	5.089	3.864	327.7	12.446	0.000	18.000
FD12TE01 (D/S)	15	5.089	3.864	327.7	12.446	0.000	18.000
FD12SP10 US	65	3.393	2.576	327.7	12.446	0.000	18.000
FD12SP10 DS	65	3.393	2.576	327.7	12.446	0.000	18.000
FD12EL08	2	6.277	4.765	327.7	12.446	0.000	18.000
FD12EL09	4	6.277	4.765	327.7	12.446	0.000	18.000
INLET E-1-1A	30	6.786	5.152	327.7	12.446	0.000	18.000

===>Grouped by Line: 013-18*-FDW-13, No Sorting.

OUTLET E-2-1B	31	8.482	6.440	327.7	12.446	0.000	18.000
FD13EL01	4	6.277	4.765	327.7	12.446	0.000	18.000
FD13SP01 US	54	5.429	4.121	327.7	12.446	0.000	18.000
FD13SP01 DS	54	5.429	4.121	327.7	12.446	0.000	18.000
FD13EL02	2	6.277	4.765	327.7	12.446	0.000	18.000
FD13SP02 US	52	4.241	3.220	327.7	12.446	0.000	18.000
FD13SP02 DS	52	4.241	3.220	327.7	12.446	0.000	18.000
FD13EL04	2	6.277	4.765	327.7	12.446	0.000	18.000
FD13SP03	52	4.241	3.220	327.7	12.446	0.000	18.000
FD13SP04	9	2.196	1.667	327.7	12.446	0.000	18.000
FD13EL04	2	6.277	4.765	327.7	12.446	0.000	18.000
FD13SP05 US	52	4.241	3.220	327.7	12.446	0.000	18.000
FD13SP05 DS	52	4.241	3.220	327.7	12.446	0.000	18.000
FD13EL05	2	6.277	4.765	327.7	12.446	0.000	18.000
FD13SP06	52	4.241	3.220	327.7	12.446	0.000	18.000
FD13SP07	9	2.196	1.667	327.7	12.446	0.000	18.000
FD13EL06	1	5.598	4.250	327.7	12.446	0.000	18.000
FD13EL07	4	6.277	4.765	327.7	12.446	0.000	18.000
FD13TE01 (U/S)	15	5.089	3.864	327.7	12.446	0.000	18.000
FD13TE01 (D/S)	15	5.089	3.864	327.7	12.446	0.000	18.000
FD13SP08 US	65	3.393	2.576	327.7	12.446	0.000	18.000
FD13SP08 DS	65	3.393	2.576	327.7	12.446	0.000	18.000
FD13EL08	2	6.277	4.765	327.7	12.446	0.000	18.000

89

FD13EL09
INLET E-1-1B

4	6.277	4.765	327.7	12.446	0.000	18.000
30	6.786	5.152	327.7	12.446	0.000	18.000

910



Wear Rate Analysis Run Definition

Run Name: **FDW 2006 E1s to Rx**

Run Title: **Feedwater E1A & E1B to Reactor**

Ending Period: **CYCLE 25**

Total Oper. Hrs.: **241618.44**

Duty Factor: **1.000**

Analysis Options

- Ignore IFA Results
- IFA Results 1st Priority
- User Input 1st Priority
- Do Not Use Measured Wear

Run Definitions

- 3rd Pt High Level
- 4th Pt Extract Steam
- 4th Pt Heater Drain
- 4th Pt High Level
- 5th Pt Extract Steam
- 5th Pt Heater Drains
- Cond LP Htr Bypass
- Cond Minimum Flow
- Condensate
- FDW 2006 E1s to Rx**
- FDW 2006 Hdr to E2s
- FDW06 2 P1s to Hdr.
- FDW06 3-P1e to Hdr
- FDW2006 E2s to E1s
- Feed Pump Recirc
- Feedwater
- Feedwater Flush
- Feedwater Low Flow
- Heater Drain Pumps

Database Lines	Add	Lines to Analyze
001-16"-FDW-01	>	008-18"-FDW-13
002-16"-FDW-02	>	008-15"-FDW-14
003-16"-FDW-03	>>	009-16"-FDW-14
004-24"-FDW-01	>>	009-15"-FDW-16
005-18"-FDW-07	>>	010-16"-FDW-19
006-18"-FDW-07	>>	010-10"-FDW-19
007-18"-FDW-12	>>	010-10"-FDW-21
011-18"-FDW-08	>>	014-18"-FDW-15

Buttons: < Prev, Next >, Add, Remove, Report, Save, Copy, Delete, Print..., Help, Done, Advanced Run Def...

List of Defined Wear Rate Runs

10





Wear Rate Analysis Run Definition

Run Name: FDW 2006 E1e to Rx
Run Title: Feedwater E1A & E1B to Reactor

Ending Period: CYCLE 25
Total Oper. Hrs.: 241618.44
Duty Factor: 1.000

Analysis Options:
 Ignore IIFA Results
 IIFA Results 1st Priority
 User Input 1st Priority
 Do Not Use Measured Wear

Database Lines	Add	Lines to Analyze
001-16"-FDW-01	>	010-10"-FDW-21
002-16"-FDW-02	>>	014-18"-FDW-15
003-16"-FDW-03	>>	014-16"-FDW-15
004-24"-FDW-01	>>	015-16"-FDW-15
005-18"-FDW-07	>>	016-10"-FDW-18
006-18"-FDW-07	>>	015-16"-FDW-17
007-18"-FDW-12	>>	016-16"-FDW-18
011-18"-FDW-08	>>	016-10"-FDW-20

Run Definitions:
 3rd Pt High Level
 4th Pt Extract Steam
 4th Pt Heater Drain
 4th Pt High Level
 5th Pt Extract Steam
 5th Pt Heater Drains
 Cond LP Htr Bypass
 Cond Minimum Flow
 Condensate
FDW 2006 E1e to Rx
 FDW 2006 Hdr to E2s
 FDW06 2 P1s to Hdr.
 FDW06 3-P1s to Hdr
 FDW2006 E2s to E1s
 Feed Pump Recirc
 Feedwater
 Feedwater Flush
 Feedwater Low Flow
 Heater Drain Pumps


Buttons: < Prev, Next >, Add, Reset, Save, Copy, Delete, Print..., Help, Done, Advanced Run Def...

List of Defined Wear Rate Runs


026



Comparison of Thickness Predictions



Comparison of Wear Predictions



 *** Wear Rate Analysis: Wear Predictions Report ***

Run Name: FDW 1006 Els to Rx
 Ending Period: CYCLE 25
 Total Plant Operating Hours: 241618 Duty Factor (Global): 1.000
 WRA Data Option: Ignore WFA Exclude Measure Wear: No
 Line Correction Factor: 0.257

Component Name	Total Lifetime In-Service Cmp.		In-Service Cmp.		In-Service Cmp.		Incremental		Time(hrs) Last Inspected		
	Wear (mils) Prd.[1] Meas.	Wear (mils) Prd.[1] Meas.	Tmeas, Method, Time (in) [3] ; [2] (hrs) [3]	Thickness (mils) [4] Tp Tm	Wear (mils) [5] PRWEAR						
===>Grouped by Line: 008-18*-FDW-14, No Sorting.											
FD14RD01(L/E)	41.3	139.0	41.3	139.0	1.236	MT	114614	1333.7	1236.0	35.5	114614
FD14RD01(S/E)	43.8	66.0	43.8	66.0	1.213	MT	114614	1175.2	1213.0	37.6	114614
===>Grouped by Line: 008-16*-FDW-14, No Sorting.											
FD14SP02	34.2	55.0	34.2	55.0	1.224	US	114614	1184.8	1224.0	29.4	114614
FD14EL03	75.8	9.0	75.8	9.0	1.176	US	230118	1143.2	1176.0	3.4	183618
FD14SP03 US	61.3	19.0	61.3	19.0	1.205	US	230118	1157.7	1205.0	2.3	230118
FD14EL05	83.9	85.0	83.9	85.0	1.134	MT	207118	1135.1	1134.0	10.2	207118
===>Grouped by Line: 009-16*-FDW-14, No Sorting.											
FD14SP08 DS	59.0	65.0	59.0	65.0	1.153	US	218618	1160.0	1153.0	4.6	218618
FD14EL07	87.3	79.0	87.3	79.0	1.261	US	218618	1131.7	1261.0	6.8	218618
===>Grouped by Line: 009-16*-FDW-16, No Sorting.											
===>Grouped by Line: 010-16*-FDW-19, No Sorting.											
FD19SP03 DS	48.5	21.0	48.5	21.0	0.789	MT	218618	795.5	789.0	3.8	218618
FD19TE01(D/S)	61.2	19.0	61.2	19.0	1.950	MT	137270	1157.8	1950.0	33.8	137270
FD19TE01(BR.)	64.6	27.0	64.6	27.0	0.769	MT	218618	779.4	769.0	7.3	137270
FD19RD01(L/E)	56.1	47.0	56.1	47.0	1.151	MT	218618	1162.9	1151.0	4.4	218618
FD19RD01(S/E)	85.1	48.0	85.1	48.0	0.781	MT	218618	758.9	781.0	6.6	218618
===>Grouped by Line: 010-10*-FDW-19, No Sorting.											
FD19SP04	66.5	19.0	66.5	19.0	0.778	US	218618	777.5	778.0	5.2	218618
===>Grouped by Line: 010-10*-FDW-21, No Sorting.											
FD21SP01 US	53.2	24.0	53.2	24.0	0.796	MT	218618	790.8	796.0	4.1	218618
===>Grouped by Line: 014-18*-FDW-15, No Sorting.											
===>Grouped by Line: 014-16*-FDW-15, No Sorting.											
FD15EL04	72.3	91.0	72.3	91.0	1.175	MT	171740	1146.7	1175.0	21.9	171740
FD15SP10	62.5	45.0	62.5	45.0	1.210	GW	171740	1156.5	1210.0	18.9	171740
FD15EL05	72.3	178.0	72.3	178.0	1.089	MT	171740	1146.7	1089.0	21.9	171740
FD15SP03	62.5	108.0	62.5	108.0	1.190	GW	171740	1156.5	1190.0	18.9	171740
===>Grouped by Line: 015-16*-FDW-15, No Sorting.											
FD15SP08 US	48.8	46.0	48.8	46.0	1.172	GW	171740	1170.2	1172.0	14.8	171740
===>Grouped by Line: 016-10*-FDW-18, No Sorting.											
FD18SP04 US	48.3	155.0	48.3	155.0	0.758	MT	195618	795.7	758.0	9.0	195618
===>Grouped by Line: 015-16*-FDW-17, No Sorting.											
===>Grouped by Line: 016-16*-FDW-18, No Sorting.											
FD18SP01 DS	46.6	73.0	46.6	73.0	0.803	GW	207118	797.4	803.0	5.7	207118
FD18EL01	83.9	140.0	83.9	140.0	1.223	US	207118	1135.1	1223.0	10.2	207118
FD18SP02 US	53.0	53.0	53.0	53.0	0.799	US	207118	791.0	799.0	6.4	207118
FD18TE01(U/S)	117.9	82.0	117.9	82.0	1.560	US	195618	1101.1	1560.0	23.0	195618
FD18TE01(D/S)	80.0	181.0	80.0	181.0	1.644	US	195618	1139.0	1644.0	15.0	195618
===>Grouped by Line: 016-10*-FDW-20, No Sorting.											
FD20SP01	60.4	123.0	60.4	123.0	0.727	MT	195618	783.6	727.0	11.3	195618

Notes:

- Predictions are for the time of last inspection (last known meas. wear).
- GW = Tmeas is minimum thickness from Band, Blanket or Area Method of greatest wear.
 MT = Tmeas is component minimum thickness.
 PW = Tmeas is Tinit - predicted wear.
 US = Tmeas is wear specified.
- If no Tmeas has been determined from measured data, then Tmeas = Tinit and Time = current component installation time.
 Tmeas is used to determine Predicted Thickness and Component Predicted Time to Texit.
- These two values are used for thickness plot.
 Tp = Predicted thickness at Tmeas.
 Tm = Last measured thickness (Tmeas).
- PRWEAR = incremental wear from last Tmeas time to analysis ending period.

*** Wear Rate Analysis: Combined Rankings for Inspection ***

Run Name: FDW 2006 EIs to Rx
 Ending Period: CYCLE 25
 Total Plant Operating Hours: 241618 Duty Factor (Global): 1.000
 WRA Data Option: Ignore NFA Exclude Measure Wear: No
 Line Correction Factor: 0.257

Component Name	Geometry Code	Average Wear Rate (mils/year)	Component Predicted Time to Tcrit (hrs)	
			Non-Inspected	Inspected
FD20EL02	1	3.431	1062259	-----
FD20EL01	2	3.847	913014	-----
FD14FE01	6	0.633	88712408	-----
FD19RD01 (S/E)	7	3.327	-----	1182188
FD15SP03	54	2.952	-----	807624
FD19TE01 (D/S)	14	5.074	2849744	-----
FD18TE01 (U/S)	14	5.074	-----	2030518
FD15EL05	4	3.413	-----	347038
FD15RD01 (L/E)	7	2.786	473292	-----
OUTLET E-1-1A	31	3.979	522532	-----
FD14RD01 (L/E)	7	2.786	-----	478243
OUTLET E-1-1B	31	3.979	522532	-----
FD19EL03	2	3.847	913014	-----
FD19EL05	2	3.847	913014	-----
FD14EL05	2	3.413	-----	538641
FD20EL03	2	3.847	913014	-----
FD14EL04	2	3.413	542240	-----
FD18EL04	2	3.847	913014	-----
FD17EL01	4	3.413	542240	-----
FD21EL02	2	3.847	913014	-----
FD14EL06	2	3.413	542240	-----
FD15EL08	2	3.413	542240	-----
FD19TE01 (BR.)	14	3.639	-----	1040838
FD15EL06	2	3.413	542240	-----
FD18TE01 (BR.)	14	3.639	983372	-----
FD16EL01	4	3.413	542240	-----
FD19TE01 (D/S)	14	3.444	-----	4258696
FD16SP05	58	1.785	588604	-----
FD18TE01 (D/S)	14	3.444	-----	3296613
FD15EL04	4	3.413	-----	637778
FD18EL03	1	3.431	1062259	-----
FD15SP02	57	2.306	678744	-----
FD19EL04	1	3.431	1062259	-----
FD15SP09	51	2.029	702760	-----
FD21EL01	1	3.431	1062259	-----
FD14EL03	2	3.413	-----	703631
FD15EL03	1	3.044	716912	-----
FD15RD01 (S/E)	7	2.952	724912	-----
FD16TE01 (D/S)	15	2.767	743024	-----
FD19EL01	2	3.413	1621719	-----
FD16TE01 (U/S)	15	2.767	743024	-----
FD14TE02 (D/S)	15	2.767	743024	-----
FD15TE02 (U/S)	15	2.767	743024	-----
FD14EL07	2	3.413	-----	979491
FD15TE02 (D/S)	15	2.767	743024	-----
FD15EL07	2	3.413	810194	-----
FD17TE01 (D/S)	15	2.767	743024	-----
FD14TE02 (U/S)	15	2.767	743024	-----
FD17TE01 (U/S)	15	2.767	743024	-----
FD18EL01	2	3.413	-----	1919003
FD18SP02 DS	52	2.155	746318	-----
FD19SP02	52	2.155	746318	-----
FD18SP02 US	52	2.155	-----	789150
FD20RD01 (S/E)	7	3.327	1116948	-----
FD14EL02	2	2.945	817946	-----
FD14EL01	4	2.945	817946	-----
FD19EL02	1	3.044	1856868	-----
FD15EL02	2	2.945	817946	-----
FD15EL01	4	2.945	817946	-----
FD18EL03	1	3.044	1856868	-----
FD14RD01 (S/E)	7	2.952	-----	824378
FD15TE01 (U/S)	15	2.388	830885	-----
FD19SP03 DS	51	1.897	-----	852124
FD15SP10	54	2.952	-----	885803
FD19SP03 US	51	1.897	891487	-----
FD18SP03 US	51	1.897	891487	-----
FD18SP03 DS	51	1.897	891487	-----
FD18SP01 US	58	1.897	891487	-----
FD19SP01 US	58	1.897	891487	-----
FD19SP01 DS	58	1.897	891487	-----
FD14SP08 DS	52	2.306	-----	920314
FD18SP01 DS	58	1.897	-----	925801
FD14FE01A	52	2.306	955281	-----
FD21SP04 DS	52	2.599	1504026	-----
FD14SP04	52	2.306	955281	-----
FD19SP03 US	52	2.599	1504026	-----
FD15SP08 DS	52	2.306	955281	-----
FD19SP06 DS	52	2.599	1504026	-----
FD14SP03 DS	52	2.306	955281	-----
FD19SP06 US	52	2.599	1504026	-----
FD14SP08 US	52	2.306	955281	-----
FD21SP04 US	52	2.599	1504026	-----
FD15SP08 US	52	2.306	-----	964409
FD20SP01	57	2.599	-----	1352849
FD20SP06 DS	52	2.599	1504026	-----

FD20SP06 US	52	2.539	1504026	-----
FD15TE01 (D/S)	15	2.388	990359	-----
FD18SP07 DS	52	2.599	1504026	-----
FD19SP09 DS	52	2.599	1504026	-----
FD19SP09 US	52	2.599	1504026	-----
FD19SP04	57	2.599	-----	1506324
FD18SP07 US	52	2.599	1504026	-----
FD20SP03 DS	52	2.599	1504026	-----
FD17SP01 DS	58	2.029	1128945	-----
FD17SP03	58	2.029	1128945	-----
FD14TE01 (D/S)	15	2.388	1254199	-----
FD17SP01 US	58	2.029	1128945	-----
FD14TE01 (U/S)	15	2.388	1370181	-----
FD16SP04	58	2.029	1128945	-----
FD17SP04	58	2.029	1128945	-----
FD14SP03 US	52	2.306	-----	1191994
FD16SP01 DS	58	2.029	1128945	-----
FD16SP03	58	2.029	1128945	-----
FD14SP02	57	2.306	-----	1151436
FD16SP01 US	58	2.029	1128945	-----
FD14SP07 US	65	1.845	1157152	-----
FD18SP05	51	2.288	1752520	-----
FD16SP02	65	1.845	1273666	-----
FD21SP02	51	2.288	1752520	-----
FD15SP06	65	1.845	1273666	-----
FD20SP04	51	2.288	1752520	-----
FD14SP07 DS	65	1.845	1273666	-----
FD19SP07	51	2.288	1752520	-----
FD17SP02	65	1.845	1273666	-----
FD19RD01 (L/E)	7	2.191	-----	2640355
FD17SP05	58	1.785	1300083	-----
FD20RD01 (L/E)	7	2.191	2518487	-----
FD14SP06 DS	56	1.692	1319530	-----
FD15SP05 DS	56	1.692	1417698	-----
FD15SP05 US	56	1.692	1417698	-----
FD21SP01 US	64	2.080	-----	1988529
FD14FE01B	56	1.692	1417698	-----
FD21SP01 DS	64	2.080	1959598	-----
FD15FE01B	56	1.692	1417698	-----
FD18SP04 DS	64	2.080	1959598	-----
FD14SP06 US	56	1.692	1441875	-----
FD18SP04 US	64	2.080	-----	1750591
FD14SP01	58	1.751	1592633	-----
FD15SP01	58	1.751	1592633	-----
FD14SP05	9	1.293	1953036	-----
FD15SP04	9	1.293	1953036	-----
FD15FE01A	9	1.293	1953036	-----
FD15SP07	9	1.293	1953036	-----
FD19SP05	9	1.508	2822808	-----
FD19SP08	9	1.508	2822808	-----
FD18SP06	9	1.508	2822808	-----
FD21SP03	9	1.508	2822808	-----
FD20SP05	9	1.508	2822808	-----
FD20SP02	9	1.508	2822808	-----
FD14CP01	65	0.054	42529632	-----
FD15CP01	65	0.054	42529632	-----
FD15FE01	6	0.033	88712408	-----
RX NOZZLE 4C	30	0.008	99000000	-----
RX NOZZLE 4A	30	0.008	99000000	-----
RX NOZZLE 4B	30	0.008	99000000	-----
RX NOZZLE 4D	30	0.008	99000000	-----

 *** Wear Rate Analysis: Thickness/Service Time Report ***

Run Name: FDW 2006 Els to Rx
 Ending Period: CYCLE 25
 Total Plant Operating Hours: 241618
 WRA Data Option: Ignore NFA
 Line Correction Factor: 0.257
 Duty Factor (Global): 1.000
 Exclude Measure Wear: No

Component Name	Thickness (in)				Component Predicted[1] Time to Tcrit (hrs)		Component Actual Service Time (hrs)
	Init.	Prd.[1]	Thoop	Tcrit	Non-Inspected	Inspected	
===>Grouped by Line: 008-18*-FDW-14, No Sorting.							
OUTLET E-1-1A	1.375	1.265	1.085	1.085	522532	-----	241618
FD14EL01	1.375	1.294	1.085	1.085	817946	-----	241618
FD14SP01	1.375	1.327	1.085	1.085	1592633	-----	241618
FD14EL02	1.375	1.294	1.085	1.085	817946	-----	241618
FD14TE01(U/S)	1.375	1.369	1.085	1.085	1370181	-----	241618
FD14TE01(D/S)	1.375	1.345	1.085	1.085	1254199	-----	241618
FD14RD01(L/E)	1.375	1.200	1.085	1.085	-----	478243	241618
FD14RD01(S/E)	1.219	1.175	0.964	0.964	-----	824378	241618
===>Grouped by Line: 008-16*-FDW-14, No Sorting.							
FD14SP02	1.219	1.195	0.964	0.964	-----	1151436	241618
FD14EL03	1.219	1.173	0.964	0.964	-----	703631	241618
FD14SP03 US	1.219	1.203	0.964	0.964	-----	1191994	241618
FD14SP03 DS	1.219	1.155	0.964	0.964	955281	-----	241618
FD14EL04	1.219	1.125	0.964	0.964	542240	-----	241618
FD14SP04	1.219	1.155	0.964	0.964	955281	-----	241618
FD14SP05	1.219	1.183	0.964	0.964	1953036	-----	241618
FD14FE01A	1.219	1.155	0.964	0.964	955281	-----	241618
FD14FE01	1.219	1.218	0.964	0.964	88712408	-----	241618
FD14FE01B	1.219	1.172	0.964	0.964	1417698	-----	241618
FD14SP06 US	1.219	1.176	0.964	0.964	1441875	-----	241618
FD14SP06 DS	1.219	1.158	0.964	0.964	1319530	-----	241618
FD14EL05	1.219	1.124	0.964	0.964	-----	538641	241618
FD14TE02(U/S)	1.219	1.143	0.964	0.964	743024	-----	241618
FD14TE02(D/S)	1.219	1.143	0.964	0.964	743024	-----	241618
FD14CP01	0.719	0.718	0.520	0.520	42529632	-----	241618
FD14SP07 US	1.219	1.149	0.964	0.964	1157152	-----	241618
===>Grouped by Line: 009-16*-FDW-14, No Sorting.							
FD14SP07 DS	1.219	1.158	0.964	0.964	1273666	-----	241618
FD14EL06	1.219	1.125	0.964	0.964	542240	-----	241618
FD14SP08 US	1.219	1.155	0.964	0.964	955281	-----	241618
FD14SP08 DS	1.219	1.148	0.964	0.964	-----	920314	241618
FD14EL07	1.219	1.254	0.964	0.964	-----	979491	241618
===>Grouped by Line: 009-16*-FDW-16, No Sorting.							
FD16SP01 US	1.219	1.163	0.964	0.964	1128945	-----	241618
FD16SP01 DS	1.219	1.163	0.964	0.964	1128945	-----	241618
FD16TE01(U/S)	1.219	1.143	0.964	0.964	743024	-----	241618
FD16TE01(D/S)	1.219	1.143	0.964	0.964	743024	-----	241618
FD16SP02	1.219	1.168	0.964	0.964	1273666	-----	241618
FD16SP03	1.219	1.163	0.964	0.964	1128945	-----	241618
FD16SP04	1.219	1.163	0.964	0.964	1128945	-----	241618
FD16SP05	1.219	1.068	0.964	0.964	588604	-----	127004
FD16EL01	1.219	1.125	0.964	0.964	542240	-----	241618
===>Grouped by Line: 010-16*-FDW-19, No Sorting.							
FD19SP01 US	0.844	0.792	0.645	0.645	891487	-----	241618
FD19SP01 DS	0.844	0.792	0.645	0.645	891487	-----	241618
FD19EL01	1.219	1.125	0.645	0.645	1621719	-----	241618
FD19SP02	0.844	0.785	0.645	0.645	746318	-----	241618
FD19EL02	1.219	1.135	0.645	0.645	1856868	-----	241618
FD19SP03 US	0.844	0.792	0.645	0.645	891487	-----	241618
FD19SP03 DS	0.844	0.785	0.645	0.645	-----	852124	241618
FD19TE01(U/S)	1.219	1.898	0.645	0.645	2849744	-----	241618
FD19TE01(D/S)	1.219	1.916	0.645	0.645	-----	4258696	241618
FD19TE01(BR.)	0.844	0.762	0.433	0.433	-----	1040838	241618
FD19RD01(L/E)	1.219	1.347	0.645	0.645	-----	2640355	241618
FD19RD01(S/E)	0.844	0.774	0.433	0.433	-----	1182188	241618
===>Grouped by Line: 010-10*-FDW-19, No Sorting.							
FD19SP04	0.844	0.773	0.433	0.433	-----	1506324	241618
FD19SP05	0.844	0.802	0.433	0.433	2822808	-----	241618
FD19EL03	0.844	0.738	0.433	0.433	913014	-----	241618
FD19SP06 US	0.844	0.772	0.433	0.433	1504026	-----	241618
FD19SP06 DS	0.844	0.772	0.433	0.433	1504026	-----	241618
SD19EL04	0.844	0.749	0.433	0.433	1962259	-----	241618
FD19SP07	0.844	0.781	0.433	0.433	1752520	-----	241618
FD19SP08	0.844	0.462	0.433	0.433	2822808	-----	241618
FD19EL05	0.844	0.738	0.433	0.433	913014	-----	241618
FD19SP09 US	0.844	0.772	0.433	0.433	1504026	-----	241618
FD19SP09 DS	0.844	0.772	0.433	0.433	1504026	-----	241618
RX NOZZLE JA	0.594	0.534	0.472	0.472	3900000	-----	241618
===>Grouped by Line: 010-10*-FDW-21, No Sorting.							
FD21SP01 US	0.844	0.773	0.433	0.433	-----	1968529	241618

FD21SP01 DS	0.844	0.747	0.433	0.433	1959594	-----	241618
FD21EL01	0.844	0.749	0.433	0.433	1062259	-----	241618
FD21SP02	0.844	0.781	0.433	0.433	1752520	-----	241618
FD21SP03	0.844	0.802	0.433	0.433	2822808	-----	241618
FD21EL02	0.844	0.738	0.433	0.433	913014	-----	241618
FD21SP04 US	0.844	0.772	0.433	0.433	1504026	-----	241618
FD21SP04 DS	0.844	0.772	0.433	0.433	1504026	-----	241618
RX NOZZLE 4B	0.594	0.594	0.472	0.472	99000000	-----	241618

===>Grouped by Line: 014-18*-FDW-15, No Sorting.

OUTLET E-1-1B	1.375	1.265	1.085	1.085	522532	-----	241618
FD15EL01	1.375	1.294	1.085	1.085	817946	-----	241618
FD15SP01	1.375	1.327	1.085	1.085	1592633	-----	241618
FD15EL02	1.375	1.294	1.085	1.085	817946	-----	241618
FD15TE01 (U/S)	1.375	1.257	1.085	1.085	830885	-----	241618
FD15TE01 (D/S)	1.375	1.290	1.085	1.085	990359	-----	241618
FD15RD01 (L/E)	1.375	1.199	1.085	1.085	473292	-----	241618
FD15RD01 (S/E)	1.219	1.150	0.964	0.964	724912	-----	241618

===>Grouped by Line: 014-16*-FDW-15, No Sorting.

FD15SP02	1.219	1.100	0.964	0.964	678744	-----	241618
FD15EL03	1.219	1.154	0.964	0.964	716912	-----	241618
FD15SP09	1.219	1.088	0.964	0.964	702760	-----	241618
FD15EL04	1.219	1.153	0.964	0.964	-----	637778	241618
FD15SP10	1.219	1.191	0.964	0.964	-----	885803	241618
FD15EL05	1.219	1.067	0.964	0.964	-----	347038	241618
FD15SP03	1.219	1.171	0.964	0.964	-----	807624	241618
FD15SP04	1.219	1.183	0.964	0.964	1953036	-----	241618
FD15FE01A	1.219	1.183	0.964	0.964	1953036	-----	241618
FD15FE01	1.219	1.218	0.964	0.964	88712408	-----	241618
FD15FE01B	1.219	1.172	0.964	0.964	1417698	-----	241618
FD15SP05 US	1.219	1.172	0.964	0.964	1417698	-----	241618
FD15SP05 DS	1.219	1.172	0.964	0.964	1417698	-----	241618
FD15EL06	1.219	1.125	0.964	0.964	542240	-----	241618
FD15TE02 (U/S)	1.219	1.143	0.964	0.964	743024	-----	241618
FD15TE02 (D/S)	1.219	1.143	0.964	0.964	743024	-----	241618
FD15CP01	0.719	0.718	0.520	0.520	42529632	-----	241618
FD15SP06	1.219	1.168	0.964	0.964	1273666	-----	241618

===>Grouped by Line: 015-16*-FDW-15, No Sorting.

FD15SP07	1.219	1.183	0.964	0.964	1953036	-----	241618
FD15EL07	1.219	1.204	0.964	0.964	810194	-----	241618
FD15SP08 US	1.219	1.157	0.964	0.964	-----	964409	241618
FD15SP08 DS	1.219	1.155	0.964	0.964	955281	-----	241618
FD15EL08	1.219	1.125	0.964	0.964	542240	-----	241618

===>Grouped by Line: 016-10*-FDW-18, No Sorting.

FD18SP04 US	0.844	0.749	0.433	0.433	-----	1750591	241618
FD18SP04 DS	0.844	0.787	0.433	0.433	1959598	-----	241618
FD18EL03	0.844	0.749	0.433	0.433	1062259	-----	241618
FD18SP05	0.844	0.781	0.433	0.433	1752520	-----	241618
FD18SP06	0.844	0.802	0.433	0.433	2822808	-----	241618
FD18EL04	0.844	0.738	0.433	0.433	913014	-----	241618
FD18SP07 US	0.844	0.772	0.433	0.433	1504026	-----	241618
FD18SP07 DS	0.844	0.772	0.433	0.433	1504026	-----	241618
RX NOZZLE 4C	0.594	0.594	0.472	0.472	99000000	-----	241618

===>Grouped by Line: 015-16*-FDW-17, No Sorting.

FD17SP01 US	1.219	1.163	0.964	0.964	1128945	-----	241618
FD17SP01 DS	1.219	1.163	0.964	0.964	1128945	-----	241618
FD17TE01 (U/S)	1.219	1.143	0.964	0.964	743024	-----	241618
FD17TE01 (D/S)	1.219	1.143	0.964	0.964	743024	-----	241618
FD17SP02	1.219	1.168	0.964	0.964	1273666	-----	241618
FD17SP03	1.219	1.163	0.964	0.964	1128945	-----	241618
FD17SP04	1.219	1.163	0.964	0.964	1128945	-----	241618
FD17SP05	1.219	1.193	0.964	0.964	1300083	-----	127004
FD17EL01	1.219	1.125	0.964	0.964	542240	-----	241618

===>Grouped by Line: 016-16*-FDW-18, No Sorting.

FD18SP01 US	0.844	0.792	0.645	0.645	891487	-----	241618
FD18SP01 DS	0.844	0.797	0.645	0.645	-----	925801	241618
FD18EL01	1.219	1.213	0.645	0.645	-----	1919003	241618
FD18SP02 US	0.844	0.793	0.645	0.645	-----	789150	241618
FD18SP02 DS	0.844	0.785	0.645	0.645	746318	-----	241618
FD18EL02	1.219	1.135	0.645	0.645	1856868	-----	241618
FD18SP03 US	0.844	0.792	0.645	0.645	891487	-----	241618
FD18SP03 DS	0.844	0.792	0.645	0.645	891487	-----	241618
FD18TE01 (U/S)	1.219	1.538	0.645	0.645	-----	2030518	241618
FD18TE01 (D/S)	1.219	1.629	0.645	0.645	-----	3296613	241618
FD18TE01 (BR.)	0.844	0.744	0.433	0.433	983372	-----	241618

===>Grouped by Line: 016-10*-FDW-25, No Sorting.

FD20RD01 (L/E)	1.219	1.123	0.645	0.645	2518487	-----	241618
FD20RD01 (S/E)	0.844	0.756	0.433	0.433	1116948	-----	241618
FD20SP01	0.844	0.716	0.433	0.433	-----	1252849	241618
FD20SP02	0.844	0.802	0.433	0.433	2822808	-----	241618
FD20EL01	0.844	0.738	0.433	0.433	913014	-----	241618
FD20SP03 US	0.844	0.772	0.433	0.433	1504026	-----	241618
FD20SP03 DS	0.844	0.772	0.433	0.433	1504026	-----	241618
FD20EL02	0.844	0.749	0.433	0.433	1062259	-----	241618
FD20SP04	0.844	0.741	0.433	0.433	1752520	-----	241618
FD20SP05	0.844	0.802	0.433	0.433	2822808	-----	241618
FD20EL03	0.844	0.738	0.433	0.433	913014	-----	241618
FD20SP06 US	0.844	0.772	0.433	0.433	1504026	-----	241618
FD20SP06 DS	0.844	0.772	0.433	0.433	1504026	-----	241618
RX NOZZLE 4D	0.594	0.594	0.472	0.472	99000000	-----	241618

99

Note:

[1] Predictions are based on last Tmeas to analysis ending period.

100

 *** Wear Rate Analysis: Inspection History Report ***

Run Name: FDW 2006 Els to Rx
 Ending Period: CYCLE 25
 Total Plant Operating Hours: 241618 Duty Factor (Global): 1.000
 WRA Data Option: Ignore NFA Exclude Measure Wear: No
 Line Correction Factor: 0.257

Component Name	Geom. Code	No.	Material			Sigma (psi)	Time (hrs)		Analysis Option	Measured Wear (mils)
			Cr. (%)	Cu. (%)	Mo. (%)		Last Inspected	Replaced		

====>Grouped by Line: 008-18*-FDW-14, No Sorting.

GUTLET E-1-1A	31	5	0.00	0.00	0.00	15000	-----	-----	---
FD14EL01	4	21	0.00	0.00	0.00	15000	-----	-----	---
FD14SP01	58	5	0.00	0.00	0.00	15000	-----	-----	---
FD14EL02	2	21	0.00	0.00	0.00	15000	-----	-----	---
FD14TE01 (U/S)	15	21	0.00	0.00	0.00	15000	-----	-----	---
FD14TE01 (D/S)	15	21	0.00	0.00	0.00	15000	-----	-----	---
FD14RD01 (L/E)	7	21	0.00	0.00	0.00	15000	114614	-----	139
FD14RD01 (S/E)	7	21	0.00	0.00	0.00	15000	114614	-----	66

====>Grouped by Line: 008-16*-FDW-14, No Sorting.

FD14SP02	57	5	0.00	0.00	0.00	15000	114614	-----	55
FD14EL03	2	21	0.00	0.00	0.00	15000	183618	-----	9
FD14SP03 US	52	5	0.00	0.00	0.00	15000	230118	-----	19
FD14SP03 DS	52	5	0.00	0.00	0.00	15000	-----	-----	---
FD14EL04	2	21	0.00	0.00	0.00	15000	-----	-----	---
FD14SP04	52	5	0.00	0.00	0.00	15000	-----	-----	---
FD14SP05	9	5	0.00	0.00	0.00	15000	-----	-----	---
FD14FE01A	52	5	0.00	0.00	0.00	15000	-----	-----	---
FD14FE01	6	5	18.00	0.00	0.00	15000	-----	-----	---
FD14FE01B	56	5	0.00	0.00	0.00	15000	-----	-----	---
FD14SP06 US	56	5	0.00	0.00	0.00	15000	-----	-----	---
FD14SP06 DS	56	5	0.00	0.00	0.00	15000	-----	-----	---
FD14EL05	2	21	0.00	0.00	0.00	15000	207118	-----	85
FD14TE02 (U/S)	15	21	0.00	0.00	0.00	15000	-----	-----	---
FD14TE02 (D/S)	15	21	0.00	0.00	0.00	15000	-----	-----	---
FD14CP01	65	21	0.00	0.00	0.00	15000	-----	-----	---
FD14SP07 US	65	5	0.00	0.00	0.00	15000	-----	-----	---

====>Grouped by Line: 009-16*-FDW-14, No Sorting.

FD14SP07 DS	65	5	0.00	0.00	0.00	15000	-----	-----	---
FD14EL06	2	21	0.00	0.00	0.00	15000	-----	-----	---
FD14SP08 US	52	5	0.00	0.00	0.00	15000	-----	-----	---
FD14SP08 DS	52	5	0.00	0.00	0.00	15000	218618	-----	64
FD14EL07	2	21	0.00	0.00	0.00	15000	218618	-----	79

====>Grouped by Line: 009-16*-FDW-16, No Sorting.

FD16SP01 US	58	5	0.00	0.00	0.00	15000	-----	-----	---
FD16SP01 DS	58	5	0.00	0.00	0.00	15000	-----	-----	---
FD16TE01 (U/S)	15	21	0.00	0.00	0.00	15000	-----	-----	---
FD16TE01 (D/S)	15	21	0.00	0.00	0.00	15000	-----	-----	---
FD16SP02	65	5	0.00	0.00	0.00	15000	-----	-----	---
FD16SP03	58	5	0.00	0.00	0.00	15000	-----	-----	---
FD16SP04	58	5	0.00	0.00	0.00	15000	-----	-----	---
FD16SP05	58	5	0.00	0.00	0.00	15000	-----	-----	---
*Replacement #1	58	5	0.00	0.00	0.00	15000	-----	114614	---
FD16EL01	4	21	0.00	0.00	0.00	15000	-----	-----	---

====>Grouped by Line: 010-16*-FDW-19, No Sorting.

FD19SP01 US	58	5	0.00	0.00	0.00	15000	-----	-----	---
FD19SP01 DS	58	5	0.00	0.00	0.00	15000	-----	-----	---
FD19EL01	2	21	0.00	0.00	0.00	15000	-----	-----	---
FD19SP02	52	5	0.00	0.00	0.00	15000	-----	-----	---
FD19EL02	1	21	0.00	0.00	0.00	15000	-----	-----	---
FD19SP03 US	51	5	0.00	0.00	0.00	15000	-----	-----	---
FD19SP03 DS	51	5	0.00	0.00	0.00	15000	218618	-----	21
FD19TE01 (U/S)	14	21	0.00	0.00	0.00	15000	-----	-----	---
FD19TE01 (D/S)	14	21	0.00	0.00	0.00	15000	137270	-----	19
FD19TE01 (BR.)	14	21	0.00	0.00	0.00	15000	137270	-----	27
FD19RD01 (L/E)	7	21	0.00	0.00	0.00	15000	218618	-----	47
FD19RD01 (S/E)	7	21	0.00	0.00	0.00	15000	218618	-----	48

====>Grouped by Line: 010-10*-FDW-19, No Sorting.

FD19SP04	57	5	0.00	0.00	0.00	15000	218618	-----	19
FD19SP05	9	5	0.00	0.00	0.00	15000	-----	-----	---
FD19EL03	2	21	0.00	0.00	0.00	15000	-----	-----	---
FD19SP06 US	52	5	0.00	0.00	0.00	15000	-----	-----	---
FD19SP06 DS	52	5	0.00	0.00	0.00	15000	-----	-----	---
FD19EL04	1	21	0.00	0.00	0.00	15000	-----	-----	---
FD19SP07	51	5	0.00	0.00	0.00	15000	-----	-----	---
FD19SP08	9	5	0.00	0.00	0.00	15000	-----	-----	---
FD19EL05	2	21	0.00	0.00	0.00	15000	-----	-----	---
FD19SP09 US	52	5	0.00	0.00	0.00	15000	-----	-----	---
FD19SP09 DS	52	5	0.00	0.00	0.00	15000	-----	-----	---
FX NOZZLE 4A	30	23	16.00	0.00	0.00	13725	-----	-----	---

====>Grouped by Line: 010-10*-FDW-21, No Sorting.

FD21SP01 US	64	5	0.00	0.00	0.00	15000	21361A	----	----	24
FD21SP01 DS	64	5	0.00	0.00	0.00	15000	-----	-----	-----	---
FD21EL01	1	21	0.00	0.00	0.00	15000	-----	-----	-----	---
FD21SP02	51	5	0.00	0.00	0.00	15000	-----	-----	-----	---
FD21SP03	9	5	0.00	0.00	0.00	15000	-----	-----	-----	---
FD21EL02	2	21	0.00	0.00	0.00	15000	-----	-----	-----	---
FD21SP04 US	52	5	0.00	0.00	0.00	15000	-----	-----	-----	---
FD21SP04 DS	52	5	0.00	0.00	0.00	15000	-----	-----	-----	---
RX NOZZLE 4B	30	83	16.00	0.00	2.00	13725	-----	-----	-----	---

===>Grouped by Line: 014-18*-FDW-15, No Sorting.

OUTLET E-1-1B	31	5	0.00	0.00	0.00	15000	-----	-----	-----	---
FD15EL01	4	21	0.00	0.00	0.00	15000	-----	-----	-----	---
FD15SP01	58	5	0.00	0.00	0.00	15000	-----	-----	-----	---
FD15EL02	2	21	0.00	0.00	0.00	15000	-----	-----	-----	---
FD15TE01(U/S)	15	21	0.00	0.00	0.00	15000	-----	-----	-----	---
FD15TE01(D/S)	15	21	0.00	0.00	0.00	15000	-----	-----	-----	---
FD15RD01(L/E)	7	21	0.00	0.00	0.00	15000	-----	-----	-----	---
FD15RD01(S/E)	7	21	0.00	0.00	0.00	15000	-----	-----	-----	---

===>Grouped by Line: 014-16*-FDW-15, No Sorting.

FD15SP02	57	5	0.00	0.00	0.00	15000	-----	-----	-----	---
FD15EL03	1	21	0.00	0.00	0.00	15000	-----	-----	-----	---
FD15SP09	51	5	0.00	0.00	0.00	15000	-----	-----	-----	---
FD15EL04	4	21	0.00	0.00	0.00	15000	171740	-----	-----	91
FD15SP10	54	5	0.00	0.00	0.00	15000	171740	-----	-----	44
FD15EL05	4	21	0.00	0.00	0.00	15000	171740	-----	-----	178
FD15SP03	54	5	0.00	0.00	0.00	15000	171740	-----	-----	108
FD15SP04	9	5	0.00	0.00	0.00	15000	-----	-----	-----	---
FD15FE01A	9	5	0.00	0.00	0.00	15000	-----	-----	-----	---
FD15FE01	6	5	18.00	0.00	0.00	15000	-----	-----	-----	---
FD15FE01B	56	5	0.00	0.00	0.00	15000	-----	-----	-----	---
FD15SP05 US	56	5	0.00	0.00	0.00	15000	-----	-----	-----	---
FD15SP05 DS	56	5	0.00	0.00	0.00	15000	-----	-----	-----	---
FD15EL06	2	21	0.00	0.00	0.00	15000	-----	-----	-----	---
FD15TE02(U/S)	15	21	0.00	0.00	0.00	15000	-----	-----	-----	---
FD15TE02(D/S)	15	21	0.00	0.00	0.00	15000	-----	-----	-----	---
FD15CP01	65	21	0.00	0.00	0.00	15000	-----	-----	-----	---
FD15SP06	65	5	0.00	0.00	0.00	15000	-----	-----	-----	---

===>Grouped by Line: 015-16*-FDW-15, No Sorting.

FD15SP07	9	5	0.00	0.00	0.00	15000	-----	-----	-----	---
FD15EL07	2	21	0.00	0.00	0.00	15000	-----	-----	-----	---
FD15SP08 US	52	5	0.00	0.00	0.00	15000	171740	-----	-----	45
FD15SP08 DS	52	5	0.00	0.00	0.00	15000	-----	-----	-----	---
FD15EL08	2	21	0.00	0.00	0.00	15000	-----	-----	-----	---

===>Grouped by Line: 016-10*-FDW-18, No Sorting.

FD18SP04 US	64	5	0.00	0.00	0.00	15000	19561A	-----	-----	155
FD18SP04 DS	64	5	0.00	0.00	0.00	15000	-----	-----	-----	---
FD18EL03	1	21	0.00	0.00	0.00	15000	-----	-----	-----	---
FD18SP05	51	5	0.00	0.00	0.00	15000	-----	-----	-----	---
FD18SP06	9	5	0.00	0.00	0.00	15000	-----	-----	-----	---
FD18EL04	2	21	0.00	0.00	0.00	15000	-----	-----	-----	---
FD18SP07 US	52	5	0.00	0.00	0.00	15000	-----	-----	-----	---
FD18SP07 DS	52	5	0.00	0.00	0.00	15000	-----	-----	-----	---
RX NOZZLE 4C	30	83	16.00	0.00	2.00	13725	-----	-----	-----	---

===>Grouped by Line: 015-16*-FDW-17, No Sorting.

FD17SP01 US	58	5	0.00	0.00	0.00	15000	-----	-----	-----	---
FD17SP01 DS	58	5	0.00	0.00	0.00	15000	-----	-----	-----	---
FD17TE01(U/S)	15	5	0.00	0.00	0.00	15000	-----	-----	-----	---
FD17TE01(D/S)	15	5	0.00	0.00	0.00	15000	-----	-----	-----	---
FD17SP02	65	5	0.00	0.00	0.00	15000	-----	-----	-----	---
FD17SP03	58	5	0.00	0.00	0.00	15000	-----	-----	-----	---
FD17SP04	58	5	0.00	0.00	0.00	15000	-----	-----	-----	---
FD17SP05	58	5	0.00	0.00	0.00	15000	-----	-----	-----	---
*Replacement #1	58	5	0.00	0.00	0.00	15000	-----	114614	-----	---
FD17EL01	4	21	0.00	0.00	0.00	15000	-----	-----	-----	---

===>Grouped by Line: 016-16*-FDW-18, No Sorting.

FD18SP01 US	58	5	0.00	0.00	0.00	15000	-----	-----	-----	---
FD18SP01 DS	58	5	0.00	0.00	0.00	15000	20711A	-----	-----	73
FD18EL01	2	21	0.00	0.00	0.00	15000	20711B	-----	-----	140
FD18SP02 US	52	5	0.00	0.00	0.00	15000	20711B	-----	-----	53
FD18SP02 DS	52	5	0.00	0.00	0.00	15000	-----	-----	-----	---
FD18EL02	1	21	0.00	0.00	0.00	15000	-----	-----	-----	---
FD18SP03 US	51	5	0.00	0.00	0.00	15000	-----	-----	-----	---
FD18SP03 DS	51	5	0.00	0.00	0.00	15000	-----	-----	-----	---
FD18TE01(U/S)	14	21	0.00	0.00	0.00	15000	19561B	-----	-----	82
FD18TE01(D/S)	14	21	0.00	0.00	0.00	15000	19561B	-----	-----	121
FD18TE01(RR.)	14	21	0.00	0.00	0.00	15000	-----	-----	-----	---

===>Grouped by Line: 016-10*-FDW-20, No Sorting.

FD20RC01(L/E)	7	21	0.00	0.00	0.00	15000	-----	-----	-----	---
FD20RC01(S/E)	7	21	0.00	0.00	0.00	15000	-----	-----	-----	---
FD20SP01	57	5	0.00	0.00	0.00	15000	19561B	-----	-----	123
FD20SP02	9	5	0.00	0.00	0.00	15000	-----	-----	-----	---
FD20EL01	2	21	0.00	0.00	0.00	15000	-----	-----	-----	---
FD20SP03 US	52	5	0.00	0.00	0.00	15000	-----	-----	-----	---
FD20SP03 DS	52	5	0.00	0.00	0.00	15000	-----	-----	-----	---
FD20EL02	1	21	0.00	0.00	0.00	15000	-----	-----	-----	---
FD20SP04	51	5	0.00	0.00	0.00	15000	-----	-----	-----	---
FD20SP05	3	5	0.00	0.00	0.00	15000	-----	-----	-----	---
FD20EL03	2	21	0.00	0.00	0.00	15000	-----	-----	-----	---
FD20SP06 US	52	5	0.00	0.00	0.00	15000	-----	-----	-----	---

FD20SP06 DS
RX NOZZLE 4D

52	5	9.00	0.00	9.00	15000	-----	-----	---
30	43	16.00	0.00	2.00	13725	-----	-----	---

*** Wear Rate Analysis: Wear Rates/Input Data Report ***

Run Name: FDW 2006 Els to Rx
 Ending Period: CYCLE 25
 Total Plant Operating Hours: 241618 Duty Factor (Global): 1.000
 WPA Data Option: Ignore NFA Exclude Measure Wear: No
 Line Correction Factor: 0.257

Component Name	Geom. Code	Average Wear Rate (mils/year)	Current Wear Rate (mils/year)	Temp. (F)	Velocity (ft/s)	Steam Quality	Diameter (in)
----------------	------------	-------------------------------	-------------------------------	-----------	-----------------	---------------	---------------

===>Grouped by Line: 008-18*-FDW-14, No Sorting.

OUTLET E-1-1A	31	3.979	3.021	373.1	12.823	0.000	18.000
FD14EL01	4	2.945	2.236	373.1	12.823	0.000	18.000
FD14SP01	58	1.751	1.329	373.1	12.823	0.000	18.000
FD14EL02	2	2.945	2.236	373.1	12.823	0.000	18.000
FD14TE01(U/S)	15	2.388	1.813	373.1	12.823	0.000	18.000
FD14TE01(D/S)	15	2.388	1.813	373.1	12.823	0.000	18.000
FD14RD01(L/E)	7	2.786	2.115	373.1	12.823	0.000	18.500
FD14RD01(S/E)	7	2.952	2.241	373.1	16.213	0.000	16.000

===>Grouped by Line: 008-16*-FDW-14, No Sorting.

FD14SP02	57	2.306	1.751	373.1	16.213	0.000	16.000
FD14EL03	2	3.413	2.591	373.1	16.213	0.000	16.000
FD14SP03 US	52	2.306	1.751	373.1	16.213	0.000	16.000
FD14SP03 DS	52	2.306	1.751	373.1	16.213	0.000	16.000
FD14EL04	2	3.413	2.591	373.1	16.213	0.000	16.000
FD14SP04	52	2.306	1.751	373.1	16.213	0.000	16.000
FD14SP05	9	1.293	0.982	373.1	16.213	0.000	16.000
FD14FE01A	52	2.306	1.751	373.1	16.213	0.000	16.000
FD14FE01	6	0.033	0.025	373.1	42.526	0.000	16.000
FD14FE01B	56	1.692	1.284	373.1	42.526	0.000	16.000
FD14SP06 US	56	1.692	1.284	373.1	42.526	0.000	16.000
FD14SP06 DS	56	1.692	1.284	373.1	42.526	0.000	16.000
FD14EL05	2	3.413	2.591	373.1	16.213	0.000	16.000
FD14TE02(U/S)	15	2.767	2.101	373.1	16.213	0.000	16.000
FD14TE02(D/S)	15	2.767	2.101	373.1	16.213	0.000	16.000
FD14CP01	65	0.054	0.041	373.1	0.180	0.000	8.625
FD14SP07 US	65	1.845	1.401	373.1	16.213	0.000	16.000

===>Grouped by Line: 009-16*-FDW-14, No Sorting.

FD14SP07 DS	65	1.845	1.401	373.1	16.213	0.000	16.000
FD14EL06	2	3.413	2.591	373.1	16.213	0.000	16.000
FD14SP08 US	52	2.306	1.751	373.1	16.213	0.000	16.000
FD14SP08 DS	52	2.306	1.751	373.1	16.213	0.000	16.000
FD14EL07	2	3.413	2.591	373.1	16.213	0.000	16.000

===>Grouped by Line: 009-16*-FDW-16, No Sorting.

FD16SP01 US	58	2.029	1.541	373.1	16.213	0.000	16.000
FD16SP01 DS	58	2.029	1.541	373.1	16.213	0.000	16.000
FD16TE01(U/S)	15	2.767	2.101	373.1	16.213	0.000	16.000
FD16TE01(D/S)	15	2.767	2.101	373.1	16.213	0.000	16.000
FD16SP02	65	1.845	1.401	373.1	16.213	0.000	16.000
FD16SP03	58	2.029	1.541	373.1	16.213	0.000	16.000
FD16SP04	58	2.029	1.541	373.1	16.213	0.000	16.000
FD16SP05	58	1.785	1.541	373.1	16.213	0.000	16.000
FD16EL01	4	3.413	2.591	373.1	16.213	0.000	16.000

===>Grouped by Line: 010-16*-FDW-19, No Sorting.

FD19SP01 US	58	1.897	1.440	373.1	14.559	0.000	16.000
FD19SP01 DS	58	1.897	1.440	373.1	14.559	0.000	16.000
FD19EL01	2	3.413	2.591	373.1	16.213	0.000	16.000
FD19SP02	52	2.155	1.636	373.1	14.559	0.000	16.000
FD19EL02	1	3.044	2.311	373.1	16.213	0.000	16.000
FD19SP03 US	51	1.897	1.440	373.1	14.559	0.000	16.000
FD19SP03 DS	51	1.897	1.440	373.1	14.559	0.000	16.000
FD19TE01(U/S)	14	5.074	3.852	373.1	16.213	0.000	16.000
FD19TE01(D/S)	14	3.444	2.614	373.1	8.107	0.000	16.000
FD19TE01(BR.)	14	3.639	2.763	373.1	18.157	0.000	10.750
FD19RD01(L/E)	7	2.191	1.664	373.1	8.107	0.000	16.000
FD19RD01(S/E)	7	3.327	2.526	373.1	18.157	0.000	10.750

===>Grouped by Line: 010-10*-FDW-19, No Sorting.

FD19SP04	57	2.599	1.973	373.1	18.157	0.000	10.750
FD19SP05	9	1.508	1.145	373.1	18.157	0.000	10.750
FD19EL03	2	3.847	2.921	373.1	18.157	0.000	10.750
FD19SP06 US	52	2.599	1.973	373.1	18.157	0.000	10.750
FD19SP06 DS	52	2.599	1.973	373.1	18.157	0.000	10.750
FD19EL04	1	3.431	2.605	373.1	18.157	0.000	10.750
FD19SP07	51	2.288	1.737	373.1	18.157	0.000	10.750
FD19SP08	9	1.508	1.145	373.1	18.157	0.000	10.750
FD19EL05	2	3.847	2.921	373.1	18.157	0.000	10.750
FD19SP09 US	51	2.339	1.973	373.1	18.157	0.000	10.750
FD19SP09 DS	51	2.599	1.973	373.1	18.157	0.000	10.750
RX H02ZLE 4A	30	0.008	0.005	373.1	16.308	0.000	10.750

===>Grouped by Line: 010-10*-FDW-21, No Sorting.

FD21SP01 US	64	2.089	1.579	373.1	18.157	0.000	10.750
-------------	----	-------	-------	-------	--------	-------	--------

FD21SP01 DS	54	2.590	1.579	373.1	18.157	0.000	10.750
FD21EL01	1	3.431	2.605	373.1	18.157	0.000	10.750
FD21SP02	51	2.288	1.737	373.1	18.157	0.000	10.750
FD21SP03	9	1.528	1.145	373.1	18.157	0.000	10.750
FD21EL03	2	3.847	2.921	373.1	18.157	0.000	10.750
FD21SP04 US	52	2.599	1.973	373.1	18.157	0.000	10.750
FD21SP04 DS	52	2.599	1.973	373.1	18.157	0.000	10.750
RX NOZZLE 4B	30	0.008	0.006	373.1	16.308	0.000	10.750

====>Grouped by Line: 014-18*-FDW-15, No Sorting.

OUTLET E-1-1B	31	3.979	3.021	373.1	12.823	0.000	18.000
FD15EL01	4	2.945	2.236	373.1	12.823	0.000	18.000
FD15SP01	58	1.751	1.329	373.1	12.823	0.000	18.000
FD15EL02	2	2.945	2.236	373.1	12.823	0.000	18.000
FD15TE01(U/S)	15	2.388	1.813	373.1	12.823	0.000	18.000
FD15TE01(D/S)	15	2.388	1.813	373.1	12.823	0.000	18.000
FD15RD01(L/E)	7	2.786	2.115	373.1	12.823	0.000	18.000
FD15RD01(S/E)	7	2.952	2.241	373.1	16.213	0.000	16.000

====>Grouped by Line: 014-16*-FDW-15, No Sorting.

FD15SP02	57	2.306	1.751	373.1	16.213	0.000	16.000
FD15EL03	1	3.044	2.311	373.1	16.213	0.000	16.000
FD15SP09	51	2.029	1.541	373.1	16.213	0.000	16.000
FD15EL04	4	3.413	2.591	373.1	16.213	0.000	16.000
FD15SP10	54	2.952	2.241	373.1	16.213	0.000	16.000
FD15EL05	4	3.413	2.591	373.1	16.213	0.000	16.000
FD15SP03	54	2.952	2.241	373.1	16.213	0.000	16.000
FD15SP04	9	1.293	0.982	373.1	16.213	0.000	16.000
FD15FE01A	9	1.293	0.982	373.1	16.213	0.000	16.000
FD15FE01	6	0.033	0.025	373.1	42.526	0.000	16.000
FD15FE01B	56	1.692	1.284	373.1	42.526	0.000	16.000
FD15SP05 US	56	1.692	1.284	373.1	42.526	0.000	16.000
FD15SP05 DS	56	1.692	1.284	373.1	42.526	0.000	16.000
FD15EL06	2	3.413	2.591	373.1	16.213	0.000	16.000
FD15TE02(U/S)	15	2.767	2.101	373.1	16.213	0.000	16.000
FD15TE02(D/S)	15	2.767	2.101	373.1	16.213	0.000	16.000
FD15CP01	65	0.054	0.041	373.1	0.180	0.000	8.625
FD15SP06	65	1.845	1.401	373.1	16.213	0.000	16.000

====>Grouped by Line: 015-16*-FDW-15, No Sorting.

FD15SP07	9	1.293	0.982	373.1	16.213	0.000	16.000
FD15EL07	2	3.413	2.591	373.1	16.213	0.000	16.000
FD15SP08 US	52	2.306	1.751	373.1	16.213	0.000	16.000
FD15SP08 DS	52	2.306	1.751	373.1	16.213	0.000	16.000
FD15EL08	2	3.413	2.591	373.1	16.213	0.000	16.000

====>Grouped by Line: 016-10*-FDW-18, No Sorting.

FD18SP04 US	64	2.080	1.579	373.1	18.157	0.000	10.750
FD18SP04 DS	64	2.080	1.579	373.1	18.157	0.000	10.750
FD18EL03	1	3.431	2.605	373.1	18.157	0.000	10.750
FD18SP05	51	2.288	1.737	373.1	18.157	0.000	10.750
FD18SP06	9	1.508	1.145	373.1	18.157	0.000	10.750
FD18EL04	2	3.847	2.921	373.1	18.157	0.000	10.750
FD18SP07 US	52	2.599	1.973	373.1	18.157	0.000	10.750
FD18SP07 DS	52	2.599	1.973	373.1	18.157	0.000	10.750
RX NOZZLE 4C	30	0.008	0.006	373.1	16.308	0.000	10.750

====>Grouped by Line: 015-16*-FDW-17, No Sorting.

FD17SP01 US	58	2.029	1.541	373.1	16.213	0.000	16.000
FD17SP01 DS	58	2.029	1.541	373.1	16.213	0.000	16.000
FD17TE01(U/S)	15	2.767	2.101	373.1	16.213	0.000	16.000
FD17TE01(D/S)	15	2.767	2.101	373.1	16.213	0.000	16.000
FD17SP02	65	1.845	1.401	373.1	16.213	0.000	16.000
FD17SP03	58	2.029	1.541	373.1	16.213	0.000	16.000
FD17SP04	58	2.029	1.541	373.1	16.213	0.000	16.000
FD17SP05	58	1.785	1.541	373.1	16.213	0.000	16.000
FD17EL01	4	3.413	2.591	373.1	16.213	0.000	16.000

====>Grouped by Line: 016-15*-FDW-18, No Sorting.

FD18SP01 US	58	1.897	1.440	373.1	14.559	0.000	16.000
FD18SP01 DS	58	1.897	1.440	373.1	14.559	0.000	16.000
FD18EL01	2	3.413	2.591	373.1	16.213	0.000	16.000
FD18SP02 US	52	2.155	1.636	373.1	14.559	0.000	16.000
FD18SP02 DS	52	2.155	1.636	373.1	14.559	0.000	16.000
FD18EL02	1	3.044	2.311	373.1	16.213	0.000	16.000
FD18SP03 US	51	1.897	1.440	373.1	14.559	0.000	16.000
FD18SP03 DS	51	1.897	1.440	373.1	14.559	0.000	16.000
FD18TE01(U/S)	14	5.074	3.852	373.1	16.213	0.000	16.000
FD18TE01(D/S)	14	3.444	2.614	373.1	8.107	0.000	16.000
FD18TE01(BR.)	14	3.639	2.763	373.1	18.157	0.000	10.750

====>Grouped by Line: 016-10*-FDW-20, No Sorting.

FD20RD01(L/E)	7	2.191	1.664	373.1	8.107	0.000	16.000
FD20RD01(S/E)	7	3.327	2.526	373.1	18.157	0.000	10.750
FD20SP01	57	2.599	1.973	373.1	18.157	0.000	10.750
FD20SP02	9	1.508	1.145	373.1	18.157	0.000	10.750
FD20EL01	2	3.847	2.921	373.1	18.157	0.000	10.750
FD20SP03 US	52	2.599	1.973	373.1	18.157	0.000	10.750
FD20SP03 DS	52	2.599	1.973	373.1	18.157	0.000	10.750
FD20EL02	1	3.431	2.605	373.1	18.157	0.000	10.750
FD20SP04	51	2.288	1.737	373.1	18.157	0.000	10.750
FD20SP05	9	1.508	1.145	373.1	18.157	0.000	10.750
FD20EL03	2	3.847	2.921	373.1	18.157	0.000	10.750
FD20SP06 US	52	2.599	1.973	373.1	18.157	0.000	10.750
FD20SP06 DS	52	2.599	1.973	373.1	18.157	0.000	10.750
RX NOZZLE 4D	30	0.008	0.006	373.1	16.308	0.000	10.750

106

Company: Vermont Yankee Nuclear Power Corporation Report Date: 25-SEP-2006 Time: 16:00:34
 Plant: Vermont Yankee Analysis Date: 19-SEP-2006 Time: 19:19:21
 Unit: CHECWORKS FAC Version 1.0F (Build 52)
 DB Name: VY

 *** Wear Rate Analysis: Combined Summary Report ***

Run Name: FDW 2006 E1s to Rx
 Ending Period: CYCLE 25
 Total Plant Operating Hours: 241618 Duty Factor (Global): 1.000
 WRA Data Option: Ignore NFA Exclude Measure Wear: No
 Line Correction Factor: 0.257

Component Name	Geom. Code	Average Wear Rate (mils/year)	Current Wear Rate (mils/year)	Thickness (in)			Tcrit	Component Predict[1]		Total Lifetime		In-Service Cmp.		In-Service Cmp.		Time (hrs) Last Inspected
				Init.	Prd. [1]	Thoop		Time to Tcrit (hrs)	Non-Insp.	Insp.	Wear (mils) Prd. [2]	Meas.	Prd. [2]	Meas.	Meas. Method	
===Grouped by Line: 008-18*-FDW-14, No Sorting.																
CUTLET E-1-1A	31	3.979	3.021	1.375	1.265	1.085	1.085	522532	-----	---	---	---	---	1.375	--	0
FD14EL01	4	2.945	2.236	1.375	1.294	1.085	1.085	817946	-----	---	---	---	---	1.375	--	0
FD14SP01	58	1.751	1.329	1.375	1.327	1.085	1.085	1592633	-----	---	---	---	---	1.375	--	0
FD14EL02	2	2.945	2.236	1.375	1.294	1.085	1.085	817946	-----	---	---	---	---	1.375	--	0
FD14TE01 (U/S)	15	2.388	1.813	1.375	1.369	1.085	1.085	1370181	-----	---	---	---	---	1.399	US	114614
FD14TE01 (D/S)	15	2.388	1.813	1.375	1.345	1.085	1.085	1254199	-----	---	---	---	---	1.375	GW	114614
FD14RD01 (L/F)	7	2.786	2.115	1.375	1.200	1.085	1.085	-----	478243	41.3	139.0	41.3	139.0	1.236	MT	114614
FD14RD01 (S/E)	7	2.952	2.241	1.219	1.175	0.964	0.964	-----	824378	43.8	66.0	43.8	66.0	1.213	MT	114614
===Grouped by Line: 008-16*-FDW-14, No Sorting.																
FD14SP02	57	2.306	1.751	1.219	1.195	0.964	0.964	-----	1151436	34.2	55.0	34.2	55.0	1.234	US	114614
FD14EL03	3	3.413	2.591	1.219	1.173	0.964	0.964	-----	703631	75.8	9.0	75.8	9.0	1.176	US	230118
FD14SP03 US	52	2.306	1.751	1.219	1.203	0.964	0.964	-----	1191994	61.3	19.0	61.3	19.0	1.205	US	230118
FD14SP03 DS	52	2.306	1.751	1.219	1.155	0.964	0.964	955281	-----	---	---	---	---	1.219	--	0
FD14EL04	3	3.413	2.591	1.219	1.125	0.964	0.964	542240	-----	---	---	---	---	1.219	--	0
FD14SP04	52	2.306	1.751	1.219	1.155	0.964	0.964	955281	-----	---	---	---	---	1.219	--	0
FD14SP05	9	1.293	0.982	1.219	1.183	0.964	0.964	1953036	-----	---	---	---	---	1.219	--	0
FD14FE01A	52	2.306	1.751	1.219	1.155	0.964	0.964	955281	-----	---	---	---	---	1.219	--	0
FD14FE01	6	0.033	0.025	1.219	1.218	0.964	0.964	88712408	-----	---	---	---	---	1.219	--	0
FD14FE01B	56	1.692	1.284	1.219	1.172	0.964	0.964	1417698	-----	---	---	---	---	1.219	--	0
FD14SP06 US	56	1.692	1.284	1.219	1.176	0.964	0.964	1441875	-----	---	---	---	---	1.200	US	102975
FD14SP06 DS	56	1.692	1.284	1.219	1.158	0.964	0.964	1319530	-----	---	---	---	---	1.163	GW	207118
FD14EL05	2	3.413	2.591	1.219	1.124	0.964	0.964	-----	538641	83.9	85.0	83.9	85.0	1.134	MT	207118
FD14TE02 (U/S)	15	2.767	2.101	1.219	1.143	0.964	0.964	743024	-----	---	---	---	---	1.151	PW	207118
FD14TE02 (D/S)	15	2.767	2.101	1.219	1.143	0.964	0.964	743024	-----	---	---	---	---	1.151	PW	207118
FD14CP01	65	0.054	0.041	0.719	0.718	0.520	0.520	42529632	-----	---	---	---	---	0.719	--	0
FD14SP07 US	65	1.845	1.401	1.219	1.149	0.964	0.964	1157152	-----	---	---	---	---	1.155	MT	207118
===Grouped by Line: 009-16*-FDW-14, No Sorting.																
FD14SP07 DS	65	1.845	1.401	1.219	1.168	0.964	0.964	1273666	-----	---	---	---	---	1.219	--	0
FD14EL06	2	3.413	2.591	1.219	1.125	0.964	0.964	542240	-----	---	---	---	---	1.219	--	0
FD14SP08 US	52	2.306	1.751	1.219	1.155	0.964	0.964	955281	-----	---	---	---	---	1.219	--	0
FD14SP08 DS	52	2.306	1.751	1.219	1.148	0.964	0.964	-----	920314	59.0	65.0	59.0	65.0	1.153	US	218618
FD14EL07	2	3.413	2.591	1.219	1.254	0.964	0.964	-----	979491	87.3	79.0	87.3	79.0	1.261	US	218618
===Grouped by Line: 009-16*-FDW-16, No Sorting.																
FD16SP01 US	58	2.029	1.541	1.219	1.163	0.964	0.964	1128945	-----	---	---	---	---	1.219	--	0
FD16SP01 DS	58	2.029	1.541	1.219	1.163	0.964	0.964	1128945	-----	---	---	---	---	1.219	--	0
FD16TE01 (U/S)	15	2.767	2.101	1.219	1.143	0.964	0.964	743024	-----	---	---	---	---	1.219	--	0
FD16TE01 (D/S)	15	2.767	2.101	1.219	1.143	0.964	0.964	743024	-----	---	---	---	---	1.219	--	0
FD16SP02	65	1.845	1.401	1.219	1.168	0.964	0.964	1273666	-----	---	---	---	---	1.219	--	0
FD16SP03	58	2.029	1.541	1.219	1.163	0.964	0.964	1128945	-----	---	---	---	---	1.219	--	0
FD16SP04	58	2.029	1.541	1.219	1.163	0.964	0.964	1128945	-----	---	---	---	---	1.219	--	0
FD16SP05	58	1.785	1.541	1.219	1.068	0.964	0.964	588604	-----	---	---	---	---	1.081	MT	171740
FD16EL01	4	3.413	2.591	1.219	1.125	0.964	0.964	542240	-----	---	---	---	---	1.219	--	0
===Grouped by Line: 010-16*-FDW-19, No Sorting.																
FD19SP01 US	58	1.897	1.440	0.844	0.792	0.645	0.645	891487	-----	---	---	---	---	0.844	--	0
FD19SP01 DS	58	1.897	1.440	0.844	0.792	0.645	0.645	891487	-----	---	---	---	---	0.844	--	0
FD19EL01	2	3.413	2.591	1.219	1.125	0.645	0.645	1621719	-----	---	---	---	---	1.219	--	0
FD19SP02	52	2.155	1.636	0.844	0.785	0.645	0.645	746318	-----	---	---	---	---	0.844	--	0
FD19EL02	1	3.044	2.311	1.219	1.135	0.645	0.645	1856868	-----	---	---	---	---	1.219	--	0
FD19SP03 DS	51	1.897	1.440	0.844	0.792	0.645	0.645	891487	-----	---	---	---	---	0.844	--	0

167

FD19SP03 DS 51 1.897 1.440 0.844 0.785 0.645 0.645 ----- 852124 48.5 21.0 48.5 21.0 0.789 MT 218618 218618
FD19TE01 (U/S) 14 5.074 3.852 1.219 1.898 0.645 0.645 2849744 -----
FD19TE01 (D/S) 14 3.444 2.614 1.219 1.916 0.645 0.645 ----- 4258696 61.2 19.0 61.2 19.0 1.948 MT 137270 137270
FD19TE01 (BR.) 14 3.639 2.763 0.844 0.762 0.433 0.433 ----- 1040838 64.6 27.0 64.6 27.0 0.769 MT 218618 218618
FD19RD01 (L/E) 7 2.191 1.664 1.219 1.147 0.645 0.645 ----- 2640355 56.1 47.0 56.1 47.0 1.151 MT 218618 218618
FD19RD01 (S/E) 7 3.327 2.526 0.844 0.774 0.433 0.433 ----- 1182188 85.1 48.0 85.1 48.0 0.781 MT 218618 218618

====>Grouped by Line: 010-10*-FDW-19, No Sorting.

FD19SP04 57 2.599 1.973 0.844 0.773 0.433 0.433 ----- 1506324 66.5 19.0 66.5 19.0 0.778 US 218618 218618
FD19SP05 9 1.508 1.145 0.844 0.802 0.433 0.433 2822808 -----
FD19EL03 2 3.847 2.921 0.844 0.738 0.433 0.433 913014 -----
FD19SP06 US 52 2.599 1.973 0.844 0.772 0.433 0.433 1504026 -----
FD19SP06 DS 52 2.599 1.973 0.844 0.772 0.433 0.433 1504026 -----
FD19EL04 1 3.431 2.605 0.844 0.749 0.433 0.433 1062259 -----
FD19SP07 51 2.288 1.737 0.844 0.781 0.433 0.433 1752520 -----
FD19SP08 9 1.508 1.145 0.844 0.802 0.433 0.433 2822808 -----
FD19EL05 2 3.847 2.921 0.844 0.738 0.433 0.433 913014 -----
FD19SP09 US 52 2.599 1.973 0.844 0.772 0.433 0.433 1504026 -----
FD19SP09 DS 52 2.599 1.973 0.844 0.772 0.433 0.433 1504026 -----
RX NOZZLE 4A 30 0.008 0.006 0.594 0.594 0.472 0.472 9900000 -----

====>Grouped by Line: 010-10*-FDW-21, No Sorting.

FD21SP01 US 64 2.080 1.579 0.844 0.792 0.433 0.433 ----- 1988529 53.2 24.0 53.2 24.0 0.796 MT 218618 218618
FD21SP01 DS 64 2.080 1.579 0.844 0.787 0.433 0.433 1959598 -----
FD21EL01 1 3.431 2.605 0.844 0.749 0.433 0.433 1062259 -----
FD21SP02 51 2.288 1.737 0.844 0.781 0.433 0.433 1752520 -----
FD21SP03 9 1.508 1.145 0.844 0.802 0.433 0.433 2822808 -----
FD21EL02 2 3.847 2.921 0.844 0.738 0.433 0.433 913014 -----
FD21SP04 US 52 2.599 1.973 0.844 0.772 0.433 0.433 1504026 -----
FD21SP04 DS 52 2.599 1.973 0.844 0.772 0.433 0.433 1504026 -----
RX NOZZLE 4B 30 0.008 0.006 0.594 0.594 0.472 0.472 9900000 -----

====>Grouped by Line: 014-18*-FDW-15, No Sorting.

OUTLET E-1-1B 31 3.979 3.021 1.375 1.265 1.085 1.085 522532 -----
FD15EL01 4 2.945 2.236 1.375 1.294 1.085 1.085 817946 -----
FD15SP01 58 1.751 1.329 1.375 1.327 1.085 1.085 1592633 -----
FD15EL02 2 3.945 2.236 1.375 1.294 1.085 1.085 817946 -----
FD15TE01 (U/S) 15 2.388 1.813 1.375 1.257 1.085 1.085 830885 -----
FD15TE01 (D/S) 15 2.388 1.813 1.375 1.290 1.085 1.085 990359 -----
FD15RD01 (L/E) 7 2.786 2.115 1.375 1.199 1.085 1.085 473292 -----
FD15RD01 (S/E) 7 2.952 2.241 1.219 1.150 0.964 0.964 724912 -----

====>Grouped by Line: 014-16*-FDW-15, No Sorting.

FD15SP02 57 2.306 1.751 1.219 1.100 0.964 0.964 678744 -----
FD15EL03 1 3.044 2.311 1.219 1.154 0.964 0.964 716912 -----
FD15SP09 51 2.029 1.541 1.219 1.088 0.964 0.964 702760 -----
FD15EL04 4 3.413 2.591 1.219 1.153 0.964 0.964 ----- 637778 72.3 91.0 72.3 91.0 1.175 MT 171740 171740
FD15SP10 54 2.952 2.241 1.219 1.191 0.964 0.964 ----- 885803 62.5 45.0 62.5 45.0 1.210 GW 171740 171740
FD15EL05 4 3.413 2.591 1.219 1.067 0.964 0.964 ----- 347038 72.3 178.0 72.3 178.0 1.089 MT 171740 171740
FD15SP03 54 2.952 2.241 1.219 1.171 0.964 0.964 ----- 807624 62.5 108.0 62.5 108.0 1.190 GW 171740 171740
FD15ST04 9 1.293 0.982 1.219 1.183 0.964 0.964 1953036 -----
FD15FE01A 9 1.293 0.982 1.219 1.183 0.964 0.964 1953036 -----
FD15FE01 6 0.033 0.025 1.219 1.218 0.964 0.964 88712408 -----
FD15FE01B 56 1.692 1.284 1.219 1.172 0.964 0.964 1417698 -----
FD15SP05 US 56 1.692 1.284 1.219 1.172 0.964 0.964 1417698 -----
FD15SP05 DS 56 1.692 1.284 1.219 1.172 0.964 0.964 1417698 -----
FD15EL06 2 3.413 2.591 1.219 1.125 0.964 0.964 542240 -----
FD15TE02 (U/S) 15 2.767 2.101 1.219 1.143 0.964 0.964 743024 -----
FD15TE02 (D/S) 15 2.767 2.101 1.219 1.143 0.964 0.964 743024 -----
FD15CF01 65 0.054 0.041 0.719 0.718 0.520 0.520 42529632 -----
FD15SP06 65 1.845 1.401 1.219 1.168 0.964 0.964 1273666 -----

====>Grouped by Line: 015-16*-FDW-15, No Sorting.

FD15SP07 9 1.293 0.982 1.219 1.183 0.964 0.964 1953036 -----
FD15EL07 2 3.413 2.591 1.219 1.204 0.964 0.964 810194 -----
FD15SP08 US 52 2.306 1.751 1.219 1.157 0.964 0.964 ----- 964409 48.8 46.0 48.8 46.0 1.172 GW 171740 171740
FD15SP08 DS 52 2.306 1.751 1.219 1.155 0.964 0.964 955281 -----
FD15EL08 2 3.413 2.591 1.219 1.125 0.964 0.964 542240 -----

====>Grouped by Line: 016-10*-FDW-1A, No Sorting.

FD18SP04 US 64 2.080 1.579 0.844 0.749 0.433 0.433 ----- 1750591 48.3 155.0 48.3 155.0 0.758 MT 195618 195618
FD18SP04 DS 64 2.080 1.579 0.844 0.787 0.433 0.433 1950598 -----

81

FD18RLO1	1	3.431	2.605	0.844	0.749	0.433	0.433	1062259	-----	---	---	---	---	0.844	--	0	-----
FD18SP03	51	2.288	1.737	0.844	0.781	0.433	0.433	1752520	-----	---	---	---	---	0.844	--	0	-----
FD18SP06	9	1.508	1.145	0.844	0.802	0.433	0.433	2822808	-----	---	---	---	---	0.844	--	0	-----
FD18RLO4	2	3.847	2.921	0.844	0.738	0.433	0.433	913014	-----	---	---	---	---	0.844	--	0	-----
FD18SP07 US	52	2.599	1.973	0.844	0.772	0.433	0.433	1504026	-----	---	---	---	---	0.844	--	0	-----
FD18SP07 DS	52	2.599	1.973	0.844	0.772	0.433	0.433	1504026	-----	---	---	---	---	0.844	--	0	-----
RK NOZZLE 4C	30	0.008	0.006	0.594	0.594	0.472	0.472	99000000	-----	---	---	---	---	0.594	--	0	-----

==>Grouped by Line: 015-16*-FDW-17, No Sorting.

FD17SP01 US	58	2.029	1.541	1.219	1.163	0.964	0.964	1128945	-----	---	---	---	---	1.219	--	0	-----
FD17SP01 DS	58	2.029	1.541	1.219	1.163	0.964	0.964	1128945	-----	---	---	---	---	1.219	--	0	-----
FD17TE01 (U/S)	15	2.767	2.101	1.219	1.143	0.964	0.964	743024	-----	---	---	---	---	1.219	--	0	-----
FD17TE01 (D/S)	15	2.767	2.101	1.219	1.143	0.964	0.964	743024	-----	---	---	---	---	1.219	--	0	-----
FD17SP02	65	1.845	1.401	1.219	1.168	0.964	0.964	1273666	-----	---	---	---	---	1.219	--	0	-----
FD17SP03	58	2.029	1.541	1.219	1.163	0.964	0.964	1128945	-----	---	---	---	---	1.219	--	0	-----
FD17SP04	58	2.029	1.541	1.219	1.163	0.964	0.964	1128945	-----	---	---	---	---	1.219	--	0	-----
FD17SP05	58	1.785	1.541	1.219	1.193	0.964	0.964	1300083	-----	---	---	---	---	1.219	--	114614	-----
FD17EL01	4	3.413	2.591	1.219	1.125	0.964	0.964	542240	-----	---	---	---	---	1.219	--	0	-----

==>Grouped by Line: 015-16*-FDW-18, No Sorting.

FD18SP01 US	58	1.897	1.440	0.844	0.792	0.645	0.645	891487	-----	---	---	---	---	0.844	--	0	-----	
FD18SP01 DS	58	1.897	1.440	0.844	0.797	0.645	0.645	891487	-----	925801	46.6	73.0	46.6	73.0	0.803	GW	207118	207118
FD18RLO1	2	3.413	2.591	1.219	1.213	0.645	0.645	891487	-----	1919003	83.9	140.0	83.9	140.0	1.223	US	207118	207118
FD18SP02 US	52	2.155	1.636	0.844	0.793	0.645	0.645	891487	-----	789150	53.0	53.0	53.0	53.0	0.799	US	207118	207118
FD18SP02 DS	52	2.155	1.636	0.844	0.785	0.645	0.645	891487	-----	746318	---	---	---	---	0.844	US	207118	207118
FD18EL02	1	3.044	2.311	1.219	1.135	0.645	0.645	1856868	-----	---	---	---	---	1.219	--	0	-----	
FD18SP03 US	51	1.897	1.440	0.844	0.792	0.645	0.645	891487	-----	---	---	---	---	0.844	--	0	-----	
FD18SP03 DS	51	1.897	1.440	0.844	0.792	0.645	0.645	891487	-----	---	---	---	---	0.844	--	0	-----	
FD18TE01 (U/S)	14	3.074	3.852	1.219	1.538	0.645	0.645	891487	-----	2030518	117.9	82.0	117.9	82.0	1.560	US	195618	195618
FD18TE01 (D/S)	14	3.444	2.614	1.219	1.629	0.645	0.645	891487	-----	3296613	80.0	181.0	80.0	181.0	1.644	US	195618	195618
FD18TE01 (BR.)	14	3.639	2.763	0.844	0.744	0.433	0.433	983372	-----	---	---	---	---	0.844	--	0	-----	

==>Grouped by Line: 016-10*-FDW-20, No Sorting.

FD20RDN1 (L/E)	7	2.191	1.664	1.219	1.123	0.645	0.645	2518487	-----	---	---	---	---	1.133	US	195618	195618	
FD20RDN1 (S/E)	7	3.327	2.526	0.844	0.756	0.433	0.433	1116948	-----	---	---	---	---	0.770	MT	195618	195618	
FD20SP01	57	2.599	1.973	0.844	0.716	0.433	0.433	2822808	-----	1252849	60.4	123.0	60.4	123.0	0.727	MT	195618	195618
FD20SP02	9	1.508	1.145	0.844	0.802	0.433	0.433	2822808	-----	---	---	---	---	0.844	--	0	-----	
FD20EL01	2	3.847	2.921	0.844	0.738	0.433	0.433	913014	-----	---	---	---	---	0.844	--	0	-----	
FD20SP03 US	52	2.599	1.973	0.844	0.772	0.433	0.433	1504026	-----	---	---	---	---	0.844	--	0	-----	
FD20SP03 DS	52	2.599	1.973	0.844	0.772	0.433	0.433	1504026	-----	---	---	---	---	0.844	--	0	-----	
FD20EL02	1	3.431	2.605	0.844	0.749	0.433	0.433	1062259	-----	---	---	---	---	0.844	--	0	-----	
FD20SP04	51	2.288	1.737	0.844	0.781	0.433	0.433	1752520	-----	---	---	---	---	0.844	--	0	-----	
FD20SP05	9	1.508	1.145	0.844	0.802	0.433	0.433	2822808	-----	---	---	---	---	0.844	--	0	-----	
FD20EL03	2	3.847	2.921	0.844	0.738	0.433	0.433	913014	-----	---	---	---	---	0.844	--	0	-----	
FD20SP06 US	52	2.599	1.973	0.844	0.772	0.433	0.433	1504026	-----	---	---	---	---	0.844	--	0	-----	
FD20SP06 DS	52	2.599	1.973	0.844	0.772	0.433	0.433	1504026	-----	---	---	---	---	0.844	--	0	-----	
RK NOZZLE 4D	30	0.008	0.006	0.594	0.594	0.472	0.472	99000000	-----	---	---	---	---	0.594	--	0	-----	


Notes:

- (1) Predictions are based on last Tmeas to analysis ending period.
- (2) Predictions are for the time of last inspection (last known meas. wear).
- (3) GW = Tmeas is minimum thickness from Band, Blanket or Area Method of greatest wear.
 MT = Tmeas is component minimum thickness.
 PI = Tmeas is Tinit - predicted wear.
 US = Tmeas is user specified.
- (4) If no Tmeas has been determined from measured data, then Tmeas = Tinit and Time = current component installation time.
 Tmeas is used to determine Predicted Thickness and Component Predicted Time to Tcrit.

118


Cumulative % of Comp. Time to Tcrit

FDW 2006 E1s to Rx



100

Tpred/Tcrit Ratio Plot





Wear Rate Analysis Run Definition

Run Name: Main Steam 2006

Run Title: Main Steam - Reactor Vessel to Turbine

Ending Period: CYCLE 25

Total Oper. Hrs.: 241618.44

Duty Factor: 1.000

Analysis Options:
 Ignore IFA Results
 IFA Results 1st Priority
 User Input 1st Priority
 Do Not Use Measured Wear

Database Lines	Add	Lines to Analyze
001-16"-FDW-01	>	074-18"-MS-01A
002-16"-FDW-02	>>	074-18"-MS-07A
003-16"-FDW-03	>>>	075-18"-MS-01A
004-24"-FDW-01	>>>	076-18"-MS-01B
005-18"-FDW-07	>>>	076-18"-MS-07B
006-18"-FDW-07	>>>	077-18"-MS-01B
007-18"-FDW-12	>>>	078-18"-MS-01C
008-16"-FDW-14	>>>	078-18"-MS-07C

Run Definitions:

- Cond Minimum Flow
- Condensate
- FDW 2006 E1s to Rx
- FDW 2006 Hdr to E2s
- FDW06 2 P1s to Hdr
- FDW06 3-P1s to Hdr
- FDW2006 E2s to E1s
- Feed Pump Recirc
- Feedwater
- Feedwater Flush
- Feedwater Low Flow
- Heater Drain Pumps
- Main Steam 2006**
- Moist Sep High Level
- Moist Separator Drn
- Reactor Cleanup
- Steam Seal Regulator
- TEST- FDWpumpsto E2
- XP Test Feedwater

< Prev
Next >
Add
Reset
Save

Copy
Delete
Print...
Help
Done

Advanced Run Def...

List of Defined Wear Rate Runs

112





Wear-Rate Analysis Run Definition

Run Name: Main Steam 2006

Run Title: Main Steam - Reactor Vessel to Turbine

Ending Period: CYCLE 25

Total Oper. Hrs.: 241618.44

Duty Factor: 1.000

Analysis Options:

- Ignore IFA Results
- IFA Results 1st Priority
- User Input 1st Priority
- Do Not Use Measured Wear

Database Lines	Add	Lines to Analyze
001-16"-FDW-01	>	076-18"-MS-07B
002-16"-FDW-02	>>	077-18"-MS-01B
003-16"-FDW-03	>>>	078-18"-MS-01C
004-24"-FDW-01	>>>>	078-18"-MS-07C
005-18"-FDW-07	>>>>>	079-18"-MS-01C
006-18"-FDW-07	>>>>>>	080-18"-MS-01D
007-18"-FDW-12	>>>>>>>	080-18"-MS-07D
008-16"-FDW-14	>>>>>>>>	081-18"-MS-01D

Run Definitions:


- Cond Minimum Flow
- Condensate
- FDW 2006 E1s to Rx
- FDW 2006 Hdr to E2s
- FDW06 2 P1s to Hdr
- FDW06 3-P1s to Hdr
- FDW2006 E2s to E1s
- Feed Pump Recirc
- Feedwater
- Feedwater Flush
- Feedwater Low Flow
- Heater Drain Pumps
- Main Steam 2006**
- Moist Sep High Level
- Moist Separator Dtn
- Reactor Cleanup
- Steam Seal Regulator
- TEST - FDWpumpsto E2
- XP Test Feedwater

List of Defined Wear Rate Runs

611




Comparison of Thickness Predictions



114

Comparison of Wear Predictions



Company: Vermont Yankee Nuclear Power Corporation Report Date: 13-SEP-2006 Time: 16:20:12
 Plant: Vermont Yankee Analysis Date: 13-SEP-2006 Time: 15:51:16
 Unit: CHECWORKS FAC Version 1.0F (Build 52)
 DS Name: VY

 *** Wear Rate Analysis: Combined Summary Report ***

Run Name: Main Steam 2006
 Ending Period: CYCLE 25
 Total Plant Operating Hours: 241618 Duty Factor (Global): 1.000
 WKA Data Option: Ignore NFA Exclude Measure Wear: No
 Line Correction Factor: 23.841

Component Name	Geom. Code	Average Wear Rate (mils/year)	Current Wear Rate (mils/year)	Thickness (in)			Component Predict(1) Time to Tcrit (hrs)		Total Lifetime Wear (mils) Prd.[2] Meas.	In-Service Cmp. Wear (mils) Prd.[2] Meas.		In-Service Cmp. Tmeas,Method,Time (in)[4] [3] (hrs)[4]			Time(hrs) Last Inspected			
				Init.	Prd.[1]	Thoop	Tcrit	Non-Insp.		Insp.	Prd.[2]	Meas.	(in)[4]	[3]		(hrs)[4]		
==>Grouped by Line: 074-18*-MS-01A, No Sorting.																		
MSIASP12 US	58	2.177	2.504	0.938	0.878	0.726	0.726	532305	-----	---	---	---	0.938	--	0			
MSIASP12 DS	58	2.177	2.504	0.938	0.878	0.726	0.726	532305	-----	---	---	---	0.938	--	0			
MSIAEL07	2	4.555	5.238	0.938	0.812	0.726	0.726	144749	-----	---	---	---	0.938	--	0			
MSIASP13 US	52	3.092	3.556	0.938	0.853	0.726	0.726	312606	-----	---	---	---	0.938	--	0			
MSIASP13 DS	52	3.092	3.556	0.938	0.853	0.726	0.726	312606	-----	---	---	---	0.938	--	0			
MSIAEL08	2	4.555	5.238	0.938	0.812	0.726	0.726	144749	-----	---	---	---	0.938	--	0			
MSIASP14 US	52	3.092	3.556	0.938	0.853	0.726	0.726	312606	-----	---	---	---	0.938	--	0			
==>Grouped by Line: 074-18*-MS-07A, No Sorting.																		
RX NOZZLE N3A	31	7.421	8.534	0.938	0.733	0.726	0.726	7710	-----	---	---	---	0.938	--	0			
MS7ASP01	61	5.343	6.144	0.938	0.791	0.726	0.726	92438	-----	---	---	---	0.938	--	0			
MS7AEL01	3	4.442	5.109	0.938	0.815	0.726	0.726	153769	-----	---	---	---	0.938	--	0			
MS7ASP02	53	3.710	4.267	0.938	0.836	0.726	0.726	225517	-----	---	---	---	0.938	--	0			
MS7AEL02	1	4.188	4.817	0.938	0.822	0.726	0.726	175822	-----	---	---	---	0.938	--	0			
MS7ASP03	51	2.721	3.129	0.938	0.863	0.726	0.726	383883	-----	---	---	---	0.938	--	0			
MS7ASP04	9	1.432	1.647	0.938	0.899	0.726	0.726	918655	-----	---	---	---	0.938	--	0			
MS7AEL03	1	3.901	4.486	0.938	0.830	0.726	0.726	204277	-----	---	---	---	0.938	--	0			
MS7ASP05 US	51	2.721	3.129	0.938	0.863	0.726	0.726	383883	-----	---	---	---	0.938	--	0			
MS7ASP05 DS	51	2.721	3.129	0.938	0.863	0.726	0.726	383883	-----	---	---	---	0.938	--	0			
MS7AEL04	2	4.555	5.238	0.938	0.812	0.726	0.726	144749	-----	---	---	---	0.938	--	0			
MS7ASP06	52	3.092	3.556	0.938	0.853	0.726	0.726	312606	-----	---	---	---	0.938	--	0			
MS7ASP07	9	1.432	1.647	0.938	0.899	0.726	0.726	918655	-----	---	---	---	0.938	--	0			
MS7AEL05	2	4.555	5.238	0.938	0.812	0.726	0.726	144749	-----	---	---	---	0.938	--	0			
MS7ASP08	52	3.092	3.556	0.938	0.853	0.726	0.726	312606	-----	---	---	---	0.938	--	0			
MS7AEL06	6	0.031	0.036	0.938	0.937	0.814	0.814	30037228	-----	---	---	---	0.938	--	0			
MS7ASP09	56	2.139	2.460	0.938	0.859	0.726	0.726	-----	-----	473077	32.7	53.0	32.7	51.0	0.885	US	137270	137270
MS7AEL06	4	4.555	5.238	0.938	0.898	0.726	0.726	-----	-----	287886	69.6	80.0	69.6	80.0	0.954	US	137270	137270
MS7ASP10	54	4.749	5.462	0.938	0.807	0.726	0.726	130227	-----	---	---	---	0.938	--	0			
MS7AVA01	22	5.443	6.259	0.938	0.788	0.776	0.776	16821	-----	---	---	---	0.938	--	0			
MS7ASP11 US	58	2.177	2.504	0.938	0.878	0.726	0.726	532305	-----	---	---	---	0.938	--	0			
MS7ASP11 DS	58	2.177	2.504	0.938	0.878	0.726	0.726	532305	-----	---	---	---	0.938	--	0			
MS7AVA02	22	5.443	6.259	0.938	0.788	0.776	0.776	16821	-----	---	---	---	0.938	--	0			
==>Grouped by Line: 075-18*-MS-01A, No Sorting.																		
MSIASP14 DS	52	3.092	3.556	0.938	0.853	0.726	0.726	312606	-----	---	---	---	0.938	--	0			
MSIAEL09	2	3.547	4.079	0.938	0.840	0.726	0.726	245599	-----	---	---	---	0.938	--	0			
MSIASP15	52	3.092	3.556	0.938	0.853	0.726	0.726	312606	-----	---	---	---	0.938	--	0			
MSIASP16	9	1.432	1.647	0.938	0.899	0.726	0.726	918655	-----	---	---	---	0.938	--	0			
MSIAEL10	2	3.547	4.079	0.938	0.840	0.726	0.726	245599	-----	---	---	---	0.938	--	0			
MSIASP17	52	3.092	3.556	0.938	0.853	0.726	0.726	312606	-----	---	---	---	0.938	--	0			
MSIASP18	9	1.432	1.647	0.938	0.899	0.726	0.726	918655	-----	---	---	---	0.938	--	0			
MSIAEL11	2	3.547	4.079	0.938	0.840	0.726	0.726	245599	-----	---	---	---	0.938	--	0			
MSIASP19 US	52	3.092	3.556	0.938	0.853	0.726	0.726	312606	-----	---	---	---	0.938	--	0			
MSIASP19 DS	52	3.092	3.556	0.938	0.853	0.726	0.726	312606	-----	---	---	---	0.938	--	0			
MSIATED1(U S)	15	3.711	4.267	0.938	0.836	0.726	0.726	225488	-----	---	---	---	0.938	--	0			
MSIATED1(D/S)	15	3.266	3.756	0.938	0.848	0.726	0.726	284860	-----	---	---	---	0.938	--	0			
MSIASP19A	65	3.661	4.210	0.938	0.837	0.726	0.726	231432	-----	---	---	---	0.938	--	0			
MS1AVA03	20	3.712	4.269	0.938	0.836	0.776	0.776	122646	-----	---	---	---	0.938	--	0			
MS1AVA04	22	4.759	5.474	1.031	0.900	0.862	0.862	80263	-----	---	---	---	1.031	--	0			
MSIASP20	58	1.904	2.190	1.031	0.978	0.806	0.806	688291	-----	---	---	---	1.031	--	0			

116

MS1AEL12	2	3.102	3.567	1.031	0.945	0.806	0.806	341346	-----	---	---	---	---	1.031	--	0	-----
MS1ASP21 US	52	2.704	3.110	1.031	0.956	0.806	0.806	422431	-----	---	---	---	---	1.031	--	0	-----
MS1AMP21 DS	52	2.704	3.110	1.031	0.956	0.806	0.806	422431	-----	---	---	---	---	1.031	--	0	-----
MS1AEL13	1	2.677	3.079	1.031	0.957	0.806	0.806	428784	-----	---	---	---	---	1.031	--	0	-----
MS1ASP22 US	51	2.380	2.737	1.031	0.965	0.806	0.806	508685	-----	---	---	---	---	1.031	--	0	-----
MS1ASP22 DS	51	2.380	2.737	1.031	0.965	0.806	0.806	508685	-----	---	---	---	---	1.031	--	0	-----
MS1AEL14	1	2.677	3.079	1.031	0.957	0.806	0.806	428784	-----	---	---	---	---	1.031	--	0	-----
MS1ASP23 US	51	2.380	2.737	1.031	0.965	0.806	0.806	508685	-----	---	---	---	---	1.031	--	0	-----
MS1ASP23 DS	9	1.174	1.351	1.031	0.999	0.806	0.806	1246356	-----	---	---	---	---	1.031	--	0	-----
MS1AEL15	2	3.983	4.581	1.031	0.921	0.806	0.806	219306	-----	---	---	---	---	1.031	--	0	-----
INLET HP TURB	30	4.327	4.976	1.031	0.912	0.806	0.806	185233	-----	---	---	---	---	1.031	--	0	-----

===>Grouped by Line: 076-18*-MS-01B, No Sorting.

MS1BSP11 US	58	2.177	2.504	0.938	0.878	0.726	0.726	532305	-----	---	---	---	---	0.938	--	0	-----
MS1BSP11 DS	58	2.177	2.504	0.938	0.878	0.726	0.726	532305	-----	---	---	---	---	0.938	--	0	-----
MS1BEL07	2	4.555	5.238	0.938	0.812	0.726	0.726	144749	-----	---	---	---	---	0.938	--	0	-----
MS1BSP12 US	52	3.092	3.556	0.938	0.853	0.726	0.726	312606	-----	---	---	---	---	0.938	--	0	-----
MS1BSP12 DS	52	3.092	3.556	0.938	0.853	0.726	0.726	312606	-----	---	---	---	---	0.938	--	0	-----
MS1BEL08	2	4.555	5.238	0.938	0.812	0.726	0.726	144749	-----	---	---	---	---	0.938	--	0	-----
MS1BSP13	52	3.092	3.556	0.938	0.853	0.726	0.726	312606	-----	---	---	---	---	0.938	--	0	-----

===>Grouped by Line: 076-18*-MS-07B, No Sorting.

RX NOZZLE N3B	31	7.421	8.534	0.938	0.753	0.726	0.726	7710	-----	---	---	---	---	0.938	--	0	-----
MS7BSP01	61	5.343	6.144	0.938	0.791	0.726	0.726	92438	-----	---	---	---	---	0.938	--	0	-----
MS7BEL01	3	4.442	5.109	0.938	0.815	0.726	0.726	153769	-----	---	---	---	---	0.938	--	0	-----
MS7BSP02	53	3.710	4.267	0.938	0.836	0.726	0.726	225517	-----	---	---	---	---	0.938	--	0	-----
MS7BEL02	1	4.188	4.817	0.938	0.822	0.726	0.726	175822	-----	---	---	---	---	0.938	--	0	-----
MS7BSP03	51	2.721	3.129	0.938	0.863	0.726	0.726	383883	-----	---	---	---	---	0.938	--	0	-----
MS7BSP04	9	1.432	1.647	0.938	0.899	0.726	0.726	918655	-----	---	---	---	---	0.938	--	0	-----
MS7BEL03	2	4.555	5.238	0.938	0.812	0.726	0.726	144749	-----	---	---	---	---	0.938	--	0	-----
MS7BSP05 US	52	3.092	3.556	0.938	0.853	0.726	0.726	312606	-----	---	---	---	---	0.938	--	0	-----
MS7BSP05 DS	52	3.092	3.556	0.938	0.853	0.726	0.726	312606	-----	---	---	---	---	0.938	--	0	-----
MS7BEL04	2	4.555	5.238	0.938	0.812	0.726	0.726	144749	-----	---	---	---	---	0.938	--	0	-----
MS7BSP06	52	3.092	3.556	0.938	0.853	0.726	0.726	312606	-----	---	---	---	---	0.938	--	0	-----
MS7BSP07	6	0.031	0.036	0.938	0.937	0.814	0.814	30037228	-----	---	---	---	---	0.938	--	0	-----
MS7BSP07	56	2.139	2.460	0.938	0.879	0.726	0.726	545399	-----	---	---	---	---	0.938	--	0	-----
MS7BEL05	4	4.555	5.238	0.938	0.812	0.726	0.726	144749	-----	---	---	---	---	0.938	--	0	-----
MS7BSP08 US	54	4.749	5.462	0.938	0.807	0.726	0.726	130227	-----	---	---	---	---	0.938	--	0	-----
MS7BSP08 DS	54	4.749	5.462	0.938	0.807	0.726	0.726	130227	-----	---	---	---	---	0.938	--	0	-----
MS7BEL06	1	3.901	4.486	0.938	0.830	0.726	0.726	204277	-----	---	---	---	---	0.938	--	0	-----
MS7BSP09	51	2.721	3.129	0.938	0.863	0.726	0.726	383883	-----	---	---	---	---	0.938	--	0	-----
MS7BVA01	22	5.443	6.259	0.938	0.788	0.776	0.776	16821	-----	---	---	---	---	0.938	--	0	-----
MS7BSP10 US	58	2.177	2.504	0.938	0.878	0.726	0.726	532305	-----	---	---	---	---	0.938	--	0	-----
MS7BSP10 DS	58	2.177	2.504	0.938	0.878	0.726	0.726	532305	-----	---	---	---	---	0.938	--	0	-----
MS7BVA02	22	5.443	6.259	0.938	0.788	0.776	0.776	16821	-----	---	---	---	---	0.938	--	0	-----

===>Grouped by Line: 077-18*-MS-01B, No Sorting.

MS1BSP14	52	3.092	3.556	0.938	0.853	0.726	0.726	312606	-----	---	---	---	---	0.938	--	0	-----
MS1BEL09	2	3.547	4.079	0.938	0.840	0.726	0.726	245599	-----	---	---	---	---	0.938	--	0	-----
MS1BSP15	52	3.092	3.556	0.938	0.853	0.726	0.726	312606	-----	---	---	---	---	0.938	--	0	-----
MS1BSP16	9	1.432	1.647	0.938	0.899	0.726	0.726	918655	-----	---	---	---	---	0.938	--	0	-----
MS1EEL10	2	3.547	4.079	0.938	0.840	0.726	0.726	245599	-----	---	---	---	---	0.938	--	0	-----
MS1BSP17	52	3.092	3.556	0.938	0.853	0.726	0.726	312606	-----	---	---	---	---	0.938	--	0	-----
MS1BSP18	9	1.432	1.647	0.938	0.899	0.726	0.726	918655	-----	---	---	---	---	0.938	--	0	-----
MS1BEL11	2	3.547	4.079	0.938	0.840	0.726	0.726	245599	-----	---	---	---	---	0.938	--	0	-----
MS1BSP19 US	52	3.092	3.556	0.938	0.853	0.726	0.726	312606	-----	---	---	---	---	0.938	--	0	-----
MS1BSP19 DS	52	3.092	3.556	0.938	0.853	0.726	0.726	312606	-----	---	---	---	---	0.938	--	0	-----
MS1BTE01 (U/S)	15	3.711	4.267	0.938	0.836	0.726	0.726	225488	-----	---	---	---	---	0.938	--	0	-----
MS1BTE01 (D/S)	15	3.266	3.756	0.938	0.848	0.726	0.726	284860	-----	---	---	---	---	0.938	--	0	-----
MS1BSP19A	65	3.661	4.210	0.938	0.837	0.726	0.726	231432	-----	---	---	---	---	0.938	--	0	-----
MS1BVA03	20	3.712	4.269	0.938	0.836	0.776	0.776	122646	-----	---	---	---	---	0.938	--	0	-----
MS1BVA04	22	4.759	5.474	1.031	0.900	0.862	0.862	60263	-----	---	---	---	---	1.031	--	0	-----
MS1BSP20	58	1.904	2.190	1.031	0.978	0.806	0.806	688291	-----	---	---	---	---	1.031	--	0	-----
MS1DEL12	2	3.102	3.567	1.031	0.945	0.806	0.806	341346	-----	---	---	---	---	1.031	--	0	-----
MS1BSP21 US	52	2.704	3.110	1.031	0.956	0.806	0.806	422431	-----	---	---	---	---	1.031	--	0	-----
MS1BSP21 DS	52	2.704	3.110	1.031	0.956	0.806	0.806	422431	-----	---	---	---	---	1.031	--	0	-----
MS1BEL13	1	2.677	3.079	1.031	0.957	0.806	0.806	428784	-----	---	---	---	---	1.031	--	0	-----
MS1BSP22 US	51	2.380	2.737	1.031	0.965	0.806	0.806	508685	-----	---	---	---	---	1.031	--	0	-----
MS1BSP22 DS	51	2.380	2.737	1.031	0.965	0.806	0.806	508685	-----	---	---	---	---	1.031	--	0	-----
MS1BEL14	1	2.677	3.079	1.031	0.957	0.806	0.806	428784	-----	---	---	---	---	1.031	--	0	-----

117

MS1SP23 US	51	2.380	2.737	1.031	0.965	0.806	0.806	508685	-----	---	---	---	---	1.031	---	0	-----
MS1SP23 DS	51	2.380	2.737	1.031	0.965	0.806	0.806	508685	-----	---	---	---	---	1.031	---	0	-----
INLET HP TURB	30	4.327	4.976	1.031	0.912	0.806	0.806	185233	-----	---	---	---	---	1.031	---	0	-----

===>Grouped by Line: 078-18*-MS-01C, No Sorting.

MS1CSP11 US	58	3.177	2.504	0.938	0.878	0.726	0.726	532305	-----	---	---	---	---	0.938	---	0	-----
MS1CSP11 DS	58	2.177	2.504	0.938	0.878	0.726	0.726	532305	-----	---	---	---	---	0.938	---	0	-----
MS1CEL07	2	4.555	5.238	0.938	0.812	0.726	0.726	144749	-----	---	---	---	---	0.938	---	0	-----
MS1CSP12 US	52	3.092	3.556	0.938	0.853	0.726	0.726	312606	-----	---	---	---	---	0.938	---	0	-----
MS1CSP12 DS	52	3.092	3.556	0.938	0.853	0.726	0.726	312606	-----	---	---	---	---	0.938	---	0	-----
MS1CEL08	2	4.555	5.238	0.938	0.812	0.726	0.726	144749	-----	---	---	---	---	0.938	---	0	-----
MS1CSP13	52	3.092	3.556	0.938	0.853	0.726	0.726	312606	-----	---	---	---	---	0.938	---	0	-----

===>Grouped by Line: 078-18*-MS-07C, No Sorting.

KX NOZZLE N3C	51	7.421	8.534	0.938	0.733	0.726	0.726	7710	-----	---	---	---	---	0.938	---	0	-----
MS7CSP01	61	5.343	6.144	0.938	0.791	0.726	0.726	92438	-----	---	---	---	---	0.938	---	0	-----
MS7CEL01	3	4.442	5.109	0.938	0.815	0.726	0.726	153769	-----	---	---	---	---	0.938	---	0	-----
MS7CSP02	53	3.710	4.267	0.938	0.636	0.726	0.726	225517	-----	---	---	---	---	0.938	---	0	-----
MS7CEL02	1	4.188	4.817	0.938	0.822	0.726	0.726	175822	-----	---	---	---	---	0.938	---	0	-----
MS7CSP03	51	2.721	3.129	0.938	0.863	0.726	0.726	383883	-----	---	---	---	---	0.938	---	0	-----
MS7CSP04	9	1.432	1.647	0.938	0.899	0.726	0.726	918655	-----	---	---	---	---	0.938	---	0	-----
MS7CEL03	2	4.555	5.238	0.938	0.812	0.726	0.726	144749	-----	---	---	---	---	0.938	---	0	-----
MS7CSP05 US	52	3.092	3.556	0.938	0.853	0.726	0.726	312606	-----	---	---	---	---	0.938	---	0	-----
MS7CSP05 DS	52	3.092	3.556	0.938	0.853	0.726	0.726	312606	-----	---	---	---	---	0.938	---	0	-----
MS7CEL04	2	4.555	5.238	0.938	0.812	0.726	0.726	144749	-----	---	---	---	---	0.938	---	0	-----
MS7CSP06	52	3.092	3.556	0.938	0.853	0.726	0.726	312606	-----	---	---	---	---	0.938	---	0	-----
MS7CSP07	6	0.031	0.036	0.938	0.937	0.814	0.814	30037228	-----	---	---	---	---	0.938	---	0	-----
MS7CSP08	56	2.139	2.460	0.938	0.879	0.726	0.726	545399	-----	---	---	---	---	0.938	---	0	-----
MS7CEL05	4	4.555	5.238	0.938	0.812	0.726	0.726	144749	-----	---	---	---	---	0.938	---	0	-----
MS7CSP08 US	54	4.749	5.462	0.938	0.807	0.726	0.726	130227	-----	---	---	---	---	0.938	---	0	-----
MS7CSP08 DS	54	4.749	5.462	0.938	0.807	0.726	0.726	130227	-----	---	---	---	---	0.938	---	0	-----
MS7CEL06	1	3.901	4.486	0.938	0.830	0.726	0.726	204277	-----	---	---	---	---	0.938	---	0	-----
MS7CSP09	51	2.721	3.129	0.938	0.863	0.726	0.726	383883	-----	---	---	---	---	0.938	---	0	-----
MS7CVA01	22	5.443	6.259	0.938	0.788	0.776	0.776	16821	-----	---	---	---	---	0.938	---	0	-----
MS7CSP10 US	58	2.177	2.504	0.938	0.878	0.726	0.726	532305	-----	---	---	---	---	0.938	---	0	-----
MS7CSP10 DS	58	2.177	2.504	0.938	0.878	0.726	0.726	532305	-----	---	---	---	---	0.938	---	0	-----
MS7CVA02	22	5.443	6.259	0.938	0.788	0.776	0.776	16821	-----	---	---	---	---	0.938	---	0	-----

===>Grouped by Line: 079-18*-MS-01C, No Sorting.

MS1CSP14	52	3.092	3.556	0.938	0.853	0.726	0.726	312606	-----	---	---	---	---	0.938	---	0	-----
MS1CEL09	2	3.547	4.079	0.938	0.840	0.726	0.726	245599	-----	---	---	---	---	0.938	---	0	-----
MS1CSP15	52	3.092	3.556	0.938	0.853	0.726	0.726	312606	-----	---	---	---	---	0.938	---	0	-----
MS1CSP16	9	1.432	1.647	0.938	0.899	0.726	0.726	918655	-----	---	---	---	---	0.938	---	0	-----
MS1CEL10	2	3.547	4.079	0.938	0.840	0.726	0.726	245599	-----	---	---	---	---	0.938	---	0	-----
MS1CSP17	52	3.092	3.556	0.938	0.853	0.726	0.726	312606	-----	---	---	---	---	0.938	---	0	-----
MS1CSP18	9	1.432	1.647	0.938	0.899	0.726	0.726	918655	-----	---	---	---	---	0.938	---	0	-----
MS1CEL11	2	3.547	4.079	0.938	0.840	0.726	0.726	245599	-----	---	---	---	---	0.938	---	0	-----
MS1CSP19 US	52	3.092	3.556	0.938	0.853	0.726	0.726	312606	-----	---	---	---	---	0.938	---	0	-----
MS1CSP19 DS	52	3.092	3.556	0.938	0.853	0.726	0.726	312606	-----	---	---	---	---	0.938	---	0	-----
MS1CTE01 (U/S)	15	3.711	4.267	0.938	0.836	0.726	0.726	225488	-----	---	---	---	---	0.938	---	0	-----
MS1CTE01 (D/S)	15	3.266	3.756	0.938	0.848	0.726	0.726	284860	-----	---	---	---	---	0.938	---	0	-----
MS1CSP19A	65	3.661	4.210	0.938	0.837	0.726	0.726	231432	-----	---	---	---	---	0.938	---	0	-----
MS1CVA03	20	3.712	4.269	0.938	0.836	0.776	0.776	122646	-----	---	---	---	---	0.938	---	0	-----
MS1CVA04	22	4.759	5.474	1.031	0.900	0.862	0.862	60263	-----	---	---	---	---	1.031	---	0	-----
MS1CSP20	58	1.904	2.190	1.031	0.978	0.806	0.806	688291	-----	---	---	---	---	1.031	---	0	-----
MS1CEL12	2	3.102	3.567	1.031	0.945	0.806	0.806	341346	-----	---	---	---	---	1.031	---	0	-----
MS1CSP21 US	52	2.704	3.110	1.031	0.956	0.806	0.806	422431	-----	---	---	---	---	1.031	---	0	-----
MS1CSP21 DS	52	2.704	3.110	1.031	0.956	0.806	0.806	422431	-----	---	---	---	---	1.031	---	0	-----
MS1BEL13	1	2.677	3.079	1.031	0.957	0.806	0.806	428784	-----	---	---	---	---	1.031	---	0	-----
MS1CSP22 US	51	2.380	2.737	1.031	0.965	0.806	0.806	508685	-----	---	---	---	---	1.031	---	0	-----
MS1CSP22 DS	51	2.380	2.737	1.031	0.965	0.806	0.806	508685	-----	---	---	---	---	1.031	---	0	-----
MS1CEL14	1	2.677	3.079	1.031	0.957	0.806	0.806	428784	-----	---	---	---	---	1.031	---	0	-----
MS1CSP23 US	51	2.380	2.737	1.031	0.965	0.806	0.806	508685	-----	---	---	---	---	1.031	---	0	-----
MS1CSP23 DS	51	2.380	2.737	1.031	0.965	0.806	0.806	508685	-----	---	---	---	---	1.031	---	0	-----
INLET HP TURB	30	4.327	4.976	1.031	0.912	0.806	0.806	185233	-----	---	---	---	---	1.031	---	0	-----

===>Grouped by Line: 080-18*-MS-01D, No Sorting.

MS1DSP12 US	58	2.177	2.504	0.938	0.878	0.726	0.726	532305	-----	---	---	---	---	0.938	---	0	-----
MS1DSP12 DS	58	2.177	2.504	0.938	0.845	0.726	0.726	-----	416019	56.8	18.0	56.8	18.0	0.848	MT	230119	230118

118

MS1DEL07	2	4.555	5.238	0.938	0.967	0.726	0.726	-----	403549	118.8	101.0	118.8	101.0	0.974	MT	230118	230118
MS1DSP13 US	52	3.092	3.556	0.938	0.853	0.726	0.726	312606	-----	---	---	---	---	0.938	--	0	-----
MS1DSP13 DS	52	3.092	3.556	0.938	0.853	0.726	0.726	312606	-----	---	---	---	---	0.938	--	0	-----
MS1DEL08	2	4.555	5.238	0.938	0.812	0.726	0.726	144749	-----	---	---	---	---	0.938	--	0	-----
MS1DSP14 US	52	3.092	3.556	0.938	0.853	0.726	0.726	312606	-----	---	---	---	---	0.938	--	0	-----

==>Grouped by Line: 080-18*-MS-07D, No Sorting.

PK NOBLE N3D	31	7.421	8.534	0.938	0.733	0.726	0.726	7710	-----	---	---	---	---	0.938	--	0	-----
MS7DSP01	61	5.343	6.144	0.938	0.791	0.726	0.726	9243R	-----	---	---	---	---	0.938	--	0	-----
MS7DEL01	3	4.442	5.109	0.938	0.815	0.726	0.726	153769	-----	---	---	---	---	0.938	--	0	-----
MS7DSP02	53	3.710	4.267	0.938	0.836	0.726	0.726	225517	-----	---	---	---	---	0.938	--	0	-----
MS7DEL02	1	4.188	4.817	0.938	0.822	0.726	0.726	175822	-----	---	---	---	---	0.938	--	0	-----
MS7DSP03	51	2.721	3.129	0.938	0.863	0.726	0.726	383883	-----	---	---	---	---	0.938	--	0	-----
MS7DSP04	9	1.432	1.647	0.938	0.899	0.726	0.726	918655	-----	---	---	---	---	0.938	--	0	-----
MS7DEL03	1	1.901	4.486	0.938	0.830	0.726	0.726	204277	-----	---	---	---	---	0.938	--	0	-----
MS7DSP05 US	51	2.721	3.129	0.938	0.863	0.726	0.726	383883	-----	---	---	---	---	0.938	--	0	-----
MS7DSP05 DS	51	2.721	3.129	0.938	0.863	0.726	0.726	383883	-----	---	---	---	---	0.938	--	0	-----
MS7DEL04	2	4.555	5.238	0.938	0.812	0.726	0.726	144749	-----	---	---	---	---	0.938	--	0	-----
MS7DSP06	52	3.092	3.556	0.938	0.853	0.726	0.726	312606	-----	---	---	---	---	0.938	--	0	-----
MS7DSP07	9	1.432	1.647	0.938	0.899	0.726	0.726	918655	-----	---	---	---	---	0.938	--	0	-----
MS7DEL05	2	4.555	5.238	0.938	0.812	0.726	0.726	144749	-----	---	---	---	---	0.938	--	0	-----
MS7DSP08	52	3.092	3.556	0.938	0.853	0.726	0.726	312606	-----	---	---	---	---	0.938	--	0	-----
MS7DFE01	6	0.031	0.036	0.938	0.937	0.814	0.814	30037228	-----	---	---	---	---	0.938	--	0	-----
MS7DSP09	56	2.139	2.460	0.938	0.879	0.726	0.726	545399	-----	---	---	---	---	0.938	--	0	-----
MS7DEL06	4	4.555	5.238	0.938	0.812	0.726	0.726	144749	-----	---	---	---	---	0.938	--	0	-----
MS7DSP10	54	4.749	5.462	0.938	0.807	0.726	0.726	130227	-----	---	---	---	---	0.938	--	0	-----
MS7DVA01	22	5.443	6.259	0.938	0.788	0.776	0.776	16821	-----	---	---	---	---	0.938	--	0	-----
MS7DSP11 US	58	2.177	2.504	0.938	0.878	0.726	0.726	532305	-----	---	---	---	---	0.938	--	0	-----
MS7DSP11 DS	58	2.177	2.504	0.938	0.878	0.726	0.726	532305	-----	---	---	---	---	0.938	--	0	-----
MS7DVA02	22	5.443	6.259	0.938	0.788	0.776	0.776	16821	-----	---	---	---	---	0.938	--	0	-----

==>Grouped by Line: 081-18*-MS-01D, No Sorting.

MS1DSP14 DS	52	3.092	3.556	0.938	0.853	0.726	0.726	312606	-----	---	---	---	---	0.938	--	0	-----
MS1DEL09	2	3.547	4.079	0.938	0.840	0.726	0.726	245599	-----	---	---	---	---	0.938	--	0	-----
MS1DSP15	52	3.092	3.556	0.938	0.853	0.726	0.726	312606	-----	---	---	---	---	0.938	--	0	-----
MS1DSP16	9	1.432	1.647	0.938	0.899	0.726	0.726	918655	-----	---	---	---	---	0.938	--	0	-----
MS1DEL10	2	3.547	4.079	0.938	0.840	0.726	0.726	245599	-----	---	---	---	---	0.938	--	0	-----
MS1DSP17	52	3.092	3.556	0.938	0.853	0.726	0.726	312606	-----	---	---	---	---	0.938	--	0	-----
MS1DSP18	9	1.432	1.647	0.938	0.899	0.726	0.726	918655	-----	---	---	---	---	0.938	--	0	-----
MS1DEL11	2	3.547	4.079	0.938	0.840	0.726	0.726	245599	-----	---	---	---	---	0.938	--	0	-----
MS1DSP19 US	52	3.092	3.556	0.938	0.853	0.726	0.726	312606	-----	---	---	---	---	0.938	--	0	-----
MS1DSP19 DS	52	3.092	3.556	0.938	0.853	0.726	0.726	312606	-----	---	---	---	---	0.938	--	0	-----
MS1DTE01 (U/S)	15	3.711	4.267	0.938	0.836	0.726	0.726	225488	-----	---	---	---	---	0.938	--	0	-----
MS1DTE01 (D/S)	15	3.266	3.756	0.938	0.848	0.726	0.726	284860	-----	---	---	---	---	0.938	--	0	-----
MS1DSP19A	65	3.661	4.210	0.938	0.837	0.726	0.726	231432	-----	---	---	---	---	0.938	--	0	-----
MS1DVA03	20	3.712	4.269	0.938	0.836	0.776	0.776	122646	-----	---	---	---	---	0.938	--	0	-----
MS1DVA04	22	4.759	5.474	1.031	0.900	0.862	0.862	60263	-----	---	---	---	---	1.031	--	0	-----
MS1DSP20	58	1.904	2.190	1.031	0.978	0.806	0.806	688291	-----	---	---	---	---	1.031	--	0	-----
MS1DEL12	2	3.102	3.567	1.031	0.945	0.806	0.806	341346	-----	---	---	---	---	1.031	--	0	-----
MS1DSP21 US	52	2.704	3.110	1.031	0.956	0.806	0.806	422431	-----	---	---	---	---	1.031	--	0	-----
MS1DSP21 DS	52	2.704	3.110	1.031	0.956	0.806	0.806	422431	-----	---	---	---	---	1.031	--	0	-----
MS1DEL13	1	2.677	3.079	1.031	0.957	0.806	0.806	428784	-----	---	---	---	---	1.031	--	0	-----
MS1DSP22 US	51	2.380	2.737	1.031	0.965	0.806	0.806	508685	-----	---	---	---	---	1.031	--	0	-----
MS1DSP22 DS	51	2.380	2.737	1.031	0.965	0.806	0.806	508685	-----	---	---	---	---	1.031	--	0	-----
MS1DEL14	1	2.677	3.079	1.031	0.957	0.806	0.806	428784	-----	---	---	---	---	1.031	--	0	-----
MS1DSP23 US	51	2.380	2.737	1.031	0.965	0.806	0.806	508685	-----	---	---	---	---	1.031	--	0	-----
MS1DSP23 DS	51	2.380	2.737	1.031	0.965	0.806	0.806	508685	-----	---	---	---	---	1.031	--	0	-----
MS1DEL15	2	3.983	4.581	1.031	0.921	0.806	0.806	219306	-----	---	---	---	---	1.031	--	0	-----
INLET HP TURB	30	4.327	4.976	1.031	0.912	0.806	0.806	185233	-----	---	---	---	---	1.031	--	0	-----


Notes:

- (1) Predictions are based on last Tmeas to analysis ending period.
- (2) Predictions are for the time of last inspection (last known meas. wear).
- (3) CW = Tmeas is minimum thickness from Band, Blanket or Area Method of greatest wear.
 MT = Tmeas is component minimum thickness.
 PW = Tmeas is Tinit - predicted wear.
 US = Tmeas is user specified.
- (4) If no Tmeas has been determined from measured data, then Tmeas = Tinit and Time = current component installation time.
 Tmeas is used to determine Predicted Thickness and Component Predicted Time to Tcrit.


619

Cumulative % of Comp. Time to Tcrit

Main Steam 2006



Tpred/Tcrit Ratio Plot



 *** Wear Rate Analysis: Combined Summary Report ***

Run Name: Main Steam 2006
 Ending Period: CYCLE 25
 Total Plant Operating Hours: 241618 Duty Factor (Global): 1.000
 WRA Data Option: Ignore NFA Exclude Measure Wear: No
 Line Correction Factor: 23.841

Component Name	Geom. Code	Average Wear Rate (mils/year)	Current Wear Rate (mils/year)	Thickness (in)			Component Predicted Time to Tcrit (hr)	
				Init.	Prd.[1]	Thoop	Tcrit	Non-Insp.

==>Grouped by Line: 074-18"-MS-01A, No Sorting.

MS1ASP12 US	58	2.177	2.504	0.938	0.878	0.726	0.726	532305	--
MS1ASP12 DS	58	2.177	2.504	0.938	0.878	0.726	0.726	532305	--
MS1AEL07	2	4.555	5.238	0.938	0.812	0.726	0.726	144749	--
MS1ASP13 US	52	3.092	3.556	0.938	0.853	0.726	0.726	312606	--
MS1ASP13 DS	52	3.092	3.556	0.938	0.853	0.726	0.726	312606	--
MS1AEL08	2	4.555	5.238	0.938	0.812	0.726	0.726	144749	--
MS1ASP14 US	52	3.092	3.556	0.938	0.853	0.726	0.726	312606	--

==>Grouped by Line: 074-18"-MS-07A, No Sorting.

RX NOZZLE N3A	31	7.421	8.534	0.938	0.733	0.726	0.726	7710	--
MS7ASP01	61	5.343	6.144	0.938	0.791	0.726	0.726	92438	--
MS7AEL01	3	4.442	5.109	0.938	0.815	0.726	0.726	153769	--
MS7ASP02	53	3.710	4.267	0.938	0.836	0.726	0.726	225517	--
MS7AEL02	1	4.188	4.817	0.938	0.822	0.726	0.726	175822	--
MS7ASP03	51	2.721	3.129	0.938	0.863	0.726	0.726	383883	--
MS7ASP04	9	1.432	1.647	0.938	0.899	0.726	0.726	918655	--
MS7AEL03	1	3.901	4.486	0.938	0.830	0.726	0.726	204277	--
MS7ASP05 US	51	2.721	3.129	0.938	0.863	0.726	0.726	383883	--
MS7ASP05 DS	51	2.721	3.129	0.938	0.863	0.726	0.726	383883	--
MS7AEL04	2	4.555	5.238	0.938	0.812	0.726	0.726	144749	--
MS7ASP06	52	3.092	3.556	0.938	0.853	0.726	0.726	312606	--
MS7ASP07	9	1.432	1.647	0.938	0.899	0.726	0.726	918655	--
MS7AEL05	2	4.555	5.238	0.938	0.812	0.726	0.726	144749	--
MS7ASP08	52	3.092	3.556	0.938	0.853	0.726	0.726	312606	--
MS7AFE01	6	0.031	0.036	0.938	0.937	0.814	0.814	30037228	--
MS7ASP09	56	2.139	2.460	0.938	0.859	0.726	0.726	-----	4'
MS7AEL06	4	4.555	5.238	0.938	0.898	0.726	0.726	-----	2'
MS7ASP10	54	4.749	5.462	0.938	0.807	0.726	0.726	130227	--
MS7AVA01	22	5.443	6.259	0.938	0.788	0.776	0.776	16821	--
MS7ASP11 US	58	2.177	2.504	0.938	0.878	0.726	0.726	532305	--
MS7ASP11 DS	58	2.177	2.504	0.938	0.878	0.726	0.726	532305	--
MS7AVA02	22	5.443	6.259	0.938	0.788	0.776	0.776	16821	--

==>Grouped by Line: 075-18"-MS-01A, No Sorting.

MS1ASP14 DS	52	3.092	3.556	0.938	0.853	0.726	0.726	312606	--
MS1AEL09	2	3.547	4.079	0.938	0.840	0.726	0.726	245599	--
MS1ASP15	52	3.092	3.556	0.938	0.853	0.726	0.726	312606	--
MS1ASP16	9	1.432	1.647	0.938	0.899	0.726	0.726	918655	--
MS1AEL10	2	3.547	4.079	0.938	0.840	0.726	0.726	245599	--
MS1ASP17	52	3.092	3.556	0.938	0.853	0.726	0.726	312606	--
MS1ASP18	9	1.432	1.647	0.938	0.899	0.726	0.726	918655	--
MS1AEL11	2	3.547	4.079	0.938	0.840	0.726	0.726	245599	--
MS1ASP19 US	52	3.092	3.556	0.938	0.853	0.726	0.726	312606	--
MS1ASP19 DS	52	3.092	3.556	0.938	0.853	0.726	0.726	312606	--
MS1ATE01 (U/S)	15	3.711	4.267	0.938	0.836	0.726	0.726	225488	--
MS1ATE01 (D/S)	15	3.266	3.756	0.938	0.848	0.726	0.726	284860	--
MS1ASP19A	65	3.661	4.210	0.938	0.837	0.726	0.726	231432	--
MS1AVA03	20	3.712	4.269	0.938	0.836	0.776	0.776	122646	--
MS1AVA04	22	4.759	5.474	1.031	0.900	0.862	0.862	60263	--
MS1ASP20	58	1.904	2.190	1.031	0.978	0.806	0.806	688291	--
MS1AEL12	2	3.102	3.567	1.031	0.945	0.806	0.806	341346	--
MS1ASP21 US	52	2.704	3.110	1.031	0.956	0.806	0.806	422431	--
MS1ASP21 DS	52	2.704	3.110	1.031	0.956	0.806	0.806	422431	--
MS1AEL13	1	2.677	3.079	1.031	0.957	0.806	0.806	428784	--
MS1ASP22 US	51	2.380	2.737	1.031	0.965	0.806	0.806	508685	--
MS1ASP22 DS	51	2.380	2.737	1.031	0.965	0.806	0.806	508685	--
MS1AEL14	1	2.677	3.079	1.031	0.957	0.806	0.806	428784	--
MS1ASP23 US	51	2.380	2.737	1.031	0.965	0.806	0.806	508685	--
MS1ASP23 DS	9	1.174	1.351	1.031	0.999	0.806	0.806	1245356	--
MS1AEL15	2	3.983	4.581	1.031	0.921	0.806	0.806	219306	--
INLET HP TURB	30	4.327	4.976	1.031	0.912	0.806	0.806	185233	--

==>Grouped by Line: 076-18"-MS-01A, No Sorting.

MS1BSP11 US	58	2.177	2.504	0.938	0.878	0.726	0.726	532305	-
MS1BSP11 DS	58	2.177	2.504	0.938	0.878	0.726	0.726	532305	-
MS1BEL07	2	4.555	5.238	0.938	0.812	0.726	0.726	144749	-
MS1BSP12 US	52	3.092	3.556	0.938	0.853	0.726	0.726	312606	-
MS1BSP12 DS	52	3.092	3.556	0.938	0.853	0.726	0.726	312606	-
MS1BEL08	2	4.555	5.238	0.938	0.812	0.726	0.726	144749	-
MS1BSP13	52	3.092	3.556	0.938	0.853	0.726	0.726	312606	-

====>Grouped by Line: 076-18"-MS-07B, No Sorting.

RX NOZZLE N3B	31	7.421	8.534	0.938	0.733	0.726	0.726	7710	-
MS7BSP01	61	5.343	6.144	0.938	0.791	0.726	0.726	92438	-
MS7BEL01	3	4.442	5.109	0.938	0.815	0.726	0.726	153769	-
MS7BSP02	53	3.710	4.267	0.938	0.836	0.726	0.726	225517	-
MS7BEL02	1	4.188	4.817	0.938	0.822	0.726	0.726	175822	-
MS7BSP03	51	2.721	3.129	0.938	0.863	0.726	0.726	383883	-
MS7BSP04	9	1.432	1.647	0.938	0.899	0.726	0.726	918655	-
MS7BEL03	2	4.555	5.238	0.938	0.812	0.726	0.726	144749	-
MS7BSP05 US	52	3.092	3.556	0.938	0.853	0.726	0.726	312606	-
MS7BSP05 DS	52	3.092	3.556	0.938	0.853	0.726	0.726	312606	-
MS7BEL04	2	4.555	5.238	0.938	0.812	0.726	0.726	144749	-
MS7BSP06	52	3.092	3.556	0.938	0.853	0.726	0.726	312606	-
MS7BFE01	6	0.031	0.036	0.938	0.937	0.814	0.814	30037228	-
MS7BSP07	56	2.139	2.460	0.938	0.879	0.726	0.726	545399	-
MS7BEL05	4	4.555	5.238	0.938	0.812	0.726	0.726	144749	-
MS7BSP08 US	54	4.749	5.462	0.938	0.807	0.726	0.726	130227	-
MS7BSP08 DS	54	4.749	5.462	0.938	0.807	0.726	0.726	130227	-
MS7BEL06	1	3.901	4.486	0.938	0.830	0.726	0.726	204277	-
MS7BSP09	51	2.721	3.129	0.938	0.863	0.726	0.726	383883	-
MS7BVA01	22	5.443	6.259	0.938	0.788	0.776	0.776	16821	-
MS7BSP10 US	58	2.177	2.504	0.938	0.878	0.726	0.726	532305	-
MS7BSP10 DS	58	2.177	2.504	0.938	0.878	0.726	0.726	532305	-
MS7BVA02	22	5.443	6.259	0.938	0.788	0.776	0.776	16821	-

====>Grouped by Line: 077-18"-MS-01B, No Sorting.

MS1BSP14	52	3.092	3.556	0.938	0.853	0.726	0.726	312606	-
MS1BEL09	2	3.547	4.079	0.938	0.840	0.726	0.726	245599	-
MS1BSP15	52	3.092	3.556	0.938	0.853	0.726	0.726	312606	-
MS1BSP16	9	1.432	1.647	0.938	0.899	0.726	0.726	918655	-
MS1BEL10	2	3.547	4.079	0.938	0.840	0.726	0.726	245599	-
MS1BSP17	52	3.092	3.556	0.938	0.853	0.726	0.726	312606	-
MS1BSP18	9	1.432	1.647	0.938	0.899	0.726	0.726	918655	-
MS1BEL11	2	3.547	4.079	0.938	0.840	0.726	0.726	245599	-
MS1BSP19 US	52	3.092	3.556	0.938	0.853	0.726	0.726	312606	-
MS1BSP19 DS	52	3.092	3.556	0.938	0.853	0.726	0.726	312606	-
MS1BTE01 (U/S)	15	3.711	4.267	0.938	0.836	0.726	0.726	225488	-
MS1BTE01 (D/S)	15	3.266	3.756	0.938	0.848	0.726	0.726	284860	-
MS1BSP19A	65	3.661	4.210	0.938	0.837	0.726	0.726	231432	-
MS1BVA03	20	3.712	4.269	0.938	0.836	0.776	0.776	122646	-
MS1BVA04	22	4.759	5.474	1.031	0.900	0.862	0.862	60263	-
MS1BSP20	58	1.904	2.190	1.031	0.978	0.806	0.806	688291	-
MS1BEL12	2	3.102	3.567	1.031	0.945	0.806	0.806	341346	-
MS1BSP21 US	52	2.704	3.110	1.031	0.956	0.806	0.806	422431	-
MS1BSP21 DS	52	2.704	3.110	1.031	0.956	0.806	0.806	422431	-
MS1BEL13	1	2.677	3.079	1.031	0.957	0.806	0.806	428784	-
MS1BSP22 US	51	2.380	2.737	1.031	0.965	0.806	0.806	508685	-
MS1BSP22 DS	51	2.380	2.737	1.031	0.965	0.806	0.806	508685	-
MS1BEL14	1	2.677	3.079	1.031	0.957	0.806	0.806	428784	-
MS1BSP23 US	51	2.380	2.737	1.031	0.965	0.806	0.806	508685	-
MS1BSP23 DS	51	2.380	2.737	1.031	0.965	0.806	0.806	508685	-
INLET HP TURB	30	4.327	4.976	1.031	0.912	0.806	0.806	185233	-

====>Grouped by Line: 078-18"-MS-01C, No Sorting.

MS1CSP11 US	58	2.177	2.504	0.938	0.878	0.726	0.726	532305	-
MS1CSP11 DS	58	2.177	2.504	0.938	0.878	0.726	0.726	532305	-
MS1CELO7	2	4.555	5.238	0.938	0.812	0.726	0.726	144749	-
MS1CSP12 US	52	3.092	3.556	0.938	0.853	0.726	0.726	312606	-
MS1CSP12 DS	52	3.092	3.556	0.938	0.853	0.726	0.726	312606	-
MS1CELO8	2	4.555	5.238	0.938	0.812	0.726	0.726	144749	-
MS1CSP13	52	3.092	3.556	0.938	0.853	0.726	0.726	312606	-

====>Grouped by Line: 078-18"-MS-07C, No Sorting.

RX NOZZLE N3C	31	7.421	8.534	0.938	0.733	0.726	0.726	7710	-
MS7CSP01	61	5.343	6.144	0.938	0.791	0.726	0.726	92438	-
MS7CELO1	3	4.442	5.109	0.938	0.815	0.726	0.726	153769	-
MS7CSP02	53	3.710	4.267	0.938	0.836	0.726	0.726	225517	-
MS7CELO2	1	4.188	4.817	0.938	0.822	0.726	0.726	175822	-
MS7CSP03	51	2.721	3.129	0.938	0.863	0.726	0.726	383883	-
MS7CSP04	9	1.432	1.647	0.938	0.899	0.726	0.726	918655	-
MS7CELO3	2	4.555	5.238	0.938	0.812	0.726	0.726	144749	-
MS7CSP05 US	52	3.092	3.556	0.938	0.853	0.726	0.726	312606	-
MS7CSP05 DS	52	3.092	3.556	0.938	0.853	0.726	0.726	312606	-

123

MS7CEL04	2	4.555	5.238	0.938	0.812	0.726	0.726	144749	--
MS7CSP06	52	3.092	3.556	0.938	0.853	0.726	0.726	312606	--
MS7CFE01	6	0.031	0.036	0.938	0.937	0.814	0.814	30037228	--
MS7CSP07	56	2.139	2.460	0.938	0.879	0.726	0.726	545399	--
MS7CEL05	4	4.555	5.238	0.938	0.812	0.726	0.726	144749	--
MS7CSP08 US	54	4.749	5.462	0.938	0.807	0.726	0.726	130227	--
MS7CSP08 DS	54	4.749	5.462	0.938	0.807	0.726	0.726	130227	--
MS7CEL06	1	3.901	4.486	0.938	0.830	0.726	0.726	204277	--
MS7CSP09	51	2.721	3.129	0.938	0.863	0.726	0.726	383883	--
MS7CVA01	22	5.443	6.259	0.938	0.788	0.776	0.776	16821	--
MS7CSP10 US	58	2.177	2.504	0.938	0.878	0.726	0.726	532305	--
MS7CSP10 DS	58	2.177	2.504	0.938	0.878	0.726	0.726	532305	--
MS7CVA02	22	5.443	6.259	0.938	0.788	0.776	0.776	16821	--

==>Grouped by Line: 079-18"-MS-01C, No Sorting.

MS1CSP14	52	3.092	3.556	0.938	0.853	0.726	0.726	312606	--
MS1CEL09	2	3.547	4.079	0.938	0.840	0.726	0.726	245599	--
MS1CSP15	52	3.092	3.556	0.938	0.853	0.726	0.726	312606	--
MS1CSP16	9	1.432	1.647	0.938	0.899	0.726	0.726	918655	--
MS1CEL10	2	3.547	4.079	0.938	0.840	0.726	0.726	245599	--
MS1CSP17	52	3.092	3.556	0.938	0.853	0.726	0.726	312606	--
MS1CSP18	9	1.432	1.647	0.938	0.899	0.726	0.726	918655	--
MS1CEL11	2	3.547	4.079	0.938	0.840	0.726	0.726	245599	--
MS1CSP19 US	52	3.092	3.556	0.938	0.853	0.726	0.726	312606	--
MS1CSP19 DS	52	3.092	3.556	0.938	0.853	0.726	0.726	312606	--
MS1CTE01 (U/S)	15	3.711	4.267	0.938	0.836	0.726	0.726	225488	--
MS1CTE01 (D/S)	15	3.266	3.756	0.938	0.848	0.726	0.726	284860	--
MS1CSP19A	65	3.661	4.210	0.938	0.837	0.726	0.726	231432	--
MS1CVA03	20	3.712	4.269	0.938	0.836	0.776	0.776	122646	--
MS1CVA04	22	4.759	5.474	1.031	0.900	0.862	0.862	60263	--
MS1CSP20	58	1.904	2.190	1.031	0.978	0.806	0.806	688291	--
MS1CEL12	2	3.102	3.567	1.031	0.945	0.806	0.806	341346	--
MS1CSP21 US	52	2.704	3.110	1.031	0.956	0.806	0.806	422431	--
MS1CSP21 DS	52	2.704	3.110	1.031	0.956	0.806	0.806	422431	--
MS1BEL13	1	2.677	3.079	1.031	0.957	0.806	0.806	428784	--
MS1CSP22 US	51	2.380	2.737	1.031	0.965	0.806	0.806	508685	--
MS1CSP22 DS	51	2.380	2.737	1.031	0.965	0.806	0.806	508685	--
MS1CEL14	1	2.677	3.079	1.031	0.957	0.806	0.806	428784	--
MS1CSP23 US	51	2.380	2.737	1.031	0.965	0.806	0.806	508685	--
MS1CSP23 DS	51	2.380	2.737	1.031	0.965	0.806	0.806	508685	--
INLET HP TURB	30	4.327	4.976	1.031	0.912	0.806	0.806	185233	--

==>Grouped by Line: 080-18"-MS-01D, No Sorting.

MS1DSP12 US	58	2.177	2.504	0.938	0.878	0.726	0.726	532305	--
MS1DSP12 DS	58	2.177	2.504	0.938	0.845	0.726	0.726	-----	4:
MS1DEL07	2	4.555	5.238	0.938	0.967	0.726	0.726	-----	4:
MS1DSP13 US	52	3.092	3.556	0.938	0.853	0.726	0.726	312606	--
MS1DSP13 DS	52	3.092	3.556	0.938	0.853	0.726	0.726	312606	--
MS1DEL08	2	4.555	5.238	0.938	0.812	0.726	0.726	144749	--
MS1DSP14 US	52	3.092	3.556	0.938	0.853	0.726	0.726	312606	--

==>Grouped by Line: 080-18"-MS-07D, No Sorting.

RX NOZZLE N3D	31	7.421	8.534	0.938	0.733	0.726	0.726	7710	--
MS7DSP01	61	5.343	6.144	0.938	0.791	0.726	0.726	92438	--
MS7DEL01	3	4.442	5.109	0.938	0.815	0.726	0.726	153769	--
MS7DSP02	53	3.710	4.267	0.938	0.836	0.726	0.726	225517	--
MS7DEL02	1	4.188	4.817	0.938	0.822	0.726	0.726	175822	--
MS7DSP03	51	2.721	3.129	0.938	0.863	0.726	0.726	383883	--
MS7DSP04	9	1.432	1.647	0.938	0.899	0.726	0.726	918655	--
MS7DEL03	1	3.901	4.486	0.938	0.830	0.726	0.726	204277	--
MS7DSP05 US	51	2.721	3.129	0.938	0.863	0.726	0.726	383883	--
MS7DSP05 DS	51	2.721	3.129	0.938	0.863	0.726	0.726	383883	--
MS7DEL04	2	4.555	5.238	0.938	0.812	0.726	0.726	144749	--
MS7DSP06	52	3.092	3.556	0.938	0.853	0.726	0.726	312606	--
MS7DSP07	9	1.432	1.647	0.938	0.899	0.726	0.726	918655	--
MS7DEL05	2	4.555	5.238	0.938	0.812	0.726	0.726	144749	--
MS7DSP08	52	3.092	3.556	0.938	0.853	0.726	0.726	312606	--
MS7DFE01	6	0.031	0.036	0.938	0.937	0.814	0.814	30037228	--
MS7DSP09	56	2.139	2.460	0.938	0.879	0.726	0.726	545399	--
MS7DEL06	4	4.555	5.238	0.938	0.812	0.726	0.726	144749	--
MS7DSP10	54	4.749	5.462	0.938	0.807	0.726	0.726	130227	--
MS7DVA01	22	5.443	6.259	0.938	0.788	0.776	0.776	16821	--
MS7DSP11 US	58	2.177	2.504	0.938	0.878	0.726	0.726	532305	--
MS7DSP11 DS	58	2.177	2.504	0.938	0.878	0.726	0.726	532305	--
MS7DVA02	22	5.443	6.259	0.938	0.788	0.776	0.776	16821	--

==>Grouped by Line: 081-18"-MS-01D, No Sorting.

MS1DSP14 DS	52	3.092	3.556	0.938	0.853	0.726	0.726	312606	--
MS1DEL09	2	3.547	4.079	0.938	0.840	0.726	0.726	245599	--
MS1DSP15	52	3.092	3.556	0.938	0.853	0.726	0.726	312606	--
MS1DSP16	9	1.432	1.647	0.938	0.899	0.726	0.726	918655	--
MS1DSP17	2	3.547	4.079	0.938	0.840	0.726	0.726	245599	--

MS1DSP17	52	3.092	3.556	0.938	0.853	0.726	0.726	312606	-
MS1DSP18	9	1.432	1.647	0.938	0.899	0.726	0.726	918655	-
MS1DEL11	2	3.547	4.079	0.938	0.840	0.726	0.726	245599	-
MS1DSP19 US	52	3.092	3.556	0.938	0.853	0.726	0.726	312606	-
MS1DSP19 DS	52	3.092	3.556	0.938	0.853	0.726	0.726	312606	-
MS1DTE01 (U/S)	15	3.711	4.267	0.938	0.836	0.726	0.726	225488	-
MS1DTE01 (D/S)	15	3.266	3.756	0.938	0.848	0.726	0.726	284860	-
MS1DSP19A	65	3.661	4.210	0.938	0.837	0.726	0.726	231432	-
MS1DVA03	20	3.712	4.269	0.938	0.836	0.776	0.776	122646	-
MS1DVA04	22	4.759	5.474	1.031	0.900	0.862	0.862	60263	-
MS1DSP20	58	1.904	2.190	1.031	0.978	0.806	0.806	688291	-
MS1DEL12	2	3.102	3.567	1.031	0.945	0.806	0.806	341346	-
MS1DSP21 US	52	2.704	3.110	1.031	0.956	0.806	0.806	422431	-
MS1DSP21 DS	52	2.704	3.110	1.031	0.956	0.806	0.806	422431	-
MS1DEL13	1	2.677	3.079	1.031	0.957	0.806	0.806	428784	-
MS1DSP22 US	51	2.380	2.737	1.031	0.965	0.806	0.806	508685	-
MS1DSP22 DS	51	2.380	2.737	1.031	0.965	0.806	0.806	508685	-
MS1DEL14	1	2.677	3.079	1.031	0.957	0.806	0.806	428784	-
MS1DSP23 US	51	2.380	2.737	1.031	0.965	0.806	0.806	508685	-
MS1DSP23 DS	51	2.380	2.737	1.031	0.965	0.806	0.806	508685	-
MS1DEL15	2	3.983	4.581	1.031	0.921	0.806	0.806	219306	-
INLET HP TURB	30	4.327	4.976	1.031	0.912	0.806	0.806	185233	-

Notes:

- [1] Predictions are based on last Tmeas to analysis ending period.
- [2] Predictions are for the time of last inspection (last known meas. wear).
- [3] GW = Tmeas is minimum thickness from Band, Blanket or Area Method of greatest wear.
 MT = Tmeas is component minimum thickness.
 PW = Tmeas is Tinit - predicted wear.
 US = Tmeas is user specified.
- [4] If no Tmeas has been determined from measured data, then Tmeas = Tinit and Time = current component
 Tmeas is used to determine Predicted Thickness and Component Predicted Time to Tcrit.

Company: Vermont Yankee Nuclear Power Corporation Report Date: 13-SEP-2006 Time: 16:15:07
 Plant: Vermont Yankee Analysis Date: 13-SEP-2006 Time: 15:51:16
 Unit: CHECWORKS FAC Version 1.0F (Build 52)
 DB Name: VY

 *** Wear Rate Analysis: Wear Predictions Report ***

Run Name: Main Steam 2006
 Ending Period: CYCLE 25
 Total Plant Operating Hours: 241618 Duty Factor (Global): 1.000
 WRA Data Option: Ignore NFA Exclude Measure Wear: No
 Line Correction Factor: 23.841

Component Name	Total Lifetime In-Service Cmp. Wear (mils)		In-Service Cmp. Wear (mils)		In-Service Cmp. Tmeas, Method, Time			In-Service Cmp. Thickness (mils) [4]		Incremental Wear (mil) PRWEAR
	Prd.[1]	Meas.	Prd.[1]	Meas.	(in)[3]	[2]	(hrs)[3]	TP	Tm	

==>Grouped by Line: 074-18"-MS-01A, No Sorting.

==>Grouped by Line: 074-18"-MS-07A, No Sorting.

MS7ASP09	32.7	53.0	32.7	53.0	0.885	US	137270	905.3	885.0	26
MS7AEL06	69.6	80.0	69.6	80.0	0.954	US	137270	868.4	954.0	56

==>Grouped by Line: 075-18"-MS-01A, No Sorting.

==>Grouped by Line: 076-18"-MS-01B, No Sorting.

==>Grouped by Line: 076-18"-MS-07B, No Sorting.

==>Grouped by Line: 077-18"-MS-01B, No Sorting.

==>Grouped by Line: 078-18"-MS-01C, No Sorting.

==>Grouped by Line: 078-18"-MS-07C, No Sorting.

==>Grouped by Line: 079-18"-MS-01C, No Sorting.

==>Grouped by Line: 080-18"-MS-01D, No Sorting.

MS1DSP12 DS	56.8	18.0	56.8	18.0	0.848	MT	230118	881.2	848.0	3
MS1DEL07	118.8	101.0	118.8	101.0	0.974	MT	230118	819.2	974.0	6

==>Grouped by Line: 080-18"-MS-07D, No Sorting.

==>Grouped by Line: 081-18"-MS-01D, No Sorting.

Notes:

- [1] Predictions are for the time of last inspection (last known meas. wear).
- [2] GW = Tmeas is minimum thickness from Band, Blanket or Area Method of greatest wear.
 MT = Tmeas is component minimum thickness.
 PW = Tmeas is Tinit - predicted wear.
 US = Tmeas is user specified.
- [3] If no Tmeas has been determined from measured data, then Tmeas = Tinit and Time = current component. Tmeas is used to determine Predicted Thickness and Component Predicted Time to Tcrit.
- [4] These two values are used for thickness plot.
 TP = Predicted thickness at Tmeas.
 Tm = Last measured thickness (Tmeas).
- [5] PRWEAR = Incremental wear from last Tmeas time to analysis ending period.

126

 *** Wear Rate Analysis: Wear Rates/Input Data Report ***

Run Name: Main Steam 2006
 Ending Period: CYCLE 25
 Total Plant Operating Hours: 241618 Duty Factor (Global): 1.000
 WRA Data Option: Ignore NFA Exclude Measure Wear: No
 Line Correction Factor: 23.841

Component Name	Geom. Code	Average Wear Rate (mils/year)	Current Wear Rate (mils/year)	Temp. (F)	Velocity (ft/s)	Steam Quality	Diameter (in)
----------------	------------	-------------------------------	-------------------------------	-----------	-----------------	---------------	---------------

==>Grouped by Line: 074-18"-MS-01A, No Sorting.

MS1ASP12 US	58	2.177	2.504	540.3	19.994	0.997	18.000
MS1ASP12 DS	58	2.177	2.504	540.3	19.994	0.997	18.000
MS1AEL07	2	4.555	5.238	540.3	19.994	0.997	18.000
MS1ASP13 US	52	3.092	3.556	540.3	19.994	0.997	18.000
MS1ASP13 DS	52	3.092	3.556	540.3	19.994	0.997	18.000
MS1AEL08	2	4.555	5.238	540.3	19.994	0.997	18.000
MS1ASP14 US	52	3.092	3.556	540.3	19.994	0.997	18.000

==>Grouped by Line: 074-18"-MS-07A, No Sorting.

RX NOZZLE N3A	31	7.421	8.534	540.3	19.994	0.997	18.000
MS7ASP01	61	5.343	6.144	540.3	19.994	0.997	18.000
MS7AEL01	3	4.442	5.109	540.3	19.994	0.997	18.000
MS7ASP02	53	3.710	4.267	540.3	19.994	0.997	18.000
MS7AEL02	1	4.188	4.817	540.3	19.994	0.997	18.000
MS7ASP03	51	2.721	3.129	540.3	19.994	0.997	18.000
MS7ASP04	9	1.432	1.647	540.3	19.994	0.997	18.000
MS7AEL03	1	3.901	4.486	540.3	19.994	0.997	18.000
MS7ASP05 US	51	2.721	3.129	540.3	19.994	0.997	18.000
MS7ASP05 DS	51	2.721	3.129	540.3	19.994	0.997	18.000
MS7AEL04	2	4.555	5.238	540.3	19.994	0.997	18.000
MS7ASP06	52	3.092	3.556	540.3	19.994	0.997	18.000
MS7ASP07	9	1.432	1.647	540.3	19.994	0.997	18.000
MS7AEL05	2	4.555	5.238	540.3	19.994	0.997	18.000
MS7ASP08	52	3.092	3.556	540.3	19.994	0.997	18.000
MS7APE01	6	0.031	0.036	540.3	68.113	0.997	18.000
MS7ASP09	56	2.139	2.460	540.3	68.113	0.997	18.000
MS7AEL06	4	4.555	5.238	540.3	19.994	0.997	18.000
MS7ASP10	54	4.749	5.462	540.3	19.994	0.997	18.000
MS7AVA01	22	5.443	6.259	540.3	19.994	0.997	18.000
MS7ASP11 US	58	2.177	2.504	540.3	19.994	0.997	18.000
MS7ASP11 DS	58	2.177	2.504	540.3	19.994	0.997	18.000
MS7AVA02	22	5.443	6.259	540.3	19.994	0.997	18.000

==>Grouped by Line: 075-18"-MS-01A, No Sorting.

MS1ASP14 DS	52	3.092	3.556	540.3	19.994	0.997	18.000
MS1AEL09	2	3.547	4.079	540.3	19.994	0.997	18.000
MS1ASP15	52	3.092	3.556	540.3	19.994	0.997	18.000
MS1ASP16	9	1.432	1.647	540.3	19.994	0.997	18.000
MS1AEL10	2	3.547	4.079	540.3	19.994	0.997	18.000
MS1ASP17	52	3.092	3.556	540.3	19.994	0.997	18.000
MS1ASP18	9	1.432	1.647	540.3	19.994	0.997	18.000
MS1AEL11	2	3.547	4.079	540.3	19.994	0.997	18.000
MS1ASP19 US	52	3.092	3.556	540.3	19.994	0.997	18.000
MS1ASP19 DS	52	3.092	3.556	540.3	19.994	0.997	18.000
MS1ATE01 (U/S)	15	3.711	4.267	540.3	19.994	0.997	18.000
MS1ATE01 (D/S)	15	3.266	3.756	540.3	19.994	0.997	18.000
MS1ASP19A	65	3.661	4.210	540.3	19.994	0.997	18.000
MS1AVA03	20	3.712	4.269	540.3	19.994	0.997	18.000
MS1AVA04	22	4.759	5.474	540.3	16.155	0.997	20.000
MS1ASP20	58	1.904	2.190	540.3	16.155	0.997	20.000
MS1AEL12	2	3.102	3.567	540.3	16.155	0.997	20.000
MS1ASP21 US	52	2.704	3.110	540.3	16.155	0.997	20.000
MS1ASP21 DS	52	2.704	3.110	540.3	16.155	0.997	20.000
MS1AEL13	1	2.677	3.079	540.3	16.155	0.997	20.000
MS1ASP22 US	51	2.380	2.737	540.3	16.155	0.997	20.000
MS1ASP22 DS	51	2.380	2.737	540.3	16.155	0.997	20.000
MS1AEL14	1	2.677	3.079	540.3	16.155	0.997	20.000
MS1ASP23 US	51	2.380	2.737	540.3	16.155	0.997	20.000
MS1ASP23 DS	9	1.174	1.351	540.3	16.155	0.997	20.000
MS1AEL15	2	3.983	4.581	540.3	16.155	0.997	20.000
INLET HP TURB	30	4.327	4.976	540.3	16.155	0.997	20.000

==>Grouped by Line: 075-18"-MS-01A, No Sorting.

MS1BSP11 US	58	2.177	2.504	540.3	19.994	0.997	18.000
MS1BSP11 DS	58	2.177	2.504	540.3	19.994	0.997	18.000
MS1BELO7	2	4.555	5.238	540.3	19.994	0.997	18.000
MS1BSP12 US	52	3.092	3.556	540.3	19.994	0.997	18.000
MS1BSP12 DS	52	3.092	3.556	540.3	19.994	0.997	18.000
MS1BELO8	2	4.555	5.238	540.3	19.994	0.997	18.000
MS1BSP13	52	3.092	3.556	540.3	19.994	0.997	18.000

====>Grouped by Line: 076-18"-MS-07B, No Sorting.

RX NOZZLE N3B	31	7.421	8.534	540.3	19.994	0.997	18.000
MS7BSP01	61	5.343	6.144	540.3	19.994	0.997	18.000
MS7BELO1	3	4.442	5.109	540.3	19.994	0.997	18.000
MS7BSP02	53	3.710	4.267	540.3	19.994	0.997	18.000
MS7BELO2	1	4.188	4.817	540.3	19.994	0.997	18.000
MS7BSP03	51	2.721	3.129	540.3	19.994	0.997	18.000
MS7BSP04	9	1.432	1.647	540.3	19.994	0.997	18.000
MS7BELO3	2	4.555	5.238	540.3	19.994	0.997	18.000
MS7BSP05 US	52	3.092	3.556	540.3	19.994	0.997	18.000
MS7BSP05 DS	52	3.092	3.556	540.3	19.994	0.997	18.000
MS7BELO4	2	4.555	5.238	540.3	19.994	0.997	18.000
MS7BSP06	52	3.092	3.556	540.3	19.994	0.997	18.000
MS7BFE01	6	0.031	0.036	540.3	68.113	0.997	18.000
MS7BSP07	56	2.139	2.460	540.3	68.113	0.997	18.000
MS7BELO5	4	4.555	5.238	540.3	19.994	0.997	18.000
MS7BSP08 US	54	4.749	5.462	540.3	19.994	0.997	18.000
MS7BSP08 DS	54	4.749	5.462	540.3	19.994	0.997	18.000
MS7BELO6	1	3.901	4.486	540.3	19.994	0.997	18.000
MS7BSP09	51	2.721	3.129	540.3	19.994	0.997	18.000
MS7BVA01	22	5.443	6.259	540.3	19.994	0.997	18.000
MS7BSP10 US	58	2.177	2.504	540.3	19.994	0.997	18.000
MS7BSP10 DS	58	2.177	2.504	540.3	19.994	0.997	18.000
MS7BVA02	22	5.443	6.259	540.3	19.994	0.997	18.000

====>Grouped by Line: 077-18"-MS-01B, No Sorting.

MS1BSP14	52	3.092	3.556	540.3	19.994	0.997	18.000
MS1BELO9	2	3.547	4.079	540.3	19.994	0.997	18.000
MS1BSP15	52	3.092	3.556	540.3	19.994	0.997	18.000
MS1BSP16	9	1.432	1.647	540.3	19.994	0.997	18.000
MS1BEL10	2	3.547	4.079	540.3	19.994	0.997	18.000
MS1BSP17	52	3.092	3.556	540.3	19.994	0.997	18.000
MS1BSP18	9	1.432	1.647	540.3	19.994	0.997	18.000
MS1BEL11	2	3.547	4.079	540.3	19.994	0.997	18.000
MS1BSP19 US	52	3.092	3.556	540.3	19.994	0.997	18.000
MS1BSP19 DS	52	3.092	3.556	540.3	19.994	0.997	18.000
MS1BTE01 (U/S)	15	3.711	4.267	540.3	19.994	0.997	18.000
MS1BTE01 (D/S)	15	3.266	3.756	540.3	19.994	0.997	18.000
MS1BSP19A	65	3.661	4.210	540.3	19.994	0.997	18.000
MS1BVA03	20	3.712	4.269	540.3	19.994	0.997	18.000
MS1BVA04	22	4.759	5.474	540.3	16.155	0.997	20.000
MS1BSP20	58	1.904	2.190	540.3	16.155	0.997	20.000
MS1BEL12	2	3.102	3.567	540.3	16.155	0.997	20.000
MS1BSP21 US	52	2.704	3.110	540.3	16.155	0.997	20.000
MS1BSP21 DS	52	2.704	3.110	540.3	16.155	0.997	20.000
MS1BEL13	1	2.677	3.079	540.3	16.155	0.997	20.000
MS1BSP22 US	51	2.380	2.737	540.3	16.155	0.997	20.000
MS1BSP22 DS	51	2.380	2.737	540.3	16.155	0.997	20.000
MS1BEL14	1	2.677	3.079	540.3	16.155	0.997	20.000
MS1BSP23 US	51	2.380	2.737	540.3	16.155	0.997	20.000
MS1BSP23 DS	51	2.380	2.737	540.3	16.155	0.997	20.000
INLET HP TURB	30	4.327	4.976	540.3	16.155	0.997	20.000

====>Grouped by Line: 078-18"-MS-01C, No Sorting.

MS1CSP11 US	58	2.177	2.504	540.3	19.994	0.997	18.000
MS1CSP11 DS	58	2.177	2.504	540.3	19.994	0.997	18.000
MS1CEL07	2	4.555	5.238	540.3	19.994	0.997	18.000
MS1CSP12 US	52	3.092	3.556	540.3	19.994	0.997	18.000
MS1CSP12 DS	52	3.092	3.556	540.3	19.994	0.997	18.000
MS1CEL08	2	4.555	5.238	540.3	19.994	0.997	18.000
MS1CSP13	52	3.092	3.556	540.3	19.994	0.997	18.000

====>Grouped by Line: 078-18"-MS-07C, No Sorting.

RX NOZZLE N3C	31	7.421	8.534	540.3	19.994	0.997	18.000
MS7CSP01	61	5.343	6.144	540.3	19.994	0.997	18.000
MS7CEL01	3	4.442	5.109	540.3	19.994	0.997	18.000
MS7CSP02	53	3.710	4.267	540.3	19.994	0.997	18.000
MS7CEL02	1	4.188	4.817	540.3	19.994	0.997	18.000
MS7CSP03	51	2.721	3.129	540.3	19.994	0.997	18.000
MS7CSP04	9	1.432	1.647	540.3	19.994	0.997	18.000
MS7CEL03	2	4.555	5.238	540.3	19.994	0.997	18.000
MS7CSP05 US	52	3.092	3.556	540.3	19.994	0.997	18.000
MS7CSP05 DS	52	3.092	3.556	540.3	19.994	0.997	18.000

MS7CEL04	2	4.555	5.238	540.3	19.994	0.997	18.000
MS7CSP06	52	3.092	3.556	540.3	19.994	0.997	18.000
MS7CFE01	6	0.031	0.036	540.3	68.113	0.997	18.000
MS7CSP07	56	2.139	2.460	540.3	68.113	0.997	18.000
MS7CEL05	4	4.555	5.238	540.3	19.994	0.997	18.000
MS7CSP08 US	54	4.749	5.462	540.3	19.994	0.997	18.000
MS7CSP08 DS	54	4.749	5.462	540.3	19.994	0.997	18.000
MS7CEL06	1	3.901	4.486	540.3	19.994	0.997	18.000
MS7CSP09	51	2.721	3.129	540.3	19.994	0.997	18.000
MS7CVA01	22	5.443	6.259	540.3	19.994	0.997	18.000
MS7CSP10 US	58	2.177	2.504	540.3	19.994	0.997	18.000
MS7CSP10 DS	58	2.177	2.504	540.3	19.994	0.997	18.000
MS7CVA02	22	5.443	6.259	540.3	19.994	0.997	18.000

===>Grouped by Line: 079-18*-MS-01C, No Sorting.

MS1CSP14	52	3.092	3.556	540.3	19.994	0.997	18.000
MS1CEL09	2	3.547	4.079	540.3	19.994	0.997	18.000
MS1CSP15	52	3.092	3.556	540.3	19.994	0.997	18.000
MS1CSP16	9	1.432	1.647	540.3	19.994	0.997	18.000
MS1CEL10	2	3.547	4.079	540.3	19.994	0.997	18.000
MS1CSP17	52	3.092	3.556	540.3	19.994	0.997	18.000
MS1CSP18	9	1.432	1.647	540.3	19.994	0.997	18.000
MS1CEL11	2	3.547	4.079	540.3	19.994	0.997	18.000
MS1CSP19 US	52	3.092	3.556	540.3	19.994	0.997	18.000
MS1CSP19 DS	52	3.092	3.556	540.3	19.994	0.997	18.000
MS1CTE01 (U/S)	15	3.711	4.267	540.3	19.994	0.997	18.000
MS1CTE01 (D/S)	15	3.266	3.756	540.3	19.994	0.997	18.000
MS1CSP19A	65	3.661	4.210	540.3	19.994	0.997	18.000
MS1CVA03	20	3.712	4.269	540.3	19.994	0.997	18.000
MS1CVA04	22	4.759	5.474	540.3	16.155	0.997	20.000
MS1CSP20	58	1.904	2.190	540.3	16.155	0.997	20.000
MS1CEL12	2	3.102	3.567	540.3	16.155	0.997	20.000
MS1CSP21 US	52	2.704	3.110	540.3	16.155	0.997	20.000
MS1CSP21 DS	52	2.704	3.110	540.3	16.155	0.997	20.000
MS1BEL13	1	2.677	3.079	540.3	16.155	0.997	20.000
MS1CSP22 US	51	2.380	2.737	540.3	16.155	0.997	20.000
MS1CSP22 DS	51	2.380	2.737	540.3	16.155	0.997	20.000
MS1CEL14	1	2.677	3.079	540.3	16.155	0.997	20.000
MS1CSP23 US	51	2.380	2.737	540.3	16.155	0.997	20.000
MS1CSP23 DS	51	2.380	2.737	540.3	16.155	0.997	20.000
INLET HP TURB	30	4.327	4.976	540.3	16.155	0.997	20.000

===>Grouped by Line: 080-18*-MS-01D, No Sorting.

MS1DSP12 US	58	2.177	2.504	540.3	19.994	0.997	18.000
MS1DSP12 DS	58	2.177	2.504	540.3	19.994	0.997	18.000
MS1DEL07	2	4.555	5.238	540.3	19.994	0.997	18.000
MS1DSP13 US	52	3.092	3.556	540.3	19.994	0.997	18.000
MS1DSP13 DS	52	3.092	3.556	540.3	19.994	0.997	18.000
MS1DEL08	2	4.555	5.238	540.3	19.994	0.997	18.000
MS1DSP14 US	52	3.092	3.556	540.3	19.994	0.997	18.000

===>Grouped by Line: 080-18*-MS-07D, No Sorting.

RX NOZZLE N3D	31	7.421	8.534	540.3	19.994	0.997	18.000
MS7DSP01	61	5.343	6.144	540.3	19.994	0.997	18.000
MS7DEL01	3	4.442	5.109	540.3	19.994	0.997	18.000
MS7DSP02	53	3.710	4.267	540.3	19.994	0.997	18.000
MS7DEL02	1	4.188	4.817	540.3	19.994	0.997	18.000
MS7DSP03	51	2.721	3.129	540.3	19.994	0.997	18.000
MS7DSP04	9	1.432	1.647	540.3	19.994	0.997	18.000
MS7DEL03	1	3.901	4.486	540.3	19.994	0.997	18.000
MS7DSP05 US	51	2.721	3.129	540.3	19.994	0.997	18.000
MS7DSP05 DS	51	2.721	3.129	540.3	19.994	0.997	18.000
MS7DEL04	2	4.555	5.238	540.3	19.994	0.997	18.000
MS7DSP06	52	3.092	3.556	540.3	19.994	0.997	18.000
MS7DSP07	9	1.432	1.647	540.3	19.994	0.997	18.000
MS7DEL05	2	4.555	5.238	540.3	19.994	0.997	18.000
MS7DSP08	52	3.092	3.556	540.3	19.994	0.997	18.000
MS7DFE01	6	0.031	0.036	540.3	68.113	0.997	18.000
MS7DSP09	56	2.139	2.460	540.3	68.113	0.997	18.000
MS7DEL06	4	4.555	5.238	540.3	19.994	0.997	18.000
MS7DSP10	54	4.749	5.462	540.3	19.994	0.997	18.000
MS7DVA01	22	5.443	6.259	540.3	19.994	0.997	18.000
MS7DSP11 US	58	2.177	2.504	540.3	19.994	0.997	18.000
MS7DSP11 DS	58	2.177	2.504	540.3	19.994	0.997	18.000
MS7DVA02	22	5.443	6.259	540.3	19.994	0.997	18.000

===>Grouped by Line: 081-18*-MS-01D, No Sorting.

MS1DSP14 DS	52	3.092	3.556	540.3	19.994	0.997	18.000
MS1DEL09	2	3.547	4.079	540.3	19.994	0.997	18.000
MS1DSP15	52	3.092	3.556	540.3	19.994	0.997	18.000
MS1DSP16	9	1.432	1.647	540.3	19.994	0.997	18.000
MS1CEL10	2	3.547	4.079	540.3	19.994	0.997	18.000

MS1DSP17	52	3.092	3.556	540.3	19.994	0.997	18.000
MS1DSP18	9	1.432	1.647	540.3	19.994	0.997	18.000
MS1DEL11	2	3.547	4.079	540.3	19.994	0.997	18.000
MS1DSP19 US	52	3.092	3.556	540.3	19.994	0.997	18.000
MS1DSP19 DS	52	3.092	3.556	540.3	19.994	0.997	18.000
MS1DTE01 (U/S)	15	3.711	4.267	540.3	19.994	0.997	18.000
MS1DTE01 (D/S)	15	3.266	3.756	540.3	19.994	0.997	18.000
MS1DSP19A	65	3.661	4.210	540.3	19.994	0.997	18.000
MS1DVA03	20	3.712	4.269	540.3	19.994	0.997	18.000
MS1DVA04	22	4.759	5.474	540.3	16.155	0.997	20.000
MS1DSP20	58	1.904	2.190	540.3	16.155	0.997	20.000
MS1DEL12	2	3.102	3.567	540.3	16.155	0.997	20.000
MS1DSP21 US	52	2.704	3.110	540.3	16.155	0.997	20.000
MS1DSP21 DS	52	2.704	3.110	540.3	16.155	0.997	20.000
MS1DEL13	1	2.677	3.079	540.3	16.155	0.997	20.000
MS1DSP22 US	51	2.380	2.737	540.3	16.155	0.997	20.000
MS1DSP22 DS	51	2.380	2.737	540.3	16.155	0.997	20.000
MS1DEL14	1	2.677	3.079	540.3	16.155	0.997	20.000
MS1DSP23 US	51	2.380	2.737	540.3	16.155	0.997	20.000
MS1DSP23 DS	51	2.380	2.737	540.3	16.155	0.997	20.000
MS1DEL15	2	3.983	4.581	540.3	16.155	0.997	20.000
INLET HP TURB	30	4.327	4.976	540.3	16.155	0.997	20.000

 *** Wear Rate Analysis: Inspection History Report ***

Run Name: Main Steam 2006
 Ending Period: CYCLE 25
 Total Plant Operating Hours: 241618 Duty Factor (Global): 1.000
 WRA Data Option: Ignore NFA Exclude Measure Wear: No
 Line Correction Factor: 23.841

Component Name	Geom. Code	Material				Sigma (psi)	Time (hrs)		Analysis Option	Measured Wear (mils)
		No.	Cr. (%)	Cu. (%)	Mo. (%)		Last Inspected	Replaced		

====>Grouped by Line: 074-18"-MS-01A, No Sorting.

MS1ASP12 US	58	5	0.00	0.00	0.00	15000	----	----	---
MS1ASP12 DS	58	5	0.00	0.00	0.00	15000	----	----	---
MS1AEL07	2	21	0.00	0.00	0.00	15000	----	----	---
MS1ASP13 US	52	5	0.00	0.00	0.00	15000	----	----	---
MS1ASP13 DS	52	5	0.00	0.00	0.00	15000	----	----	---
MS1AEL08	2	21	0.00	0.00	0.00	15000	----	----	---
MS1ASP14 US	52	5	0.00	0.00	0.00	15000	----	----	---

====>Grouped by Line: 074-18"-MS-07A, No Sorting.

RX NOZZLE N3A	31	5	0.00	0.00	0.00	15000	----	----	---
MS7ASP01	61	5	0.00	0.00	0.00	15000	----	----	---
MS7AEL01	3	21	0.00	0.00	0.00	15000	----	----	---
MS7ASP02	53	5	0.00	0.00	0.00	15000	----	----	---
MS7AEL02	1	21	0.00	0.00	0.00	15000	----	----	---
MS7ASP03	51	5	0.00	0.00	0.00	15000	----	----	---
MS7ASP04	9	5	0.00	0.00	0.00	15000	----	----	---
MS7AEL03	1	21	0.00	0.00	0.00	15000	----	----	---
MS7ASP05 US	51	5	0.00	0.00	0.00	15000	----	----	---
MS7ASP05 DS	51	5	0.00	0.00	0.00	15000	----	----	---
MS7AEL04	2	21	0.00	0.00	0.00	15000	----	----	---
MS7ASP06	52	5	0.00	0.00	0.00	15000	----	----	---
MS7ASP07	9	5	0.00	0.00	0.00	15000	----	----	---
MS7AEL05	2	21	0.00	0.00	0.00	15000	----	----	---
MS7ASP08	52	5	0.00	0.00	0.00	15000	----	----	---
MS7AFE01	6	61	18.00	0.00	0.00	13325	----	----	---
MS7ASP09	56	5	0.00	0.00	0.00	15000	137270	----	53
MS7AEL06	4	21	0.00	0.00	0.00	15000	137270	----	80
MS7ASP10	54	5	0.00	0.00	0.00	15000	----	----	---
MS7AVA01	22	93	0.00	0.00	0.00	14000	----	----	---
MS7ASP11 US	58	5	0.00	0.00	0.00	15000	----	----	---
MS7ASP11 DS	58	5	0.00	0.00	0.00	15000	----	----	---
MS7AVA02	22	93	0.00	0.00	0.00	14000	----	----	---

====>Grouped by Line: 075-18"-MS-01A, No Sorting.

MS1ASP14 DS	52	5	0.00	0.00	0.00	15000	----	----	---
MS1AEL09	2	5	0.00	0.00	0.00	15000	----	----	---
MS1ASP15	52	5	0.00	0.00	0.00	15000	----	----	---
MS1ASP16	9	5	0.00	0.00	0.00	15000	----	----	---
MS1AEL10	2	5	0.00	0.00	0.00	15000	----	----	---
MS1ASP17	52	5	0.00	0.00	0.00	15000	----	----	---
MS1ASP18	9	5	0.00	0.00	0.00	15000	----	----	---
MS1AEL11	2	5	0.00	0.00	0.00	15000	----	----	---
MS1ASP19 US	52	5	0.00	0.00	0.00	15000	----	----	---
MS1ASP19 DS	52	5	0.00	0.00	0.00	15000	----	----	---
MS1ATE01 (U/S)	15	21	0.00	0.00	0.00	15000	----	----	---
MS1ATE01 (D/S)	15	21	0.00	0.00	0.00	15000	----	----	---
MS1ASP19A	65	5	0.00	0.00	0.00	15000	----	----	---
MS1AVA03	20	93	0.00	0.00	0.00	14000	----	----	---
MS1AVA04	22	93	0.00	0.00	0.00	14000	----	----	---
MS1ASP20	58	5	0.00	0.00	0.00	15000	----	----	---
MS1AEL12	2	5	0.00	0.00	0.00	15000	----	----	---
MS1ASP21 US	52	5	0.00	0.00	0.00	15000	----	----	---
MS1ASP21 DS	52	5	0.00	0.00	0.00	15000	----	----	---
MS1AEL13	1	5	0.00	0.00	0.00	15000	----	----	---
MS1ASP22 US	51	5	0.00	0.00	0.00	15000	----	----	---
MS1ASP22 DS	51	5	0.00	0.00	0.00	15000	----	----	---
MS1AEL14	1	5	0.00	0.00	0.00	15000	----	----	---
MS1ASP23 US	51	5	0.00	0.00	0.00	15000	----	----	---
MS1ASP23 DS	9	5	0.00	0.00	0.00	15000	----	----	---
MS1AEL15	2	21	0.00	0.00	0.00	15000	----	----	---
INLET HP TRB	30	5	0.00	0.00	0.00	15000	----	----	---

====>Grouped by Line: 076-18"-MS-01A, No Sorting.

MS1BSP11 US	58	5	0.00	0.00	0.00	15000	----	----	----
MS1BSP11 DS	58	5	0.00	0.00	0.00	15000	----	----	----
MS1BEL07	2	21	0.00	0.00	0.00	15000	----	----	----
MS1BSP12 US	52	5	0.00	0.00	0.00	15000	----	----	----
MS1BSP12 DS	52	5	0.00	0.00	0.00	15000	----	----	----
MS1BEL08	2	21	0.00	0.00	0.00	15000	----	----	----
MS1BSP13	52	5	0.00	0.00	0.00	15000	----	----	----

==>Grouped by Line: 076-18"-MS-07B, No Sorting.

RX NOZZLE N3B	31	5	0.00	0.00	0.00	15000	----	----	----
MS7BSP01	61	5	0.00	0.00	0.00	15000	----	----	----
MS7BEL01	3	21	0.00	0.00	0.00	15000	----	----	----
MS7BSP02	53	5	0.00	0.00	0.00	15000	----	----	----
MS7BEL02	1	21	0.00	0.00	0.00	15000	----	----	----
MS7BSP03	51	5	0.00	0.00	0.00	15000	----	----	----
MS7BSP04	9	5	0.00	0.00	0.00	15000	----	----	----
MS7BEL03	2	21	0.00	0.00	0.00	15000	----	----	----
MS7BSP05 US	52	5	0.00	0.00	0.00	15000	----	----	----
MS7BSP05 DS	52	5	0.00	0.00	0.00	15000	----	----	----
MS7BEL04	2	21	0.00	0.00	0.00	15000	----	----	----
MS7BSP06	52	5	0.00	0.00	0.00	15000	----	----	----
MS7BFE01	6	61	18.00	0.00	0.00	13325	----	----	----
MS7BSP07	56	5	0.00	0.00	0.00	15000	----	----	----
MS7BEL05	4	21	0.00	0.00	0.00	15000	----	----	----
MS7BSP08 US	54	5	0.00	0.00	0.00	15000	----	----	----
MS7BSP08 DS	54	5	0.00	0.00	0.00	15000	----	----	----
MS7BEL06	1	21	0.00	0.00	0.00	15000	----	----	----
MS7BSP09	51	5	0.00	0.00	0.00	15000	----	----	----
MS7BVA01	22	93	0.00	0.00	0.00	14000	----	----	----
MS7BSP10 US	58	5	0.00	0.00	0.00	15000	----	----	----
MS7BSP10 DS	58	5	0.00	0.00	0.00	15000	----	----	----
MS7BVA02	22	93	0.00	0.00	0.00	14000	----	----	----

==>Grouped by Line: 077-18"-MS-01B, No Sorting.

MS1BSP14	52	5	0.00	0.00	0.00	15000	----	----	----
MS1BEL09	2	5	0.00	0.00	0.00	15000	----	----	----
MS1BSP15	52	5	0.00	0.00	0.00	15000	----	----	----
MS1BSP16	9	5	0.00	0.00	0.00	15000	----	----	----
MS1BEL10	2	5	0.00	0.00	0.00	15000	----	----	----
MS1BSP17	52	5	0.00	0.00	0.00	15000	----	----	----
MS1BSP18	9	5	0.00	0.00	0.00	15000	----	----	----
MS1BEL11	2	5	0.00	0.00	0.00	15000	----	----	----
MS1BSP19 US	52	5	0.00	0.00	0.00	15000	----	----	----
MS1BSP19 DS	52	5	0.00	0.00	0.00	15000	----	----	----
MS1BTE01 (U/S)	15	21	0.00	0.00	0.00	15000	----	----	----
MS1BTE01 (D/S)	15	21	0.00	0.00	0.00	15000	----	----	----
MS1BSP19A	65	5	0.00	0.00	0.00	15000	----	----	----
MS1BVA03	20	93	0.00	0.00	0.00	14000	----	----	----
MS1BVA04	22	93	0.00	0.00	0.00	14000	----	----	----
MS1BSP20	58	5	0.00	0.00	0.00	15000	----	----	----
MS1BEL12	2	5	0.00	0.00	0.00	15000	----	----	----
MS1BSP21 US	52	5	0.00	0.00	0.00	15000	----	----	----
MS1BSP21 DS	52	5	0.00	0.00	0.00	15000	----	----	----
MS1BEL13	1	5	0.00	0.00	0.00	15000	----	----	----
MS1BSP22 US	51	5	0.00	0.00	0.00	15000	----	----	----
MS1BSP22 DS	51	5	0.00	0.00	0.00	15000	----	----	----
MS1BEL14	1	5	0.00	0.00	0.00	15000	----	----	----
MS1BSP23 US	51	5	0.00	0.00	0.00	15000	----	----	----
MS1BSP23 DS	51	5	0.00	0.00	0.00	15000	----	----	----
INLET HP TURB	30	5	0.00	0.00	0.00	15000	----	----	----

==>Grouped by Line: 078-18"-MS-01C, No Sorting.

MS1CSP11 US	58	5	0.00	0.00	0.00	15000	----	----	----
MS1CSP11 DS	58	5	0.00	0.00	0.00	15000	----	----	----
MS1CEL07	2	21	0.00	0.00	0.00	15000	----	----	----
MS1CSP12 US	52	5	0.00	0.00	0.00	15000	----	----	----
MS1CSP12 DS	52	5	0.00	0.00	0.00	15000	----	----	----
MS1CEL08	2	21	0.00	0.00	0.00	15000	----	----	----
MS1CSP13	52	5	0.00	0.00	0.00	15000	----	----	----

==>Grouped by Line: 078-18"-MS-07C, No Sorting.

RX NOZZLE N3C	31	5	0.00	0.00	0.00	15000	----	----	----
MS7CSP01	61	5	0.00	0.00	0.00	15000	----	----	----
MS7CEL01	3	21	0.00	0.00	0.00	15000	----	----	----
MS7CSP02	53	5	0.00	0.00	0.00	15000	----	----	----
MS7CEL02	1	21	0.00	0.00	0.00	15000	----	----	----
MS7CSP03	51	5	0.00	0.00	0.00	15000	----	----	----
MS7CSP04	9	5	0.00	0.00	0.00	15000	----	----	----
MS7CEL03	2	21	0.00	0.00	0.00	15000	----	----	----
MS7CSP05 US	52	5	0.00	0.00	0.00	15000	----	----	----
MS7CSP05 DS	52	5	0.00	0.00	0.00	15000	----	----	----

MS7CEL04	2	21	0.00	0.00	0.00	15000	----	----	---
MS7CSP06	52	5	0.00	0.00	0.00	15000	----	----	---
MS7CFE01	6	61	18.00	0.00	0.00	13325	----	----	---
MS7CSP07	56	5	0.00	0.00	0.00	15000	----	----	---
MS7CEL05	4	21	0.00	0.00	0.00	15000	----	----	---
MS7CSP08 US	54	5	0.00	0.00	0.00	15000	----	----	---
MS7CSP08 DS	54	5	0.00	0.00	0.00	15000	----	----	---
MS7CEL06	1	21	0.00	0.00	0.00	15000	----	----	---
MS7CSP09	51	5	0.00	0.00	0.00	15000	----	----	---
MS7CVA01	22	93	0.00	0.00	0.00	14000	----	----	---
MS7CSP10 US	58	5	0.00	0.00	0.00	15000	----	----	---
MS7CSP10 DS	58	5	0.00	0.00	0.00	15000	----	----	---
MS7CVA02	22	93	0.00	0.00	0.00	14000	----	----	---

==>Grouped by Line: 079-18*-MS-01C, No Sorting.

MS1CSP14	52	5	0.00	0.00	0.00	15000	----	----	---
MS1CEL09	2	5	0.00	0.00	0.00	15000	----	----	---
MS1CSP15	52	5	0.00	0.00	0.00	15000	----	----	---
MS1CSP16	9	5	0.00	0.00	0.00	15000	----	----	---
MS1CEL10	2	5	0.00	0.00	0.00	15000	----	----	---
MS1CSP17	52	5	0.00	0.00	0.00	15000	----	----	---
MS1CSP18	9	5	0.00	0.00	0.00	15000	----	----	---
MS1CEL11	2	5	0.00	0.00	0.00	15000	----	----	---
MS1CSP19 US	52	5	0.00	0.00	0.00	15000	----	----	---
MS1CSP19 DS	52	5	0.00	0.00	0.00	15000	----	----	---
MS1CTE01(U/S)	15	21	0.00	0.00	0.00	15000	----	----	---
MS1CTE01(D/S)	15	21	0.00	0.00	0.00	15000	----	----	---
MS1CSP19A	65	5	0.00	0.00	0.00	15000	----	----	---
MS1CVA03	20	93	0.00	0.00	0.00	14000	----	----	---
MS1CVA04	22	93	0.00	0.00	0.00	14000	----	----	---
MS1CSP20	58	5	0.00	0.00	0.00	15000	----	----	---
MS1CEL12	2	5	0.00	0.00	0.00	15000	----	----	---
MS1CSP21 US	52	5	0.00	0.00	0.00	15000	----	----	---
MS1CSP21 DS	52	5	0.00	0.00	0.00	15000	----	----	---
MS1BEL13	1	5	0.00	0.00	0.00	15000	----	----	---
MS1CSP22 US	51	5	0.00	0.00	0.00	15000	----	----	---
MS1CSP22 DS	51	5	0.00	0.00	0.00	15000	----	----	---
MS1CEL14	1	5	0.00	0.00	0.00	15000	----	----	---
MS1CSP23 US	51	5	0.00	0.00	0.00	15000	----	----	---
MS1CSP23 DS	51	5	0.00	0.00	0.00	15000	----	----	---
INLET HP TURB	30	5	0.00	0.00	0.00	15000	----	----	---

==>Grouped by Line: 080-18*-MS-01D, No Sorting.

MS1DSP12 US	58	5	0.00	0.00	0.00	15000	----	----	---
MS1DSP12 DS	58	5	0.00	0.00	0.00	15000	230118	----	18
MS1DEL07	2	21	0.00	0.00	0.00	15000	230118	----	101
MS1DSP13 US	52	5	0.00	0.00	0.00	15000	----	----	---
MS1DSP13 DS	52	5	0.00	0.00	0.00	15000	----	----	---
MS1DEL08	2	21	0.00	0.00	0.00	15000	----	----	---
MS1DSP14 US	52	5	0.00	0.00	0.00	15000	----	----	---

==>Grouped by Line: 080-18*-MS-07D, No Sorting.

RX NOZZLE N3D	31	5	0.00	0.00	0.00	15000	----	----	---
MS7DSP01	61	5	0.00	0.00	0.00	15000	----	----	---
MS7DEL01	3	21	0.00	0.00	0.00	15000	----	----	---
MS7DSP02	53	5	0.00	0.00	0.00	15000	----	----	---
MS7DEL02	1	21	0.00	0.00	0.00	15000	----	----	---
MS7DSP03	51	5	0.00	0.00	0.00	15000	----	----	---
MS7DSP04	9	5	0.00	0.00	0.00	15000	----	----	---
MS7DEL03	1	21	0.00	0.00	0.00	15000	----	----	---
MS7DSP05 US	51	5	0.00	0.00	0.00	15000	----	----	---
MS7DSP05 DS	51	5	0.00	0.00	0.00	15000	----	----	---
MS7DEL04	2	21	0.00	0.00	0.00	15000	----	----	---
MS7DSP06	52	5	0.00	0.00	0.00	15000	----	----	---
MS7DSP07	9	5	0.00	0.00	0.00	15000	----	----	---
MS7DEL05	2	21	0.00	0.00	0.00	15000	----	----	---
MS7DSP08	52	5	0.00	0.00	0.00	15000	----	----	---
MS7DFE01	6	61	18.00	0.00	0.00	13325	----	----	---
MS7DSP09	56	5	0.00	0.00	0.00	15000	----	----	---
MS7DEL06	4	21	0.00	0.00	0.00	15000	----	----	---
MS7DSP10	54	5	0.00	0.00	0.00	15000	----	----	---
MS7DVA01	22	93	0.00	0.00	0.00	14000	----	----	---
MS7DSP11 US	58	5	0.00	0.00	0.00	15000	----	----	---
MS7DSP11 DS	58	5	0.00	0.00	0.00	15000	----	----	---
MS7DVA02	22	93	0.00	0.00	0.00	14000	----	----	---

==>Grouped by Line: 081-18*-MS-01D, No Sorting.

MS1DSP14 DS	52	5	0.00	0.00	0.00	15000	----	----	---
MS1DEL09	2	5	0.00	0.00	0.00	15000	----	----	---
MS1DSP15	52	5	0.00	0.00	0.00	15000	----	----	---
MS1DSP16	9	5	0.00	0.00	0.00	15000	----	----	---
MS1DSP17	2	5	0.00	0.00	0.00	15000	----	----	---

MSIDSP17	52	5	0.00	0.00	0.00	15000	----	----	---
MSIDSP18	9	5	0.00	0.00	0.00	15000	----	----	---
MSIDEL11	2	5	0.00	0.00	0.00	15000	----	----	---
MSIDSP19 US	52	5	0.00	0.00	0.00	15000	----	----	---
MSIDSP19 DS	52	5	0.00	0.00	0.00	15000	----	----	---
MSIDTE01 (U/S)	15	21	0.00	0.00	0.00	15000	----	----	---
MSIDTE01 (D/S)	15	21	0.00	0.00	0.00	15000	----	----	---
MSIDSP19A	65	5	0.00	0.00	0.00	15000	----	----	---
MSIDVA03	20	93	0.00	0.00	0.00	14000	----	----	---
MSIDVA04	22	93	0.00	0.00	0.00	14000	----	----	---
MSIDSP20	58	5	0.00	0.00	0.00	15000	----	----	---
MSIDEL12	2	5	0.00	0.00	0.00	15000	----	----	---
MSIDSP21 US	52	5	0.00	0.00	0.00	15000	----	----	---
MSIDSP21 DS	52	5	0.00	0.00	0.00	15000	----	----	---
MSIDEL13	1	5	0.00	0.00	0.00	15000	----	----	---
MSIDSP22 US	51	5	0.00	0.00	0.00	15000	----	----	---
MSIDSP22 DS	51	5	0.00	0.00	0.00	15000	----	----	---
MSIDEL14	1	5	0.00	0.00	0.00	15000	----	----	---
MSIDSP23 US	51	5	0.00	0.00	0.00	15000	----	----	---
MSIDSP23 DS	51	5	0.00	0.00	0.00	15000	----	----	---
MSIDEL15	2	21	0.00	0.00	0.00	15000	----	----	---
INLET HP TURB	30	5	0.00	0.00	0.00	15000	----	----	---

Company: Vermont Yankee Nuclear Power Corporation Report Date: 13-SEP-2006 Time: 16:11:25
 Plant: Vermont Yankee Analysis Date: 13-SEP-2006 Time: 15:51:16
 Unit: CHECWORKS FAC Version 1.0F (Build 52)
 DB Name: VY

 *** Wear Rate Analysis: Combined Rankings for Inspection ***

Run Name: Main Steam 2006
 Ending Period: CYCLE 25
 Total Plant Operating Hours: 241618 Duty Factor (Global): 1.000
 WRA Data Option: Ignore NFA Exclude Measure Wear: No
 Line Correction Factor: 23.841

Component Name	Geometry Code	Average Wear Rate (mils/year)	Component Predicted Time to Tcrit (hrs)	
			Non-Inspected	Inspected
MS7AEL01	3	4.442	153769	-----
MS7CEL05	4	4.555	144749	-----
MS7DFE01	6	0.031	30037228	-----
MS7DVA02	22	5.443	16821	-----
MS7ASP01	61	5.343	92438	-----
RX NOZZLE N3C	31	7.421	7710	-----
RX NOZZLE N3A	31	7.421	7710	-----
RX NOZZLE N3B	31	7.421	7710	-----
RX NOZZLE N3D	31	7.421	7710	-----
MS7BVA01	22	5.443	16821	-----
MS7BVA02	22	5.443	16821	-----
MS7CVA02	22	5.443	16821	-----
MS7CVA01	22	5.443	16821	-----
MS7AVA01	22	5.443	16821	-----
MS7DVA01	22	5.443	16821	-----
MS7AVA02	22	5.443	16821	-----
MS7CSP01	61	5.343	92438	-----
MS1DVA04	22	4.759	60263	-----
MS7BSP01	61	5.343	92438	-----
MS1CVA04	22	4.759	60263	-----
MS1BVA04	22	4.759	60263	-----
MS7DSP01	61	5.343	92438	-----
MS1AVA04	22	4.759	60263	-----
MS7DSP10	54	4.749	130227	-----
MS1BVA03	20	3.712	122646	-----
MS7CSP08 US	54	4.749	130227	-----
MS1AVA03	20	3.712	122646	-----
MS7ASP10	54	4.749	130227	-----
MS1DVA03	20	3.712	122646	-----
MS7BSP08 DS	54	4.749	130227	-----
MS1CVA03	20	3.712	122646	-----
MS7CSP08 DS	54	4.749	130227	-----
MS7BSP08 US	54	4.749	130227	-----
MS7CEL03	2	4.555	144749	-----
MS7BEL04	2	4.555	144749	-----
MS1AEL08	2	4.555	144749	-----
MS1BEL08	2	4.555	144749	-----
MS7CEL04	2	4.555	144749	-----
MS1DEL08	2	4.555	144749	-----
MS7AEL06	4	4.555	-----	287886
MS1BEL07	2	4.555	144749	-----
MS7DEL06	4	4.555	144749	-----
MS7AEL05	2	4.555	144749	-----
MS1CEL08	2	4.555	144749	-----
MS1CEL07	2	4.555	144749	-----
MS7AEL04	2	4.555	144749	-----
MS7BEL03	2	4.555	144749	-----
MS7DEL05	2	4.555	144749	-----
MS1DEL07	2	4.555	-----	403549
MS7DEL04	2	4.555	144749	-----
MS7BEL05	4	4.555	144749	-----
MS1AEL07	2	4.555	144749	-----
MS7CEL01	3	4.442	153769	-----
MS7DEL01	3	4.442	153769	-----
MS7BEL01	3	4.442	153769	-----
INLET HP TURB	30	4.327	185233	-----
INLET HP TURB	30	4.327	185233	-----
INLET HP TURB	30	4.327	185233	-----
MS7BEL02	1	4.188	175822	-----
INLET HP TURB	30	4.327	185233	-----
MS7AEL02	1	4.188	175822	-----
MS7CEL02	1	4.188	175822	-----
MS7DEL02	1	4.188	175822	-----
MS1AEL15	2	3.983	219306	-----
MS1DEL15	2	3.983	219306	-----
MS7BEL06	1	3.901	204277	-----
MS7CEL06	1	3.901	204277	-----
MS7DEL06	1	3.901	204277	-----

MS7AEL03	1	3.901	204277	-----
MS1BTE01 (U/S)	15	3.711	225488	-----
MS1ATE01 (U/S)	15	3.711	225488	-----
MS1CTE01 (U/S)	15	3.711	225488	-----
MS1DTE01 (U/S)	15	3.711	225488	-----
MS7CSP02	53	3.710	225517	-----
MS7BSP02	53	3.710	225517	-----
MS7DSP02	53	3.710	225517	-----
MS7ASP02	53	3.710	225517	-----
MS1CSP19A	65	3.661	231432	-----
MS1ASP19A	65	3.661	231432	-----
MS1BSP19A	65	3.661	231432	-----
MS1DSP19A	65	3.661	231432	-----
MS1BEL09	2	3.547	245599	-----
MS1BEL10	2	3.547	245599	-----
MS1CEL09	2	3.547	245599	-----
MS1AEL11	2	3.547	245599	-----
MS1AEL10	2	3.547	245599	-----
MS1CEL10	2	3.547	245599	-----
MS1CEL11	2	3.547	245599	-----
MS1BEL11	2	3.547	245599	-----
MS1DEL10	2	3.547	245599	-----
MS1DEL11	2	3.547	245599	-----
MS1AEL09	2	3.547	245599	-----
MS1DEL09	2	3.547	245599	-----
MS1CTE01 (D/S)	15	3.266	284860	-----
MS1ATE01 (D/S)	15	3.266	284860	-----
MS1BTE01 (D/S)	15	3.266	284860	-----
MS1DTE01 (D/S)	15	3.266	284860	-----
MS1BSP15	52	3.092	312606	-----
MS1BEL12	2	3.102	341346	-----
MS7BSP06	52	3.092	312606	-----
MS1CEL12	2	3.102	341346	-----
MS7CSP06	52	3.092	312606	-----
MS1DEL12	2	3.102	341346	-----
MS7ASP06	52	3.092	312606	-----
MS1AEL12	2	3.102	341346	-----
MS7DSP06	52	3.092	312606	-----
MS1ASP13 DS	52	3.092	312606	-----
MS7DSP08	52	3.092	312606	-----
MS7ASP08	52	3.092	312606	-----
MS1ASP14 US	52	3.092	312606	-----
MS1BSP12 DS	52	3.092	312606	-----
MS1BSP12 US	52	3.092	312606	-----
MS1CSP15	52	3.092	312606	-----
MS1ASP14 DS	52	3.092	312606	-----
MS1CSP13	52	3.092	312606	-----
MS1BSP17	52	3.092	312606	-----
MS1CSP12 DS	52	3.092	312606	-----
MS1BSP19 DS	52	3.092	312606	-----
MS7BSP05 DS	52	3.092	312606	-----
MS1CSP17	52	3.092	312606	-----
MS7CSP05 DS	52	3.092	312606	-----
MS1ASP17	52	3.092	312606	-----
MS1CSP12 US	52	3.092	312606	-----
MS1DSP15	52	3.092	312606	-----
MS7BSP05 US	52	3.092	312606	-----
MS1DSP14 US	52	3.092	312606	-----
MS1DSP17	52	3.092	312606	-----
MS1CSP19 DS	52	3.092	312606	-----
MS1ASP19 US	52	3.092	312606	-----
MS1ASP19 DS	52	3.092	312606	-----
MS7CSP05 US	52	3.092	312606	-----
MS1DSP13 DS	52	3.092	312606	-----
MS1ASP13 US	52	3.092	312606	-----
MS1ASP15	52	3.092	312606	-----
MS1BSP13	52	3.092	312606	-----
MS1DSP19 DS	52	3.092	312606	-----
MS1CSP14	52	3.092	312606	-----
MS1BSP19 US	52	3.092	312606	-----
MS1DSP13 US	52	3.092	312606	-----
MS1CSP19 US	52	3.092	312606	-----
MS1DSP14 DS	52	3.092	312606	-----
MS1DSP19 US	52	3.092	312606	-----
MS1BSP14	52	3.092	312606	-----
MS7CSP03	51	2.721	383883	-----
MS7DSP05 US	51	2.721	383883	-----
MS7ASP05 US	51	2.721	383883	-----
MS7BSP03	51	2.721	383883	-----
MS7ASP05 DS	51	2.721	383883	-----
MS7DSP03	51	2.721	383883	-----
MS7BSP09	51	2.721	383883	-----
MS7CSP09	51	2.721	383883	-----
MS7DSP05 DS	51	2.721	383883	-----
MS7ASP03	51	2.721	383883	-----
MS1BSP14 DS	51	2.721	383883	-----

MS1DSP12 DS	58	2.177	-----	416019
MS1DSP21 DS	52	2.704	422431	-----
MS1BSP21 US	52	2.704	422431	-----
MS1ASP21 DS	52	2.704	422431	-----
MS1CSP21 DS	52	2.704	422431	-----
MS1DSP21 US	52	2.704	422431	-----
MS1CSP21 US	52	2.704	422431	-----
MS1ASP21 US	52	2.704	422431	-----
MS1BEL13	1	2.677	428784	-----
MS1AEL13	1	2.677	428784	-----
MS1DEL14	1	2.677	428784	-----
MS1DEL13	1	2.677	428784	-----
MS1BEL13	1	2.677	428784	-----
MS1BEL14	1	2.677	428784	-----
MS1CEL14	1	2.677	428784	-----
MS1AEL14	1	2.677	428784	-----
MS1BSP22 US	51	2.380	508685	-----
MS1BSP23 DS	51	2.380	508685	-----
MS7ASP09	56	2.139	-----	473077
MS1ASP22 DS	51	2.380	508685	-----
MS1ASP22 US	51	2.380	508685	-----
MS1CSP22 US	51	2.380	508685	-----
MS1DSP22 US	51	2.380	508685	-----
MS1DSP23 DS	51	2.380	508685	-----
MS1CSP22 DS	51	2.380	508685	-----
MS1DSP22 DS	51	2.380	508685	-----
MS1CSP23 DS	51	2.380	508685	-----
MS1BSP23 US	51	2.380	508685	-----
MS1CSP23 US	51	2.380	508685	-----
MS1DSP23 US	51	2.380	508685	-----
MS1ASP23 US	51	2.380	508685	-----
MS1BSP22 DS	51	2.380	508685	-----
MS1ASP12 DS	58	2.177	532305	-----
MS7CSP10 US	58	2.177	532305	-----
MS7ASP11 DS	58	2.177	532305	-----
MS7BSP10 US	58	2.177	532305	-----
MS7ASP11 US	58	2.177	532305	-----
MS1BSP11 US	58	2.177	532305	-----
MS1CSP11 DS	58	2.177	532305	-----
MS7DSP11 US	58	2.177	532305	-----
MS7CSP10 DS	58	2.177	532305	-----
MS1CSP11 US	58	2.177	532305	-----
MS7BSP10 DS	58	2.177	532305	-----
MS1ASP12 US	58	2.177	532305	-----
MS7DSP11 DS	58	2.177	532305	-----
MS1BSP11 DS	58	2.177	532305	-----
MS1DSP12 US	58	2.177	532305	-----
MS7CSP07	56	2.139	545399	-----
MS7DSP09	56	2.139	545399	-----
MS7BSP07	56	2.139	545399	-----
MS1DSP20	58	1.904	688291	-----
MS1ASP20	58	1.904	688291	-----
MS1BSP20	58	1.904	688291	-----
MS1CSP20	58	1.904	688291	-----
MS1CSP16	9	1.432	918655	-----
MS7DSP07	9	1.432	918655	-----
MS1BSP16	9	1.432	918655	-----
MS1CSP18	9	1.432	918655	-----
MS1DSP16	9	1.432	918655	-----
MS7ASP04	9	1.432	918655	-----
MS7CSP04	9	1.432	918655	-----
MS1DSP18	9	1.432	918655	-----
MS1ASP16	9	1.432	918655	-----
MS7ASP07	9	1.432	918655	-----
MS7DSP04	9	1.432	918655	-----
MS1ASP18	9	1.432	918655	-----
MS7BSP04	9	1.432	918655	-----
MS1BSP18	9	1.432	918655	-----
MS1ASP23 DS	9	1.174	1246356	-----
MS7AFE01	6	0.031	30037228	-----
MS7CFE01	6	0.031	30037228	-----
MS7BFE01	6	0.031	30037228	-----

 *** Wear Rate Analysis: Thickness/Service Time Report ***

Run Name: Main Steam 2006
 Ending Period: CYCLE 25
 Total Plant Operating Hours: 241618 Duty Factor (Global): 1.000
 WRA Data Option: Ignore NFA Exclude Measure Wear: No
 Line Correction Factor: 23.841

Component Name	----- Thickness (in) -----				Component Predicted[1]		Component Actual Service Time (hrs)
	Init.	Prd. [1]	Thoop	Tcrit	Time to Tcrit (hrs)	Inspected	

===>Grouped by Line: 074-18"-MS-01A, No Sorting.

MS1ASP12 US	0.938	0.878	0.726	0.726	532305	-----	241618
MS1ASP12 DS	0.938	0.878	0.726	0.726	532305	-----	241618
MS1AEL07	0.938	0.812	0.726	0.726	144749	-----	241618
MS1ASP13 US	0.938	0.853	0.726	0.726	312606	-----	241618
MS1ASP13 DS	0.938	0.853	0.726	0.726	312606	-----	241618
MS1AEL08	0.938	0.812	0.726	0.726	144749	-----	241618
MS1ASP14 US	0.938	0.853	0.726	0.726	312606	-----	241618

===>Grouped by Line: 074-18"-MS-07A, No Sorting.

RX NOZZLE N3A	0.938	0.733	0.726	0.726	7710	-----	241618
MS7ASP01	0.938	0.791	0.726	0.726	92438	-----	241618
MS7AEL01	0.938	0.815	0.726	0.726	153769	-----	241618
MS7ASP02	0.938	0.836	0.726	0.726	225517	-----	241618
MS7AEL02	0.938	0.822	0.726	0.726	175822	-----	241618
MS7ASP03	0.938	0.863	0.726	0.726	383883	-----	241618
MS7ASP04	0.938	0.899	0.726	0.726	918655	-----	241618
MS7AEL03	0.938	0.830	0.726	0.726	204277	-----	241618
MS7ASP05 US	0.938	0.863	0.726	0.726	383883	-----	241618
MS7ASP05 DS	0.938	0.863	0.726	0.726	383883	-----	241618
MS7AEL04	0.938	0.812	0.726	0.726	144749	-----	241618
MS7ASP06	0.938	0.853	0.726	0.726	312606	-----	241618
MS7ASP07	0.938	0.899	0.726	0.726	918655	-----	241618
MS7AEL05	0.938	0.812	0.726	0.726	144749	-----	241618
MS7ASP08	0.938	0.853	0.726	0.726	312606	-----	241618
MS7AFE01	0.938	0.937	0.814	0.814	30037228	-----	241618
MS7ASP09	0.938	0.859	0.726	0.726	-----	473077	241618
MS7AEL06	0.938	0.898	0.726	0.726	-----	287886	241618
MS7ASP10	0.938	0.807	0.726	0.726	130227	-----	241618
MS7AVA01	0.938	0.788	0.776	0.776	16821	-----	241618
MS7ASP11 US	0.938	0.878	0.726	0.726	532305	-----	241618
MS7ASP11 DS	0.938	0.878	0.726	0.726	532305	-----	241618
MS7AVA02	0.938	0.788	0.776	0.776	16821	-----	241618

===>Grouped by Line: 075-18"-MS-01A, No Sorting.

MS1ASP14 DS	0.938	0.853	0.726	0.726	312606	-----	241618
MS1AEL09	0.938	0.840	0.726	0.726	245599	-----	241618
MS1ASP15	0.938	0.853	0.726	0.726	312606	-----	241618
MS1ASP16	0.938	0.899	0.726	0.726	918655	-----	241618
MS1AEL10	0.938	0.840	0.726	0.726	245599	-----	241618
MS1ASP17	0.938	0.853	0.726	0.726	312606	-----	241618
MS1ASP18	0.938	0.899	0.726	0.726	918655	-----	241618
MS1AEL11	0.938	0.840	0.726	0.726	245599	-----	241618
MS1ASP19 US	0.938	0.853	0.726	0.726	312606	-----	241618
MS1ASP19 DS	0.938	0.853	0.726	0.726	312606	-----	241618
MS1ATE01 (U/S)	0.938	0.836	0.726	0.726	225488	-----	241618
MS1ATE01 (D/S)	0.938	0.848	0.726	0.726	284860	-----	241618
MS1ASP19A	0.938	0.837	0.726	0.726	231432	-----	241618
MS1AVA03	0.938	0.836	0.776	0.776	122646	-----	241618
MS1AVA04	1.031	0.900	0.862	0.862	60263	-----	241618
MS1ASP20	1.031	0.978	0.806	0.806	688291	-----	241618
MS1AEL12	1.031	0.945	0.806	0.806	341346	-----	241618
MS1ASP21 US	1.031	0.956	0.806	0.806	422431	-----	241618
MS1ASP21 DS	1.031	0.956	0.806	0.806	422431	-----	241618
MS1AEL13	1.031	0.957	0.806	0.806	428784	-----	241618
MS1ASP22 US	1.031	0.965	0.806	0.806	508685	-----	241618
MS1ASP22 DS	1.031	0.965	0.806	0.806	508685	-----	241618
MS1AEL14	1.031	0.957	0.806	0.806	428784	-----	241618
MS1ASP23 US	1.031	0.965	0.806	0.806	508685	-----	241618
MS1ASP23 DS	1.031	0.999	0.806	0.806	1246356	-----	241618
MS1AEL15	1.031	0.921	0.806	0.806	219306	-----	241618
INLET HP TURB	1.031	0.912	0.806	0.806	185233	-----	241618

===>Grouped by Line: 075-18"-MS-01B, No Sorting.

MS1BSP11 US	0.938	0.878	0.726	0.726	532305	-----	241618
MS1BSP11 DS	0.938	0.878	0.726	0.726	532305	-----	241618
MS1BEL07	0.938	0.812	0.726	0.726	144749	-----	241618
MS1BSP12 US	0.938	0.853	0.726	0.726	312606	-----	241618
MS1BSP12 DS	0.938	0.853	0.726	0.726	312606	-----	241618
MS1BEL08	0.938	0.812	0.726	0.726	144749	-----	241618
MS1BSP13	0.938	0.853	0.726	0.726	312606	-----	241618

==>Grouped by Line: 076-18"-MS-07B, No Sorting.

RX NOZZLE N3B	0.938	0.733	0.726	0.726	7710	-----	241618
MS7BSP01	0.938	0.791	0.726	0.726	92438	-----	241618
MS7BEL01	0.938	0.815	0.726	0.726	153769	-----	241618
MS7BSP02	0.938	0.836	0.726	0.726	225517	-----	241618
MS7BEL02	0.938	0.822	0.726	0.726	175822	-----	241618
MS7BSP03	0.938	0.863	0.726	0.726	383883	-----	241618
MS7BSP04	0.938	0.899	0.726	0.726	918655	-----	241618
MS7BEL03	0.938	0.812	0.726	0.726	144749	-----	241618
MS7BSP05 US	0.938	0.853	0.726	0.726	312606	-----	241618
MS7BSP05 DS	0.938	0.853	0.726	0.726	312606	-----	241618
MS7BEL04	0.938	0.812	0.726	0.726	144749	-----	241618
MS7BSP06	0.938	0.853	0.726	0.726	312606	-----	241618
MS7BFE01	0.938	0.937	0.814	0.814	30037228	-----	241618
MS7BSP07	0.938	0.879	0.726	0.726	545399	-----	241618
MS7BEL05	0.938	0.812	0.726	0.726	144749	-----	241618
MS7BSP08 US	0.938	0.807	0.726	0.726	130227	-----	241618
MS7BSP08 DS	0.938	0.807	0.726	0.726	130227	-----	241618
MS7BEL06	0.938	0.830	0.726	0.726	204277	-----	241618
MS7BSP09	0.938	0.863	0.726	0.726	383883	-----	241618
MS7BVA01	0.938	0.788	0.776	0.776	16821	-----	241618
MS7BSP10 US	0.938	0.878	0.726	0.726	532305	-----	241618
MS7BSP10 DS	0.938	0.878	0.726	0.726	532305	-----	241618
MS7BVA02	0.938	0.788	0.776	0.776	16821	-----	241618

==>Grouped by Line: 077-18"-MS-01B, No Sorting.

MS1BSP14	0.938	0.853	0.726	0.726	312606	-----	241618
MS1BEL09	0.938	0.840	0.726	0.726	245599	-----	241618
MS1BSP15	0.938	0.853	0.726	0.726	312606	-----	241618
MS1BSP16	0.938	0.899	0.726	0.726	918655	-----	241618
MS1BEL10	0.938	0.840	0.726	0.726	245599	-----	241618
MS1BSP17	0.938	0.853	0.726	0.726	312606	-----	241618
MS1BSP18	0.938	0.899	0.726	0.726	918655	-----	241618
MS1BEL11	0.938	0.840	0.726	0.726	245599	-----	241618
MS1BSP19 US	0.938	0.853	0.726	0.726	312606	-----	241618
MS1BSP19 DS	0.938	0.853	0.726	0.726	312606	-----	241618
MS1BTE01 (U/S)	0.938	0.836	0.726	0.726	225488	-----	241618
MS1BTE01 (D/S)	0.938	0.848	0.726	0.726	284860	-----	241618
MS1BSP19A	0.938	0.837	0.726	0.726	231432	-----	241618
MS1BVA03	0.938	0.836	0.776	0.776	122646	-----	241618
MS1BVA04	1.031	0.900	0.862	0.862	60263	-----	241618
MS1BSP20	1.031	0.978	0.806	0.806	688291	-----	241618
MS1BEL12	1.031	0.945	0.806	0.806	341346	-----	241618
MS1BSP21 US	1.031	0.956	0.806	0.806	422431	-----	241618
MS1BSP21 DS	1.031	0.956	0.806	0.806	422431	-----	241618
MS1BEL13	1.031	0.957	0.806	0.806	428784	-----	241618
MS1BSP22 US	1.031	0.965	0.806	0.806	508685	-----	241618
MS1BSP22 DS	1.031	0.965	0.806	0.806	508685	-----	241618
MS1BEL14	1.031	0.957	0.806	0.806	428784	-----	241618
MS1BSP23 US	1.031	0.965	0.806	0.806	508685	-----	241618
MS1BSP23 DS	1.031	0.965	0.806	0.806	508685	-----	241618
INLET HP TURB	1.031	0.912	0.806	0.806	185233	-----	241618

==>Grouped by Line: 078-18"-MS-01C, No Sorting.

MS1CSP11 US	0.938	0.878	0.726	0.726	532305	-----	241618
MS1CSP11 DS	0.938	0.878	0.726	0.726	532305	-----	241618
MS1CEL07	0.938	0.812	0.726	0.726	144749	-----	241618
MS1CSP12 US	0.938	0.853	0.726	0.726	312606	-----	241618
MS1CSP12 DS	0.938	0.853	0.726	0.726	312606	-----	241618
MS1CEL08	0.938	0.812	0.726	0.726	144749	-----	241618
MS1CSP13	0.938	0.853	0.726	0.726	312606	-----	241618

==>Grouped by Line: 078-18"-MS-07C, No Sorting.

RX NOZZLE N3C	0.938	0.733	0.726	0.726	7710	-----	241618
MS7CSP01	0.938	0.791	0.726	0.726	92438	-----	241618
MS7CEL01	0.938	0.815	0.726	0.726	153769	-----	241618
MS7CSP02	0.938	0.836	0.726	0.726	225517	-----	241618
MS7CEL02	0.938	0.822	0.726	0.726	175822	-----	241618
MS7CSP03	0.938	0.863	0.726	0.726	383883	-----	241618
MS7CSP04	0.938	0.899	0.726	0.726	918655	-----	241618
MS7CEL03	0.938	0.812	0.726	0.726	144749	-----	241618
MS7CSP05 US	0.938	0.853	0.726	0.726	312606	-----	241618
MS7CSP05 DS	0.938	0.853	0.726	0.726	312606	-----	241618

MS7CEL04	0.938	0.812	0.726	0.726	144749	-----	241618
MS7CSP06	0.938	0.853	0.726	0.726	312606	-----	241618
MS7CFE01	0.938	0.937	0.814	0.814	30037228	-----	241618
MS7CSP07	0.938	0.879	0.726	0.726	545399	-----	241618
MS7CEL05	0.938	0.812	0.726	0.726	144749	-----	241618
MS7CSP08 US	0.938	0.807	0.726	0.726	130227	-----	241618
MS7CSP08 DS	0.938	0.807	0.726	0.726	130227	-----	241618
MS7CEL06	0.938	0.830	0.726	0.726	204277	-----	241618
MS7CSP09	0.938	0.863	0.726	0.726	383883	-----	241618
MS7CVA01	0.938	0.788	0.776	0.776	16821	-----	241618
MS7CSP10 US	0.938	0.878	0.726	0.726	532305	-----	241618
MS7CSP10 DS	0.938	0.878	0.726	0.726	532305	-----	241618
MS7CVA02	0.938	0.788	0.776	0.776	16821	-----	241618

==>Grouped by Line: 079-18"-MS-01C, No Sorting.

MS1CSP14	0.938	0.853	0.726	0.726	312606	-----	241618
MS1CEL09	0.938	0.840	0.726	0.726	245599	-----	241618
MS1CSP15	0.938	0.853	0.726	0.726	312606	-----	241618
MS1CSP16	0.938	0.899	0.726	0.726	918655	-----	241618
MS1CEL10	0.938	0.840	0.726	0.726	245599	-----	241618
MS1CSP17	0.938	0.853	0.726	0.726	312606	-----	241618
MS1CSP18	0.938	0.899	0.726	0.726	918655	-----	241618
MS1CEL11	0.938	0.840	0.726	0.726	245599	-----	241618
MS1CSP19 US	0.938	0.853	0.726	0.726	312606	-----	241618
MS1CSP19 DS	0.938	0.853	0.726	0.726	312606	-----	241618
MS1CTE01 (U/S)	0.938	0.836	0.726	0.726	225488	-----	241618
MS1CTE01 (D/S)	0.938	0.848	0.726	0.726	284860	-----	241618
MS1CSP19A	0.938	0.837	0.726	0.726	231432	-----	241618
MS1CVA03	0.938	0.836	0.776	0.776	122646	-----	241618
MS1CVA04	1.031	0.900	0.862	0.862	60263	-----	241618
MS1CSP20	1.031	0.978	0.806	0.806	688291	-----	241618
MS1CEL12	1.031	0.945	0.806	0.806	341346	-----	241618
MS1CSP21 US	1.031	0.956	0.806	0.806	422431	-----	241618
MS1CSP21 DS	1.031	0.956	0.806	0.806	422431	-----	241618
MS1BEL13	1.031	0.957	0.806	0.806	428784	-----	241618
MS1CSP22 US	1.031	0.965	0.806	0.806	508685	-----	241618
MS1CSP22 DS	1.031	0.965	0.806	0.806	508685	-----	241618
MS1CEL14	1.031	0.957	0.806	0.806	428784	-----	241618
MS1CSP23 US	1.031	0.965	0.806	0.806	508685	-----	241618
MS1CSP23 DS	1.031	0.965	0.806	0.806	508685	-----	241618
INLET HP TURB	1.031	0.912	0.806	0.806	185233	-----	241618

==>Grouped by Line: 080-18"-MS-01D, No Sorting.

MS1DSP12 US	0.938	0.878	0.726	0.726	532305	-----	241618
MS1DSP12 DS	0.938	0.845	0.726	0.726	-----	416019	241618
MS1DEL07	0.938	0.967	0.726	0.726	-----	403549	241618
MS1DSP13 US	0.938	0.853	0.726	0.726	312606	-----	241618
MS1DSP13 DS	0.938	0.853	0.726	0.726	312606	-----	241618
MS1DEL08	0.938	0.812	0.726	0.726	144749	-----	241618
MS1DSP14 US	0.938	0.853	0.726	0.726	312606	-----	241618

==>Grouped by Line: 080-18"-MS-07D, No Sorting.

RX NOZZLE N3D	0.938	0.733	0.726	0.726	7710	-----	241618
MS7DSP01	0.938	0.791	0.726	0.726	92438	-----	241618
MS7DEL01	0.938	0.815	0.726	0.726	153769	-----	241618
MS7DSP02	0.938	0.836	0.726	0.726	225517	-----	241618
MS7DEL02	0.938	0.822	0.726	0.726	175822	-----	241618
MS7DSP03	0.938	0.863	0.726	0.726	383883	-----	241618
MS7DSP04	0.938	0.899	0.726	0.726	918655	-----	241618
MS7DEL03	0.938	0.830	0.726	0.726	204277	-----	241618
MS7DSP05 US	0.938	0.863	0.726	0.726	383883	-----	241618
MS7DSP05 DS	0.938	0.863	0.726	0.726	383883	-----	241618
MS7DEL04	0.938	0.812	0.726	0.726	144749	-----	241618
MS7DSP06	0.938	0.853	0.726	0.726	312606	-----	241618
MS7DSP07	0.938	0.899	0.726	0.726	918655	-----	241618
MS7DEL05	0.938	0.812	0.726	0.726	144749	-----	241618
MS7DSP08	0.938	0.853	0.726	0.726	312606	-----	241618
MS7DFE01	0.938	0.937	0.814	0.814	30037228	-----	241618
MS7DSP09	0.938	0.879	0.726	0.726	545399	-----	241618
MS7DEL06	0.938	0.812	0.726	0.726	144749	-----	241618
MS7DSP10	0.938	0.807	0.726	0.726	130227	-----	241618
MS7DVA01	0.938	0.788	0.776	0.776	16821	-----	241618
MS7DSP11 US	0.938	0.878	0.726	0.726	532305	-----	241618
MS7DSP11 DS	0.938	0.878	0.726	0.726	532305	-----	241618
MS7DVA02	0.938	0.788	0.776	0.776	16821	-----	241618

==>Grouped by Line: 081-18"-MS-01D, No Sorting.

MS1DSP14 DS	0.938	0.853	0.726	0.726	312606	-----	241618
MS1DEL09	0.938	0.840	0.726	0.726	245599	-----	241618
MS1DSP15	0.938	0.853	0.726	0.726	312606	-----	241618
MS1DSP16	0.938	0.899	0.726	0.726	918655	-----	241618
MS1DSP17	0.938	0.840	0.726	0.726	245599	-----	241618

MS1DSP17	0.938	0.853	0.726	0.726	312606	-----	241618
MS1DSP18	0.938	0.899	0.726	0.726	918655	-----	241618
MS1DEL11	0.938	0.840	0.726	0.726	245599	-----	241618
MS1DSP19 US	0.938	0.853	0.726	0.726	312606	-----	241618
MS1DSP19 DS	0.938	0.853	0.726	0.726	312606	-----	241618
MS1DTE01 (U/S)	0.938	0.836	0.726	0.726	225488	-----	241618
MS1DTE01 (D/S)	0.938	0.848	0.726	0.726	284860	-----	241618
MS1DSP19A	0.938	0.837	0.726	0.726	231432	-----	241618
MS1DVA03	0.938	0.836	0.776	0.776	122646	-----	241618
MS1DVA04	1.031	0.900	0.862	0.862	60263	-----	241618
MS1DSP20	1.031	0.978	0.806	0.806	688291	-----	241618
MS1DEL12	1.031	0.945	0.806	0.806	341346	-----	241618
MS1DSP21 US	1.031	0.956	0.806	0.806	422431	-----	241618
MS1DSP21 DS	1.031	0.956	0.806	0.806	422431	-----	241618
MS1DEL13	1.031	0.957	0.806	0.806	428784	-----	241618
MS1DSP22 US	1.031	0.965	0.806	0.806	508685	-----	241618
MS1DSP22 DS	1.031	0.965	0.806	0.806	508685	-----	241618
MS1DEL14	1.031	0.957	0.806	0.806	428784	-----	241618
MS1DSP23 US	1.031	0.965	0.806	0.806	508685	-----	241618
MS1DSP23 DS	1.031	0.965	0.806	0.806	508685	-----	241618
MS1DEL15	1.031	0.921	0.806	0.806	219306	-----	241618
INLET HP TURB	1.031	0.912	0.806	0.806	185233	-----	241618

Note:

[1] Predictions are based on last Tmeas to analysis ending period.



Wear Rate Analysis Run Definition

Run Name: Cond2006 E4 to E3

Run Title: Condensate Hrs E4A,B to E3A,B

Ending Period: CYCLE 25

Total Oper. Hrs.: 241618.44

Duty Factor: 1.000

Analysis Options:

- Ignore IFA Results
- IFA Results 1st Priority
- User Input 1st Priority
- Do Not Use Measured Wear

Database Lines	Add	Remove	Lines to Analyze
001-16"-FDW-01	>	<	032-20"-C-27
002-16"-FDW-02	>>	<<	033-20"-C-28
003-16"-FDW-03			
004-24"-FDW-01			
005-18"-FDW-07			
006-18"-FDW-07			
007-18"-FDW-12			
008-16"-FDW-14			


Run Definitions:

- 36" MS Inlet piping
- 3rd Pt Extract Steam
- 3rd Pt Heater Drain
- 3rd Pt High Level
- 4th Pt Extract Steam
- 4th Pt Heater Drain
- 4th Pt High Level
- 5th Pt Extract Steam
- 5th Pt Heater Drains
- Cond LP Hdr Bypass
- Cond Minimum Flow
- Cond2006 E3 to 3 FWP
- Cond2006 E4 to E3**
- Condensate
- FDW 2006 E1a to Rx
- FDW 2006 Hdr to E2s
- FDW06 2 P1s to Hdr.
- FDW06 3-P1s to Hdr
- FDW2006 E2s to E1s


< Prev	Next >	Add	Reset	Save
Copy	Delete	Print...	Help	Done

List of Defined Wear Rate Runs

197




Comparison of Wear Predictions



143

Comparison of Thickness Predictions



◆ Current Component

hhl



Company: Vermont Yankee Nuclear Power Corporation Report Date: 28-SEP-2006 Time: 08:32:16
 Plant: Vermont Yankee Analysis Date: 28-SEP-2006 Time: 08:29:41
 Unit: CHECWORKS FAC Version 1.0F (Build 52)
 Db Name: VY

 Wear Rate Analysis: Combined Summary Report

Run Name: VANDUO6 E4 to E3
 Ending Period: CYCLE 25
 Total Plant Operating Hours: 241618 Duty Factor (Global): 1.000
 WRA Data Option: Ignore NFA Exclude Measure Wear: No
 Line Correction Factor: 0.960

Component Name	Geom. Code	Average Wear Rate (mils/year)	Current Wear Rate (mils/year)	Thickness (in)			Component Predict(1)		Total Lifetime Wear (mils)		In-Service Cmp. Wear (mils)		In-Service Cmp. Tmeas, Method, Time (in) [4] [3] (hrs) [4]		Time (hrs) Last Inspected			
				Init.	Prd. [1]	Thoop	Tcrit	Time to Tcrit (hrs) Non- Insp.	Insp.	Prd. [2]	Meas.	Prd. [2]	Meas.	(in) [4]		[3]	(hrs) [4]	
---Grouped by Line: 032-20*-C-27, No Sorting.																		
OUTLET NOZZLE E-4-1A	31	7.134	6.571	0.812	0.727	0.394	0.394	444354	---	---	---	---	0.812	---	137270			
CD27EL01	3	5.883	4.466	0.594	0.432	0.394	0.394	74624	---	---	---	---	0.594	---	0			
CD27SP01	53	4.202	3.190	0.594	0.478	0.394	0.394	231778	---	---	---	---	0.594	---	0			
CD27EL02	4	6.219	4.721	0.594	0.422	0.394	0.394	53387	---	---	---	---	0.594	---	0			
CD27SP02	54	5.378	4.083	0.594	0.446	0.394	0.394	111457	---	---	---	---	0.594	---	0			
CD27EL03	2	6.219	4.721	0.594	0.422	0.394	0.394	53387	---	---	---	---	0.594	---	0			
CD27SP03	52	4.202	3.190	0.594	0.478	0.394	0.394	231778	---	---	---	---	0.594	---	0			
CD27SEL03A	9	1.888	1.433	0.594	0.542	0.394	0.394	906060	---	---	---	---	0.594	---	0			
CD27EL04	2	6.219	4.721	0.594	0.422	0.394	0.394	53387	---	---	---	---	0.594	---	0			
CD27SP04	52	4.202	3.190	0.594	0.478	0.394	0.394	231778	---	---	---	---	0.594	---	0			
CD27EL05	1	5.546	4.211	0.594	0.441	0.394	0.394	98435	---	---	---	---	0.594	---	0			
CD27EL06	3	5.883	4.466	0.594	0.432	0.394	0.394	74624	---	---	---	---	0.594	---	0			
CD27SP05	53	4.202	3.190	0.594	0.478	0.394	0.394	231778	---	---	---	---	0.594	---	0			
CD27EL07	2	6.219	4.721	0.594	0.422	0.394	0.394	53387	---	---	---	---	0.594	---	0			
CD27SP06	52	4.202	3.190	0.594	0.478	0.394	0.394	231778	---	---	---	---	0.594	---	0			
CD27EL08	2	6.219	4.721	0.594	0.422	0.394	0.394	53387	---	---	---	---	0.594	---	0			
CD27EL09	4	6.219	4.721	0.594	0.422	0.394	0.394	53387	---	---	---	---	0.594	---	0			
CD27SP07	54	5.378	4.083	0.594	0.446	0.394	0.394	111457	---	---	---	---	0.594	---	0			
CD27EL10	2	6.219	4.721	0.594	0.422	0.394	0.394	53387	---	---	---	---	0.594	---	0			
CD27SP08	52	4.202	3.190	0.594	0.478	0.394	0.394	231778	---	---	---	---	0.594	---	0			
CD27EL11	1	5.546	4.211	0.594	0.441	0.394	0.394	98435	---	---	---	---	0.594	---	0			
CD27EL12	4	6.219	4.721	0.594	0.422	0.394	0.394	53387	---	455148	144.5	140.0	144.5	140.0	0.666	GW	195618	195618
CD27EL13	3	5.883	4.466	0.594	0.713	0.394	0.394	627208	---	136.7	141.0	136.7	141.0	0.739	GW	195618	195618	
INLET NOZZLE E-3-1A	30	5.746	5.104	0.594	0.518	0.394	0.394	213519	---	---	---	---	0.594	---	125911			

---Grouped by Line: 033-20*-C-28, No Sorting.

OUTLET NOZZLE E-4-1B	31	7.134	6.571	0.812	0.727	0.394	0.394	444354	---	---	---	---	0.812	---	137270
CD28EL01	61	4.538	3.445	0.594	0.469	0.394	0.394	191034	---	---	---	---	0.594	---	0
CD28EL02	4	6.219	4.721	0.594	0.422	0.394	0.394	53387	---	---	---	---	0.594	---	0
CD28EL03	4	6.219	4.721	0.594	0.422	0.394	0.394	53387	---	---	---	---	0.594	---	0
CD28SP02	54	5.378	4.083	0.594	0.446	0.394	0.394	111457	---	---	---	---	0.594	---	0
CD28SEL02A	9	1.888	1.433	0.594	0.542	0.394	0.394	906060	---	---	---	---	0.594	---	0
CD28EL04	2	6.219	4.721	0.594	0.422	0.394	0.394	53387	---	---	---	---	0.594	---	0
CD28EL04	4	6.219	4.721	0.594	0.422	0.394	0.394	53387	---	---	---	---	0.594	---	0
CD28SP03	54	5.378	4.083	0.594	0.446	0.394	0.394	111457	---	---	---	---	0.594	---	0
CD28EL05	2	6.219	4.721	0.594	0.422	0.394	0.394	53387	---	---	---	---	0.594	---	0
CD28SP04	52	4.202	3.190	0.594	0.478	0.394	0.394	231778	---	---	---	---	0.594	---	0
CD28EL06	2	6.219	4.721	0.594	0.422	0.394	0.394	53387	---	---	---	---	0.594	---	0
CD28SP05	52	4.202	3.190	0.594	0.478	0.394	0.394	231778	---	---	---	---	0.594	---	0
CD28EL07	2	6.219	4.721	0.594	0.422	0.394	0.394	53387	---	---	---	---	0.594	---	0
CD28SP06	52	4.202	3.190	0.594	0.478	0.394	0.394	231778	---	---	---	---	0.594	---	0
CD28EL08	1	5.546	4.211	0.594	0.441	0.394	0.394	98435	---	---	---	---	0.594	---	0
CD28EL09	4	6.219	4.721	0.594	0.422	0.394	0.394	53387	---	---	---	---	0.594	---	0
CD28EL10	3	5.883	4.466	0.594	0.432	0.394	0.394	74624	---	---	---	---	0.594	---	0
INLET NOZZLE E-3-1B	30	5.746	5.104	0.594	0.518	0.394	0.394	213519	---	---	---	---	0.594	---	125911

Notes:

- (1) Predictions are based on last Tmeas to analysis ending period.
- (2) Predictions are for the time of last inspection (last known meas. wear).
- (3) GW = Tmeas is minimum thickness from Band, Blanket or Area Method of greatest wear.
 MT = Tmeas is component minimum thickness.
 PW = Tmeas is Tinit - predicted wear.
 US = Tmeas is user specified.
- (4) If no Tmeas has been determined from measured data, then Tmeas = Tinit and Time = current component installation time.
 Tmeas is used to determine Predicted Thickness and Component Predicted Time to Tcrit.

SCHEDULED FOR INSPECTION IS RPO26

145

Company: Vermont Yankee Nuclear Power Corporation Report Date: 28-SEP-2006 Time: 08:32:11
 Plant: Vermont Yankee Analysis Date: 28-SEP-2006 Time: 08:29:41
 Unit: CHECWORKS FAC Version 1.0F (Build 52)
 DB Name: VY

 *** Wear Rate Analysis: Wear Predictions Report ***

Run Name: Cond200b E4 to E3
 Ending Period: CYCLE 05
 Total Plant Operating Hours: 241618 Duty Factor (Global): 1.000
 WRA Data Options: Ignore NFA Exclude Measure Wear: No
 Line Correction Factor: 0.600

Component Name	Total Lifetime Wear (mils)		In-Service Wear (mils)		In-Service Tmeas, Method, Time (in) [3] [2] (hrs) [3]		In-Service Thickness (mils) [4] Tp Tm		Incremental PRWEAR	Time (hrs) Last Inspected
	Prd. [1]	Meas.	Prd. [1]	Meas.						

---Grouped by Line: 032-20*-C-27, No Sorting.

CD37EL12	144.5	140.0	144.5	140.0	0.666	GW	195618	449.5	666.0	27.0	195618
CD37EL13	136.7	141.0	136.7	141.0	0.739	GW	195618	457.3	739.0	25.5	195618

---Grouped by Line: 033-20*-C-28, No Sorting.

Notes:

- [1] Predictions are for the time of last inspection (last known meas. wear).
- [2] GW - Tmeas is minimum thickness from Band, Blanket or Area Method of greatest wear.
 MF - Tmeas is component minimum thickness.
 PW - Tmeas is Tinit - predicted wear.
 US - Tmeas is user specified.
- [3] If no Tmeas has been determined from measured data, then Tmeas = Tinit and Time = current component installation time.
 Tmeas is used to determine Predicted Thickness and Component Predicted Time to Tcrit.
- [4] These two values are used for thickness plot.
 Tp = Predicted thickness at Tmeas.
 Tm = Last measured thickness (Tmeas).
- [5] PRWEAR = incremental wear from last Tmeas time to analysis ending period.

146

Company: Vermont Yankee Nuclear Power Corporation Report Date: 28-SEP-2006 Time: 08:32:07
 Plant: Vermont Yankee Analysis Date: 28-SEP-2006 Time: 08:29:41
 Unit: CHECWORKS FAC Version 1.0F (Build 52)
 UR Name: VY

 *** Wear Rate Analysis: Combined Rankings for Inspection ***

Run Name: Cond2006 E4 to E3
 Ending Period: CYCLE 35
 Total Plant Operating Hours: 241618
 N/A Data Option: Ignore N/A
 Line Correction Factor: 0.600
 Duty Factor (Global): 1.000
 Exclude Measure Wear: No

Component Name	Geometry Code	Average Wear Rate (mils/year)	Component Predicted Time to Tcrit (hrs)	
			Non-Inspected	Inspected
CDLREL10	3	5.883	74624	-----
CD08EL06	2	6.219	53387	-----
CD07SP07	54	5.378	111457	-----
OUTLET NOZZLE E-4-1B	31	7.134	444354	-----
OUTLET NOZZLE E-4-1A	31	7.134	444354	-----
CD08EL04	4	6.219	53387	-----
CD08EL05 *	4	6.219	53387	-----
CD08EL06	2	6.219	53387	-----
CD08EL12	4	6.219	-----	455148
CD07EL04	4	6.219	53387	-----
CD07EL03	2	6.219	53387	-----
CD07EL05	4	6.219	53387	-----
CD08EL07	2	6.219	53387	-----
CD07EL04	2	6.219	53387	-----
CD08EL03	2	6.219	53387	-----
CD07EL08	2	6.219	53387	-----
CD08EL01	4	6.219	53387	-----
CD08EL09	4	6.219	53387	-----
CD07EL07	2	6.219	53387	-----
CD07EL10	2	6.219	53387	-----
CD07EL01	3	5.883	74624	-----
CD07EL06	1	5.883	74624	-----
CD07EL13	3	5.883	-----	627208
CD07EL02	1	5.546	98435	-----
CD08EL02 *	1	5.546	98435	-----
CD08EL11	1	5.546	98435	-----
CD08SP01	54	5.378	111457	-----
INLET NOZZLE E-3-1A	30	5.746	213519	-----
INLET NOZZLE E-3-1B	30	5.746	213519	-----
CD08SP02	54	5.378	111457	-----
CD07SP02	54	5.378	111457	-----
CD08SP01	61	4.538	191034	-----
CD08SP06	52	4.202	231778	-----
CD07SP01	53	4.202	231778	-----
CD07SP04	52	4.202	231778	-----
CD08SP04	52	4.202	231778	-----
CD07SP03	52	4.202	231778	-----
CD07SP05	53	4.202	231778	-----
CD08SP05	52	4.202	231778	-----
CD07SP06	52	4.202	231778	-----
CD07SP08	52	4.202	231778	-----
CD08SP02A	9	1.888	906060	-----
CD07SP03a	9	1.888	906060	-----

* SCHEDULED FOR INSPECTION in R026

647

 *** Wear Rate Analysis: Thickness; Service Time Report ***

Run Name: 0302006 E4 to E5
 Ending Period: CYCLE 25
 Total Plant Operating Hours: 241618 Duty Factor (Global): 1.000
 NFA Data Option: Ignore NFA Exclude Measure Wear: No
 Line Correction Factor: 0.000

Component Name	Thickness (in)				Component Predicted [1]		Component Actual
	Init.	Prd. [1]	Thoop	Tcrit	Time to Tcrit (hrs)	Non-Inspected	Service Time (hrs)

====Grouped by Line: 032-20*-C-27, No Sorting.

OUTLET NOZZLE E-4-1A	0.812	0.727	0.394	0.394	444354	-----	104347
CD37EL01	0.594	0.432	0.394	0.394	74624	-----	241618
CD37EL01	0.594	0.478	0.394	0.394	231778	-----	241618
CD37EL02	0.594	0.422	0.394	0.394	53387	-----	241618
CD37EL02	0.594	0.446	0.394	0.394	111457	-----	241618
CD37EL03	0.594	0.422	0.394	0.394	53387	-----	241618
CD37SP03	0.594	0.478	0.394	0.394	231778	-----	241618
CD37SP03A	0.594	0.542	0.394	0.394	906060	-----	241618
CD37EL04	0.594	0.422	0.394	0.394	53387	-----	241618
CD37SP04	0.594	0.478	0.394	0.394	231778	-----	241618
CD37EL05	0.594	0.441	0.394	0.394	98435	-----	241618
CD37EL06	0.594	0.432	0.394	0.394	74624	-----	241618
CD37SP05	0.594	0.478	0.394	0.394	231778	-----	241618
CD37EL07	0.594	0.422	0.394	0.394	53387	-----	241618
CD37SP06	0.594	0.478	0.394	0.394	231778	-----	241618
CD37EL08	0.594	0.422	0.394	0.394	53387	-----	241618
CD37EL09	0.594	0.422	0.394	0.394	53387	-----	241618
CD37SP07	0.594	0.446	0.394	0.394	111457	-----	241618
CD37EL10	0.594	0.422	0.394	0.394	53387	-----	241618
CD37SP08	0.594	0.478	0.394	0.394	231778	-----	241618
CD37EL11	0.594	0.441	0.394	0.394	98435	-----	241618
CD37EL12	0.594	0.639	0.394	0.394	-----	455148	241618
CD37EL13	0.594	0.713	0.394	0.394	-----	627208	241618
INLET NOZZLE E-3 1A	0.594	0.518	0.394	0.394	213519	-----	115707

====Grouped by Line: 033-20*-C-28, No Sorting.

OUTLET NOZZLE E-4-1B	0.812	0.727	0.394	0.394	444354	-----	104347
CD38SP01	0.594	0.469	0.394	0.394	191034	-----	241618
CD38EL01	0.594	0.422	0.394	0.394	53387	-----	241618
CD38EL02	0.594	0.422	0.394	0.394	53387	-----	241618
CD38SP02	0.594	0.446	0.394	0.394	111457	-----	241618
CD38SP02A	0.594	0.542	0.394	0.394	906060	-----	241618
CD38EL03	0.594	0.422	0.394	0.394	53387	-----	241618
CD38EL04	0.594	0.422	0.394	0.394	53387	-----	241618
CD38SP05	0.594	0.446	0.394	0.394	111457	-----	241618
CD38EL05	0.594	0.422	0.394	0.394	53387	-----	241618
CD38EL06	0.594	0.478	0.394	0.394	231778	-----	241618
CD38EL06	0.594	0.422	0.394	0.394	53387	-----	241618
CD38SP05	0.594	0.478	0.394	0.394	231778	-----	241618
CD38EL07	0.594	0.422	0.394	0.394	53387	-----	241618
CD38SP06	0.594	0.478	0.394	0.394	231778	-----	241618
CD38EL08	0.594	0.441	0.394	0.394	98435	-----	241618
CD38EL09	0.594	0.422	0.394	0.394	53387	-----	241618
CD38EL10	0.594	0.432	0.394	0.394	74624	-----	241618
INLET NOZZLE E-3 1B	0.594	0.518	0.394	0.394	213519	-----	115707

Note:
 [1] Predictions are based on last Tmeas to analysis ending period.

SCHEDULED FOR INSPECTION IN R026

148

Company: Vermont Yankee Nuclear Power Corporation Report Date: 28-SEP-2006 Time: 08:31:59
 Plant: Vermont Yankee Analysis Date: 28-SEP-2006 Time: 08:29:41
 Unit: CHECWORKS FAC Version 1.0F (Build 52)
 Db Name: VY

*** Wear Rate Analysis: Inspection History Report ***

Run Name: Cond2006 E4 to E3
 Ending Period: CYCLE 25
 Total Plant Operating Hours: 24168 Duty Factor (Global): 1.000
 WRA Data Option: Ignore NFA Exclude Measure Wear: No
 Line Correction Factor: 0.600

Component Name	Geom. Code	No.	Material			Sigma (psi)	Time (hrs)		Analysis Option	Measured Wear (mils)
			Cr. (%)	Cu. (%)	Mo. (%)		Last Inspected	Replaced		

=== Grouped by Line: 030-20*-C-27, No Sorting.

OUTLET NOZZLE E-4-1A	31	5	0.00	0.00	0.00	15000	----	----	----
*Replacement #1	31	5	0.00	0.00	0.00	15000	----	137270	----
CD27EL01	3	21	0.00	0.00	0.00	15000	----	----	----
CD27SP01	54	5	0.00	0.00	0.00	15000	----	----	----
CD27EL02	4	21	0.00	0.00	0.00	15000	----	----	----
CD27SP02	54	5	0.00	0.00	0.00	15000	----	----	----
CD27EL03	2	21	0.00	0.00	0.00	15000	----	----	----
CD27SP03	52	5	0.00	0.00	0.00	15000	----	----	----
CD27SP03A	9	5	0.00	0.00	0.00	15000	----	----	----
CD27EL04	2	21	0.00	0.00	0.00	15000	----	----	----
CD27SP04	52	5	0.00	0.00	0.00	15000	----	----	----
CD27EL05	1	21	0.00	0.00	0.00	15000	----	----	----
CD27EL06	3	21	0.00	0.00	0.00	15000	----	----	----
CD27SP05	54	5	0.00	0.00	0.00	15000	----	----	----
CD27EL07	2	21	0.00	0.00	0.00	15000	----	----	----
CD27SP06	52	5	0.00	0.00	0.00	15000	----	----	----
CD27EL08	3	21	0.00	0.00	0.00	15000	----	----	----
CD27EL09	4	21	0.00	0.00	0.00	15000	----	----	----
CD27SP07	54	5	0.00	0.00	0.00	15000	----	----	----
CD27EL10	2	21	0.00	0.00	0.00	15000	----	----	----
CD27SP08	52	5	0.00	0.00	0.00	15000	----	----	----
CD27EL11	1	21	0.00	0.00	0.00	15000	----	----	----
CD27EL12	4	21	0.00	0.00	0.00	15000	195618	----	140
CD27EL13	3	21	0.00	0.00	0.00	15000	195618	----	141
INLET NOZZLE E-3-1A	30	5	0.00	0.00	0.00	15000	----	----	----
*Replacement #1	30	5	0.00	0.00	0.00	15000	----	125911	----

=== Grouped by Line: 033-20*-C-28, No Sorting.

OUTLET NOZZLE E-4-1b	31	5	0.00	0.00	0.00	15000	----	----	----
*Replacement #1	31	5	0.00	0.00	0.00	15000	----	137270	----
CD28NP01	61	5	0.00	0.00	0.00	15000	----	----	----
CD28EL01	4	21	0.00	0.00	0.00	15000	----	----	----
CD28EL02	4	21	0.00	0.00	0.00	15000	----	----	----
CD28SP02	54	5	0.00	0.00	0.00	15000	----	----	----
CD28SP02A	9	5	0.00	0.00	0.00	15000	----	----	----
CD28EL03	2	21	0.00	0.00	0.00	15000	----	----	----
CD28EL04	4	21	0.00	0.00	0.00	15000	----	----	----
CD28SP03	54	5	0.00	0.00	0.00	15000	----	----	----
CD28EL05	2	21	0.00	0.00	0.00	15000	----	----	----
CD28SP04	52	5	0.00	0.00	0.00	15000	----	----	----
CD28EL06	2	21	0.00	0.00	0.00	15000	----	----	----
CD28SP05	52	5	0.00	0.00	0.00	15000	----	----	----
CD28EL07	2	21	0.00	0.00	0.00	15000	----	----	----
CD28SP06	52	5	0.00	0.00	0.00	15000	----	----	----
CD28EL08	1	21	0.00	0.00	0.00	15000	----	----	----
CD28EL09	4	21	0.00	0.00	0.00	15000	----	----	----
CD28EL10	3	21	0.00	0.00	0.00	15000	----	----	----
INLET NOZZLE E-3-1B	30	5	0.00	0.00	0.00	15000	----	----	----
*Replacement #1	30	5	0.00	0.00	0.00	15000	----	125911	----

149

Company: Vermont Yankee Nuclear Power Corporation Report Date: 28-SEP-2006 Time: 08:31:50
 Plant: Vermont Yankee Analysis Date: 28-SEP-2006 Time: 08:29:41
 Unit: CHECWORKS FAC Version 1.0P (Build 52)
 Db Name: VT

 *** Wear Rate Analysis: Wear Rates/Input Data Report ***

Run Name: Trn1000 E4 to E3
 Ending Period: CYCLE 25
 Total Plant Operating Hours: 241618 Duty Factor (Global): 1.000
 NFA Data Option: Ignore NFA Exclude Measure Wear: No
 Line Correction Factor: 0.600

Component Name	Geom. Code	Average Wear Rate (mils/year)	Current Wear Rate (mils/year)	Temp. (F)	Velocity (ft/s)	Steam Quality	Diameter (in)
----------------	------------	-------------------------------	-------------------------------	-----------	-----------------	---------------	---------------

====Grouped by Line: 032-20*-C-27, No Sorting.


OUTLET NOZZLE E-4-1A	31	7.134	6.571	229.0	8.138	0.000	20.000
CD27EL01	3	5.563	4.466	229.0	7.765	0.000	20.000
CD27SP01	53	4.202	3.190	229.0	7.765	0.000	20.000
CD27EL02	4	6.219	4.721	229.0	7.765	0.000	20.000
CD27SP02	54	5.378	4.083	229.0	7.765	0.000	20.000
CD27EL03	2	6.219	4.721	229.0	7.765	0.000	20.000
CD27SP03	52	4.202	3.190	229.0	7.765	0.000	20.000
CD27SP03A	9	1.888	1.433	229.0	7.765	0.000	20.000
CD27EL04	2	6.219	4.721	229.0	7.765	0.000	20.000
CD27SP04	52	4.202	3.190	229.0	7.765	0.000	20.000
CD27EL05	1	5.546	4.211	229.0	7.765	0.000	20.000
CD27EL06	2	5.883	4.466	229.0	7.765	0.000	20.000
CD27SP05	53	4.202	3.190	229.0	7.765	0.000	20.000
CD27EL07	2	6.219	4.721	229.0	7.765	0.000	20.000
CD27SP06	52	4.202	3.190	229.0	7.765	0.000	20.000
CD27EL08	2	6.219	4.721	229.0	7.765	0.000	20.000
CD27EL09	4	6.219	4.721	229.0	7.765	0.000	20.000
CD27SP07	54	5.378	4.083	229.0	7.765	0.000	20.000
CD27EL10	3	6.219	4.721	229.0	7.765	0.000	20.000
CD27SP08	52	4.202	3.190	229.0	7.765	0.000	20.000
CD27EL11	1	5.546	4.211	229.0	7.765	0.000	20.000
CD27EL12	4	6.219	4.721	229.0	7.765	0.000	20.000
CD27EL13	3	5.883	4.466	229.0	7.765	0.000	20.000
INLET NOZZLE E-4-1A	30	5.746	5.104	229.0	7.765	0.000	20.000

====Grouped by Line: 033-20*-C-28, No Sorting.

OUTLET NOZZLE E-4-1B	31	7.134	6.571	229.0	8.138	0.000	20.000
CD28EL01	61	4.538	3.445	229.0	7.765	0.000	20.000
CD28EL02	4	6.219	4.721	229.0	7.765	0.000	20.000
CD28EL03	4	6.219	4.721	229.0	7.765	0.000	20.000
CD28SP02	54	5.378	4.083	229.0	7.765	0.000	20.000
CD28SP02A	9	1.888	1.433	229.0	7.765	0.000	20.000
CD28EL03	2	6.219	4.721	229.0	7.765	0.000	20.000
CD28EL04	4	6.219	4.721	229.0	7.765	0.000	20.000
CD28SP03	54	5.378	4.083	229.0	7.765	0.000	20.000
CD28EL05	2	6.219	4.721	229.0	7.765	0.000	20.000
CD28SP04	52	4.202	3.190	229.0	7.765	0.000	20.000
CD28EL06	2	6.219	4.721	229.0	7.765	0.000	20.000
CD28SP05	52	4.202	3.190	229.0	7.765	0.000	20.000
CD28EL07	2	6.219	4.721	229.0	7.765	0.000	20.000
CD28SP06	52	4.202	3.190	229.0	7.765	0.000	20.000
CD28EL08	1	5.546	4.211	229.0	7.765	0.000	20.000
CD28EL09	4	6.219	4.721	229.0	7.765	0.000	20.000
CD28EL10	3	5.883	4.466	229.0	7.765	0.000	20.000
INLET NOZZLE E-4-1B	30	5.746	5.104	229.0	7.765	0.000	20.000


150

Tpred/Tcrit Ratio Plot



Cumulative % of Comp. Time to Tcrit

Cond2006 E4 to E3



% of Fittings



% of Fittings Added

152





Wear Rate Analysis Run Definition

Run Name: Cond2006 E3 to 2 FWP

Run Title: Condensate E3A/B to 2 FDW Pumps Run'g

Ending Period: CYCLE 25

Total Oper. Hrs.: 241618.44

Duty Factor: 1.000

Analysis Options

Ignore IIFA Results

IIFA Results 1st Priority

User Input 1st Priority

Do Not Use Measured Wear

Database Lines		Add	Remove	Lines to Analyze
001-16"-FDW-01	▲	>	<	034-20"-C-29
002-16"-FDW-02	▲	>>	<<	035-20"-C-30
003-16"-FDW-03				036-24"-C-30
004-24"-FDW-01				037-16"-C-30
005-18"-FDW-07				037-20"-C-30
006-18"-FDW-07				039-16"-C-32
007-18"-FDW-12				039-20"-C-32
008-16"-FDW-14	▼			

< Prev
Next >
Add
Reset
Save

Copy
Delete
Print...
Help
Done

Run Definitions

- Cond Minimum Flow
- Cond2006 E3 to 2 FWP**
- Cond2006 E3 to 3 FWP
- Cond2006 E4 to E3
- Condensate
- FDW 2006 E1s to Rx
- FDW 2006 Hdr to E2s
- FDW06 2 P1s to Hdr
- FDW06 3-P1s to Hdr
- FDW2006 2P1s to E2s
- FDW2006 E2s to E1s
- Feed Pump Recirc
- Feedwater
- Feedwater Flush
- Feedwater Low Flow
- Heater Drain Pumps
- Main Steam 2006
- Moist Sep High Level
- Moist Separator Drn


Advanced Run Def...

List of Defined Wear Rate Runs

153




Comparison of Wear Predictions



154



Comparison of Thickness Predictions



155

Company: Vermont Yankee Nuclear Power Corporation Report Date: 28-SEP-2006 Time: 09:29:20
 Plant: Vermont Yankee Analysis Date: 28-SEP-2006 Time: 09:09:53
 Unit: CHECWORKS FAC Version 1.0P (Build 53)
 DB Name: VY

*** Wear Rate Analysis: Combined Summary Report ***

Full Name: COND006 E3 to 2 FWP
 Ending Period: CYCLE 25
 Total Plant Operating Hours: 241618
 WRA Data Option: Ignore NFA
 Line Correction Factor: 0.265
 Duty Factor (Global): 1.000
 Exclude Measure Wear: No

Component Name	Geom. Code	Average Wear Rate (mils/year)		Current Wear Rate (mils/year)	Thickness (in)			Component Predict (1) Time to Trrit (hrs)	Total Lifetime Wear (mils)	In-Service Cmp. Wear (mils)		In-Service Cmp. Tmeas.Method/Time (in) [4] [3] (hrs) [4]		Time (hrs) Last Inspected	
		Wear Rate	Wear Rate		Init.	Prd. [1]	Thoop			Tcrit	Prd. [2]	Meas.	Prd. [2]		Meas.
=== Grouped by Line: 034-20*-C-29, No Sorting.															
OUTLET NOZZLE E-3-1A	31	4.771	4.238	0.594	0.531	0.394	0.394	283788	---	---	---	---	0.594	125911	----
CD39EL01	4	4.131	3.136	0.594	0.480	0.394	0.394	241257	---	---	---	---	0.594	0	----
CD39SP01	54	3.572	2.712	0.594	0.495	0.394	0.394	328682	---	---	---	---	0.594	0	----
CD39VA01	22	5.513	4.185	0.594	0.442	0.421	0.421	43124	---	---	---	---	0.594	0	----
CD39EL02	4	4.131	3.136	0.594	0.473	0.394	0.394	223443	---	---	---	---	0.594	0	----
CD39SP02 US	54	3.572	2.712	0.594	0.529	0.394	0.394	---	437223	47.6	34.0	47.6	34.0	0.580	MT 114614 102975
CD39SP02 DS	54	3.572	2.712	0.594	0.495	0.394	0.394	328682	---	---	---	---	0.594	0	----
CD39EL03	4	4.131	3.136	0.594	0.626	0.394	0.394	---	649218	55.0	125.0	55.0	125.0	0.685	GW 102975 102975
CD39SP03 US	54	3.572	2.712	0.594	0.533	0.394	0.394	---	450143	47.6	36.0	47.6	36.0	0.584	GW 102975 102975
CD39SP03 DS	54	3.572	2.712	0.594	0.552	0.394	0.394	---	511511	47.6	59.0	47.6	59.0	0.603	GW 102975 102975
=== Grouped by Line: 035-20*-C-30, No Sorting.															
OUTLET NOZZLE E-3-1B	31	4.771	4.238	0.594	0.531	0.394	0.394	283788	---	---	---	---	0.594	125911	----
CD39EL01	4	4.131	3.136	0.594	0.480	0.394	0.394	241257	---	---	---	---	0.594	0	----
CD39VA01	22	5.513	4.185	0.594	0.442	0.421	0.421	43124	---	---	---	---	0.594	0	----
CD39EL02	4	4.131	3.136	0.594	0.544	0.394	0.394	---	420036	96.0	96.0	96.0	96.0	0.562	GW 195618 195618
CD39EL03	4	4.131	3.136	0.594	0.518	0.394	0.394	---	347407	96.0	135.0	96.0	135.0	0.536	GW 195618 195618
CD39SP01 US	54	3.572	2.712	0.594	0.495	0.394	0.394	328682	---	---	---	---	0.594	0	----
CD39SP01 DS	54	3.572	2.712	0.594	0.495	0.394	0.394	328682	---	---	---	---	0.594	0	----
CD39EL04	2	4.131	3.136	0.594	0.480	0.394	0.394	241257	---	---	---	---	0.594	0	----
CD39SP02 US	52	2.791	2.119	0.594	0.517	0.394	0.394	509826	---	---	---	---	0.594	0	----
CD39SP02 DS	52	2.791	2.119	0.594	0.517	0.394	0.394	509826	---	---	---	---	0.594	0	----
=== Grouped by Line: 036-24*-C-30, No Sorting.															
CD39SP03 DS	9	0.898	0.682	0.688	0.650	0.472	0.472	---	2283118	23.0	36.0	23.0	36.0	0.652	MT 218618 218618
CD39RD01 (L/E)	18	2.450	1.860	0.688	0.620	0.472	0.472	696846	---	---	---	---	0.688	0	----
CD39RD01 (R/E)	18	3.126	2.373	0.594	0.508	0.394	0.394	421103	---	---	---	---	0.594	0	----
CD39TE01 (U/S)	15	2.450	1.860	0.688	0.620	0.472	0.472	696846	---	---	---	---	0.688	0	----
CD39TE01 (D/S)	15	2.450	1.860	0.688	0.620	0.472	0.472	696846	---	---	---	---	0.688	0	----
CD39SF03	95	1.634	1.240	0.688	0.643	0.472	0.472	1204399	---	---	---	---	0.688	0	----
CD39TE02 (U/S)	14	4.492	3.410	0.688	0.893	0.472	0.472	---	1080385	114.9	140.0	114.9	140.0	0.902	MT 218618 218618
CD39TE02 (D/S)	14	7.191	5.459	0.688	1.023	0.472	0.472	---	882906	184.0	133.0	184.0	133.0	1.037	GW 218618 218618
CD39TE02 (BR.)	14	3.907	2.966	0.594	0.682	0.394	0.394	851983	---	---	---	---	0.690	GW 218618 218618	
CD39SP04 US	64	1.634	1.240	0.688	0.626	0.472	0.472	---	1082898	41.8	52.0	41.8	52.0	0.629	MT 218618 218618
CD39SP04 DS	64	1.634	1.240	0.688	0.658	0.472	0.472	---	1308712	21.8	30.0	21.8	30.0	0.681	MT 102975 102975
CD39TE03 (U/S)	12	3.349	2.542	0.688	0.874	0.472	0.472	1384564	---	---	---	---	0.922	MT 102975 102975	
CD39TE03 (D/S)	12	5.347	4.059	0.688	0.883	0.472	0.472	885578	---	---	---	---	0.959	MT 102975 102975	
CD39TE03 (BR.)	12	3.796	2.882	0.594	0.489	0.394	0.394	290627	---	---	---	---	0.594	0	----
CD39SP05 US	64	2.608	1.980	0.688	0.650	0.472	0.472	---	784763	34.8	53.0	34.8	53.0	0.687	GW 102975 102975
CD39SP05 DS	64	2.608	1.980	0.688	0.616	0.472	0.472	635428	---	---	---	---	0.688	0	----
CD39EL05	1	4.303	3.267	0.688	0.569	0.472	0.472	259732	---	---	---	---	0.688	0	----
CD39SP06	51	2.869	2.178	0.688	0.660	0.472	0.472	---	755904	56.5	33.0	56.5	33.0	0.683	GW 160352 160352
CD39EL06	3	4.564	3.465	0.688	0.635	0.472	0.472	---	411011	89.9	82.0	89.9	82.0	0.671	MT 160352 160352
CD39SP07	53	3.260	2.475	0.688	0.640	0.472	0.472	---	594109	64.2	27.0	64.2	27.0	0.666	MT 160352 160352
CD39TE04 (U/S)	14	7.172	5.445	0.688	0.490	0.472	0.472	28535	---	---	---	---	0.688	0	----
CD39TE04 (D/S)	14	4.492	3.410	0.688	0.564	0.472	0.472	235433	---	---	---	---	0.688	0	----
CD39TE04 (BR.)	14	3.907	2.966	0.594	0.486	0.394	0.394	273230	---	---	---	---	0.594	0	----
CD39RD02 (L/E)	7	2.859	2.170	0.688	0.837	0.472	0.472	1473385	---	---	---	---	0.860	MT 160352 160352	
CD39RD02 (R/E)	7	5.572	3.712	0.594	0.495	0.394	0.394	328682	---	---	---	---	0.524	PW 160352 160352	
=== Grouped by Line: 037-16*-C-30, No Sorting.															
CD39EL13	4	5.492	4.170	0.500	0.349	0.315	0.315	70500	---	---	---	---	0.500	0	----
INLET NOZZLE F-1-1A	30	5.937	4.508	0.500	0.336	0.315	0.315	41343	---	---	---	---	0.500	0	----

156

---Grouped by Line: 037-20*-C-30, No Sorting.

CD30SP08 US	57	2.791	2.119	0.594	0.526	0.394	0.394	-----	546937	55.0	46.0	55.0	46.0	0.548	MT	160352	160352
CD30SP08 DS	57	2.791	2.119	0.594	0.517	0.394	0.394	509826	-----	---	---	---	---	0.594	--	0	-----
CD30EL03	2	4.131	3.136	0.594	0.480	0.394	0.394	241257	-----	---	---	---	---	0.594	--	0	-----
CD30VA02	22	5.513	4.185	0.594	0.442	0.421	0.421	43124	-----	---	---	---	---	0.594	--	0	-----
CD30SP09	58	2.456	1.865	0.594	0.526	0.394	0.394	622747	-----	---	---	---	---	0.594	--	0	-----
CD30EL04	3	3.907	2.966	0.594	0.486	0.394	0.394	273230	-----	---	---	---	---	0.594	--	0	-----
CD30EL05	3	3.907	2.966	0.594	0.486	0.394	0.394	273230	-----	---	---	---	---	0.594	--	0	-----
CD30SP10	53	2.791	2.119	0.594	0.517	0.394	0.394	509826	-----	---	---	---	---	0.594	--	0	-----
CD30EL11	4	4.131	3.136	0.594	0.480	0.394	0.394	241257	-----	---	---	---	---	0.594	--	0	-----
CD30SP11	54	3.572	2.712	0.594	0.495	0.394	0.394	328682	-----	---	---	---	---	0.594	--	0	-----
CD30FE01	6	0.054	0.041	0.594	0.593	0.420	0.420	36983356	-----	---	---	---	---	0.594	--	0	-----
CD30FE01A	56	2.762	2.097	0.812	0.836	0.460	0.460	-----	1571069	73.4	28.0	73.4	28.0	0.839	MT	230118	230118
CD30EL11	3	3.907	2.966	0.594	0.736	0.394	0.394	-----	1011135	103.9	99.0	103.9	99.0	0.740	GW	230118	230118
CD30SP10	53	2.791	2.119	0.594	0.550	0.394	0.394	-----	647083	74.2	38.0	74.2	38.0	0.553	MT	230118	230118
CD30EL12	4	4.131	3.136	0.594	0.591	0.394	0.394	-----	551448	55.0	74.0	55.0	74.0	0.650	GW	102975	102975
CD30SP13	54	3.572	2.712	0.594	0.495	0.394	0.394	328682	-----	---	---	---	---	0.594	--	0	-----
CD30RD03 (L/E)	17	2.791	2.119	0.594	0.517	0.394	0.394	509826	-----	---	---	---	---	0.594	--	0	-----
CD30RD03 (S/E)	17	2.672	2.028	0.500	0.426	0.315	0.315	480859	-----	---	---	---	---	0.500	--	0	-----

---Grouped by Line: 039-16*-C-32, No Sorting.

CD30EL06	4	5.492	4.170	0.500	0.349	0.315	0.315	70500	-----	---	---	---	---	0.500	--	0	-----
HUBBET BUSHLE P-1-1C	30	5.937	4.508	0.500	0.336	0.315	0.315	41343	-----	---	---	---	---	0.500	--	0	-----

---Grouped by Line: 039-20*-C-32, No Sorting.

CD30SP05	51	2.456	1.865	0.594	0.530	0.394	0.394	-----	640826	62.8	59.0	62.8	59.0	0.535	MT	218618	218618
CD30SP04	64	2.233	1.695	0.594	0.508	0.394	0.394	-----	588349	57.1	75.0	57.1	75.0	0.512	MT	218618	218618
CD30EL06	3	3.907	2.966	0.594	0.681	0.394	0.394	-----	849030	100.0	160.0	100.0	160.0	0.689	GW	218618	218618
CD30VA01	22	5.513	4.185	0.594	0.442	0.421	0.421	43124	-----	---	---	---	---	0.594	--	0	-----
CD30EL03	4	4.131	3.136	0.594	0.480	0.394	0.394	241257	-----	---	---	---	---	0.594	--	0	-----
CD30SP03	54	3.572	2.712	0.594	0.495	0.394	0.394	328682	-----	---	---	---	---	0.594	--	0	-----
CD30FE01	6	0.054	0.041	0.594	0.593	0.420	0.420	36983356	-----	---	---	---	---	0.594	--	0	-----
CD30FE01A	56	2.762	2.097	0.812	0.736	0.460	0.460	-----	1151529	64.2	23.0	64.2	23.0	0.748	PW	195618	195618
CD30EL04	3	3.907	2.966	0.594	0.661	0.394	0.394	-----	789453	90.8	95.0	90.8	95.0	0.678	GW	195618	195618
CD30SP02	53	2.791	2.119	0.594	0.517	0.394	0.394	509826	-----	---	---	---	---	0.594	--	0	-----
CD30EL05	4	4.131	3.136	0.594	0.480	0.394	0.394	241257	-----	---	---	---	---	0.594	--	0	-----
CD30SP03	54	3.572	2.712	0.594	0.495	0.394	0.394	328682	-----	---	---	---	---	0.594	--	0	-----
CD30RD01 (L/E)	17	2.791	2.119	0.594	0.517	0.394	0.394	509826	-----	---	---	---	---	0.594	--	0	-----
CD30RD01 (S/E)	17	2.672	2.028	0.500	0.426	0.315	0.315	480859	-----	---	---	---	---	0.500	--	0	-----

Notes:

- [1] Predictions are based on last Tmeas to analysis ending period.
 - [2] Predictions are for the time of last inspection (last known meas. wear).
 - [3] GW = Tmeas is minimum thickness from Band, Blanket or Area Method of greatest wear.
 - MT = Tmeas is component minimum thickness.
 - PW = Tmeas is Tinit - predicted wear.
 - US = Tmeas is user specified.
 - [4] if no Tmeas has been determined from measured data, then Tmeas = Tinit and Time = current component installation time.
- Tmeas is used to determine Predicted Thickness and Component Predicted Time to Tcrit.

157

 *** Wear Rate Analysis: Inspection History Report ***

Pun Name: Cond2006 E3 to 2 FWP
 Ending Period: CYCLE 25
 Total Plant Operating Hours: 241618 Duty Factor (Global): 1.000
 WPA Data Option: Ignore NFA Exclude Measure Wear: No
 Line Correction Factor: 0.265

Component Name	Geom. Code	Material			Sigma (psi)	Time (hrs)		Analysis Option	Measured Wear (mils)
		Cr. No.	Co. (%)	Mo. (%)		Last Inspected	Replaced		

====>Grouped by Line: 034-20*-C-29, No Sorting.

OUTLET NOZZLE E-3-1A	31	5	0.00	0.00	0.00	15000	-----	-----	---
*Replacement #1	31	5	0.00	0.00	0.00	15000	-----	125911	---
CD29EL01	4	21	0.00	0.00	0.00	15000	-----	-----	---
CD29SP01	54	5	0.00	0.00	0.00	15000	-----	-----	---
CD29VA01	22	93	0.00	0.00	0.00	14000	-----	-----	---
CD29EL02	4	21	0.00	0.00	0.00	15000	-----	-----	---
CD29SP02 US	54	5	0.00	0.00	0.00	15000	102975	-----	34
CD29SP02 DS	54	5	0.00	0.00	0.00	15000	-----	-----	---
CD29EL03	4	21	0.00	0.00	0.00	15000	102975	-----	125
CD29SP03 US	54	5	0.00	0.00	0.00	15000	102975	-----	36
CD29SP03 DS	54	5	0.00	0.00	0.00	15000	102975	-----	59

====>Grouped by Line: 035-20*-C-30, No Sorting.

OUTLET NOZZLE E-3-1B	31	5	0.00	0.00	0.00	15000	-----	-----	---
*Replacement #1	31	5	0.00	0.00	0.00	15000	-----	125911	---
CD30EL01	4	21	0.00	0.00	0.00	15000	-----	-----	---
CD30VA01	22	93	0.00	0.00	0.00	14000	-----	-----	---
CD30EL02	4	21	0.00	0.00	0.00	15000	195618	-----	96
CD30EL03	4	21	0.00	0.00	0.00	15000	195618	-----	135
CD30SP01 US	54	5	0.00	0.00	0.00	15000	-----	-----	---
CD30SP01 DS	54	5	0.00	0.00	0.00	15000	-----	-----	---
CD30EL04	2	21	0.00	0.00	0.00	15000	-----	-----	---
CD30SP02 US	52	5	0.00	0.00	0.00	15000	-----	-----	---
CD30SP02 DS	52	5	0.00	0.00	0.00	15000	-----	-----	---

====>Grouped by Line: 036-24*-C-30, No Sorting.

CD30SP03DS	9	21	0.00	0.00	0.00	15000	218618	-----	36
CD30RD01(L/E)	18	21	0.00	0.00	0.00	15000	-----	-----	---
CD30RD01(S/E)	18	21	0.00	0.00	0.00	15000	-----	-----	---
CD30TE01(U/S)	15	21	0.00	0.00	0.00	15000	-----	-----	---
CD30TE01(L/S)	15	21	0.00	0.00	0.00	15000	-----	-----	---
CD30SP03	65	5	0.00	0.00	0.00	15000	-----	-----	---
CD30TE02(U/S)	14	21	0.00	0.00	0.00	15000	218618	-----	140
CD30TE02(D/S)	14	21	0.00	0.00	0.00	15000	218618	-----	133
CD30TE02(BR.)	14	21	0.00	0.00	0.00	15000	-----	-----	---
CD30SP04 US	64	5	0.00	0.00	0.00	15000	218618	-----	52
CD30SP04 DS	64	5	0.00	0.00	0.00	15000	102975	-----	30
CD30TE03(U/S)	12	21	0.00	0.00	0.00	15000	-----	-----	---
CD30TE03(D/S)	12	21	0.00	0.00	0.00	15000	-----	-----	---
CD30TE03(BR.)	12	21	0.00	0.00	0.00	15000	-----	-----	---
CD30SP05 US	64	5	0.00	0.00	0.00	15000	102975	-----	53
CD30SP05 DS	64	5	0.00	0.00	0.00	15000	-----	-----	---
CD30EL05	1	21	0.00	0.00	0.00	15000	-----	-----	---
CD30SP06	51	5	0.00	0.00	0.00	15000	160352	-----	33
CD30EL06	3	21	0.00	0.00	0.00	15000	160352	-----	82
CD30SP07	53	5	0.00	0.00	0.00	15000	160352	-----	27
CD30TE04(U/S)	14	21	0.00	0.00	0.00	15000	-----	-----	---
CD30TE04(D/S)	14	21	0.00	0.00	0.00	15000	-----	-----	---
CD30TE04(BR.)	14	21	0.00	0.00	0.00	15000	-----	-----	---
CD30RD02(L/E)	7	21	0.00	0.00	0.00	15000	-----	-----	---
CD30RD02(S/E)	7	21	0.00	0.00	0.00	15000	-----	-----	---

====>Grouped by Line: 037-16*-C-30, No Sorting.

CD30EL13	4	21	0.00	0.00	0.00	15000	-----	-----	---
INLET NOZZLE P-1-1A	30	5	0.00	0.00	0.00	15000	-----	-----	---

====>Grouped by Line: 037-20*-C-30, No Sorting.

CD30SP08 US	57	5	0.00	0.00	0.00	15000	160352	-----	45
CD30SP08 DS	57	5	0.00	0.00	0.00	15000	-----	-----	---
CD30EL07	3	21	0.00	0.00	0.00	15000	-----	-----	---
CD30VA02	22	93	0.00	0.00	0.00	14000	-----	-----	---
CD30SP09	58	5	0.00	0.00	0.00	15000	-----	-----	---
CD30EL08	3	21	0.00	0.00	0.00	15000	-----	-----	---
CD30EL09	3	21	0.00	0.00	0.00	15000	-----	-----	---
CD30SP10	53	5	0.00	0.00	0.00	15000	-----	-----	---
CD30EL10	4	21	0.00	0.00	0.00	15000	-----	-----	---
CD30SP11	54	5	0.00	0.00	0.00	15000	-----	-----	---
CD30SP12	2	61	14.00	0.00	0.00	14000	-----	-----	---
CD30SP12A	56	3	0.00	0.00	0.00	12000	230118	-----	28
CD30EL11	3	31	0.00	0.00	0.00	15000	230118	-----	39
CD30SP12	53	5	0.00	0.00	0.00	15000	230118	-----	37
CD30EL12	4	21	0.00	0.00	0.00	15000	102975	-----	74
CD30SP13	54	5	0.00	0.00	0.00	15000	-----	-----	---
CD30RD03(L/E)	17	21	0.00	0.00	0.00	15000	-----	-----	---
CD30RD03(S/E)	17	21	0.00	0.00	0.00	15000	-----	-----	---

====>Grouped by Line: 039-16*-C-30, No Sorting.

CD32EL06	4	21	0.00	0.00	0.00	15000	-----	-----	---
INLET NOZZLE P-1-1C	30	5	0.00	0.00	0.00	15000	-----	-----	---

====>Grouped by Line: 039-20"-C-32, No Sorting.

CD30SP05	51	5	0.00	0.00	0.00	15000	218618	-----	58
CD32SP04	64	5	0.00	0.00	0.00	15000	218618	-----	74
CD32EL03	3	21	0.00	0.00	0.00	15000	218618	-----	160
CD32YA01	22	93	0.00	0.00	0.00	14500	-----	-----	---
CD32EL03	4	21	0.00	0.00	0.00	15000	-----	-----	---
CD32SP01	54	5	0.00	0.00	0.00	15000	-----	-----	---
CD32FE01	6	61	18.00	0.00	0.00	14050	-----	-----	---
CD32FE01A	56	2	0.00	0.00	0.00	12800	195618	-----	23
CD32EL04	3	21	0.00	0.00	0.00	15000	195618	-----	95
CD32SP02	53	5	0.00	0.00	0.00	15000	-----	-----	---
CD32EL05	4	21	0.00	0.00	0.00	15000	-----	-----	---
CD32SP03	54	5	0.00	0.00	0.00	15000	-----	-----	---
CD32PD01(L/E)	17	21	0.00	0.00	0.00	15000	-----	-----	---
CD32RD01(S/E)	17	21	0.00	0.00	0.00	15000	-----	-----	---

*** Wear Rate Analysis: Wear Rates/Input Data Report ***

Run Name: Cond2006 E3 to 2 FWP
 Ending Period: CYCLE 25
 Total Plant Operating Hours: 241618 Duty Factor (Global): 1.000
 WPA Data Option: Ignore NFA Exclude Measure Wear: No
 Line Correction Factor: 0.265

Component Name	Geom. Code	Average Wear Rate (mils/year)	Current Wear Rate (mils/year)	Temp. (F)	Velocity (ft/s)	Steam Quality	Diameter (in)
=== Grouped by Line: 034-20*-C-29, No Sorting.							
OUTLET NOZZLE	E-3-1A	31	4.771	4.238	294.7	8.023	20.000
CD29EL01		4	4.131	3.136	294.7	8.023	20.000
CD29SP01		54	3.572	2.712	294.7	8.023	20.000
CD29VA01		22	5.513	4.185	294.7	7.865	20.000
CD29EL02		4	4.131	3.136	294.7	8.023	20.000
CD29SP02 US		54	3.572	2.712	294.7	8.023	20.000
CD29SP02 DS		54	3.572	2.712	294.7	8.023	20.000
CD29EL03		4	4.131	3.136	294.7	8.023	20.000
CD29SP03 US		54	3.572	2.712	294.7	8.023	20.000
CD29SP03 DS		54	3.572	2.712	294.7	8.023	20.000
===> Grouped by Line: 035-20*-C-30, No Sorting.							
OUTLET NOZZLE	E-3-1B	31	4.771	4.238	294.7	8.023	20.000
CD30EL01		4	4.131	3.136	294.7	8.023	20.000
CD30VA01		22	5.513	4.185	294.7	7.865	20.000
CD30EL02		4	4.131	3.136	294.7	8.023	20.000
CD30EL03		4	4.131	3.136	294.7	8.023	20.000
CD30SP01 US		54	3.572	2.712	294.7	8.023	20.000
CD30SP01 DS		54	3.572	2.712	294.7	8.023	20.000
CD30EL04		2	4.131	3.136	294.7	8.023	20.000
CD30SP02 US		52	2.791	2.119	294.7	8.023	20.000
CD30SP02 DS		52	2.791	2.119	294.7	8.023	20.000
===> Grouped by Line: 036-24*-C-30, No Sorting.							
CD30SP03DS		9	0.898	0.682	294.7	5.547	24.000
CD30RD01(L/E)		18	2.450	1.860	294.7	5.547	24.000
CD30RD01(S/E)		18	3.126	2.373	294.7	8.023	20.000
CD30TE01(U/S)		15	2.450	1.860	294.7	5.547	24.000
CD30TE01(D/S)		15	2.450	1.860	294.7	5.547	24.000
CD30SP03		65	1.634	1.240	294.7	5.547	24.000
CD30TE02(U/S)		14	4.492	3.410	294.7	5.547	24.000
CD30TE02(D/S)		14	7.131	5.459	294.7	11.146	24.000
CD30TE02(BR.)		14	3.907	2.966	294.7	8.023	20.000
CD30SP04 US		64	1.634	1.240	294.7	5.547	24.000
CD30SP04 DS		64	1.634	1.240	294.7	5.547	24.000
CD30TE03(U/S)		12	3.349	2.542	294.7	5.547	24.000
CD30TE03(D/S)		12	5.347	4.059	294.7	11.094	24.000
CD30TE03(BR.)		12	3.796	2.882	294.7	8.023	20.000
CD30SP05 US		64	2.608	1.980	294.7	11.094	24.000
CD30SP05 DS		64	2.608	1.980	294.7	11.094	24.000
CD30EL05		1	4.303	3.267	294.7	11.094	24.000
CD30SP06		51	2.859	2.178	294.7	11.094	24.000
CD30EL06		3	4.564	3.465	294.7	11.094	24.000
CD30SP07		53	3.260	2.475	294.7	11.094	24.000
CD30TE04(U/S)		14	7.172	5.445	294.7	11.094	24.000
CD30TE04(D/S)		14	4.492	3.410	294.7	5.547	24.000
CD30TE04(BR.)		14	3.907	2.966	294.7	8.023	20.000
CD30RD02(L/E)		7	2.859	2.170	294.7	5.547	24.000
CD30RD02(S/E)		7	3.572	2.712	294.7	8.023	20.000
===> Grouped by Line: 037-16*-C-30, No Sorting.							
CD30EL13		4	5.492	4.170	294.7	12.619	16.000
INLET NOZZLE	P-1-1A	30	5.937	4.508	294.7	12.619	16.000
===> Grouped by Line: 037-20*-C-30, No Sorting.							
CD30SP08 US		57	3.791	2.119	294.7	8.023	20.000
CD30SP08 DS		57	2.791	2.119	294.7	8.023	20.000
CD30EL17		2	4.131	3.136	294.7	8.023	20.000
CD30VA02		22	5.513	4.185	294.7	7.865	20.000
CD30SP09		58	3.456	1.865	294.7	8.023	20.000
CD30EL08		3	3.907	2.966	294.7	8.023	20.000
CD30EL09		3	3.907	2.966	294.7	8.023	20.000
CD30SP10		53	2.791	2.119	294.7	8.023	20.000
CD30EL10		4	4.131	3.136	294.7	8.023	20.000
CD30SP11		54	3.572	2.712	294.7	8.023	20.000
CD30FE01		6	0.351	0.241	294.7	33.876	20.000
CD30FE01A		56	2.782	2.097	294.7	33.876	20.000
CD30EL11		3	3.207	2.366	294.7	8.023	20.000
CD30SP12		53	2.791	2.119	294.7	8.023	20.000
CD30EL12		4	4.131	3.136	294.7	8.023	20.000
CD30SP13		54	3.572	2.712	294.7	8.023	20.000
CD30RD03(L/E)		17	2.791	2.119	294.7	8.023	20.000
CD30RD03(S/E)		17	3.572	2.098	294.7	12.619	16.000
===> Grouped by Line: 039-16*-C-32, No Sorting.							
CD30EL13		4	5.492	4.170	294.7	12.619	16.000
INLET NOZZLE	P-1-1C	30	5.937	4.508	294.7	12.619	16.000

====>Grouped by Line: 030-20*-C-32, No Sorting.

CD30SP05	51	2.456	1.865	294.7	8.023	0.000	20.000
CD32SP04	84	2.233	1.595	294.7	8.023	0.000	20.000
CD32RL02	3	2.967	2.965	294.7	8.023	0.000	20.000
CD32VA01	22	5.513	4.185	294.7	7.865	0.000	20.000
CD32EL03	4	4.131	3.136	294.7	8.023	0.000	20.000
CD32SP01	54	3.572	2.712	294.7	8.023	0.000	20.000
CD32FE01	6	0.054	0.041	294.7	33.876	0.000	20.000
CD32FE01A	56	2.762	2.097	294.7	33.876	0.000	20.000
CD32EL04	3	3.907	2.966	294.7	8.023	0.000	20.000
CD32SP02	53	2.791	2.119	294.7	8.023	0.000	20.000
CD32EL05	4	4.131	3.136	294.7	8.023	0.000	20.000
CD32SP03	54	3.572	2.712	294.7	8.023	0.000	20.000
CD32RD01 (L/E)	17	2.791	2.119	294.7	8.023	0.000	20.000
CD32RD01 (S/E)	17	2.672	2.028	294.7	12.619	0.000	16.000

 *** Wear Rate Analysis: Wear Predictions Report

Run Name: Cond2006 E3 to 2 FWP
 Ending Period: CYCLE 35
 Total Plant Operating Hours: 241618 Duty Factor (Global): 1.000
 NFA Data Option: Ignore NFA Exclude Measure Wear: No
 Line Correction Factor: 0.165

Component Name	Total Lifetime Wear (mils)		In-Service Wear (mils)		In-Service Tmeas, Method, Time			In-Service Thickness (mils) [4]		Incremental Wear (mils) [5]	Time (hrs) Last Inspected
	Prd. [1]	Meas.	Prd. [1]	Meas.	(in) [3]	[2]	(hrs) [3]	Tp	Tm		

====>Grouped by Line: 034-20*-C-29, No Sorting.

CD29SP02 US	47.6	34.0	47.6	34.0	0.580	MT	102975	546.4	580.0	50.9	102975
CD29EL03	55.0	125.0	55.0	125.0	0.685	GW	102975	539.0	685.0	58.9	102975
CD29SP03 US	47.6	36.0	47.6	36.0	0.584	GW	102975	546.4	584.0	50.9	102975
CD29SP03 DS	47.6	59.0	47.6	59.0	0.603	GW	102975	546.4	603.0	50.9	102975

====>Grouped by Line: 035-20*-C-30, No Sorting.

CD30EL02	96.0	96.0	96.0	96.0	0.562	GW	195618	498.0	562.0	17.9	195618
CD30EL03	96.0	135.0	96.0	135.0	0.536	GW	195618	498.0	536.0	17.9	135618

====>Grouped by Line: 036-24*-C-30, No Sorting.

CD30SP03DS	23.0	36.0	23.0	36.0	0.652	MT	218618	665.0	652.0	1.8	218618
CD30TE02(U/S)	114.9	140.0	114.9	140.0	0.902	MT	218618	573.1	902.0	9.0	218618
CD30TE02(D/S)	184.0	133.0	184.0	133.0	1.037	GW	218618	504.0	1037.0	14.3	218618
CD30SP04 US	41.8	52.0	41.8	52.0	0.629	MT	218618	646.2	629.0	3.3	218618
CD30SP04 DS	21.8	30.0	21.8	30.0	0.681	MT	102975	666.2	681.0	23.3	102975
CD30SP05 US	34.8	53.0	34.8	53.0	0.687	GW	102975	653.2	687.0	37.2	102975
CD30SP06	56.5	33.0	56.5	33.0	0.683	GW	160352	631.5	683.0	22.6	160352
CD30EL06	89.9	82.0	89.9	82.0	0.671	MT	160352	598.1	671.0	36.0	160352
CD30SP07	64.2	27.0	64.2	27.0	0.666	MT	160352	623.8	666.0	25.7	160352

====>Grouped by Line: 037-16*-C-30, No Sorting.

====>Grouped by Line: 037-20*-C-30, No Sorting.

CD30SP08 US	55.0	46.0	55.0	46.0	0.548	MT	160352	539.0	548.0	22.0	160352
CD30FE01A	73.4	28.0	73.4	28.0	0.839	MT	230118	738.6	839.0	2.8	230118
CD30EL11	103.9	99.0	103.9	99.0	0.740	GW	230118	490.1	740.0	3.9	230118
CD30SP12	74.2	38.0	74.2	38.0	0.553	MT	230118	519.8	553.0	2.8	230118
CD30EL12	55.0	74.0	55.0	74.0	0.650	GW	102975	539.0	650.0	58.9	102975

====>Grouped by Line: 039-16*-C-32, No Sorting.

====>Grouped by Line: 039-20*-C-32, No Sorting.

CD30SP05	62.8	59.0	62.8	59.0	0.535	MT	218618	531.2	535.0	4.9	218618
CD32SP04	57.1	75.0	57.1	75.0	0.512	MT	218618	536.9	512.0	4.5	218618
CD32EL02	100.0	160.0	100.0	160.0	0.689	GW	218618	494.0	689.0	7.8	218618
CD32FE01A	64.2	23.0	64.2	23.0	0.748	PW	195618	747.8	747.8	12.0	195618
CD32EL04	90.8	95.0	90.8	95.0	0.678	GW	195618	503.2	678.0	17.0	195618

- Notes:
- [1] Predictions are for the time of last inspection (last known meas. wear).
 - [2] GW = Tmeas is minimum thickness from Band, Blanket or Area Method of greatest wear.
 MT = Tmeas is component minimum thickness.
 PW = Tmeas is Tinit - predicted wear.
 US = Tmeas is user specified.
 - [3] If no Tmeas has been determined from measured data, then Tmeas = Tinit and Time = current component installation time.
 Tmeas is used to determine Predicted Thickness and Component Predicted Time to Tcrit.
 - [4] These two values are used for thickness plot.
 Tp = Predicted thickness at Tmeas.
 Tm = Last measured thickness (Tmeas).
 - [5] PRWEAR = Incremental wear from last Tmeas time to analysis ending period.

*** Wear Rate Analysis: Combined Rankings for Inspection ***

Run Name: Cond3006 E3 to 2 FWP
 Ending Period: CYCLE 25
 Total Plant Operating Hours: 241618 Duty Factor (Global): 1.000
 WRA Data Option: Ignore NFA Exclude Measure Wear: No
 Line Correction Factor: 0.265

Component Name	Geometry Code	Average Wear Rate (mils/year)	Component Predicted Time to Tcrit (hrs)	
			Non-Inspected	Inspected
CD30EL05	1	4.564	-----	411011
CD30EL13	4	5.492	70500	-----
CD32FE01	6	0.054	36983356	-----
CD30RD02 (S/E)	7	3.572	328682	-----
CD30VA02	22	5.513	43124	-----
CD29SP02 DS	54	3.572	328682	-----
CD30TE02 (D/S)	14	7.191	-----	882906
CD30TE04 (U/S)	14	7.172	28535	-----
INLET NOZZLE P-1-1A	30	5.937	41343	-----
INLET NOZZLE P-1-1C	30	5.937	41343	-----
CD29VA01	22	5.513	43124	-----
CD30VA01	22	5.513	43124	-----
CD32VA01	22	5.513	43124	-----
CD32EL06	4	5.492	70500	-----
CD29EL02	4	4.131	222443	-----
CD30TE03 (D/S)	12	5.347	885578	-----
CD30TE04 (D/S)	14	4.492	235433	-----
OUTLET NOZZLE E-3-1A	31	4.771	283788	-----
CD30EL04	2	4.131	241257	-----
OUTLET NOZZLE E-3-1B	31	4.771	283788	-----
CD32EL05	4	4.131	241257	-----
CD30EL07	2	4.131	241257	-----
CD30EL01	4	4.131	241257	-----
CD30TE02 (U/S)	14	4.492	-----	1080385
CD29EL01	4	4.131	241257	-----
CD30EL05	1	4.303	259732	-----
CD32EL03	4	4.131	241257	-----
CD30EL10	4	4.131	241257	-----
CD30EL02	4	4.131	-----	420036
CD30EL09	3	3.907	273230	-----
CD30EL03	4	4.131	-----	347407
CD30EL08	3	3.907	273230	-----
CD30TE04 (BR.)	14	3.907	273230	-----
CD22EL03	4	4.131	-----	649218
CD30TE03 (BR.)	12	3.736	290627	-----
CD30EL12	4	4.131	-----	551448
CD32SP03	54	3.572	328682	-----
CD29SP01	54	3.572	328682	-----
CD30SP13	54	3.572	328682	-----
CD30SP01 DS	54	3.572	328682	-----
CD30TE02 (BR.)	14	3.907	851983	-----
CD32SP01	54	3.572	328682	-----
CD32EL02	3	3.907	-----	843030
CD30SP01 US	54	3.572	328682	-----
CD30EL11	3	3.907	-----	1011135
CD30SP11	54	3.572	328682	-----
CD32EL04	3	3.907	-----	789453
CD30RD01 (S/E)	18	3.126	421103	-----
CD29SP03 DS	54	3.572	-----	511511
CD29SP02 US	54	3.572	-----	437223
CD29SP03 US	54	3.572	-----	450143
CD30RD03 (S/E)	17	2.672	480859	-----
CD32RD01 (S/E)	17	2.672	480859	-----
CD30SP02 DS	52	2.791	509826	-----
CD30SP10	53	2.791	509826	-----
CD32RD01 (L/E)	17	2.791	509826	-----
CD30RD03 (L/E)	17	2.791	509826	-----
CD30SP08 DS	57	2.791	509826	-----
CD32SP02	53	2.791	509826	-----
CD30SP02 US	52	2.791	509826	-----
CD30TE03 (U/S)	12	3.349	1384564	-----
CD30SP07	53	3.260	-----	594109
CD30SP08 US	57	2.791	-----	546937
CD30SP06	51	3.869	-----	755904
CD32SP04	64	2.233	-----	588349
CD30RD02 (L/E)	17	2.859	1473385	-----
CD30SP09	58	2.456	622747	-----
CD30SP05 DS	64	2.608	635428	-----
CD30SP05	51	2.456	-----	640826
CD30SP12	53	2.791	-----	647083
CD30TE01 (D/S)	12	3.450	696846	-----
CD30TE01 (U/S)	14	2.450	696846	-----
CD30RD01 (L/E)	18	2.450	696846	-----
CD30FE01A	56	2.762	-----	1191529
CD30SP05 US	64	1.608	-----	784763
CD30FE01A	56	2.762	-----	1571069
CD30SP04 US	64	1.614	-----	1882832
CD30SP03	55	1.614	1704397	-----
CD30SP04 DS	64	1.634	-----	1302712
CD30SP05 DS	64	1.634	-----	3283118
CD30FE01	6	0.054	36983356	-----

 *** Wear Rate Analysis: Thickness Service Time Report ***

Run Name: Cond2006 E3 to 2 FWP
 Ending Period: CYCLE 25
 Total Plant Operating Hours: 241618 Duty Factor (Global): 1.000
 WRA Data Option: Ignore NFA Exclude Measure Wear: No
 Line Correction Factor: 0.255

Component Name	Thickness (in)				Component Predicted(1) Time to Tcrit (hrs)		Component Actual Service Time (hrs)
	Init.	Prd. (1)	Thoop	Tcrit	Non-Inspected	Inspected	
===>Grouped by Line: 034-20*-C-29, No Sorting.							
OUTLET NOZZLE E-3-1A	0.594	0.531	0.394	0.394	283788	-----	115707
CD29EL01	0.594	0.480	0.394	0.394	241257	-----	241618
CD29SP01	0.594	0.495	0.394	0.394	328682	-----	241618
CD29VA01	0.594	0.442	0.421	0.421	43124	-----	241618
CD29EL02	0.594	0.473	0.394	0.394	222443	-----	241618
CD29SP02 US	0.594	0.529	0.394	0.394	-----	437233	241618
CD29SP02 DS	0.594	0.495	0.394	0.394	328682	-----	241618
CD29EL03	0.594	0.526	0.394	0.394	-----	649218	241618
CD29SP03 US	0.594	0.533	0.394	0.394	-----	450143	241618
CD29SP03 DS	0.594	0.552	0.394	0.394	-----	511511	241618

===>Grouped by Line: 035-20*-C-30, No Sorting.							
OUTLET NOZZLE E-3-1B	0.594	0.531	0.394	0.394	283788	-----	115707
CD30EL01	0.594	0.480	0.394	0.394	241257	-----	241618
CD30VA01	0.594	0.442	0.421	0.421	43124	-----	241618
CD30EL02	0.594	0.544	0.394	0.394	-----	420036	241618
CD30EL03	0.594	0.518	0.394	0.394	-----	347407	241618
CD30SP01 US	0.594	0.495	0.394	0.394	328682	-----	241618
CD30SP01 DS	0.594	0.495	0.394	0.394	328682	-----	241618
CD30EL04	0.594	0.480	0.394	0.394	241257	-----	241618
CD30SP02 US	0.594	0.517	0.394	0.394	509826	-----	241618
CD30SP02 DS	0.594	0.517	0.394	0.394	509826	-----	241618

===>Grouped by Line: 036-24*-C-30, No Sorting.							
CD30SP03DS	0.688	0.650	0.472	0.472	-----	2283118	241618
CD30RD01(L/E)	0.688	0.620	0.472	0.472	696846	-----	241618
CD30RD01(S/E)	0.594	0.508	0.394	0.394	421103	-----	241618
CD30TE01(U/S)	0.688	0.620	0.472	0.472	696846	-----	241618
CD30TE01(D/S)	0.688	0.620	0.472	0.472	696846	-----	241618
CD30SP03	0.688	0.643	0.472	0.472	1204399	-----	241618
CD30TE02(U/S)	0.688	0.893	0.472	0.472	-----	1080385	241618
CD30TE02(D/S)	0.688	1.023	0.472	0.472	-----	882906	241618
CD30TE02(BR.)	0.594	0.682	0.394	0.394	851983	-----	241618
CD30SP04 US	0.688	0.626	0.472	0.472	-----	1082898	241618
CD30SP04 DS	0.688	0.658	0.472	0.472	-----	1308712	241618
CD30TE03(U/S)	0.688	0.874	0.472	0.472	1384564	-----	241618
CD30TE03(D/S)	0.688	0.883	0.472	0.472	885578	-----	241618
CD30TE03(BR.)	0.594	0.489	0.394	0.394	290627	-----	241618
CD30SP05 US	0.688	0.650	0.472	0.472	-----	784763	241618
CD30SP05 DS	0.688	0.616	0.472	0.472	635428	-----	241618
CD30EL05	0.688	0.569	0.472	0.472	259732	-----	241618
CD30SP06	0.688	0.660	0.472	0.472	-----	755904	241618
CD30EL06	0.688	0.635	0.472	0.472	-----	411011	241618
CD30SP07	0.688	0.640	0.472	0.472	-----	594109	241618
CD30TE04(U/S)	0.688	0.490	0.472	0.472	28535	-----	241618
CD30TE04(D/S)	0.688	0.564	0.472	0.472	235433	-----	241618
CD30TE04(BR.)	0.594	0.486	0.394	0.394	273230	-----	241618
CD30RD02(L/E)	0.688	0.837	0.472	0.472	1473385	-----	241618
CD30RD02(S/E)	0.594	0.495	0.394	0.394	328682	-----	241618

===>Grouped by Line: 037-15*-C-30, No Sorting.							
CD36EL13	0.500	0.349	0.315	0.315	70500	-----	241618
INLET NOZZLE P-1-1A	0.500	0.336	0.315	0.315	41343	-----	241618

===>Grouped by Line: 037-20*-C-30, No Sorting.							
CD36SP08 US	0.594	0.526	0.394	0.394	-----	546937	241618
CD36SP08 DS	0.594	0.517	0.394	0.394	509826	-----	241618
CD30EL07	0.594	0.480	0.394	0.394	241257	-----	241618
CD30VA02	0.594	0.442	0.421	0.421	43124	-----	241618
CD36SP09	0.594	0.525	0.394	0.394	622747	-----	241618
CD30EL08	0.594	0.486	0.394	0.394	273230	-----	241618
CD30EL09	0.594	0.486	0.394	0.394	273230	-----	241618
CD30EL10	0.594	0.517	0.394	0.394	509826	-----	241618
CD30EL10	0.594	0.480	0.394	0.394	241257	-----	241618
CD36SP11	0.594	0.495	0.394	0.394	328682	-----	241618
CD36FE01	0.594	0.593	0.420	0.420	2698356	-----	241618
CD36FE01A	0.412	0.836	0.460	0.460	-----	1571069	241618
CD30EL11	0.594	0.736	0.394	0.394	-----	1011135	241618
CD36FE12	0.594	0.550	0.394	0.394	-----	647083	241618
CD30EL12	0.594	0.591	0.394	0.394	-----	551438	241618
CD36SP13	0.594	0.495	0.394	0.394	328682	-----	241618
CD36RD03(L/E)	0.594	0.517	0.394	0.394	509826	-----	241618
CD36RD03(S/E)	0.500	0.426	0.315	0.315	440859	-----	241618

===>Grouped by Line: 037-15*-C-32, No Sorting.							
CD36EL06	0.500	0.349	0.315	0.315	70500	-----	241618
INLET NOZZLE P-1-1B	0.500	0.336	0.315	0.315	41343	-----	241618

====Grouped by Line: 039-20*-C-32, No Sorting.


CD30SP05	0.594	0.530	0.394	0.394	-----	540826	241618
CD32SP04	0.594	0.508	0.394	0.394	-----	584349	241618
CD32EL03	0.594	0.681	0.394	0.394	-----	449030	241618
CD32VA01	0.594	0.442	0.421	0.421	43124	-----	241618
CD32EL03	0.594	0.480	0.394	0.394	241257	-----	241618
CD32EP01	0.594	0.495	0.394	0.394	328682	-----	241618
CD32FE01	0.594	0.593	0.420	0.420	36983356	-----	241618
CD32FE01A	0.812	0.736	0.460	0.460	-----	1151929	241618
CD32EL04	0.594	0.662	0.394	0.394	-----	789453	241618
CD32SP02	0.594	0.517	0.394	0.394	509826	-----	241618
CD32EL05	0.594	0.480	0.394	0.394	241257	-----	241618
CD32SP03	0.594	0.495	0.394	0.394	328682	-----	241618
CD32RD01(L/E)	0.594	0.517	0.394	0.394	509826	-----	241618
CD32RD01(S/E)	0.500	0.426	0.315	0.315	480859	-----	241618

Note:

[1] Predictions are based on last Tmeas to analysis ending period.

Tpred/Tcrit Ratio Plot

Cond2006 E3 to 2 FWP




Now

18 Months from Now

166

Cumulative % of Comp. Time to Tcrit

Cond2006 E3 to 2 FWP





Wear Rate Analysis Run Definition

Run Name: Cond2006 E3 to J FWP

Run Title: Condensate E3A,B to J FDW Pumps Run'g

Ending Period: CYCLE 25

Total Oper. Hrs.: 241618.44

Duty Factor: 1.000

Analysis Options

Ignore IIFA Results

IIFA Results 1st Priority

User Input 1st Priority

Do Not Use Measured Wear

Database Lines		Add	Remove	Lines to Analyze
001-16"-FDW-01	▲	>	<	034-20"-C-29
002-16"-FDW-02	▲	>>	<	035-20"-C-30
003-16"-FDW-03	▲	>>>	<	036-24"-C-30
004-24"-FDW-01	▲	>>>>	<	037-20"-C-30
005-18"-FDW-07	▲	>>>>>	<	037-16"-C-30
006-18"-FDW-07	▲	>>>>>>	<	038-20"-C-31
007-18"-FDW-12	▲	>>>>>>>	<	038-16"-C-31
008-16"-FDW-14	▼	>>>>>>>>	<	039-20"-C-32

Run Definitions

- 5th Pt Extract Steam
- 5th Pt Heater Drains
- Cond LP Htr Bypass
- Cond Minimum Flow
- Cond2006 E3 to J FWP**
- Cond2006 E4 to E3
- Condensate
- FDW 2006 E1s to Rx
- FDW 2006 Hdr to E2s
- FDW06 2 P1s to Hdr.
- FDW06 3-P1s to Hdr
- FDW2006 2P1s to E2s
- FDW2006 E2s to E1s
- Feed Pump Recirc
- Feedwater
- Feedwater Flush
- Feedwater Low Flow
- Heater Drain Pumps
- Main Steam 2006

< Prev	Next >	Add	Reset	Save
Copy	Delete	Print...	Help	Done

[Advanced Run Def...](#)

List of Defined Wear Rate Runs

108





Wear Rate Analysis Run Definition

Run Name: Cond2006 E3 to 3 FWP

Run Title: Condensate E3A,B to 3 FDW Pumps Run'g

Ending Period: CYCLE 25

Total Oper. Hrs.: 241618.44

Duty Factor: 1.000

Analysis Options

Ignore IIFA Results

IIFA Results 1st Priority

User Input 1st Priority

Do Not Use Measured Wear

Database Lines		Add	Remove	Lines to Analyze
001-16"-FDW-01	▲	>	<	035-20"-C-30
002-16"-FDW-02	▲	>>	<	036-24"-C-30
003-16"-FDW-03	▲	>>>	<	037-20"-C-30
004-24"-FDW-01	▲	>>>>	<	037-16"-C-30
005-18"-FDW-07	▲	>>>>>	<	038-20"-C-31
006-18"-FDW-07	▲	>>>>>>	<	038-16"-C-31
007-18"-FDW-12	▲	>>>>>>>	<	039-20"-C-32
008-16"-FDW-14	▼	>>>>>>>>	<	039-16"-C-32

Run Definitions

5th Pt Exh act Steam

5th Pt Heater Drains

Cond LP Htr Bypass

Cond Minimum Flow

Cond2006 E3 to 3 FWP

Cond2006 E4 to E3

Condensate

FDW 2006 E1s to Rx

FDW 2006 Hdr to E2s

FDW06 2 P1s to Hdr

FDW06 3-P1s to Hdr

FDW2006 2P1s to E2s

FDW2006 E2s to E1s

Feed Pump Recirc

Feedwater

Feedwater Flush

Feedwater Low Flow

Heater Drain Pumps

Main Steam 2006

< Prev	Next >	Add	Reset	Save
Copy	Delete	Print...	Help	Done


[Advanced Run Def...](#)

List of Defined Wear Rate Runs

169




Comparison of Wear Predictions



170



Comparison of Thickness Predictions



171

Company: Vermont Yankee Nuclear Power Corporation Report Date: 28-SEP-2006 Time: 08:51:41
 Plant: Vermont Yankee Analysis Date: 28-SEP-2006 Time: 08:47:32
 Unit: CHECWORKS FAC Version 1.0F (Build 52)
 LS Name: VY

*** Wear Rate Analysis: Combined Summary Report ***

Run Name: Cond2006 E3 to 3 FWP
 Ending Period: CYCLE 24
 Total Plant Operating Hours: 241618 Duty Factor (Global): 1.000
 NFA Data Option: Ignore NFA Exclude Measure Wear: No
 Line Correction Factor: 0.252

Component Name	Geom Code	Average Wear Rate (mils/year)	Current Wear Rate (mils/year)	Thickness (in)			Component Predict[1] Time to Tcrit (hrs)		Total Lifetime Wear (mils)		In-Service Cmp. Wear (mils)		In-Service Cmp. Tmeas, Method, Time (in) [4] [3] (hrs) [4]		Time (hrs) Last Inspected			
				Init.	Prd. [1]	Thoop	Tcrit	Non-Insp.	Insp.	Prd. [2]	Meas.	Prd. [2]	Meas.					
===Grouped by Line: 034-20*-C-29, No Sorting.																		
OUTLET NOZZLE	E-3-1A	31	4.546	4.039	0.594	0.534	0.394	0.394	304197	-----	---	---	---	0.594	--	125911	-----	
CD30EL01		4	3.937	2.989	0.594	0.485	0.394	0.394	268836	-----	---	---	---	0.594	--	0	-----	
CD30SP01		54	3.405	2.585	0.594	0.500	0.394	0.394	360571	-----	---	---	---	0.594	--	0	-----	
CD30VA01		22	5.254	3.988	0.594	0.449	0.421	0.421	60937	-----	---	---	---	0.594	--	0	-----	
CD30EL02		4	3.937	2.989	0.594	0.476	0.394	0.394	240659	-----	---	---	---	0.526	MT	114614	-----	
CD30SP02 US		54	3.405	2.585	0.594	0.531	0.394	0.394	-----	466883	45.4	34.0	45.4	34.0	0.580	MT	102975	102975
CD30SP02 DS		54	3.405	2.585	0.594	0.500	0.394	0.394	360571	-----	---	---	---	0.594	--	0	-----	
CD30EL03		4	3.937	2.989	0.594	0.629	0.394	0.394	-----	689327	52.5	125.0	52.5	125.0	0.685	GW	102975	102975
CD30SP03 US		54	3.405	2.585	0.594	0.535	0.394	0.394	-----	480439	45.4	36.0	45.4	36.0	0.584	GW	102975	102975
CD30SP03 DS		54	3.405	2.585	0.594	0.554	0.394	0.394	-----	544832	45.4	59.0	45.4	59.0	0.603	GW	102975	102975

===Grouped by Line: 035-20*-C-30, No Sorting.																		
OUTLET NOZZLE	E-3-1B	31	4.546	4.039	0.594	0.534	0.394	0.394	304197	-----	---	---	---	0.594	--	125911	-----	
CD30EL01		4	3.937	2.989	0.594	0.485	0.394	0.394	268836	-----	---	---	---	0.594	--	0	-----	
CD30VA01		22	5.254	3.988	0.594	0.449	0.421	0.421	60937	-----	---	---	---	0.594	--	0	-----	
CD30EL02		4	3.937	2.989	0.594	0.545	0.394	0.394	-----	443209	91.5	96.0	91.5	96.0	0.562	GW	195618	195618
CD30EL03		4	3.937	2.989	0.594	0.519	0.394	0.394	-----	367000	91.5	135.0	91.5	135.0	0.536	GW	195618	195618
CD30SP01 US		54	3.405	2.585	0.594	0.500	0.394	0.394	360571	-----	---	---	---	0.594	--	0	-----	
CD30SP01 DS		54	3.405	2.585	0.594	0.500	0.394	0.394	360571	-----	---	---	---	0.594	--	0	-----	
CD30EL04		2	3.937	2.989	0.594	0.485	0.394	0.394	268836	-----	---	---	---	0.594	--	0	-----	
CD30SP02 US		52	2.660	2.019	0.594	0.521	0.394	0.394	550644	-----	---	---	---	0.594	--	0	-----	
CD30SP02 DS		52	2.660	2.019	0.594	0.521	0.394	0.394	550644	-----	---	---	---	0.594	--	0	-----	

===Grouped by Line: 036-24*-C-30, No Sorting.																		
CD30SP03DS		9	0.856	0.650	0.688	0.650	0.472	0.472	-----	2396788	21.9	36.0	21.9	36.0	0.652	MT	218618	218618
CD30RD01 (L/E)		18	2.335	1.773	0.688	0.624	0.472	0.472	746881	-----	---	---	---	0.688	--	0	-----	
CD30RD01 (S/E)		18	2.979	2.262	0.594	0.512	0.394	0.394	457547	-----	---	---	---	0.594	--	0	-----	
CD30TE01 (U/S)		15	2.335	1.773	0.688	0.624	0.472	0.472	746881	-----	---	---	---	0.688	--	0	-----	
CD30TE01 (D/S)		15	2.335	1.773	0.688	0.624	0.472	0.472	746881	-----	---	---	---	0.688	--	0	-----	
CD30SP03		65	1.557	1.182	0.688	0.645	0.472	0.472	1279453	-----	---	---	---	0.688	--	0	-----	
CD30TE02 (U/S)		14	4.281	3.250	0.688	0.893	0.472	0.472	-----	1134771	109.5	140.0	109.5	140.0	0.902	MT	218618	218618
CD30TE02 (D/S)		14	6.853	5.203	0.688	1.023	0.472	0.472	-----	927559	175.4	133.0	175.4	133.0	1.037	GW	218618	218618
CD30TE02 (BR.)		14	3.724	2.827	0.594	0.683	0.394	0.394	895111	-----	---	---	---	0.690	GW	218618	218618	
CD30SP04 US		64	1.557	1.182	0.688	0.626	0.472	0.472	-----	1137408	39.8	52.0	39.8	52.0	0.629	MT	218618	218618
CD30SP04 DS		64	1.557	1.182	0.688	0.659	0.472	0.472	-----	1381328	20.7	30.0	20.7	30.0	0.681	MT	102975	102975
CD30TE03 (U/S)		12	3.191	2.423	0.688	0.877	0.472	0.472	1460918	-----	---	---	---	0.922	MT	102975	-----	
CD30TE03 (D/S)		12	5.095	3.868	0.688	0.886	0.472	0.472	937337	-----	---	---	---	0.959	MT	102975	-----	
CD30TE03 (BR.)		12	3.617	2.746	0.594	0.494	0.394	0.394	320639	-----	---	---	---	0.594	--	0	-----	
CD30SP05 US		64	2.486	1.887	0.688	0.652	0.472	0.472	-----	831553	33.1	53.0	33.1	53.0	0.687	GW	102975	102975
CD30SP05 DS		64	2.486	1.887	0.688	0.619	0.472	0.472	682436	-----	---	---	---	0.688	--	0	-----	
CD30EL04		1	4.101	3.114	0.688	0.575	0.472	0.472	288222	-----	---	---	---	0.688	--	0	-----	
CD30SP06		51	2.734	2.076	0.688	0.661	0.472	0.472	-----	797648	53.9	33.0	53.9	33.0	0.683	GW	160352	160352
CD30EL05		3	4.350	3.302	0.688	0.637	0.472	0.472	-----	435754	85.7	82.0	85.7	82.0	0.671	MT	160352	160352
CD30SP07		53	3.107	2.359	0.688	0.642	0.472	0.472	-----	627877	61.2	27.0	61.2	27.0	0.666	MT	160352	160352
CD30TE04 (U/S)		14	6.835	5.189	0.688	0.499	0.472	0.472	45628	-----	---	---	---	0.688	--	0	-----	
CD30TE04 (D/S)		14	4.281	3.250	0.688	0.570	0.472	0.472	262725	-----	---	---	---	0.688	--	0	-----	
CD30TE04 (BR.)		14	3.724	2.827	0.594	0.491	0.394	0.394	302385	-----	---	---	---	0.594	--	0	-----	
CD30RD02 (L/E)		7	2.724	2.068	0.688	0.839	0.472	0.472	1550493	-----	---	---	---	0.860	MT	160352	-----	
CD30RD02 (S/E)		7	3.405	2.585	0.594	0.500	0.394	0.394	360571	-----	---	---	---	0.527	PW	160352	-----	

===Grouped by Line: 037-20*-C-30, No Sorting.																		
CD30SP08 US		57	2.660	2.019	0.594	0.527	0.394	0.394	-----	578380	52.4	46.0	52.4	46.0	0.548	MT	160352	160352
CD30SP08 DS		57	2.660	2.019	0.594	0.521	0.394	0.394	550644	-----	---	---	---	0.594	--	0	-----	
CD30EL07		7	3.937	2.989	0.594	0.485	0.394	0.394	268836	-----	---	---	---	0.594	--	0	-----	

172

CD30FA02	22	5.254	3.988	0.594	0.449	0.421	0.421	60937	-----	---	---	---	---	0.594	--	0	-----
CD30SF03	58	2.341	1.777	0.594	0.529	0.394	0.394	669131	-----	---	---	---	---	0.594	--	0	-----
CD30EL08	3	3.724	2.827	0.594	0.491	0.394	0.394	302385	-----	---	---	---	---	0.594	--	0	-----
CD30EL09	3	3.724	2.827	0.594	0.491	0.394	0.394	302385	-----	---	---	---	---	0.594	--	0	-----
CD30SP10	53	2.660	2.019	0.594	0.521	0.394	0.394	550644	-----	---	---	---	---	0.594	--	0	-----
CD30EL10	4	3.937	2.989	0.594	0.485	0.394	0.394	268836	-----	---	---	---	---	0.594	--	0	-----
CD30SP11	54	3.405	2.585	0.594	0.500	0.394	0.394	360571	-----	---	---	---	---	0.594	--	0	-----
CD30FE01	6	0.051	0.039	0.594	0.593	0.420	0.420	38821984	-----	---	---	---	---	0.594	--	0	-----
CD30FE01A	56	2.633	1.999	0.812	0.836	0.460	0.460	-----	1649076	70.0	28.0	70.0	36.0	0.839	MT	230118	230118
CD30EL11	3	3.724	2.827	0.594	0.736	0.394	0.394	-----	1061541	99.0	99.0	99.0	99.0	0.740	GW	230118	230118
CD30SP12	53	2.660	2.019	0.594	0.550	0.394	0.394	-----	679545	70.7	38.0	70.7	38.0	0.553	MT	230118	230118
CD30EL12	4	3.937	2.989	0.594	0.594	0.394	0.394	-----	586738	52.5	74.0	52.5	74.0	0.650	GW	102975	102975
CD30SP13	54	3.405	2.585	0.594	0.500	0.394	0.394	-----	-----	---	---	---	---	0.594	--	0	-----
CD30RD01 (L/E)	17	2.660	2.019	0.594	0.521	0.394	0.394	-----	-----	---	---	---	---	0.594	--	0	-----
CD30RD01 (S/E)	17	2.546	1.933	0.500	0.430	0.315	0.315	-----	-----	---	---	---	---	0.500	--	0	-----

---Grouped by Line: 037-16*-C-30, No Sorting.

CD30EL13	4	5.234	3.974	0.500	0.356	0.315	0.315	89662	-----	---	---	---	---	0.500	--	0	-----
INLET NOZZLE P-1-1A	30	5.658	4.296	0.500	0.344	0.315	0.315	59068	-----	---	---	---	---	0.500	--	0	-----

---Grouped by Line: 038-20*-C-31, No Sorting.

CD31VA01	27	5.254	3.988	0.594	0.449	0.421	0.421	60937	-----	---	---	---	---	0.594	--	0	-----
CD31SP01	58	2.341	1.777	0.594	0.529	0.394	0.394	669131	-----	---	---	---	---	0.594	--	0	-----
CD31EL01	3	3.724	2.827	0.594	0.491	0.394	0.394	302385	-----	---	---	---	---	0.594	--	0	-----
CD31EL02	3	3.724	2.827	0.594	0.491	0.394	0.394	302385	-----	---	---	---	---	0.594	--	0	-----
CD31SP02	53	2.660	2.019	0.594	0.521	0.394	0.394	550644	-----	---	---	---	---	0.594	--	0	-----
CD31EL03	4	3.937	2.989	0.594	0.485	0.394	0.394	268836	-----	---	---	---	---	0.594	--	0	-----
CD31SP03	54	3.405	2.585	0.594	0.500	0.394	0.394	360571	-----	---	---	---	---	0.594	--	0	-----
CD31FE01	6	0.051	0.039	0.594	0.593	0.420	0.420	38821984	-----	---	---	---	---	0.594	--	0	-----
CD31FE01A	56	2.633	1.999	0.812	0.761	0.460	0.460	-----	1320359	70.0	44.0	70.0	44.0	0.764	MT	230118	230118
CD31EL04	3	3.724	2.827	0.594	0.679	0.394	0.394	-----	884921	99.0	85.0	99.0	85.0	0.683	GW	230118	230118
CD31SP04	53	2.660	2.019	0.594	0.545	0.394	0.394	-----	657855	70.7	46.0	70.7	46.0	0.548	MT	230118	230118
CD31EL05	4	3.937	2.989	0.594	0.485	0.394	0.394	-----	-----	---	---	---	---	0.594	--	0	-----
CD31SP05	54	3.405	2.585	0.594	0.500	0.394	0.394	-----	-----	---	---	---	---	0.594	--	0	-----
CD31RD01 (L/E)	17	2.660	2.019	0.594	0.626	0.394	0.394	-----	1067845	52.4	192.0	52.4	192.0	0.647	GW	160352	160352
CD31RD01 (S/E)	17	2.546	1.933	0.500	0.788	0.315	0.315	-----	2143244	50.2	123.0	50.2	123.0	0.808	GW	160352	160352

---Grouped by Line: 038-16*-C-31, No Sorting.

CD31EL06	4	5.234	3.974	0.500	0.468	0.315	0.315	-----	336789	103.1	102.0	103.1	102.0	0.509	GW	160352	160352
INLET NOZZLE P-1-1B	30	5.658	4.296	0.500	0.344	0.315	0.315	59068	-----	---	---	---	---	0.500	--	0	-----

---Grouped by Line: 039-20*-C-32, No Sorting.

CD30SP05	51	2.341	1.777	0.594	0.530	0.394	0.394	-----	673546	59.9	59.0	59.9	59.0	0.535	MT	218618	218618
CD32SP04	64	2.128	1.615	0.594	0.508	0.394	0.394	-----	618482	54.5	75.0	54.5	75.0	0.512	MT	218618	218618
CD32EL02	3	3.724	2.827	0.594	0.682	0.394	0.394	-----	892013	95.3	160.0	95.3	160.0	0.689	GW	218618	218618
CD32VA01	22	5.254	3.988	0.594	0.449	0.421	0.421	60937	-----	---	---	---	---	0.594	--	0	-----
CD32EL03	4	3.937	2.989	0.594	0.485	0.394	0.394	268836	-----	---	---	---	---	0.594	--	0	-----
CD32SP01	54	3.405	2.585	0.594	0.500	0.394	0.394	360571	-----	---	---	---	---	0.594	--	0	-----
CD32FE01	6	0.051	0.039	0.594	0.593	0.420	0.420	38821984	-----	---	---	---	---	0.594	--	0	-----
CD32FE01A	56	2.633	1.999	0.812	0.739	0.460	0.460	-----	1223976	61.2	23.0	61.2	23.0	0.751	PW	195618	195618
CD32EL04	3	3.724	2.827	0.594	0.662	0.394	0.394	-----	830835	86.5	95.0	86.5	95.0	0.678	GW	195618	195618
CD32SP02	53	2.660	2.019	0.594	0.521	0.394	0.394	550644	-----	---	---	---	---	0.594	--	0	-----
CD32EL05	4	3.937	2.989	0.594	0.485	0.394	0.394	268836	-----	---	---	---	---	0.594	--	0	-----
CD32SP03	54	3.405	2.585	0.594	0.500	0.394	0.394	360571	-----	---	---	---	---	0.594	--	0	-----
CD32RD01 (L/E)	17	2.660	2.019	0.594	0.521	0.394	0.394	550644	-----	---	---	---	---	0.594	--	0	-----
CD32RD01 (S/E)	17	2.546	1.933	0.500	0.430	0.315	0.315	520249	-----	---	---	---	---	0.500	--	0	-----

---Grouped by Line: 039-16*-C-32, No Sorting.

CD32EL06	4	5.234	3.974	0.500	0.356	0.315	0.315	89662	-----	---	---	---	---	0.500	--	0	-----
INLET NOZZLE F-1-1C	30	5.658	4.296	0.500	0.344	0.315	0.315	59068	-----	---	---	---	---	0.500	--	0	-----

Notes:

- (1) Predictions are based on last Tmeas to analysis ending period.
- (2) Predictions are for the time of last inspection (last known meas. wear).
- (3) MW = Tmeas is minimum thickness from Band, Blanket or Area Method of greatest wear.
MT = Tmeas is component minimum thickness.
PW = Tmeas is Tinit - predicted wear.
US = Tmeas is user specified.
- (4) If no Tmeas has been determined from measured data, then Tmeas = Tinit and Time = current component installation time.
Tmeas is used to determine Predicted Thickness and Component Predicted Time to Tcrit.

173

*** Wear Rate Analysis: Wear Predictions Report ***

Run Name: Cond2006 R1 to 3 FWP
 Ending Period: CYCLE 25
 Total Plant Operating Hours: 241618 Duty Factor (Global): 1.000
 NFA Data Option: Ignore NFA Exclude Measure Wear: No
 Line Correction Factor: 0.250

Component Name	Total Lifetime In-Service Cmp. Wear (mils)		In-Service Cmp. Tmeas, Method, Time		In-Service Cmp. Thickness(mils) [4]		Incremental Wear(mils) [5] PRWEAR	Time (hrs) Last Inspected			
	Prd. [1]	Meas.	Prd. [1]	Meas.	Time (in) [3]	Time (hrs) [2]			Tp	Tm	
===Grouped by Line: 034-20*-C-29, No Sorting.											
CD02P02 US	45.4	34.0	45.4	34.0	0.580	MT	102975	548.6	580.0	48.5	102975
CD02E03	52.5	135.0	52.5	135.0	0.685	GW	102975	541.5	685.0	56.1	102975
CD03P03 US	45.4	36.0	45.4	36.0	0.584	GW	102975	546.6	584.0	48.5	102975
CD03E03 US	45.4	59.0	45.4	59.0	0.603	GW	102975	548.6	603.0	48.5	102975
===Grouped by Line: 035-20*-C-30, No Sorting.											
CD06E03	91.5	96.0	91.5	96.0	0.562	GW	195618	502.5	562.0	17.1	195618
CD06E03	91.5	135.0	91.5	135.0	0.536	GW	195618	502.5	536.0	17.1	195618
===Grouped by Line: 036-24*-C-30, No Sorting.											
CD06SP03D	21.9	36.0	21.9	36.0	0.652	MT	218618	666.1	652.0	1.7	218618
CD06E03 (U.S)	109.5	140.0	109.5	140.0	0.902	MT	218618	578.5	902.0	8.5	218618
CD06E03 (D/S)	175.4	133.0	175.4	133.0	1.037	GW	218618	512.6	1037.0	13.7	218618
CD06SP03 UC	39.8	52.0	39.8	52.0	0.629	MT	218618	648.2	629.0	3.1	218618
CD06SP03 DG	20.7	30.0	20.7	30.0	0.681	MT	102975	667.3	681.0	22.2	102975
CD06SP03 US	33.1	53.0	33.1	53.0	0.687	GW	102975	654.9	687.0	35.4	102975
CD06SP03	53.9	33.0	53.9	33.0	0.683	GW	160352	634.1	683.0	21.6	160352
CD06E03	85.7	82.0	85.7	82.0	0.671	MT	160352	602.3	671.0	34.3	160352
CD06SP03	61.2	27.0	61.2	27.0	0.666	MT	160352	626.8	666.0	24.5	160352
===Grouped by Line: 037-20*-C-30, No Sorting.											
CD30SP08 US	52.4	46.0	52.4	46.0	0.548	MT	160352	541.6	548.0	21.0	160352
CD06E01A	70.0	28.0	70.0	28.0	0.839	MT	230118	742.0	839.0	2.6	230118
CD06E01	99.0	99.0	99.0	99.0	0.740	GW	230118	495.0	740.0	3.7	230118
CD06SP12	70.7	38.0	70.7	38.0	0.553	MT	230118	523.3	553.0	2.7	230118
CD06E01B	52.5	74.0	52.5	74.0	0.650	GW	102975	541.5	650.0	56.1	102975
===Grouped by Line: 037-16*-C-30, No Sorting.											
===Grouped by Line: 038-20*-C-31, No Sorting.											
CD06E01A	70.0	44.0	70.0	44.0	0.764	MT	230118	742.0	764.0	2.6	230118
CD06E04	99.0	85.0	99.0	85.0	0.683	GW	230118	495.0	683.0	3.7	230118
CD06SP04	70.7	46.0	70.7	46.0	0.548	MT	230118	523.3	548.0	2.7	230118
CD06E01 (L/E)	52.4	192.0	52.4	192.0	0.647	GW	160352	541.6	647.0	21.0	160352
CD06AD01 (S/E)	50.2	123.0	50.2	123.0	0.808	GW	160352	449.8	808.0	20.1	160352
===Grouped by Line: 038-16*-C-31, No Sorting.											
CD06E03	103.1	102.0	103.1	102.0	0.509	GW	160352	396.9	509.0	41.3	160352
===Grouped by Line: 039-20*-C-32, No Sorting.											
CD06SP05	59.9	59.0	59.9	59.0	0.535	MT	218618	534.1	535.0	4.7	218618
CD06SP04	54.5	75.0	54.5	75.0	0.512	MT	218618	539.5	512.0	4.3	218618
CD06E02	95.3	160.0	95.3	160.0	0.689	GW	218618	498.7	689.0	7.4	218618
CD06E01A	61.2	23.0	61.2	23.0	0.751	FW	195618	750.8	750.8	11.4	195618
CD06E03	86.5	95.0	86.5	95.0	0.678	GW	195618	507.5	678.0	16.2	195618

===Grouped by Line: 039-16*-C-32, No Sorting.

h/h

- (1) Predictions are for the time of last inspection (last known meas. wear).
- (2) W = T_{meas} is minimum thickness from Band, Blanket or Area Method of greatest wear.
 NT = T_{meas} is component minimum thickness.
 M = T_{meas} is T_{init} - predicted wear.
 US = T_{meas} is user specified.
- (3) If no T_{meas} has been determined from measured data, then $T_{meas} = T_{init}$ and T_{ime} = current component installation time.
 T_{meas} is used to determine Predicted Thickness and Component Predicted Time to T_{crit} .
- (4) These two values are used for thickness plot.
 T_p = Predicted thickness at T_{meas} .
 T_m = Last measured thickness (T_{meas}).
- (5) $PRWEAK$ = Incremental wear from last T_{meas} time to analysis ending period.

176

Company: Vermont Yankee Nuclear Power Corporation Report Date: 28-SEP-2006 Time: 08:51:32
 Plant: Vermont Yankee Analysis Date: 28-SEP-2006 Time: 08:47:32
 Unit: CHECWORKS FAC Version 1.0F (Build 52)
 CS Name: VY

 *** Wear Rate Analysis: Combined Rankings for Inspection ***

File Name: Cond2006 E3 to 3 FWP
 Ending Period: CYCLE 25
 Total Plant Operating Hours: 241618 Duty Factor (Global): 1.000
 AKA Data Option: Ignore NFA Exclude Measure Wear: No
 Line Correction Factor: 0.352

Component Name	Geometry Code	Average Wear Rate (mils/year)	Component Predicted Time to Torit (hrs)	
			Non-Inspected	Inspected
CD00EL05	3	4.350	-----	435754
CD01EL06	4	5.234	-----	336789
CD00FE01	6	0.051	38821984	-----
CD00RE02 (S.E)	7	3.405	360571	-----
CD00VA01	22	5.254	60937	-----
CD00SP03 DS	54	3.405	-----	544832
CD00TE02 (D.S)	14	6.853	-----	927559
CD00TE04 (U.S)	14	6.835	45628	-----
INLET NOZZLE P-1-1C	30	5.658	59068	-----
INLET NOZZLE P-1-1B	30	5.658	59068	-----
INLET NOZZLE P-1-1A	30	5.658	59068	-----
CD00VA02	22	5.254	60937	-----
CD00VA01	22	5.254	60937	-----
CD01VA01	22	5.254	60937	-----
CD02VA01	22	5.254	60937	-----
CD01EL06	4	5.234	89662	-----
CD00EL13	4	5.234	89662	-----
CD09EL02	4	3.937	240659	-----
CD00TE04 (P/S)	14	4.281	262725	-----
CD00TE03 (D.S)	12	5.095	937337	-----
CD02EL05	4	3.937	268836	-----
OUTLET NOZZLE E-3-1B	31	4.546	304197	-----
CD00EL10	4	3.937	268836	-----
OUTLET NOZZLE E-3-1A	31	4.546	304197	-----
CD01EL03	4	3.937	268836	-----
CD00EL03	4	3.937	268836	-----
CD00EL01	4	3.937	268836	-----
CD00TE02 (U/S)	14	4.281	-----	1134771
CD00EL07	2	3.937	268836	-----
CD00RE05	1	4.101	288222	-----
CD09EL01	4	3.937	268836	-----
CD00EL04	2	3.937	268836	-----
CD01EL05	4	3.937	268836	-----
CD00EL00	3	3.724	302385	-----
CD01EL01	3	3.724	302385	-----
CD01EL02	3	3.724	302385	-----
CD00EL08	3	3.724	302385	-----
CD00TE04 (BR.)	14	3.724	302385	-----
CD00EL12	4	3.937	-----	586738
CD00EL09	4	3.937	-----	367000
CD00TE05 (BR.)	12	3.617	320639	-----
CD09EL03	4	3.937	-----	689327
CD00EL02	4	3.937	-----	443209
CD02SP01	54	3.405	360571	-----
CD00EL11	3	3.724	-----	1061541
CD00SP03	54	3.405	360571	-----
CD00SP11	54	3.405	360571	-----
CD00SP03	54	3.405	360571	-----
CD00SP05	54	3.405	360571	-----
CD00SP01 DS	54	3.405	360571	-----
CD00EL04	3	3.724	-----	830835
CD00SP01	54	3.405	360571	-----
CD00TE02 (BR.)	14	3.724	895111	-----
CD00SP01 US	54	3.405	360571	-----
CD02EL03	3	3.724	-----	892013
CD09SP02 DS	54	3.405	360571	-----
CD00SP13	54	3.405	360571	-----
CD01EL04	3	3.724	-----	884921
CD00RD01 (S.E)	18	2.979	457547	-----
CD00SP02 DS	54	3.405	-----	466883

177

CD39SP03 US	54	3.405	-----	480439
CD39RE01 (S-E)	17	2.546	520249	-----
CD39RE03 (S-E)	17	2.546	520249	-----
CD39SE02 US	52	2.660	550644	-----
CD39SE03	53	2.660	550644	-----
CD39SE10	53	2.660	550644	-----
CD39SE08 DS	57	2.660	550644	-----
CD39SE02	53	2.660	550644	-----
CD39SE02 DS	52	2.660	550644	-----
CD39RE03 (L-E)	17	2.660	550644	-----
CD39TE03 (U-S)	12	3.191	1460918	-----
CD39RE03 (L-E)	17	2.660	550644	-----
CD39SE07	53	3.107	-----	627877
CD39SP08 US	57	2.860	-----	578380
CD39SP06	51	2.734	-----	797648
CD39SE04	64	2.128	-----	618482
CD39RE02 (L-E)	7	2.734	1550493	-----
CD39SP12	53	2.660	-----	679545
CD39SP04	53	2.660	-----	657855
CD39SE01	58	2.341	669131	-----
CD39SE09	58	2.341	669131	-----
CD39SE05	51	2.341	-----	673546
CD39SP05 DS	64	2.486	682436	-----
CD39RE01 (L-E)	17	2.660	-----	1007845
CD39TE01 (U-S)	15	2.335	746881	-----
CD39TE01 (U-S)	15	2.335	746881	-----
CD39RE03 (L-E)	18	2.335	746881	-----
CD39FE01A	56	2.633	-----	1223976
CD39SP05 US	64	2.486	-----	831553
CD39FE01A	56	2.633	-----	1320359
CD39FE01A	58	2.633	-----	1649076
CD39RE01 (S-E)	17	2.546	-----	2143244
CD39SP04 US	64	1.557	-----	1137408
CD39SP03	65	1.557	1279453	-----
CD39SP04 US	64	1.557	-----	1381328
CD39SP03DS	9	0.856	-----	2396788
CD39FE01	6	0.051	38821984	-----
CD39FE01	6	0.051	38821984	-----

178

Company: Vermont Yankee Nuclear Power Corporation Report Date: 28-SEP-2006 Time: 08:51:28
 Plant: Vermont Yankee Analysis Date: 28-SEP-2006 Time: 08:47:52
 Unit: CHECWORKS FAC Version 1.0F (Build 52)
 UR Name: VY

 *** Wear Rate Analysis: Thickness/Service Time Report ***

Run Name: Cond2006 E3 to 3 FWP
 Ending Period: CYCLE 25
 Total Plant Operating Hours: 241618
 NRA Data Option: Ignore NFA
 Line Correction Factor: 0.252
 Duty Factor (Global): 1.000
 Exclude Measure Wear: No

Component Name	Thickness (in)				Component Predicted(1) Time to Tcrit (hrs)		Component Actual Service Time (hrs)
	Init.	Prd.(1)	Thoop	Tcrit	Non-Inspected	Inspected	
===Grouped by Line: 034-20*-C-29, No Sorting.							
OUTLET NOZZLE E-3-1A	0.594	0.534	0.394	0.394	304197	-----	115707
CD29EL01	0.594	0.485	0.394	0.394	268836	-----	241618
CD29SP01	0.594	0.500	0.394	0.394	360571	-----	241618
CD29VA01	0.594	0.449	0.421	0.421	60937	-----	241618
CD29EL02	0.594	0.476	0.394	0.394	240659	-----	241618
CD29SP01 US	0.594	0.531	0.394	0.394	-----	466883	241618
CD29SP02 DS	0.594	0.500	0.394	0.394	360571	-----	241618
CD29EL03	0.594	0.629	0.394	0.394	-----	689327	241618
CD29SP03 US	0.594	0.535	0.394	0.394	-----	480439	241618
CD29SP03 DS	0.594	0.554	0.394	0.394	-----	544832	241618
===Grouped by Line: 035-20*-C-30, No Sorting.							
OUTLET NOZZLE E-3-1B	0.594	0.534	0.394	0.394	304197	-----	115707
CD30EL01	0.594	0.485	0.394	0.394	268836	-----	241618
CD30VA01	0.594	0.449	0.421	0.421	60937	-----	241618
CD30EL02	0.594	0.545	0.394	0.394	-----	443209	241618
CD30EL03	0.594	0.519	0.394	0.394	-----	367000	241618
CD30SP01 US	0.594	0.500	0.394	0.394	360571	-----	241618
CD30SP01 DS	0.594	0.500	0.394	0.394	360571	-----	241618
CD30EL04	0.594	0.485	0.394	0.394	268836	-----	241618
CD30SP02 US	0.594	0.521	0.394	0.394	550644	-----	241618
CD30SP02 DS	0.594	0.521	0.394	0.394	550644	-----	241618
===Grouped by Line: 036-24*-C-30, No Sorting.							
CD30SP03DS	0.688	0.650	0.472	0.472	-----	2396788	241618
CD30PD01 (L/E)	0.688	0.624	0.472	0.472	746881	-----	241618
CD30RD01 (S/E)	0.594	0.512	0.394	0.394	457547	-----	241618
CD30TE01 (U/S)	0.688	0.624	0.472	0.472	746881	-----	241618
CD30TE01 (D/S)	0.688	0.624	0.472	0.472	746881	-----	241618
CD30SP03	0.688	0.645	0.472	0.472	1279453	-----	241618
CD30TE02 (U/S)	0.688	0.891	0.472	0.472	-----	1134771	241618
CD30TE02 (D/S)	0.688	1.023	0.472	0.472	-----	927559	241618
CD30YE02 (BK.)	0.594	0.683	0.394	0.394	895111	-----	241618
CD30SP04 US	0.688	0.626	0.472	0.472	-----	1137408	241618
CD30SP04 DS	0.688	0.659	0.472	0.472	-----	1381328	241618
CD30TE03 (U/S)	0.688	0.877	0.472	0.472	1460918	-----	241618
CD30TE03 (D/S)	0.688	0.886	0.472	0.472	937337	-----	241618
CD30TE03 (BK.)	0.594	0.494	0.394	0.394	320639	-----	241618
CD30SP05 US	0.688	0.652	0.472	0.472	-----	831553	241618
CD30SP05 DS	0.688	0.619	0.472	0.472	682436	-----	241618
CD30EL05	0.688	0.575	0.472	0.472	288222	-----	241618
CD30SP06	0.688	0.661	0.472	0.472	-----	797648	241618
CD30EL06	0.688	0.637	0.472	0.472	-----	435754	241618
CD30SP07	0.688	0.642	0.472	0.472	-----	627877	241618
CD30TE04 (U/S)	0.688	0.499	0.472	0.472	45628	-----	241618
CD30TE04 (D/S)	0.688	0.570	0.472	0.472	262725	-----	241618
CD30TE04 (BK.)	0.594	0.491	0.394	0.394	302385	-----	241618
CD30PD02 (L/E)	0.688	0.439	0.472	0.472	1550493	-----	241618
CD30RD02 (S/E)	0.594	0.500	0.394	0.394	360571	-----	241618
===Grouped by Line: 037-20*-C-30, No Sorting.							
CD30SP08 US	0.594	0.527	0.394	0.394	-----	578380	241618
CD30SP08 DS	0.594	0.521	0.394	0.394	550644	-----	241618
CD30EL07	0.594	0.485	0.394	0.394	268836	-----	241618

671

CD30VA0	0.594	0.449	0.421	0.421	60937	-----	241618
CD30SP0	0.594	0.529	0.394	0.394	669131	-----	241618
CD30EL0R	0.594	0.491	0.394	0.394	302385	-----	241618
CD30EL0	0.594	0.491	0.394	0.394	302385	-----	241618
CD30SP10	0.594	0.521	0.394	0.394	550644	-----	241618
CD30EL10	0.594	0.485	0.394	0.394	268836	-----	241618
CD30SP11	0.594	0.500	0.394	0.394	360571	-----	241618
CD30FE01	0.594	0.593	0.420	0.420	38821984	-----	241618
CD30FE01A	0.812	0.836	0.460	0.460	-----	1649076	241618
CD30EL11	0.594	0.736	0.394	0.394	-----	1061541	241618
CD30SP12	0.594	0.550	0.394	0.394	-----	679545	241618
CD30EL11	0.594	0.594	0.394	0.394	-----	586738	241618
CD30SP13	0.594	0.500	0.394	0.394	360571	-----	241618
CD30RD01(L/E)	0.594	0.521	0.394	0.394	550644	-----	241618
CD30RD01(S/E)	0.500	0.430	0.315	0.315	520249	-----	241618

---Grouped by Line: 037-16*-C-30, No Sorting.

CD30EL05	0.500	0.356	0.315	0.315	89662	-----	241618
INLET NOZZLE P-1-1A	0.500	0.344	0.315	0.315	59068	-----	241618

---Grouped by Line: 038-20*-C-31, No Sorting.

CD31VA01	0.594	0.449	0.421	0.421	60937	-----	241618
CD31SP01	0.594	0.529	0.394	0.394	669131	-----	241618
CD31EL01	0.594	0.491	0.394	0.394	302385	-----	241618
CD31EL02	0.594	0.491	0.394	0.394	302385	-----	241618
CD31SP02	0.594	0.521	0.394	0.394	550644	-----	241618
CD31EL03	0.594	0.485	0.394	0.394	268836	-----	241618
CD31SP03	0.594	0.500	0.394	0.394	360571	-----	241618
CD31FE01	0.594	0.593	0.420	0.420	38821984	-----	241618
CD31FE01A	0.812	0.761	0.460	0.460	-----	1320359	241618
CD31EL04	0.594	0.679	0.394	0.394	-----	884921	241618
CD31SP04	0.594	0.545	0.394	0.394	-----	657855	241618
CD31EL05	0.594	0.485	0.394	0.394	268836	-----	241618
CD31SP05	0.594	0.500	0.394	0.394	360571	-----	241618
CD31RD01(L/E)	0.594	0.526	0.394	0.394	-----	1007845	241618
CD31RD01(S/E)	0.500	0.788	0.315	0.315	-----	2143244	241618

---Grouped by Line: 038-16*-C-31, No Sorting.

CD31EL06	0.500	0.468	0.315	0.315	-----	336789	241618
INLET NOZZLE P-1-1B	0.500	0.344	0.315	0.315	59068	-----	241618

---Grouped by Line: 039-20*-C-32, No Sorting.

CD30SP05	0.594	0.530	0.394	0.394	-----	673546	241618
CD30SP04	0.594	0.508	0.394	0.394	-----	618482	241618
CD30EL02	0.594	0.682	0.394	0.394	-----	892013	241618
CD30VA01	0.594	0.449	0.421	0.421	60937	-----	241618
CD30EL03	0.594	0.485	0.394	0.394	268836	-----	241618
CD30SP01	0.594	0.500	0.394	0.394	360571	-----	241618
CD30FE01	0.594	0.593	0.420	0.420	38821984	-----	241618
CD30FE01A	0.812	0.739	0.460	0.460	-----	1223976	241618
CD30EL04	0.594	0.662	0.394	0.394	-----	830835	241618
CD30SP02	0.594	0.521	0.394	0.394	550644	-----	241618
CD30EL05	0.594	0.485	0.394	0.394	268836	-----	241618
CD30SP03	0.594	0.500	0.394	0.394	360571	-----	241618
CD30RD01(L/E)	0.594	0.521	0.394	0.394	550644	-----	241618
CD30RD01(S/E)	0.500	0.430	0.315	0.315	520249	-----	241618

---Grouped by Line: 039-16*-C-32, No Sorting.

CD30EL06	0.500	0.356	0.315	0.315	89662	-----	241618
INLET NOZZLE P-1-1C	0.500	0.344	0.315	0.315	59068	-----	241618

Note:

(1) Predictions are based on last Tmeas to analysis ending period.

1870

Company: Vermont Yankee Nuclear Power Corporation Report Date: 28-SEP-2006 Time: 08:51:24
 Plant: Vermont Yankee Analysis Date: 28-SEP-2006 Time: 08:47:32
 Unit: CHECWORKS FAC Version 1.0F (Build 52)
 EB Name: VY

 *** Wear Rate Analysis: Inspection History Report ***

Run Name: Cond2206 E3 to 3 FWP
 Running Period: CYCLE 25
 Total Plant Operating Hours: 241618 Duty Factor (Global): 1.000
 WRA Data Option: Ignore NPA Exclude Measure Wear: No
 Line Correction Factor: 0.252

Component Name	Geom. Code	Material				Sigma (psi)	Time (hrs)		Analysis Option	Measured Wear (mils)
		Cr. No.	Cr. (%)	Cu. (%)	Mo. (%)		Last Inspected	Replaced		

====Grouped by Line: 034-20*-C-29, No Sorting.

OUTLET NOZZLE E-3-1A	31	5	0.00	0.00	0.00	15000	-----	-----	---
*Replacement #1	31	5	0.00	0.00	0.00	15000	-----	125911	---
CD29EL01	4	21	0.00	0.00	0.00	15000	-----	-----	---
CD29SP01	54	5	0.00	0.00	0.00	15000	-----	-----	---
CD29VA01	22	93	0.00	0.00	0.00	14000	-----	-----	---
CD29EL02	4	21	0.00	0.00	0.00	15000	-----	-----	Excl LCF
CD29SP02 US	54	5	0.00	0.00	0.00	15000	102975	-----	34
CD29SP02 DS	54	5	0.00	0.00	0.00	15000	-----	-----	---
CD29EL03	4	21	0.00	0.00	0.00	15000	102975	-----	125
CD29SP03 US	54	5	0.00	0.00	0.00	15000	102975	-----	36
CD29SP03 DS	54	5	0.00	0.00	0.00	15000	102975	-----	59

====Grouped by Line: 035-20*-C-30, No Sorting.

OUTLET NOZZLE E-3-1B	31	5	0.00	0.00	0.00	15000	-----	-----	---
*Replacement #1	31	5	0.00	0.00	0.00	15000	-----	125911	---
CD30EL01	4	21	0.00	0.00	0.00	15000	-----	-----	---
CD30VA01	22	93	0.00	0.00	0.00	14000	-----	-----	---
CD30EL02	4	21	0.00	0.00	0.00	15000	195618	-----	96
CD30EL03	4	21	0.00	0.00	0.00	15000	195618	-----	135
CD30SP01 US	54	5	0.00	0.00	0.00	15000	-----	-----	---
CD30SP01 DS	54	5	0.00	0.00	0.00	15000	-----	-----	---
CD30EL04	4	21	0.00	0.00	0.00	15000	-----	-----	---
CD30SP02 US	52	5	0.00	0.00	0.00	15000	-----	-----	---
CD30SP02 DS	52	5	0.00	0.00	0.00	15000	-----	-----	---

====Grouped by Line: 036-24*-C-30, No Sorting.

CD30SP03DS	9	21	0.00	0.00	0.00	15000	218618	-----	36
CD30RE01(L/E)	18	21	0.00	0.00	0.00	15000	-----	-----	---
CD30RE01(S/E)	18	21	0.00	0.00	0.00	15000	-----	-----	---
CD30TE01(H/S)	15	21	0.00	0.00	0.00	15000	-----	-----	---
CD30TE01(H/S)	15	21	0.00	0.00	0.00	15000	-----	-----	---
CD30TE01(D/S)	15	21	0.00	0.00	0.00	15000	-----	-----	---
CD30TE02(U/S)	14	21	0.00	0.00	0.00	15000	218618	-----	140
CD30TE02(D/S)	14	21	0.00	0.00	0.00	15000	218618	-----	133
CD30TE02(LR.)	14	21	0.00	0.00	0.00	15000	-----	-----	---
CD30SP04 US	64	5	0.00	0.00	0.00	15000	218618	-----	52
CD30SP04 DS	64	5	0.00	0.00	0.00	15000	102975	-----	30
CD30TE03(U/S)	12	21	0.00	0.00	0.00	15000	-----	-----	Excl LCF
CD30TE03(D/S)	12	21	0.00	0.00	0.00	15000	-----	-----	Excl LCF
CD30TE03(LR.)	12	21	0.00	0.00	0.00	15000	-----	-----	Excl LCF
CD30SP05 DS	64	5	0.00	0.00	0.00	15000	102975	-----	53
CD30SP05 DS	64	5	0.00	0.00	0.00	15000	-----	-----	---
CD30EL05	1	21	0.00	0.00	0.00	15000	-----	-----	---
CD30SP06	51	5	0.00	0.00	0.00	15000	160352	-----	33
CD30EL06	3	21	0.00	0.00	0.00	15000	160352	-----	82
CD30SP07	51	5	0.00	0.00	0.00	15000	160352	-----	27
CD30TE04(U/S)	14	21	0.00	0.00	0.00	15000	-----	-----	---
CD30TE04(D/S)	14	21	0.00	0.00	0.00	15000	-----	-----	---
CD30TE04(LR.)	14	21	0.00	0.00	0.00	15000	-----	-----	---
CD30RD02(L/E)	7	21	0.00	0.00	0.00	15000	-----	-----	---
CD30RD02(S/E)	7	21	0.00	0.00	0.00	15000	-----	-----	---

====Grouped by Line: 037-20*-C-30, No Sorting.

CD30SP08 US	67	5	0.00	0.00	0.00	15000	160352	-----	45
-------------	----	---	------	------	------	-------	--------	-------	----

181

CD30SP08 DS	57	5	0.00	0.00	0.00	15000	----	----	---
CD30EL07	3	21	0.00	0.00	0.00	15000	----	----	---
CD30VA02	22	93	0.00	0.00	0.00	14000	----	----	---
CD30SP09	58	5	0.00	0.00	0.00	15000	----	----	---
CD30EL08	3	21	0.00	0.00	0.00	15000	----	----	---
CD30EL09	3	21	0.00	0.00	0.00	15000	----	----	---
CD30SP10	53	5	0.00	0.00	0.00	15000	----	----	---
CD30EL10	4	21	0.00	0.00	0.00	15000	----	----	---
CD30SP11	54	5	0.00	0.00	0.00	15000	----	----	---
CD30FE01	6	61	18.00	0.00	0.00	14050	----	----	---
CD30FE01A	56	2	0.00	0.00	0.00	12800	230118	----	28
CD30EL11	3	21	0.00	0.00	0.00	15000	230118	----	99
CD40SP12	53	5	0.00	0.00	0.00	15000	230118	----	37
CD30EL12	4	21	0.00	0.00	0.00	15000	102975	----	74
CD30SP13	54	5	0.00	0.00	0.00	15000	----	----	---
CD30RD03 (L/E)	17	21	0.00	0.00	0.00	15000	----	----	---
CD30RD03 (S/E)	17	21	0.00	0.00	0.00	15000	----	----	---

====Grouped by Line: 037-16*-C-30, No Sorting.

CD30EL13	4	21	0.00	0.00	0.00	15000	----	----	---
INLET NOZZLE P-1-1A	30	5	0.00	0.00	0.00	15000	----	----	---

====Grouped by Line: 038-20*-C-31, No Sorting.

CD31VA01	22	93	0.00	0.00	0.00	14000	----	----	---
CD31SP01	58	5	0.00	0.00	0.00	15000	----	----	---
CD31EL01	3	21	0.00	0.00	0.00	15000	----	----	---
CD31EL02	3	21	0.00	0.00	0.00	15000	----	----	---
CD31SP02	53	5	0.00	0.00	0.00	15000	----	----	---
CD31EL03	4	21	0.00	0.00	0.00	15000	----	----	---
CD31SP03	54	5	0.00	0.00	0.00	15000	----	----	---
CD31FE01	6	61	18.00	0.00	0.00	14050	----	----	---
CD31FE01A	56	2	0.00	0.00	0.00	12800	230118	----	43
CD31EL04	3	21	0.00	0.00	0.00	15000	230118	----	85
CD31SP04	53	5	0.00	0.00	0.00	15000	230118	----	45
CD31EL05	4	21	0.00	0.00	0.00	15000	----	----	---
CD31SP05	54	5	0.00	0.00	0.00	15000	----	----	---
CD31RD01 (L/E)	17	21	0.00	0.00	0.00	15000	160352	----	192
CD31RD01 (S/E)	17	21	0.00	0.00	0.00	15000	160352	----	123

====Grouped by Line: 038-16*-C-31, No Sorting.

CD31EL06	4	21	0.00	0.00	0.00	15000	160352	----	102
INLET NOZZLE P-1-1B	30	5	0.00	0.00	0.00	15000	----	----	---

====Grouped by Line: 039-20*-C-32, No Sorting.

CD32SP03	51	5	0.00	0.00	0.00	15000	218618	----	58
CD32SP04	64	5	0.00	0.00	0.00	15000	218618	----	74
CD32EL02	3	21	0.00	0.00	0.00	15000	218618	----	160
CD32VA01	22	93	0.00	0.00	0.00	14000	----	----	---
CD32EL03	4	21	0.00	0.00	0.00	15000	----	----	---
CD32SP01	54	5	0.00	0.00	0.00	15000	----	----	---
CD32FE01	6	61	18.00	0.00	0.00	14050	----	----	---
CD32FE01A	56	2	0.00	0.00	0.00	12800	195618	----	23
CD32EL04	3	21	0.00	0.00	0.00	15000	195618	----	95
CD32SP02	53	5	0.00	0.00	0.00	15000	----	----	---
CD32EL05	4	21	0.00	0.00	0.00	15000	----	----	---
CD32SP03	54	5	0.00	0.00	0.00	15000	----	----	---
CD32RD01 (L/E)	17	21	0.00	0.00	0.00	15000	----	----	---
CD32RD01 (S/E)	17	21	0.00	0.00	0.00	15000	----	----	---

====Grouped by Line: 039-16*-C-32, No Sorting.

CD32EL06	4	21	0.00	0.00	0.00	15000	----	----	---
INLET NOZZLE P-1-1C	30	5	0.00	0.00	0.00	15000	----	----	---

1822

Company: Vermont Yankee Nuclear Power Corporation Report Date: 28-SEP-2006 Time: 08:51:19
 Plant: Vermont Yankee Analysis Date: 28-SEP-2006 Time: 08:47:32
 Unit: CHECWORKS FAC Version 1.0F (Build 52)
 RB Name: VY

 *** Wear Rate Analysis: Wear Rates/Input Data Report ***

Run Name: Cond2006 E3 to 3 FWP
 Ending Period: CYCLE 25
 Total Plant Operating Hours: 241618 Duty Factor (Global): 1.000
 WRA Data Option: Ignore NFA Exclude Measure Wear: No
 Line Correction Factor: 0.252

Component Name	Geom. Code	Average Wear Rate (mils/year)	Current Wear Rate (mils/year)	Temp. (F)	Velocity (ft/s)	Steam Quality	Diameter (in)	
===Grouped by Line: 034-20*-C-23, No Sorting.								
OUTLET NOZZLE	E-3-1A	31	4.546	4.039	294.7	8.023	0.000	20.000
CD39EL01		4	3.937	2.989	294.7	8.023	0.000	20.000
CD39SP01		54	3.405	2.585	294.7	8.023	0.000	20.000
CD39VA01		22	5.254	3.988	294.7	7.865	0.000	20.000
CD39EL02		4	3.937	2.989	294.7	8.023	0.000	20.000
CD39SP02 US		54	3.405	2.585	294.7	8.023	0.000	20.000
CD39SP02 DS		54	3.405	2.585	294.7	8.023	0.000	20.000
CD39EL03		4	3.937	2.989	294.7	8.023	0.000	20.000
CD39SP03 US		54	3.405	2.585	294.7	8.023	0.000	20.000
CD39SP03 DS		54	3.405	2.585	294.7	8.023	0.000	20.000

===Grouped by Line: 035-20*-C-30, No Sorting.								
OUTLET NOZZLE	E-3-1B	31	4.546	4.039	294.7	8.023	0.000	20.000
CD39EL01		4	3.937	2.989	294.7	8.023	0.000	20.000
CD39VA01		22	5.254	3.988	294.7	7.865	0.000	20.000
CD39EL02		4	3.937	2.989	294.7	8.023	0.000	20.000
CD39EL03		4	3.937	2.989	294.7	8.023	0.000	20.000
CD39SP01 US		54	3.405	2.585	294.7	8.023	0.000	20.000
CD39SP01 DS		54	3.405	2.585	294.7	8.023	0.000	20.000
CD39EL04		2	3.937	2.989	294.7	8.023	0.000	20.000
CD39SP02 US		52	2.660	2.019	294.7	8.023	0.000	20.000
CD39SP02 DS		52	2.660	2.019	294.7	8.023	0.000	20.000

===Grouped by Line: 036-24*-C-30, No Sorting.								
CD39SP03DS		9	0.856	0.650	294.7	5.547	0.000	24.000
CD39RD01 (L/E)		18	2.335	1.773	294.7	5.547	0.000	24.000
CD39RD01 (S/E)		18	2.979	2.262	294.7	8.023	0.000	20.000
CD39TE01 (U/S)		15	2.335	1.773	294.7	5.547	0.000	24.000
CD39TE01 (L/S)		15	2.335	1.773	294.7	5.547	0.000	24.000
CD39SP03		65	1.557	1.182	294.7	5.547	0.000	24.000
CD39TE02 (U/S)		14	4.281	3.250	294.7	5.547	0.000	24.000
CD39TE02 (D/S)		14	6.853	5.203	294.7	11.146	0.000	24.000
CD39TE02 (BR.)		14	3.724	2.827	294.7	8.023	0.000	20.000
CD39SP04 US		64	1.557	1.182	294.7	5.547	0.000	24.000
CD39SP04 DS		64	1.557	1.182	294.7	5.547	0.000	24.000
CD39TE03 (U/S)		12	3.191	2.423	294.7	5.547	0.000	24.000
CD39TE03 (BR.)		12	5.095	3.868	294.7	11.094	0.000	24.000
CD39TE03 (BR.)		12	3.617	2.746	294.7	8.023	0.000	20.000
CD39SP05 US		64	2.486	1.887	294.7	11.094	0.000	24.000
CD39SP05 DS		64	2.486	1.887	294.7	11.094	0.000	24.000
CD39EL05		1	4.101	3.114	294.7	11.094	0.000	24.000
CD39SP06		51	2.734	2.076	294.7	11.094	0.000	24.000
CD39EL06		3	4.350	3.302	294.7	11.094	0.000	24.000
CD39SP07		53	3.107	2.359	294.7	11.094	0.000	24.000
CD39TE04 (U/S)		14	6.835	5.189	294.7	11.094	0.000	24.000
CD39TE04 (D/S)		14	4.281	3.250	294.7	5.547	0.000	24.000
CD39TE04 (BR.)		14	3.724	2.827	294.7	8.023	0.000	20.000
CD39RD02 (L/E)		7	2.724	2.068	294.7	5.547	0.000	24.000
CD39RD02 (S/E)		7	3.405	2.585	294.7	8.023	0.000	20.000

===Grouped by Line: 037-20*-C-30, No Sorting.								
CD39SP08 US		57	2.660	2.019	294.7	8.023	0.000	20.000
CD39SP08 DS		57	2.660	2.019	294.7	8.023	0.000	20.000
CD39SP09		2	3.937	2.989	294.7	8.023	0.000	20.000

183

CD30VA02	22	5.254	3.988	294.7	7.865	0.000	20.000
CD30SP09	58	2.341	1.777	294.7	8.023	0.000	20.000
CD30EL08	3	3.724	2.827	294.7	8.023	0.000	20.000
CD30FL09	3	3.724	2.827	294.7	8.023	0.000	20.000
CD30SP10	53	2.660	2.019	294.7	8.023	0.000	20.000
CD30EL10	4	3.937	2.989	294.7	8.023	0.000	20.000
CD30SP11	54	3.405	2.585	294.7	8.023	0.000	20.000
CD30FE01	6	0.051	0.039	294.7	33.876	0.000	20.000
CD30FE01A	56	2.633	1.999	294.7	33.876	0.000	20.000
CD30EL11	3	3.724	2.827	294.7	8.023	0.000	20.000
CD30SP12	53	2.660	2.019	294.7	8.023	0.000	20.000
CD30EL12	4	3.937	2.989	294.7	8.023	0.000	20.000
CD30SP13	54	3.405	2.585	294.7	8.023	0.000	20.000
CD30RD01(L/E)	17	2.660	2.019	294.7	8.023	0.000	20.000
CD30RD01(S/E)	17	2.546	1.933	294.7	12.619	0.000	16.000

==>Grouped by Line: 037-16*-C-30, No Sorting.

CD30EL13	4	5.234	3.974	294.7	12.619	0.000	16.000
INLET NOZZLE P-1-1A	30	5.658	4.296	294.7	12.619	0.000	16.000

===>Grouped by Line: 038-20*-C-31, No Sorting.

CD31VA01	22	5.254	3.988	294.7	7.865	0.000	20.000
CD31SP01	58	2.341	1.777	294.7	8.023	0.000	20.000
CD31EL01	3	3.724	2.827	294.7	8.023	0.000	20.000
CD31EL02	3	3.724	2.827	294.7	8.023	0.000	20.000
CD31SP02	53	2.660	2.019	294.7	8.023	0.000	20.000
CD31EL03	4	3.937	2.989	294.7	8.023	0.000	20.000
CD31SP03	54	3.405	2.585	294.7	8.023	0.000	20.000
CD31FE01	6	0.051	0.039	294.7	33.876	0.000	20.000
CD31FE01A	56	2.633	1.999	294.7	33.876	0.000	20.000
CD31EL04	3	3.724	2.827	294.7	8.023	0.000	20.000
CD31SP04	53	2.660	2.019	294.7	8.023	0.000	20.000
CD31EL05	4	3.937	2.989	294.7	8.023	0.000	20.000
CD31SP05	54	3.405	2.585	294.7	8.023	0.000	20.000
CD31RD01(L/E)	17	2.660	2.019	294.7	8.023	0.000	20.000
CD31RD01(S/E)	17	2.546	1.933	294.7	12.619	0.000	16.000

==>Grouped by Line: 038-16*-C-31, No Sorting.

CD31EL06	4	5.234	3.974	294.7	12.619	0.000	16.000
INLET NOZZLE P-1-1B	30	5.658	4.296	294.7	12.619	0.000	16.000

==>Grouped by Line: 039-20*-C-32, No Sorting.

CD30SP06	51	2.341	1.777	294.7	8.023	0.000	20.000
CD30SP04	64	2.128	1.615	294.7	8.023	0.000	20.000
CD30EL02	3	3.724	2.827	294.7	8.023	0.000	20.000
CD30VA01	22	5.254	3.988	294.7	7.865	0.000	20.000
CD30EL03	4	3.937	2.989	294.7	8.023	0.000	20.000
CD30SP03	54	3.405	2.585	294.7	8.023	0.000	20.000
CD30FE01	6	0.051	0.039	294.7	33.876	0.000	20.000
CD30FE01A	56	2.633	1.999	294.7	33.876	0.000	20.000
CD30EL04	3	3.724	2.827	294.7	8.023	0.000	20.000
CD30SP03	53	2.660	2.019	294.7	8.023	0.000	20.000
CD30EL05	4	3.937	2.989	294.7	8.023	0.000	20.000
CD30SP03	54	3.405	2.585	294.7	8.023	0.000	20.000
CD30RD01(L/E)	17	2.660	2.019	294.7	8.023	0.000	20.000
CD30RD01(S/E)	17	2.546	1.933	294.7	12.619	0.000	16.000


==>Grouped by Line: 039-16*-C-32, No Sorting.

CD30EL06	4	5.234	3.974	294.7	12.619	0.000	16.000
INLET NOZZLE P-1-1C	30	5.658	4.296	294.7	12.619	0.000	16.000

184
202
AS

Tpred/Tcrit Ratio Plot


Cond2006 E3 to 3 FWP



AT
8581

Cumulative % of Comp. Time to Tcrit

Cond2006 E3 to 3 FWP



185
186

■ % of Fittings ■ % of Fittings Added

Version: 2

Significance Code: C - INVEST & CORRECT

Classification Code: C

Owner Group: Eng DE Civil Struct Mgmt

Performed By: Felumb,Rhonda

09/05/2006 11:55

Assignment Description:

CR-VTY-2006-2699

Screening Data

On 09/05/2006 CRG Recommend this CR as a C - INVEST & CORRECT Assigned to Eng DE Civil Struct Mgmt

Comments:

Trending Items

MANAGEMENT OVERSIGHT

RW - 1 (SELF-IDENTIFIED)

Problem Code Work Group

WN Eng. Work practices ESDE Design Engineering/Fluids/Civil/Elec

Additional CA's Required

ACTION CA issued to Eng DE Civil Struct Mgmt With 0 NONE Plant Constraint CA Comments: Evaluate for Adverse Trend and present to CRG.

Initiated Date: 8/30/2006 14:09 **Owner Group :**Eng DE Civil Struct Mgmt

Current Contact: RMF

Current Significance: C - INVEST & CORRECT

Closed by: Pallang,Alexander P

10/4/2006 5:36

Summary Description:

Untimely update to FAC CHECWORKS Models

During FAC Program Health Report presentation to Plant Management it was reported that the program status/color (e.g. white trending to yellow) was due, in part because the CHECWORKS predictive models are not current. This issue was previously identified and was being tracked thru the ER process for completing model updates. Due to more emergent issues supporting EPU/EPU Contentions, LR/LR Contentions, the model updates remain incomplete. This CR is written in order to place a higher level focus within Engineering Management to facilitate completion of this task to update the models.

This is an administrative issue with respect to the FAC Program and has no effect upon plant equipment or operations.

Remarks Description:

Closure Description:

CR Closure review completed by responsible department

SUBJECT: Extent of Condition Evaluation for CR-VTY-2006-2699 (CA2), Untimely Update to FAC CHECWORKS Models

DISCUSSION: The subject CR was written to document a programmatic issue related to not having all historical inspection data loaded into the existing models. As noted, this issue is related to programmatic aspects of the FAC Program.

In order to evaluate the extent of condition related to this issue, guidance contained in EN-LI-119, Attachment 9.5 was used. Following this guidance, the nonconformance is maintaining the programmatic aspects of the FAC Program. The existence of this similar condition does not extend to any other program under the cognizance of DE C/S as the FAC Program is the only such program that remains in DE C/S. A review of Open Action Items as listed in the 7-12-06 Program Health Report has been performed with the following results:

- 1) Perform snap shot SA of FAC Program activities. This action is scheduled for completion on 12/10/06.
- 2) Convert existing FAC component location sketches into controlled drawings. This is a recommended program enhancement. This activity is on-going and is approximately 85% complete with a due date of 9/30/06.
- 3) Incorporate program reports/documents into RIMS per ENN-DC-126 and EN-DC-147 as applicable. This is an enhancement that will allow easier document recall going forward. This activity is on-going and is approximately 90% complete with a due date of 9/19/06.
- 4) Add into the Program the new piping 8" CD-46 installed under MM 2003-024. This is due 1/11/07.
- 5) Add into the Program the new FW Htrs and related components installed under VYDC 2003-002. This is due 3/15/07.
- 6) Evaluate items identified in the EPU Recommendations and Observations data base and disposition. This is due 11/10/06.

The Fleet FAC Program Procedure, ENN-DC-315 became effective at VY on 3-15-06. Active participation in the FAC peer group has influenced many of these programmatic activities to be pursued. All actions are being tracked in PCRS as LOCAs. The Program is in transition from DE C/S to Engineering Programs consistent with the Fleet model. A new employee has been recently hired into Engineering Programs to assume the role of FAC Coordinator.

The CR listed above recommends increased management attention to support the allocation and dedication of resources that will result in programmatic activities being completed in a timely manner.

Discussions were held with Engineering Programs Supervision to determine if any additional VY Programs are having difficulty maintaining the programmatic/administrative aspects of program requirements. Based on these discussions, there are none.

Based on the review performed above it is concluded that there is no adverse trend related to this issue. The suggested actions contained within the subject CR will resolve the condition.

Attachment Header

Document Name:

untitled

Document Location

Resp Description

Attach Title:

Extent of Condition

CA Number: 2

Group

Name

Assigned By: CRG/CARB/OSRC

Assigned To: Eng DE Civil Struct Mgmt

Goodwin, Scott D

Subassigned To : Eng DE Civil Struct Mgmt

Originated By: Felumb, Rhonda

9/5/2006 11:58:14

Performed By: Goodwin, Scott D

9/13/2006 12:46:11

Subperformed By:

Approved By:

Closed By: Pallang, Alexander P

9/14/2006 07:50:59

Current Due Date: 09/15/2006

Initial Due Date: 09/15/2006

CA Type: ACTION

Plant Constraint: 0 NONE

CA Description:

Evaluate for Adverse Trend and present to CRG.

Response:

Extent of condition evaluation performed iaw EN-li-119 Attachment 9.5 guidelines and attached.

Subresponse :

Closure Comments:

APPROVED BY CRG ON 9/14/06

Attachments:

Resp Description

Extent of Condition

7	Revise report VY-RPT-05-00013 to incorporate changes as a result of ER 05-0591	JCF	2/27/07	Tracked per WT-2006-0000 CA817
---	--	-----	---------	--------------------------------



Title: Vermont Yankee Flow Accelerated Corrosion (FAC) Inspection Program
Action Plan to Return Program Health Status to Green

Manager: JH Callaghan

Issue Date: 10/2/06

	Action	Owner	Due Date	Status
1	Perform Snapshot SA of Program	JCF	12/8/06	Tracked per LO-VTYLO-2003-00327 CA2
2	Update FAC component sketches and convert to plant controlled drawings	JCF	10/15/06	Tracked per LO-VTYLO-2003-00327 CA4
3	Complete program report per ENN-DC-147 for small bore susceptibility (VY-RPT-05-00013)	JCF	10/31/06	Tracked per LO-VTYLO-2003-00327 CA6
4	Update program documents as a result of installing Condemineralizer Bypass under MM 2003-024	JCF	1/9/2007	Tracked per LO-VTYLO-2004-00399 CA1
5	Update program documents as a result of installing HP FW Htrs and include any related effects from VYDC 2003-0002	JCF	3/13/2007	Tracked per LO-VTYLO-2005-00215
6	Revise VY-RPT-05-00012 to incorporate changes as a result of ER 05-0591	JCF	2/27/07	Tracked per WT-2006-0000 CA816

Closure
Justification:

CORRECTIVE ACTION PLAN

Vermont Yankee

Title:

Vermont Yankee Flow Accelerated Corrosion (FAC) Inspection Program

Action Plan to Return Program Health Status to Green

10/2/06

**Corrective
Action Plan
Lead:**

JC Fitzpatrick

DE C/S

10/2/06

Print Name / Signature

Department

Date

Reviewed By:

SD Goodwin

DE C/S

10/2/06

Print Name / Signature

Department

Date

Approved By:

JH Callaghan

DEM

10/2/06

Print Name / Signature

Department

Date

Approved By:

Print Name / Signature

Department

Date

Purpose:

Address timeliness of completion of programmatic actions associated with the FAC Program. Refer CR-VTY-2006-2699

Reference(s):

1. ENN-DC-315, Rev.1, Flow Accelerated Corrosion Program
2. ENN-CS-S-008 Engineering Standard Pipe Wall Thinning Evaluation
3. ENN-EP-S-005, Rev.0, Flow Accelerated Corrosion Component Scanning and Gridding Standard.

Status:

See attached

Action(s):

See attached.

Attachment Header

Document Name:

untitled

Document Location

Resp Description

Attach Title:

FAC Action Plan

CA Number: 1

Group

Name

Assigned By: CRG/CARB/OSRC

Assigned To: Eng DE Civil Struct Mgmt

Goodwin,Scott D

Subassigned To :

Originated By: Felumb,Rhonda

9/5/2006 11:57:08

Performed By: Goodwin,Scott D

10/3/2006 13:57:21

Subperformed By:

Approved By:

Closed By: Pallang,Alexander P

10/4/2006 04:56:25

Current Due Date: 10/05/2006

Initial Due Date: 10/05/2006

CA Type: DISP - CA

Plant Constraint: 0 NONE

CA Description:

C - INVEST & CORRECT (Review CR for full details)

The CRG has initially classified this CR as

Classification Code - "C"

Significance Code - INVEST & CORRECT

Per the CRG, Perform an Investigation of the issues identified in this CR and determine if additional actions are required within 30 days.

All Attachments are to be in PDF format

Ensure all Screening Comments have been addressed in the investigation - (CR assignment tab)

Develop adequate corrective actions and issue CAs. (Due Dates per LI 102 Attachment 9.4)

LT CAs Require Approval from Site VP/ GMPO or Director prior to initiating. Completion of Attachment 9.9 LTCA

Classification Form is required.

Response:

Problem Statement: Untimely update to FAC CHECWORKS Models

All piping models related to the FAC program have been updated to include all inspections data obtained thru latest set of outage inspections. The results of the updated model execution has not identified any instances where recommended inspections have not been performed.

In addition, as suggested in the the Initiation Tab of the CR, DE C/S has reviewed all outstanding programmatic actions that are identified in the latest program health report and entered these items into a formal action plan to be used going forward to more closely monitor programmatic activities. A copy of the action plan is attached.

There are no further actions required to be taken as a result of this event. This CR has been reviewed in accordance with the requirements of LI-102 and can be closed.

Subresponse :

Closure Comments:

Attachments:

Resp Description

FAC Action Plan

Version: 1

Significance Code: C - INVEST & CORRECT

Classification Code: C

Owner Group: Eng DE Civil Struct Mgmt

Performed By: Goodwin, Scott D

08/30/2006 14:54

Assignment Description:

Pre-Screening - Assignment Response:

RW(4)

WN

DE Eng

Keywords: MANAGEMENT OVERSIGHT

Engineering Report No. VY-RPT-05-00012 Rev. 0
 Page 1 of 42



ENTERGY NUCLEAR NORTHEAST
 Engineering Report Cover Sheet

Engineering Report Title:

**VERMONT YANKEE PIPING FLOW ACCELERATED CORROSION
 INSPECTION PROGRAM - FAC SUSCEPTIBILITY REVIEW**

Engineering Report Type:

New Revision Cancelled Superseded

Applicable Site(s)

IP1 IP2 IP3 JAF PNPS VY

Quality-Related: Yes No

Prepared by: James C. Fitzpatrick
 Responsible Engineer (Print Name/Sign)

Date: 10/5/05

**Reviewed by: Thomas M. O'Connor
 **Reviewer (Print Name/Sign)

Date: 10/7/05

*Reviewed by: N/A
 Authorized Nuclear In-service Inspector (ANII)

Date: N/A

Approved by: Scott D. Goodwin
 Supervisor (Print Name/Sign)

Date: 10.25.05

Multiple Site Review (10)

Site	Design Verifier/Reviewer (Print Name/Sign)	Supervisor (Print Name/Sign)	Date
	N/A	N/A	N/A

* For ASME Section XI Code Program plans per ENN-DC-120, if required.

** This Report does not interpret design, nor are the results used for design input to a design change. Therefore Design Verification per ENN-DC-134 is not required. Only a technical review is performed.

RECORD OF REVISIONS

Engineering Report No: VY-RPT-05-00012, "Vermont Yankee Piping Flow Accelerated Corrosion Inspection Program – FAC Susceptibility Review"

Revision No.	Description of Change	Reason For Change
0	Original Report: Converts previous Vermont Yankee Susceptibility Evaluation into ENN-DC-147 format and includes piping and system changes made since May 15, 2000. This revision incorporates operation under Nobel Metal Hydrogen Water Chemistry (NMHWC) and the increased flows from 120% Extended Power Uprate (EPU).	LO-VTYLO-2003-00327-CA6, LO-VTYLO-2004-00399-CA1, LO-VTYLO-2005-00030-CA11, LO-VTYLO-2005-00215-CA1

REVISION SUMMARY

Revision 0:

Information in this report was originally contained in a Vermont Yankee FAC Inspection Program document entitled "FAC Susceptible Piping Identification" Revision 0, dated May 15, 2000. This report formalizes the previous VY document per the requirements of ENN-DC-147. Also piping system operational, configuration, and material changes made at Vermont Yankee since May 15, 2000 are incorporated. These include operation under Nobel Metals Hydrogen Water Chemistry, piping changes to various feedwater heater replacements, and piping replacements due to previous through wall leaks. This revision considers the effects of the increased flow rates and revised Heat Balance Diagrams resulting from a proposed 120% Extended Power Uprate (EPU).

TABLE OF CONTENTS

Section	Description	Page No.
	ENGINEERING REPORT COVER SHEET (ENN-DC-147 ATT.9.1)	1
	RECORD OF REVISIONS.....	2
	REVISION SUMMARY	3
	TABLE OF CONTENTS	4
1.0	INTRODUCTION	5
2.0	PURPOSE	5
3.0	SCOPE OF REVIEW.....	5
4.0	INPUT DATA.....	6
5.0	EVALUATION CRITERIA.....	7
6.0	ASSUMPTIONS.....	9
7.0	SUSCEPTIBILITY REVIEW METHODOLOGY.....	10
8.0	RESULTS / CONCLUSIONS.....	11
9.0	REFERENCES.....	12
Table 1:	Plant Flow Diagrams & Equipment Drawings Reviewed	14
Table 2:	Summary of Line by Line Screening	16

1.0 INTRODUCTION

An evaluation was performed to ensure all plant piping lines which are susceptible to damage from Flow Accelerated Corrosion (FAC) are included in the scope of the Vermont Yankee Piping FAC Inspection Program.

The evaluation documented herein identifies the plant systems and piping lines considered, the assumptions applied, sources of data, and drawing references. The evaluation considers both the current Vermont Yankee design and operating conditions and the effects of a proposed 120% Extended Power Uprate. The criteria used to screen the piping for susceptibility to FAC was developed by EPRI in [Ref. 4].

VY will adopt the Entergy Northeast Standard FAC Program Procedure, ENN-DC-315, "Flow Accelerated Corrosion Program" [Ref. 5]. The existing VY Program Procedure, No. PP 7028 [Ref. 3] will be superseded. Information in this report was originally contained in a Vermont Yankee FAC Inspection Program document entitled "FAC Susceptible Piping Identification" Revision 0, dated May 15, 2000. This report formalizes the previous VY document per the requirements of procedure ENN-DC-147.

Piping system operational, configuration, and material changes made at Vermont Yankee since May 15, 2000 are incorporated. These are listed in section 4.0. This revision considers the effects of the increased flow rates and revised Heat Balance Diagrams resulting from a proposed 120% Extended Power Uprate (EPU).

2.0 PURPOSE

The purpose of this document is to provide a single, comprehensive, source to identify all piping systems or portions of systems, which could be susceptible to damage caused by flow accelerated corrosion (FAC). This document will be periodically reviewed and revised as required to reflect changes in plant operation and configuration [Ref. 5, Section 5.14].

3.0 SCOPE OF REVIEW

To insure that all susceptible piping is included in the scope of the Piping FAC Inspection Program, all plant piping systems shown on plant flow diagrams and equipment drawings will be screened using the criteria listed in Section 5.0. Piping provided with vendor supplied equipment, which is generally not shown on plant flow diagrams (i.e., turbine Gland Seal Supply lines) is also included.

All feedwater heater shells at Vermont Yankee have now been replaced with FAC resistant materials [Ref. 24]. No shell wall thickness inspections are anticipated to be required for the remaining term of the plant operating license. FAC susceptible equipment other than feedwater heater shells may also be identified during this review although inspection of equipment is currently outside the scope of the Piping FAC Inspection Program.

The plant flow diagrams and drawings reviewed are listed in Table 1.

4.0 INPUT DATA

4.1 Piping Design Data

The piping systems at VY are shown on the drawings (Flow Diagrams for Mechanical Systems) listed in Table 1. Each flow diagram contains a "Piping Line List" which contains for each line: the line number, line size, piping schedule, material, the design temperature and pressure, and a reference to the original Ebasco Piping Specification, [Ref. 6]. There is no separate controlled line list at Vermont Yankee. The flow diagrams are the controlled design information.

Piping and fitting materials installed by Ebasco, the original plant Architect /Engineer are identified by piping class (i.e. CS-1 or LAS-2), as shown on the Flow Diagrams. These designations refer to sections in the Ebasco Piping Specification [Ref. 6] which give detailed material requirements for the respective piping class. Equipment manufacturer data is used if available.

4.2 Operating Conditions

Operating temperatures and pressures for process steam piping are shown on the plant Heat Balance diagrams. Prior to RFO 24 (Spring 2004), normal operating conditions at current licensed thermal power (CLTP) are taken from Drawing No. 5920-11399, Sh.2 of 19, Rev.1, reference 7. The HP turbine rotor was replaced and the steam path was modified during RFO 24. The revised Heat Balance Diagram for CLTP is drawing No. 5920-13297 Sht.6, reference 19. The Heat Balance Diagram for the 120% Extended Power Uprate (EPU) including the HP Turbine replacement is shown on drawing No. 5920-13297 Sht. 4, [Ref. 20].

An additional Heat Balance for both CLTP and 122% EPU using the PEPSE code for evaluation of balance of plant equipment (BOP) was developed by Stone & Webster, reference 18. These Heat Balance Diagrams contain more detailed modeling for some BOP piping.

VY has continuously operated under Nobel Metals Hydrogen Water Chemistry since November 2003. Current plant power level is 100% CLTP. Accession testing to 120% CLTP (EPU) operation is expected to start in 2006.

Reference 20 (120% EPU) conditions will be used for the FAC susceptibility screening. If actual operating temperatures are not available, the conservative end of the design range with respect to FAC is used.

4.3 Piping and Equipment Design Changes

Plant design changes that affect FAC Susceptible systems installed at VY since May 15, 2000 as documented in the plant Flow Diagrams listed in Table 1.

- VYDC-2003-002 - HP Feedwater Heater Replacements
- VYDC 2003-006 - High Pressure Turbine Replacement
- VYDC 2003-016 - Alternate Souse Term (AST)
- MM 2000-25 - Hydrogen Water Chemistry Outage Modifications
- MM 2000-51 Main Steam Drain Modifications for Small HELB
- MM 2003-24 - Condensate Demineralizer Filtered Bypass
- MM 2003-26 Alternate Source Term (AST) Component Modifications
- MM 2003-43 Min Turbine Cross-around Pipe Relief Valves Discharge Piping Mods
- MM 2003-26 Alternate Source Term (AST) Level Control Valve Replacements

5.0 EVALUATION CRITERIA

There are thousands of piping components (pipe and fittings) in service at VY, most of which do not operate under conditions where FAC is a concern. FAC occurs in piping with single-phase water and two-phase water/steam flow regimes under certain thermodynamic and chemistry conditions. In order to focus attention and resources effectively, those components where FAC is not a concern shall be eliminated from the scope of the FAC inspection program. To accomplish this, the exclusion criteria developed by EPRI contained in Section 4.2.2 of NSAC 202L-R2, [Ref.4], will be used.

Portions of piping systems which meet certain exclusion criteria, may or may not be excluded from the program scope. Examples include piping with no flow connecting directly to the condenser which has experienced leak-by from normally closed valves. The piping excluded by the criteria below could be susceptible to damage from other corrosion or degradation mechanisms. These include; cavitation, erosion, liquid impingement erosion, inter-granular stress corrosion cracking (IGSCC), microbiologically-influenced corrosion (MIC), and solid particle erosion.

All plant systems are considered within the scope of the VY Piping FAC Inspection Program unless excluded (screened out) by one of the following criteria [Ref. 4 Section 4.2.2]:

5.1 Exclusion Criteria

5.1.1 Stainless Steel or Low Alloy Steel Piping

Systems of stainless steel piping or low alloy steel piping with nominal chromium content equal to or greater than 1-1/4%. This exclusion pertains only to complete piping systems constructed of FAC resistant alloys. If some components in a high alloy line are carbon steel (valves) then the line shall not be excluded. In lines with specific components or sections of piping replaced with FAC resistant materials, the entire line should be identified as susceptible. Note that high chromium materials do not necessarily protect against other damage mechanisms, especially cavitation and liquid impingement erosion. If the specific damage mechanism which prompted previous material replacement has not been identified, then the system should not automatically be excluded from the program scope.

Piping locations with upstream FAC resistant material replacements will be noted for future inspection due to the "Leading Edge Effect" at the chrome material - carbon steel material boundary.

5.1.2 Superheated Steam Systems

Superheated steam systems with no moisture content regardless of temperature or pressure levels. However drains, traps, and other potentially high-moisture content lines from super-heated steam systems should not be excluded automatically.

5.1.3 High Dissolved Oxygen or Raw Water Systems

Systems with high levels of dissolved oxygen (oxygen > 1000. ppb), such as Service Water, Circulating Water, and Fire Protection.

5.1.4 Single Phase Systems With Temperature Below 175F.

EPRI recommends exclusion of single phase systems with temperature below 200F (low temperature). However, if measurable wear is found in nearby piping operating slightly above 200F, EPRI recommends that the systems exclusion be reconsidered. A temperature of 175F will be used for conservatism.

5.1.5 Systems With No Flow, or Which is in Use Less Than 2% of Plant Operating Time

Systems with no flow, or those that operate less than 2% of plant operating time or single phase systems that operate with temperature > 200F less than 2% of plant operating time. However, if the actual operating conditions of the system can not be confirmed (potentially leaking valves, etc.) or if the service is severe (fluid flashing), the system should not be excluded based on operation time alone.

This includes normally closed small bore equipment vents, drains, and level control instrument lines which are not connected to the condenser. These lines will not be accounted for in Table 2.

5.1.6 Piping Which Carries Fluids Other Than water or Wet Steam

The VY Piping FAC Inspection Program applies only to piping carrying water or wet steam. Therefore non-water systems such as Instrument Air or Turbine Lube Oil Systems are excluded.

6.0 ASSUMPTIONS

- 6.1 EPRI report NSAC-2021-R2, [Ref.4] describes systems susceptible to FAC as those made of carbon or low alloy steel which contain flowing water or wet steam. Process instrumentation and sampling lines at Vermont Yankee are typically constructed of stainless steel tubing, fittings, and valves. Instrumentation lines are typically considered as negligible flow and therefore not susceptible to FAC. These lines are not shown in Table 2.
- 6.2 All small bore equipment and piping low point drain and vent lines with normally closed manual valves are considered as non-susceptible to FAC based on the usage criteria unless otherwise noted.
- 6.3 Emergency bypass lines to the condenser will be included on a case by case basis. Thermal Performance Monitoring instruments on lines connecting to the main condenser are used to identify possible leakage by normally closed valves.
- 6.4 If the actual operating time of a system cannot be confirmed, or if the system operates under severe conditions relative to FAC, then that system should not be excluded from FAC inspection program based on time alone.
- 6.5 Large bore piping will be considered as 3 inch nominal diameter and larger. Small bore piping will be considered as 2-1/2 inch nominal diameter and smaller. Some small bore lines may include short segments of 3 inch pipe. These short segments of 3 inch pipe will be considered as small bore for classification of the line.
- 6.6 For the purpose of determining system susceptibility, system operating temperatures are assumed to be less than or equal to design temperatures and system operating pressures are assumed to be less than or equal to design pressures at all times. Design values are used if the operating values from the Heat Balance Diagram (reference 20) are not available.

7.0 SUSCEPTIBILITY REVIEW METHODOLOGY

For each System or Line contained on the drawings listed in Table 1 document the piping size and material, design temperature and process fluid.

Determine line operating conditions at full power EPU (120% CLTP) from available documentation. See Heat Balance Diagrams, references 18 & 20). Valve lineups are taken from System Operating Procedures, references 10 to 13, and 21.

Review all plant piping shown on the drawings listed in Table 1 against the exclusion criteria listed in Section 5 above. Document in Table 2 whether it is susceptible to FAC or not, and how it is addressed if it is susceptible.

All piping determined to be susceptible to FAC is considered within the scope of the program. Piping determined to be resistant to FAC, or the fluid environment is not conducive to FAC, is considered outside the scope of the program.

Each System or and/or Line in each system is assigned to one of the following categories:

Non-Susceptible (NS):

These systems/lines are not susceptible to FAC per the exclusion criteria contained in Section 5.0.

Susceptible–Modeled in CHECWORKS (SMC):

These large bore systems/lines are susceptible to FAC and the fluid flow regime is appropriate for modeling using CHECWORKS.

Susceptible– Not Modeled (SNM):

These large bore systems/lines are susceptible to FAC and are not appropriate for modeling using CHECWORKS due to pipe size, or uncertain thermodynamic conditions.

Susceptible Small Bore (SSB):

These small bore lines are generally not modeled using CHECWORKS. The entire line is considered susceptible. However, only specific locations on these lines are inspected. The locations inspected are included in a separate small bore piping database [Ref.14]. Long term trending and inspection of small bore piping is generally not performed at VY. If small bore piping and components show significant wear the entire line is generally replaced with FAC resistant materials.

8.0 RESULTS/CONCLUSIONS

All piping line shown on the plant P&IDs listed in Table 1, have been reviewed using the methodology from Section 7.0 and the exclusion criteria from Section 5.0. The results of the susceptibility screening are shown in Table 2. Each line, or group of lines, has been classified into one of four categories:

- NS: Non-Susceptible to FAC
- SMC: Susceptible–Modeled in CHECWORKS
- SNM: Susceptible– Not Modeled
- SSB: Susceptible Small Bore

Table 2 is essentially an inventory of every line shown on the plant P&IDs, excluding normally closed small bore vents, drains, instrument taps, and test connections.

Non Susceptible piping is considered outside the scope of the FAC inspection program.

Large bore piping, both SMC and SNM, is currently monitored for FAC damage under PP 7028. VY will adopt the Entergy Northeast Standard FAC Program Procedure, ENN-DC-315, "Flow Accelerated Corrosion Program" [Ref. 5]. PP 7028 [Ref. 3] will be superseded.

Inspections of susceptible small bore piping, SSB, are prioritized and documented using a separate Small Bore Data base documented in ENVY Engineering Report No. VY-RPT-05-00013 Rev.0, "Vermont Yankee Piping Flow Accelerated Corrosion Inspection Program – Small Bore Piping Component Inspection Database". [Ref.14].

9.0 REFERENCES

1. V.Y. Piping Flow Accelerated Corrosion (FAC) Inspection Program Manual, Revision 2a, November 2, 1999. [Note Historical Reference Superseded by PP 7028, Reference 3]
2. V.Y. Procedure, "Piping Flow Accelerated Corrosion Inspection", DP 4023, Rev. 2, March 20, 1998. [Note Historical Reference Superseded by PP 7028, Reference 3]
3. V.Y. Program Procedure, "Piping Flow Accelerated Corrosion Inspection Program", PP7028, Original, Issued LPC 1, 12/06/01.
4. EPRI Report "Recommendations for an Effective Flow Accelerated Corrosion Program", NSAC-202L-R2, Final Report, April 1999, Electric Power Research Institute.
5. Entergy Northeast Standard FAC Program Procedure, ENN-DC-315, "Flow Accelerated Corrosion Program" Revision 0.
6. Ebasco Specification for Piping, Piping Components, Hangers and Supports for Station Piping Systems BWR QC-10, Revised 2/1/70.
7. VY Plant Heat Balance Diagram for 100% rated Power Drawing No. 5920-11399, Sh.2 of 19, Rev.1, "Vermont Yankee Thermal Kit: Turbine S/N 170X383. [Note: Historical Reference, Superseded by Reference 19]
8. Steam Tables - Properties of Saturated and Superheated Steam, ABB Combustion Engineering (reprint of 1967 ASME Steam Tables).
9. Vermont Yankee Piping FAC Inspection Program, Small Bore Piping Component Selection Review, Revision 1 December 6, 1999. (Includes Small Bore Data Base). [Note: Historical Reference, Superseded by Reference 14]
10. VY Procedure RP 2170, Condensate System, Revision 24, LPC 1, (Appendices A & B – Valve Lineup).
11. VY Procedure OP 2113, Main & Auxiliary Steam, Revision 20, (Appendix A – Valve Lineup).
12. VY Procedure RP 2171, Condensate Demineralizer System, Revision 30.
13. VY Procedure OP 2172, Feedwater System, Revision 23, LPC No.3
14. ENVY Engineering Report No. VY-RPT-05-00013 Rev.0, "Vermont Yankee Piping Flow Accelerated Corrosion Inspection Program – Small Bore Piping Component Inspection Database"
15. Engineering Request ER 04-1409, "Extended Power Uprate Master Design Change"
16. GE Project Task Report for ENVY Extended Power Uprate Task T0100: Reactor Heat Balance, GE-NE-0000-0010-0197-01 Revision 0 December 2002.
17. GE Project Task Report for ENVY Extended Power Uprate Task T0700: Turbine-Generator Performance Evaluation, GE-NE-0000-0007-5277-01 Revision 0 June 2003.
18. Entergy / Vermont Yankee Nuclear Power Station PEPSE Heat Balances for Extended Power Uprate, Rev.0 dated March 26, 2003, by Stone & Webster

Vermont Yankee Piping Flow Accelerated Corrosion Inspection Program – FAC Susceptibility Review

19. Entergy – Vermont Yankee #1 Turbine 170x383 Heat Balance Diagram for HP ADSP at 100% Current Licensed Thermal Power Conditions (1593 MWt), VY Drawing No. 5920-13297, Sh.6, Rev.0, "Thermal Kit for HP Steam Path Replacement".
20. Entergy – Vermont Yankee #1 Turbine 170x383 Heat Balance Diagram for HP ADSP / 120% CTP Uprate Rated Power Conditions (1912 MWt), VY Drawing No. 5920-13297, Sh.4, Rev.0, "Thermal Kit for HP Steam Path Replacement".
21. VY Procedure OP 0105 Reactor Operations, Revision 11, LPC 5
22. GEK 17999A, Turbine Bypass Valves and System Description GE Power Systems, March 1991.
23. VY-RPT-05-00008, Revision 0, ALT Drain Paths and Seismic Isolation Boundaries for AST
24. VYDC-2003-002 - HP Feedwater Heater Replacements
25. VY Drawings VYI-FDW-Part 22A, VYI-FDW-Part 22B, 5920-10841. Feedwater flush lines partial Replacement drawings for PAR 87-12.
26. INPO Operating Experience OE 16287, "Reactor Feed Pump Turbine Sealing Steam Small-Bore Piping not Included in the Flow Accelerated Corrosion Program"

TABLE 1: Plant Flow Diagrams & Equipment Drawings Reviewed

Drawing No.	Revision (Note 1)	Title
G191156	36	Flow Diagram – Main , Extraction, & Auxiliary Steam Systems
G191157 Sht.1	59	Flow Diagram – Condensate, Feedwater, and Air Evacuation Systems
G191157 Sht.2	05	Flow Diagram – Condensate, Feedwater, and Air Evacuation Systems
G191157 Sht.3	03	Flow Diagram – Condensate, Feedwater, and Air Evacuation Systems
G191158	27	Flow Diagram – Heater Drain & Vent Systems
G191159 Sht.1	72	Flow Diagram Service Water System
G191159 Sht.2	84	Flow Diagram Service Water System
G191159 Sht.3	37	Flow Diagram RCW Cooling Water System
G191159 Sht.4	35	Flow Diagram TCW Cooling Water System
G191159 Sht.5	16	Flow Diagram Recirc. Pump Cooling Water
G191159 Sht.6	09	Flow Diagram AOG Closed Cooling Water
G191160 Sht.1	30	Flow Diagram Instrument Air System
G191160 Sht.2	17	Flow Diagram Instrument Air System
G191160 Sht.3	28	Flow Diagram Instrument Air System
G191160 Sht.4	19	Flow Diagram Instrument Air System
G191160 Sht.5	20	Flow Diagram Service Air System
G191160 Sht.6	10	Flow Diagram Service Air System
G191160 Sht.7	22	Flow Diagram Diesel Starting Air System
G191160 Sht.8	03	Flow Diagram Service Air System
G191161	22	Flow Diagram Makeup Water Treatment System
G191162 Sht.1	19	Flow Diagram Misc. Systems Turbine & Recirculation Lube Oil
G191162 Sht.2	25	Flow Diagram Misc. Systems Fuel Oil
G191162 Sht.3	22	Flow Diagram Misc. Systems Exhaust Stack & Off Gas System
G191162 Sht.4	10	Gas Control Piping Diagram
G191162 Sht.5	02	Arrangement of Shaft Sealing System
G191162 Sht.6	01	P& ID H2 System
G191162 Sht 7	05	Stator Winding Cooling Water System
G191163 Sht.1	39	Flow Diagram Fire Protection System - Inner Loop
G191163 Sht.2	13	Flow Diagram Fire Protection System – Outer Loop
G191163 Sht.3	06	Flow Diagram Fire Protection System – Low Pressure CO2
G191163 Sht.4	00	Flow Diagram Fire Protection System – Control Room Bldg. Cable Vault, East & West Switchgear Rooms
G191164	23	Flow Diagram Sampling System Sheet 1
G191165	44	Flow Diagram Sampling System Sheet 2
G191166	44	Flow Diagram Circulating Water & Associated Systems
G191167	74	Flow Diagram – Nuclear Boiler
G191168	43	Flow Diagram – Core Spray
G191169 Sht.1	47	Flow Diagram – High Pressure Coolant Injection System
G191169 Sht.2	43	Flow Diagram – High Pressure Coolant Injection System
G191170	48	Flow Diagram – Control Rod Drive Hydraulic System
G191171	25	Flow Diagram – Standby Liquid Control System
G191172	64	Flow Diagram – Residual Heat Removal System
G191173 Sht.1	36	Flow Diagram – Fuel Pool Cooling & Cleanup System
G191173 Sht.2	08	Flow Diagram – Fuel Pool Cooling & Cleanup System
G191174 Sht.1	42	Flow Diagram – Reactor Core Isolation Cooling System
G191174 Sht.2	23	Flow Diagram – Reactor Core Isolation Cooling System
G191175 Sht.1	69	Flow Diagram Primary Containment & Atmospheric Control System
G191175 Sht.2	19	Nitrogen Supply System - Flow Diagram
G191176 Sht.1	41	Flow Diagram – Condensate and Demin. Water Transfer System

TABLE 1: Plant Flow Diagrams & Equipment Drawings Reviewed - continued

Drawing No.	Revision (Note 1)	Title
G191176 Sht.2	42	Flow Diagram – Condensate and Demin. Water Transfer System
G191177 Sht.1	39	Flow Diagram – Radwaste Systems
G191177 Sht.2	22	Flow Diagram – Radwaste Systems
G191177 Sht.3	21	Flow Diagram – Radwaste Systems
G191177 Sht.4	16	Flow Diagram – Radwaste Systems
G191178 Sht.1	49	Flow Diagram – Reactor Water Clean-Up System
G191178 Sht.2	21	Flow Diagram – Reactor Water Clean-Up System
G191236	09	HVAC-Flow Diagram Radwaste Building
G191237 Sht.1	46	HVAC-Flow Diagram Turbine, Service, and Control Room Bldgs.
G191237 Sht.2	10	HVAC-Flow Diagram Turbine, Service, and Control Room Bldgs.
G191238	33	HVAC-Flow Diagram Reactor Building
G191254	35	HVAC-Heating Flow Diagram & Boiler Room Layout.
G191267 Sht.1	30	Flow Diagram – Nuclear Boiler Vessel Instrumentation
G191267 Sht.2	05	Flow Diagram – Nuclear Boiler Vessel Instrumentation
G191274	36	Flow Diagram – Condensate Demineralizer System
G191280	11	Potable Water - Flow Diagram
VY-E-75-001	11	Flow Diagram A. O. G.
VY-E-75-002	19	Engineering Flow Diagram Containment Atmosphere Dilution System (CAD)
33600-A-00202	04	Process Flow Diagram Off Gas System
33600-A-00207	22	Engineering Flow Diagram Train A Recombiner Area
33600-A-00208	20	Engineering Flow Diagram Train B Recombiner Area
33600-A-00209	17	Engineering Flow Diagram Train A Off Gas Drying
33600-A-00210	16	Engineering Flow Diagram Train B Off Gas Drying
33600-A-00211	21	Engineering Flow Diagram Charcoal Off Gas System
33600-A-00213	13	Engineering Flow Diagram H2O Chiller System (GCH-100-1A &1B)
33600-A-00216	11	Utility Flow Diagram Steam ReHeat Coils
33600-A-00217	21	Engineering Flow Diagram Turbine Bldg. Area Off Gas Modification
5920-00568	04	Moisture Removal Provisions & Extraction Diagram
5920-00870	11	HPCI Turbine Oil Piping Diagram
5920-01068	03	Flow Diagram Instrument Air Dryer ORIAD Model 4127
5920-11015	00	Flow Diagram (Atlas-Copco Station Air Compressors)
5920-12598	02	Diagram of Steam Seal Piping (GE No.735E758)
5920-12857 Sh.1	00	Flow Diagram Hydrogen & Process Air Injection Module
5920-12857 Sh.2	00	Flow Diagram Hydrogen & Process Air Injection Module
5920-12858	00	Flow Diagram Off Gas Monitor Panel

Notes:

1. Revision as of 6/16/05 including pending drawing changes documented on VY Drawing Pending Change List dated 6/16/05 located on \\Vyshared1\public\Controlled Doc.

Vermont Yankee Piping Flow Accelerated Corrosion Inspection Program – FAC Susceptibility Review

TABLE 2: Summary of Line by Line FAC Susceptibility Screening

Drawing No.	System	Line No(s).	Description	Fluid	Oper. Temp (F)	Material	Flow at Full Power Operation	Exclusion (Note 1)	Susceptibility Classification (Note 2)	Notes
G191156	Main Steam	18-MS-1A to -1D	MS from V2-86A-D to Turbine Stop & Control valves.	Sat Steam	540.	CS-5	Continuous		SMC	Note 8
G191156	Main Steam	20-MS by GE	MS leads from S.&C. valves to H.P Turbine.	Sat Steam	540	CS	Continuous		SMC	
G191156	Main Steam	16-MS-2A to -2D	MS from 18-MS to Turbine Bypass Valve Chests Z-1-1A & Z-1-1B	Sat Steam	<540	CS-5	Static- N.C. Valves.	U	NS	Flow during startup & transients. Note 8
G191156	Main Steam to SSR	3", 3-1/2", 5"-MS (GE-SSRM)	MS from MS-1A to V60-6 & SSR (SSR Supply)	Sat Steam	<540	CS-5	Static- N.C. Valve.	U	NS	V60-6 N.C. @ >70% power (Ref. 21), Note 8
G191156	Main Steam to SSR	5-MS (GE-SSRM) US/DS of V60-10	Steam Seal Regulator Bypass	Sat Steam	<540	CS-5	Normally Closed	U	NS	Ref. 11 & 21
G191156	Main Steam to SSR	8,12-MS (GE-SSRM) US/DS of V60-9	Steam Seal Regulator Unload	Sat Steam	<540	CS-5	Normally Closed	U	NS	Ref. 11
G191156	Main Steam Bypass	10-MS-3A to -3J	Bypass lines from Z1-1A & Z1-1B to condenser	Sat Steam	<540	CS-5	Warming Steam		SNM	Note 7
G191156	Turbine Cross Around	36" CAR A to D	CAR from H.P. turbine to M.S.	Sat Steam	<435	CS*	Continuous		SNM	*GE copper bearing alloy
G191156	Turbine Cross Around	30" CAR A, C, & D	CAR from M.S. to L.P.turbine.	Sat Steam	<435	LAS	Continuous		NS	A691-P22
G191156	Turbine Cross Around	30" CAR B	CAR from M.S. to L.P.turbine.	Sat Steam	<435	CS	Continuous		SNM	B line is carbon steel
G191156	Extraction Steam	12-ES-1A & -1B	ES from H.P.Turb to No.1 FDW Htrs.	Steam	<440	LAS-2	Continuous	M	NS	Note 3
G191156	Extraction Steam	10-ES-2A & -2B	ES from LP 7 th stg to No. 2 FDW Htrs.	Steam	<400	LAS-1	Continuous	M	NS	Note 3
G191156	Extraction Steam	20-ES-3A & -3B	ES from LP 8 th stg to No. 3 FDW Htrs.	Steam	<370	LAS-1	Continuous	M	NS	Note 3
G191156	Extraction Steam	20,30-ES-4A & -4B	ES from LP 10 th stg to No. 4 FDW Htrs.	Steam	<300	LAS-1	Continuous	M	NS	Note 3
G191156	Extraction Steam	26/20-ES-5A to 5H	ES from LP 12 th stg to No. 5 FDW Htrs.	Steam	<300	LAS-1	Continuous	M	NS	Note 3
G191156	Extraction Steam	12-ES-6	SSR CV-1-1A to E-5-1A	Steam	<300.	CS	Intermittent		SNM	1992 Inspections
G191156	Extraction Steam	3-ES-7A & -7B	Bypass to conden. from 30-ES-4A/B to valve LCV-4A/B	Steam	<300	LAS-1	Static - N.C. Valve	M	NS	

Vermont Yankee Piping Flow Accelerated Corrosion Inspection Program – FAC Susceptibility Review

TABLE 2: Summary of Line by Line FAC Susceptibility Screening

Drawing No.	System	Line No(s).	Description	Fluid	Oper. Temp (F)	Material	Flow at Full Power Operation	Exclusion (Note 1)	Susceptibility Classification (Note 2)	Notes
G191156	Extraction Steam	3-ES-8A & -8B	Bypass to conden. Downstream valve LCV-4A/B	Steam	<300	LAS-1	Static - N.C. Valve	M	NS	SB Loc. 120 & 121. Note 3.
G191156	Extraction Steam	2-ES-9A & -9B 2-ES-10A & -10B	Bypass to conden. From 20-ES-3A/B US & DS of valve LCV-3A/B	Steam	<370	LAS-1	Static - N.C. Valve	M	NS	SB Loc. 63 & 65. Note 3.
G191156	Extraction Steam	2-ES-11A & -11B 2-ES-12A & -12B	Bypass to conden. From 10-ES-2A/B US & DS of valve LCV-2A/B	Steam	<400	LAS-1	Static - N.C. Valve	M	NS	SB Loc. 62 & 64. Note 3.
G191156, 5920-0568	Extraction Steam	8" 13 th stage ES into condenser	13 th stage ES line US of RO 61-13 A to H in condenser	Steam	<300	LAS	Continuous	M	NS	Note 12.
G191156	Turbine Steam Relief Valves	18", 20" -SRV-1 to SRV-4	From CIV to Main Condenser Nozzle 48	Steam	<435	CS-2	Static - N.C. Valve	U	NS	
G191156	SSR Relief Valves	10-SRV-5A& 5B 10-SRV-6A& 6B	SSR RV to Main Condenser Nozzles 36 & 37	Steam	<540	CS-1	Static - N.C. Valve	U	NS	
G191156	Aux. Steam	2 SS-1	Piping at FE-9	Steam	540	316-SS	Continuous	M	NS	Note 8
G191156	Aux. Steam	3,2-1/2,2-AS 1	Steam Supply from MS-1A to SJAE	Steam	540	CS-5	Continuous		SSB	Note 8
G191156	Aux. Steam	2-1/2-AS-2A & -2B	FCV-1A/1B to 1 st Stg. Inter-condenser	Steam	540	CS-5	Continuous		SSB	Note 8
G191156	Aux. Steam	3-AS-3	PCV-1 to 2 nd Stg. Aftercondenser	Steam	540	CS-5	Continuous		SSB	Note 8
G191156	Aux. Steam	3-AS-4	Piping at FCV-36A & FCV-35	Steam	540	CS-5	Continuous		SSB	Note 8
G191156	Aux. Steam	2" & 2-1/2" AS	Piping US/DS of FCV-2A & -2B to after condenser	Steam	540	CS-5	Continuous		SSB	
G191156	Aux. Steam	1" & 2"-AS	US & DS of LCV-101-39 & ST-62-1	Steam	<540	CS-5	Intermittent		SSB	SB Location Nos. 66 & 67, Note 8
G191156	Aux. Steam	2" -MSD-465	Drain from FVC-34 to condenser at Conn. 68	Steam	<540	CS-5	Intermittent		SSB	SB Location Nos. 68,69
G191156	Aux. Steam	1" & 1-1/2"-AS	US & DS of LCV-101-40 & ST-62-2 to main condenser Conn.69	Steam	<540	CS-5	Intermittent		SSB	SB Location Nos. 70,71,72
G191156	Off Gas	2 & 2-1/2-HS-190	Steam Supply MS-7B to A.O.G	Steam	540	CS	Continuous		SSB	Note 8
G191156	Main Steam Drains	3-MSD-4	MS drain DS of ST60-3& LCV-143 in RX Bldg. At condenser Nozzle 47	Water/ Steam	<540	CS-5	Intermittent		SSB	SB Location No. 5, Note 8

Vermont Yankee Piping Flow Accelerated Corrosion Inspection Program – FAC Susceptibility Review

TABLE 2: Summary of Line by Line FAC Susceptibility Screening

Drawing No.	System	Line No(s).	Description	Fluid	Oper. Temp (F)	Material	Flow at Full Power Operation	Exclusion (Note 1)	Susceptibility Classification (Note 2)	Notes
G191156	Main Steam Drains	1,2-1/2 US/DS of V60-2A thru -2D	Turbine Stop Valve Inlet drains	Water/ Steam	540	CS-5	Start- up / Normally Closed		SSB	SB Location Nos. 14,15, 16,17, Note 8
G191156	Main Steam Drains	2-1/2-MSD-6	Combined TSV inlet drains from V60-4 to condenser Nozzle 33.	Water/ Steam	<540	CS-5	Start- up / Normally Closed		SSB	SB Location Nos. 18,19,20
G191156	Main Steam Drains	6-MSD-7A to 7D	MS Drip Leg off MS-7A to MS-7D	Water / steam	540	CS-5	Intermittent (drip leg)		SNM	Note 8
G191156	Main Steam Drains	1, & 2-1/2 MSD-7A to 7D D.S. of ST-60-2A to -2D	MS Line Drip Leg Steam Traps	Water / steam	540	CS-5	Intermittent		SSB	SB Location Nos. 6,8,10,12, Note 8
G191156	Main Steam Drains	1,2, & 2-1/2 MSD-8A-D at LCVs-38A-D, MS-956-A	MS Line Drip Leg Level control valves	Water / steam	540	CS-5	Intermittent		SSB	SB Location Nos. 7,9,11,13, Note 8
G191156	Main Steam Drains	8-MSD-9	MS Line Drip Leg collector to condenser	Water / steam	<540	CS-5	Intermittent		SNM	SB Location Nos. 7,9,11,13, Note 8
G191156	Main Steam Drains	1-MSD U.S./D.S. of Valves MS-5A to MS-5D	Turbine Control Valve Inlet Drain	Water / steam	540	CS-5	Start- up / Normally Closed		SSB	SB Location Nos. 21,22,23,24
G191156	Main Steam Drains	2" D.S. V60-5A - 5D to condenser	TCV inlet drains from V60-5A-D to condenser Nozzle 34	Water / steam.	<540	CS-5	Start- up / Normally Closed		SSB	SB Location Nos. 25,26,27
G191156	Main Steam Drains	1" & 2" MSD, U.S. V60-12 / R.O.60-1	HP Leads drains to V60-12 and R.O.60-1	Water / steam	540	CS-5	Continuous		SSB	
G191156	Main Steam Drains	1" & 2" MSD, D.S. V60-12/R.O.60-1 to stub at Cond. A	HP Leads drain from V60-12 and R.O.60-1 to stub at condenser nozzle 35	Water / Steam	<540	SS & A335-P11	Continuous	M	NS	SB Location Nos. 28,29,30 Note 4.
G191156	Main Steam Drains	2" MSD, D.S. V60-12 / R.O.60-1	Stub at condenser Nozzle 35 D.S. of V60-12 and R.O.60-1	Water / Steam	<540	CS	Continuous		SSB	Note 10
G191156	SSH	1" LPDR	SSH Front End Low Point drain to condenser nozzle 61	Water / Steam	<540	CS	Continuous		SSB	
G191156	SSH	1/2" & 1-1/2" drains	1/2" & 1-1/2" drains SR60-1A, 1B, 2A, 2B to condenser Nozzle 62	Water / Steam	<540	CS	Static - N.C. Valve	U	NS	
G191157 Sht.1	Condensate	20-C-1,20-C-2 24,30,36-C3 24-C-4, 24-C-5	Condensate Pump suction from Hotwell	Water	105	CS-1	Continuous	T	NS	Note 3, Ref 20

Vermont Yankee Piping Flow Accelerated Corrosion Inspection Program – FAC Susceptibility Review

TABLE 2: Summary of Line by Line FAC Susceptibility Screening

Drawing No.	System	Line No(s).	Description	Fluid	Oper. Temp (F)	Material	Flow at Full Power Operation	Exclusion (Note 1)	Susceptibility Classification (Note 2)	Notes
G191157 Sht.1	Condensate	18-C-6, 18-C-7 18,24-C-8	Condensate Pump discharge to SJAE inter-condensers	Water	105	CS-2	Continuous	T	NS	Note 3, Ref 20
G191157 Sht.1	Condensate	12-C-10, 12-C-11 12-C-13, 12-C-14	SJAE inter- condenser inlet & outlet.	Water	106	CS-2	Continuous	T	NS	Note 3, Ref 20
G191157 Sht.1	Condensate	12-C-9, 12-C-12	SJAE after- condenser inlet & outlet.	Water	105	CS-2	Static – N.C. Valves	T,U	NS	Note 3, OG558/OG560 closed
G191157 Shts.1& 2	Condensate	24-C-15,24-C-16	From SJAE to SPE to Con. Demin.	Water	106	CS-2	Continuous	T	NS	Note 3, Ref.20
G191157 Shts.1& 2	Condensate	20,24-C-18, 20-C-19	Con Demin to E-5s	Water	107	CS-2	Continuous	T	NS	Note 3, Ref.20
G191157 Sht.2	Condensate	4-C-20, 4-C-48	To LCV-1A-2 (to CRD pumps)	Water	107	CS-2	Continuous	T	NS	Ref.20
G191157 Sht.1	Condensate	10,14-C-21, 10-C-22	Min flow line thru FCV-4 to main condenser Nzl.44	Water	107	CS-2	Start-up	T,U	NS	Ref.20
G191157 Sht.1	Condensate	12-C-23	LP Htr bypass line	Water	107	CS	Normally Closed	T,U	NS	V64-19 closed
G191157 Sht.1	Condensate	20-C-25, 20-C-26	E-5s to E-4s	Water	172	CS-2	Continuous	T	NS	Note 3, Ref.20
G191157 Sht.1	Condensate	20-C-27, 20-C-28	E-4s to E-3s	Water	249	CS-2	Continuous		SMC	Ref.20
G191157 Shts.1&2	Condensate	20-C-29, 16,20,24 -C-30 16,20-C-31 & -32	E-3s to Feedwater Pumps	Water	309	CS-2	Continuous		SMC	Ref.20
G191157 Shts.1& 2	Condensate	6,8,12-C-33, 6-C-34	Hotwell Emergency Makeup CST to condenser Nzl.45 Thru N.C. V64-31	Water	90	CS-1	Normally Closed	T,U	NS	
G191157 Sht.1	Condensate	4,6,C-33,	US/DS of LCV-1A-1 (Condenser Makeup LCV) bypasses N.C. V64-31	Water	90	CS-1	Normally Closed	T,U	NS	
G191157 Sht.1	Condensate	4,6-C-35	Condenser hood spray Bypass (FVC-36) at Nzl.60	Water	107	CS-2	Start-up / Intermittent	T,U	NS	Ref.20
G191157 Sht.1	Condensate	3,6-C-37, 3-C-38, 3-C-39	Condensate Pump Casing Vent to Hotwell Nozzle 46	Water	105	CS-1	Open / Static	T	NS	Ref.20
G191157 Shts.1& 2	Condensate	4-C-40	SPE Loop Seal drain to Atm. Drain Tank	Water	<175	CS-1	Drain	T	NS	
G191157 Sht.1	Condensate	4-C-41, 2-1/2-C-41A &41B	SJAE loop seal drain to Cond Nzl.49	Water	<175	CS-1	Drain	T	NS	

Vermont Yankee Piping Flow Accelerated Corrosion Inspection Program – FAC Susceptibility Review

TABLE 2: Summary of Line by Line FAC Susceptibility Screening

Drawing No.	System	Line No(s).	Description	Fluid	Oper. Temp (F)	Material	Flow at Full Power Operation	Exclusion (Note 1)	Susceptibility Classification (Note 2)	Notes
G191157 Shts.1& 2	Condensate	8-C-42	DS of valve V62-18 N.C.	Water	107	CS-1	Static / N.C.	T,U	NS	
G191157 Shts.1& 2	Condensate	2-1/2-C-43	US/DS of LCV-1A-3 (Condenser Reject LCV)	Water	107	CS-2	Continuous	T	NS	SB Location No. 116
G191157 Shts.1& 2	Condensate	3,4-C-44, 3-C-44A	Atmos. Drain Tank drain to Condenser Nozzle 63	Water	105	CS-1	Drain	T	NS	
G191157 Shts.1& 2	Condensate	2-1/2-C-45, 2-1/2-C-41B	SJAE afterconden. Loop seal drain line to Atm. Dm. Tk.	Water	105	CS-1	Static / N.C. valve	T	NS	V64-46 is N.C.
G191157 Shts.1& 2	Condensate	2" C & 6"-C-46	Atmos. Drain Tank overflow / drain to sump.	Water / Air	105	CS-1	Drain	T	NS	Vented to Atmosphere
G191157 Sht.2	Condensate	3-C-47	Atmos. Dm Tk vent to suction of Ventilation Exhaust Sys.	Air/Gas	105	CS-1	Vent	T,NW	NS	
G191157 Shts.1 & 2	Condensate	¾" & 1"-C	Press. Line for RHR,CS, HPCI,RCIC in Rx. Bldg. thru PCV-32, & RO-64-2 to condenser nozzle 64	Water	107	CS-1	Continuous	T*	SSB*	SB Location No. 119 *Note 9
G191157 Sht.1	Condensate	¾" & 1"	Condensate Pump Gland seal lines (R.O. 64-1A & 1B)	Water	105	CS-1	Continuous	T*	SSB*	*Note 9
G191157 Sht.1	Condensate	¾" & 1" lines at V64-26A,B,C	(SRV's SR-643A,B,C) & bypass lines	Water	310	CS-1	Static - N.C Valve	U	NS	V64-27A,B,C N.C., Ref. 10
G191157 Sht.1	Condensate	2"-C	Condenser Exhaust Hood Spray lines (FCV-5)	Water	105	CS-2	Start-Up / Low Power	U,T	NS	
G191157 Sht.1	Condensate	¾"	¾" SJAE bypass line with unidentified FE OG-559 is N.C.	Water	105	CS	Static -N.C. Valve	U	NS	
G191157 Sht.1	Condensate	2"-C	2" bypass around valves V64-25A & V64-25B	Water	310	CS-2	Static -N.C. Valve	U	NS	V64-145A & B N.C., Ref. 10
G191157 Sht.2	Condemin	8" CD-46	Condemin Bypass Strainer Return to Condensate	Water	107	CS-2	Intermittent	U,T	NS	
G191157 Sht.3	Feedwater	12,16,24-FDW-1 12,16-FDW-2, -3 18-FDW-7, -8	Feedwater Pumps to E-2s)	Water	312	CS-5	Continuous		SMC	Ref.20
G191157 Sht.3	Feedwater	18-FDW-12, -13	E-2s to E-1s	Water	344	CS-5	Continuous		SMC	Ref 20
G191157 Sht.3	Feedwater	16,18-FDW-14, -15	E-1s to Rx	Water	392	CS-5	Continuous		SMC	Ref.20
G191157 Sht.3	Feedwater	6-FDW-9	10% flow Feed Reg Valve.	Water	312	CS-5	Start-up	U	NS	Ref.20
G191157 Sht.3	Feedwater	18-FDW-10	Equalizing line	Water	312	CS-5	Continuous (Static)		SMC	Flow at startup; Ref 20

Vermont Yankee Piping Flow Accelerated Corrosion Inspection Program – FAC Susceptibility Review

TABLE 2: Summary of Line by Line FAC Susceptibility Screening

Drawing No.	System	Line No(s).	Description	Fluid	Oper. Temp (F)	Material	Flow at Full Power Operation	Exclusion (Note 1)	Susceptibility Classification (Note 2)	Notes
G191157 Sht.3	Feedwater	10-FDW-11	HP Heater Bypass line	Water	312	CS-5	Normally Closed	U	NS	V63-5 N.C.
G191157 Sht.3	Feedwater	4-FDW-4, -5, -6	Feed Pump Recirc: from 16" FDW to FCV 2A,B,C	Water	312	CS-5	Normally Closed	U	SMC*	*Notes 3,5
G191157 Sht.3	Feedwater	4-FDW-24, -25, -26	Feed Pump Recirc: FCV 2A,B,C to 4x6 expander	Water	312	A335-P11	Normally Closed	U,M	SMC*	*Notes 3,5
G191157 Sht.3	Feedwater	6-FDW-4, -5, -6	Feed Pump Recirc: 4x6 expander to Cond. Nzl. 32	Water	312	CS-5	Normally Closed	U	SMC*	*Notes 3,5,10
G191157 Sht.3	Feedwater	8-FDW-22A & 22B	Feedwater HP Htr. flush from 18" FDW to V63-22A,B.	Water	312	CS-5	Normally Closed	U	SMC*	*Notes 3,5, Ref.25
G191157 Sht.3	Feedwater	8-FDW-22A & 22B	Feedwater HP Htr. flush from V63-22A,B. to V63-23A,B	Water	312	A335-P11	Normally Closed	U,M	SMC*	*Notes 3,5, Ref.25
G191157 Sht.3	Feedwater	8-FDW-22A & 22B	Feedwater HP Htr. flush from V63-23A,B to 5-FDW-22A,B.	Water	312	CS-5	Normally Closed	U	SMC*	Notes 3,5, 10 Ref.25
G191157 Sht.3	Feedwater	5-FDW-22A & 22B	FDW Htr. Flush U.S. of R.O. 2A-C & RO3A-C.	Water	312	A335-P11	Normally Closed	U,M	SMC*	Notes 3,5, Ref.25
G191157 Sht.3	Feedwater	10-FDW-23A & 23B	R.O. 2A-C & R.O. 3A-C to Condenser Nzl. 70	Water	312	A335-P11	Normally Closed	U,M	SMC*	Notes 3,5, Ref.25
G191157 Sht.3	Feedwater	1/2" & 3/4"	Feed pump Warm-up lines (R.O.4)	Water	312	CS-1	Continuous		SSB	Ref.13
G191157 Sht.3	Feedwater	2"	2" bypass around valves V63-7A & V63-7B	Water	392	CS-5	Static N. C. Valve	U	NS	Ref.13
G191157 Sht. 3	Air Evacuation	10,16,-AE-1, 10-AE-2 8,10-AE-3 10,14-AE-4 2" & Smaller	Air Evacuation System from condenser to SJAE and P-53-1A	Air, Gases	<175	CS-1	Continuous	NW	NS	
G191157 Sht. 3	Off Gas	10-OG-1 10,16-OG-2 10-OG-3,3-OG-11	Off Gas Piping from SPE	Air, Gases	<175	CS-1	Continuous	NW	NS	
G191157 Shts. 2&3	Off Gas	1/1/2" -OG-5	Drain from Shutdown Iodine Filter to Atmos. Drain Tank	Water	<175	CS-1	Static No Flow to SIF	T	NS	
G191157 Sht.1	Off Gas	10, 12-OG-100	Off Gas Piping from SJAE to AOG (thru Valve OG-557)	Air, Gases	<175	CS-1	Continuous	NW	NS	
G191157 Sht.2	Off Gas	SIF-1, SIF-2, SIF-3, SIF-4	16" inlet & outlet piping at Shutdown Iodine Filter	Air, Gases	<175	CS-1	Static N.C. Valves	NW	NS	
G191157 Sht.1	Oxygen Injection	All	Condensate Oxygen Injection From Manifolds to 24"-C-6	O ₂	Ambient	SS Tubing	Continuous	M,NW	NS	

Vermont Yankee Piping Flow Accelerated Corrosion Inspection Program – FAC Susceptibility Review

TABLE 2: Summary of Line by Line FAC Susceptibility Screening

Drawing No.	System	Line No(s).	Description	Fluid	Oper. Temp (F)	Material	Flow at Full Power Operation	Exclusion (Note 1)	Susceptibility Classification (Note 2)	Notes
G191157 Sht.2	SPE Drip Leg Loop Seal	1-1/2" vent	SPE Header Drip Leg Loop Seal vents to line 3"C-47	Gases	<195	CS	Continuous	NW	NS	
G191157 Sht.2	SPE Drip Leg Loop Seal	1", 1-1/2" drain	SPE Header Drip Leg Loop Seal drain to TK-3-1A.	Water	<195	CS	Continuous		SSB	
G191158	Heater Drains	6-HD-1A, & -1B (3" @ LCV)	E-1-1A to LCV-103-1A-1 E-1-1B to LCV-103-1B-1	Water	354	CS-2	Continuous		SMC	Refs.20,24
G191158	Heater Drains	3-HD-1A, & -1B	LCV-103-1A-1/1B-1 to E-2-1A/B	Water	354	A335-P11	Continuous	M	NS	Refs. 20,24
G191158	Heater Drains	6-HD-2A/ -2B 3,10-HD-18A /18B	E-1-1A/B to E-2-1A/B Condenser Bypass Lines	Water	354	CS-2	Normally Closed	U	NS	Note 3, Ref.20
G191158	Heater Drains	8,10-HD-3A, & -HD-3B	E-2-1A/B to LCV-103-2A/B-1	Water	322	CS	Continuous		SMC	Ref.20
G191158	Heater Drains	3,10-HD-23A & -HD-23B	LCV-103-2A/B-1 to E-3-1A/B	Water	322	SS	Continuous	M	NS	SA240-304L Ref.20
G191158	Heater Drains	6-HD-4A, & -4B 6-HD-19A & -19B	E-2-1A/B to E-3-1A/B Condenser Bypass Lines	Water	322	CS	Normally Closed	U	NS	Note 3, Ref.20
G191158	Heater Drains	10,14-HD-5A, HD-5B	E-3-1A/B to LCV-103-3A/B-1	Water	250	CS	Continuous		SMC	Ref.20
G191158	Heater Drains	6,20-HD-24A & HD-24B	LCV-103-3A/B-1 to E-4-1A/B	Water	250	SS	Continuous	M	NS	A430, TP-308L, Ref.20
G191158	Heater Drains	6-HD-6A, & -6B 6,18-HD-20A/20B	E-3-1A/B to E-4-1A/B Condenser Bypass Lines	Water	250	CS	Normally Closed	U	NS	Note 3, Ref.20
G191158	Heater Drains	16-HD-7A, -7B 14-HD-25A -25B	E-4-1A/B to E-5-1A/B	Water	182	CS	Continuous		SMC	Ref.20
G191158	Heater Drains	16-HD-8A, -8B 10,18-HD-21A/B	E-4-1A/B to E-5-1A/B Condenser Bypass Lines	Water	182	CS	Normally Closed	U	NS	Note 3, Ref.20
G191158	Heater Drains	8,12-HD-9A, -9B	P-3-1A/B suction and discharge	Water	<182	CS	N.C. used @ <70% Power	U	NS	Note 3, Ref.20
G191158	Heater Drains	4-HD-10A, -10B	P-3-1A/B min flow lines	Water	<182	CS	N.C. used @ <70% Power	U	NS	Note 3, Ref.20
G191158	Heater Drains	16,20-HD-14A/B, 16,24-HD-17A-D	E-5-1A/B to E-6-1A/B (condenser)	Water	117	CS	Continuous	T	NS	Note 3, Ref.20
G191158	Heater Drains	3-HD-26A /B	E-5-1A/B external reference leg for level controls	Water	117	CS-1	Static	T,U	NS	
G191158	Moisture Separator Drains	6,24-HD-11A-11D 6-HD-12A -12D	MS-1-1A-D to LCV-24A-D	Water	<440	CS-2	Continuous		SMC	

Vermont Yankee Piping Flow Accelerated Corrosion Inspection Program – FAC Susceptibility Review

TABLE 2: Summary of Line by Line FAC Susceptibility Screening

Drawing No.	System	Line No(s).	Description	Fluid	Oper. Temp (F)	Material	Flow at Full Power Operation	Exclusion (Note 1)	Susceptibility Classification (Note 2)	Notes
G191158	Moisture Separator Drains	6,14-HD-15A & 15B	LCV-24A-D to E-2-1A & 1B	Water	<440	A335-P22	Continuous	M	SMC*	Notes 3,5
G191158	Moisture Separator Drains	4,6-HD-13A-13D	MS-1-1A-D to LCV-23A-D (Bypass to Condenser)	Water	<440	CS-2	No flow, Normally Closed	U	NS	Note 5
G191158	Moisture Separator Drains	4,6-HD-16A-16D	LCV-23A-D to Condenser	Water	<440	A335-P22	No flow, Normally Closed	U,M	NS	Note 5
G191158	Heater Vents	1-HV-1A/1B	E-1-1A/B Shell Start-up Vent US/DS of V67-1A/1B to Condenser B - Nozzle 25	Gases / Vapor	<440	A335-P11	Start up	U, M	NS	Ref.24
G191158	Heater Vents	2-HV-12A/12B	E-1-1A/B Shell Continuous Vent US/DS of R.O. 1A/1B to common 2 inch line to Cond. B Nozzle 25A	Gases / Vapor	<440	A335-P11	Continuous	M	NS	Ref.24
G191158	Heater Vents	1-HV-14A/14B	1 inch Bypass around R.O. 1A & 1B	Gases / Vapor	<440	A335-P11	Static N.C. Valve	U,M	NS	Ref. 10, 24
G191158	Heater Vents	1-HV-2A/2B	E-2-1A/B Shell Start-up Vent US /DS of V67-4A/4B to condenser A –Nozzle 24	Gases / Vapor	<400	A335-P11	Start Up	U,M	NS	Ref.24
G191158	Heater Vents	1-HV-13A/13B	E-2-1A/B Shell Continuous Vent to Cond. B (Nzl. 24) US & DS of R.O. 2A & 2B	Gases / Vapor	<400	A335-P11	Continuous	M	NS	Ref.24
G191158	Heater Vents	1-HV-15A/15B	1 inch Bypass around R.O. 2A & 2B	Gases / Vapor	<400	A335-P11	Static N.C. Valve	U,M M	NS	Ref.10, 24
G191158	Heater Vents	1, 1-1/2-HV-3A/3B	E-3-1A/B Drain Cooler Startup Vent US/DS of V67-7A & 7B to Cond. A (Nzl. 23)	Gases / Vapor	<300	CS-1	Start Up	U	NS	Note 3, SB Location Nos. 46,47,51,52
G191158	Heater Vents	3/4-HV-8A/8B	E-3-1A/B to V67-15A/B, Shell Start-up Vent	Gases / Vapor	<300	SS	Start Up	U,M	NS	
G191158	Heater Vents	2-HV-9A/9B	E-3-1A/B Shell Continuous Vent US/DS of R.O. 3A/3B to Cond. A Nzl. 23B.	Gases / Vapor	<300	CS	Continuous		SSB	SB Location Nos. 48,49,50, 53,54,55
G191158	Heater Vents	2-1/2-HV-4A/4B	E-4-1A/B Shell Start-up Vent US/DS V67-9A/9B to Condenser B (Nzl. 22)	Gases / Vapor	<370	CS-2	Start Up	U	NS	SB Location Nos. 56,58,59,61

Vermont Yankee Piping Flow Accelerated Corrosion Inspection Program – FAC Susceptibility Review

TABLE 2: Summary of Line by Line FAC Susceptibility Screening

Drawing No.	System	Line No(s).	Description	Fluid	Oper. Temp (F)	Material	Flow at Full Power Operation	Exclusion (Note 1)	Susceptibility Classification (Note 2)	Notes
G191158	Heater Vents	2-1/2,4-HV-8A	E-4-1A/B Shell Continuous US/DS of R.O. 4A/4B to common 4 inch line to Cond. A Nozzle 22B	Gases / Vapor	<370	CS-2	Continuous		SSB	SB Location Nos. 57,60,118
G191158	Heater Vents	3,4-HV-11A/11B	E-5-1A/B Vent to Condenser A/B (Nzl. 21A/21B)	Gases / Vapor	<168	CS-1	Continuous	T	NS	
G191158	Heater Vents	1-HV-5A/5B	E-5-1A/B Start-up Vent to Condenser A/B (Nzl. 21A/B) (V67-11A & 11B)	Gases / Vapor	<168	CS-1	Start Up	U,T	NS	
G191158	Heater Vents	3/4-HV	HD Pump P-3-1A/B Vent to E-4-1A/B	Gases / Vapor	<163	CS-1	Start Up	U,T	NS	
G191158	Heater Vents	2-HV	HD Pump P-3-1A/B Vent to Condenser B (Nzl 50)	Gases / Vapor	<163	CS-1	Start Up	U,T	NS	
G191158	Moisture Separator Vents	3-HV-6A to 6D	MS-1-1A to D, shell to drain tank TK-1-1A vent	Gases / Vapor	<380	CS-2	Static / Equalizing Line	U	NS	
G191158	Moisture Separator Vents	6-HV-7A to 7D	MS-1-1A to D, drain line to tank TK-1-1A equalizing line.	Gases / Vapor	<380	CS-2	Static / Equalizing Line	U	NS	
G191158	Safety Relief	6-SRV-7A/B	Heater Shell Safety Relief E-1-1A/B to Conden B (Nzl. 29)	Steam	<380	CS-2	No Flow (Relief line)	U	NS	
G191158	Safety Relief	6-SRV-8A/B	Heater Shell Safety Relief E-1-2A/B to Conden A (Nzl. 28)	Steam	<333	CS-2	No Flow (Relief line)	U	NS	
G191158	Safety Relief	1-SRV	Heater Tube Side Safety Relief E-1-2A/B to Conden A (Nzl. 30)	Steam	<327	CS-2	No Flow (Relief line)	U	NS	
G191158	Safety Relief	6-SRV-9A/B	Heater Shell Safety Relief E-1-3A/B to Conden A (Nzl. 27)	Steam	<300	CS-1	No Flow (Relief line)	U	NS	
G191158	Safety Relief	6-SRV-10A/B	Heater Shell Safety Relief E-1-4A/B to Conden B (Nzl. 26)	Steam	<234	CS-1	No Flow (Relief line)	U	NS	
G191158	Safety Relief	1-SRV	Heater Tube Side Safety Relief E-1-5A/B to 10-AE-4	Steam	<168	CS-2	No Flow (Relief line)	U	NS	
G191159 Sht.1 & 2 Sht.6	Service Water & AOGCCW	All	All	Raw Water	32 to 150	CS/SS, Copper	Continuous	O2,T	NS	

Vermont Yankee Piping Flow Accelerated Corrosion Inspection Program – FAC Susceptibility Review

TABLE 2: Summary of Line by Line FAC Susceptibility Screening

Drawing No.	System	Line No(s).	Description	Fluid	Oper. Temp (F)	Material	Flow at Full Power Operation	Exclusion (Note 1)	Susceptibility Classification (Note 2)	Notes
G191159 Sht.3 & 5	RBCCW	All	All	Treated Water	32 to 150	CS-1,	Continuous	T	NS	
G191159 Sht.4	TBCCW	All	All	Treated Water	32 to 150	CS-1, Copper	Continuous	T	NS	
G191160 Shts . 1 to 4 & Sht.8	Instrument Air	All	All	Air	150	CS-1	Continuous	NW	NS	
G191160 Sht. 5 & 6	Service Air	All	All	Air	150	CS-1	Continuous	NW	NS	
G191160 Sht. 7	Diesel Generator Starting Air	All	Diesel Generator Starting Air & Air Inlets and Exhausts	Air	150	CS-1	Continuous	NW	NS	
G191161	Makeup Water Treatment	All	Raw Water & Demineralized Water	Raw Water	<175	CS-1	Continuous	O ₂ ,T	NS	
G191162 Sht. 1	Lube Oil	All	Turbine & Recirc Pump MG Set Lube Oil	Lube Oil	100 & 250	CS-1	Continuous	NW	NS	
G191162 Sht.2	Fuel Oil	All	Diesel Generator, House Heating , & Diesel Fire Pump Fuel Oil	Fuel Oil	100	CS-1	Continuous	NW	NS	
G191162 Sht.3	Exhaust Stack & Off Gas	All	Exhaust Stack & Off Gas	Gas	175	CS-1	Continuous	NW	NS	
G191162 Sh.4	Gas Control Piping	All	Generator CO ₂ & H ₂ Piping	Gas			Continuous	NW	NS	
G191162 Sh.5	Generator Shaft Seal	All	Generator H ₂ & Seal Oil Piping	Gas/Oil			Continuous	NW	NS	
G191162 Sh.6	Hydrogen Piping	ALL	H ₂ Piping from Trailer to Turbine Building	H ₂	<150	S.S	Continuous	NW	NS	
G191162 Sh.7	Stator Winding Cooling	All	Skid and piping to stator. Closed loop cooling system	De-ionized H ₂ O	<212	CS/CU	Continuous	O ₂	NS	
G191163 Shts 1 & 2	Fire Protection	All	Fire Protection Piping : Inner & Outer Loops	Raw Water	100	A53 & A-120	No Flow	O ₂	NS	
G191163 Sht. 3	Fire Protection	All	Low Pressure CO ₂	CO ₂		CS	No Flow	NW	NS	
G191163 Sht. 4	Fire Protection	All	CO ₂ piping and bottle racks for Cable Vault / SWGR Rms	CO ₂		CS	No Flow	NW	NS	

Vermont Yankee Piping Flow Accelerated Corrosion Inspection Program – FAC Susceptibility Review

TABLE 2: Summary of Line by Line FAC Susceptibility Screening

Drawing No.	System	Line No(s).	Description	Fluid	Oper. Temp (F)	Material	Flow at Full Power Operation	Exclusion (Note 1)	Susceptibility Classification (Note 2)	Notes
G191164	Sampling System Sh.1	All	Process Sampling Line	Water		SS		M	NS	
G191165	Sampling System Sh.2	All	Process Sampling Line	Water		SS		M	NS	
G191166	Circ. Water	All	Circulating Water System & Associated Piping	Raw Water	<150	CS	Continuous	O2	NS	
G191167	Main Steam	18-MS-7A to -7D	MS from Rx to V2-86A -86D	Sat Steam	540	CS-5	Continuous		SMC	Ref. 20
G191167	Main Steam	10-MS-4A	MS 18-MS-7D to HPCI Turb.	Sat Steam	540	CS-5	Static	U	NS	Ref. 20
G191167	Main Steam	3-MS-5A	MS 18-MS-7C to RCIC Turb.	Sat Steam	540	CS-5	Static	U	NS	Ref. 20
G191167	Main Steam Drains	3-MSD-2	MSD Drain Header in Drywell thru Pen. X-8 (US of V2-77)	Steam/ Condensate	540	CS-5	Start-Up	U	NS	Ref. 20
G191167	Main Steam Drains	1-1/2,2-1/2 & 3-MSD-3	MSD Header in Stm Tunnel to 3-MS-3 in Torus Area between MS-77, -79, & -78	Steam/ Condensate	540	CS-5	Start-Up	U	NS	Ref. 20, Note 8
G191167	Main Steam Drains	3-MSD-4	MSD drain header D.S. of V2-79 Torus Area & Htr. Bay to condenser nozzle 45.	Steam/ Condensate	540	CS-5	Intermittent		SNM/SSB	SB Locations No. 4 & No. 5 Note 8.
G191167	Main Steam Drains	3-MSD-5	MSD drain header to CRW (N.C. line)	Steam/ Condensate	540	CS-5	Normally Closed	U	NS	Note 8
G191167	Main Steam Drains	6-MSD-10	MSD drip leg MS-1-1A	Steam/ Condensate	540	CS-5	Intermittent		SNM	Note 8
G191167	Main Steam Drains	1,2,2-1/2-MSD-11	From 3" MSD-4 thru ST-60-3 to tee with line 2-1/2-MSD-12	Steam/ Condensate	540	CS-5	Intermittent		SSB	SB Location No. 2, Note 8
G191167	Main Steam Drains	1,2-1/2-MSD-12	MSD around ST-60-3 thru LCV-143 to line 3-MSD-4	Steam/ Condensate	540	CS-5	Intermittent		SSB	SB Location No. 3, Note 8
G191167	Main Steam Drains	2-MSD-1	MSD from 6"MSD-10 drip leg to 2-1/2"MSD-3	Steam/ Condensate	540	CS-5	Intermittent		SSB	Note 8
G191167	Main Steam Drains	2", 1" -MSD	MSD piping immediately downstream of V60-24	Steam/ Condensate	540	A335-P11	Intermittent		NS	Note 8

Vermont Yankee Piping Flow Accelerated Corrosion Inspection Program – FAC Susceptibility Review

TABLE 2: Summary of Line by Line FAC Susceptibility Screening

Drawing No.	System	Line No(s).	Description	Fluid	Oper. Temp (F)	Material	Flow at Full Power Operation	Exclusion (Note 1)	Susceptibility Classification (Note 2)	Notes
G191167	Main Steam Drains	1-MSD	MSD from HPCI & RCIC Stm Supply in Drywell to 3-MSD-2 (US of V23-15 & V23-15)	Steam/ Condensate	540	CS-5	Start-Up	U	NS	Note 8
G191167	Main Steam Drains	2-MSD	MSD from 18-MS-7A to D in Drywell to 3-MSD-2	Steam/ Condensate	540	CS-5	Start-Up	U	NS	Note 8
G191167	Main Steam Drains	1- MSD	MSD MS-79 bypass (open thru orificed valve MS-33)	Steam/ Condensate	540	CS-5	Continuous		SSB	SB Location No.1, Note 8
G191167	Main Steam Drains	1-MSD	MSD from HPCI/ RCIC Stm. Supply outside Drywell to 2"MSD-1 (US of V23-16 & V23-16)	Steam/ Condensate	540	CS-5	Static - N.C. Valve	U	NS	Note 8
G191167	Rx Recirc.	12,22,28-PLR.	Rx Recirculation Piping in Drywell.	Water	540	SA316L	Continuous	M	NS	
G191167	Feedwater	16-FDW-14/15	FDW in Turb. Bldg. & Stm. Tunnel up to V2-96B & -27B Turb.	Water	392	CS-5	Continuous		SMC	Ref.20
G191167	Feedwater	16-FDW-16/17	FDW in Stm. Tunnel & Drywell up to V2-29A/B.	Water	392	CS-5	Continuous		SMC	Ref.20
G191167	Feedwater	16,10-FDW-18 to -FDW-21	FDW in Drywell from V2-29A/B to Reactor.	Water	392	CS-5	Continuous		SMC	Ref.20
G191167	Rx Safety Relief	10-SRV -15A to -15D	SRV in Drywell & Torus	Steam	<540	CS-2	No Flow (Relief line)	U	NS	
G191167	Rx. Water Clean Up	2-CUW	Rx Btm. Head Drain (N-15) to SS weld at bottom of CRDs	Water	<540	CS	Continuous		SSB	
G191167	Rx. Water Clean Up	2-CUW	Rx Btm. Head Drain SS weld at bottom of CRDs to V2-99	Water	<540	SS	Continuous	M	NS	
G191167	Rx. Water Clean Up	2-CUW-19	Rx Btm. Head Drain V2-99 to 4" CUW-18	Water	<540	SS	Continuous	M	NS	
G191167	Rx. Water Clean Up	4-CUW-18	CUW from RHR to V12-16	Water	<540	SS	Static N.C. Valve	M	NS	
G191167	Rx. Water Clean Up	2-CUW	Rx Btm. Head Drain DS of Valve V2-46 to floor drain	Water	<540	CS	Static N.C. Valve	U	NS	
G191167	RV Top Head Vent	1", 2 "	Vent Line N-7 to FCV-2-17, and Rx Vessel Instrument.	Steam	540	SS	Static	M	NS	
G191167	RV Top Head Vent	2 "	Vent Line N-7 to 18"MS-7C	Steam	540	SS	Continuous	M	NS	

Vermont Yankee Piping Flow Accelerated Corrosion Inspection Program – FAC Susceptibility Review

TABLE 2: Summary of Line by Line FAC Susceptibility Screening

Drawing No.	System	Line No(s).	Description	Fluid	Oper. Temp (F)	Material	Flow at Full Power Operation	Exclusion (Note 1)	Susceptibility Classification (Note 2)	Notes
G191167	RV Top Head Vent	1", 2"	Drain Line from FCV-2-18 and FCV-2-21 to Drywell Equipment Sump	Water/ Steam	<540	CS	Intermittent		SSB	
G191167	RV Flange Leakoff	½", 1"	RV Flange High Pressure leakoff N-13 to LCV-2-21	Steam/ Condensate	<540	SS	Intermittent	M	NS	
G191167	RV Flange Leakoff	½", 1"	RV Flange Low Pressure leakoff N-14 (capped line)	Steam/ Condensate	<540	CS	Static	U	NS	
G191168	Core Spray	12-CS-1A/B 10-CS-2A/B 8-CS-3A/B 8-CS-4A/B(partial)	Core Spray from Torus to 6 inches beyond valves CS 12A/B	Water	<175 <175 <575 <575	CS-1 CS-2 CS-5 CS-5	ECCS	U,T	NS	
G191168	Core Spray	8-CS-4A/B(partial)	Core Spray from beyond valves CS 12A/B to Rx.	Water	<575	S.S.	ECCS	U,M,T	NS	
G191168	Core Spray	1-1/2-CS-8A/8B 3-CS-5A/5B	SRV-20A/B suction & disch. to Rx. Bldg. floor sumps.	Water	<175	CS-2 CS-1	ECCS	U,T	NS	
G191168	Core Spray	8-CS-6A/6B	Core Spray full flow test line to 12-RHR-17/18 & Torus	Water	<175	CS-2	ECCS	U,T	NS	
G191168	Core Spray	8-CS-6A/6B	Core Spray full flow test line DS of RO 42A and 42B	Water	<175	CS-2	ECCS	U,T*	SNM*	Note 9
G191168	Core Spray	3-CS-7A to 7D	Core Spray connect. to RHR Normally Closed Valves CS-16A/B	Water	<175	CS-2	Static	U,T	NS	
G191168	Core Spray	3-CS-11A/11B	CS Pump Min Flow Lines to 12-RHR-17/18 & Torus	Water	<175	CS-2	ECCS	U,T	NS	
G191168	Core Spray	3-CS-11A/11B	CS Pump Min Flow Lines DS of R.O. 37A and 37B	Water	<175	CS-2	ECCS	U,T*	SMN*	Note 9
G191168	Core Spray	2-CS-9A/9B	Core Spray Pump Min Flow Line RO bypass N.C. valve CS-27A /27B.	Water	<175	CS-2	ECCS	U	NS	
G191168	Core Spray	2-CS-10A/10B	Core Spray flushing line from CST. N.C. valve CS-21A /2B.	Water	<175	CS-2	ECCS	U	NS	
G191168	Core Spray	1-CS-12A/12B	1 inch line to core dp above core plate instruments.	Water	<575	SS-6	ECCS	U,M	NS	
G191168	Core Spray	1-CS-13A/13B	1 inch line pressurizing line from Condensate.	Water	<175	CS-2	ECCS	U	NS	
G191168	Condensate Storage	12-CST4 12-CST-27	12 inch line from CST. N.C. valves CS-8A & CS-8B.	Water	<175	CS-2	ECCS	U	NS	

Vermont Yankee Piping Flow Accelerated Corrosion Inspection Program – FAC Susceptibility Review

TABLE 2: Summary of Line by Line FAC Susceptibility Screening

Drawing No.	System	Line No(s).	Description	Fluid	Oper. Temp (F)	Material	Flow at Full Power Operation	Exclusion (Note 1)	Susceptibility Classification (Note 2)	Notes
G191169 Sht.1 & 2	HPCI	14,16-HPCI-1	HPCI Pump suction from CST	Water	<175	CS-1	ECCS	U	NS	
G191169 Sht.1 & 2	HPCI	14-CST-1	HPCI Pump suction from CST	Water	<175	SS-1	ECCS	U,M	NS	
G191169 Sht.1 & 2	HPCI	10-HPCI-18 14-HPCI-2, 14-HPCI-15B/15A	HPCI Pump discharge to RX	Water	<175 <140 <400	CS-5	ECCS	U	NS	
G191169 Sht.1 & 2	HPCI	18,20,24-HPCI-3	HPCI Turbine Exhaust to Torus	Steam	<350	CS-1	ECCS	U	NS	
G191169 Sht.1 & 2	HPCI	16-HPCI-14A / 14B	HPCI Turbine Exhaust to Torus Rupture Disc.	Steam	<350	CS-1	ECCS	U	NS	
G191169 Sht.1 & 2	HPCI	16-HPCI-4	HPCI Pump suction from Torus	Water	<175	CS-1	ECCS	U	NS	
G191169 Sht.1 & 2	HPCI	10-HPCI-5	HPCI Test line to CST from 14-HPCI-15B to V-23-24	Water	<140	CS-5	ECCS	U	NS	
G191169 Sht.1 & 2	CST	10-CST-2	HPCI Test line to CST (from V23-24 to CST)	Water	<140	SS-1	ECCS	U,M	NS	
G191169 Sht.1 & 2	HPCI	4-HPCI-6 4-HPCI-7	HPCI Pump Min. Flow line	Water	<175	CS-5 CS-1	ECCS	U	NS	
G191169 Sht.1 & 2	HPCI	2-HPCI-8 2-HPCI-9 & -12	Coolant for HPCI Gland Seal Condenser (suction & disch.)	Water	<140 <175	CS-2 CS-1	ECCS	U	NS	
G191169 Sht.1 & 2	HPCI	2-HPCI-10 2-HPCI-11	Coolant for HPCI Lube Oil Cooler (suction & discharge)	Water	<140 <175	CS-1	ECCS	U	NS	
G191169 Sht.1 & 2	HPCI	2,4-HPCI-12	Gland Seal Condenser Coolant discharge back to HPCI pump suction	Water	<175	CS	ECCS	U	NS	
G191169 Sht.1 & 2	HPCI	3-HPCI-13	Gland Seal Exhauster Discharge to SBT	Gas / Water Vapor	<175	CS	ECCS	U	NS	
G191169 Sht.1 & 2	HPCI	2-HPCI-16	HPCI Turbine Exhaust Drain line to Torus	Stm./ Water	<375	CS	ECCS	U	NS	
G191169 Sht.1 & 2	HPCI	2-HPCI-17	HPCI Turbine Hotwell to HPCI Pump suction.	Water	<200	CS-1	ECCS	U	NS	
G191169 Sht.1 & 2	HPCI	2,3-HPCI-19	HPCI Turbine Exhaust to Torus Air Space Vacuum Breaker.	Air/N2/ Steam	<350	CS-1	ECCS	U	NS	
G191169 Sht.1 & 2	HPCI	1-HPCI	HPCI Turbine discharge drain to gland seal condenser.	Water	<175	CS-1	ECCS	U	NS	

Vermont Yankee Piping Flow Accelerated Corrosion Inspection Program – FAC Susceptibility Review

TABLE 2: Summary of Line by Line FAC Susceptibility Screening

Drawing No.	System	Line No(s).	Description	Fluid	Oper. Temp (F)	Material	Flow at Full Power Operation	Exclusion (Note 1)	Susceptibility Classification (Note 2)	Notes
G191169 Sht.1 & 2	HPCI	1-HPCI	From HPCI gland seal condenser to hotwell.	Water	<175	CS-1	ECCS	U	NS	
G191169 Sht.1 & 2	HPCI	1-HPCI	1 inch line pressurizing line from Condensate.	Water	<175	CS-1	ECCS	U	NS	
G191169 Sht.1 & 2	HPCI	1-HPCI	1" vent line between rupture discs on 14-HPCI-14B.	Air	<175	CS-1	No Flow	U	NS	
G191169 Sht.1 & 2	HPCI	1-HPCI	To floor drain through LCV-39 & LCV-40	Water	<200	CS-1	No Flow	U	NS	
G191169 Sht.1 & 2	Main Steam	10-MS 4A/4B	MS Supply from Rx to V-23-14	Steam	540	CS-5	Static/ECCS	U	NS	
G191169 Sht.1 & 2	Main Steam Drains	1-MSD	HPCI Turb. Casing Drain to Exhaust Steam Drain Pot.	Steam	540	CS-1	ECCS	U	NS	
G191169 Sht.1 & 2	Main Steam Drains	1, 3/4-MSD (HPCI Skid)	HPCI Turb. Ring Drain to Exhaust Steam Drain Pot.	Steam	540	CS-5	ECCS	U	NS	
G191169 Sht.1 & 2	Main Steam Drains	3/4-MSD(HPCI Skid)	HPCI Turb. Chest Drain to Exhaust Steam Drain Pot.	Steam	540	CS-5	ECCS	U	NS	
G191169 Sht.1 & 2	Main Steam Drains	3/4-MSD (HPCI Skid)	HPCI Turb. Seat Drain to Exhaust Steam Drain Pot.	Steam	540	CS-5	ECCS	U	NS	
G191169 Sht.1 & 2	Main Steam Drains	1-MSD (HPCI Skid)	HPCI Turb. Shaft Seal L.P.Leakoff to Gland Seal Condenser .	Steam	540	CS-5	ECCS	U	NS	
G191169 Sht.1 & 2	Main Steam Drains	1-MSD Two Lines (HPCI Skid)	HPCI Turb. Control Valve Stem Leakoff to Gland Seal Condenser .	Steam	540	CS-5	ECCS	U	NS	
G191169 Sht.1 & 2	Main Steam Drains	1-MSD HPCI Skid	HPCI Turb. Stop Valve Stem Leakoff to Gland Seal Condenser .	Steam	540	CS-5	ECCS	U	NS	
G191169 Sht.1 & 2	Main Steam Drains	1-MSD	HPCI MS Drain Pot to HPCI LCV-53 to intersection of line D.S. of ST-3.	Condensate	540	CS-5	Continuous		SSB	SB Location No. 122, Note 8
G191169 Sht.1 & 2	Main Steam Drains	1-MSD	HPCI MS Drain Pot to ST-3 to intersection of line D.S. of HPCI LCV-53	Condensate	540	CS-5	Continuous		SSB	SB Location No. 123, Note 8
G191169 Sht.1 & 2	Main Steam Drains	1-MSD	HPCI MS Drain piping US & DS of HPCI FCV-42	Condensate	540	CS-5	Continuous		SSB	SB Location No. 124, Note 8

Vermont Yankee Piping Flow Accelerated Corrosion Inspection Program – FAC Susceptibility Review

TABLE 2: Summary of Line by Line FAC Susceptibility Screening

Drawing No.	System	Line No(s).	Description	Fluid	Oper. Temp (F)	Material	Flow at Full Power Operation	Exclusion (Note 1)	Susceptibility Classification (Note 2)	Notes
G191169 Sht.1 & 2	Main Steam Drains	1', 2"-MSD	HPCI MS Drain piping & fittings D.S. of HPCI FCV-43 to Condenser @ Conn. 56	Condensate	540	A335-P11	Continuous	M	NS	SB Locations No. 31 & 33 (Note 4), Note 8
G191170	Control Rod Drive	4" & 3" CRD-1A/1B	CRD Pumps P-38-1A/B Suction -	Water	<150	CS-1	Continuous	T	NS	
G191170	Control Rod Drive	2-1/2-CRD-2	CRD return to RWCU Return	Water	<150	CS-5	Continuous	T	NS	
G191170	Control Rod Drive	2-1/2 & 3-CRD-3	Old return line to Rx through Pen X-36. Cut & capped.	Water	<150	SS-5	No Flow	M/U	NS	
G191170	Control Rod Drive	10-CRD-4 & 4A 6-CRD-5 & 5A 6-CRD-6 & 6A 6-CRD-7 & 8	Scram Discharge Volume & Headers	Water	<280	CS-4	Post Scram	U	NS	
G191170	Control Rod Drive	2-1/2-CRD-9	CRD Return to RWCU Return DS of check valve CUW-181	Water	<575	CS-5	Continuous		SMC	
G191170	Control Rod Drive	2-CRD	CRD Pump Discharge to Filters F-16-1A/1B	Water	<150	CS-5	Continuous	T	NS	
G191170	Control Rod Drive	2-CRD	Filters F-16-1A/1B to FCV-19A/B	Water	<150	SS-5	Continuous	M,T	NS	
G191170	Control Rod Drive	1 & 1-1/2CRD	FCV-19A/B to PCV-20 & PCV-22 to 2-1/2 CRD-2	Water	<280	SS-5	Continuous	M	NS	
G191170	Control Rod Drive	1 CRD	Drive Water & Cooling Water to HCUs	Water	<280	SS-5	Continuous	M	NS	
G191170	Control Rod Drive	2-CRD	Charging Water to HCUs	Water	<280	SS-5	Continuous	M	NS	
G191170	Control Rod Drive	1-CRD	Exhaust Water from HCUs to 2-1/2-CRD-2	Water	<280	CS	During Rod Movement	U	NS	
G191170	Control Rod Drive	1 & 3/4-CRD	Insert & Withdraw lines (89 Total)	Water	<280	SS	Continuous	M	NS	
G191170	Control Rod Drive	1 & 1-1/2-CRD	CRD Pump Min Flow to 10-CST-2	Water	<150	CS	Continuous	T, U	NS	
G191170	Control Rod Drive	1-CRD	CRD Pump Min Flow DS of R.O.s 24A/B & 25A/B	Water	<150	CS	Continuous	T,U*	SSB*	Note 9
G191171	Standby Liquid Control	All	SLC Piping	Borated Water		SS	Static	M,U	NS	
G191172	RHR	20-RHR-1A to 1D	RHR Pump Suction from Recirc.	Water	<300	CS-1	Shutdown Cooling	U	NS	

Vermont Yankee Piping Flow Accelerated Corrosion Inspection Program – FAC Susceptibility Review

TABLE 2: Summary of Line by Line FAC Susceptibility Screening

Drawing No.	System	Line No(s).	Description	Fluid	Oper. Temp (F)	Material	Flow at Full Power Operation	Exclusion (Note 1)	Susceptibility Classification (Note 2)	Notes
G191172	RHR	20,24,26-RHR-2A to 2D	RHR Pump Suction from Torus	Water	<300	CS-1	ECCS & Torus Cooling	U	NS	
G191172	RHR	20,24,26-RHR-2A to 2D	RHR Pump Discharge to RHR Hx.	Water	<300	CS-2	ECCS & Torus Cooling	U	NS	
G191172	RHR	4-RHR-4,4A,4B	RHR to Rad Waste	Water	<300	CS-1/2	Normally Closed	U	NS	
G191172	RHR	16-RHR-5A/5B 20,24-RHR-6 & 7	RHR Hx. Discharge & Bypass	Water	<300	CS-2	Shutdown & Torus Cooling	U	NS	
G191172	RHR	20-RHR-8	Train A to B cross connection Normally Closed.	Water	<262	CS-2	No Flow	U	NS	
G191172	RHR	12,14,16-RHR-9	Containment Spray Lower Header	Water	<262	CS-2	LOCA	U	NS	
G191172	RHR	12,14-RHR-14	Containment Spray Upper Header	Water	<300	CS-2	LOCA	U	NS	
G191172	RHR	4-RHR-11 & 16 4-RHR-21 & 22	RHR Hx. to Torus (Torus Spray)	Water	<300	CS-1	LOCA	U	NS	
G191172	RHR	12-RHR-10 & 15 12-RHR-12 & 17 12-RHR-20 & 23	RHR Hx. to Torus (Torus Cooling)	Water	<300	CS-2	Shutdown & Torus Cooling	U	NS	
G191172	RHR	3,4-RHR-13A to D 4-RHR-24A & 24B	RHR Pump Min-flow lines	Water	<300	CS-2	Shutdown & Torus Cooling	U	NS	
G191172	RHR	24-RHR-6 & 28, 24-RHR-7 & 29	LPCI & Shut Down Cooling to RX	Water	<300 <575	CS-2	ECCS, Shut Down Cooling	U	NS	
G191172	RHR	24-RHR-30, & -31	LPCI & Shut Down Cooling to RX	Water	<575	SS-6	ECCS, Shut Down Cooling	M	NS	
G191172	RHR	4-RHR-26A - 26D 4-RHR-27A - 27D 4-RHR-44A - 44D 4-RHR-45A - 45D 4-RHR-42A - 42D 4-RHR-43A - 43B	Drain Lines to Rx floor drain Sump or to Rad Waste	Water	<300	CS-1	N.C. Drain	U	NS	
G191172	RHR	20-RHR-32	RHR suction from Recirc. Loop in Drywell	Water	<575	SS-6	Shut Down Cooling	M	NS	

Vermont Yankee Piping Flow Accelerated Corrosion Inspection Program – FAC Susceptibility Review

TABLE 2: Summary of Line by Line FAC Susceptibility Screening

Drawing No.	System	Line No(s).	Description	Fluid	Oper. Temp (F)	Material	Flow at Full Power Operation	Exclusion (Note 1)	Susceptibility Classification (Note 2)	Notes
G191172	RHR	20-RHR-33	RHR suction from Recirc. In Drywell at V-18 to V-17	Water	<575	CS-5	Shut Down Cooling	U	NS	
G191172	RHR	4-RHR-35A & 35B 4-RHR-36A & 36B 4-RHR-37A & 37B 4-RHR-38A - 38C	Filling & Flushing Lines from CST	Water	<300	CS-2 CS-1	Normally Closed	U	NS	
G191172	RHR	8-RHR-39	From Fuel Pool Cooling System to RHR pump suction	Water	<150	CS-1	Normally Closed	U,T	NS	
G191172	RHR	8-RHR-40	To Fuel Pool from RHR Hx. A	Water	<262	CS-2	Normally Closed	U	NS	
G191172	RHR	10-RHR-41A/B	Tie in from Service Water	Water	<262	CS-2	Normally Closed	U	NS	
G191173 Shts. 1 & 2	FPC	All	FPC & Enhanced FPC	Water	<175	CS & SS		T	NS	
G191174 Sht.1 & 2	RCIC	4-RCIC-1 4-RCIC-8B/8A	RCIC Pump to 16-FDW-15	Water	<175 <450	CS-5	ECCS	U	NS	
G191174 Sht.1 & 2	RCIC	4-RCIC-2	RCIC Flow Test Line to 10-HPCI-5 & CST	Water	<140	CS-5	ECCS	U,T	NS	
G191174 Sht.1 & 2	RCIC	6-RCIC-3	RCIC Pump Suction from Torus	Water	<175	CS-1	ECCS	U	NS	
G191174 Sht.1 & 2	RCIC	6-RCIC-7	RCIC Pump Suction from CST	Water	<175	CS-1	ECCS	U	NS	
G191174 Sht.1 & 2	CST	6-CST-3	RCIC Pump Suction from CST	Water	<325	SS-1	ECCS	M	NS	
G191174 Sht.1 & 2	RCIC	8-RCIC-4	RCIC Turbine Exhaust to Torus	Steam	<325	CS-1	ECCS	U	NS	
G191174 Sht.1 & 2	RCIC	8-RCIC-5A/5B	RCIC Turbine Exhaust to Torus Rupture Disk	Steam	<325	CS-1	ECCS / Static	U	NS	
G191174 Sht.1 & 2	RCIC	3-RCIC-6	RCIC Turbine Exhaust Drip Leg	Steam	<325	CS-1	ECCS	U	NS	
G191174 Sht.1 & 2	RCIC	2-RCIC-9 2-RCIC-10	RCIC Pump Min Flow Line to 12-RHR-17	Water	<175	CS-5 CS-1	ECCS	U,T	NS	
G191174 Sht.1 & 2	RCIC	2-RCIC-11 2-RCIC-12	RCIC Pump Disch. to L.O. Cooler & Barometric Condenser	Water	<175	CS-5 CS-1	ECCS	U,T	NS	
G191174 Sht.1 & 2	RCIC	2-RCIC-13	RCIC Vacuum Pump Disch. to Torus.	Gas/ C'ndens	<175	CS-1	ECCS	U,T	NS	

Vermont Yankee Piping Flow Accelerated Corrosion Inspection Program – FAC Susceptibility Review

TABLE 2: Summary of Line by Line FAC Susceptibility Screening

Drawing No.	System	Line No(s).	Description	Fluid	Oper. Temp (F)	Material	Flow at Full Power Operation	Exclusion (Note 1)	Susceptibility Classification (Note 2)	Notes
G191174 Sht.1 & 2	RCIC	1-1/4-RCIC-13	RCIC Vacuum Pump Disch. To Barometric condenser (through valve PCV-36).	Gas/ C'ndens	<175	CS-1	ECCS	U,T	NS	
G191174 Sht.1 & 2	RCIC	2-RCIC-14	RCIC Cond. Pump Disch. to RCIC Pump Suction.	Water	<175	CS-1	ECCS	U,T	NS	
G191174 Sht.1 & 2	RCIC	1,2-RCIC-16	RCIC Turbine Exhaust to Torus Air Space Vacuum Breaker.	Steam/ Vapor	<325	CS-1	ECCS	U	NS	
G191174 Sht.1 & 2	RCIC	1-RCIC	1 inch vent line between rupture discs on 8-RCIC-5B.	Air	<325	CS-1	No Flow	NW	NS	
G191174 Sht.1 & 2	RCIC	1-RCIC	To floor drain through LCV-12 & LCV-13	Water	<325	CS-1	No Flow	U	NS	
G191174 Sht.1 & 2	Main Steam	3-MS-5A 2,3-MS-5B	MS Supply from Rx to V-131& V-1	Steam	540	CS-5	Static	U	NS	
G191174 Sht.1 & 2	Main Steam Drains	1-MSD (Skid Piping)	RCIC Turbine Seal Drains to Barometric Condenser	C'ndens	540	CS-1	ECCS	U	NS	
G191174 Sht.1 & 2	Main Steam Drains	1-MSD (Skid Piping)	RCIC Turbine Casing Drain to Turb. Exhaust Drip Leg	C'ndens	<325	CS-1	ECCS	U	NS	
G191174 Sht.1 & 2	Main Steam Drains	1-MSD -2 lines (Skid Piping)	RCIC Turbine Trip/Throttle & Governing valves Seal leakoff lines to barometric condenser	C'ndens	<540	CS-5	ECCS	U	NS	
G191174 Sht.1 & 2	Main Steam Drains	3/4-MSD (Skid Piping)	RCIC Turbine drain from Trip/Throttle to turbine	C'ndens	<540	CS-1	ECCS	U	NS	
G191174 Sht.1 & 2	Main Steam Drains	1/2-MSD -2 lines (Skid Piping)	RCIC Turbine Trip/Throttle & Governing valves seat drains to Turb. Exhaust Drip Leg	C'ndens	<540	CS-1	ECCS	U	NS	
G191174 Sht.1 & 2	Main Steam Drains	1-MSD	Drain from Turbine Exhaust dripleg US & DS of ST13-7 to barometric condenser	C'ndens	<325	CS-1	ECCS	U	NS	
G191174 Sht.1 & 2	Main Steam Drains	¾, 1-MSD	RCIC MS Drain Pot to RCIC LCV-32 to intersection of line D.S. of ST-6.	C'ndens	<540	CS-5	Continuous		SSB	SB Location No.125, Note.8
G191174 Sht.1 & 2	Main Steam Drains	1-MSD	RCIC MS Drain Pot to ST-6 to intersection of line D.S. of HPCI LCV-32	C'ndens	<540	CS-5	Continuous		SSB	SB Location No.126, Note 8
G191174 Sht.1 & 2	Main Steam Drains	1-MSD	RCIC MS Drain piping US & DS of RCIC FCV-34	C'ndens	<540	CS-5	Continuous		SSB	SB Location No.127, Note 8

Vermont Yankee Piping Flow Accelerated Corrosion Inspection Program – FAC Susceptibility Review

TABLE 2: Summary of Line by Line FAC Susceptibility Screening

Drawing No.	System	Line No(s).	Description	Fluid	Oper. Temp (F)	Material	Flow at Full Power Operation	Exclusion (Note 1)	Susceptibility Classification (Note 2)	Notes
G191174 Sht.1 & 2	Main Steam Drains	1-MSD	HPCI MS Drain piping & fittings D.S. of RCIC FCV-35	C'ndens	<540	A335 P-11	Continuous	M	NS	SB Location No.32 (Notes 4 & 8)
G191176 Sht.1	Condensate Transfer	14-CST-1 10-CST-2 6-CST 3	CST Supply to HPCI & RCIC pumps and combined test line return	Water	<175	SS-1	ECCS	M,U	NS	
G191176 Sht.1	Condensate Transfer	12-CST-4	CST Supply to CS through N.C. Valves V14-8A & 8B	Water	<175	SS-1/	No Flow	M,U,T	NS	
G191176 Sht.1	Condensate Transfer	4-CST-5	Supply to CST from Rad Waste	Water	<175	SS-1	Intermittent	M,T	NS	
G191176 Sht.1	Condensate Transfer	6-CST-6	From Fuel Pool (6-FPC-21) Normally Closed.	Water	<175	SS-1	Intermittent	M,T	NS	
G191176 Sht.1	Condensate Transfer	6-CST-6	From Fuel Pool (6-FPC-21) Normally Closed.	Water	<175	SS-1	Intermittent	M,T	NS	
G191176 Sht.1	Condensate Transfer	CST-7 through CST-34	Misc. transfer lines	Water	<175	CS-1	Intermittent	O2, T	NS	
G191176 Sht.1	House Heating Steam	4-HS-1	HHS to CST and DWST Steam Heating Coils	Steam	<365	CS-1	Winter		SNM	
G191176 Sht.1	House Heating Steam	2, 2-1/2" HS-1,	HHS to CST Steam Heating Coil	Steam	<365	CS-1	Winter		SSB	
G191176 Sht.1	House Heating Steam		CST Steam Heating Coil	Steam	<365	Alum. 6061	Winter	M	NS	VY Dwg. No. 5920-3912
G191176 Sht.1	House Heating Steam	1-1/2,2-HSCR	HHS Condensate return from CST Steam Heating Coil	Condensate	<365	CS-1	Winter		SSB	
G191176 Sht. 2	Demin. Water	DW-1 to DW-3, DW-5 to DW-9, DW-10 to DW-11	Various Demineralized Water Transfer Lines	Water	<175	SS-1	Intermittent	T	NS	
G191176 Sht. 2	Demin. Water	DW-10	Demin. Water Storage Tank (DWST) Overflow	Water	<175	SS-1	No Flow	O2, T	NS	
G191176 Sht. 2	House Heating Steam	2" & SM -HS	HHS to DWST Steam Heating Coil	Steam	<365	CS-1	Winter		SSB	
G191176 Sht.1	House Heating Steam		DWST Steam Heating Coil	Steam	<365	Alum. 6061	Winter	M	NS	VY Dwg. No. 5920-3913
G191176 Sht. 2	House Heating Steam	1-1/2,2-HSCR	HHS Condensate return from CST Steam Heating Coil	Condensate	<365	CS-1	Winter		SSB	
G191177 Shts. 1 - 4	Rad Waste Systems	All	Radwaste System Piping	Water/ Air	<175	CS-1	Intermittent	T	NS	

Vermont Yankee Piping Flow Accelerated Corrosion Inspection Program – FAC Susceptibility Review

TABLE 2: Summary of Line by Line FAC Susceptibility Screening

Drawing No.	System	Line No(s).	Description	Fluid	Oper. Temp (F)	Material	Flow at Full Power Operation	Exclusion (Note 1)	Susceptibility Classification (Note 2)	Notes
G191178 Sht.1	Rx. Water Clean Up	4-CUW-18 4-CUW-1,1A,1B 3,4-CUW-2A,2B,3	Letdown from Rx to RWCU pumps to Regen Hx. to Non-Regen. Hx.	Water	575	SS-6	Continuous	M	NS	
G191178 Sht.1	Rx. Water Clean Up	3,4-CUW-4A & 4B	Letdown Non - Regen Hx. to Cleanup Filter Demin.	Water	150	SS-5	Continuous	M	NS	
G191178 Sht.1	Rx. Water Clean Up	3,4-CUW-5A & 5B	Return from Cleanup Filter Demin to Regen. Hx.	Water	150	SS-5	Continuous	M	NS	
G191178 Sht.1	Rx. Water Clean Up	4-CUW-6 4-CUW-54	Return from Regen. Hx. to line 4-CUW-55	Water	<575	SS-6	Continuous	M	NS	
G191178 Sht.1	Rx. Water Clean Up	4-CUW-55	Return from line 4-CUW-54 to FDW System	Water	450/ 575	CS-5	Continuous	O2	NS	Note 3
G191178 Sht.1	Rx. Water Clean Up	4-CUW-7 4-CUW-8	Return from Clean-up Demin. To main condenser (Conn. 66)	Water	150	CS-5 CS-1	Continuous	T	NS	
G191178 Sht.1	Rx. Water Clean Up	4-CUW-9 4-CUW-10	Clean-up Demin drain to Rad Waste.	Water	150	CS-5 CS-1	Normally Closed	U	NS	
G191178 Sht.1	Rx. Water Clean Up	2-CUW-19	Rx Btm. Head Drain V2-99 to 4" CUW-18	Water	<540	SS	Continuous	M	NS	See list for G191167
G191178 Sht.2	Rx Water Clean Up – Demineralizer	2,3-CUW-11 2-CUW-12A - 12B 2-CUW-13A - 13B 3-1/2-CUW-14 2,3-CUW-14 -15 2,3-CUW-16 -17	Clean-up Filter Demin. Pre-coat pump associated piping.	Water	150	CS-5 CS-1	Continuous	T	NS	
G191178 Sht.2	Rx Water Clean Up - Demineralizer	1 to 4 inch piping Line Nos. 20 to 53 and from 56 to 62	Remaining lines on the Clean-up Filter Demin / Phase separator associated piping.	Water	150	CS / SS	Continuous	T	NS	
G191237 Sht. 2	Chilled Water	3-CHS & 3-CHR	SAC-1 & SAC -2 Chilled Water Supply & Return Lines	Water	<175	CS	Continuous	T	NS	
G191237 Sht. 2	SCH-1	7/8 & 1-3/8 CU	Chiller SCH-1 Condenser Piping to SACC-1A/1B	Refrigerant	<175	CU	Continuous	NW	NS	
G191238	SW & RBCCW	1,2-1/2,& 6 SW & RCW	RRU Supply & Return Piping	Water	<175	CS/CU	Continuous	O2, T	NS	

Vermont Yankee Piping Flow Accelerated Corrosion Inspection Program – FAC Susceptibility Review

TABLE 2: Summary of Line by Line FAC Susceptibility Screening

Drawing No.	System	Line No(s).	Description	Fluid	Oper. Temp (F)	Material	Flow at Full Power Operation	Exclusion (Note 1)	Susceptibility Classification (Note 2)	Notes
G191254	House Heating Stm	All HHS	HHS Supply Piping to SUH & Bldg. Heaters	Steam	<365	CS	Winter		SNM/SSB	
G191254	House Heating Stm	HSCR piping US & DS of Steam Traps	HHS Condensate Return Lines from SUH & Bldg. Heaters	Steam, Condensate	<365	CS	Winter		SSB	Possible Steam Trap Blow-by
G191254	House Heating Stm	HSCR piping DS/ remote from Steam Traps	HHS Condensate Return Lines from SUH & Bldg. Heaters	Condensate	<175	CS	Winter	T	NS	
G191267 Shts.1 & 2	Nuclear Boiler Vessel Instrument.	All	Reactor Instrument Tubing and Piping.	Water	540	SS	Continuous	M	NS	
G191274	Condensate Demineralizer	CD-1A through CD-42E	Condensate Demineralizer & Backwash Piping	Water.	107.1	CS	Continuous	T	NS	
G191280	Potable Water	All	Plant Potable Water piping	Water	<100	B88/ PVC	Continuous	T	NS	
VY-E-75-002	Containment Atmosphere Dilution	All	Containment Atmosphere Dilution Piping	Air/ N2	<200	CS	Continuous	NW	NS	
VY-E-75-001 33600-A-202 33600-A-207	Advanced Off Gas (AOG)	12-OGE-100-G1 12-OGE-101A-G1 12-OGE-102A-G1 12-OGE-103A-J1	Off Gas Process Line from OG-557to Steam Mixing Tee ED-100-1A to HE-101-1A	Gas/ Steam	273 to 655	CS	Continuous		SNM	
		Remaining AOG Process Lines except steam supply	Remaining AOG Process Lines	Gas	<175	CS	Continuous	T	NS	
	Steam Supply	4-MS-191A-D3	Steam to MS-100-1A	Steam	365	CS	Continuous		SNM	
		1-1/2-MS-136A-D3	Steam to HE-100-1A	Steam	365	CS	Continuous		SSB	
		2-MS-138A-G1	Steam to ED-100-1A Mixing Tee	Steam	365	CS	Continuous		SSB	
	Steam / Condensate Return Lines	½", 1", 2" CNP	Condensate Return Lines to TK-104-1A	Condensate	<365	CS	Continuous		SSB	
		2" CNP-164-D3, 2" CNP-184-D3	Condensate Return TK-104-1A/P-151-1A/B to Cond. B	Condensate	<365	CS	Continuous		SSB	
	Cooling from Condensate System	8"WCS , 8"WCR	HE-101-1A Condenser Cooling Supply and Return	Water	<175	CS	Continuous	T	NS	

Vermont Yankee Piping Flow Accelerated Corrosion Inspection Program – FAC Susceptibility Review

TABLE 2: Summary of Line by Line FAC Susceptibility Screening

Drawing No.	System	Line No(s).	Description	Fluid	Oper. Temp (F)	Material	Flow at Full Power Operation	Exclusion (Note 1)	Susceptibility Classification (Note 2)	Notes
VY-E-75-001 33600-A-202 33600-A-208	Advanced Off Gas (AOG)	12-OGE-100-G1 12-OGE-101A-G1 12-OGE-102A-G1 12-OGE-103A-J1	Off Gas Process Line from OG-557 to Steam Mixing Tee ED-100-1B to HE-101-1B	Gas/ Steam	273 to 655	CS	Continuous		SNM	
VY-E-75-001 33600-A-202 33600-A-208	Advanced Off Gas (AOG)	Remaining AOG Process Lines except steam supply	Remaining AOG Process Lines	Gas	<175	CS	Continuous	T	NS	
	Steam Supply	4-MS-191B-D3	Steam to MS-100-1B	Steam	365	CS	Continuous		SNM	
		1½" -MS-136B-D3	Steam to HE-100-1B	Steam	365	CS	Continuous		SSB	
		2-MS-138B-G1	Steam to ED-100-1B Mixing Tee	Steam	365	CS	Continuous		SSB	
	Cooling from Condensate System.	8"WCS	Condenser Cooling Supply to HE-101-1B and HE -101-1A	Water	<175	CS	Continuous	T	NS	
	Steam / Condensate Return Lines	½", 1",2" CNP	Condensate Return Lines to TK-104-1A	Condensate	<365	CS	Continuous		SSB	
VY-E-75-001 33600-A-202 33600-A-209 33600-A-210	AOG Off Gas Drying A & B	All	Off Gas Drying Trains A & B	Gas		CS	Continuous	NW	NS	
	Steam / Condensate Return Lines	1" CNP & smaller	Condensate Return Lines to TK-104-1A	Condensate	<365	CS	Continuous		SSB	
VY-E-75-001 33600-A-202 33600-A-211	AOG Charcoal Off Gas System	All	Charcoal Beds	Gas		CS	Continuous	NW	NS	
	Condensate Return Lines	½", 1",2" CNP	Closed Loop Condensate Return Lines	Water	<175	CS	Continuous	T	NS	
	Adsorber Bed Drains	1½" VRE-171-G1	Drain to Sample Collection Tank and to Cond, B	Water	<175	CS	Continuous	T	NS	
VY-E-75-001 33600-A-202 33600-A-213	AOG Chiller System	All	Water Chiller System Skid Piping.	Water/ Refrig.	<175	CS	Continuous	T,NW	NS	
33600-A-216	AOG Steam Reheat	3"-SH & Smaller	Supply Piping for 30Lb. Steam to Steam Reheat Coils	Steam	365	CS	Continuous		SSB	

Vermont Yankee Piping Flow Accelerated Corrosion Inspection Program – FAC Susceptibility Review

TABLE 2: Summary of Line by Line FAC Susceptibility Screening

Drawing No.	System	Line No(s).	Description	Fluid	Oper. Temp (F)	Material	Flow at Full Power Operation	Exclusion (Note 1)	Susceptibility Classification (Note 2)	Notes
33600-A-216	AOG Steam Reheat	2"-CNH & Smaller, 2" HSCR & Smaller	Condensate Return Piping from Steam Traps and Steam Reheat Coils .	Condensate	<365	CS	Continuous		SSB	
33600-A-217	AOG Steam Turbine Bldg.	4"-MS-137-D3	Supply Piping for 30Lb. Steam to Steam Reheat Coils	Steam	365	CS	Continuous		SSB	SB Location Nos. 73,74,75
33600-A-217	AOG Steam Turbine Bldg.	6"-SRV-7B	Relief Valve Disch to line 6"-SRV-7B	Steam	365	CS	No Flow	U	NS	
33600-A-217	AOG Steam Turbine Bldg.	¾"-HCN188-H1 ¾"-MS-189-D3 MS-113A-1A MS-115A-1A	Drains to 3"-MSD-4 from steam traps at pressure reducing station.	Condensate	<540	A335-P11	Continuous	M	NS	SB Locations 74,75,76,77 Replaced in 1998 (Note 4)
5920-1068	Instrument Air Dryer	All	Internal piping to Instrument Air Dryer	Air, Water Vapor			Continuous	NW	NS	
5920-0870	HPCI Turbine Oil Piping	All	HPCI Turbine Skid Oil Piping	Oil		CS	Intermittent (with turbine operation)	NW	NS	
5920-11015	Station Air Compressors	All	Internal piping for Station Air Compressors	Air, Water Vapor			Continuous	NW	NS	
5920-12598	Turbine Steam Seal	(GE) 10", 12" SSH	Turbine Steam Seal Supply Header (SSH)	Steam	225	CS	Continuous		SNM	
5920-12598	Turbine Steam Seal	(GE) 8" 1SSH1	HP Turbine N1 Packing to SSH	Steam	225	CS	Continuous		SNM	
5920-12598	Turbine Steam Seal	(GE) 6" 2SSH2	HP Turbine N2 Packing to SSH	Steam	225	CS	Continuous		SNM	
5920-12598	Turbine Steam Seal	(GE) 5" 1SSH3	SSH supply to LP Turbine N3 Packing	Steam	225	CS	Continuous		SNM	
5920-12598	Turbine Steam Seal	(GE) 8" SSH	Common SSH supply to LP Turbine N4 & N5 Packings	Steam	225	CS	Continuous		SNM	
5920-12598	Turbine Steam Seal	(GE) 5"1SSH4	SSH supply to LP Turbine N4 Packing	Steam	225	CS	Continuous		SNM	
5920-12598	Turbine Steam Seal	(GE) 5" 1SSH5	SSH supply to LP Turbine N5 Packing	Steam	225	CS	Continuous		SNM	
5920-12598	Turbine Steam Seal	(GE) 5" 1SSH6	SSH supply to LP Turbine N6 Packing	Steam	225	CS	Continuous		SNM	
5920-12598	Turbine Steam Seal	(GE) 2,3-1/2 2SPE1	From N1 Packing to SPE Header	Steam/ Water	195	CS	Continuous		SNM	

TABLE 2: Summary of Line by Line FAC Susceptibility Screening

Drawing No.	System	Line No(s).	Description	Fluid	Oper. Temp (F)	Material	Flow at Full Power Operation	Exclusion (Note 1)	Susceptibility Classification (Note 2)	Notes
5920-12598	Turbine Steam Seal	(GE) 4 3SPE2	From N2 Packing to SPE Header	Steam/Water	195	CS	Continuous		SNM	
5920-12598	Turbine Steam Seal	(GE) 6 2SPE3	From N3 Packing to SPE Header	Steam/Water	195	CS	Continuous		SNM	
5920-12598	Turbine Steam Seal	(GE) 6 2SPE4	From N4 Packing to 10" SPE common riser	Steam/Water	195	CS	Continuous		SNM	
5920-12598	Turbine Steam Seal	(GE) 6 2SPE5	From N5 Packing to 10" SPE common riser	Steam/Water	195	CS	Continuous		SNM	
5920-12598	Turbine Steam Seal	(GE) 10, SPE 6	Common riser from N4 & N5 Packings to SPE Header	Steam/Water	195	CS	Continuous		SNM	
5920-12598	Turbine Steam Seal	(GE) 6 2SPE6	From N6 Packing to SPE Header	Steam/Water	195	CS	Continuous		SNM	
5920-12598	Turbine Steam Seal	(GE) 8,10,16 SPE	Steam Packing Exhauster	Steam/Water	195	CS	Continuous		SNM	
5920-12598	Turbine Steam Seal	1-1/2" & 3" 1SLMSV	Stop Valve first seal leakoff lines to SSL	Steam	<540	CS	Continuous		SSB	SB Locations Nos. 78 to 82
5920-12598	Turbine Steam Seal	1" & 3" 2SLMSV	Stop Valve second seal leakoff lines to SPE	Steam	<540	CS	Continuous		SSB	SB Locations Nos. 88 to 90
5920-12598	Turbine Steam Seal	1-1/2" 1SCVL	Control Valve first seal leakoff to 36" Cross around	Steam	390	CS	Continuous		SSB	SB Locations Nos. 83 to 87
5920-12598	Turbine Steam Seal	2-1/2" 2SCVL	Control Valve second seal leakoff to SSH	Steam	320	CS	Continuous		SSB	SB Locations Nos. 91 to 95
5920-12598	Turbine Steam Seal	2" 3SCVL	Control Valve third seal leakoff to SPE	Steam	<320	CS	Continuous		SSB	
5920-12598	Turbine Steam Seal	1/2",2" 1SLBPV	Bypass Valve first seal leakoff to 36" Cross Around	Steam	390	CS	Continuous		SSB	SB Locations Nos. 96 to 106. See Note 11
5920-12598	Turbine Steam Seal	1",2-1/2" 2SLBPV	Bypass Valve second seal leakoff to SSH	Steam	320	CS	Continuous		SSB	SB Locations Nos. 107 – 109
5920-12598	Turbine Steam Seal	1",2-1/2" 3SLBPV	Bypass Valve third seal leakoff to SPE	Steam	<320	CS	Continuous		SSB	
5920-12598	Turbine Steam Seal	2-1/2" 1SPL2	HP Turbine pocket drain to 36" Cross Around	Steam	540	CS	Continuous		SSB	SB Locations Nos. 110 – 115
5920-12598	Turbine Steam Seal	1" 1SLCIV (4 lines total)	CIV Intercept Valve first seal leakoff to SSH	Steam	<382	CS	Continuous		SSB	
5920-12598	Turbine Steam Seal	1" 2SLCIV (4 lines total)	CIV Intercept Valve second seal leakoff to SSH	Steam	<382	CS	Continuous		SSB	
5920-12598	Turbine Steam Seal	1" (4 lines total)	CIV Intermediate Stop Valve seal leakoff to SPE	Steam	<382	CS	Continuous		SSB	

Vermont Yankee Piping Flow Accelerated Corrosion Inspection Program – FAC Susceptibility Review

TABLE 2: Summary of Line by Line FAC Susceptibility Screening

Drawing No.	System	Line No(s).	Description	Fluid	Oper. Temp (F)	Material	Flow at Full Power Operation	Exclusion (Note 1)	Susceptibility Classification (Note 2)	Notes
5920-12598	Turbine Steam Seal	1" (4 lines total)	CIV Intermediate Stop Valve seal leakoff to SPE	Steam	<382	CS	Continuous		SSB	
5920-12598	Turbine Steam Seal	1" SLSSR	Steam Seal Regulator to SPE	Steam	<540	CS	Continuous		SSB	
5920-12857 SH.1	H2 & Air Injection	All	H2 System Injection Process Module	H2, Air	<150	SS	Continuous		NS	
5920-12857 SH.2	H2 & Air Injection	All	H2 System Injection Process Module	H2, Air	<150	SS	Continuous		NS	
5920-12858	Off Gas Monitor	All	Off-gas Monitoring Panel	Offgass, H2, O2, N2	<150	SS	Continuous		NS	

TABLE 2.0 NOTES:

1. Key to Exemption Reasons:
 - M = Stainless or low alloy FAC resistant material (Section 5.1.1)
 - Q = Superheated steam (5.1.2)
 - O2 = High dissolved oxygen or Raw Water (5.1.3)
 - T = Single phase system operation below 175F (5.1.4)
 - U = No flow, or operating less than 2% or total time (5.1.5)
 - NW = Fluid other than water or wet steam (5.1.6)

2. Key to be Susceptibility Classification
 - NS = Non Susceptible.
 - SMC = Susceptible Large Bore – Modeled using CHECWORKS.
 - SNM = Susceptible Large Bore – Not Modeled.
 - SSB = Susceptible Small Bore

3. Non Susceptible using NSAC 202L–R2 Exclusion Criteria. However Large bore line has been modeled using CHECWORKS. Specific locations on the small bore lines have been included in the Small Bore Location data base.

4. Original piping was carbon steel. Replaced with FAC resistant material.

5. Piping screens out based on no flow (normally closed valves). Line is included in Program Scope based on past leakage through the valves.

6. Normally closed small bore equipment vents, drains, and level control instrument lines along with sampling lines are automatically excluded due to No Flow condition.

TABLE 2: Summary of Line by Line FAC Susceptibility Screening

TABLE 2.0 NOTES: - continued

7. Lines 10" MS-3A to 10"MS-3J, Turbine Bypass Valve Discharge lines to the main condensers: Flow from MS lines only during startup, testing, or transients and would screen out as NS based on Usage < 2% of time. However, warming steam continuously flows from line 36 "CAR C via the BPV 1st seal leakoff line 1SLBPV per GEK 17999A, Reference 22.
8. Line is included in AST post DBA Alternate Leakage Treatment Boundary, reference VYDC-2003-016. These lines along with the condenser have been seismically evaluated and are required to remain intact during and after a SSE. See Reference 23.
9. Min Flow line screens as Non-Susceptible based on Usage and/or Temperature. However, there has been industry experience (IE) with wall loss downstream of restriction orifices on Min Flow lines. Include piping downstream of restriction orifices as Susceptible to FAC.
10. Upstream components have been replaced with FAC resistant materials. Noted here for potential of increased wear rates due to "Leading Edge Effect".
11. Turbine Bypass valve Chest 1st Seal Leakoff piping line 1SLBPV is currently scheduled for replacement with FAC resistant material during RFO 25. Refer to Engineering Request No. 04-0964. This line will be considered as susceptible to FAC until replacement is complete.
12. Upstream piping was supplied with LAS replacement casings and is considered as part of the LP turbine. Piping downstream of each the Restriction Orifices was removed. See drawing 5920-568 (Pending Change for VYDC 2003-006, J.O. 2003-038).

Recommendations for an Effective Flow-Accelerated Corrosion Program

NSAC-202L-R2

Final Report, April 1999

NEC-4

Contains EPRI Licensed
Material

Pg 1-1 through A-10

EPRI Project Manager
B. Chexal

SINGLE USER LICENSE AGREEMENT

THIS IS A LEGALLY BINDING AGREEMENT BETWEEN YOU AND THE ELECTRIC POWER RESEARCH INSTITUTE, INC. (EPRI). PLEASE READ IT CAREFULLY BEFORE BREAKING OR TEARING THE WARNING LABEL AND OPENING THIS SEALED PACKAGE.

BY OPENING THIS SEALED REPORT YOU ARE AGREEING TO THE TERMS OF THIS AGREEMENT. IF YOU DO NOT AGREE TO THE TERMS OF THIS AGREEMENT, PROMPTLY RETURN THE UNOPENED REPORT TO EPRI AND THE PURCHASE PRICE WILL BE REFUNDED.

1. GRANT OF LICENSE

EPRI grants you the nonexclusive and nontransferable right during the term of this agreement to use this report only for your own benefit and the benefit of your organization. This means that the following may use this report: (I) your company (at any site owned or operated by your company); (II) its subsidiaries or other related entities; and (III) a consultant to your company or related entities, if the consultant has entered into a contract agreeing not to disclose the report outside of its organization or to use the report for its own benefit or the benefit of any party other than your company.

This shrink-wrap license agreement is subordinate to the terms of the Master Utility License Agreement between most U.S. EPRI member utilities and EPRI. Any EPRI member utility that does not have a Master Utility License Agreement may get one on request.

2. COPYRIGHT

This report, including the information contained in it, is either licensed to EPRI or owned by EPRI and is protected by United States and international copyright laws. You may not, without the prior written permission of EPRI, reproduce, translate or modify this report, in any form, in whole or in part, or prepare any derivative work based on this report.

3. RESTRICTIONS

You may not rent, lease, license, disclose or give this report to any person or organization, or use the information contained in this report, for the benefit of any third party or for any purpose other than as specified above unless such use is with the prior written permission of EPRI. You agree to take all reasonable steps to prevent unauthorized disclosure or use of this report. Except as specified above, this agreement does not grant you any right to patents, copyrights, trade secrets, trade names, trademarks or any other intellectual property, rights or licenses in respect of this report.

4. TERM AND TERMINATION

This license and this agreement are effective until terminated. You may terminate them at any time by destroying this report. EPRI has the right to terminate the license and this agreement immediately if you fail to comply with any term or condition of this agreement. Upon any termination you may destroy this report, but all obligations of nondisclosure will remain in effect.

5. DISCLAIMER OF WARRANTIES AND LIMITATION OF LIABILITIES

NEITHER EPRI, ANY MEMBER OF EPRI, ANY COSPONSOR, NOR ANY PERSON OR ORGANIZATION ACTING ON BEHALF OF ANY OF THEM:

(A) MAKES ANY WARRANTY OR REPRESENTATION WHATSOEVER, EXPRESS OR IMPLIED, (I) WITH RESPECT TO THE USE OF ANY INFORMATION, APPARATUS, METHOD, PROCESS OR SIMILAR ITEM DISCLOSED IN THIS REPORT, INCLUDING MERCHANTABILITY AND FITNESS FOR A PARTICULAR PURPOSE, OR (II) THAT SUCH USE DOES NOT INFRINGE ON OR INTERFERE WITH PRIVATELY OWNED RIGHTS, INCLUDING ANY PARTY'S INTELLECTUAL PROPERTY, OR (III) THAT THIS REPORT IS SUITABLE TO ANY PARTICULAR USER'S CIRCUMSTANCE; OR

(B) ASSUMES RESPONSIBILITY FOR ANY DAMAGES OR OTHER LIABILITY WHATSOEVER (INCLUDING ANY CONSEQUENTIAL DAMAGES, EVEN IF EPRI OR ANY EPRI REPRESENTATIVE HAS BEEN ADVISED OF THE POSSIBILITY OF SUCH DAMAGES) RESULTING FROM YOUR SELECTION OR USE OF THIS REPORT OR ANY INFORMATION, APPARATUS, METHOD, PROCESS OR SIMILAR ITEM DISCLOSED IN THIS REPORT.

6. EXPORT

The laws and regulations of the United States restrict the export and re-export of any portion of this report, and you agree not to export or re-export this report or any related technical data in any form without the appropriate United States and foreign government approvals.

7. CHOICE OF LAW

This agreement will be governed by the laws of the State of California as applied to transactions taking place entirely in California between California residents.

8. INTEGRATION

You have read and understand this agreement, and acknowledge that it is the final, complete and exclusive agreement between you and EPRI concerning its subject matter, superseding any prior related understanding or agreement. No waiver, variation or different terms of this agreement will be enforceable against EPRI unless EPRI gives its prior written consent, signed by an officer of EPRI.

DISCLAIMER OF WARRANTIES AND LIMITATION OF LIABILITIES

THIS REPORT WAS PREPARED BY THE ORGANIZATION(S) NAMED BELOW AS AN ACCOUNT OF WORK SPONSORED OR COSPONSORED BY THE ELECTRIC POWER RESEARCH INSTITUTE, INC. (EPRI). NEITHER EPRI, ANY MEMBER OF EPRI, ANY COSPONSOR, THE ORGANIZATION(S) NAMED BELOW, NOR ANY PERSON ACTING ON BEHALF OF ANY OF THEM:

(A) MAKES ANY WARRANTY OR REPRESENTATION WHATSOEVER, EXPRESS OR IMPLIED, (I) WITH RESPECT TO THE USE OF ANY INFORMATION, APPARATUS, METHOD, PROCESS, OR SIMILAR ITEM DISCLOSED IN THIS REPORT, INCLUDING MERCHANTABILITY AND FITNESS FOR A PARTICULAR PURPOSE, OR (II) THAT SUCH USE DOES NOT INFRINGE ON OR INTERFERE WITH PRIVATELY OWNED RIGHTS, INCLUDING ANY PARTY'S INTELLECTUAL PROPERTY, OR (III) THAT THIS REPORT IS SUITABLE TO ANY PARTICULAR USER'S CIRCUMSTANCE; OR

(B) ASSUMES RESPONSIBILITY FOR ANY DAMAGES OR OTHER LIABILITY WHATSOEVER (INCLUDING ANY CONSEQUENTIAL DAMAGES, EVEN IF EPRI OR ANY EPRI REPRESENTATIVE HAS BEEN ADVISED OF THE POSSIBILITY OF SUCH DAMAGES) RESULTING FROM YOUR SELECTION OR USE OF THIS REPORT OR ANY INFORMATION, APPARATUS, METHOD, PROCESS, OR SIMILAR ITEM DISCLOSED IN THIS REPORT.

ORGANIZATION(S) THAT PREPARED THIS REPORT

Altos Engineering

ORDERING INFORMATION

Requests for copies of this report should be directed to the EPRI Distribution Center, 207 Coggins Drive, P.O. Box 23205, Pleasant Hill, CA 94523, (510) 934-4212.

Electric Power Research Institute and EPRI are registered service marks of the Electric Power Research Institute, Inc. EPRI. POWERING PROGRESS is a service mark of the Electric Power Research Institute, Inc.

Copyright © 1999 Electric Power Research Institute, Inc. All rights reserved.

CITATIONS

This report was prepared by

Electric Power Research Institute
3412 Hillview Avenue
Palo Alto, California 94303

Authors
V.K. Chexal
D.P. Munson

Altos Engineering
370 Distel Circle, Suite B100
Los Altos, California 94022

Author
G.A. Randall

DuPage Computer Applications, Inc.
3331 Avenida Sierra
Escondido, California 92029

Author
J.S. Horowitz

With support from the CHUG Advisory Committee

I.L. Breedlove, Virginia Power
H.M. Crockett, Texas Utilities Electric Company
R. Guizar, Southern California Edison Company
A. Kelley, Commonwealth Edison Company
J. Ritchie, Arizona Public Service Company
S. Slosnerick, First Energy Corporation
D.A. Smith, Duke Power Company

This report describes research sponsored by EPRI.

The report is a corporate document that should be cited in the literature in the following manner:

Recommendations for an Effective Flow-Accelerated Corrosion Program, EPRI, Palo Alto, CA: 1999.
NSAC-202L-R2.

REPORT SUMMARY

Since the mid-1980s, nuclear power plants have experienced leaks and ruptures caused by flow-accelerated corrosion (FAC). The nuclear power industry has mounted a broad-based effort to reduce the amount of FAC that occurs and to uncover incidents of excessive FAC before failures are likely to occur. This report describes the elements of an effective FAC prevention program, identifying procedures and tasks, necessary documentation, and a strategy for developing and implementing a long-term program. This revision incorporates lessons learned concerning FAC and new prevention technology since November 1996.

Background

FAC—sometimes referred to as flow-assisted corrosion or erosion-corrosion—leads to wall thinning (metal loss) of steel piping exposed to flowing water or wet steam. The rate of metal loss depends on a complex interplay of many parameters such as water chemistry, material composition, and hydrodynamics. Carbon steel piping components that carry wet steam are especially susceptible to FAC and represent an industrywide problem. Experience has shown that FAC damage to piping at fossil and nuclear plants can lead to costly outages and repairs and can affect plant reliability and safety. EPRI and the industry as a whole have worked steadily since 1986 to develop or refine monitoring programs in order to prevent FAC-induced pipe failures.

Objectives

To present a set of recommendations for an effective FAC prevention program.

Approach

EPRI—with the support of the CHECKWORKS™ Users Group (CHUG)—conducted a series of plant visits designed to review the scope and effectiveness of utility FAC programs. (CHUG is an industry-sponsored group formed to deal with FAC-induced wall thinning.) The visits revealed the need for a set of programmatic recommendations. EPRI developed a set of recommendations to help utility personnel design and implement a comprehensive FAC prevention program.

Results

The Institute of Nuclear Power Operations (INPO), Nuclear Management and Resources Council (NUMARC, now the Nuclear Energy Institute), U.S. Nuclear Regulatory Commission (USNRC), and American Society of Mechanical Engineers (ASME) have all issued guidance related to prevention of FAC. This report describes the organization and activities necessary to implement a successful FAC program. It

identifies typical elements of an effective FAC program and describes the steps utilities should take to minimize the chances of experiencing a FAC-induced consequential leak or rupture. The guidance is directed primarily at FAC-induced wall thinning in large-bore piping, although small-bore piping is also addressed. Key elements of the guidelines include

- Discussion of an effective FAC program design, with emphasis on corporate commitment, industry FAC experience, inspections, engineering judgment, and long-term strategies
- Description of implementation procedures and documentation, including use of a governing document
- Identification of recommended FAC tasks, with key steps of identifying susceptible systems, performing FAC analysis, selecting and scheduling components for inspection, performing inspections, evaluating inspection data, assessing worn components, and repairing and replacing components
- Explanation of how to develop a long-term strategy, with discussions of FAC-resistant materials, water chemistry, and system design changes

EPRI Perspective

The recommendations in this document will help utilities implement an effective monitoring program at their plants and establish a uniform industry approach toward mitigating FAC damage. It is believed that implementation of the recommendations will prove a cost-effective method for increasing personnel safety, plant safety, and plant availability. The recommendations also have the potential to reduce forced outages and thus increase the capacity factor while decreasing the cost of plant operations and maintenance. Though implementation of these recommendations should greatly reduce the probability of a consequential leak or a rupture, the industry recognizes it will never be possible to prevent all FAC-related leaks and ruptures. The continuing occurrence of FAC failures is evidence that efforts to eliminate such incidents should be maintained at plants with good experience and intensified at plants that have marginal FAC prevention programs or poor experience.

NSAC-202L-R2

Interest Categories

Piping, reactor vessel and internals

Non-destructive examination

Corrosion control

Plant support engineering

Keywords

Flow-accelerated corrosion

Wall thinning

Piping systems

Reliability

Availability

Safety

Erosion Corrosion

ABSTRACT

This document presents a set of recommendations for an effective flow-accelerated corrosion program. These recommendations are the product of a series of plant visits conducted by EPRI. The visits were designed to review the scope and effectiveness of utility flow-accelerated corrosion (FAC) programs. The essential ingredients for an effective FAC program are presented in this document. The steps that utilities should take to minimize the chances of experiencing a FAC-induced consequential leak or rupture are also presented.

ACKNOWLEDGMENTS

The authors wish to acknowledge the support of the members of the CHECWORKS™ Users Group (CHUG) for their support in developing this document. As of December 1998, this membership included:

Altran Corporation	Scott Blodgett
American Electric Power Service Corp.	Eric W. Anderson
Arizona Public Service Company	John M. Ritchie
Baltimore Gas & Electric Company	Harvey Enoch
Boston Edison Company	John A. Tucker
Carolina Power & Light Company	Tom Freeman
Commonwealth Edison Company	Aaron Kelley
Consolidated Edison Company of New York	William A. Kessler
Consumers Power Inc.	Tom Fouty
Corrosion Services, Inc.	Dan Poe
Duke Engineering & Services, Inc.	Ned Dietrich
Duke Power Company	David A. Smith
Duquesne Light Company	David P. Grabski
Electricite de France	Michel Bouchacourt
Entergy Operations, Inc.	Robert W. Wright, Sr.
First Energy Corporation	Stephen Slosnerick
Florida Power & Light Company	William A. Klein
Florida Power Corporation	Matthew Denny
GPU Nuclear Corporation	Hazel Malone
IEA of Japan Company, Ltd.	Shinichi Oka
IES Industries	Russ Severson
Illinois Power Company	Chris Rogan
Institute of Nuclear Energy Research	Li-Fu Lin

Korea Electric Power Corp.	Sung Ho Lee
Nebraska Public Power District	Terry Ackerman
New Brunswick Electric Power Commission	Arturo Guillermo
New York Power Authority	Robert Penny
Niagara Mohawk Power Corporation	James Wadsworth
Northeast Utilities	Steven Janes
Northern States Power Company	Tin Tran
Nuclear Research Institute	Martin Ruscak
Omaha Public Power District	Dave Rollins
Ontario Hydro	John Allingham
Pacific Gas & Electric Company	Lee F. Goyette
PECO Energy Company	Edward P. Troy
Pennsylvania Power & Light Company	Matthew A. Hober, Jr.
Public Service Electric & Gas Company	Robert Montgomery
Rochester Gas & Electric Corporation	Ata Istar
South Carolina Electric & Gas Company	John E. Waters, Jr.
South Texas Project Nuclear Operating Corp.	Jerry Stauber
Southern California Edison Company	Raul Guizar
Southern Nuclear Operating Company	Charles W. Dean
Tennessee Valley Authority	Gay I. Haliburton
Texas Utilities Electric Company	Harold M. Crockett
Union Electric Company	Roger D. Myatt
Vermont Yankee Nuclear Power Corp.	James C. Fitzpatrick
Virginia Power	Ian L. Breedlove
Washington Public Power Supply System	Douglas Ramey
Wisconsin Electric Power Company	Scott Johnson
Wisconsin Public Service Corporation	Jerry T. Krueger
Wolf Creek Nuclear Operating Corporation	Carlos Hernandez

NSAC PERSPECTIVE

Since the mid eighties, nuclear power plants have experienced leaks and ruptures caused by flow-accelerated corrosion (FAC), also known as flow-assisted corrosion or erosion-corrosion. The nuclear power industry has mounted a broad-based effort to reduce the amount of FAC that occurs and to uncover incidents of excessive FAC before failures are likely to occur. EPRI, the Nuclear Energy Institute (NEI - formerly the Nuclear Management and Resources Council-NUMARC), and the Institute of Nuclear Power Operations (INPO) have all contributed to this effort. Nevertheless, problems caused by FAC have continued to occur.

Several major ruptures in the early nineties showed the importance of having an effective FAC program. In response, EPRI,—with the support of the CHECWORKS™ Users Group (CHUG)—sponsored a series of plant visits to learn about the implementation of utility FAC programs. These visits showed that there were large differences among utility programs. After these visits, EPRI and CHUG decided that a set of programmatic recommendations prepared by EPRI would be desirable. This document is a result of that decision.

This document describes the necessary elements of an effective FAC program. The desirable procedures and necessary documentation are described, as well as a detailed description of the necessary tasks. A strategy for developing a long-term program is also presented. The application of these recommendations should reduce the probability of experiencing FAC-induced leaks and ruptures.

This revision incorporates lessons learned and new technology that has become available since the last revision of this document in November 1996.

CONTENTS

1 INTRODUCTION	1-1
1.1 Background.....	1-2
1.2 Industry Status.....	1-4
2 ELEMENTS OF AN EFFECTIVE FAC PROGRAM	2-1
2.1 Corporate Commitment.....	2-1
2.2 Analysis	2-2
2.3 Industry FAC Experience	2-3
2.4 Inspections.....	2-4
2.5 Training and Engineering Judgment.....	2-4
2.6 Long-Term Strategy.....	2-5
3 PROCEDURES AND DOCUMENTATION.....	3-1
3.1 Governing Document.....	3-1
3.2 Implementing Procedures	3-1
3.3 Documentation.....	3-2
4 RECOMMENDATIONS FOR FAC TASKS.....	4-1
4.1 Definitions	4-1
4.2 Identifying Susceptible Systems	4-2
4.2.1 Potential Susceptible Systems.....	4-2
4.2.2 Exclusion of Systems From Evaluation	4-3
4.2.3 Prioritize Systems For Evaluation.....	4-4
4.3 Performing FAC Analysis.....	4-5
4.4 Selecting And Scheduling Components For Inspection	4-6
4.4.1 Initial Inspection	4-6
4.4.1.1 Sample Selection	4-7

4.4.1.2 Expanded Sample Inspection	4-8
4.4.1.3 Inspection Locations for Lines with Uncertain Operating Conditions.....	4-9
4.4.2 Second Inspection	4-10
4.4.3 Follow-On Inspections.....	4-11
4.5 Performing Inspections	4-12
4.5.1 Inspection Technique	4-12
4.5.2 Grid Coverage.....	4-14
4.5.3 Grid Size	4-16
4.5.4 Measuring Trace Alloy Content.....	4-19
4.6 Evaluating Inspection Data	4-19
4.6.1 Evaluation Process	4-19
4.6.2 Data Reduction	4-20
4.6.3 Determining Initial Thickness and Measured Wear	4-20
4.7 Evaluating Worn Components	4-25
4.7.1 Acceptable Wall Thickness	4-25
4.7.2 Maximum Wear Rate.....	4-27
4.7.3 Remaining Service Life	4-29
4.8 Repairing and Replacing Components	4-30
5 DEVELOPMENT OF A LONG-TERM STRATEGY	5-1
5.1 Need For A Long-Term Strategy.....	5-1
5.2 FAC Resistant Materials	5-2
5.3 Water Chemistry	5-3
5.3.1 PWR Plants.....	5-4
5.3.1.1 Effect of pH and Amines on FAC	5-4
5.3.1.2 Effect of Hydrazine on FAC.....	5-5
5.3.2 BWR Plants.....	5-6
5.4 System Design Changes	5-8
5.5 Summary	5-8
6 REFERENCES	6-1
APPENDIX A RECOMMENDATIONS FOR AN EFFECTIVE FAC PROGRAM FOR SMALL BORE PIPING	A-1
A1.0 Introduction.....	A-1

A2.0 Identifying Susceptible Systems.....	A-1
A3.0 Evaluating Susceptible Systems for Consequence of Failure	A-1
A4.0 Scheduling Inspections	A-2
A4.1 Category 1 Piping	A-2
A4.2 Prioritizing Category 1 Piping Based On Level of Susceptibility	A-3
A4.3 Category 2 Piping	A-3
A5.0 Selecting Components for Initial Inspection.....	A-3
A5.1 Grouping Piping Lines Into Sub-Systems	A-3
A5.2 Selecting Components For Inspection.....	A-4
A6.0 Performing Inspections.....	A-5
A6.1 Radiography Techniques (RT).....	A-5
A6.2 Ultrasonic Techniques (UT)	A-5
A6.3 Thermography	A-5
A7.0 Evaluating Inspection Results	A-5
A8.0 Disposition of Sub-Systems.....	A-6
A8.1 Low Wear Sub-Systems	A-6
A8.2 High Wear Sub-Systems.....	A-6
A9.0 Long Term Strategy.....	A-7

LIST OF FIGURES

Figure 2-1 An Effective FAC Program is Founded on Interrelated Elements	2-1
Figure 4-1 Grid Layout for an Elbow	4-16
Figure 4-2 Example of Band Method	4-22
Figure 4-3 Example of Area Method	4-23
Figure 4-4 Example of Moving Blanket Method	4-24
Figure 4-5 Predicted Thickness Profile	4-26
Figure 4-6 Potential for Error When Using Average Wear Rate Based on Inspection Data	4-28
Figure 4-7 Danger Of Using Wear Rate Based On Inspection Data From Two Inspections.....	4-29
Figure 5-1 Expected Trends for Inspections Over a Plant's Life	5-2
Figure 5-2 Impact of Change in pH Level on FAC (As Predicted by CHECWORKS*)	5-4
Figure 5-3 Amine Comparison - Typical Conditions at the Same Cold pH.....	5-5
Figure 5-4 Relationship Between FAC and Hydrazine.....	5-6
Figure 5-5 Effects of BWR Steam Line Oxygen Concentration.....	5-7
Figure A-1 Small Bore Piping FAC Program.....	A-8

LIST OF TABLES

Table 4-1 Maximum Grid Sizes for Standard Pipe Sizes	4-18
Table 5-1 Performance of Common FAC-Resistant Alloys	5-3
Table 5-2 Effect of Oxygen on Typical Feedwater Wear Rates	5-7

1

INTRODUCTION

In December 1986, an elbow in the condensate system ruptured at the Surry Power Station. The failure caused four fatalities and tens of millions of dollars in repair costs and lost revenue. Flow-accelerated corrosion (FAC)¹ was found to be the cause of the failure.² Following this failure, EPRI developed the CHEC® family of computer codes to assist utilities in planning inspections and evaluating the inspection data to prevent piping failures caused by FAC. More recently, EPRI developed the CHECWORKS™ code to replace the original CHEC® family of codes (CHEC®, CHECMATE®, CHEC-NDE™, and CHEC-T™).³ EPRI has also conducted many technology transfer workshops to promote the exchange of information among utility personnel and to help utilities address this issue. This technology and information have greatly reduced the threat of FAC failures. Nevertheless, instances of severe thinning, leaks, and ruptures still occur. The most significant examples of recent failures occurred at Millstone Unit 3 in December 1990, at Millstone Unit 2 in November 1991, at Sequoyah Unit 2 in March 1993, at the Pleasant Prairie fossil plant in February 1995, at the Green Bay fossil plant in April 1996, and at Fort Calhoun in April 1997

The continuing occurrence of FAC failures is evidence that plant programs to control FAC should be maintained and improved as necessary as industry knowledge evolves and more industry and plant data becomes available. The CHECWORKS™ Users Group (CHUG), an industry sponsored group formed to deal with FAC induced wall thinning, authorized and provided major funding for EPRI to conduct a series of plant visits to understand how the technology, plant experience, and engineering know-how are being used. One result of these visits was that a need was identified for a set of recommendations to help utility personnel develop and effectively implement a comprehensive FAC program.

This document describes the organization and activities necessary to implement a successful FAC program. Typical elements of an effective FAC program are identified,

¹ Flow-accelerated corrosion is sometimes, but incorrectly, called erosion-corrosion. Erosion, it should be noted, is not part of the degradation mechanism.

² This was not the first instance that a rupture was caused by FAC, but it did bring the issue to prominence.

³ The CHECWORKS™ code and this document supersede the previous EPRI position on FAC found in EPRI Report NP-3944 (Reference 1).

Introduction

and recommendations for implementation are made. This document is written to be of use to all utilities, irrespective of the predictive analytical methodology being used.

This document is directed at wall thinning caused by FAC. It is primarily directed at wall thinning in large-bore piping, although small-bore piping is also addressed. It does not cover other thinning mechanisms, such as cavitation, microbiologically-influenced corrosion (MIC), and erosive wear. It is planned that this document will be periodically updated to reflect the advances made in FAC control.

1.1 Background

Flow-accelerated corrosion (FAC) is sometimes referred to as flow-assisted corrosion or erosion-corrosion. FAC leads to wall thinning (metal loss) of steel piping exposed to flowing water or wet steam. The rate of metal loss depends on a complex interplay of many parameters including water chemistry, material composition, and hydrodynamics. FAC damage to plant piping can lead to costly outages and repairs and can affect plant reliability and safety. Pipe wall thinning rates as high as 0.120 inch/year have occurred. Pipe ruptures and leaks caused by FAC have occurred at both fossil and nuclear plants. Carbon-steel piping components that carry wet steam are especially susceptible to FAC and represent an industry-wide problem.

Although there were limited FAC programs in place before the Surry pipe rupture, it was not until after this accident that utilities expanded their inspection programs to reduce the risk of pipe ruptures caused by FAC in susceptible single-phase systems. Since the Surry incident in December 1986, the industry has worked steadily to develop or refine their monitoring programs to prevent the failure of piping due to FAC. In March 1987, INPO issued a Significant Operating Experience Report (SOER 87-3, reference 2), which recommended that a continuing program be established at all U.S. nuclear power plants. The program should include analyses for predicting wear rates and selecting intervals for regular inspections. In July 1987, the United States Nuclear Regulatory Commission (USNRC) issued bulletin 87-01 asking licensees to monitor the pipe wall thickness in high-energy piping systems and to report any areas where wall thinning had been identified.

The Nuclear Management and Resources Council⁴ (NUMARC) and EPRI developed a resolution approach for FAC in single-phase piping systems and provided the utilities with recommendations for a program (reference 3). This document was issued in June 1987 and recommended that utilities do the following:

⁴ In 1993 NUMARC and several other industry organizations were combined to form the Nuclear Energy Institute - NEI.

1. Conduct appropriate analysis and a limited but thorough initial inspection of susceptible single-phase piping.
2. Determine the extent of thinning, and repair or replace worn piping components as necessary.
3. Perform follow-up inspections to confirm or quantify rates of thinning.
4. Take long term corrective action.

Based on the NUMARC/EPRI document, the U.S. industry conducted the initial inspections of nuclear plant piping systems during 1987 and 1988. The United States Nuclear Regulatory Commission (USNRC) monitored the results of these inspections and in May 1989 issued Generic Letter 89-08 (reference 4). This, in essence, required that operators of nuclear power plants perform the following:

1. Implement a long term FAC monitoring program.
2. Include all susceptible high-energy carbon-steel piping systems.
3. Include both single- and two-phase systems.
4. Utilize the NUMARC/EPRI or other equally effective analysis method.

To support the industry effort, EPRI began developing the CHEC[®] (reference 5) and CHECMATE[®] (reference 6) computer codes for predicting FAC wear rates in piping containing single- and two-phase flow. These codes were developed specifically to assist the utility industry in planning and implementing inspection programs to prevent FAC failures. The codes could also be used to evaluate the effect of changes in piping design or operating conditions on FAC wear rates.

In response to utility requests for assistance in managing and evaluating the NDE data acquired during inspections, the CHEC-NDE[™] (reference 7) computer code was developed and released in April 1991. To assist utilities in performing stress analysis of worn fittings, EPRI developed the CHEC-T[™] computer code (reference 8). In July 1989, EPRI formed the CHEC[®]/CHECMATE[®] Users Group, since renamed the CHECWORKS[™] Users Group, CHUG. The key purpose of this group is to provide a forum for the exchange of information pertaining to FAC issues and to provide user support and maintenance for the EPRI codes.

EPRI has continued to develop technology to help utilities control FAC, and in December 1993 released the CHECWORKS[™] code (reference 9). In summary, CHECWORKS[™] integrated and updated the capability of the previous four codes, and was written to take full advantage of the recent advances in computer technology.

Introduction

Additionally, capability was added to help utilities manage related plant data and to automate many of the analysis and reporting tasks conducted during an inspection outage.

In response to utility requests, the American Society of Mechanical Engineers (ASME) has published Code Case N-597, "Requirements for Analytical Evaluation of Pipe Wall Thinning" which provides rules for evaluating piping for FAC. These rules (reference 15) provide structural acceptance criteria for Class 1, 2, and 3 piping components that have experienced wall thinning⁵.

1.2 Industry Status

Since the Millstone 3 failure in December 1990, EPRI has conducted a series of visits to nuclear power plants to ascertain how well FAC programs had been implemented. The goal was to review the scope, implementation, current status, and effectiveness of individual FAC programs. It was found that, although the utilities had a common goal of preventing leaks and ruptures, their approaches toward and rates of success in attaining this goal varied.

The recommendations in this document are provided to aid utilities in implementing an effective monitoring program at their plants and to establish a uniform industry approach toward mitigating FAC damage. It is believed that the implementation of these recommendations will prove to be a cost-effective method of increasing personnel safety, plant safety, and plant availability. These recommendations also have the potential to reduce forced outages and thus increase the capacity factor, while reducing the cost of plant operations and maintenance. The implementation of recommendations found in this document should greatly reduce the probability of a consequential leak or a rupture occurring. However, it is recognized that it will never be possible to prevent all FAC related leaks and ruptures from occurring.

⁵ Some organizations are also using Code Case N-597 to evaluate ANSI B31.1 piping for FAC related wall thinning.

2

ELEMENTS OF AN EFFECTIVE FAC PROGRAM

Six key and interrelated elements are necessary for a plant FAC program to be fully effective. These elements are illustrated in Figure 2-1 and are described in more detail below.




Figure 2-1
An Effective FAC Program is Founded on Interrelated Elements

2.1 Corporate Commitment

Corporate Commitment is essential to an effective FAC program. It is recommended that this commitment include the following:

Elements of an Effective FAC Program

- Providing adequate financial resources to ensure that all tasks are properly completed.
- Ensuring that overall authority and task responsibilities are clearly defined, and that the assigned personnel have adequate time to complete the work.
- Ensuring that assigned personnel are properly qualified and trained for their area of technical responsibility. Ensuring that adequately trained, backup personnel are available.
- Ensuring that adequate and formal communications exist between various departments. Formalized sharing of data and information is essential.
- Ensuring that FAC experiences at other plants are continuously monitored and evaluated.
- Minimizing personnel turnover on the program, and providing sufficient transition when turnover does occur to ensure that plant and industry experience is not lost.
- Developing and implementing a long-term plan to reduce high FAC wear rates.
- Ensuring that appropriate quality assurance is applied. This should include preparing and documenting procedures for tasks to be performed, properly documenting work, and providing for periodic independent reviews of all phases of the FAC program.

2.2 Analysis

There are several thousand piping components in a typical nuclear power plant that are potentially susceptible to FAC damage. Without an accurate FAC analysis of the plant, inspection drawings, and a piping database that includes inspection and replacement histories, the only way to prevent leaks and ruptures is to inspect each susceptible component during each outage. This would be a very costly inspection program.

A primary objective of FAC analysis is to identify the most susceptible components, thereby reducing the number of inspections (the size of this sample being a strong function of both the plant susceptibility and the accuracy of the plant model and analysis method used). This limited sample should be chosen to select the components with the greatest susceptibility to FAC. Some plants have used a simplified approach, often involving rating factors for this susceptibility analysis. However, due to the necessary conservatism involved, simplified analysis still results in a large number of inspections.

Plants that have used simplified FAC analyses can inspect as many as 300 to 500 inspection locations⁶ during each fuel cycle for large-bore piping alone. Experience has shown that until a comprehensive analysis of all susceptible systems has been completed, plant personnel cannot be confident that all highly susceptible components have been identified and are being monitored to prevent leakage or rupture.

Analytical methods should utilize the results of plant specific inspection data to develop plant specific correction factors. This correction accounts for uncertainties in plant data, and for systematic discrepancies caused by plant operation. Utilities that have a comprehensive analytical model of their plants which incorporates inspection data to refine the wear rate predictions and have reduced susceptibility are averaging approximately 50 to 100 large-bore and an additional 10 to 35 small bore inspection locations per fuel cycle. Although the number of inspection locations examined per fuel cycle is extremely plant-specific, depending on the plant age, wall thickness margins, materials, and susceptibility, the above figures reflect a sample of industry experience as of the end of 1998.

For each piping component, an analytical method should be used to predict the FAC wear rate, and the estimated time until it must be reinspected, repaired, or replaced. The analytical model can also be utilized for design studies. These studies are valuable for cost benefit evaluations such as water chemistry changes, materials changes, and design changes, considering various plant constraints for existing and new designs. The rankings of components can be used as relative rankings to assist in planning and carrying out the initial inspection program of a plant or system.

2.3 Industry FAC Experience

Review and incorporation of industry experience provides a valuable supplement to plant analysis and associated inspections. To assist utilities in assembling the relevant past data, EPRI has issued a CHUG-supported Plant Experiences Database (PEDB) which summarizes much of the relatively recent US plant FAC experience (reference 11). Utilities have found the following benefits from sharing plant experiences:

- Identifying generic plant problem areas where additional inspections may be warranted.
- Understanding differences in similar types of components (e.g., FAC wear rates of downstream piping is more severe when control valves made by certain manufacturers are used).

⁶ In this document, an inspection location consists of measurements on the component and the attached pieces of straight piping.

Elements of an Effective FAC Program

- Understanding the FAC consequences of using systems off-design (e.g., running bypass lines full time).
- Sharing information on costs, materials, qualified suppliers, repair or replacement techniques, inspection techniques, new equipment, etc.

Membership in the CHECWORKS™ Users Group (CHUG) is recommended as an excellent way for utilities to share industry experience.

2.4 Inspections

Good inspections are the foundation of an effective FAC program. Wall thickness measurements will establish the extent of wear in a given component, provide data to help evaluate FAC trends, and provide data to refine the predictive model. Thorough inspections are the key to fulfilling these needs. Thorough inspection of a few components is much more beneficial to a FAC program than a cursory inspection of a large number of components. One practice particularly not recommended is recording only the minimum thicknesses ascertained by UT scanning of large-bore components. Rather, a systematic method of collecting data is recommended. This will help to increase repeatability and allow for the trending of results. Complete inspections may require material sampling.

2.5 Training and Engineering Judgment

Training of key personnel is essential to the success of a FAC program. It is recommended that:

- The FAC coordinator of each plant receive both Introductory and Advanced EPRI/CHUG training,
- Each plant FAC coordinator have a trained backup, who has received at least the Introductory EPRI/CHUG training, and
- Other plant personnel that are relied on to successfully implement a comprehensive FAC program also receive training. These personnel may include plant operators, systems engineers, maintenance engineers, inspection personnel, and design engineers. The training should include an overview of FAC and how FAC affects their responsibilities. It can be given by a knowledgeable person such as the plant FAC coordinator.

Application of good engineering judgment is an important ingredient in each step of a FAC program. Judgment should be applied to all steps, from modeling decisions to evaluating inspection data. Accordingly, it is important that personnel involved in the

program be aware of industry experience, be formally trained in an appropriate engineering discipline (such as mechanical engineering or engineering mechanics), be trained in FAC, and receive input from the systems engineers, plant operations, maintenance, and water chemistry departments.

Although an important ingredient in a successful FAC program, training and engineering judgment cannot substitute for other factors, such as analysis or inspection. As described above, all of the six key elements are interrelated, and must be used together, not as substitutes for one another.

2.6 Long-Term Strategy

The establishment and implementation of a long-term strategy is essential to the success of a plant FAC program. This strategy should focus on reducing FAC wear rates and focusing inspections on the most susceptible locations. Monitoring of components is crucial to preventing failures. However, without a concerted effort to reduce FAC wear rates, the number of inspections necessary will increase as the operating hours increase, due to increased wear. In addition, even with selective repair and replacement, the probability of experiencing a consequential leak or rupture may increase as operating hours increase.

3

PROCEDURES AND DOCUMENTATION

It is recommended that a comprehensive set of procedures (or instructions) be developed to define the FAC program, identify responsibilities, and control how various tasks are performed. For utilities with multiple plants, it is recommended that the procedures (or instructions) be as common to all plants as is practical. These procedures (or instructions) should be controlled documents.

3.1 Governing Document

It is recommended that a governing, corporate level document be developed to define the overall program and responsibilities. It is recommended that this document include the following elements:

- A corporate commitment to monitor and control FAC.
- Identification of the tasks to be performed (including implementing procedures) and associated responsibilities.
- Identification of the position that has overall responsibility for the FAC program at each plant.
- Communication requirements between the lead position and other departments that have responsibility for performing support tasks.
- Quality assurance requirements.
- Identification of long-term goals and strategies for reducing high FAC wear rates.
- A method for evaluating plant performance against long-term goals.

3.2 Implementing Procedures

It is recommended that implementing procedures (or instructions) be developed for each specific task conducted as part of the FAC program. These procedures (or instructions) should be organized in the manner most appropriate for the organization

of the utility and project. These procedures (or instructions) should recognize any differences between safety-related and balance-of-plant systems and large bore and small bore piping systems.

Procedures (or instructions) should be provided for controlling the major tasks of an effective FAC program:

- Identifying susceptible systems.
- Performing FAC analysis.
- Selecting and scheduling components for initial inspection.
- Performing inspections.
- Evaluating inspection data.
- Evaluating worn components.
- Repairing and replacing components when necessary.
- Selecting and scheduling locations for follow-on inspections.

Recommendations on how to implement these major tasks are provided in Section 4.

3.3 Documentation

The results of the major decisions and tasks should be documented, and appropriate records should be maintained. It is recommended that a report be prepared for each inspection outage. This report should identify the components inspected and justify the basis for their selection, (*i.e.*, predictive ranking, industry experience, engineering judgment), the results of those inspections, and an evaluation and disposition of worn components. The plant database of inspection and replacement history should be updated after every outage.

4

RECOMMENDATIONS FOR FAC TASKS

4.1 Definitions

As used in the remainder of this document, the following definitions apply:

Predictive Methodology - A predictive methodology uses formulas or relationships to predict the rate of wall thinning and total amount of wall thinning to date in a specific piping component such as an individual elbow, tee, or straight run. The predictions need to be based on factors such as the component geometry, material, and flow conditions. An example of a predictive methodology is the Chexal-Horowitz correlation incorporated in the CHECWORKS™ code (reference 9).

A predictive methodology should incorporate the following attributes:

- Take into account the geometry, temperature, velocity, water chemistry, and material content of each component.
- Address the range of hydrodynamic conditions (*i.e.*, diameter, fitting geometry, temperature, quality, and velocity) expected in a nuclear power plant. It is desirable to have the ability to calculate the flow and thermodynamic conditions in lines where only the line geometry and the end conditions are known.
- Consider the water treatments commonly used in nuclear power plants. The water chemistry parameters that should be addressed are the pH range, the concentration of dissolved oxygen, the pH control amine used (PWR only), the hydrazine concentration (PWR only), and the main steam line oxygen content (BWR only). It is particularly desirable to have a method of calculating the local chemistry conditions around the steam circuit.
- Cover the range of material alloy compositions found in nuclear power plants.
- Use the hydrodynamic, water chemistry, and materials information discussed above to predict the FAC wear rate accurately. To do this, the model may be based on laboratory data scaled to plant conditions. The model should be validated by comparing its predictions with wear measured in power plants.

Recommendations for FAC Tasks

- Provide the user with the wear rates of components and the time remaining before a specified minimum wall thickness is reached. Various rankings will probably be provided as part of these calculations.
- Provide the capability to use measured wear data to improve the accuracy of the plant predictions.
- The developer of the predictive methodology should also periodically review the accuracy of the predictive correlations and refine it as necessary.

Predictive Plant Model - A Predictive Plant Model is a mathematical representation of the power plant's FAC susceptible lines and systems. Typically it utilizes a computer code which incorporates the attributes defined above. The Predictive Plant Model should also be developed on a component-by-component basis using a logical and unique naming convention for each component.

It is recommended that wherever possible, the Predictive Plant Model utilize the results of wall thickness inspections to enhance the FAC predictions. In CHECWORKS™, this is called a Pass 2 analysis.

Analysis Line - An Analysis Line is one or more physical lines of piping that have been analyzed together in the Predictive Plant Model. In CHECWORKS™ Pass 2 analyses, they utilize a common line correction factor and is called a CHECWORKS™ run.

4.2 Identifying Susceptible Systems

4.2.1 Potential Susceptible Systems

The first evaluation task in the plant FAC program is to identify all piping systems, or portions of systems, that could be susceptible to FAC. FAC is known to occur in piping systems made of carbon and low-alloy steel with flowing water or wet steam. All such systems should be considered susceptible to FAC. The plant line list and Piping and Instrumentation Drawings (P&IDs) can be used to ensure that all potentially susceptible systems are included in the program. Note that lines supplied by an equipment vendor, such as gland steam lines, are often not on the plant line list. Additionally, interviews with plant operators and systems engineers are useful to identify how lines and systems are actually being used (or have been used) in the various plant operating modes. Guidelines for such interviews can be found in Reference 20.

Care should be taken to ensure that all such susceptible lines are included in the FAC program. Additionally, this evaluation should be periodically reviewed to ensure that it is kept current with plant design changes and ways that systems are being operated.

4.2.2 Exclusion of Systems From Evaluation

Some susceptible systems, or portions of systems, can be excluded from further evaluation due to their relatively low level of susceptibility. Based on both laboratory and plant experience, the following systems can be safely excluded from further evaluation:

- Systems of stainless-steel piping, or low-alloy steel piping with nominal chromium content equal to or greater than 1-1/4 % (high content of FAC resistant alloy). This exclusion pertains only to complete piping lines manufactured of FAC-resistant alloy. If some components in a high-alloy line are carbon steel (e.g., the valves), then the line should not be excluded. Also, in lines where only certain components or sections of piping have been replaced with a FAC-resistant alloy, the entire line, including the replaced components, should be identified as susceptible and analyzed. Note that high chromium materials do not necessarily protect against other damage mechanisms, especially cavitation and liquid impingement erosion. Thus, if the wear mechanism has not been identified it is not prudent to exclude the replaced components from the inspection program.
- Superheated steam systems with no moisture content, regardless of temperature or pressure levels. However, drains, traps, and other potentially high-moisture content lines from superheated steam systems should not be excluded automatically. Further, experience has shown that some systems designed to operate under superheated conditions may actually be operating with some moisture in off-normal or reduced power level conditions. Care must be exercised not to exclude such systems.
- Systems with high levels of dissolved oxygen (oxygen > 1000 ppb), such as service water, circulating water, and fire protection.
- Single-phase systems with a temperature below 200°F (low temperature). Caution—if measurable wear is identified in nearby piping operating slightly above 200°F, it is recommended that the system's exclusion be reconsidered. There is no temperature exclusion limit that can be recommended for two-phase systems. Note that other damage mechanisms, such as cavitation, are predominant below 200°F and need to be taken into account. However, this document does not address these other damage mechanisms.
- Systems with no flow, or those that operate less than 2% of plant operating time (low operating time); or single-phase systems that operate with temperature >200°F less than 2% of the plant operating time. Caution—if the actual operating conditions of the system cannot be confirmed (e.g., potential leaking valve, time of system operation cannot be confirmed), or if the service is especially severe (e.g., flashing flow), that system should not be excluded from evaluation based on operating time

Recommendations for FAC Tasks

alone. A further caution—some lines that operate less than 2% of the time have experienced damage caused by FAC. These lines include Feedwater Recirculation, startup condensate lines, High Pressure Coolant Injection (HPCI), and Reactor Coolant Inventory Control (RCIC). Such lines should be excluded only if no wear has been observed and continued operation under existing parameters is assured.

- Care should be taken not to exclude piping downstream of leaking valves or malfunctioning steam traps⁷. Leaking valves and steam traps can be identified using means such as infrared thermography or thermocouples, often performed as part of a plant thermal performance evaluation.

It is recommended that a list be developed of the systems excluded from the FAC program and the basis for their exclusion. This list should be appropriately documented and reviewed. It has proven useful to have plant operating personnel review the list of excluded systems.

Systems should not be excluded from evaluation based on low pressure. Pressure does not affect the level of FAC wear. Pressure only affects the level of consequence should a failure occur. A failure in a low-pressure system could have significant consequences (e.g., failure in a low-pressure extraction line). Also, arbitrary ranges of velocity or other operating conditions should not be used to exclude a system from evaluation.

The systems excluded by these criteria will not experience significant FAC damage over the life of the plant. However, it should be noted that such systems could be susceptible to damage from other corrosion or degradation mechanisms. These include cavitation erosion, liquid impingement erosion, intergranular stress corrosion cracking (IGSCC), microbiologically-influenced corrosion (MIC) and solid particle erosion. These mechanisms are not part of a FAC program and should be evaluated separately. In addition, the list of excluded systems should be periodically reviewed to ensure that the effects of any changes in operating practice or plant modifications have been appropriately considered and addressed.

4.2.3 Prioritize Systems For Evaluation

The list of susceptible systems for evaluation will be large. All of these systems must be evaluated. However, if time or resources are limited, it may be necessary to prioritize the scheduling of evaluations. The following is a reasonable, first-order listing of priorities:

⁷ Following the repair of any leaking valve or steam trap, and inspection of the downstream piping, the downstream piping can again be excluded from the FAC program provided that it meets the exclusion criteria provided herein.

1. Large-bore piping.
2. Susceptible small-bore piping with the most significant consequences of failure.
3. The remaining small-bore piping.

A failure in a large-bore piping system has potentially more significant consequences to plant and personnel safety and should be given first priority. Analysis and inspection of all susceptible large-bore piping systems is recommended. At minimum, initial inspections of large-bore systems should be conducted at the next scheduled refueling outage, if they have not yet been performed. For purpose of FAC evaluation, large-bore piping is defined as piping with a nominal diameter of greater than two (2) inches. Recommendations are provided in Subsections 4.3 through 4.8 for addressing large bore piping.

Although the consequences of failure may be less, problems with small-bore piping in general, and socket-welded fittings in particular, have been experienced. FAC-related leaks and ruptures, some resulting in plant shutdowns, have been reported in small-bore lines. For the purpose of FAC evaluation, small-bore piping is defined as both butt-welded and socket welded piping with a nominal diameter of less than or equal to two (2) inches.

The number of inspections performed for small bore piping is utility dependent. Economics could determine the extent of inspections performed versus wholesale replacement with FAC-resistant materials. A recommended program for small bore piping is provided in Appendix A.

4.3 Performing FAC Analysis

Once the susceptible, large-bore piping systems have been identified, it is recommended that, where feasible, a detailed FAC analysis be performed for each system using a predictive methodology such as CHECWORKS™. The purpose of this analysis is to predict the FAC wear rate and to determine the remaining service life for each piping component, including uninspected components. Utilities may select any analytical tool that covers the necessary plant design, operating, and water chemistry conditions.

4.4 Selecting And Scheduling Components For Inspection

4.4.1 Initial Inspection

An initial inspection is recommended to determine the level of plant FAC susceptibility, to identify components with unacceptable damage, to collect data to determine FAC trends, and to enhance the Predictive Plant Model with inspection data so as to more accurately predict future wear.

For these recommendations, the initial inspection is defined as the first inspection outage at which the inspection locations for a given "Analysis Line"⁸ were selected based upon a Predictive Plant Model. All operating U.S. nuclear power plants have a FAC program in place and have conducted some inspections. However, experience has shown that until a comprehensive analysis of all susceptible systems has been completed, a high degree of confidence cannot be established that all highly susceptible locations have been identified and are being monitored to prevent leakage or rupture. It is recommended that, where feasible, a FAC analysis be performed for each large bore susceptible system using a Predictive Plant Model to help select the inspection locations. The components selected by this process that have not been inspected previously should be inspected at the next scheduled plant outage.

Components are selected for the initial inspection by means of a three-step process for each Analysis Line:

1. Select a sample of the most potentially susceptible components from both the ranking analysis and plant and industry experience.
2. Conduct inspections of this sample. If any of these inspections reveal significant FAC wear, expand the sample to identify significant wear in other components.
3. As the sample inspections are completed, determine the measured wear of each of those components. Enter this wear into the Predictive Plant Model to update the ranking model to a line-specific predictive model and predict the FAC wear rates. Utilize these predicted wear rates to calculate the remaining FAC service life for each component in the Analysis Line. See Subsection 4.7.3 for the method of calculating predicted remaining service life. Resolve those components not already inspected as part of steps (1) and (2) above, for which the analysis predicts a service life of less than the time to the next inspection outage plus a reasonable safety factor. The NUMARC Guidelines (reference 3) recommended a safety factor of 10% on time.

⁸ See definition of analysis line in Subsection 4.1.

It is important that data concerning past replacements and leaks (wear = initial thickness minus remaining thickness at time of leak) also be included in the model.

Those components not inspected are, by definition, acceptable for continued service. Service life for these components will exceed the time to the next inspection outage. Those components that were inspected because of short service life should be reevaluated using the measured data, or repaired or replaced as described in Subsection 4.8.

Recommendations for selection of components for the initial sample, and expanded sample, if necessary, are as follows:

4.4.1.1 Sample Selection

The following recommendations are made for selecting components for the inspection sample of each Analysis Line:

1. Select a sample from the components identified in the wear ranking as having the highest relative wear. To the extent practical, the sample should include components from each geometry type present in the Analysis Line (e.g., elbows, reducers, expanders, tees, valves, orifices, equipment nozzles, piping downstream of other components, etc.). Engineering judgment should be employed to ensure that the most representative sample of the items with the highest probability of damage be examined. For example, if the three highest-ranked components are elbows, and the first tee in the rankings is the sixth highest ranked item, then that tee should be inspected in preference to the third ranked elbow. However, if the highest ranked tee is the hundredth item, it should not replace the third ranked elbow.
2. Select one or more components with the shortest relative remaining service life from the time rankings, if they are not included in sample of (1) above.
3. A minimum of one component should be selected from each parallel train in a multi-train line. These components should be in similar locations for the purpose of comparing results. It is recommended that this location be one of the highest ranked items in the relative wear ranking.
4. Include components immediately downstream of control valves and orifices. These locations should be included in each train of multi-train lines. Note that locations downstream of control valves and orifices are often susceptible to damage caused by cavitation or droplet impingement.
5. Minimum of one location in each two-phase line of piping. This is necessary because it is difficult to determine moisture content in two-phase lines.

Recommendations for FAC Tasks

6. Include all known and potential FAC problem areas based on past plant experience, and past experience in sister plants.
7. Consider all applicable locations known from industry experience to be high-wear areas in other plants.
8. Consider components that have been replaced in the past, the attached downstream pipe, and the next downstream component, or the upstream pipe and component if the replaced component was an expander or expanding elbow.
9. Consider unusual geometries, including field fabricated tees and laterals⁹ and locations known to have backing rings.
10. Based on EPRI experience, the size of the sample based on the wear ranking should be a minimum of 3 to 5 components per Analysis Line, depending upon the number of components in the Analysis Line, the predicted wear, and its complexity.
CAUTION: The recommended sample size of 3-5 components per Analysis Line is based on the demonstrated accuracy of the CHECWORKS™ code. If other methods are used to select inspection locations, then the sample size used should be justified.

4.4.1.2 Expanded Sample Inspection

1. When inspections of the sample selection detect significant FAC wear, the sample size for that Analysis Line should be increased to include the following:
 - a) Any component within two diameters downstream of the component displaying significant wear, or within two diameters upstream if that component is an expander or expanding elbow.
 - b) A minimum of the next two most susceptible components from the relative wear ranking in the same train as the piping component displaying significant wear.
 - c) Corresponding components in each other train of a multi-train line with a configuration similar to that of the piping component displaying significant wear.
2. When inspections of the expanded sample of (1) above detect additional components with significant FAC wear, the sample should be further expanded to include:

⁹ Special attention is recommended for field fabricated tees and laterals as they sometimes have protuberances into the flow stream (increasing local turbulence) and they often lack structural reinforcement.

- a) Any component within two diameters downstream of the component displaying significant wear, or within two diameters upstream if that component is an expander or expanding elbow.
 - b) A minimum of the next two most susceptible components from the relative wear ranking in the same train as the component displaying significant wear.
3. When inspections of the expanded sample of (2) above detect additional components with significant wear, the sample expansion of (2) above should be repeated until no additional components with significant wear are detected.

The above selection process should be reviewed with other personnel involved in the implementation of the FAC program.

4.4.1.3 Inspection Locations for Lines with Uncertain Operating Conditions

Certain large bore systems, or portions of systems, such as auxiliary steam and gland steam, may have unknown or widely varying operating conditions which prevent the development of reasonably accurate analytical models. These lines are sometimes called susceptible non-modeled lines. Inspection locations on these lines should be conservatively selected using a combination of engineering judgment, industry experience, and plant experience.

The recommendations provided in A5.2 are applicable for selecting initial inspection locations for susceptible non-modeled large bore lines. It is recommended that special consideration be given to the following locations:

- Downstream of orifices
- Downstream of flow control valves and level control valves
- Nozzles
- Tees and laterals, particularly field fabricated tees and laterals
- Complex geometric locations such as components located within two diameters of each other (e.g., an elbow welded to a tee)
- Components with backing rings and counterbores
- Components downstream of replaced components (upstream if expander), and components that have been replaced in the past if not upgraded to resistant material

Recommendations for FAC Tasks

If initial inspections detect significant FAC caused thinning, then the inspection sample should be expanded using the criteria of Subsection 4.4.1.2 (1) (a) and (c).

4.4.2 Second Inspection

A second inspection should be conducted for each Analysis Line. The purpose of the second inspection is to:

1. Confirm the results of the first inspection.
2. Obtain data for trending wear. This is done by inspecting some of the previously inspected, highly-ranked components.
3. Inspect those components with a short remaining service life to confirm that all components are suitable for continued service.

The timing of the second inspection should be conservatively selected considering results from the first inspection, predictions of the Predictive Plant Model, structural margins, presence of any known aggravating conditions (e.g., leaking, flashing, or cycling valves), potential consequences of failure, and plant and industry experience. For example, lines with high wear rates or low structural margins should be reinspected at the next refueling outage.

It is recommended that the following components be included in the second inspection for each Analysis Line:

1. A minimum of three components from the initial inspection having the most FAC wear. This will help confirm predictions made by the Predictive Plant Model and verify the inspection and data acquisition systems used.
2. A representative sample of components for which a Predictive Plant Model enhanced by inspection data shows a remaining service life of less than the amount of time until the next scheduled inspection. This situation can occur in both previously inspected components as well as non-inspected components. See Subsection 4.7.3 for calculations of predicted remaining service life.

The sample needs to represent factors such as component type, location, upstream influences, train where located, size, operating conditions, etc. For example, results of an inspection of one elbow closely located on the same train with two other elbows (e.g., same predicted wear rate and remaining service life) could serve to represent all three elbows. However, three otherwise identical elbows located on different trains should not be qualified by one inspection.

3. Consideration should also be given to inspecting problem areas that have been experienced at other power plants since the initial inspection.

Regardless of the analytical method used, the analysis should be updated and the revised model used to predict the future FAC wear rates.

4.4.3 Follow-On Inspections

Inspections following the second inspection should be scheduled as necessary to monitor plant susceptibility and to inspect wearing components prior to the end of their predicted service life. For each Analysis Line, the interval until the next inspection outage should be based on the results of the prior inspection and any changes in plant design, operating conditions, and water chemistry since then. Industry experience with problem areas in other plants should also be considered.

It is recommended that the next inspection for each component be scheduled for no later than the normally scheduled refueling outage preceding the end of the predicted FAC service life of the component plus an appropriate safety factor. At that outage, it is recommended that the following components, at minimum, be included for inspection:

1. A representative sample of components for which a Predictive Plant Model enhanced by inspection data shows a remaining service life of less than the amount of time until the next scheduled inspection outage, with an appropriate safety factor.

The sample needs to represent factors such as component type, location, upstream influences, train where located, size, operating conditions, etc. For example, results of an inspection of one elbow closely located on the same train with two other elbows (e.g., same predicted wear rate and remaining service life) could serve to represent all three elbows. However, three otherwise identical elbows located on different trains should not be qualified by one inspection.

2. A minimum of the highest-wear component found in the previous inspection, if it has not already been replaced.

In addition, the following components should be considered for inspection:

1. Straight pipe and the next downstream component of previously replaced components, or the upstream pipe and next component if the replaced component was an expander or expanding elbow.
2. Susceptible piping components immediately downstream of control valves and orifices that showed wear from previous outage inspections for trending of the measured wear.

Recommendations for FAC Tasks

3. Areas that have experienced problems at other plants since the previous inspection.
4. Components with high predicted or measured wear. High wear tends to increase turbulence, which can accelerate the wear rate.
5. To confirm predictions, consideration should also be given to periodically inspecting previously repaired and replaced components, unless the replacement components are fabricated of a FAC-resistant material.
6. Components (including straight pipe) immediately downstream of components containing chromium greater than 0.1%.

It is recommended that the user monitor plant design and operational changes, and any leaking valves and steam traps, between scheduled inspection outages and update the susceptibility analysis (see Subsection 4.2) and the FAC analysis as appropriate.

If inspection results are consistent with predictions, no further inspections are necessary during this outage. Those components that were not inspected are, by definition, acceptable for continued service, as service life will exceed the amount of time until the next inspection outage. Those components that were inspected due to short remaining service life, and the other components these components represent if an inspection sample was used, should be reevaluated using measured data, or repaired or replaced as described in Subsection 4.8.

If inspection results are *unexpected and inconsistent* with predictions, the reasons for those inconsistencies should be investigated. An updated FAC analysis should be performed, and additional inspections conducted and material determinations made as appropriate.

The above process for follow-on inspections should be repeated for the life of the plant.

4.5 Performing Inspections

4.5.1 Inspection Technique

Components can be inspected for FAC wear using ultrasonic techniques (UT), radiography techniques (RT), or by visual observation. Both UT and RT methods can be used to investigate whether or not wear is present. However, the UT method provides more complete data for measuring the remaining wall thickness. RT is commonly used for socket-welded fittings. RT has one advantage of providing broad coverage with a visual indication of any wall loss. Additionally, RT can be performed without removing the pipe insulation and during plant operation, providing cost and outage time savings in certain situations. Nearly all utilities are using the manual UT method

with electronic data loggers for performing most of the large-bore inspections. Visual observation is often used for examination of very large diameter piping (e.g., crossunder and crossover piping), followed by UT examinations of areas where significant damage is observed or suspected. Reference 12 provides details of various inspection methods.

For large-bore piping, the recommended UT inspection process consists of marking a grid pattern on the component and using the appropriate transducer and data acquisition equipment to take wall-thickness readings at the grid intersection points. If the readings indicate significant thinning, the region between the grid intersection points should also be scanned, or the size of the grid reduced to identify the extent and depth of the thinning.

Although scanning the entire component and recording the minimum thickness is not recommended, scanning within grids and recording the minimum found within each grid square is an acceptable alternative to the above method.

The inspection data is used for three purposes:

1. To determine whether the component has experienced wear and to identify the location of maximum thinning.
2. To ascertain the extent and depth of the thinning.
3. If data from multiple inspections is available, to evaluate the wear rate and wear pattern to identify any trends.

To attain all three of these objectives, it is recommended that the component be inspected using a complete grid with a grid size sufficiently small as not to miss worn areas (see Subsection 4.5.3). Although scanning will meet the first two objectives, it will not provide sufficient data to determine component wear rates or to develop sufficient data to perform a detailed stress analysis of a worn component. Further, scanning is of limited use in trending the wear found.

High-temperature paints, china markers, or other marking devices should be used to identify the grid intersection points where the measurements will be taken. This will ensure that future inspections can be repeated at the same locations. It is good practice to mark at least one location, such as the grid origin, with a low stress stamp or an etching tool. This provides a means of re-establishing the grid if the markings are obscured. Note that approved marking materials should be used when gridding components. Templates may also be used to achieve repeatable measurements.

Recommendations for FAC Tasks

FAC has also been observed in pressure vessels and tank walls. Inspection approaches used for this situation are normally internal visual (similar to crossunder piping), and external UT.

When a component is to be replaced with another component made of a non-FAC resistant material, the new component should be appropriately gridded and baseline UT data obtained. The new component should also be examined visually to observe the eccentricity, surface, roughness, local thinning—such as is caused by depressions in the surface, etc. These data should be recorded and will provide a good baseline for determining future component wear. Additionally, if there is any evidence that some of the wear may have been caused by a mechanism other than FAC (e.g., cavitation or droplet impingement), then consideration should also be given to developing an appropriate inspection program to address the suspected phenomenon.

The inspection grid should have a unique identification for each measurement location. For compatibility with the CHECWORKS™ computer code, if it is used, it is recommended that letters be used to designate circumferential locations, and numbers used to designate axial locations on grids. It is also recommended that the origin of the grid be on the upstream side of the component.

For small-bore piping, there are no standardized inspection methods. The most common approaches are:

- Gridding or scanning the downstream piping and expanding to the component if substantial wear is found.
- Gridding the component and recording the readings.
- Scanning the component and recording the minimum measured on the entire component or in quadrants.
- Using RT methods.

Further guidance is provided in Appendix A.

4.5.2 Grid Coverage

Experience has shown that it is very difficult to predict where the maximum wear will occur in a given component. (For the purpose of this section, a component refers to both fittings and straight pipes.) To ensure that the maximum FAC wear can be detected, the UT grid should fully cover the component being inspected. A full-coverage grid also provides a good baseline for future inspections. As wear can spread over time, a partial grid, even if larger than the original wear area, may be too small to ensure that the full extent of the wear can be detected in the future.

It is also beneficial to inspect the area on both sides of each pipe-to-component weld. It is desirable to start the grid line on both sides of the weld, as close as possible to the toe of the weld, in order to locate potential thin areas adjacent to the weld. This will help detect the presence of backing rings, the use of counterbore to match the two inner surfaces, or the localized wear that is sometimes found adjacent to welds¹⁰. Having data on the connected pipe can also be helpful in evaluating whether variation of wall thickness in the component is FAC wear or fabrication variations. In many cases, the grid in the counterbore region will have to be evaluated separately.

It is also suggested that when fittings are welded directly to fittings, the weld area on the downstream fitting be inspected. This will provide the same benefits as discussed above.

The results of EPRI tests, as well as the evaluation of data from a large number of power plant inspections, show that FAC can also extend into the piping downstream of a component. Consequently, it is recommended that the inspection grid extend from two grid lines upstream of the toe of the upstream weld to a minimum of two grid lines or six inches, whichever is greater, beyond the toe of the downstream weld. If there is a straight pipe immediately downstream of the examined component, and the measured wall thickness in the pipe is decreasing in the downstream direction, or if significant wear is present, the inspection grid should be continued downstream until an increasing thickness trend is established. If expanded inspections are performed on the downstream pipe, then the pipe should be separately evaluated for acceptance.

Test results also show that in the case of expanders (or diffusers) and expanding elbows, FAC can occur upstream of the component as well. It is recommended that for these components the wall thickness in the upstream pipe be measured. The grid should be extended upstream 2 grid lines or six inches, whichever is greater. The grid should be expanded further upstream if necessary.

Maximum wear in straight pipe downstream of components typically occurs within two diameters of the connecting weld. Consideration should be given to extending the grid two diameters downstream (or two diameters upstream for expanders and expanding elbows), at least for the first two inspections. This may avoid extra inspection time during the outage to investigate the first two grids and then having to inspect further downstream.

Valves, orifices, equipment nozzles, and other like components cannot be inspected completely with UT techniques due to their shape and thickness. They need to be treated differently. Experience has shown that FAC wear in these components can be

¹⁰ This effect has been most frequently observed at locations where a carbon steel component is downstream of a more resistant component (chromium $\geq 0.1\%$). See reference 24.

gauged from wear that may be present in piping located immediately downstream. It is therefore recommended that for these components the inspection grid be placed on the downstream pipe for a distance of two diameters downstream of the connecting weld, and, if possible, one or two grids in the component itself. If significant wear is detected in the downstream pipe, the component should also be examined. This approach for valves, orifices and equipment nozzles is only applicable if the piping downstream is manufactured of material with equal or higher susceptibility (equal or lower chromium content), and has not been repaired or replaced. A combination of UT, RT and/or visual techniques are typically utilized to inspect valves, orifices and equipment nozzles.

4.5.3 Grid Size

To be compatible with CHECWORKS™, if it is used, grid lines must be either perpendicular or parallel to the flow. For elbows, the lines perpendicular to the flow (inspection bands) are radial lines focusing on the center of curvature. This results in the same number of grid intersection points on both the intrados and the extrados of an elbow. The suggested grid layout is shown in Figure 4-1.




Figure 4-1
Grid Layout for an Elbow

It is important that the grid size (maximum distance along the component surface between grid lines) be small enough to ensure that the thinned region can be identified. Experience and plant data have shown that the grid size should be such that the maximum distance between grid lines is no greater than $\pi D/12$, where D is the nominal outside diameter. The grid size need not be smaller than 1 inch, and should not be larger than 6 inches. The following table illustrates the maximum grid sizes for standard pipe sizes. The user should select convenient grid sizes equal to or smaller than those tabulated for the pipe sizes of interest.

Recommendations for FAC Tasks

Table 4-1
Maximum Grid Sizes for Standard Pipe Sizes

<u>Pipe Size (inch)</u>	<u>Outside Diameter (inch)</u>	<u>Maximum Grid Size (inch)</u>
2	2.375	1.00
3	3.500	1.00
4	4.500	1.17
6	6.625	1.73
8	8.625	2.25
10	10.750	2.81
12	12.750	3.33
14	14.000	3.67
16	16.000	4.19
18	18.000	4.71
20	20.000	5.23
24	24.000	6.00
>24	-----	6.00

The above grid size is sufficient to detect the presence of wear, but may not be small enough to determine the extent and maximum depth of that wear. Therefore, where inspections reveal FAC wall thinning, the grid size should be reduced to a size sufficient to map the depth and extent of the thinned area. A grid size of one half the maximum size should be sufficient for mapping.

Because of the importance of grid layout in the inspection process and in the interpretation of the obtained data, it is important that the grid layouts used be well thought out and not be changed arbitrarily. This will provide the best possible value from the data sets obtained.

Although the above recommendations should generally be used, occasionally special circumstances—most particularly high radiation fields—may justify the use of a larger grid. If larger grid spacings are used, then the evaluation of the data, the planning of future inspections, and the repair evaluations should be done with additional conservatisms.

4.5.4 Measuring Trace Alloy Content

It is well known that the presence of small amounts of chromium—and to a lesser extent copper and molybdenum—will dramatically reduce the rate at which FAC occurs. Measurements of trace alloy content can be factored into the Predictive Plant Model on a component-by-component basis to improve the accuracy of predictions and to ensure that the inspection program is directed at the fittings most likely to fail. These measurements are particularly useful in cases where the measured wear is substantially less than the predicted wear. This will help in both understanding the reason for the differences as well as improving the accuracy of a Predictive Plant Model. Note that material libraries built into computer codes such as CHECWORKS™, normally use minimum specified values for the alloy content. If alloy measurements are used, the analyst must confirm that the measurements are accurate enough to ensure that the predictions remain conservative.

4.6 Evaluating Inspection Data

4.6.1 Evaluation Process

The purpose of evaluating the inspection data is to determine the location, extent, and amount of total wear for each inspected component. The evaluation process is complicated by several factors, including the following:

- Unknown initial wall thickness (if baseline data was not taken).
- Variation of as-built thickness along the axis and around the circumference of the component.
- Inaccuracies in NDE measurements.
- The possible presence of pipe to component misalignment, backing rings, or the use of counterbore to match two surfaces.
- Data recording errors or data transfer errors.
- Obstructions that prevent complete gridding (*e.g.*, a welded attachment).

The challenge is to minimize the effect of these problems by applying uniform evaluation methods and utilizing engineering judgment.

The large amount of inspection data can present a substantial data management problem. To manage the data, it is recommended that a scheme be utilized to organize and maintain the data logger files. A database should be used to store past inspection

data and contain provisions to accommodate future inspection data. The database will provide an efficient means of organizing and accessing the data.

The evaluation process consists of reviewing the inspection data for accuracy, determining the total wear, and determining the wear rate for each inspected component. These processes are described below.

4.6.2 Data Reduction

The inspection data should be carefully reviewed to identify any data that is judged to be in error. Erroneous data points should preferably be reinspected, or if necessary, eliminated to obtain valid readings. High and low readings should be compared to adjacent readings to evaluate their validity. One high or low reading in an area of consistent thickness may indicate an erroneous reading. Finally, depending on the component type, the variation in thickness attributable to manufacturing variations should be separated from the FAC wear. Reviewing data from the attached upstream and downstream pipe can be helpful. Elbows, tees, reducers and expanders are examples of components in which there is significant variation in thickness due to the manufacturing process. The presence of backing rings and counterbore should be noted so that these effects can be excluded.

Once the data set is acceptable, any wear region on the component should be identified. The location of a potential wear region should be compared with the component orientation, flow direction, and attached piping. The variation in thickness within this region should be compared to the adjacent region to confirm the existence of wear. If data from previous inspections are available, they should be compared with the current measurements, and wear trends/patterns should be identified.

4.6.3 Determining Initial Thickness and Measured Wear

Wear evaluations fall into two categories. The first category includes those components for which baseline (pre-service) thickness data are available. The second category includes those components for which no baseline data exists. The method used for calculating the component maximum wear (the maximum depth of wall thinning since the component was installed or repaired) will be different for the second case as the initial thickness is unknown.

There are four methods commonly used for determining the wear of piping components from UT inspection data¹¹. The methods are:

¹¹ Validity of the methods to determine wear and estimate the component's initial thickness is based on grid sizes and configurations consistent with that recommended in Subsection 4.5.

- Band Method
- Area Method
- Moving Blanket Method
- Point to Point Method

Three of the methods—band, area and blanket—also estimate the component's initial thickness and can be used to evaluate components with single outage inspection data. All the methods are predicated on the theory that the wear caused by FAC is typically found in a localized area or region. The methods are described below:

Band Method

The Band Method is predicated on the assumption that wear caused by FAC is localized. As such, the thickness variations observed around circumferential bands is an indication of the wear experienced by the component. By successively evaluating these circumferential bands, the component wear is determined by the maximum variation observed from all such bands.

The band method divides a component into circumferential bands of one grid width each. Each band is in a plane perpendicular to the direction of the flow. Figure 4-2 shows a cross sectional view of a circumferential band on a component with a localized wear region.




Figure 4-2
Example of Band Method

The initial thickness of each band is assumed to be the larger of the nominal thickness or the maximum thickness found in the band (t_{max}). The band wear is the initial thickness minus the minimum thickness found in the band (t_{min}).

For each band: $t_{init} = \text{larger of } t_{nom} \text{ or } t_{max}$

$$\text{Wear} = t_{init} - t_{min}$$

The component maximum wear is the largest of the individual band wear values. The component initial thickness is then the initial thickness from the band of maximum wear. The use of the nominal wall thickness in the above calculations addresses the possibility that an entire band may have thinned uniformly, which may have caused most or all of the thickness to be under the nominal wall thickness.

A variation of the Band Method is the Strip Method. The Strip Method applies the same methodology to determine wear but utilizes longitudinal strips instead of circumferential bands in evaluating the maximum difference in thickness.

Both the band and the strip method are based on the assumption of a uniform initial thickness of the band or strip (e.g., no manufacturing variation). Any such variation is reflected in the calculated wear. An appropriate method should thus be used to determine the measured wear of components suspected to have manufacturing variations (e.g., elbows). Further information is contained in reference 9.

Area Method

The Area Method is a combination of the Band and Strip methods in which a local rectangular region, identified as the wear region, is evaluated for wear. It is based on the assumption that the entire wear area, and a thickness representative of the initial thickness, is encompassed within the rectangular region. More than one area can be defined for a given component. The initial thickness of each area is assumed to be a larger of the nominal thickness or the maximum thickness found in the area. The area wear is the initial thickness minus the minimum thickness found in the area. An example of the Area Method is shown in Figure 4-3.




Figure 4-3
Example of Area Method

For each area: $t_{init} = \text{larger of } t_{nom} \text{ or } t_{max}$

$$\text{Wear} = t_{init} - t_{min}$$

The component maximum wear is the largest of the individual area wear values. The component initial thickness is then the initial thickness from the area of maximum wear. The use of nominal wall thickness in the above calculations addresses the possibility that an entire area may have thinned uniformly, which may have caused most or all of the thickness to be under the nominal wall thickness.

Recommendations for FAC Tasks

Moving Blanket Method

The Moving Blanket Method is a refinement of the Area Method. It automates the process of identifying the region of maximum wear and attempts to minimize the effect of measurement errors. The Moving Blanket Method was developed by reviewing extensive amounts of component data to identify a method that would provide realistic, yet somewhat conservative estimates of initial thickness and wear. The method that was developed consists of placing a predetermined wear area or "blanket" of certain dimensions over the grid data. See Figure 4-4. The data that is within each blanket is evaluated to estimate both the initial thickness and the wear. The blanket is then moved to another location on the component and the process is repeated. The process continues until all possible locations on the component have been covered.




Figure 4-4
Example of Moving Blanket Method

Point-to-Point Method

The Point-to-Point Method can be used when data taken at the same grid locations exists from two or more outages (or baseline data plus data from one or more outages). In such a case, it is possible to obtain a difference in thickness readings at each of the grid locations. In summary, the wear at each grid location is the thickness taken at the earlier inspection minus the thickness taken at the later inspection. The largest of the grid wear values is the component maximum wear between the two outages. The Point-to-Point Method does not estimate the initial component thickness.

Summary

It is the responsibility of the owner to select the evaluation method for each set of UT data. Further information on each of these methods, along with guidance for evaluating various types of components including counterbore areas, is provided in the modeling guidelines of reference 9.

4.7 Evaluating Worn Components

4.7.1 Acceptable Wall Thickness

A component can be considered suitable for continued service if the predicted wall thickness, t_p , at the time of the next inspection is greater than or equal to the minimum acceptable wall thickness, t_{accpt} .

$$t_p \geq t_{accpt}$$

where,

t_p = Predicted remaining wall thickness at a given location on the component

t_{accpt} = Minimum acceptable wall thickness at location of t_p

Note that t_p can be rewritten in terms of the current thickness, t_c , as:

$$t_p = t_c - \text{"predicted wear"}$$

or

$$t_p = t_c - (R \times T \times SF)$$

where,

t_c = Current wall thickness at location of t_p

R = FAC wear rate at location of t_p

T = Time until next inspection

SF = Safety Factor

The wear rate and the amount of wear varies throughout a component. However, it is recommended that the component maximum wear rate be assumed to occur throughout the wear rate the component, giving a predicted future thickness profile as shown in Figure 4-5. Note that this approach is conservative, as the amount of wear is overstated at all locations other than the point of maximum wear. See Subsection 4.7.2 for a method to determine the component maximum wear rate. An acceptable approach

Recommendations for FAC Tasks

to determine the future thickness profile would be to use the local wear rate from the band or area under consideration, combined with engineering judgement and a higher factor of safety than if a uniform wear rate is assumed to occur.




Figure 4-5
Predicted Thickness Profile

For susceptible components that have not been inspected, the predicted thickness should be used to calculate the lifetime of the component. The component nominal wall thickness should be utilized as the initial thickness unless another value can be justified.

A reasonable safety factor should be applied to the predicted wear rates to account for inaccuracies in the FAC wear rate calculations. This can also provide a mechanism by which the analyst may apply engineering judgment in setting the interval for reinspection. As the plant program matures and several outages of good inspection data are collected, the safety factor can be changed based on the use of actual inspection data.

The minimum acceptable wall thickness for each component should be calculated. For ASME Class 1, 2 and 3 pipe, component acceptance criteria are typically based on the ASME Boiler and Pressure Vessel construction code of record for the plant (reference 13), or using Code Case N-597¹²(reference 15), which is based on EPRI report NP-5911 (reference 16). For ANSI B31.1 (reference 14) pipe, component acceptance criteria are typically based on the construction code of record for the plant or from guidance provided by industry standards such as Code Case N-597.

It is recommended that the calculation of t_{accept} be performed by an engineer with experience in piping stress analysis.

¹² Use of Code Case N-597 may require review and approval by the enforcement and regulatory authorities.

4.7.2 Maximum Wear Rate

The Predictive Plant Model should be used to predict the future maximum wear rate for every component analyzed, whether inspected or not. For those components that have been inspected, two methods have been used to determine the wear rate directly from the inspection data.

With the first method, the component maximum wear is divided by the period of service to obtain the average wear rate over the component lifetime. This past rate is then assumed to continue into the future. However, this method may cause several potential inaccuracies:

1. If baseline thickness data is not available, the initial thickness is unknown. Thus the estimated wear may be considerably higher or lower than the actual wear. This effect is smoothed out in CHECWORKS™, by using several components with a statistically calculated line correction factor.
2. This method assumes that operating conditions that affect FAC wear rate, (e.g., water chemistry, plant power level) have not changed since plant startup. If changes did occur, the current wear rate could be considerably different than the average wear rate.
3. The method cannot accommodate potential future changes in operating conditions.

Figure 4-6 shows the potential for error when using an average wear rate based on inspection data and changing operating conditions for determining component lifetimes.




Figure 4-6
Potential for Error When Using Average Wear Rate Based on Inspection Data

A second method can be utilized if data from more than one inspection is available. The measured thickness at the point of maximum wear from the current outage is subtracted from the value measured at the previous outage. This difference is then divided by the time interval to obtain the average wear rate. This method is known as the point-to-point method. It has the advantage of being mechanical—the maximum wear is simply the maximum difference between two sets of readings at the same location. Note that the user does not have to estimate initial thickness of the component in order to calculate the measured wear. The difficulties in using the point-to-point method occur in cases where the wear between the outages is small. Two large numbers (wall thickness) are subtracted to obtain a small number (wear since previous outage) and then divided by another relatively small number (interval between outages) to determine the wear rate. UT measurement inaccuracies could cause significant calculation error with this method. This is illustrated in Figure 4-7. However, in most cases where inspection data from several inspection outages is available, the point-to-point method will provide more accurate determinations of wear than other methods.




Figure 4-7
Danger Of Using Wear Rate Based On Inspection Data From Two Inspections

If CHECWORKS™ is used, it is recommended that until data from several inspections are available, the CHECWORKS™ predicted “current” wear rate be used. CHECWORKS™ takes into account past and planned future operational changes and smoothes out some of the temporal variations of the input parameters. If the analyst chooses to use wear rates calculated from inspection data, they should first be compared with the predicted values. Note that the t_{crit} used for each component is defined on a global basis. Thus, t_{crit} of a given component may be different from the actual component-specific t_{accpt} value calculated by an experienced pipe stress analyst.

4.7.3 Remaining Service Life

It is recommended to determine the remaining FAC service life of each component,

where,

$$T_{life} = \text{remaining service life}$$

$$T_{life} = \frac{\text{current thickness} - \text{minimum acceptable thickness}}{\text{current wear rate} \times \text{safety factor}} \quad (\text{eq. 4-1})$$

$$T_{life} = \frac{t_c - t_{accpt}}{R \times SF}$$

Recommendations for FAC Tasks

For those components that have been inspected, it is recommended that actual measured values be used for t_c . For components not inspected, t_c can be predicted utilizing predicted wear rates,

$$t_c = t_{init} - \text{"predicted wear"} \\ = t_{init} - (T \times R \times SF)$$

where,

T = component service time to date

R = average wear rate over time T

SF = safety factor

If the predicted remaining service life is shorter than the amount of time until the next inspection, there are three options for disposition of the component:

1. Shorten the inspection interval.
2. Perform a detailed stress analysis to obtain a more accurate value of the acceptable thickness.
3. Repair or replace the component.

4.8 Repairing and Replacing Components

The following items should be considered in making replacement decisions:

- The cost and availability of replacement fittings.
- The need for skills and procedures to weld alloy steels and clad material to carbon steel.
- The pre-and post-weld heat treatments generally required for welding chrome-moly fittings¹³. This heat treatment may affect the outage schedule.
- The piping stress analysis required if a large portion of a carbon steel line is replaced with stainless steel.

¹³ Some organizations have developed justification and procedures to exempt chrome moly welds of one-half inch and less thickness from pre- and post-weld heat treatments.

- The feasibility of replacing the entire system with a more wear-resistant material.

If repair is decided upon, the weld buildup technique is commonly used for the temporary repair of balance of plant piping. Weld repairs on ASME class piping must be performed in accordance with Section XI (reference 10) requirements.

Supplementary rules for exterior weld repair are found in ASME Code Cases N-561-1 and N562-1 (references 21 and 22, respectively). However, interior weld buildup is generally preferred to exterior buildup for the following reasons:

- Interior weld repair results in a smoother internal surface. Conversely, use of exterior buildup and leaving the interior surface irregular, will tend to increase turbulence and accelerate the wear rate.
- By using interior weld repair, the resulting, smoother internal surface reduces the difficulty of making future UT inspections.
- An exterior weld buildup tends to result in a more complex state of stress.
- Exterior weld buildup has not been accepted by the NRC for the long-term repair of safety-grade piping.

However, interior weld build up is often limited by accessibility.

Temporary clamping devices are often used to make temporary repairs to balance of plant piping. Repairs to ASME class piping must be performed in accordance with Section XI (reference 10) and NRC requirements.

If repair or replacement of a component is necessary, it is recommended that the plant owner develop a strategy (e.g., replacement with a more resistant alloy) so that the wear process does not continue. A discussion of long-term options to reduce wear rates is provided in Section 5.0. The use of FAC resistant material, especially when done on a line or spool piece basis, provides the following benefits:

- Assures that FAC is eliminated in this portion of the system,
- Eliminates the need for future inspections in those portions of the line, and
- Reduces iron transport to the steam generators or reactor vessel, as a disruptive deposition on flow measurement nozzles, and to extend the life of demineralizer resin beds.

However, there are cases in which use of like-for-like (*i.e.*, non FAC resistant) material is appropriate. These cases include:

Recommendations for FAC Tasks

- The plant is now using a significantly better water chemistry or the line will experience less damaging operating conditions (e.g., a higher steam quality) such that the replacement is projected to last the remaining life of the plant.
- Procurement of a resistant material would delay plant restart. In this case, consideration should be given to upgrading the replacement with a resistant material at the next outage.
- The remaining life of the plant, including potential life extension, is such that a like-for-like replacement will perform satisfactorily.
- Life cycle costs and risk considerations associated with like-for-like replacement, including associated inspection costs, do not support change to FAC resistant material.

5

DEVELOPMENT OF A LONG-TERM STRATEGY

5.1 Need For A Long-Term Strategy

Development of a long-term strategy is recommended. The strategy should focus on reducing the plant FAC susceptibility. Optimizing the inspection planning process is important, but reduction of FAC wear rates is needed if both the number of inspections and the probability of failure are to be reduced. (See Figure 5-1.)

One mitigating approach that is sometimes used is to replace only those fittings that have experienced significant wear. This approach is satisfactory if the wear is very localized. This is the case in which the wear is concentrated downstream of a flow control valve or an orifice. In most cases, though, the wear is widespread throughout a given system. Since flow conditions and water chemistry in a given line tend to be the same, it is only a matter of time until upstream or downstream fittings will also need to be replaced. This fitting-by-fitting replacement approach is less expensive in the short term, but is generally not cost effective over the long term. Plants using this selected replacement technique have also experienced unexpected failures in components scheduled for future replacement.

Development of a Long-Term Strategy




Figure 5-1
Expected Trends for Inspections Over a Plant's Life

It is recommended that in order to achieve the long-term goals of reduced cost and increased safety, a strategy of a systematic reduction of FAC rates be adopted. Three options are available to reduce FAC wear rates. These are:

1. Improvements in materials.
2. Improvements in water chemistry.
3. Local design changes.

Material improvements can reduce the wear rate to effectively zero. Depending on the location in the system, changes to PWR water chemistry can reduce the wear rate by up to a factor of ten. For BWR's, increases to condensate oxygen can significantly reduce FAC in the feed train. Design changes will result in improvements in specific areas. These three options are discussed in detail in reference 23 and summarized below.

5.2 FAC Resistant Materials

It has been widely demonstrated that materials containing chromium are resistant to FAC damage (reference 23). Lesser improvements come from molybdenum and copper. Replacing carbon steel piping with chrome-moly alloy (SA335, Grade P11 or P22) or stainless steel (normally a 304 alloy) should alleviate FAC damage for the life of the plant. The benefit can also be achieved by coating the piping surface with a high-alloy

layer (flame spraying or weld overlay) or using a clad pipe with a high-chrome or stainless steel inner layer surrounded by a carbon steel outer layer.

Table 5-1 presents the degree of improvement associated with common piping alloys as predicted by CHECWORKS™ which is based on the data of Ducreux (reference 17). Other studies have found that the Ducreux data may underestimate the effects of chrome on FAC, particularly trace amounts of chrome. Work is continuing in this area. However, all data has shown that FAC can be effectively eliminated through material improvement.

Table 5-1
Performance of Common FAC-Resistant Alloys

<u>Material</u>	<u>Nominal Composition (Chrome & Moly only)</u>	<u>Rate_{carbon}/Rate_{alloy}</u>
P11	1.25% Cr, 0.50% Mo	34
P22	2.25% Cr, 1.00%-Mo	65
304	18% Cr	>250

Material changes can be used to replace an entire system or to repair an especially troublesome area. However, material replacement may not reduce the wear rate if the damage is caused by a mechanism other than FAC. This is the case, for instance, if the damage is caused by cavitation or liquid impingement.

5.3 Water Chemistry

Changes in plant water chemistry can reduce the rate of FAC damage. Increasing the pH at operating temperature (the hot pH) for a PWR or increasing the amount of dissolved oxygen for a BWR can reduce the rate of FAC damage significantly. Chemistry changes are attractive as they can reduce the damage rate globally, help reduce rates of iron transport and the resulting steam generator sludge, and extend the life of the demineralizers.

5.3.1 PWR Plants

5.3.1.1 Effect of pH and Amines on FAC

For PWRs, one way of achieving a higher pH at temperature is by increasing the cold (control) pH. Figure 5-2 presents a summary of the effects of changing the cold pH on FAC wear rate over a range of temperature for a typical single-phase line. As can be seen, increasing the pH reduces the FAC wear rate significantly.




Figure 5-2
Impact of Change in pH Level on FAC (As Predicted by CHECWORKS*)

Another way of achieving a higher pH at temperature is by changing the pH control amine. This is mostly related to the tendency of amines to partition in two-phase flow conditions. Volatile amines such as ammonia tend to favor the vapor phase and tend not to provide much protection to two-phase lines. Less volatile amines such as morpholine and ethanolamine (ETA) are more effective in two-phase conditions. The selection of optimum water chemistry for PWR plants is a complex decision influenced by presence or absence of copper in the system (e.g., in condenser or feedwater heater tubes), the type and capacity of the condensate polishers or demineralizers, concerns about organic acids produced by the decomposition of certain amines, and the condition of the steam generators. Considerations for selecting optimum chemistry for PWR plants is provided in the EPRI PWR Secondary Water Chemistry Guidelines (reference 18). A comparison of typical FAC wear rates at strategic locations around the secondary system is provided in Figure 5-3. Note that the comparisons shown in Figures 5-2 and 5-3 reflect a specific plant configuration and set of operating conditions, and will be different for other configurations and conditions.




Figure 5-3
Amine Comparison - Typical Conditions at the Same Cold pH

5.3.1.2 Effect of Hydrazine on FAC

Historically, PWR plants located in the United States operated at about 20 ppb of hydrazine as measured in the condensate system. This concentration was implicit in the FAC predictive model included in the CHEC, CHECMATE, and earlier versions of the CHECWORKS code (through Version 1.0E). In an effort to create more reducing conditions in the steam generators, and decrease the susceptibility of the tubes to stress corrosion cracking, many PWR plants have recently increased the concentration of hydrazine. Subsequent laboratory testing found that varying the hydrazine concentration does have an effect on FAC—this has also been confirmed by analysis of plant data.

Below about 150 ppb, a lower hydrazine concentration will decrease the rate of FAC. Above about 150 ppb, the rate of FAC decreases somewhat with an increasing hydrazine concentration. See Figure 5-4. It should be noted that this dependency is the local concentration, which can be quite different from that injected (due to decomposition to ammonia and partitioning wherever flow divides or joins, particularly in two-phase locations).




Figure 5-4
Relationship Between FAC and Hydrazine

FAC can generally be reduced by decreasing the overall quantity of hydrazine injected to the condensate system. However, this reduction must be done while maintaining sufficient reducing conditions in the steam generators to protect the tubes against stress corrosion cracking.

Another option to reduce FAC in the condensate and feedwater systems, while maintaining reducing conditions in the steam generators, is to move the hydrazine injection point to as close as practical to the steam generators. This will reduce the hydrazine concentration upstream of the injection point to only that amount returned by the heater drains and that which is passed through the condensate polishers¹⁴.

5.3.2 BWR Plants

For a BWR, there are two separate issues. These are the levels of oxygen in the feedwater and the levels of oxygen in the steam portions of the steam cycle. The amount of oxygen in the condensate and feedwater systems is primarily determined by the in-leakage of air into the condenser. If the level is too low¹⁵, it can be supplemented by direct injection of oxygen into the condensate. A comparison of typical feedwater wear rates as a function of oxygen concentration is provided in Table 5-2.

¹⁴ For a plant with full flow polishers and forward pumped heater drains, moving the hydrazine injection point next to the steam generators will nearly eliminate hydrazine in the condensate system and reduce it by about 2/3 in the feedwater system.

¹⁵ The EPRI BWR Water Chemistry Guidelines (reference 19) specify a feedwater oxygen level of between 15 and 200 ppb. From the perspective of FAC, operating at the middle to high end of this range is more desirable.

Table 5-2
Effect of Oxygen on Typical Feedwater Wear Rates

<u>Feedwater Oxygen (ppb)</u>	<u>Relative Wear Rate</u>
10	1.00
30	0.30
50	0.18
100	0.11

For the steam part of the system (extraction and drains) the oxygen level is determined by radiolysis which is occurring in the reactor core and by venting of the moisture separator/reheater and the feedwater heaters. For plants with normal water chemistry (NWC), the steam line oxygen is typically 18 ppm. For plants with hydrogen water chemistry (HWC)¹⁶, the steam line concentration will vary from about 3 to 12 ppm depending on the amount of hydrogen injected. It is normally not possible to control the oxygen levels in the steam part of the system as this level is a function of the neutron and gamma levels within the reactor core. However, if excessive venting of the moisture separator reheaters or feedwater heaters is occurring, than FAC can be reduced in the downstream piping and equipment by reducing the vent rates. The effects of varying steam line oxygen concentration on a typical BWR plant are shown in Figure 5-5. However, it should be noted that these results are for a specific plant and will vary for other plant designs.




Figure 5-5
Effects of BWR Steam Line Oxygen Concentration

¹⁶ Hydrogen Water Chemistry (HWC) is used to combat intergranular stress corrosion cracking (IGSCC) in the vessel and in the recirculation piping.

5.4 System Design Changes

In general, design changes result in only small reductions to the rate of FAC damage. For example, changing the diameter of a piping system from 12 to 14 inches will only reduce the FAC rate by about 20%. There are instances, however, where design changes can be effective:

- Increasing the pipe diameter to reduce the velocity in control valve stations. Valve stations are typically designed to accommodate the flow capacity of control valves. This typically results in a reduced diameter of about 60% of the line size and a consequent increase in the fluid velocity. This locally increased velocity has often caused damage downstream of the valve. Redesigning the valve station to reduce the local velocity and turbulence can greatly reduce the rate of FAC damage.
- In wet steam lines, the FAC wear rates can be reduced by reducing the local moisture content. This can be achieved by improving the efficiency of the existing moisture separator design or by installing additional moisture separation equipment. This will reduce the number of water droplets that impinge upon the downstream components. This method has been widely used in France and has proven to be effective in reducing the FAC damage in such components as cross-under lines and feedwater heater shells.

5.5 Summary

As can be seen from the above discussion, improved water chemistry in combination with highly resistant materials can help mitigate FAC. Utilities should evaluate these options carefully from a technical as well as a financial standpoint and make a determined effort to mitigate FAC.

6

REFERENCES

1. Electric Power Research Institute, "Erosion/Corrosion in Nuclear Power Plant Steam Piping: Causes and Inspection Program Guidelines", EPRI NP-3944, April 1985.
2. Institute of Nuclear Power Operations, Significant Operating Event Report (SOER), 87-3 March 1987.
3. Nuclear Utilities Management and Resources Council, "Working Group on Piping Erosion/Corrosion", Summary Report, June 11, 1987.
4. United States Nuclear Regulatory Commission, Generic Letter 89-08, May 1989.
5. Electric Power Research Institute, "CHEC[®] Computer Program Users Manual", NSAC/112L, Rev. 1, July 1989.
6. Electric Power Research Institute, "CHECMATE[®] Computer Program Users Manual", NSAC/145L, Rev. 1, April 1991.
7. Electric Power Research Institute, "CHEC-NDE[™] a Tool for Managing Non-Destructive Evaluation Data from Pipe Inspections", NP-7017-CCML, NSAC-149L, April 1991.
8. Electric Power Research Institute, "CHEC-T[™] Software for the Evaluation of Pipe Wall Thinning: Description and Users Manual", Report No. NP-6793-CCML, April 1990.
9. Electric Power Research Institute, "CHECWORKS[™] Computer Program Users Guide", TR-103198-P1, June 1998.
10. American Society of Mechanical Engineers, Boiler and Pressure Vessel Code, Section XI, "Rules for In-Service Inspection of Nuclear Power Plant Components".
11. Electric Power Research Institute, "Plant Experiences Database Instances of Pipe Wall Thinning, Leaks, and Ruptures Caused by Flow-Accelerated Corrosion in

References

- Nuclear Power Plant Piping Systems", Report No. TR-102032, Revision 2, December 1995.
12. Electric Power Research Institute, "NDE of Ferritic Piping For Erosion/Corrosion", Report No. NP-5410, September 1987.
 13. American Society of Mechanical Engineers, Boiler and Pressure Vessel Code, Section III, "Rules for Construction of Nuclear Power Plant Components".
 14. American National Standard Code for Pressure Piping, "Power Piping", ANSI B31.1.
 15. American Society of Mechanical Engineers, Boiler and Pressure Vessel Code, Section XI, Division 1, Code Case N-597, "Requirements for Analytical Evaluation of Pipe Wall Thinning".
 16. Electric Power Research Institute, "Acceptance Criteria for Structural Evaluation of Erosion/Corrosion Thinning in Carbon Steel Piping", Report No. NP-5911, April 1988.
 17. Ducreux, J., "Theoretical and Experimental Investigation of the Effect of Chemical Composition of Steels on Their Erosion-Corrosion Resistance", presented at the Specialists Meeting on the "Corrosion-Erosion of Steels in High-Temperature Water and Wet Steam," Les Renardieres, France, May 1982.
 18. Electric Power Research Institute, "PWR Secondary Water Chemistry Guidelines, Revision 4", Report TR-102134-R4, November 1996.
 19. Electric Power Research Institute, "BWR Water Chemistry Guidelines-1996 Revision", Report No. TR-103515-R1, December 1996.
 20. Altran Corporation, "Guidelines for Interviewing Plant Personnel within a Flow-Accelerated Corrosion Program", Technical Report 95217-TR-01, August 1996.
 21. American Society of Mechanical Engineers, Boiler and Pressure Vessel Code, Section XI, Division 1, Code Case N-561-1, "Alternative Requirements for Wall Thickness Restoration of Class 2 and High-energy Class 3 Carbon Steel Piping".
 22. American Society of Mechanical Engineers, Boiler and Pressure Vessel Code, Section XI, Division 1, Code Case N-562-1, "Alternative Requirements for Wall Thickness Restoration of Class 3 Moderate-energy Carbon Steel Piping".
 23. Electric Power Research Institute, "Flow-Accelerated Corrosion in Power Plants", TR-106611-R1, 1998.

24. Horowitz, J., Chexal, B., and Goyette, L., "A New Parameter in Flow-Accelerated Corrosion Modeling", ASME, PVP Volume 368, 1998.

A

RECOMMENDATIONS FOR AN EFFECTIVE FAC PROGRAM FOR SMALL BORE PIPING

A1.0 Introduction

Many of the recommendations for large bore piping can be applied to small bore. However, there are significant differences which must be addressed. For example, analysis of small bore piping typically is not feasible nor practical. Determination of local operating conditions necessary for analysis may prove difficult to obtain or are not consistent, especially in vent lines and downstream of steam traps and leaking, normally closed valves. Also, the lack of knowledge of the actual fit-up gap between a pipe and associated socket-welded fittings is common in small bore piping and limits the applicability of analytical methods and wear trending. In addition, failures in small bore piping are in general of less consequence than large bore piping.

This Appendix provides recommendations for an effective FAC program for small bore piping which takes these differences into account. An illustration of the program is provided in Figure A-1. For purpose of FAC evaluation, small bore piping is defined as piping with a nominal diameter of two inches or less.

A2.0 Identifying Susceptible Systems

The first task in the recommended program is to identify all small bore piping lines which are susceptible to FAC. This task should be done along with the large bore piping, utilizing the recommendations of Subsection 4.2. Care should be taken to include lines supplied with equipment, as often they are not included in line lists. Also, in applying exclusion criteria, consideration should be given to the fact that operating conditions and maintenance are typically less certain in small bore systems.

A3.0 Evaluating Susceptible Systems for Consequence of Failure

It is recommended that the small bore program take into account the level of consequence of failure in systems under evaluation. Considerable savings can result without compromising safety or system availability.

Recommendations for an Effective FAC Program for Small Bore Piping

Each of the small bore lines identified in A2.0 as susceptible should be evaluated based on the consequence of a failure in the line, and identified as Category 1 or Category 2. An acceptable alternative would be to designate all lines as Category 1.

Category 2 lines are those in which it can be demonstrated that a failure would be of minimal consequence. Lines can be demonstrated to be Category 2 if they meet all of the following:

1. The line is not part of a safety-related system.
2. A failure would not cause a reactor shutdown or measurable loss of power (i.e., a major train shutdown), either by automatic trip or operator action.
3. A failure can be readily isolated or controlled (i.e., repaired on-line) in time to prevent reactor or major train shutdown.
4. A failure would not likely result in personnel injury. The likely injury to personnel can be taken as a function of the line's accessibility and operating temperature. Piping in inaccessible or infrequently accessed areas can be considered unlikely to cause injury upon failure.

Plant owners who have conducted consequent of failure evaluations have reported that a significant number of susceptible small bore lines can be designated as Category 2.

Category 1 lines are the remaining susceptible piping in which, by definition, a failure is potentially greater than of minimal consequence, thus need further consideration.

This prioritization evaluation should be documented in a report, and periodically reviewed for impact of changes to plant design and operating conditions, related plant experience, and related industry experience. The report should include a discussion of the evaluation, identification of the susceptible small bore piping with identification of the Category 1 or 2, and the basis for that categorization.

A4.0 Scheduling Inspections

A4.1 Category 1 Piping

Category 1 susceptible piping should be inspected. Locations should be selected for initial inspections, the inspections performed, inspection results evaluated, and disposition made as recommended in A5.0 through A8.0 below.

Due to the large volume of small bore piping in a power plant, initial inspections will need to be scheduled over multiple outage periods. The timing of these inspections is

the responsibility of the plant owner. However, that timing should as a minimum consider relative level of susceptibility and the most susceptible lines inspected early in the program. The evaluation of A4.2 below can serve as a basis for prioritizing inspection timing.

A4.2 Prioritizing Category 1 Piping Based On Level of Susceptibility

A FAC susceptibility evaluation may be conducted of Category 1 lines and utilized to assist prioritizing inspection scheduling. It is recognized that it is not possible to predict levels of wear rate in most small bore piping with any accuracy. However, experience has shown that it is possible in most situations to categorize lines on a relative basis as potentially highly susceptible, moderately susceptible, or minimally susceptible.

Such an evaluation should consider all design and operating conditions which effect FAC. It is recognized that operating conditions for much of the small bore piping may be difficult to determine, and considerable engineering judgment and conservatism may be required.

This FAC susceptibility level evaluation should be documented in a report. The report should include a description of the evaluation, the assignment of level of susceptibility for all Category 1 piping, and the basis for that assignment.

A4.3 Category 2 Piping

Any further FAC program activities for Category 2 lines may be specified by the plant Owner. Category 2 lines need not be scheduled for inspection due to the minimum consequence from a failure.

A5.0 Selecting Components for Initial Inspection

A5.1 Grouping Piping Lines Into Sub-Systems

Category 1 piping lines should be grouped into sub-systems with similar flow and operating conditions, such that the sample inspection locations selected will represent the components in that sub-system. As flow and operating conditions in small bore systems are typically not well defined, the boundaries of these sub-systems should be smaller than would be defined for with more rigorous analysis, such as in a CHECWORKS™ run.

A5.2 Selecting Components For Inspection

Locations should be selected for initial inspection with the objective of identifying a sufficient number, and the appropriate locations, to confirm system susceptibility and to establish the level of wear present. Locations should be selected for each sub-system as follows:

1. An inspection sample of components should be selected to represent the potentially high wear locations in the sub-system. Variables influencing FAC should be considered in the selection. As sub-systems by definition bound piping areas with similar operating conditions, of particular importance are components with high flow velocity and turbulence (*i.e.*, variation in component geometry). As flow and operating conditions for these sub-systems will typically not be well defined, engineering judgment by FAC experienced engineers should be utilized to insure the sample is sufficient. The sample size selected should take into consideration the level of susceptibility as determined in the evaluations of Subsection A4.2 above.
2. Special consideration should be given to including components, along with piping downstream of those components, which are known within the industry to be particularly susceptible, including:
 - Control valves
 - Component inlet and discharge nozzles
 - Orifices
 - Steam traps
 - Reducing couplings
 - Unusual geometry configurations

As with large bore piping, inspections of joints and piping downstream can be utilized as evidence of the state of wear in thick components such as valves and orifices.

3. Consideration should also be given to components, and sections of piping, that have any historical wear, or where similar areas in parallel trains or sister plants have historical wear, or if industry experience has demonstrated potential susceptibility.
4. Where small bore piping sub-systems tie into headers that are of larger diameter piping (*i.e.*, drain headers), consideration should be given to extending inspections into the attached portions of those systems as part of the small bore program.

A6.0 Performing Inspections

A6.1 Radiography Techniques (RT)

Radiography is recommended for establishing whether or not significant wear is present, including those small diameter piping and socket-weld fittings where UT techniques are impractical. Radiography can be especially beneficial for conducting inspections on line.

A6.2 Ultrasonic Techniques (UT)

In many situations radiography techniques are not practical. UT is also an acceptable method for inspection of small bore components. In addition, UT can be used for measuring remaining wall thickness and thus establishing level of wear. Acceptable approaches for UT inspection include the following:

1. Gridding or scanning the downstream piping and expanding to the component if substantial wear is found.
2. Gridding the component and recording the readings.
3. Scanning the component and recording the minimum measured on the entire component or in quadrants.

Caution should be taken when utilizing UT on socket-welded connections. It is difficult to measure wall thickness close to the toe of the connection weld, where experience has shown significant wear can occur due to gaps caused by pipe to socket mismatch.

A6.3 Thermography

Thermography is a tool that can enhance the identification of potential problem areas in small bore piping. If available, thermography data should be examined to identify any leaking valves or steam traps that could accelerate FAC damage in downstream piping components.

A7.0 Evaluating Inspection Results

Trying to establish future wear rates is not recommended for small bore piping with socket-welded fittings, or in subsystems where design and operating conditions are not sufficiently defined. Predicted wear rates in systems without known and constant operating conditions, whether calculated (such as with CHECWORKS™) or trended from inspection data, are not considered reliable for any significant length of time.

Consequently, decisions on disposition of small bore piping needs to be made each inspection outage based on the results of inspections during that outage.

Inspection results from the initial inspection of a given sub-system should be evaluated to establish the level of FAC wear present in the components inspected. If little or no wear can be found, the sub-system can be classified as Low Wear. If significant wear is established, the sub-system should be classified as potentially High Wear.

Recommendations for disposition of the subsystem are given in A8.0 below based on their level of wear classification. Inspection data and evaluation results should be documented and maintained.

A8.0 Disposition of Sub-Systems

A8.1 Low Wear Sub-Systems

Sub-systems in which only low wear is found in the components inspected can be considered acceptable for continued service.

A representative number of the highest ranked components should be re-inspected during the inspection outage following the initial inspection of that subsystem to confirm the level of wear.

If the level of wear is confirmed during the repeat inspection to be low or none, future monitoring can be limited to a minimum level to help ensure any changes in the FAC rate are not missed. The number of components to inspect, and the timing of those inspections, should be consistent with the size of the sub-system, its level of susceptibility, knowledge of the operating conditions present (*i.e.*, systems where operating conditions may have changed, or for which maintenance is unknown, may need to be watched more closely), and related industry and plant experience with that and comparable sub-systems.

If significant wear is discovered during any re-inspection, the sub-system should be reclassified as High Wear and re-evaluated accordingly.

A8.2 High Wear Sub-Systems

Sub-systems in which the components inspected are classified as high wear should be addressed as soon as practical. It is recommended that high wear sub-systems be replaced with FAC resistant material before the sub-system is returned to service. Once that is accomplished, the subsystem can be removed from the further consideration in the FAC program.

If replacement of the sub-system with FAC resistant material is not practical prior to return to service, inspections should be expanded and selected repairs/replacements made as follows:

1. For sections of piping with butt-welded joints, expand the inspections to include components in the vicinity of those inspected components showing significant wear, and in similar locations in sister trains. If significant wear is found in the expanded inspections, the expansion process should be continued to define the limits of the components with significant wear.
2. For sections of piping with socket-welded joints, expand the inspections to include other socket welded locations.
3. Before the sub-system is returned to service, repair or replace components for which the inspections show significant wear, or justify adequacy until the next plant refueling outage. Guidance for repair and replacement is provided in Subsection 4.8.
4. Repeat the above steps in this Subsection A8.2 in each following refueling outage until replacement with FAC resistant material can be accomplished.

A9.0 Long Term Strategy

The recommendations of Section 5.0 in most cases apply to small bore as well as large bore piping. It is recommended that special consideration be given to replacement of susceptible small bore piping with FAC resistant material. Plant owners have reported that replacement can be significantly more economical than conducting evaluations and performing inspections of such systems.

Recommendations for an Effective FAC Program for Small Bore Piping




Figure A-1
Small Bore Piping FAC Program




Figure A-1 continued




Figure A-1 continued

VERMONT YANKEE NUCLEAR POWER STATION

PROGRAM PROCEDURE

PP 7028

ORIGINAL

PIPING FLOW ACCELERATED CORROSION INSPECTION PROGRAM

USE CLASSIFICATION: INFORMATION

LPC No.	Effective Date	Affected Pages
1	12/06/01	3-5 & 13-15 of 15

Implementation Statement: This procedure supercedes VY Procedure DP 4023 and use of the Vermont Yankee Piping Flow Accelerated Corrosion Program Manual, Revision 2a, prepared for Vermont Yankee by Yankee Atomic – Nuclear Services Division.

Issue Date: 05/10/01

TABLE OF CONTENTS

1.0	PURPOSE, SCOPE, AND DISCUSSION	3
2.0	DEFINITIONS	5
3.0	PRIMARY RESPONSIBILITIES.....	5
4.0	PROCEDURE	9
4.1.	Program Maintenance.....	9
4.2.	Initial Screening and Identification of FAC Susceptible Piping.....	9
4.3.	CHECWORKS Modeling	9
4.4.	Outage to Outage Activities	10
5.0	REFERENCES AND COMMITMENTS	12
6.0	FINAL CONDITIONS	14
7.0	ATTACHMENTS.....	15

1.0 PURPOSE, SCOPE, AND DISCUSSION

1.1. Purpose

LPC
1
The purpose of the Vermont Yankee Piping Flow Accelerated Corrosion (FAC) Inspection Program is to provide a systematic approach to ensure that FAC does not lead to degradation of plant piping systems and feedwater heaters. This Program Procedure controls the engineering and inspection activities performed to predict, detect, monitor, and evaluate wall thinning due to FAC at the Vermont Yankee Nuclear Power Station.

1.2. Scope

LPC
1
The scope of this program is limited to evaluation and inspection of plant piping systems and feedwater heater shells that could be susceptible to FAC.

FAC is known to occur in piping systems constructed of carbon or low-alloy steels, which carry water or wet steam. All plant piping systems have been screened for susceptibility to damage from FAC. A separate document titled "FAC Susceptible Piping Identification" has been developed to identify, on a line by line basis, the piping which is susceptible to damage from FAC. This document is maintained by the Piping FAC Inspection Program coordinator and is updated as required to reflect changes in plant operation and configuration.

There is no finite scope of piping components to be scheduled for inspection on a periodic basis. Each refueling outage inspection efforts will be optimized to focus on piping components which have been identified as wearing, or potentially wearing due to FAC. The components selected for inspection each refueling outage are identified using:

- Results of ultrasonic thickness (UT) inspections from previous refueling outages.
- Results of the CHECWORKS predictive software, which incorporates actual inspection data.
- Operating conditions at VY, which may indicate FAC damage is occurring.
- Operating experience and events from other plants.

LPC
1
Carbon steel feedwater heater shells have experienced thinning and through wall leaks due to FAC. Vermont Yankee has replaced all low pressure feedwater heaters with new heaters constructed of materials resistant to FAC. The four remaining high pressure feedwater heater shells are carbon steel. Long term monitoring of shell thickness for plant feedwater heaters is included in the scope of this program.

1.3. Discussion

Following the December 1986 Surry pipe rupture the industry has worked steadily to develop and implement monitoring programs to prevent the rupture of high energy piping due to single phase erosion-corrosion (FAC). In March 1987 INPO issued Significant Operating Experience Report (SOER) 87-3 which recommended that a continuing program be established at all U.S. nuclear power plants including analyses to predict wear rates and to plan and schedule periodic inspections. USNRC Generic Letter GL 89-08, requires all holders of operating licenses to provide assurances that a systematic program has been implemented to ensure that Flow Accelerated Corrosion does not lead to degradation of plant piping systems.

This Program Procedure (PP) controls engineering and inspection activities performed to assess the susceptible plant piping. This procedure defines the methods and criteria used in the evaluation and inspection of plant piping components which are susceptible to wall thinning due to FAC. The program is based on current industry practice and the latest EPRI recommendations (REF 5.4.8.).

LPC
1

Long term monitoring of plant feedwater heater shell thickness is included in the scope of this program. Previous heater inspection efforts were performed by Project Engineering and Design Engineering in conjunction with feedwater heater repair and replacement efforts. All six of the low pressure feedwater heaters have been replaced with new heaters constructed of materials resistant to FAC. The four remaining high pressure feedwater heater shells are carbon steel. Design criteria used in the feedwater heater repair and replacement activities are included in the documentation for the corresponding design change or work order which implemented the repair or replacement.

Overall health of the feedwater heaters is not only determined by the condition of the shell and nozzles, but is also dependent on the condition of the heater internals: tubes, tube support plates, impingement plates, tie rods, drain cooler end plates, etc. Evaluation of the overall component health is the responsibility of the Maintenance Department. Shell and nozzle inspections of feedwater heaters will be coordinated through the responsible System Engineer and the Maintenance Support Department. UT inspections of the heater shells will be performed in conjunction with internal visual inspections and eddy current testing of the heater tubes under Preventive Maintenance (PM) work orders.

Elements of the program controlled by this procedure are:

- Criteria for selection of piping systems and components susceptible to FAC and for maintenance of a "FAC Susceptible Piping Identification", which identifies all plant piping susceptible to FAC.
- Criteria for ongoing program maintenance including; benchmarking with current industry practice, evaluation of industry events, and participation in industry working groups.
- Criteria for use and control of the CHECWORKS predictive software used to evaluate piping, plan inspections, track inspection results, wear rates, piping component data, and repair and/or replacement history.
- Criteria for selection and scheduling of components to be inspected during refueling outages including initial inspections, follow-on inspections, and scope expansion / reduction.
- Criteria and procedures for evaluation of thinned piping components and, if required, for repair and replacements.
- Documentation requirements and criteria for maintenance and storage of inspection data.

NOTE

LPC
1

The program only addresses wall thinning due to FAC in pressure boundary piping components and feedwater heater shells. Wear in other pressure vessels, pumps, valves, and in-line items is not included. However, detected wear in the attached piping may indicate wear in the component and should be pursued.

The primary purpose of performing UT inspections each outage is to locate piping components degraded by FAC prior to the time that an immediate repair or replacement is required. This allows sufficient lead time for a planned replacement which will have a minimum impact on plant operation.

Given the costs of inspection and replacement of piping components, a long term approach for mitigating the effects of FAC taken under this program will be towards reducing component wear rates. To accomplish this, components found with significant wall loss due to FAC under this program, will be preferably replaced with materials which are more resistant to FAC damage.

2.0 DEFINITIONS

- 2.1. Flow Accelerated Corrosion (FAC): A corrosion process that causes thinning of steel piping exposed to flowing water or wet steam. The rate of loss is dependent on several parameters, which include flow regime, service life, water chemistry, piping material, piping geometry, and hydrodynamics.
- 2.2. Program: A set of activities that benefit from the existence of a formal, high level "Program Document." Such documents are meant to provide for a common understanding of program depth, breath and technical bases as well as the responsibilities of the program owner and those helping to implement the program. "Program Documents" are typically created to ensure regulatory requirements are satisfied. They can also be used to lay out the technical bases and personnel responsibilities related to complex, multi-departmental processes.
- 2.3. Program Owner: The individual responsible for maintaining the program, program documents, and assuring proper execution of the program requirements. Each program shall have an individual assigned as the program owner. The appropriate job title is determined by the responsible Department Manager. A summary of expectations for the program owner are contained in Appendix A of AP 0098 and shall be referenced in all Program Procedures.
- 2.4. Single-Phase Flow: The flow in the piping system remains in the liquid phase at all design and operating pressures and temperatures.
- 2.5. Two-Phase Flow: The flow in the piping system may vary from liquid to wet steam. This depends on the operating pressures and temperatures and varies with the specific location in the piping system.

3.0 PRIMARY RESPONSIBILITIES

Implementation of the tasks performed under this program involve several plant departments. The organization for personnel performing tasks under this program is shown in Figure 1.

- 3.1. The VY Design Engineering Mechanical / Structural (DE M/S) Department is responsible for the Piping FAC Inspection Program. The DE M/S Lead Design Engineer (LDE) has responsibility for the overall program management and administration and, for structural evaluation of thinned piping components.
- 3.1.1. Establishment and maintenance of criteria and procedures for evaluation of thinned wall piping components.
- 3.1.2. Performing structural evaluations of thinned wall piping components.
- 3.2. The Vermont Yankee Piping FAC Inspection Program Coordinator (FACPC) works within the Mechanical Structural (DE M/S) Department under the direction of the DE M/S LDE. The responsibilities of the FAC Program Coordinator are:
- 3.2.1. Maintenance of the Vermont Yankee Piping FAC Inspection Program Procedure and supporting documents to ensure that program meets commitments to GL 89-08 and the "Expectations of Program Owners" as defined in Appendix A of AP 0098.
- 3.2.2. Continual assessment of FAC inspection program to insure program effectiveness.
- 3.2.3. Participation in relevant industry working groups, benchmarking with current industry practice, evaluation of industry events; and implementation of revisions, changes, and process improvements which result from the participation.
- 3.2.4. Establishment and maintenance of criteria for selection of piping systems and components susceptible to FAC and for maintenance of the "FAC Susceptible Piping Identification" document which screens all current plant piping systems and identifies piping susceptible to FAC.
- 3.2.5. Establishment and maintenance of criteria for selection and scheduling of components to be inspected during refueling outages including: initial inspections, follow-on inspections, and scope expansion and/or reduction.

- 3.2.6. Establishment and maintenance of criteria for use and control of the CHECWORKS predictive software used to evaluate piping, plan inspections, track inspection results, wear rates, piping component data, and repair and/or replacement history.
- 3.2.7. Review of design change and maintenance documents as necessary to assess the impact of the proposed tasks on the inspection program, and recommend action when appropriate.
- 3.2.8. Ensure that all physical and operational changes or additions to plant piping systems are incorporated into the program.
- 3.2.9. Analytical evaluation of plant piping systems for FAC using the EPRI CHECWORKS codes as appropriate.
- 3.2.10. Pre-outage activities including:
- Development of inspection scope for each refueling outage.
 - Perform/update analytical evaluations (CHECWORKS models) as required.
 - Provide pre-inspection implementation support.
- 3.2.11. Outage activities including:
- Providing engineering support for inspection implementation.
 - Evaluation and disposition of all inspection results.
 - Recommend changes to the planned inspection scope upon discovery of unacceptable conditions.
 - Providing assistance as required in the development of repair/replacement options.
 - Providing written summary of inspection results to ISIPC prior to plant startup.
 - Ensure that cognizant departments and the Control Room are informed of unacceptable conditions discovered during evaluation of inspection results and facilitate completion of appropriate paperwork (ER's, WOR, IDR, etc.).
- 3.2.12. Post-outage activities including:
- Development of outage inspection report including trending analyses and long term recommendations.
 - Update/maintain the plant CHECWORKS models and maintain a history of all piping inspections.
 - Update/maintain "FAC Susceptible Piping Identification" document to reflect plant changes as required.
- 3.2.13. Keep DE M/S LDE informed on the progress of FAC related tasks.

3.3. The Vermont Yankee In-Service Inspection Program Coordinator (ISIPC): works within the System Engineering Department under the direction of the Superintendent of System Engineering. The responsibilities of the ISIPC include:

3.3.1. Provide for overall coordination with the Vermont Yankee In-Service Inspection Program if inspection results on safety class piping indicate violations of the piping design code.

3.3.2. Coordination of pre-outage activities including:

- Input to the development of outage schedules and budgets relative to FAC activities.
- Providing oversight of work order planning and coordination with ISI Program resources.
- Arrange on-site services as required.

3.3.3. Coordination of outage activities including:

- Ensure components scheduled for inspection are properly prepared and accessible.
- Performance of inspections.
- Post inspection restoration of components.
- Repair/replacement effort of unacceptable components.

3.3.4. Interface with the cognizant departments, as needed to insure all safety related repair/replacement ISI examination requirements are satisfied.

3.3.5. Ensure that required piping repairs and/or replacements are performed according to plant procedures and repairs to safety class piping and components are performed in accordance with ASME Section XI requirements.

3.3.6. Ensure that cognizant departments and the Control Room are informed of unacceptable conditions discovered during evaluation of inspection results and facilitate completion of appropriate paperwork (ER's, WOR, IDR, etc.).

3.3.7. Ensure that inspection records are temporarily stored per AP 6807 and permanently stored per AP 6809 and available for the plant lifetime.

3.3.8. Keep the Superintendent of System Engineering informed on the progress of FAC related tasks.

3.3.9. Provide technical advice on implementation and inspection aspects of the FAC program.

3.3.10. NDE procedure development and maintenance.

3.4. Level III / ISI Supervisor is a certified Level III UT examiner and works under the direction of the ISIPC. The responsibilities of the Level III /ISI Supervisor include:

3.4.1. Review of applicable NDE procedures used in pipe UT wall thickness measurements.

3.4.2. Ensuring that UT inspectors are properly qualified and trained to the applicable inspection procedures.

3.4.3. Review of inspection results for compliance to the applicable procedures.

3.4.4. Resolution of anomalies found in inspection data.

3.4.5. Recommendations for augmented or special NDE procedures or techniques as required.

3.4.6. Direct supervision of inspection personnel to ensure that the inspection personnel accurately and efficiently execute the inspection plan, complete inspections, and appropriately document inspection results.

3.4.7. Control of all inspection data during the refueling outage.

3.4.8. At the completion of inspections forwarding all inspection records to the ISIPC for permanent storage per the requirements of Section 6.2

3.5. Non Destructive Examination (NDE) Personnel

3.5.1. Meet Applicable qualification Standards. Personnel performing ultrasonic inspections shall be qualified to the requirements of NE 8043.

3.5.2. Perform assigned setup, calibrations, and examinations.

3.5.3. Documentation of results in accordance with approved procedures.

3.6. Plant Support Services

The Project Engineering Department is responsible for providing staging, lighting, insulation removal, surface preparation of piping components, and for component restoration after inspections are performed. Activities are controlled through the VY Work Order process in accordance with plant procedures.

4.0 PROCEDURE

4.1. Program Maintenance

The FACPC shall maintain the Yankee Piping FAC Inspection Program Procedure, PP 7028 and supporting documents to ensure that program meets commitments to GL 89-08 by:

- 4.1.1. Continual reassessment of the piping FAC inspection program to insure program effectiveness. A FAC Program Self Assessment shall be performed at least once per operating cycle.
- 4.1.2. Participation in relevant industry working groups, benchmarking with current industry practice, evaluation of industry events; and implementation of revisions, changes, and process improvements which result from the participation.
- 4.1.3. Adaptation of current or developing industry practices: for selection and scheduling of components to be inspected, follow-on inspections, scope expansion and/or reductions, and criteria and procedures for evaluation of thinned wall piping components.
- 4.1.4. Review design change and maintenance documents as necessary to assess the impact of the proposed tasks on the inspection program, and recommend action when appropriate.
- 4.1.5. Incorporate all physical and operational changes or additions to plant piping systems into the program as applicable.

4.2. Initial Screening and Identification of FAC Susceptible Piping

- 4.2.1. A screening and evaluation of all plant piping systems for susceptibility to FAC shall be performed. The screening shall use the EPRI Guidelines from reference 5.4.8., industry experience, and previous Vermont Yankee inspection results. The evaluation shall be performed and reviewed by engineers with FAC experience and familiar with plant systems. The resulting document shall be controlled by the FACPC.
- 4.2.2. The FACPC shall revise the "FAC Susceptible Piping Identification" document as required to reflect changes in plant operation, piping configuration, and/or materials.

4.3. CHECWORKS Modeling

- 4.3.1. Evaluate the susceptible plant piping systems for FAC using the EPRI CHECWORKS code. The evaluations shall be performed, reviewed, and documented per the requirements of Appendix D.

4.4. Outage to Outage Activities

Inspection and evaluation efforts performed under the program follow a cyclic pattern. Once inspection data from a given outage is obtained, it is incorporated into the appropriate predictive model and the results are then used in conjunction with other FAC related information to establish the inspection scope for the next refueling outage.

NOTE

Each large bore piping component within the scope of this program has been given a unique identification number as described in Appendix A. The location (building and elevation) of each large bore component is obtained from the Component Location Sketches in Appendix A. Small bore piping inspection locations included in the program are identified in Appendix B.

The tasks performed each refueling outage to implement the piping inspections under the FAC inspection program are detailed below. These are also broken out chronologically in a flow chart included here as Figure 2.

- 4.4.1. The outage inspection scope is determined by the FACPC using previous inspection data, the results of the CHECWORKS models, industry experience, and the guidelines contained in Appendix E.
- 4.4.2. The outage inspection scope is reviewed by the ISIPC for impact on and conflicts with the overall outage plan. The ISIPC will plan and organize the on-site resources required to implement the piping inspections.
- 4.4.3. A work package is assembled for each piping component or group of components. This package includes component location sketches, support requirements such as scaffolding, lighting, etc., surface preparation and gridding requirements, and any special inspection requirements as determined by the FACPC.
- 4.4.4. Prepare piping components for inspection.
 - 4.4.4.1. As directed by the ISIPC, scaffolding, lighting, insulation removal, and surface preparation of each piping component to be inspected are performed by on-site services in accordance with the applicable plant procedures.
 - 4.4.4.2. Surface preparation and gridding of piping components for inspection shall conform to the guidelines in NSAC 202L (reference 5.4.8.). Specific instructions for surface preparation are given in NE 8044. Specific instructions for gridding of piping components are given in Attachment A of NE 8053, or as further directed by the FACPC.

4.4.5. Perform UT inspections.

4.4.5.1. Piping wall thickness shall be determined using ultrasonic testing (UT). Personnel performing ultrasonic or other inspections shall be qualified to the requirements of NE 8043. Wall thickness measurements made by UT shall be performed in accordance with NE 8053.

4.4.5.2. Inspection will be performed by using a 100% scan of the area between the grids lines. The lowest measurement in each area will be recorded as the measured thickness.

4.4.5.3. An inspection results package shall be assembled for each large bore component and for each group of small bore components inspected. The form and content of the inspection results package shall be per NE 8053.

4.4.6. The Level III / ISI Supervisor shall review all UT inspection data for procedure compliance, anomalies, and completeness.

4.4.6.1. Ensure discrepancies are resolved, and any missing data are supplied.

4.4.6.2. The completed examination report shall be forwarded to the FACPC for evaluation.

4.4.7. The inspection data for each piping component shall be evaluated for structural integrity by qualified Mechanical/Structural Design Engineering personnel in accordance with DP 0072.

4.4.7.1. Per DP 0072 all components inspected will be classified as either "acceptable as is", "acceptable for continued operation" (with future inspections required), or "repair or replacement is required".

4.4.7.2. If significant wear is found in a component, additions to the planned inspection scope may be required. The FACPC shall use the criteria for sample expansion in Appendix E for selection of additional components.

4.4.7.3. Deletions in the planned inspection scope may be warranted based on the inspection results of similar piping components. The FACPC shall provide written justification to the ISIPC and the DE M/S LDE for all scope reductions.

4.4.8. Piping components determined to be "accept as is" by DE M/S can be restored (replace insulation, etc.) for operation.

4.4.8.1. If future inspections on a component are required or anticipated, then consideration should be given to installing removable insulation blankets.

4.4.9. For piping components determined to need repair or replacement, the FACPC will notify the ISIPC, the DE M/S LDE, the cognizant departments and/or the Control Room of unacceptable conditions discovered during evaluation of inspection results by completion of appropriate paperwork (ER's, WOR, IDR, etc.).

- 4.4.10. Piping repairs and/or replacements shall be performed in accordance with the applicable design codes and plant procedures.
 - 4.4.10.1. Safety class piping and components under ASME Section XI requirements shall be dispositioned in accordance with DP 4027.
 - 4.4.10.2. Repair of safety related components shall be performed per AP 0070.
 - 4.4.10.3. Baseline Inspections (wall thickness measurements) shall be performed for all new piping components installed to replace worn piping. Measurements shall be made using approved procedures. The baseline inspection measurements and the replacement material data shall be forwarded to the FACPC.
- 4.4.11. Prior to plant startup the FACPC shall:
 - 4.4.11.1. Ensure all inspection results are assessed for piping code compliance, impact on plant operability, and personnel safety.
 - 4.4.11.2. Provide the ISIPC and the DE M/S LDE with a written summary of inspection results. The summary will identify all thinned components found, and any required repairs and/or replacements performed during the outage.
- 4.4.12. Within 90 days of plant startup the FACPC shall prepare an outage inspection report. The contents of the outage inspection report shall be per Section 6.3.
- 4.4.13. The FACPC will, as applicable, incorporate the inspection results into the CHECWORKS models for use in planning the scope of the next refueling outage.

5.0 REFERENCES AND COMMITMENTS

5.1. Technical Specifications and Site Documents

5.1.1. VOQAM – Appendix D

5.2. Codes, Standards, and Regulations

5.2.1. USAS B31.1.0 - 1967, Power Piping Code

5.2.2. ANSI B31.1 - 1977, Power Piping Code

5.2.3. ASME Code Case N-597, Requirements for Analytical Evaluation of Pipe Wall Thinning, Section XI, Division 1

5.3. Commitments

- 5.3.1. USNRC Generic Letter 89-08, Erosion/Corrosion-Induced Pipe Wall Thinning, dated May 2, 1989
- 5.3.2. Vermont Yankee letter to the USNRC, Vermont Yankee Response to NRC Generic Letter 89-08: "Erosion/Corrosion-Induced Pipe Wall Thinning, dated July 14, 1989
- 5.3.3. USNRC Bulletin No. 87-01, Thinning of Pipe Walls in Nuclear Power Plants, dated July 9, 1987
- 5.3.4. Vermont Yankee letter to the USNRC, Vermont Yankee Response to NRC Bulletin No. 87-01: Thinning of Pipe Walls in Nuclear Power Plants, dated September 11, 1987
- 5.3.5. Vermont Yankee letter to the USNRC, Supplement to Vermont Yankee Response to NRC Bulletin No. 87-01: Thinning of Pipe Walls in Nuclear Power Plants, dated December 24, 1987
- 5.3.6. USNRC Generic Letter 90-05, Guidance for Performing Temporary Non-Code Repair of ASME Code Class 1, 2, and 3 Piping, dated June 15, 1990
- 5.3.7. Vermont Yankee Letter to the USNRC, Request for Relief from the ASME Code to Use Code Case N-597, dated March 19, 2001, BVY 01-12
- 5.3.8. USNRC Letter to Vermont Yankee, Vermont Yankee Nuclear Power Station - Relief Request for Use of ASME Code Case N-597 as an Alternative Analytical Evaluation of Wall Thinning (TAC No. MB1530), dated July 27, 2001, NVY 01-74
- 5.3.9. VY Memo: J.F. Calchera to OEC (R. McCullough), Subject: Response to Commitment Item: ER-990876_01, Reevaluate Feedwater (Heater) Inspection Program to Address Ownership, dated April 25, 2000

LPC
1

5.4. Supplemental References

- 5.4.1. Vermont Yankee FAC Susceptible Piping Identification, Rev. 0, Dated May 15, 2000
- 5.4.2. Vermont Yankee CHECWORKS MODELS, Rev.0, Dated June 30, 2000
- 5.4.3. VY Small Bore Piping Component Selection Review, Revision 1, dated December 6, 1999
- 5.4.4. Institute of Nuclear Power Operations (INPO), Significant Operating Experience Report (SOER) No.87-3, Pipe Failures in High Energy Systems Due to Erosion/Corrosion, dated March 20, 1987
- 5.4.5. W. Stuart, et al, NUMARC Working Group on Erosion-Corrosion Summary Report, June 1987
- 5.4.6. Boiling Water Reactor Ebasco Specification for Piping, Piping Components, Hangers and Supports for Station Piping Systems, Specification No. BWR QC-10 9/15/68, by EBASCO Services Inc.
- 5.4.7. Acceptance Criteria for Structural Evaluation of Erosion-Corrosion Thinning in Carbon Steel Piping, EPRI NP-5911SP, Project 1757-61, Final Report, July 1988
- 5.4.8. Recommendations for an Effective Flow-Accelerated Corrosion Program, NSAC-202L-R2, Final Report, April 1999, Electric Power Research Institute
- 5.4.9. CHECWORKS - Computer Program User Guide, TR 103496, August 1994 by Altos Engineering Applications Inc. for EPRI.
- 5.4.10. CHECWORKS FAC Application Guidelines for Plant Modeling and Interpretation of Inspection Data, Draft Report, By Altos Engineering for EPRI, dated February 3, 1997
- 5.4.11. AP 0009, Event Reports
- 5.4.12. AP 0017, Calculations and Analyses
- 5.4.13. AP 0070, ASME Section XI Repair and Replacement Procedure
- 5.4.14. DP 0072, Structural Evaluation of Thinned Wall Piping Components
- 5.4.15. DP 4027, Disposition of Inservice Inspection Findings
- 5.4.16. AP 6024, Plant Housekeeping and Foreign Material Exclusion/Cleanliness Control
- 5.4.17. AP 6045, Engineering Record Correspondence (ERC) and Technical Evaluations (TE)
- 5.4.18. AP 6807, Collection, Temporary Storage and Retrieval of QA Records
- 5.4.19. AP 6809, Plant QA Records Management System
- 5.4.20. NE 8043, Training, Qualification and Certification of NDE Personnel

- 5.4.21. NE 8044, Preparation of Examination Surfaces and Reference Marking of Welds for Nondestructive Examination
- 5.4.22. NE 8047, Visual Examination Procedure for VT-3 and General Visual
- 5.4.23. NE 8053, Ultrasonic Thickness Measurement
- 5.4.24. EPRI CHUG Position Paper No. 3, Recommendations for Inspecting Feedwater Heater Shells for Flow Accelerated Corrosion Damage, dated February 2000

LPC
1

6.0 FINAL CONDITIONS

The following requirements apply to all permanent documents for the Piping FAC Inspection Program.

Inspection records including personnel, equipment, and material certifications, calibration sheets, inspection data sheets, records of repairs, and other records required by the applicable piping codes are submitted to the ISIPC for filing in accordance with the applicable implementation procedures.

6.1. Systems Screening, Predictive Models, and Wall Thinning Evaluations

LPC
1

- 6.1.1. The "FAC Susceptible Piping Identification" shall be maintained by the FACPC. A copy shall be forwarded to Records & Information Management Services (RIMS) for permanent storage.
- 6.1.2. The CHECWORKS predictive models and FAC evaluations of plant piping systems shall be documented maintained by the FACPC. A copy shall be forwarded to DCC for permanent storage.
- 6.1.3. All evaluations of pipe wall thinning below code minimum wall thickness (Level 3) shall be performed and documented in a VY Calculation per the requirements of AP 0017 and DP 0072.

6.2. UT & VT Inspection Data

- 6.2.1. The official inspection record for each large bore component or group of small bore components is the UT Inspection Report developed per NE 8053.
- 6.2.2. For each component inspected, the complete record of instrument data and thickness measurements from the data loggers as applicable shall be stored on disk or for future retrieval.
- 6.2.3. During the refueling outage all inspection records are controlled by the ISI Supervisor and are stored per AP 6807.
- 6.2.4. At the completion of the inspections, all records and forms required by the applicable UT & VT, procedures used to perform the inspections shall be forwarded to the ISIPC for permanent storage per the requirements of AP 6809.

6.3. Refueling Outage Inspection Reports

An Inspection Report shall be generated after each refueling outage to summarize the inspection activities performed, and to provide a formal means for documentation of the inspection results. The Piping Inspection Report shall identify the following:

- Total number of piping components inspected, including a summary of measured thickness data.
- Components which were repaired or replaced.
- Components designated as requiring future monitoring.
- Components or portions of piping systems which UT measurements indicate repair or replacement will be required.
- Components added or deleted from the planned Inspection Scope. Also provide the basis for adding or deleting each component.
- Unexpected measurement results/problems.
- Recommended changes/revisions to the Inspection Program to be implemented in future outages.
- Reference to applicable VY Calculations.

A copy shall be forwarded to RIMS for permanent storage.

6.4. Supplemental Program Data

The FACPC shall maintain files for any other FAC related correspondence and documents such as:

- QA audit reports and NRC Inspections
- Program Self Assessments
- Evaluation of FAC related Industry Events
- Documentation of additional activities to supplement the FAC Inspection Program

7.0 ATTACHMENTS

- 7.1. Figure 1 Piping FAC Inspection Site Organization
- 7.2. Figure 2 Piping FAC Inspection & Evaluation Process Flow Chart
- 7.3. Appendix A Large Bore Piping Component Location Sketches
- 7.4. Appendix B Small Bore Piping Inspection Location Database
- 7.5. Appendix C Identification of FAC Susceptible Systems and Piping Components
- 7.6. Appendix D Use and Control of CHECWORKS Models
- 7.7. Appendix E Criteria for Selection of Piping Components for Inspection and sample Expansion Guidelines

FIGURE 1

PIPING FAC INSPECTION SITE ORGANIZATION




Figure 1
PP 7028 Original
Page 1 of 1

FIGURE 2

PIPING FAC INSPECTION & EVALUATION PROCESS FLOW CHART




Figure 2
 PP 7028 Original
 Page 1 of 1

APPENDIX A


LARGE BORE PIPING COMPONENT LOCATION SKETCHES

Notes For Component Locations Sketches

1. The Component Location Sketches contained in this Appendix are to be used only for identification and location of specific piping components which are modeled, inspected, and evaluated under this program.
2. The sketches are not to be used for design work. Refer to the Plant Drawings referenced on each Sketch.
3. The Component Location Sketches are in the form of partial piping isometric drawings. Lengths shown are approximate.
4. The piping component numbering scheme is shown on page 2 of this Appendix.

Piping Component Numbering Scheme

Each large bore piping component (elbow, valve, reducer, straight run, etc.) has been given an 8 or 10 character identification number based on the following convention:



<u>System Identification:</u>	FD	Feedwater
	CD	CONDENSATE
	MS	Main Steam
	HD	Heater Drains
	ES	Extraction Steam
	CU	Reactor Water Cleanup
	CAR	Turbine Cross-around Piping
	HV	Feedwater Heater Vent Piping
	MD(MSD)	Main Steam Drain Piping
	HH	House Heating Steam

<u>Component Type:</u>	SP	Straight Pipe
	EL	ELBOW
	VA	Valve
	TE	Tee
	RD	Reducer
	OR	Orifice
	FE	Flow Element
	BL	Bellows

Notes on Numbering Scheme:

1. At the time this numbering system was developed, the original data logging equipment had an 8 character limitation. Piping systems with multiple trains are numbered 1A, 2A, 3A, etc. For multiple trains with line numbers 10 and above, (10A, 10B, 10C, etc.) components are generally identified in order by train (line 10A, 10B, 10C, etc.) in the direction of fluid flow.
2. Straight pipe segments longer than about 15 diameters in length have subsequently been modeled as two distinct piping locations. The same first 8 characters are used with the addition of "US" for the upstream end of the pipe run and "DS" for the down stream end of the pipe run. (Example: "FD01SP01US")

APPENDIX A (Continued)


SKETCH No.	TITLE	REVISION
001	FEEDWATER LINE 16" FDW-1	1
002	FEEDWATER LINE 16" FDW-2	1
003	FEEDWATER LINE 16" FDW-3	1
004	FEEDWATER HEADER 24" FDW-1	1
005	FEEDWATER LINE 18" FDW-7	1
006	FEEDWATER LINE 18" FDW-7 (CONT)	2
007	FEEDWATER LINE 18" FDW-12	1
008	FEEDWATER LINE 16"-FDW-14	1
009	FEEDWATER LINES 16" FDW-14 & 16	1
010	FEEDWATER LINES 10"-FDW-19 & -21	1
011	FEEDWATER LINE 18"-FDW-8	1
012	FEEDWATER LINE 18" FDW-8 (CONT)	2
013	FEEDWATER LINE 18" FDW-13	2
014	FEEDWATER LINE 16"-FDW-15	1
015	FEEDWATER LINES 16" FDW-15 & 17	1
016	FEEDWATER LINES 10"-FDW-18 & 20	1
017	FEEDWATER LINE 4"-FDW-4	1
018	FEEDWATER LINE 4"-FDW-5	1
019	FEEDWATER LINE 4"-FDW-6	1
020	FEEDWATER LINES 6"-FDW-9 & 18" FDW-10	1
021	FEEDWATER LINES 18"-FDW-10 & 10" FDW-11	1
022	FEEDWATER LINES 8"-FDW-22A & 10" FDW-23A	2
023	FEEDWATER LINES 8"-FDW-22B & 10" FDW-23B	1
024	CONDENSATE LINES 20"-C1 & C2, 36"-C-3, 24"-C4, AND 24"-C5	0
025	CONDENSATE LINES 18"-C-6,7,8, 24"-C-8, 12"-C-9,10,11	0
026	CONDENSATE LINES 12"-C-13,14,15, 24"-C-15 AND 24"-C-16	0
027	CONDENSATE HEADER TO DEMINS.	0
028	CONDENSATE LINE 24"-CD-3 & 24"-C-18	0
029	CONDENSATE LINE 24"-C-18 & 20"-C-19	0
030	CONDENSATE LINE 20"-C-25	1
031	CONDENSATE LINE 20"-C-26	0
032	CONDENSATE LINE 20"-C-27	0
033	CONDENSATE LINE 20"-C-28	0
034	CONDENSATE LINE 20"-C-29	1
035	CONDENSATE LINE 20"-C-30	1
036	CONDENSATE LINE 24"-C-30	0
037	CONDENSATE LINE 20"-C-30 (CONTINUED)	0
038	CONDENSATE LINE 20"-C-31	0
039	CONDENSATE LINE 20"-C-32	0
040	CONDENSATE LINE 14"-C-21	1
041	CONDENSATE LINES 14"-C-21, 10"-C-21& 10"-C-22	0
042	CONDENSATE LINE 12"-C-23	0
043	HEATER DRAIN LINES 6"-HD-1A & 6"-HD-2A	1
044	HEATER DRAIN LINES 10"-HD-3A & 10"-HD-4A	2
045	HEATER DRAIN LINES 14"-HD-5A & 14"-HD-6A	1
046	HEATER DRAIN LINES 16"-HD-7A & 20"-HD-25A	1



APPENDIX A (Continued)

SKETCH No.	TITLE	REVISION
047	HEATER DRAIN LINES 16"-HD-8A, 12"-HD-9A, & 18"-HD-21A	1
048	HEATER DRAIN LINES 12"-HD-9A & 4"-HD-10A	1
049	HEATER DRAIN LINES 20"-HD-14A, 16"-HD-14A, AND 24"-HD-17A & C	0
050	HEATER DRAIN LINES 6"-HD-1B & 6"-HD-2B	1
051	HEATER DRAIN LINES 10"-HD-3B & 10"-HD-4B	2
052	HEATER DRAIN LINE 14"-HD-5B & 14"-HD-6B	1
053	HEATER DRAIN LINES 16"-HD-7B & 20"-HD-25B	2
054	HEATER DRAIN LINES 16"-HD-8B, 12"-HD-9B, & 18"-HD-21B	
055	HEATER DRAIN LINES 12"-HD-9B & 4"-HD-10B	1
056	HEATER DRAIN LINES 20"-HD-14B, 16"-HD-14B, AND 24"-HD-17B & D	0
057	HEATER DRAIN LINES 6"-HD-11A, 6"-HD-12A, 6", 6"-HD-13A, AND 6"-HD-16A	1
058	HEATER DRAIN LINES 6"-HD-11B, 6"-HD-12B, 6"-HD-13B AND 6"-HD-16B	1
059	HEATER DRAIN LINE 6"-HD-11C, 6"-HD-12C, 6"-HD-13C, 6"-HD-16C	2
060	HEATER DRAIN LINES 6"-HD-11D, 6"-HD-12D, 6"-HD-13D, 6"-HD-16D	1
061	HEATER DRAIN LINES 6"-HD-12A, 6"-HD-12B, AND 14"-HD-15B	2
062	HEATER DRAIN LINES 6"-HD-12C, 6"-HD-12D, AND 14"-HD-15A	1
063	EXTRACTION STEAM LINE 12"-ES-1A	1
064	EXTRACTION STEAM LINE 12"-ES-1B	1
065	EXTRACTION STEAM LINE 10"-ES-2A	1
066	EXTRACTION STEAM LINE 10"-ES-2B	1
067	EXTRACTION STEAM LINE 20"-ES-3A	2
068	EXTRACTION STEAM LINE 20"-ES-3B	2
069	EXTRACTION STEAM LINES 20"-ES-4A & 30"-ES-4A	1
070	EXTRACTION STEAM LINES 30"-ES-4B	0
071	EXTRACTION STEAM LINES 20" & 26"-ES-5A, 5B, 5C, 5D	1
072	EXTRACTION STEAM LINES 20" & 26"-ES-5E, 5F, 5G, 5H	1
073	EXTRACTION STEAM LINE 12"-ES-6	1
074	MAIN STEAM LINE 18"-MS-1A & 18"-MS-7A	0
075	MAIN STEAM LINE 18"-MS-1A (CONTINUED)	0
076	MAIN STEAM LINE 18"-MS-1B & 18"-MS-7B	0
077	MAIN STEAM LINE 18"-MS-1B (CONTINUED)	0
078	MAIN STEAM LINE 18"-MS-1C & 18"-MS-7C	0
079	MAIN STEAM LINE 18"-MS-1C (CONTINUED)	0
080	MAIN STEAM LINE 18"-MS-1D & 18"-MS-7D	0
081	MAIN STEAM LINE 18"-MS-1D (CONTINUED)	0
082	30" & 36" TURBINE CROSS AROUND PIPING, "A" LINE	0
083	30" & 36" TURBINE CROSS AROUND PIPING "B" LINE	0
084	30" & 36" TURBINE CROSS AROUND PIPING "C" LINE	0
085	30" & 36" TURBINE CROSS AROUND PIPING "D" LINE	0
086	REACTOR WATER CLEANUP 4" CUW-54 & 55	0
087	BPV 1 10"-MS-3A	0
088	BPV 2 10"-MS-3B	0

APPENDIX A (Continued)


SKETCH No.	TITLE	REVISION
089	BPV 3 10"-MS-3C	0
090	BPV 4 10"-MS-3D	0
091	BPV 5 10"-MS-3E	0
092	BPV 6 10"-MS-3F	0
093	BPV 7 10"-MS-3G	0
094	BPV 8 10"-MS-3H	0
095	BPV 9 10"-MS-3I	0
096	BPV 10 10"-MS-3J	0
097	8"-MSD-9	0






TURBINE BUILDING-FEEDWATER PUMP ROOM.
 REFERENCES: G191157,G191182,G191183,5920-FS-124


REVISION 1: 11/24/91
VERMONT YANKEE PIPING EROSION-CORROSION INSPECTION PROGRAM
FEEDWATER LINE 16" FDW-2
COMPONENT LOCATION SKETCH No.002



TURBINE BUILDING-FEEDWATER PUMP ROOM
 REFERENCES: G191157,G191182,G191183,5920-FS-124


REVISION 1: 11/24/91
VERMONT YANKEE PIPING EROSION-CORROSION INSPECTION PROGRAM
FEEDWATER LINE 16' FDW-3
COMPONENT LOCATION SKETCH No.003







TURBINE BLDG FEED PUMP ROOM/HEATER BAY.
 REFERENCES: G191157,G191182,191183,5920-FS-124


REVISION 1: 11/24/91
VERMONT YANKEE PIPING EROSION-CORROSION INSPECTION PROGRAM
FEEDWATER LINE 18" FDW-7
COMPONENT LOCATION SKETCH No.005








(COLUMN LINE F)
MATCH LINE SKETCH No.009




TURBINE BUILDING-HEATER BAY
REFERENCES: G191157,G191182,G191183,5920-FS-I25

REVISION 1: 11/24/91
VERMONT YANKEE PIPING EROSION-CORROSION INSPECTION PROGRAM
FEEDWATER LINE 16'-FDW-14
COMPONENT LOCATION SKETCH No.008



REACTOR BUILDING-STEAM TUNNEL/DRYWELL
 REFERENCES: G191167,G191180,G191181
 VYI-FDW-PART 5A,VYI-FDW-PART 5C.





REVISION 1: 11/24/91


VERMONT YANKEE PIPING EROSION-CORROSION INSPECTION PROGRAM


FEEDWATER LINES 16' FDW-14 & 16

COMPONENT LOCATION SKETCH No.009











REVISION 2: 6/17/93


TURBINE BUILDING-HEATER BAY
 REFERENCES: G191157, G191182, G191183, 5920-FS-125

VERMONT YANKEE PIPING EROSION-CORROSION INSPECTION PROGRAM
FEEDWATER LINE 18" FDW-13
COMPONENT LOCATION SKETCH No.013







REACTOR BUILDING-STEAM TUNNEL/DRYWELL
 REFERENCES: G191167, G191180, 191181, VYI-FDW-PART 5A





REVISION 1: 11/24/91


VERMONT YANKEE PIPING EROSION-CORROSION INSPECTION PROGRAM
FEEDWATER LINES 16' FDW-15 & 17
COMPONENT LOCATION SKETCH No.015

















TURBINE BUILDING-HEATER BAY
 REFERENCES: G191157,G191182,G191183,VYI-FDW-PART 5C(2/2)


REVISION 1: 11/25/91
VERMONT YANKEE PIPING EROSION-CORROSION INSPECTION PROGRAM
FEEDWATER LINES 18"-FDW-10 & 10" FDW-11
COMPONENT LOCATION SKETCH No.021







TURBINE BUILDING-HEATER BAY (TRENCH) & CONDENSATE PUMP ROOM
 REFERENCES: G191157,G191186,G191187,5920-FS-116





TURBINE BUILDING-CONDENSATE PUMP ROOM
 REFERENCES G191157,G191186,G191187,5920-FS-117


VERMONT YANKEE PIPING EROSION-CORROSION INSPECTION PROGRAM


CONDENSATE LINES 18'-C-6,7,8, 24'-C-8, 12'-C-9,10,11

COMPONENT LOCATION SKETCH No.025










TURBINE BUILDING-HEATER BAY
 REFERENCES: G191157,G191186,G191187,5920-FS-116,5920-FS-117



VERMONT YANKEE PIPING EROSION-CORROSION INSPECTION PROGRAM
CONDENSATE LINE 24"-C-1B & 20"-C-19
COMPONENT LOCATION SKETCH No. 029



TURBINE BUILDING-HEATER BAY
 REFERENCES: G191157,G191186,G191187,5920-FS-116,5290-FS-117

REVISION 1: 6/17/93

VERMONT YANKEE PIPING EROSION-CORROSION INSPECTION PROGRAM
CONDENSATE LINE 20'-C-25
COMPONENT LOCATION SKETCH No.030




REVISION 0: 7/13/90


VERMONT YANKEE PIPING EROSION-CORROSION INSPECTION PROGRAM


CONDENSATE LINE 20"-C-26

COMPONENT LOCATION SKETCH No.031

TURBINE BUILDING-HEATER BAY
 REFERENCES: G191157,G191186,G191187,5920-FS-116,5290-FS-117











TURBINE BUILDING-HEATER BAY
 REFERENCES: G191157,G191186,G191187,5920-FS-I16


REVISION 1: 6/17/93
VERMONT YANKEE PIPING EROSION-CORROSION INSPECTION PROGRAM
CONDENSATE LINE 20'-C-29
COMPONENT LOCATION SKETCH No.034
















TURBINE BUILDING-HEATER BAY
 REFERENCES: G191158,G191188,G191189,5920-FS-I35




TURBINE BUILDING-HEATER BAY
 REFERENCES: G191158,G191188,G191189,5920-FS-135




TURBINE BUILDING-HEATER BAY
 REFERENCES: G191158,G191188,G191189,5920-FS-135

REVISION 0: 7/13/90
VERMONT YANKEE PIPING EROSION-CORROSION INSPECTION PROGRAM
CONDENSATE LINE 12'-C-23
COMPONENT LOCATION SKETCH No.042



TURBINE BUILDING-HEATER BAY
 REFERENCES: G191158,G191188,G191189,5920-FS-135

REVISION 1: 2/7/92
 VERMONT YANKEE PIPING EROSION-CORROSION INSPECTION PROGRAM
 HEATER DRAIN LINES 6"-HD-1A & 6"-HD-2A
 COMPONENT LOCATION SKETCH No. 043




TURBINE BUILDING-HEATER BAY
 REFERENCES: G191158,G191188,G191189,5920-FS-15


REVISION 2: 6/17/93

VERMONT YANKEE PIPING EROSION-CORROSION INSPECTION PROGRAM

HEATER DRAIN LINES 10"-HD-3A & 10"-HD-4A

COMPONENT LOCATION SKETCH No. 044






TURBINE BUILDING-HEATER BAY
 REFERENCES: G191158,G191188,G191189,5920-FS-I35

VERMONT YANKEE PIPING EROSION-CORROSION INSPECTION PROGRAM

HEATER DRAIN LINES 16"-HD-7A & 20"-HD-25A


COMPONENT LOCATION SKETCH No.046


REVISION 1: 6/16/93




REVISION 11 6/16/93
VERMONT YANKEE PIPING EROSION-CORROSION INSPECTION PROGRAM
HEATER DRAIN LINES 16"-HD-8A, 12"-HD-9A 18"-HD-21A
COMPONENT LOCATION SKETCH No.047

TURBINE BUILDING-HEATER BAY
 REFERENCES: G191158,G191188,G191189,5920-FS-135











TURBINE BUILDING-HEATER BAY
 REFERENCES: G191158, G191188, G191189, 5920-FS-135


REVISION 1: 2/7/92
VERMONT YANKEE PIPING EROSION-CORROSION INSPECTION PROGRAM
HEATER DRAIN LINES 6"-HD-1B & 6"-HD-2B
COMPONENT LOCATION SKETCH No.050













REVISION 1: 2/7/92


VERMONT YANKEE PIPING EROSION-CORROSION INSPECTION PROGRAM


HEATER DRAIN LINES 12"-HD-9B & 4"-HD-10B


COMPONENT LOCATION SKETCH No. 055















CONT. FROM SKETCH No. 05B EL 227'-7"

CONT FROM SKETCH No. 057 EL 226'-2"


TURBINE BUILDING-HEATER BAY
 REFERENCES: G191158,G191188,G191189,5920-FS-15

VERMONT YANKEE PIPING EROSION-CORROSION INSPECTION PROGRAM

HEATER DRAIN LINES 6"-HD-12A, 6"-HD-12B, AND 14"-HD-15B

COMPONENT LOCATION SKETCH No. 061

REVISION 2: 6/17/93




CONT. FROM SKETCH No. 060
EL 227'-7"

CONT. FROM SKETCH No. 059
EL 226'-2"


TURBINE BUILDING-HEATER BAY
REFERENCES: G191158,G191188,G191189,5920-FS-15


REVISION 1: 2/7/92
VERMONT YANKEE PIPING EROSION-CORROSION INSPECTION PROGRAM
HEATER DRAIN LINES 6'-HD-12C, 6'-HD-12D, AND 14'-HD-15A
COMPONENT LOCATION SKETCH No. 062





VERMONT YANKEE PIPING EROSION-CORROSION INSPECTION PROGRAM
EXTRACTION STEAM LINE 12"-ES-1A
COMPONENT LOCATION SKETCH No. 063

TURBINE BUILDING-HEATER BAY
 REFERENCES: G191156,G191184,G191185,5920-FS-I-8











TURBINE BUILDING-HEATER BAY
 REFERENCES: G191156,G191184,G191185,5920-FS-132


REVISION 2: 6/16/93
 VERMONT YANKEE PIPING EROSION-CORROSION INSPECTION PROGRAM



EXTRACTION STEAM LINE 20-ES-3A

COMPONENT LOCATION SKETCH No. 067











REVISION 1: 2/7/92

VERMONT YANKEE PIPING EROSION-CORROSION INSPECTION PROGRAM

EXTRACTION STEAM LINES 20" & 26"-ES-5A
5B,5C,5D

COMPONENT LOCATION SKETCH No. 071


INSIDE CONDENSER E-6-1A
REFERENCES: G191156,5920-FS-I32



INSIDE CONDENSER E-6-1B
 REFERENCES: G191158,5920-FS-132


REVISION 1: 2/7/92

VERMONT YANKEE PIPING EROSION-CORROSION INSPECTION PROGRAM
EXTRACTION STEAM LINES 20' & 26'-ES-5E 5F,5G,5H
COMPONENT LOCATION SKETCH No. 072




TURBINE BUILDING-H.P. HEATER BAY
 REFERENCES: G191156, G191184, G191185

REVISION 1; 6/16/93
VERMONT YANKEE PIPING EROSION-CORROSION INSPECTION PROGRAM
EXTRACTION STEAM LINE 12'-ES-6
COMPONENT LOCATION SKETCH No. 073





DRYWELL & STEAM TUNNEL
 REFERENCES: G191167, G191182, 5920-FS-13


REVISION 0: 6/23/93
 VERMONT YANKEE PIPING EROSION-
 CORROSION INSPECTION PROGRAM
 MAIN STEAM LINE 18"-MS-1A & 18"-MS-7A
 COMPONENT LOCATION SKETCH No.074




TURBINE BUILDING-HEATER BAY
 REFERENCES: G191156,G191182,G191183,5920-FS-II&I2











TURBINE BUILDING-HEATER BAY
 REFERENCES: G191156,G191182,G191183,5920-FS-I1&12


REVISION 0: 6/23/93
VERMONT YANKEE PIPING EROSION-CORROSION INSPECTION PROGRAM
MAIN STEAM LINE 18'-MS-1C (CONTINUED)
COMPONENT LOCATION SKETCH No. 079



DRYWELL & STEAM TUNNEL
 REFERENCES: G191167, G191182, 5920-FS-13

REVISION 0: 6/23/93
 VERMONT YANKEE PIPING EROSION-CORROSION INSPECTION PROGRAM
 MAIN STEAM LINE 18"-MS-1D & 18"-MS-7D
 COMPONENT LOCATION SKETCH No.080






TURBINE BULDING-HEATER BAY
 REFERENCES: G191156,5920-6841,5920-6846,5920-FS-12


REVISION 0: 6/25/93

VERMONT YANKEE PIPING EROSION-CORROSION INSPECTION PROGRAM

30" & 36" TURBINE CROSS
 AROUND PIPING - "A" LINE

COMPONENT LOCATION SKETCH No.082






TURBINE BUILDING-HEATER BAY
 REFERENCES: G191156,5920-6841,5920-6846,5920-F5-12


VERMONT YANKEE PIPING EROSION-CORROSION INSPECTION PROGRAM

30" & 36" TURBINE CROSS
 AROUND PIPING - 'C' LINE

COMPONENT LOCATION SKETCH No.084


REVISION 0: 6/25/93








REACTOR BLDG NW / STEAM TUNNEL
 REFERENCES: G191178,VYI-CUW-PART4

REVISION 0: 7/1/93
VERMONT YANKEE PIPING EROSION-CORROSION INSPECTION PROGRAM
REACTOR WATER CLEAN UP 4"-CUW-54 & 4"-CUW-55
COMPONENT LOCATION SKETCH No.086









TURBINE BYPASS
VALVE CHEST A
BPV 4

EL 261'-4"

MS3DSP01

MS3DELO1

EL 259'-4"

MS3DELO2

MS3DSP02

MS3DELO3

MS3DSP03

49'-3"

SLOPE

MS3DSP04

MS3DELO4

13'-9"

FLOW

MS3DSP05

EL 258'-9"

MS3DELO5

MS3DSP06

CONDENSER A

EL 246'-0"

MS3DSP08

MS3DELO6

EL 246'-3"

MS3DELO7

2'

5'-0"

MS3DSP07

MS3DELO8

15'-0"

2'


REVISION 0: 8/4/93

VERMONT YANKEE PIPING EROSION-CORROSION INSPECTION PROGRAM


10'-MS-3D

COMPONENT LOCATION SKETCH No.090

TURBINE BUILDING-HEATER BAY
REFERENCES: G191156,G191182,G191183,5920-FS-I2



TURBINE BYPASS VALVE CHEST A
BPV 5




TURBINE BUILDING-HEATER BAY
REFERENCES: G191156,G191182,G191183,5920-FS-12


REVISION 0: 8/4/93


VERMONT YANKEE PIPING EROSION-CORROSION INSPECTION PROGRAM

10"-MS-3E

COMPONENT LOCATION SKETCH No.091








TURBINE BUILDING-HEATER BAY
 REFERENCES: G191156,G191182,G191183,5920-FS-12


REVISION 0: 8/2/93

VERMONT YANKEE PIPING EROSION-
 CORROSION INSPECTION PROGRAM

10'-MS-3H

COMPONENT LOCATION SKETCH No.094







TURBINE BUILDING-HEATER BAY
 REFERENCES: G191156,G191182,G191183,5920-FS-I2

REVISION 0: 8/4/93

VERMONT YANKEE PIPING EROSION-CORROSION INSPECTION PROGRAM

10"-MS-3J

COMPONENT LOCATION SKETCH No.096



TURBINE BULDING-HEATER BAY
 REFERENCES: G191156,G191182,G191183,5920-FS-I-1B

REVISION 0: 8/18/93	COND A EL 237'-1/2"
VERMONT YANKEE PIPING EROSION-CORROSION INSPECTION PROGRAM	
8'-MSD-9	
COMPONENT LOCATION SKETCH No.097	

APPENDIX B

SMALL BORE PIPING INSPECTION LOCATION DATABASE

Identification of Small bore components

Only specific small bore locations consisting of piping components (valves, steam traps, orifices, etc.) and the adjacent piping will be inspected under this program. These locations were selected and identified in reference 5.4.3., and are compiled in the Small Bore Inspection Database.

Each location has been given a unique point number in the Small Bore Component Database. Additional components will be included into the database as warranted. Since the majority of the small bore components will be inspected only once, the previous system for identification of inspection results was retained.

Each inspection performed is identified as follows:

"YR-SBxx"

where: YR - is the year the location is inspected.
 SB - denotes small bore piping (less than 2-1/2" diameter).
 xx - a number assigned to the location by the FACPC for that specific
 refueling outage.

Example: 93-SB04

The Data base identifies all small bore points inspected up to and including the 1999 RFO.

APPENDIX B (Continued)

SMALL BORE PIPING INSPECTION LOCATION DATABASE										
PT.	PREV. INSPECT. No.	SYSTEM	DESCRIPTION	LOCATION	DRAWINGS	COMMENTS	SIZE	SCH.	T _{nom} inch	T _{min} inch
1	93-SB01	MSD	1" Pipe & Fittings D.S. of valve M-33	Rx. Bldg. Torus Area	G191167	MS-33(N.C.)labeled as orificed valve.	1"	160	.250	.053
2	93-SB02 95-SB01	MSD	1" Pipe & Fittings D.S. of steam trap ST60-3.	Rx. Bldg. Torus Area	G191167	Normal flow to condenser is thru ST60-3. (dp=965psi)	1"	160	.250	.053
3	93-SB03	MSD	1" piping D.S. of LCV-2-143	Rx. Bldg. Torus Area	G191167	Mn Steam strainer ST60-3 blow down. (dp=965psi)	1"	160	.250	.053
4	93-SB04	MSD	3" & 2½" MSD D. S. of valve MS-79 (3"-MSD-4)	Rx. Bldg. Torus Area	G191167	N.C. valve (dp=965psi)	3" 2½"	160 160	.438 .375	0.141 0.116
5	93-SB05	MSD	3" MSD-4 U.S. of Condenser A. Nozzle 67	T. B. - Heater Bay	G191156	IE	3"	160 STD	.438 .216	0.141 0.141
6	93-SB06	MSD	1" & 2½" MSD-7A D.S. of steam trap, ST-60-2A	T. B. - Heater Bay	G191156	IE	1" 2-1/2"	160 160	.250 .375	.053 .116
7	93-SB07	MSD	1" & 2½" MSD-8A @ LCV-38A.	T. B. - Heater Bay	G191156	IE	1" 2½"	160 160	.250 .375	.053 .116
8	95-SB03	MSD	1" & 2½" MSD-7B D.S. of steam trap, ST-60-2B.	T. B. - Heater Bay	G191156	IE	1" 2-1/2"	160 160	.250 .375	.053 .116
9	95-SB04	MSD	1" & 2½" MSD-8B @ LCV-38B.	T. B. - Heater Bay	G191156	IE	1" 2½"	160 160	.250 .375	.053 .116
10	93-SB09	MSD	1"&2½" MSD-7C D.S. of steam trap ST60-2C.	T. B. - Heater Bay	G191156	IE	1" 2-1/2"	160 160	.250 .375	.053 .116
11	93-SB10 95-SB02	MSD	1" & 2½" MSD-8C @ LCV-38C.	T. B. - Heater Bay	G191156	IE	1" 2½"	160 160	.250 .375	.053 .116
12	95-SB05	MSD	1" & 2½" MSD-7D D.S. of steam trap, ST-60-2D.	T. B. - Heater Bay	G191156	IE	1" 2-1/2"	160 160	.250 .375	.053 .116
13	95-SB-06	MSD	1" & 2½" MSD-8D @ LCV-38D.	T. B. - Heater Bay	G191156	IE	1" 2½"	160 160	.250 .375	.053 .116
	93-SB08	MSD	8" MSD-9 Hdr. @ 2½" conn. (See L.B. Sketch 097)	T. B. - Heater Bay	G191156	(IE) Portions of LB component inspected with SB pipe.	8"	80	.500	.347

APPENDIX B (Continued)

SMALL BORE PIPING INSPECTION LOCATION DATABASE										
PT.	PREV. INSPECT. No.	SYSTEM	DESCRIPTION	LOCATION	DRAWINGS	COMMENTS	SIZE	SCH.	T nom inch	T min inch
14	93-SB12	MSD	1"&2½" Piping @ valve MS-2A.	T. B. - Heater Bay	G191156	IE	1"	160	.250	.053
15	95-SB-07	MSD	1"&2½" Piping @ valve MS-2B.	T. B. - Heater Bay	G191156	IE	1"	160	.250	.053
16	93-SB13	MSD	1"&2½" Piping @ valve MS-2C.	T. B. - Heater Bay	G191156	IE	1" 2½"	160 160	.250 .375	.053 .116
17	95-SB08	MSD	1"&2½" Piping @ valve MS-2D.	T. B. - Heater Bay	G191156	IE	1" 2½"	160 160	.250 .375	.053 .116
18	93-SB14	MSD	D.S. of valve MS-4 on 2½" MSD-6.	T. B. - Heater Bay	G191156	IE	2½"	160	.375	.116
19	93-SB15	MSD	2½" MSD-6 @ Fittings U. S. of Condenser A.	T. B. - Heater Bay	G191156	IE	2½"	160	.375	.116
20	95-SB09 96-SB01	MSD	2½" MSD-6. (2 ft. length at Connect. to Condens. A -Noz.33	T. B. - Heater Bay	G191156	IE	2½"	160	.375	.116
21	93-SB16	MSD	1" MSD U.S. & D.S. of valve MS-5A.	T. B. - Heater Bay	G191156	IE	1"	160	.250	.053
22	93-SB55	MSD	1" MSD U.S. & D.S. of valve MS-5B.	T. B. - Heater Bay	G191156	IE	1"	160	.250	.053
23	93-SB17	MSD	1" MSD U.S. & D.S. of valve MS-5C.	T. B. - Heater Bay	G191156	IE	1"	160	.250	.053
24	93-SB56	MSD	1" MSD U.S. & D.S. of valve MS-5D.	T. B. - Heater Bay	G191156	IE	1"	160	.250	.053
25	93-SB18	MSD	2" MSD hdr. Under 5A & 5C valves.	T. B. - Heater Bay	G191156	IE	2"	160	.344	.096
26	93-SB19	MSD	2" pipe & fittings D.S. of valves MS-5A to 5D..	T. B. - Heater Bay	G191156	IE	2"	160	.344	.096
27	95-SB10	MSD	2" pipe & fittings D.S. of valves MS-5A to 5D. at Connect to Condenser. A Noz.34	T. B. - Heater Bay	G191156	IE	2"	160	.344	.096
28	92-SB10 92-SB11 95-SB38	MSD	2" pipe & fittings D.S. of valve MS-12 up to tee conn.	T. B. - Heater Bay	G191156	Leak @ MS-12 valve in 1992 Replaced in 1992	2"	80	.218	.096
29	92-SB13 to 92-SB15 95-SB11	MSD	1" pipe & fittings U.S. & D.S. of R.O. 60-1 up to tee conn.	T. B. - Heater Bay	G191156	Replaced in 1992.	1"	80	.179	.053

APPENDIX B (Continued)

SMALL BORE PIPING INSPECTION LOCATION DATABASE										
PT.	PREV. INSPECT. No.	SYSTEM	DESCRIPTION	LOCATION	DRAWINGS	COMMENTS	SIZE	SCH.	Tnom inch	T min inch
30A	92-SB12 95-SB12	MSD	2" piping D.S. of tee conn. D.S. of R.O.60-1.	T. B. - Heater Bay	G191156	Leak @MS-12 valve in 1992 Replaced in 96 W/ A335 P11	2"	80	.218	.096
30B	95-SB12	MSD	2" piping D.S. of tee conn. D.S. of R.O. 60-1. at condenser	T. B. - Heater Bay	G191156	Replaced in 96 W/ A335 P11				
31	96-SB03	MSD (HPCI)	1" pipe & fittings D.S. of valve HPCI FCV - 43	RX. - HPCI Room.	G191169 VYI-HPCI/RCIC-DRAIN	Replaced in 1990, w/ A335-P11	1"	80	.179	.053
32	96-SB04	MSD (RCIC)	1" pipe & fittings D.S. of valve RCIC FCV-35	RX. - RCIC Room	G191174 VYI-HPCI/RCIC-DRAIN	Replaced in 1990, w/ A335-P11	2"	80	.218	.096
33		MSD (HPCI/RCIC)	2" pipe & fittings U.S. of connect. to Condenser B.	T.B. - Heater Bay	G191156 VYI-HPCI/RCIC-DRAIN	Replaced in 1990, w/ A335-P11	2"	80	.218	.096
34	93-SB20	HV	1"-HV-1A, pipe & fittings U.S. of connect. to Cond. B.	T. B. - Heater Bay	G191158	Industry Experience Point	1"	80	.179	.011
35	93-SB21	HV	1"HV -1A, pipe & fittings D.S. of R.O.-1A	T. B. - Heater Bay	G191158	Industry Experience Point	1"	80	.179	.011
36	93-SB22	HV	1"HV-1A, pipe & fittings @ valve HV-1A	T. B. - Heater Bay	G191158	Industry Experience Point	1"	80	.179	.011
37	95-SB17	HV	1"-HV-1B. pipe & fittings U.S. of connect. to Cond. B	T. B. - Heater Bay	G191158	Industry Experience Point	1"	80	.179	.011
38	95-SB16	HV	1"- HV-1B, pipe & fittings D.S. of R.O.-1B	T. B. - Heater Bay	G191158	Industry Experience Point	1"	80	.179	.011
39	95-SB18	HV	1"-HV-1B, pipe & fittings @ valve HV-1B	T. B. - Heater Bay	G191158	Industry Experience Point	1"	80	.179	.011
40	95-SB19 98-SB01	HV	1"-HV-2A, pipe & fittings @ valve HV-4A	T. B. - Heater Bay	G191158	Industry Experience Point	1"	80	.179	.007
41	95-SB20 98-SB02	HV	1"-HV-2A, pipe & fittings @ R.O.-2A.	T. B. - Heater Bay	G191158	Industry Experience Point	1"	80	.179	.007

APPENDIX B (Continued)

SMALL BORE PIPING INSPECTION LOCATION DATABASE										
PT.	PREV. INSPECT. No.	SYSTEM	DESCRIPTION	LOCATION	DRAWINGS	COMMENTS	SIZE	SCH.	T nom inch	T min inch
42	95-SB21 98-SB03	HV	1"-HV-2A, pipe & fittings @ Condenser A.	T. B. - Heater Bay	G191158	Industry Experience Point	1"	80	.179	.007
43	93-SB23	HV	1"-HV-2B, pipe & fittings @ valve HV-4B	T. B. - Heater Bay	G191158	Industry Experience Point	1"	80	.179	.007
44	93-SB24	HV	1"-HV-2B, pipe & fittings @ R.O.-2B.	T. B. - Heater Bay	G191158	Industry Experience Point	1"	80	.179	.007
45	93-SB25	HV	1"-HV-2B, pipe & fittings @ condenser A	T. B. - Heater Bay	G191158	Industry Experience Point	1"	80	.179	.007
46		HV	1½"-HV-3A, pipe & fittings @ valve HV-7A	T. B. - Heater Bay	G191158	Industry Experience Point	1½"	80	.200	.007
47	95-SB22	HV	1½"-HV-3A, pipe & fittings @ Condenser A. Nozzle 23	T. B. - Heater Bay	G191158	Industry Experience Point	1½"	80	.200	.007
48		HV	2"-HV-9A, pipe & fittings @ R.O.-3A.	T. B. - Heater Bay	G191158	Industry Experience Point	2"	80	.218	.008
49		HV	2"-HV-9A, pipe & fittings D.S. of valve HV- 15A	T. B. - Heater Bay	G191158	IE	2"	80	.218	.008
50		HV	2"-HV-9A, pipe & fittings @ Condenser A.	T. B. - Heater Bay	G191158	IE	2"	80	.218	.008
51		HV	1½"-HV-3B, pipe & fittings @ valve HV-7B	T. B. - Heater Bay	G191158	IE	1½"	80	.200	.007
52	95-SB23	HV	1½"-HV-3B, pipe & fittings @ Condenser A.	T. B. - Heater Bay	G191158	IE	1½"	80	.200	.007
53		HV	2"-HV-9B, pipe & fittings @ R.O.-3B.	T. B. - Heater Bay	G191158	IE	2"	80	.218	.008
54		HV	2"-HV-9B, pipe & fittings D.S. of valve HV- 15B	T. B. - Heater Bay	G191158	IE	2"	80	.218	.008
55		HV	2"-HV-9B, pipe & fittings @ Condenser A.	T. B. - Heater Bay	G191158	IE	2"	80	.218	.008

APPENDIX B (Continued)

SMALL BORE PIPING INSPECTION LOCATION DATABASE										
PT.	PREV. INSPECT. No.	SYSTEM	DESCRIPTION	LOCATION	DRAWINGS	COMMENTS	SIZE	SCH.	T nom inch	T min inch
56		HV	2½"-HV-4A, pipe & fittings U.S. of connect. to Cond. B.	T. B. - Heater Bay	G191158	Industry Experience Point	1"	80	.179	.011
57		HV	2½"-HV-4A, pipe & fittings D.S. of R.O.-4A	T. B. - Heater Bay	G191158	Industry Experience Point	1"	80	.179	.011
58		HV	2½"-HV-4A, pipe & fittings @ valve HV-9A	T. B. - Heater Bay	G191158	Industry Experience Point	1"	80	.179	.011
59		HV	2½"-HV-4B, pipe & fittings U.S. of connect. to Cond. B	T. B. - Heater Bay	G191158	Industry Experience Point	1"	80	.179	.011
60		HV	2½"-HV-4B, pipe & fittings D.S. of R.O.-4B	T. B. - Heater Bay	G191158	Industry Experience Point	1"	80	.179	.011
61		HV	2½"-HV-4B, pipe & fittings @ valve HV-9B	T. B. - Heater Bay	G191158	Industry Experience Point	1"	80	.179	.011
62	95-SB24 98-SB08	ES	2"-ES-12A piping US & DS of LCV-2A near Condenser A	T. B. - Heater Bay	G191156	Industry Experience Point	2"	80	.218	.012
63	95-SB25	ES	2"-ES-10A piping US & DS of LCV-3A near Condenser A	T. B. - Heater Bay	G191156	Industry Experience Point	2"	80	.218	.012
64	93-SB26	ES	2"-ES-12B piping US & DS of LCV-2B near Condenser B.	T. B. - Heater Bay	G191156	Industry Experience Point	2"	80	.218	.012
65	93-SB27 98-SB09	ES	2"-ES-10B piping US & DS of LCV-3B near Condenser B	T. B. - Heater Bay	G191156	Industry Experience Point	2"	80	.218	.012
66	93-SB28	AS	1" piping US & DS of valve LCV-101-39	T.B. - SIAE Room.	G191156	Industry Experience Point	1"	160	.250	.053
67	93-SB29 98-SB04	AS	1" & 2" piping US & DS of steam trap ST 62-1.	T.B. - SIAE Room.	G191156	Industry Experience Point	1" 2"	160 160	.250 .344	.053 .096
68	93-SB30 98-SB03	AS	2"-MSD-465 pipe & fittings @ connect. to Condenser B Nozzle 68	T.B. - Heater Bay	G191156	Industry Experience Point	2"	160	.344	.096

APPENDIX B (Continued)

SMALL BORE PIPING INSPECTION LOCATION DATABASE										
PT.	PREV. INSPECT. No.	SYSTEM	DESCRIPTION	LOCATION	DRAWINGS	COMMENTS	SIZE	SCH.	T nom inch	T min inch
69	95-SB26	AS	2"-MSD-465 pipe & fittings DS of valve V-62-2	T.B. - SJAЕ Room.	G191156	Industry Experience Point	1"	160	.250	.053
70	95-SB27	AS	1" piping US & DS of valve LCV-101-40	T.B. - SJAЕ Room.	G191156	Industry Experience Point	1"	160	.250	.053
71	95-SB28 98-SB06	AS	1" & 1½" piping US & DS of steam trap ST 62-2.	T.B. - SJAЕ Room.	G191156	Industry Experience Point	1" 2"	160 160	.250 .344	.053 .096
72	95-SB29 98-SB07	AS	1½"-MSD-464 pipe & fittings @ connect. to Condenser B Nozzle 69	T.B. - Heater Bay	G191156	Industry Experience Point	2"	160	.344	.096
73	95-SB30	AS(AOG)	2" piping of DS of valve OG PRV -834A	T.B. - Heater Bay El.248.	33600-A217	Industry Experience Point	1"	160	.250	.053
74	95-SB31	AS(AOG)	¾" piping US & DS of steam trap MS-113-1A.	T.B. - Heater Bay El.248.	33600-A217	Industry Experience Point	1" 2"	160 160	.250 .344	.053 .096
75	95-SB32	AS(AOG)	¾" piping US & DS of steam trap MS115-1A	T.B. - Heater Bay El.248.	33600-A217	Industry Experience Point	2"	160	.344	.096
76	95-SB33	AS(AOG)	¾"MS-189-D3 AS drain from OG @ conn. to 3"-MSD-4.	T.B. - Heater Bay El 233'-4"	33600-A217	Industry Experience Point	2"	160	.344	.096
77	95-SB34	AS(AOG)	¾"HCN-188-H1 AS drain from OG @ conn. to 3"-MSD-4.	T.B. - Heater Bay El 233'-4"	33600-A217	I. E. Point, Replaced prior to 1990	2"	160	.344	.096
78	93-SB31	SSL	1½" & 3" Header for 1SLMSV off Turbine Stop Valves	T.B. - Heater Bay.	5920-224	Industry Experience Point	1½" 3"	80 40	.200 .216	.077 .141
79	93-SB32	SSL	1½"-1SLMSV - Stop Valve A	T.B. - Heater Bay	5920-224	Industry Experience Point	1½"	80	.200	.077
80	93-SB33	SSL	1½"-1SLMSV - Stop Valve B	T.B. - Heater Bay	5920-224	Industry Experience Point	1½"	80	.200	.077
81	93-SB34	SSL	1½"-1SLMSV - Stop Valve C	T.B. - Heater Bay	5920-224	Industry Experience Point	1½"	80	.200	.077
82	93-SB35	SSL	1½"-1SLMSV - Stop Valve D	T.B. - Heater Bay	5920-224	Industry Experience Point	1½"	80	.200	.077

APPENDIX B (Continued)

SMALL BORE PIPING INSPECTION LOCATION DATABASE										
PT.	PREV. INSPECT. No.	SYSTEM	DESCRIPTION	LOCATION	DRAWINGS	COMMENTS	SIZE	SCH.	T nom inch	T min inch
83	93-SB36	SSL	1½" Header for 1SCVL off Turbine Control Valves	T.B. - Heater Bay	5920-224		1½"	80	.200	.067
84	93-SB38	SSL	½"-1SCVL - Control Valve A.	T.B. - Heater Bay	5920-224		½"	80	.147	.033
85	93-SB39/40	SSL	½"-1SCVL - Control Valve B.	T.B. - Heater Bay	5920-224		½"	80	.147	.033
86	93-SB41/42	SSL	½"-1SCVL - Control Valve C.	T.B. - Heater Bay	5920-224		½"	80	.147	.033
87	93-SB37	SSL	½"-1SCVL - Control Valve D.	T.B. - Heater Bay	5920-224		½"	80	.147	.033
88	93-SB43	SSL	1" & 3" Header for 2SLMSV off Turbine Stop Valves A & B	T.B. - Heater Bay	5920-224		2-1/2" 1"	40 80	.203 .179	.116 .053
89	93-SB44	SSL	1" & 3" Header for 2SLMSV off Turbine Stop Valve C	T.B. - Heater Bay	5920-224		3" 1"	40 80	.216 .179	.141 .053
90	93-SB45	SSL	1" - 2SLMSV off Turbine Stop Valve D	T.B. - Heater Bay	5920-224		3" 1"	40 80	.216 .179	.141 .053
91	93-SB58	SSL	2½" - Header for 2SCVL off Turbine Control Valves	T.B. - Heater Bay	5920-224		1"	80	.179	.053
92	93-SB61	SSL	1" - 2SCVL off Control Valve A	T.B. - Heater Bay	5920-224		2¼"	40	.203	.116
93	93-SB60	SSL	1" - 2SCVL off Control Valve B	T.B. - Heater Bay	5920-224		1"	80	.179	.053
94	93-SB59	SSL	1" - 2SCVL off Control Valve C	T.B. - Heater Bay	5920-224		1"	80	.179	.053
95	93-SB57	SSL	1" - 2SCVL off Control Valve D	T.B. - Heater Bay	5920-224		1"	80	.179	.053
96	92-(SB-info only)	SSL	Turbine Bypass Valve Chest 1st Seal Leakoff 1/2"-1SLBPV	T.B. - Heater Bay	5920-224		1/2"	80	.147	.034
97	92-SB01	SSL	TBV Chest 1st Seal Leakoff 2"-1SLBPV	T.B. - Heater Bay	5920-224		2"	80	.218	.099
98	92-SB02	SSL	TBV Chest 1st Seal Leakoff 2"-1SLBPV	T.B. - Heater Bay	5920-224		2"	80	.218	.099
99	92-SB03	SSL	TBV Chest 1st Seal Leakoff 2"-1SLBPV	T.B. - Heater Bay	5920-224		2"	80	.218	.099

APPENDIX B (Continued)

SMALL BORE PIPING INSPECTION LOCATION DATABASE										
PT.	PREV. INSPECT. No.	SYSTEM	DESCRIPTION	LOCATION	DRAWINGS	COMMENTS	SIZE	SCH.	T nom inch	T min inch
100	92-SB04	SSL	TBV Chest 1st Seal Leakoff 2"-1SLBPV	T.B. - Heater Bay	5920-224		2"	80	.218	.099
101	92-SB05	SSL	TBV Chest 1st Seal Leakoff 2"-1SLBPV	T.B. - Heater Bay	5920-224		2"	80	.218	.099
102		SSL	TBV Chest 1st Seal Leakoff 2"-1SLBPV	T.B. - Heater Bay	5920-224	Not Inspected in 1992	2"	80	.218	.099
103	92-SB07	SSL	TBV Chest 1st Seal Leakoff 2"-1SLBPV	T.B. - Heater Bay	5920-224		2"	80	.218	.099
104	92-SB08	SSL	TBV Chest 1st Seal Leakoff 2"-1SLBPV	T.B. - Heater Bay	5920-224		2"	80	.218	.099
105	92-SB09	SSL	TBV Chest 1st Seal Leakoff 2"-1SLBPV	T.B. - Heater Bay	5920-224	Vertical section replaced in 1992.	2"	80	.218	.099
106	92-SB10	SSL	TBV Chest 1st Seal Leakoff 2"-1SLBPV	T.B. - Heater Bay	5920-224	Loc. of 1992 leak, replaced in 1992.	2"	80	.218	.099
107	93-SB46	SSL	TBV Chest 2nd Seal Leakoff 2½" - 2SLBPV	T.B. - Heater Bay	5920-224	Continuation of 1992 inspections	2½"	40	.203	.116
108	93-SB47 95-SB35	SSL	TBV Chest 2nd Seal Leakoff 2½" - 2SLBPV	T.B. - Heater Bay	5920-224	" "	2½"	40	.203	.116
109	93-SB48A 93-SB48B 95-SB36A 95-SB36B	SSL	TBV Chest 2nd Seal Leakoff 2½" - 2SLBPV	T.B. - Heater Bay	5920-224	" "	2½"	40	.203	.116
110	93-SB49	SSL	2½" - 1SPL2 H.P. Turbine Pocket Drain	T.B. - Heater Bay	5920-224	Significant Wear @ Duane Arnold	2½"	40	.203	.023
111	93-SB50	SSL	2½" - 1SPL2 H.P. Turbine Pocket Drain	T.B. - Heater Bay	5920-224	" "	2½"	40	.203	.023
112	93-SB51	SSL	2½" - 1SPL2 H.P. Turbine Pocket Drain	T.B. - Heater Bay	5920-224	" "	2½"	40	.203	.023
113	93-SB52	SSL	2½" - 1SPL2 H.P. Turbine Pocket Drain	T.B. - Heater Bay	5920-224	" "	2½"	40	.203	.023
114	93-SB53	SSL	2½" - 1SPL2 H.P. Turbine Pocket 90 deg elbow	T.B. - Heater Bay	5920-224	" "	2½"	40	.203	.023
115	93-SB54	SSL	1SPL2 2½" x 2" reducer at 36" CAR pipe.	T.B. - Heater Bay	5920-224	" "	2½" 2"	40 40	.203 .154	.023 .019

APPENDIX B (Continued)

SMALL BORE PIPING INSPECTION LOCATION DATABASE										
PT.	PREV. INSPECT. No.	SYSTEM	DESCRIPTION	LOCATION	DRAWINGS	COMMENTS	SIZE	SCH.	Tnom inch	T min inch
116	95-SB37	C	1½" & 2½" piping US & DS of LCV 1A-3	T.B. - Heater Bay	G191157 Sht.1	IE	1½" 2½"	80 80	.200 .276	.038 .057
117		MSD	Steam Seal Regulator to Steam Seal Piping low point drain		G191156 5920-224	IE	1"			
118		HV	4"-HV-8A @ Condenser A No.4 continuous vent.	T.B. - Heater Bay	G191158	IE				
119		C	1" Piping D.S. of R.O. 64-2	T.B. - Heater Bay	G191157 Sht.1	IE				
120		ES	3"-ES-8A D.S. of LCV-4A	T.B. - Heater Bay	G191156	IE				
121		ES	3"-ES-8B D.S. of LCV-4B	T.B. - Heater Bay	G191156	IE				
122	99-SB01	MSD	1" piping US & DS valve HPCI-LCV-53	Rx. Bldg. HPCI Rm.	G191169 Sht.1 VYI-HPCI- Pt.3A St.2/2	(I.E.) Dresden 3 LER 3/96	1"	160	.250	.053
123	99-SB02	MSD	1" piping US & DS of Steam Trap ST-3	Rx. Bldg. HPCI Rm.	G191169 Sht.1 VYI-HPCI- Pt.3A St.2/2	(I.E.) Dresden 3 LER 3/96	1"	160	.250	.053
124	99-SB03	MSD	1" piping US & DS valve HPCI-FCV-42	Rx. Bldg. HPCI Rm.	G191169 Sht.1 VYI-HPCI- Pt.3A St.2/2	(I.E.) Dresden 3 LER 3/96	1"	160	.250	.053
125	99-SB04	MSD	1" piping US & DS valve RCIC LCV-32	Rx. Bldg. RCIC Rm.	G191174 Sht.1 VYI-RCIC-Pt.3A Shts.1/2 & 2/2	(I.E.) Dresden 3 LER 3/96	1"	160	.250	.053
126	99-SB05	MSD	1" piping US & DS of Steam Trap ST-6	Rx. Bldg. RCIC Rm.	G191174 Sht.1 VYI-RCIC-Pt.3A Shts.1/2 & 2/2	(I.E.) Dresden 3 LER 3/96	1"	160	.250	.053
127	99-SB06	MSD	1" piping US & DS valve RCIC FCV-34	Rx. Bldg. RCIC Rm.	G191174 Sht.1 VYI-RCIC-Pt.3A Shts.1/2 & 2/2	(I.E.) Dresden 3 LER 3/96	1"	160	.250	.053

APPENDIX C

IDENTIFICATION OF FAC SUSCEPTIBLE SYSTEMS & COMPONENTS

C.1 FAC PHENOMENON

Flow-accelerated corrosion is a process that leads to wall thinning (metal loss) in carbon or low alloy steel piping exposed to flowing water or wet steam. The rate of metal loss depends on a complex interplay of several parameters. These include but are not limited to:

- water chemistry; pH, oxygen content, and temperature.
- piping material composition; chromium, copper, and molybdenum content.
- hydrodynamics; fluid flow velocity, piping geometry, and steam quality.

This phenomenon normally occurs in flowing deoxygenated water with a pH between 7.0 and 9.5. It is not a classical erosion process in that the metal loss is not caused by a mechanical process. A large body of experimental work has identified several key variables that influence the rate of attack. These are listed below with an indication of how they impact the material loss behavior.

<u>Variable:</u>	<u>FAC increases if variable is:</u>
Fluid Velocity	Higher
Fluid pH level	Lower
Fluid oxygen content	Lower
Fluid temperature	250-400 F.
Steam Quality	0.1 - 0.9
Component Geometry	Such as to create more turbulence
Component chromium content	Lower
Component copper content	Lower
Component molybdenum content	Lower

Single phase FAC is most likely to occur in main feedwater, condensate, and heater drain piping. Areas demonstrated to be especially susceptible include bypass lines for recirculation flow around pumps and control valves. It is also likely to occur downstream of control valves (angle valves in particular), restriction orifices, and in elbows in close proximity to other fittings.

Two-phase FAC often occurs in piping for main steam, extraction steam, moisture separator drains, blowdown piping, feedwater heater drains, and downstream of leaking valves.

C.2 SYSTEM SELECTION CRITERIA

All Plant piping systems are subject to review for potential inclusion into the Piping FAC Inspection Program. A piping system is defined here as a section of piping within a plant system which has a unique history of operating conditions (temperature, flow, water chemistry). Generally piping systems extend between two major components such as pumps, heaters, and vessels.

There are thousands of piping components in service at VY, most of which do not operate under conditions where FAC is a concern. FAC occurs in single phase water and two-phase water/steam piping under certain thermodynamic and chemistry conditions. In order to focus attention and resources effectively, those components where FAC is not a concern shall be eliminated from the scope of the inspection program. To accomplish this the exclusion criteria developed by EPRI contained in Section 4.2.2 of NSAC 202L (Ref. 5.4.8.) will be used.

NOTE

Portions of piping systems which meet certain exclusion criteria, may or may not be excluded from the program scope. The systems excluded by the criteria below could be susceptible to damage from other corrosion or degradation mechanisms. These include cavitation erosion, liquid impingement erosion, intergranular stress corrosion cracking (IGSCC), microbiologically influenced corrosion (MIC), and solid particle erosion.

All plant systems are considered as in the scope of the VY Piping FAC Inspection Program unless excluded by one of the criteria listed in Appendix C.3

C.3 SYSTEM EXCLUSION CRITERIA

C.3.1 Stainless Steel or Low Alloy Steel Piping

Systems of stainless steel piping or low alloy steel piping with a nominal chromium content equal to or greater than 1-1/4%. This exclusion pertains only to complete piping systems constructed of FAC resistant alloys. If some components in a high alloy line are carbon steel (valves) then the line shall not be excluded. In lines with specific components or sections of piping replaced with FAC resistant materials, the entire line shall be identified as susceptible. Note that high chromium materials do not necessarily protect against other damage mechanisms, especially cavitation and liquid impingement erosion. If the damage mechanism which prompted previous material replacement has not been identified, then the system should not automatically be excluded from the program scope.

C.3.2 Superheated Steam Systems

Superheated steam systems with no moisture content regardless of temperature or pressure levels. However drains, traps, and other potentially high-moisture content lines from super-heated steam systems should not be excluded automatically.

APPENDIX C (Continued)

C.3.3 High Dissolved Oxygen or Raw Water Systems

Systems with high levels of dissolved oxygen (oxygen > 1000. ppb), such as service water, circulating water, and fire protection.

C.3.4 Single Phase Systems with Temperature Below 175F.

EPRI recommends exclusion of single phase systems with temperature below 200F (low temperature). A temperature of 175F will be used for conservatism. If measurable wear is found in nearby piping operating slightly above 200F, EPRI recommends that the systems exclusion be reconsidered.

C.3.5 Systems With No Flow, or Which is in Use Less Than 2% of Plant Operating Time

Systems with no flow; or those that operate less than 2% of plant operating time or single phase systems that operate with temperature > 200F less than 2% of plant operating time. If the actual operating conditions of the system can not be confirmed (potentially leaking valves, etc.) or if the service is severe (flashing flow), the system should not be excluded based on operation time alone.

This includes normally closed small bore equipment vents, drains, and level control instrument lines.

C.3.6 Piping Which Carries Fluids Other Than water or Wet Steam

The VY Piping FAC Inspection Program applies only to piping carrying water or wet steam. Therefore non-water systems such as Instrument Air or Turbine Lube Oil Systems are excluded.

A formal evaluation to identify FAC of susceptible piping ("susceptibility analysis") has been performed and is documented in reference 5.4.1.. The susceptibility analysis will be revised as required to reflect changes in plant operation and configuration.

C.4 COMPONENT SELECTION CRITERIA

All components on large bore lines not excluded by the criteria in Appendix C.3 above are included in the scope of the program. Each component is given a unique identification (Component ID). Each large bore line will be modeled using CHECWORKS as appropriate. When large bore piping is inspected, the results included into the CHECWORKS model and long term wear is trended.

All small bore lines 2-1/2 inch nominal diameter and smaller not excluded by the criteria in Appendix C.3 are included in the scope of the program. However, not all components on these lines are given a unique component identification. Only selected locations on these lines are inspected to determine if significant wear is occurring.

Long term tracking of wear in small bore piping will not generally be performed. Components and attached piping which exhibit FAC damage will preferably be replaced with FAC resistant materials.

APPENDIX C (Continued)

C.5 ADDITIONS TO THE PROGRAM SCOPE

Additional piping systems and components may be added to the inspection program at any time in the future based on: new industry experience, discovered wear during plant maintenance, installation of new piping, and planned or discovered changes in the operation of an existing system.

APPENDIX D

USE AND CONTROL OF CHECWORKS MODELS

D.1 EPRI CHECWORKS

The EPRI developed CHECWORKS code, (REF. 5.4.9.), is a Windows based personal computer code. It is an integrated software platform for evaluating power plant piping systems for the most common types of corrosion that degrade piping and equipment.

Version 1.0 of CHECWORKS contains a FAC module which incorporates the capabilities of the previously used CHECMATE family of codes, CHECMATE, CHEC-NDE, and CHEC-T as parts of the same program. It also contains extensive data base capabilities for: organizing plant design information for input to FAC evaluations, storage of piping inspection data, tracking component wear, and planning and scheduling piping component inspections.

D.2 TRAINING

As a minimum, the engineers modeling plant piping systems with CHECWORKS shall have received the EPRI/CHUG Introductory FAC and CHECWORKS training.

D.3 MODELING OF PLANT PIPING SYSTEMS USING CHECWORKS

Evaluation of the susceptible plant piping systems for FAC performed using the EPRI CHECWORKS code shall use references 5.4.9. and 5.4.10. for input conventions and modeling guidance.

D.4 DOCUMENTATION

CHECWORKS is used as a tool to plan inspections, track inspection results, wear rates, piping component data, and repair and/or replacement history. Results from the code are not used for design or to demonstrate conformance to design bases. The CHECWORKS evaluations are not considered as design basis input. Therefore, the evaluations will not be documented as a formal "VYC" calculation.

The CHECWORKS model inputs, assumptions, and results shall be documented in a manner consistent with the technical content requirements of AP 0017 or AP 6045 Technical Evaluations. The modeling and documentation shall be independently reviewed using Appendix B of AP 0017 as guidance. The models and supporting documentation will be controlled and maintained by the FACPC.

D.5 REVISIONS & UPDATES

Revisions to the plant CHECWORKS models shall be performed to reflect current plant operation and configuration. The Design changes and plant upgrades will be reviewed by the FACPC for effects on the current plant models.

The CHECWORKS models shall be updated after each refueling outage to incorporate inspection data taken during the outage for use in planning inspections for the following outage.

APPENDIX E

CRITERIA FOR SELECTION OF PIPING COMPONENTS FOR INSPECTION AND SAMPLE EXPANSION GUIDELINES

E.1 Inspection Planning

E.1.1 GENERAL

The outage inspection scope is determined by the FACPC using: pipe wall thickness measurements from past outages, predictive evaluations performed using the CHECWORKS computer code, industry events related to FAC, results from other plant inspection programs, and engineering judgment.

The FACPC prepares an inspection plan and identifies the inspection scope (specific components) prior to each refueling outage in accordance with outage planning milestones. This scope is used by the ISIPC for resource planning and for input to the outage schedule.

Repeat inspections are performed on piping components which have evidenced FAC damage in the past. Industry events such as a pipe rupture or discovery of eroded components may dictate a change or addition to the inspection scope. Components are added to the inspection scope based on experience or events at other operating plants as information is received. The planned inspection scope for each refueling outage may be increased or decreased during the outage based upon the quantitative inspection results of selected components.

When significant component wear is found, inspections of additional components (sample expansion) shall be performed. Sample expansion is based on the guidelines presented in Appendix E.3 below.

E.1.2 Long Term Planning

The scope of future piping inspections is dependent on the inspection results from previous outage inspections. For this reason all components to be inspected in the future cannot be scheduled several outages in advance.

With time, previous inspection results and the predictive models correlated with the inspection results will be the driving force behind inspection point selection. By then enough inspection data will have been obtained to predict, with a high degree of confidence, the locations at Vermont Yankee experiencing significant FAC damage.

Other factors to consider in planning future inspections include:

- The consequences of failure of a particular component with respect to personnel safety and plant availability.
- The margin of nominal wall thickness to code minimum wall thickness. It is a function of the original piping design and varies from system to system, and from line to line on the same system.
- Replacement of susceptible components with different piping materials. If wear rates are primarily due to piping material, replacement materials should reduce wear rates. If wear is due primarily to geometry, a partial or full redesign of the system will significantly reduce susceptibility to FAC.

APPENDIX E (Continued)

E.1.3 Initial Inspections

Components selected for initial inspection shall be representative of the most susceptible systems and the component ranking within those systems. An effort to select a variety of component types should be made.

The corresponding components on parallel trains or on similar piping systems can be grouped. Each group can contain one or several piping components. At least one component from each group should be inspected.

Parallel trains of the same system should have essentially the same geometry and flow conditions. If not, the trains should be considered a separate group. Piping components downstream of each flow control valve should be considered as a separate group.

E.2 Selection Methods and/or Basis for Component Inspections

The basis for selection of specific components for examination during a refueling outage is by one or more of the following:

E.2.1. CHECWORKS Predictive Models

Components are ranked for susceptibility to FAC by the CHECWORKS computer code based on a number of factors including; component geometry, piping material, fluid environment (single-phase or two-phase flow), water chemistry, and temperature. Once actual inspection data is included the CHECWORKS model, the predicted wear rates and thickness values are statistically factored to reflect the actual wear from the inspection data.

- a) For piping modeled using the EPRI CHECWORKS code without previous inspection data, select the most susceptible components on a line or section of piping for inspection.
- b) For piping modeled using the EPRI CHECWORKS code with previous inspection data, select the components with the highest calculated wear rate and lowest time to minimum code wall thickness. In general, components should be scheduled for inspection by projecting the calculated wear such that it will be inspected prior to reaching 0.875 times the nominal wall thickness.
- c) Components can be included in the inspection scope to help calibrate the CHECWORKS models. Generally include components from lines which have no (or a limited amount of) previous inspections data.

E.2.2 Components Identified During Previous Inspections

The Outage Inspection Reports identify components which have experienced wear and specific components to be included in future inspections. Components shall be scheduled for re-inspection for the following reasons:

- Monitoring of identified piping component wear on a component from a previous outage.
- Suspect or questionable inspection results which require confirmation.

APPENDIX E (Continued)

E.2.3 Industry Experience Components

Industry experience components from other plant inspection programs or from other plant piping failures are typically identified via INPO industry operating experience (OE) or through the EPRI CHUG. Industry Experience Components include, but are not limited to locations listed below.

Large Bore Piping:

- Downstream of flow control valves.
- Downstream of orifices and /or flow meters.
- Downstream of exit nozzles.
- Downstream of feed pumps.

Small Bore Piping:

- Downstream of flow control valves.
- Downstream of orifices and /or flow meters.
- Upstream and downstream of steam traps.
- Drain and vent connections to large bore piping or components with two-phase flow.
- Last two changes in direction prior to entering the condenser.(i.e. 90 & 45 degree elbows, reducers, orifices, or globe valves).

E.2.4 Systems Not Modeled Using CHECWORKS (Susceptible-Non Modeled, SNM)

Susceptible Piping which has not been modeled using CHECWORKS (SNM) includes systems that contain lines which have unknown or widely varying operating conditions which preclude the development of accurate analytical models. These include vent and drain piping with multi-phase flow and lines subject to off normal flow conditions.

Inspection locations are selected based a combination of industry experience, plant experience, and engineering judgement. Locations should be selected for initial inspection with the objective of identifying a sufficient number and the appropriate locations to confirm system susceptibility.

Locations to inspect include:

- a) Isolated lines to the condenser in which leakage is indicated from the turbine performance monitoring system. Data is normally obtained from the Systems Engineering Group, (Thermal Performance Monitoring)
- b) Components in susceptible piping which has not been modeled using CHECWORKS and have not received an initial inspection. Specifically:
 - Downstream of orifices
 - Downstream of flow control valves and level control valves.
 - Nozzles
 - Tees and laterals, particularly field fabricated tees and laterals
 - Complex geometric locations such as components located within two diameters of each other
 - Components with backing rings and counterbores.
 - Components downstream of replaced components (upstream, if expander).
 - Components which have been replaced in the past and not upgraded to a FAC resistant material.

APPENDIX E (Continued)

E.2.5 Parametric Studies and Engineering Judgment

In general, piping systems will be modeled using CHECWORKS. However, certain piping systems or portions of lines have usage and flow rates which cannot be accurately quantified due to operating conditions which vary greatly or are controlled by remote level, pressure or temperature signals. An example is the emergency bypass lines to the condenser on the heater drain system.

Alternate methods for selection of components for inspection include parametric studies and the use of seasoned engineering judgment. Comparative studies using the CHECWORKS code or other fluid dynamics analysis tools to model a piping segment while varying parameters such as temperature, flow rate, valve position, etc. can be used to rank the effects of each parameter on susceptibility to FAC. These rankings are then used as a guide in selecting components for inspection.

Certain piping configurations and flow conditions are known to have a high susceptibility to FAC. Lines containing control valves or pressure reducing orifices which flow to a lower pressure sink such as the condenser are important to consider because of possible flashing and high velocities downstream of these components. Other conditions are not as evident, such as leakage by normally closed valves on lines considered to have no flow during normal operation.

E.3 Sample Expansion Guidelines

Expansion of the scope is required when significant wall thinning is discovered in a particular piping component. When this occurs, identical or similar piping components in parallel and/or alternate piping components shall be inspected. The EPRI sample expansion guidelines (Reference 5.4.8.) shall be used to select additional components.

"Significant wall thinning" in a piping component is determined by the evaluation of inspection data performed by Design Engineering Mechanical/Structural Dept. using DP 0072.

- (1) When sample expansion is required per DP 0072, the selection of additional components to be inspected shall be as follows:
 - (a) Any component within two diameters downstream of the component displaying significant wear, and within two diameters upstream if that component is an expander or expanding elbow.
 - (b) A minimum of the next two most susceptible components from the CHECWORKS relative wear ranking in the same train as the piping component displaying significant wear.
 - (c) Corresponding components in each other train of a multi-train line with a configuration similar to that of the piping component displaying significant wear
- (2) When inspections of the expanded sample (1) above detect additional components with significant FAC wear the sample should be further expanded to include:
 - (a) Any component within two diameters downstream of the component displaying significant wear, and within two diameters upstream if that component is an expander or expanding elbow.
 - (b) A minimum of the next two most susceptible components from the relative wear ranking in the same train as the piping component displaying significant wear.

APPENDIX E (Continued)

- (3) When inspections of the expanded sample of (2) above detect additional components with significant FAC wear, the sample expansion of (2) above should be repeated until no additional components with significant wear are detected.

VERMONT YANKEE


PIPING FLOW ACCELERATED CORROSION

INSPECTION PROGRAM

(PP 7028)


2001 REFUELING OUTAGE INSPECTION REPORT

Prepared by:

 8/1/01

James C. Fitzpatrick
Design Engineering – Mechanical /Structural

Reviewed by:

 8/1/01

Thomas M. O'Connor
Design Engineering – Mechanical /Structural

V.Y. PIPING F.A.C. INSPECTION PROGRAM: 2001 REFUELING OUTAGE

INSPECTION REPORT

TABLE OF CONTENTS

- 1.0 SUMMARY
 - 2.0 2001 REFUELING OUTAGE INSPECTION PLAN
 - 3.0 EVALUATION OF INSPECTION RESULTS
 - 3.1 Large Bore Piping
 - 3.2 Small Bore Piping
 - 4.0 COMPONENTS REQUIRING FUTURE MONITORING
 - 5.0 COMPONENTS REQUIRING POSSIBLE REPAIR OR REPLACEMENT
 - 6.0 INSPECTION DATA RETENTION
 - 7.0 RECOMMENDATIONS FOR FUTURE FAC INSPECTIONS
 - 8.0 REFERENCES
- ATTACHMENT 1: SUMMARY OF LARGE BORE PIPING UT INSPECTION RESULTS
- ATTACHMENT 2: SUMMARY OF SMALL BORE PIPING UT INSPECTION RESULTS

V.Y. PIPING F.A.C. INSPECTION PROGRAM: 2001 REFUELING OUTAGE

INSPECTION REPORT

1.0 SUMMARY

This was the first outage in which FAC piping inspection activities were controlled under a new Vermont Yankee Program Procedure, PP-7028 "Piping Flow Assisted Corrosion Inspection Program".

External UT measurements were taken on 25 large bore piping components in the Feedwater and Condensate Systems. Also inspected were 2 sections of small bore piping, on the turbine Steam Seal Regulator drain piping. No internal visual inspections were performed on the Turbine Cross-Around piping.

The large bore results were evaluated using a three level screening process defined in a new plant procedure DP 0072. All components inspected were found to have a wall thickness greater than the code minimum wall thickness. The predicted thickness at the next refueling outage was greater than the code minimum wall thickness for all components. A summary of the large bore piping component screening is contained in Attachment 1. Attachment 2 contains a summary of the small bore piping inspection results.

No piping components required repair or replacement during the refueling outage and there were no immediate operability concerns.

Component selection was based on a combination of; previous inspection experience, industry events, analyses using the EPRI developed CHECWORKS computer code, and the consequences of component failure.

During the 2001 refueling outage, the UT inspections were performed by the same personnel performing the ASME Section XI in-service inspections. Panametrics 26DL+ electronic thickness measurement and data logging equipment was used to collect data. Component preparation, scaffolding, insulation removal, and surface cleaning, were performed by NPS personnel. Due to the small inspection scope, application of grid markings was performed by the UT personnel using guidelines contained in Appendix A of the UT procedure, NE 8053.

This was the first outage that the UT results were directly downloaded from the data loggers into the EPRI CHECWORKS program located on the VY computer network. This reduced both time and effort required to transmit data to engineering personnel and resulted in a faster turn around time for engineering to evaluate the inspection results and release components for restoration.

V.Y. PIPING F.A.C. INSPECTION PROGRAM: 2001 REFUELING OUTAGE

INSPECTION REPORT

2.0 2001 REFUELING OUTAGE INSPECTION PLAN

The 2001 refueling outage inspection scope (references 4 & 5) was developed to satisfy the following goals:

- To inspect components requiring follow up inspections, based on UT data from previous refueling outages.
- Inspect components identified by the EPRI CHECWORKS computer code ranked high for susceptibility to wear and/or having the least time remaining to reach code minimum wall thickness.
- Perform repeat inspections on selected components for calibration of the CHECWORKS models.
- To incorporate industry experience into the program through inspection of components at VY that are similar to those that have either failed or showed significant wall thinning at other plants.
- To perform inspections on any large bore and small bore piping components subjected to off normal flow conditions, such as components downstream of normally closed valves with seat leakage. These components are identified by the cognizant Systems Engineer, using the turbine performance monitoring system. Two Heater Drain system bypass valves at the condenser were identified by the thermal performance monitoring system as leaking by the normally closed valves. The plan was for the outage was for maintenance to disassemble the valves, perform an internal visual inspection for erosion of the valve bodies and the downstream piping. External UT measurements would only be performed if indications of internal wear were identified.

V.Y. PIPING F.A.C. INSPECTION PROGRAM: 2001 REFUELING OUTAGE

INSPECTION REPORT

3.0 EVALUATION OF INSPECTION RESULTS

3.1 Large Bore Piping

Twenty-four (24) large bore piping components and one (1) equipment nozzle were included in the planned inspection scope for external UT exams. Inspections of the turbine cross around piping were deferred until the 2002 RFO based on an evaluation of the inspection results from the 1996, 1998, and 1999 refueling outages.

The UT results were evaluated using a three level screening process as defined in a new procedure, DP 0072. The UT results were directly downloaded from the data loggers into the EPRI CHECWORKS program located on the VY computer network. This reduced both time and effort required to transmit data to engineering personnel and resulted in a faster turn around time for engineering to evaluate the inspection results and release components for restoration.

The UT inspection results for each component were reviewed for anomalies and consistency with piping geometry. Wear rates (wear/cycle) were calculated for each component using methods specified in DP 0072. For component UT results which indicated no wear or minimal wear has occurred, a minimum wear rate of 0.005 inches/cycle was used. Using the calculated wear rates and the 2001 measured thickness, the predicted thickness at the end of the next cycle (2002 T_{pred}) was calculated using a safety factor of 1.2 on the calculated wear per cycle. Using both the wear rate and 2001 measurement data, the projected number of cycles beyond the Spring 2001 refueling outage for each component to wear down to the code minimum wall thickness was also calculated.

The methods used to predict wall thickness at the next refueling outage are consistent with NSAC-202L, reference (8). The wear rate calculations and projected times to code minimum wall for single phase flow systems are assumed to be linear. In fact they may not be, but a linear projection is used for the wear rates given that observed wear has occurred at a relatively slow rate (approx. 29 years). These calculated times to code minimum are based on the lowest measured thickness including a safety factor, and generally will be conservative.

Components passing the Level 1 screen have 2002 T_{pred} greater than $.875T_{nom}$ (the manufacturing tolerance of new piping) and require no further evaluation. The Level 2 screen is for components with 2002 T_{pred} less than $.875T_{nom}$ but greater than T_{min} (the code minimum wall thickness). These components are acceptable for continued operation but future monitoring is recommended. The Level 3 screening is for components with 2002 T_{pred} less than T_{min} . The Level 3 screening is a detailed analytical methodology. It also requires that additional piping components be inspected this outage (sample expansion), and considered for inspection during future refueling outages.

Twenty-five (25) large bore piping components were inspected. Only the weld area on the equipment nozzle (P-1-1A) was inspected. Eighteen (72%) passed the Level 1 screen, and the remaining seven (28%) passed the Level 2 screen. All components inspected were

V.Y. PIPING F.A.C. INSPECTION PROGRAM: 2001 REFUELING OUTAGE

INSPECTION REPORT

Large Bore Piping – continued

found to have wall thickness greater than code minimum wall thickness. All predicted wall thickness (at the 2002 refueling outage) values were above code minimum wall thickness.

No large bore repairs or replacements were required. Only one component was identified as requiring future monitoring and is discussed in Section 4.0 of this report. A summary of the large bore piping component screening is contained in Attachment 1.

The Systems Engineer for the thermal performance monitoring program identified possible leakage by two normally closed valves, LCV-103-1A-2 and LCV-103-3B-2. These are the high level emergency dump valves for the 1A and 3B feedwater heaters. They are located adjacent to the condenser. No evidence of erosion was found on the valve body or downstream piping for LCV-103-1A-2. Visual inspections identified erosion below the seat on the valve body and in the 6 inch diameter end of the 6 x 16 expander downstream of the valve LCV-103-3B-2. UT measurements were then taken on the valve body and the expander to determine the remaining wall thickness. The evaluation of the UT data is contained in VY Technical Evaluation No. TE-2001-024, reference(10).

The TE concluded that the as-found wall thickness values for the eroded areas on both the valve body and the 6 inch diameter end of the downstream expander are greater than the code minimum required wall thickness. The TE demonstrated the structural integrity of the valve body and the downstream piping as found during RFO 22 with localized eroded areas. It did not address the possibility of continued degradation from leakage past the seat during future operation. The rate of erosion of the valve body wall due to leakage past the seat could not be estimated. However TPM data indicate that this valve may have been leaking since the TPM system was installed in 1995. The valve seat was repaired/replaced during the outage.

3.2 Small Bore Piping

Two sections of small bore piping were scheduled for external UT inspection during the 2001 refueling outage. These were new inspections. They were scheduled due to a leak at the Steam Seal Regulator. No significant wear was found in either section of piping. A summary of the small bore piping inspection results is contained in Attachment 2.

V.Y. PIPING F.A.C. INSPECTION PROGRAM: 2001 REFUELING OUTAGE

INSPECTION REPORT

4.0 COMPONENTS REQUIRING FUTURE MONITORING

Components requiring future monitoring are identified using the "2001 Predicted Thickness", the "Screening Level" which the component passed, and the "Approximate Cycles to T_{min}" shown in Attachment 1. From the wear rates and cycles to T_{min} calculated in Attachment 1, only one component, FD01TE05 was identified as with less than 10 cycles to T_{min}. This component has multiple year inspection data and a low calculated wear rate. Previous inspection data indicate that that a local region adjacent to the weld to the downstream valve was fabricated with little margin over code minimum wall thickness. This component will be re-inspected during the 2004 refueling outage.

The 2001 refueling outage inspection results will be incorporated into the existing CHECWORKS models of the Condensate and Feedwater Systems. The 2001 inspection data, and data from previous inspections will be used to refine the wear rate predictions. The results shown in Attachment 1 and the updated CHECWORKS analyses will be used to determine the inspection scope for future refueling outages.

5.0 COMPONENTS REQUIRING POSSIBLE REPAIR OR REPLACEMENT

No specific components were identified as requiring repairs or replacements. However, with future operation under GE hydrogen water chemistry, wear rates in the Feedwater and Heater Drain systems are expected to increase. The Feedwater System piping from the feed pumps past the feed regulator valves has a relatively low margin for wall loss due to flow accelerated corrosion. This is due to the high design pressure and the installed wall thickness. The CHECWORKS models for this piping will be updated with the 2001 RFO inspection data, and inspections of specific components on the Feedwater System piping will continue in the future.

6.0 INSPECTION DATA RETENTION

UT thickness data has been taken using Vermont Yankee owned Panametrics 26DL⁺ digital UT and electronic data logging system. The large bore UT inspection results were downloaded directly into the CHECWORKS data base located on the VY computer network. The measured thickness data for each component is stored in the CHECWORKS data base. A thickness data sheet (form VYNEF8053.01) including the CHECWORKS thickness matrix printout was created for each inspection. The inspection reports are controlled and put into permanent storage by VY ISI personnel per AP 6807 & AP 6809.

V.Y. PIPING F.A.C. INSPECTION PROGRAM: 2001 REFUELING OUTAGE

INSPECTION REPORT

7.0 RECOMMENDATIONS FOR FUTURE FAC INSPECTIONS

Recommendations made in past refueling outage inspection reports have been formalized and incorporated into the new Program Procedure PP 7028. These have included the continued use of the Panametrics UT/data logging equipment and conversion from ITHACUS to CHECWORKS for data processing.

7.1 Prepare for Possible Repair or Replacement of Components During the 2001 Refueling Outage.

The potential for finding significant wear in any piping component exists. Contingency planning as required for either weld repair or replacement of large bore components in the piping systems should be considered. ASME code cases for external weld overlay of eroded piping have been approved in recent years. The applicability and possible use of these of these code cases at VY should be evaluated to provide additional methods for timely and effective repairs to be made during short refueling outages.

V.Y. PIPING F.A.C. INSPECTION PROGRAM: 2001 REFUELING OUTAGE

INSPECTION REPORT

8.0 REFERENCES

1. V.Y. Program Procedure PP 7028, Piping Flow Accelerated Corrosion (FAC) Inspection Program, Original Issue 5/10/01.
2. V.Y. Department Procedure, DP 0072, "Structural Evaluation of Thinned Wall Piping Components", Original Issue 5/17/01.
3. V.Y. Nondestructive Examination Procedure, NE 8053, "Ultrasonic Thickness Measurement" Original Issue 11/03/00, LPC 1.
4. Memo J.C.Fitzpatrick to J.H.Callaghan, subject: Piping FAC Inspection Scope for the 2001 Refueling Outage, VYM 2000/051, dated June 15,2000.
5. VY Piping FAC Inspection Program – 2001 Refueling Outage: Inspection Location Worksheets / Methods and Reasons for Component Selection, dated 6/20/00.
6. Memo J.C.Fitzpatrick to S.D.Goodwin, subject: 2001 Refueling Outage Piping Flow Accelerated Corrosion Inspection Summary, VYM 2001/015, dated May 17,2001.
7. Memo J.Fortier/J.C.Fitzpatrick to J.H.Callaghan subject: 1999 Refueling Outage Turbine Cross Around Piping Inspections, VYM 99/129, dated November 28,1999.
8. EPRI Report, "Recommendations for an Effective Flow-Accelerated Corrosion Program", EPRI NSAC-202L-R2, April 1999.
9. CHECWORKS - Computer Program User Guide, TR 103496, August 1994 by Altos Engineering Applications Inc. for EPRI.
10. VY Technical Evaluation No. 2001-024, " Evaluation Of Wall Loss Found In Valve LCV-103-2B-2 and Downstream Piping."

V.Y. PIPING F.A.C. INSPECTION PROGRAM: 2001 REFUELING OUTAGE INSPECTION REPORT

ATTACHMENT 1: SUMMARY OF LARGE BORE PIPING UT INSPECTION RESULTS

Inspection No.	Comp ID	DIA	Tnom	.875* Tnom	Tmin	2001 Min Tmeas	Wear Rate(in./cycle)	2002 Tpred.	Passed Screen Level	Approx. Cycles to Tmin	Future Inspections Recommended	Comments
01-01	PUMP1A-NZL	12	1.000	0.875	0.769							Note 5
01-02	FD01RD01	12	1.000	0.875	0.769	0.869	0.005	0.863	2	16.7		
		16	1.219	1.067	0.984	1.035	0.005	1.029	2	11.7		
01-03	FD01EL01	16	1.219	1.067	0.965	1.059	0.005	1.053	2	12.5		
01-04	FD01TE05	16	1.219	1.067	0.965	0.994	0.005	0.988	2	4.8	2004 RFO	
01-05	FD01SP02DS	16	1.219	1.067	0.965	1.120	0.006	1.113	1	21.5		
01-06	FD01EL03	16	1.219	1.067	0.965	1.527	0.009	1.516	1	49.8		
01-07	FD01SP03US	16	1.219	1.067	0.965	1.069	0.005	1.063	2	17.3		
01-08	FD03EL03	16	1.219	1.067	0.965	1.448	0.005	1.395	1	77.		
01-09	FD03SP03	16	1.219	1.067	0.965	1.029	0.005	1.023	2	10.7		
01-10	FD03EL04	16	1.219	1.067	0.965	1.423	0.006	1.416	1	65.4		
01-11	FD03SP04	16	1.219	1.067	0.965	1.068	0.006	1.061	2	14.3		
01-12	FD07RD03	10	0.844	0.738	0.648	0.760	0.005	0.754	1	18.7		
		18	1.375	1.203	1.085	1.223	0.005	1.217	1	23.		
01-13	FD08SP03	18	1.375	1.203	1.085	1.231	0.005	1.225	1	24.3		
01-14	FD18TE01	16	0.844	0.738	0.645	0.906	0.0065	0.899	1	33.5		@ Row 1 transition from Sch. 80 pipe.
		16	1.219	1.067	0.645	1.494	0.0065	1.486	1	108.8		Rows 2-11
		16			1.335	1.560	0.005	1.554	1	37.5		@ branch connection reinforcement zone, Note.6
01-15	FD18SP04	10	0.844	0.738	0.433	0.758	0.005	0.752	1	54.2		Note 7
01-16	FD20RD01	16	1.219	1.067	0.645	1.083	0.013	1.067	1	28.		Note 8
		10	0.844	0.738	0.433	0.962	0.016	0.943	1	27.6		rows 6 & 7 on reducer
		10	0.844	0.738	0.433	0.770	0.016	0.751	1	17.		rows 8-10 on pup piece
01-17	FD20SP01	10	0.844	0.738	0.433	0.727	0.005	0.721	2	49.		

V.Y. PIPING F.A.C. INSPECTION PROGRAM: 2001 REFUELING OUTAGE INSPECTION REPORT

ATTACHMENT 1: SUMMARY OF LARGE BORE PIPING UT INSPECTION RESULTS

Inspection No.	Comp ID	DIA	Tnom	.875* Tnom	Tmin	2001 Min Tmeas	Wear Rate(in./cycle)	2002 Tpred.	Passed Screen Level	Approx. Cycles to Tmin	Future Inspections Recommended	Comments
01-18A	CD32FE01	20	0.594	0.520	0.393	0.793	0.005	0.787	1	66.7		Note 9.
01-18	CD32EL04	20	0.594	0.520	0.393	0.591	0.005	0.585	1	32.		
01-19	CD32SP02	20	0.594	0.520	0.393	0.547	0.005	0.541	1	25.7		
01-20	CD32EL05	20	0.594	0.520	0.393	0.626	0.012	0.612	1	16.2		
01-21	CD30EL02	20	0.594	0.520	0.393	0.559	0.005	0.553	1	27.7		
01-22	CD30EL03	20	0.594	0.520	0.393	0.536	0.005	0.530	1	23.8		
01-23	CD30SP01	20	0.594	0.520	0.393	0.561	0.005	0.555	1	28		
01-24	CD27EL12	20	0.594	0.520	0.393	0.649	0.010	0.637	1	21.3		
01-25	CD27EL13	20	0.594	0.520	0.393	0.745	0.005	0.739	1	58.7		

NOTES:

1. All thickness values are inches.
2. Wear/Cycle is approximately inches/18 months. The wear per cycle was calculated per DP0072 using 15.9 equivalent 18 month cycles based on approx. 157,000 operating hours up to 1996 outage, and 12000 ± hrs./cycle. Minimum Wear/Cycle used to calculate Tpred and Cycles to Tmin is 0.005 inches per cycle.
3. 2002 T predicted = 2001 T measured - F.S. * (Wear/Cycle), F.S. = Factor of Safety = 1.20.
4. Cycles to Tmin is calculated from: $\frac{2001 \text{ T measured} - T_{min}}{F.S. \times \text{Wear/Cycle}}$ (i.e. Cycles from 2001 RFO)
5. Only area adjacent to weld on Feedwater Pump 1 A discharge nozzle was inspected. Asbestos insulation on pump casing at discharge nozzle was not abated, only attached reducer was exposed.
6. FD18TE01, additional thickness required in branch reinforcement zone for 10" diameter pipe.
7. FR18SP04, conservative measured thickness (single low reading) Tmeas = 0.770in. would be more representative.
8. FD20RD01 conservative measured thickness (single low reading) Tmeas = 1.133 in. would be more representative.
9. Section of pipe supplied with condensate flow element FE-2 appears to be Sch. 60 vs. Sch 40 for Condensate piping.

V.Y. PIPING F.A.C. INSPECTION PROGRAM: 2001 REFUELING OUTAGE INSPECTION REPORT

ATTACHMENT 2: SUMMARY OF SMALL BORE PIPING UT INSPECTION RESULTS

SMALL BORE PIPING

S.B. Inspection Number (Data Base No.)	Description / Location	Section	Size	Sch	Tnom. (inch)	.875 * Tnom. (inch)	T min. (inch) (Note 1)	2001 Min. Measured Thickness (inch)	Apparent Wear Rate (inch/cycle)	Cycles to Tmin. (Note2)	Comments
01-SB01 (117)	1SLSSR -1" drain off SSR US & DS branches at Tee fitting. TB Heater Bay (Approx. El. 262 under SSR).	Rows: 1-3, & 38-40	½"	40	.109	.095	.039*	.102	<0.005	10.5	Conservative wear rate used.
		Rows: 4-24, & 41-50	¾"	80	.154	.135	0.040	.135	<0.005	15.8	
		Rows: 25-37, & 51	1"	80	.179	.157	.042	.160	<0.005	21.3	
01-SB02 (117)	1SLSSR -1" drain off SSR piping at connection to 8"- SPE pipe. (Approx. El. 262)	N/A	1"	80	.179	.157	.042	.161	<0.005	19.8	

NOTES:

1. Tmin includes a 0.035 inch corrosion allowance per ANSI B31.1 –1967.
2. Cycles to Tmin from 2001 refueling outage. SF (safety factor) = 1.2 was used on the apparent wear rate. Small bore wear is not trended for the purposes of repeat inspections. Small bore components will generally be replaced if significant thinning is observed.

VERMONT YANKEE

PIPING FLOW ACCELERATED CORROSION

INSPECTION PROGRAM

(PP 7028)

2002 REFUELING OUTAGE INSPECTION REPORT


(RFO 23- Fall 2002)

Prepared by:

 1/20/03

James C. Fitzpatrick
Design Engineering – Mechanical /Structural

Reviewed by:

 1/22/03

Thomas M. O'Connor
Design Engineering – Mechanical /Structural

V.Y. PIPING F.A.C. INSPECTION PROGRAM: 2002 REFUELING OUTAGE

INSPECTION REPORT

TABLE OF CONTENTS

- 1.0 SUMMARY
 - 2.0 2002 REFUELING OUTAGE INSPECTION PLAN
 - 3.0 EVALUATION OF INSPECTION RESULTS
 - 3.1 Large Bore Piping
 - 3.2 Turbine Cross Around Piping
 - 3.3 Small Bore Piping
 - 3.4 Feedwater Heater Shells
 - 3.5 Extraction Steam Reverse Current Valves
 - 4.0 COMPONENTS REQUIRING FUTURE MONITORING
 - 5.0 COMPONENTS REQUIRING POSSIBLE REPAIR OR REPLACEMENT
 - 6.0 INSPECTION DATA RETENTION
 - 7.0 RECOMMENDATIONS FOR FUTURE FAC INSPECTIONS
 - 8.0 REFERENCES
- ATTACHMENT 1: SUMMARY OF LARGE BORE PIPING UT INSPECTION RESULTS
- ATTACHMENT 2: SUMMARY OF SMALL BORE PIPING UT INSPECTION RESULTS

V.Y. PIPING F.A.C. INSPECTION PROGRAM: 2002 REFUELING OUTAGE

INSPECTION REPORT

1.0 SUMMARY

External UT measurements were taken on 22 large bore piping components in the Feedwater and Condensate Systems. External UT inspections were performed on 3 sections of small bore piping on the Heater Vents piping and the low point drain for the turbine steam seal header. An internal visual inspection of the 30 inch B Turbine Cross-Around line was also performed. Planned UT inspections on the No.1 High Pressure feedwater heaters were deleted from the scope due to the decision to replace all 4 HP feedwater heaters in 2004.

Component selection was based on a combination of, previous inspection data, industry events, analyses using the EPRI developed CHECWORKS computer code, and the consequences of component failure. A detailed selection process was used and was documented in reference (4).

The large bore results were evaluated using a three level screening process defined in plant procedure DP 0072. All components inspected were found to have a wall thickness greater than the code minimum wall thickness. The predicted thickness at the next refueling outage was greater than the code minimum wall thickness for all components. No piping components required repair or replacement during the refueling outage and there were no immediate operability concerns.

A summary of the large bore piping component screening is contained in Attachment 1. Attachment 2 contains a summary of the small bore piping inspection results.

During the 2002 refueling outage, the UT inspections were performed by the same personnel performing the ASME Section XI In-service inspections. Panametrics 26DL+ electronic thickness measurement and data logging equipment was used to collect data. Component preparation, scaffolding, insulation removal, and surface cleaning were performed by NPS personnel. Due to the small inspection scope, application of grid markings was performed by the UT personnel using guidelines contained in Appendix A of the UT procedure, NE 8053. UT results were directly downloaded from the data loggers into the EPRI CHECWORKS program located on the VY computer network. This reduced both time and effort required to transmit data to engineering personnel and resulted in a faster turn around time for Engineering to evaluate the inspection results and release components for restoration.

Of note, but not directly under the scope of the Piping FAC Inspection Program, was the discovery of erosion of internal components found in the Extraction Steam system reverse current valves. The VY valve maintenance procedures include an internal check for erosion /corrosion of valve parts. The damage was discovered during planned maintenance. The erosion of the valve covers and disc stem nuts was due to a material deficiency. The design specification required a chrome-moly material, the vendor supplied a carbon steel material. A contributing cause to the extent of the damage was the lack of maintenance on these valves during the past 30 years of operation.

V.Y. PIPING F.A.C. INSPECTION PROGRAM: 2002 REFUELING OUTAGE

INSPECTION REPORT

2.0 2002 REFUELING OUTAGE INSPECTION PLAN

The 2002 refueling outage inspection scope was developed to satisfy the following goals:

- Inspect large bore components requiring follow up inspections, based on UT data from previous refueling outages.
- Inspect components identified by the EPRI CHECWORKS computer code as being ranked high for susceptibility to wear and/or having the least time remaining to reach code minimum wall thickness.
- Perform repeat inspections on selected large bore components for calibration of the CHECWORKS models.
- To incorporate industry experience into the program through inspection of components at VY that are similar to those that have either failed or showed significant wall thinning at other plants.
- Perform an internal visual inspection of the 30" B turbine cross around piping. This is the last remaining carbon steel section. The last internal inspection was performed in 1999.
- Inspection of selected small bore components contained in the Small Bore Database which have not had an initial inspection.
- Inspection of selected small bore components based on previous wear or leaks.
- To complete base line UT inspections on the No.1 high pressure (HP) feedwater heaters shells adjacent to the extraction steam inlet nozzles.
- Inspections on any large bore and small bore piping components subjected to off normal flow conditions, such as components downstream of normally closed valves with seat leakage are generally performed each refueling outage. These components are typically identified by the cognizant Systems Engineer, using the turbine performance monitoring system. No components were identified during the scoping for RFO 23.

The planned duration for RFO 23 FAC activities was approximately 15 days. Given the shorter duration consideration was given to optimizing the locations and number of components to be inspected, and also to be consistent with previous outage inspection efforts. The detailed reasoning for component selection is contained in the Inspection Location Worksheets, reference (4). The complete planned scope for RFO 23 is contained in reference (5).

V.Y. PIPING F.A.C. INSPECTION PROGRAM: 2002 REFUELING OUTAGE

INSPECTION REPORT

3.0 EVALUATION OF INSPECTION RESULTS

3.1 Large Bore Piping

The planned large bore piping inspection scope for RFO 23 included external UT exams on 23 large bore piping components at nine locations on the Feedwater and Heater Drain Systems. Three components adjacent to feedwater heater E-2-1A on the Heater Drain System were removed from the scope due to the decision to replace all 4 high pressure feedwater heaters in 2004. Two additional components on the Feedwater System were inspected due to availability. A total of 22 large bore components were inspected using external UT.

The UT results were directly downloaded from the data loggers into the EPRI CHECWORKS program located on the VY computer network. The thickness data were evaluated using a three level screening process as defined in procedure, DP 0072. The UT inspection results for each component were reviewed for anomalies and consistency with piping geometry. Wear rates (wear/cycle) were calculated for each component using methods specified in DP 0072, and are consistent with NSAC-202L, reference (8). For component UT results which indicated no wear or minimal wear has occurred, a minimum wear rate of 0.005 inches/cycle was used. Using the calculated wear rates and the 2002 measured thickness, the predicted thickness at the end of the next cycle (2004 Tpred) was calculated using a safety factor of 1.2 on the calculated wear per cycle. Using both the wear rate and 2002 measurement data, the projected number of cycles beyond the Fall 2002 refueling outage (RFO23) for each component to wear down to the code minimum wall thickness was also calculated.

Components passing the Level 1 screen have 2004 Tpred greater than .875Tnom (the manufacturing tolerance of new piping) and require no further evaluation. The Level 2 screen is for components with 2004 Tpred less than .875Tnom but greater than Tmin (the code minimum wall thickness to resist pressure and mechanical loads). These components are acceptable for continued operation but future monitoring is recommended. The Level 3 screening is for components with 2004 Tpred less than Tmin. The Level 3 screening is a detailed analytical methodology. It also requires that additional piping components be inspected this outage (sample expansion), and considered for inspection during future refueling outages.

All components inspected were found to have wall thickness greater than code minimum wall thickness. All predicted wall thickness (at the 2004 refueling outage) values were above code minimum wall thickness. Of the 22 large bore piping components inspected, 18 (82%) passed the Level 1 screen, and the remaining 4 (18%) passed the Level 2 screen.

No large bore repairs or replacements were required. Only one component was identified as requiring future monitoring and is discussed in Section 4.0 of this report. A summary of the large bore piping component screening is contained in Attachment 1.

V.Y. PIPING F.A.C. INSPECTION PROGRAM: 2002 REFUELING OUTAGE

INSPECTION REPORT

3.2 Turbine Cross Around Piping

Inspections of the turbine cross around piping had been deferred until the 2002 RFO based on an evaluation of the inspection results from the 1996, 1998, and 1999 refueling outages. An internal visual inspection was performed on the B 30" diameter Cross Around (CAR) line which runs from the B Moisture Separator to the low pressure turbine. This line is the last remaining carbon steel Cross Around line. The last inspection of this pipe was performed during the 1999 Refueling Outage.

During the 1995 refueling outage, new moisture separator Internals were installed and extensive weld repairs were made in this line. The weld repairs performed in 1995 essentially restored the wall thickness of the entire run to a minimum of 0.50" (nominal wall thickness). The extent of the weld repairs performed in 1995 was greater than previous efforts. The previous repairs were intended to last only one cycle. The 1995 repairs were originally intended to last until 1998 with an inspection and minor touch up in 1996 as required.

The 30" B line generally appears essentially the same as observed in 1999. No new areas of red/black oxide were identified. Also, the extent of areas of red/black oxide identified in previous inspections is essentially the same. Markings on the interior of the pipe to identify the 1995 inspection/repair locations, and the 1996 inspection locations are still visible. These are evidence that there is no significant wall loss occurring. Based on the visual results no supplemental internal ultrasonic (UT) thickness exams were performed. No repairs were required based on the criteria developed in reference(10).

The series of internal visual inspections performed since 1996 along with limited UT measurements verifies that degradation of the interior surface of the carbon steel 30 inch B Cross Around piping has been minimal as compared to observed damage prior to the internal modifications made in the Moisture Separators. The rate of degradation previously observed and the need for extensive weld repairs has been mitigated by both the repair effort performed in 1995 and the installation of new internals in the moisture separators.

If no changes to plant operation that effect the flow regime (i.e. pressure, flow rate, moisture content, etc.) in this line occur, or are planned, then the next scheduled internal visual inspection can be deferred one operating cycle to the Fall of 2005. However, if the planned modifications to the high pressure turbine and moisture separators as part of the power uprate project are to be executed during the Spring 2004 refueling outage, the changes in operating pressures and flows will require a reassessment of the current Cross Around piping inspection and evaluation methodology. Inputs to reference(10) will change and the current evaluation criteria will be affected.

V.Y. PIPING F.A.C. INSPECTION PROGRAM: 2002 REFUELING OUTAGE

INSPECTION REPORT

3.3 Small Bore Piping

Three sections of small bore piping were scheduled for external UT inspection during the 2002 refueling outage. These were new inspections. Two sections of Heater Vent piping from the No. 3 feedwater heaters were inspected in RFO 23. This piping was installed in 1992 when the No.3 feedwater heaters were replaced. The other section inspected was on the 1"-LPDR low point drain off the turbine steam seal header line at the condenser. This location is downstream of the location of a through wall leak at a socket welded elbow fitting that occurred in 2001, reference (12). The damaged elbow and adjacent piping were replaced during the outage.

No significant wear was found in any of the small bore piping inspected. A summary of the small bore piping inspection results is contained in Attachment 2.

3.4 Feedwater Heater Shells

The planned scope for RFO 23 was to complete baseline UT inspections on the No.1 high pressure (HP) feedwater heater shells adjacent to the extraction steam inlet nozzles. Additional asbestos abatement was planned on these heaters due to planned installation of inspection ports. The extent of the existing grids was to be increased. Also, additional UT measurements on the No. 2 HP heaters shells were to be performed as required to supplement internal visual inspections.

The planned inspections were not performed due to the decision to replace all 4 high pressure feedwater heaters in 2004. Limited internal visual inspections were performed on the No.2 HP feedwater heaters to assess changes since the last RFO, and to confirm conditions for one more operating cycle.

3.5 Extraction Steam Reverse Current Valves

Of note, but not directly under the scope of the Piping FAC Inspection Program, was the discovery of erosion of internal components found in the Extraction Steam system reverse current valves. The extraction steam piping routes high pressure and low pressure turbine exhaust steam to the shell sides of the feedwater heaters. The flow rates and steam quality vary in each stage depending on its turbine exhaust point and the line size. The extent of erosion varied in each stage exhaust line, with the most damage found in the 7th stage extraction from the LP turbines.

There are a total of 8 valves located in lines originally constructed using chrome-moly piping. The valve bodies and a majority of the internal parts are cast steel A217-WC6 which is more resistant to wall loss from wet steam flow than the typical A216-WCB carbon steel used in other plant systems. However, the flat covers which form the pressure boundary and the hex nuts which hold the valve disk to the swing arm are carbon steel.

V.Y. PIPING F.A.C. INSPECTION PROGRAM: 2002 REFUELING OUTAGE

INSPECTION REPORT

The Adverse Trend Investigation Report for ER 2002-2568, reference (11) identified the root cause of the erosion as a material deficiency. The design specification required a chrome-moly material, the vendor supplied a carbon steel material. The lack of maintenance on these valves during the past 30 years of operation contributed to the extent of the erosion found.

The valve covers and the nuts are located out of the flow stream and partially shielded by the open disc. The severe wear was limited to the covers and the nuts. The chrome-moly internal parts and the valve bodies show no or limited wear considering 30 years of operation. The manufacturers drawing shows blank spaces and then "steel" as the material. Apparently changes to the drawings were made during procurement and fabrication. The replacement covers obtained from the vendor are carbon steel A285 Gr. C as specified by the vendor.

External UT inspections of valves, especially check valves, are not typically performed under the Piping FAC Inspection Program at VY. Based on past experience with UT measurement on valves, line items were added to the valve maintenance procedures to inspect for internal wear/corrosion of the bodies and internal parts. Had we performed UT inspections on these valves, the inspection would have been limited to the flow stream, the covers would not have been included in the inspection since they are located outside the flow stream. This is the first valve cover erosion we have experienced. The erosion was not expected considering the valves bodies are chrome-moly. The carbon steel parts are inconsistent with the chrome-moly bodies with respect to FAC wear resistance. The materials used in the cover and disc nut are incompatible with long term exposure to wet steam flow.

The long term solution should include replacement of carbon steel components with FAC resistant materials, and a review of piece parts in other valves with similar flow regimes to insure this situation does not exist in other valves.

4.0 COMPONENTS REQUIRING FUTURE MONITORING

Components requiring future monitoring are identified using the "2004 Predicted Thickness", the "Screening Level" which the component passed, and the "Approximate Cycles to T_{min}" shown in Attachment 1. From the wear rates and cycles to T_{min} calculated in Attachment 1, only one component, FD18EL01 was identified with less than 10 cycles to T_{min}. However, a conservative wear rate based on a single inspection was used in the time calculation. The conservative time to T_{min} is approximately 8 cycles. Inspection of this component should be performed in 4 cycles (2007 RFO) to confirm the calculated wear rates.

The 2002 refueling outage inspection results will be incorporated into the existing CHECWORKS models of the Feedwater and Heater Drain Systems. The 2002 inspection data, and data from previous inspections will be used to refine the wear rate predictions. The results shown in Attachment 1 and the updated CHECWORKS analyses will be used to determine the inspection scope for future refueling outages.

V.Y. PIPING F.A.C. INSPECTION PROGRAM: 2002 REFUELING OUTAGE

INSPECTION REPORT

5.0 COMPONENTS REQUIRING POSSIBLE REPAIR OR REPLACEMENT

No specific components were identified as requiring repairs or replacements. However, with future operation under GE hydrogen water chemistry, wear rates in the Feedwater and Heater Drain systems are expected to increase. The Feedwater System piping from the feed pumps past the feed regulator valves has a relatively low margin for wall loss due to flow accelerated corrosion. This is due to the high design pressure and the installed wall thickness. The CHECWORKS models for this piping will be updated with the 2002 (RFO23) inspection data, and inspections of specific components on the Feedwater System piping will continue in the future.

6.0 INSPECTION DATA RETENTION

UT thickness data has been taken using Vermont Yankee owned Panametrics 26DL⁺ digital UT and electronic data logging system. The large bore UT inspection results were downloaded directly into the CHECWORKS database located on the VY computer network. The measured thickness data for each component is stored in the CHECWORKS data base. A thickness data sheet (form VYNEF8053.01) including the CHECWORKS thickness matrix printout was created for each inspection. The inspection reports are controlled and put into permanent storage by VY ISI personnel per AP 6807. Component evaluations are documented and transferred to Records Management per the FAC Program Procedure PP 7028.

V.Y. PIPING F.A.C. INSPECTION PROGRAM: 2002 REFUELING OUTAGE

INSPECTION REPORT

7.0 RECOMMENDATIONS FOR FUTURE FAC INSPECTIONS

Based on results from the RFO 23 inspections no new immediate or near term repairs or replacements are required.

Utilization of ISI inspection personnel to perform FAC inspections, use of the Panametric data logging equipment, and the CHECWORKS code has proven to be effective in performing and evaluating the UT inspections required under PP 7028. The continued use of this setup is recommended.

The long term solution for erosion of the carbon steel parts in the Extraction Steam reverse current valves should include replacement of carbon steel components with FAC resistant materials, and a review of the piece parts in other valves with similar flow regimes to insure this situation does not exist in other valves. These recommendations will be evaluated by the FAC Program Coordinator under commitment item No. ER 2002-2586_03.

The planned power uprate project underway at VY will require a complete review of program evaluations, piping modelling, and procedures to account for changes in equipment and flow regimes in plant piping systems. This review should be performed prior to the next refueling outage to insure all required baseline inspections are performed prior to increased power operations.

The potential for finding significant wear in any piping component exists. Contingency planning as required for either weld repair or replacement of large bore components in the piping systems should be considered. ASME code cases for external weld overlay of eroded piping have been approved in recent years. The applicability and possible use of these code cases at VY should be evaluated. These code cases could provide additional methods for timely and effective repairs during short refueling outages.

V.Y. PIPING F.A.C. INSPECTION PROGRAM: 2002 REFUELING OUTAGE

INSPECTION REPORT

8.0 REFERENCES

1. V.Y. Program Procedure PP 7028, Piping Flow Accelerated Corrosion (FAC) Inspection Program, Original Issue 5/10/01 with LPC 1 dated 12/06/01.
2. V.Y. Department Procedure, DP 0072, "Structural Evaluation of Thinned Wall Piping Components", Original Issue 5/17/01, with LPC 1 dated 10/02/01.
3. V.Y. Nondestructive Examination Procedure, NE 8053, "Ultrasonic Thickness Measurement" Revision 1, dated 9/13/02.
4. VY Piping FAC Inspection Program – 2002 Refueling Outage: Inspection Location Worksheets / Methods and Reasons for Component Selection, dated 10/31/01.
5. Memo J.C.Fitzpatrick to S.D.Goodwin, subject: Piping FAC Inspection Scope for the 2002 Refueling Outage, VYM 2001/025, dated 10/31/01.
6. ENVY Memo J.C.Fitzpatrick to S.D.Goodwin, subject: Summary of RFO 23 Turbine Cross Around Piping Inspections, VYM 2002-009, dated 10/13/02.
7. ENVY Memo J.C.Fitzpatrick to S.D.Goodwin, subject: 2002 Refueling Outage Piping Flow Accelerated Corrosion Inspection Summary, VYM 2002-010, dated 10/21/02.
8. EPRI Report, "Recommendations for an Effective Flow-Accelerated Corrosion Program", EPRI NSAC-202L-R2, April 1999.
9. CHECWORKS - Computer Program User Guide, TR 103496, August 1994 by Altos Engineering Applications Inc. for EPRI.
10. VY Calculation No. VYPC 92-004, Rev. 0, "Turbine Cross Around Piping Wall Thinning Evaluation"
11. VY Event Report No. ER 2002-2568, Identification of Adverse Trend with reports of erosion on valve parts in the Extraction Steam (ES) system.
12. VY Event Report No. ER 2001-1823, Steam Seal Pressure Regulator Steam Leak

V.Y. PIPING F.A.C. INSPECTION PROGRAM: 2002 REFUELING OUTAGE INSPECTION REPORT

ATTACHMENT 1: SUMMARY OF LARGE BORE PIPING UT INSPECTION RESULTS

Inspect. No.	Component ID	DIA	Tnom	.875° Tnom	Tmin	2002 Min Tmeas	Wear Rate(in./cycle)	2004 Tpred.	Passed Screen Level	Approx. Cycles to Tmin	Future Inspections Recommended	Comments
		(in)	(in)	(in)	(in)	(in)	Note 2	Note 3		Note 4		
2002-01	FD01SP11US	24	1.812	1.586	1.447	1.551	0.005	1.545	2	17.3		
2002-02	FD08RD01	24	1.812	1.586	1.447	1.578	0.005	1.572	2	21.8		
		18	1.375	1.203	1.085	1.263	0.005	1.257	1	29.7		
2002-03	FD08EL01	18	1.375	1.203	1.085	1.328	0.010	1.314	1	20.1		
2002-03A	FD08SP01US	18	1.375	1.203	1.085	1.224	0.0075	1.215	1	15.4		Note 5
2002-04	FD14SP06DS	18	1.219	1.067	0.984	1.126	0.006	1.119	1	22.5		
2002-05	FD14EL05	18	1.219	1.067	0.954	1.134	0.005	1.128	1	26.3		
2002-06	FD14TE02	18	1.219	1.067	0.984	1.250	0.005	1.244	1	47.7		Run
		8	0.719	0.629	0.520	0.670	0.005	0.664	1	25.0		Branch
2002-06A	FD14SP07DS	18	1.219	1.067	0.954	1.155	0.005	1.149	1	31.8		Note 5
2002-07	FD18SP01DS	18	0.844	0.739	0.645	0.785	0.005	0.779	1	23.3		
2002-08	FD18EL01	18	0.844	0.739	0.645	0.797	0.016	0.778	1	7.92*	2007 RFO	*Note 6
2002-09	FD18SP02US	18	0.844	0.739	0.845	0.753	0.005	0.747	1	18.0		
2002-10	HD12SP20DS	6	0.280	0.245	0.120	0.242	0.007	0.233	2	20.3		
2002-11	HD12EL22	8	0.280	0.245	0.120	0.282	0.005	0.276	1	27.0		
2002-12	HD12SP21US	8	0.280	0.245	0.120	0.243	0.005	0.237	2	20.5		
2002-16	HD1BEL03	8	0.280	0.245	0.200	0.299	0.007	0.291	1	11.8*		*Note 6
2002-17	HD1BSP05US	6	0.280	0.245	0.200	0.257	0.005	0.251	1	12.5*		*Note 6
2002-18	HD3AEL01	10	0.365	0.319	0.200	0.349	0.005	0.343	1	23.9		
2002-19	HD3ASP03US	10	0.365	0.319	0.154	0.348	0.005	0.342	1	32.3		

V.Y. PIPING F.A.C. INSPECTION PROGRAM: 2002 REFUELING OUTAGE INSPECTION REPORT

ATTACHMENT 1: SUMMARY OF LARGE BORE PIPING UT INSPECTION RESULTS

Inspect. No.	Component ID	DIA	Tnom	.875* Tnom	Tmin	2002 Min Tmeas	Wear Rate (in./cycle)	2004 Tpred.	Passed Screen Level	Approx. Cycles to Tmin	Future Inspections Recommended	Comments
		(in)	(in)	(in)	(in)	(in)	Note 2	Note 3		Note 4		
2002-20	HD5BTE01	14	0.375	0.328	0.175	0.570	0.010	0.559	1	33.6		Run
		14	0.375	0.328	0.175	0.526	0.008	0.516	1	35.5		Branch
2002-20A	HD5BSP06DS	14	0.375	0.328	0.146	0.336	0.005	0.330	1	31.6		Note 5
2002-21	HD5BSP07US	14	0.375	0.328	0.146	0.339	0.005	0.333	1	32.2		
2002-22	HD7AEL04	16	0.375	0.328	0.280	0.447	0.007	0.438	1	19.1		
2002-23	HD7ASP04US	18	0.375	0.328	0.140	0.328	0.005	0.322	2	31.3		

NOTES:

- All thickness values are inches.
- Wear/Cycle is approximately inches/18 months. The wear per cycle was calculated per DP0072 using 16.8 equivalent 18 month cycles based on approx. 157,000 operating hours up to 1996 outage, and 12000 ± hrs./cycle. Minimum Wear/Cycle used to calculate Tpred and Cycles to Tmin is 0.005 inches per cycle.
- 2004 T predicted = 2002 T measured - F.S. * (Wear/Cycle), F.S. = Factor of Safety = 1.20.
- Cycles to Tmin is calculated from: $\frac{(2002\ T\ measured - T_{min})}{F.S. \times\ Wear/Cycle}$ (i.e. Cycles from 2002 RFO)
- Component added to scope due to availability. Scaffolding and insulation removal were already performed for adjacent components.
- Conservative of wear rate used. Wear rate based on single inspection using band method (max-min).

V.Y. PIPING F.A.C. INSPECTION PROGRAM: 2002 REFUELING OUTAGE INSPECTION REPORT

ATTACHMENT 2: SUMMARY OF SMALL BORE PIPING UT INSPECTION RESULTS

SMALL BORE PIPING

S.B. Inspection Number (Data Base No.)	Description / Location	Section	Size (in.)	Sch	Tnom. (inch)	.875 * Tnom. (inch)	T min. (inch) (Note 1)	2002 Min. Measured Thickness (inch)	Apparent Wear Rate (inch/cycle)	Cycles to Tmin. (Note2)	Comments
02-SB01 (48)	2"-HV-9A Pipe & Fittings @ R.O.-3A at FDW heater E-3-1A / TB Heater Bay (Approx. Elev. 236.)	A	2	80	.218	.191	.073	.210	<0.005	22.8	
		B	2	80	.218	.191	.073	.207	<0.005	22.3	
		C	2	80	.218	.191	.073	.208	<0.005	22.5	
02-SB02 (55)	2"-HV-9B Pipe & Fittings @ Condenser Nozzle 23B / TB Heater Bay (Approx. Elev. 236.)	A	2	80	.218	.191	.073	.203	<0.005	21.7	
		B	2	80	.218	.191	.073	.199	<0.005	21.0	
		C	2	80	.218	.191	.073	.206	<0.005	22.2	
02-SB03 (129)	SSH Low Point Drain 1-LPDR-1" drain off SSH piping & fittings at connection to Condenser A, Nozzle 61. / TB Heater Bay (Approx. Elev. 236.)	A	1	80	.179	.157	.066	.169	<0.005	17.2	
		B	1"	160	.250	.219	.066	.216	<0.005	35.0	

NOTES:

1. Tmin includes a 0.065 inch corrosion allowance per ANSI B31.1-1987.
2. Cycles to Tmin from 2002 refueling outage. SF (safety factor) = 1.2 was used on the apparent wear rate. Small bore wear is generally not trended for the purposes of repeat inspections. Small bore components will generally be replaced if significant thinning is observed.

Engineering Report No. VY-RPT-04-00010 Rev. 0
 Page 1 of 20

Plus attached CD



ENTERGY NUCLEAR NORTHEAST

Engineering Report Cover Sheet

Engineering Report Title:

**VERMONT YANKEE PIPING FLOW ACCELERATED CORROSION
 INSPECTION PROGRAM (PP 7028)
 2004 REFUELING OUTAGE INSPECTION REPORT
 (RFO 24- Spring 2004)**

Engineering Report Type:

New Revision Cancelled Superseded

Applicable Site(s)

IP1 IP2 IP3 JAF PNPS VY

Quality-Related: Yes No

Prepared by: James C. Fitzpatrick *[Signature]*
 Responsible Engineer (Print Name/Sign)

Date: 2/15/05

Verified/Reviewed by: Thomas M. O'Connor *[Signature]*
 Design Verifier/Reviewer (Print Name/Sign)

Date: 2/15/05

*Reviewed by: N/A
 Authorized Nuclear In-service Inspector (ANII)

Date: N/A

Approved by: Scott D. Goodwin *[Signature]*
 Supervisor (Print Name/Sign)

Date: 2-15-05

Multiple Site Review (10)

Site	Design Verifier/Reviewer (Print Name/Sign)	Supervisor (Print Name/Sign)	Date
	N/A	N/A	N/A

*: For ASME Section XI Code Program plans per ENN-DC-120, if required.

TABLE OF CONTENTS

Section	Description	Page No.
	Engineering Report Cover Sheet (ENN-DC-147 Att.9.1)	1
	TABLE OF CONTENTS	2
1.0	EXECUTIVE SUMMARY	3
2.0	PURPOSE	4
3.0	ASSUMPTIONS	4
4.0	2004 REFUELING OUTAGE INSPECTION PLAN	4
5.0	EVALUATION OF INSPECTION RESULTS	6
5.1	Large Bore Piping	6
5.2	Turbine Cross Around Piping	7
5.3	Small Bore Piping	8
5.4	Feedwater Heater Shells	8
6.0	COMPONENTS REQUIRING FUTURE MONITORING	8
7.0	COMPONENTS REQUIRING POSSIBLE REPAIR OR REPLACEMENT	9
8.0	CONCLUSIONS / RECOMMENDATIONS FOR FUTURE FAC INSPECTIONS	9
9.0	REFERENCES	10
ATTACHMENT 1:	SUMMARY OF LARGE BORE PIPING UT INSPECTION RESULTS	11-12
ATTACHMENT 2:	SUMMARY OF SMALL BORE PIPING UT INSPECTION RESULTS	13-14
ATTACHMENT 3:	COMPONENTS RECOMMENDED FOR FUTURE MONITORING	15-16
ATTACHMENT 4:	CATALOG OF PHOTOS FROM INTERNAL INSPECTION OF 36 INCH DIAMETER CROSS AROUND PIPING	17-19
ATTACHMENT 5:	ENN-DC-147 ATT.9.3 TECHNICAL REVIEW COMMENTS AND RESOLUTION FORM	20

PLUS CD CONTAINING JPEG FILES of 36 INCH DIAMETER CROSS AROUND PIPING PHOTOS

1.0 EXECUTIVE SUMMARY

External UT measurements were taken on 26 large bore piping components in the Feedwater, Condensate, Extraction Steam, and Main Steam Drain Systems. External UT inspections were performed on 11 sections of small bore piping on the turbine bypass valve first seal leakoff piping, the high pressure turbine pocket drain line, and the feedwater pump warm-up line. Internal visual inspections of the turbine cross around piping were performed in all four 36 inch diameter lines A to D, and the two west 30 inch diameter lines C and D.

Component selection was based on a combination of; previous inspection data, industry events, analyses using the EPRI developed CHECWORKS computer code, and the consequences of component failure. A detailed selection process was used and was documented in reference (4).

The large bore results were evaluated using a three level screening process defined in plant procedure DP 0072. All components inspected were found to have a wall thickness greater than the code minimum wall thickness. The predicted thickness at the next refueling outage was greater than the code minimum wall thickness for all components. No large bore piping components required repair or replacement during the refueling outage.

Small bore inspections on line 1SLBPV identified localized wall loss and a local "like-for-like" carbon steel replacement at inspection location 04-SB04 was performed during RFO 24. Engineering Request ER 04-0964 was written for replacement of the entire 1SLBPV line with FAC resistant material.

A summary of the large bore piping component screening is contained in Attachment 1. Attachment 2 contains a summary of the small bore piping inspection results.

Section 6.0 discusses the criteria used to screen components as requiring future monitoring. Attachment 3 contains a summary of piping components recommended for future inspections.

Section 7.0 identifies components repaired or replaced during RFO 24.

Section 8.0 contains conclusions and recommendations for future FAC inspections. There were no immediate operability concerns as the result of FAC inspections performed during RFO24.

2.0 PURPOSE

Each refueling outage, ultrasonic thickness (UT) measurements and or/internal visual inspections are performed on plant piping per the Vermont Yankee Piping Flow Accelerated Corrosion (FAC) Inspection Program, PP7028, reference (1). This report summarizes the results of the inspections performed during RFO 24-Spring 2004.

3.0 ASSUMPTIONS

There are no assumptions.

4.0 2004 REFUELING OUTAGE INSPECTION PLAN

The 2004 refueling outage inspection scope was developed to satisfy the following goals:

- Inspection of large bore components requiring follow up inspections, based on UT data from previous refueling outages.
- Inspection of components identified by the EPRI CHECWORKS computer code as being ranked high for susceptibility to wear and/or having the least time remaining to reach code minimum wall thickness.
- Perform repeat inspections on selected large bore components for calibration of the CHECWORKS models.
- To incorporate industry experience into the program through inspection of components at VY that are similar to those that have either failed or showed significant wall thinning at other plants. During the 2004 RFO, inspections were performed on large bore piping connected directly to the condenser which serves as a drain collector for several small bore lines.
- Perform an internal visual inspection of all four 36" turbine cross around lines exiting the high pressure (HP) turbine. These inspections are to baseline the condition prior to changes in flows due to the HP turbine modifications and power uprate. A priority is to assess the condition of a 12 inch diameter carbon steel stub piece visible from inside the 36"A line.
- Perform an internal visual inspection of the 30" C and D cross around lines to confirm the condition of previous P22 material replacements.
- Inspection of selected small bore components contained in the Small Bore Database which have not had an initial inspection.
- Inspection of selected small bore components based on previous wear or leaks, primarily on the turbine bypass valve chest first seal leak off piping.

- Inspection of selected small bore components connected to the HP turbine to baseline the condition prior to changes in flows due to the HP turbine modification and power uprate.
- Large and small bore piping components subjected to off normal flow conditions, such as components downstream of normally closed valves with seat leakage are generally performed each refueling outage. These components are typically identified by the cognizant Systems Engineer, using the turbine performance monitoring system. No components were identified during the scoping for RFO 24.
- All four HP feedwater heaters were scheduled for replacement in the 2004 RFO. This limits access to piping in the upper heater bay. To optimize the inspection scope a number of inspections will be performed in the feedwater pump room on both the feedwater and condensate systems. These inspections will serve to baseline conditions prior to the increased flows from power uprate.

The planned duration for RFO 24 FAC activities was approximately 18 days. Given the shorter duration consideration was given to optimizing the locations and number of components to be inspected, and also to be consistent with previous outage inspection efforts. The detailed reasoning for component selection is contained in the Inspection Location Worksheets, reference (4). The complete planned scope for RFO 24 is contained in reference (5).

5.0 EVALUATION OF INSPECTION RESULTS

5.1 Large Bore Piping

The planned large bore piping inspection scope for RFO 24 included external UT exams on 26 large bore piping components at eleven locations on the Feedwater, Condensate, Extraction Steam, and Main Steam Drain Systems. All 26 components were inspected using external UT.

The thickness data were evaluated using a three level screening process as defined in procedure, DP 0072. The UT inspection results for each component were reviewed for anomalies and consistency with piping geometry. Wear rates (wear/cycle) were calculated for each component using methods specified in DP 0072, and are consistent with NSAC-202L, reference (6). For component UT results which indicated no wear or minimal wear has occurred, a minimum wear rate of 0.005 inches/cycle was used. Using the calculated wear rates and the 2004 measured thickness, the predicted thickness at the end of the next cycle (2005 T_{pred}) was calculated using a safety factor of 1.2 on the calculated wear per cycle. Using both the wear rate and 2004 measurement data, the projected number of cycles beyond the Spring 2004 refueling outage (RFO24) for each component to wear down to the code minimum wall thickness was also calculated.

Components passing the Level 1 screen have 2005 T_{pred} greater than $.875T_{nom}$ (the manufacturing tolerance of new piping) and require no further evaluation. The Level 2 screen is for components with 2005 T_{pred} less than $.875T_{nom}$ but greater than T_{min} (the code minimum wall thickness to resist pressure and mechanical loads). These components are acceptable for continued operation but future monitoring is recommended. The Level 3 screening is for components with 2005 T_{pred} less than T_{min} . The Level 3 screening is a detailed analytical methodology. It also requires that additional piping components be inspected this outage (sample expansion), and considered for inspection during future refueling outages.

All components inspected were found to have wall thickness greater than code minimum wall thickness. All predicted wall thickness (at the 2005 refueling outage) values were above code minimum wall thickness. Of the 26 large bore piping components inspected, 14 (54%) passed the Level 1 screen, and the remaining 12 (46%) passed the Level 2 screen.

No large bore repairs or replacements were required. Eight components were recommended for future monitoring. These are discussed in Section 6.0 of this report. A summary of the large bore piping component screening is contained in Attachment 1.

5.2 Turbine Cross Around Piping

36 Inch Diameter Lines A to D:

Internal visual inspections of the four 36" turbine cross around lines exiting the HP turbine were performed. These inspections were performed to document the condition of the lines prior to operation with the modified turbine and increased flows from power uprate. Also, the visual inspection of a section of 12 inch diameter carbon steel pipe on line 12-ES-1A stub piece visible from inside the 36"A line was performed. This section was also included in the large bore external UT scope as inspection No. 2004-022.

Prior to entering the piping, FAC inspection reports and notes from previous refueling outages and reference (12) were reviewed to identify previously noted conditions.

No areas of active corrosion were identified. Previously identified surface tiger striping with no discernable depth, showed no change in surface extent. The piping is essentially in the same condition as noted in 1998 in reference(12).

Digital photos were taken in each line to document the condition during RFO 24. These will be used for comparison during future outages. The photos are JPEG files contained on the attached CD. Attachment 4 to this report is an index and description of each photo.

30 Inch Diameter Lines C & D:

An internal visual inspection of both the C & D 30 inch diameter cross around lines on the west side of the turbine was performed to confirm the condition of previous P22 material replacements. Both lines have been replaced with P22 Chrome-Moly piping material. The 30" C line was replaced in 1993. This was the first inspection since the replacement. The 30" D line was replaced in 1985 and the last internal inspection was performed in 1995.

Both lines have a smooth grey/blue interior surface with no evidence of wall loss or active surface corrosion. No photos were taken in the 30 inch diameter piping due to resource constraints. For the 30 inch C line the only notable feature is discoloration in the heat affected zone on the downstream weld at elbow CARCEL06 shown on FAC location Sketch No.084. For the 30 inch D line, original fabrication grinding marks on the extrados of elbow CARDEL05 (FAC Location Sketch 085) which were previously identified in 1995 are essentially the same as in 1995.

With 19 years of operation for the 30 inch D line and 10 years for the 30 inch C line, the ASTM A691 P-22 piping material shows no evidence of wall loss due to FAC and has proven as an effective replacement material for the original GE supplied carbon steel piping.

5.3 Small Bore Piping

Eleven sections of small bore piping were scheduled for external UT inspection during the 2004 refueling outage. One inspection was a new location from the small bore database. Five locations on the turbine bypass valve chest first seal leakoff line 1SLBPV were inspected to determine the extent of condition due to a through leak during the cycle, reference (9). A temporary engineered leak enclosure, reference (10), was removed and the damaged piping was replaced during the outage. One of the locations inspected on 1SLBPV, 04-SB04 had localized wall loss and was replaced with carbon steel pipe. Engineering Request ER 04-964, reference (11) was written to replace the entire 1SLBPV line with FAC resistant material.

The remaining five locations were on the HP turbine pocket drain line 1SPL2 located directly under the HP turbine. These were repeat inspections performed to assess the condition of the piping prior to the HP turbine modifications and operation under power uprate flows.

No significant wear was found in the small bore piping inspected except for location 04-SB04 on line 1SLBPV. A summary of the small bore piping inspection results and recommendations for future inspections is contained in Attachment 2.

5.4 Feedwater Heater Shells

All four HP feedwater heaters were replaced during RFO 24. All ten feedwater heater shells have been replaced with either chrome-moly or stainless steel materials. There are no planned UT inspections for the feedwater heater shells in the near term.

6.0 COMPONENTS REQUIRING FUTURE MONITORING

Components requiring future monitoring are identified using the predicted thickness at the next refueling outage (2005 $T_{\text{Predicted}}$), the "Screening Level" which the component passed, and the "Approximate Cycles to T_{min}" shown in Attachment 1. From the wear rates and cycles to T_{min} calculated in Attachment 1, five components were identified with less than 10 cycles to T_{min}. These calculated times are based on conservative wear rate estimates. A detailed description is contained in Attachment 3. Re-inspections were recommended for 8 components with lowest calculated times to T_{min}. The recommended inspection time is generally one-half the calculated time to reach T_{min}.

The 2004 refueling outage inspection results will be incorporated into the existing CHECWORKS models of the Feedwater and Condensate Systems. The 2004 inspection data along with data from previous inspections will be used to refine the wear rate predictions. The results shown in Attachment 1 and the updated CHECWORKS analyses will be used to determine the inspection scope for future refueling outages.

7.0 COMPONENTS REQUIRING POSSIBLE REPAIR OR REPLACEMENT

No specific large bore components were identified as requiring repairs or replacements.

Small bore inspections on line 1SLBPV identified localized wall loss and a local "like-for-like" carbon steel replacement at inspection location 04-SB04 was performed during RFO 24. Engineering Request ER 04-0964 was written for replacement of the entire 1SLBPV line replacement with FAC resistant material.

No other small bore piping was identified as requiring repair or replacement.

8.0 CONCLUSIONS / RECOMMENDATIONS FOR FUTURE FAC INSPECTIONS

There were no immediate operability concerns as the result of FAC inspections performed during RFO24.

Based on results from the RFO 24 inspections, no new immediate or near term repairs or replacements are required. Replacement of small bore line 1SLBPV piping which has experienced through wall leaks in the past is being addressed in ER 04-0964.

The planned power uprate project underway at VY requires a complete review of program evaluations, piping modeling, and procedures to account for changes in equipment and flow regimes in plant piping systems. Inspection data taken this outage will serve as part of the baseline data prior to operation with the increased flows from power uprate.

9.0 REFERENCES

1. V.Y. Program Procedure PP 7028, Piping Flow Accelerated Corrosion (FAC) Inspection Program, Original Issue 5/10/01 with LPC 1 dated 12/06/01.
2. V.Y. Department Procedure, DP 0072, "Structural Evaluation of Thinned Wall Piping Components", Original Issue 5/17/01, with LPC 1 dated 10/02/01.
3. ENN-NDE-9.05, Revision 0, Ultrasonic Thickness Examination.
4. VY Piping FAC Inspection Program – 2004 Refueling Outage: Inspection Location Worksheets / Methods and Reasons for Component Selection, dated 3/27/03.
5. ENVY Memo: J.C.Fitzpatrick to S.D.Goodwin, subject: Piping FAC Inspection Scope for the 2004 Refueling Outage, VYM 2003/009, dated 3/27/03.
6. EPRI Report, "Recommendations for an Effective Flow-Accelerated Corrosion Program", EPRI NSAC-202L-R2, April 1999.
7. CHECWORKS - Computer Program User Guide, TR 103496, August 1994 by Altos Engineering Applications Inc. for EPRI.
8. VY Calculation No. VYPC 92-004, Rev. 0, "Turbine Cross Around Piping Wall Thinning Evaluation".
9. Vermont Yankee Event Report ER No. 2003-044, Turbine Bypass Steam Leak , Line #1 1SLBPV, Level 2.
10. Temporary Modification Package No. 2003-002, Installation of Steam Leak Repair Enclosure on 2" Steam Seal Off the Turbine Bypass Valves.
11. Engineering Request ER 04 -0964, Replace Turbine Bypass Valve Chest 1st Seal Leakoff Piping 1SLBPV.
12. VY Design Engineering - Bolton MEMO: J.C. Fitzpatrick to D.Girroi(VY-ISI), VYM 98/91, dated May 8,1998, subject:1998 Refueling Outage Turbine Cross Around Piping Inspections.

V.Y. PIPING FAC INSPECTION PROGRAM 2004 REFUELING OUTAGE INSPECTION REPORT (RFO24- Spring 2004)
ATTACHMENT 1: SUMMARY OF LARGE BORE PIPING UT INSPECTION RESULTS

Inspect. No.	Component ID	DIA (in.)	T _{nom} (in.)	.875T _{nom} (in.)	T _{min} (in.)	2004 Min. T _{meas} (in.)	Wear Rate (in./cycle) Note 2	2005 T _{predicted} Note 3	Passed Screen Level	Approx. Cycles to T _{min} Note 4	Future Inspections Recommended	Comments
2004-01	FD01RD01	16	1.219	1.066	0.965	1.031	0.005	1.025	2	11.0		
		12	1.000	0.875	0.769	0.906	0.005	0.900	1	22.8		
2004-02	FD01EL01	16	1.219	1.066	0.984	1.074	0.005	1.068	1	15.0		
2004-03	FD01TE05	16	1.219	1.066	0.965	1.010	0.005	1.004	2	7.5	2008 RFO	Note 5
2004-04	FD01EL04	16	1.219	1.066	1.090	1.431	0.006	1.423	1	47.4		
2004-05	FD01SP04	16	1.219	1.066	0.965	1.065	0.005	1.059	2	16.7		
2004-06	FD02RD01	16	1.219	1.066	0.965	1.026	0.005	1.020	2	10.2	2011 RFO	
		12	1.000	0.875	0.769	1.052	0.005	1.046	1	47.2		
2004-07	FD02EL01	16	1.219	1.066	0.984	1.187	0.005	1.181	1	33.8		
2004-08	FD02TE01	16	1.219	1.066	0.965	0.986	0.005	0.980	2	3.5*	2007 RFO	Note 5 *See Note 6
2004-09	FD03SP01	16	1.219	1.066	0.965	1.068	0.008	1.058	2	10.2	2011 RFO	
2004-10	FD07SP02	18	1.375	1.203	1.085	1.197	0.014	1.181	2	6.8	2008 RFO	
2004-11	FD07EL03	18	1.375	1.203	1.160	1.385	0.009	1.374	1	20.2		
2004-12	FD14SP08US	16	1.219	1.066	0.965	1.113	0.007	1.105	1	18.7		
2004-13	FD14EL07	16	1.219	1.066	0.965	1.164	0.007	1.155	1	23		Rows 1 to 12
		16	1.219	1.066	0.965	1.021	0.006	1.014	2	5.2	2008 RFO	Row 13, pup piece
2004-14	FD19SP03DS	16	0.844	0.739	0.645	0.789	0.005	0.783	1	24.0		Rows 1,2 US pipe
	FD19TE01	16	1.219	1.066	0.645	0.910	0.005	0.904	1	44.2	CC N560	Row 3
2004-15	FD19RD01	16	1.219	1.066	0.645	1.151	0.005	1.145	1	84.3	CC N560	
		10	0.844	0.739	0.585	0.781	0.005	0.775	1	32.7		
2004-16	FD19SP04	10	0.844	0.739	0.450	0.778	0.005	0.772	1	54.7	CC N560	
2004-17	FD21SP01	10	0.844	0.739	0.460	0.796	0.005	0.790	1	56.0	CC N560	
	FD19TE01	10	0.844	0.739	0.460	0.769	0.005	0.763	1	50.5		Branch FD19TE01

V.Y. PIPING FAC INSPECTION PROGRAM 2004 REFUELING OUTAGE INSPECTION REPORT (RFO24- Spring 2004)
ATTACHMENT 1: SUMMARY OF LARGE BORE PIPING UT INSPECTION RESULTS

<u>Inspect. No.</u>	<u>Component ID</u>	<u>DIA</u> (in.)	<u>T_{nom}</u> (in.)	<u>.875T_{nom}</u> (in.)	<u>T_{min}</u> (in.)	<u>2004 Min. T_{meas}</u> (in.)	<u>Wear Rate</u> (in./cycle) Note 2	<u>2005 T_{predicted}</u> Note 3	<u>Passed Screen Level</u>	<u>Approx. Cycles to T_{min}</u> Note 4	<u>Future Inspections Recommended</u>	<u>Comments</u>
	CD30SP03	24	0.688	0.602	0.472	0.660	0.005	0.654	1	31.3		Rows 1-2
2004-18	CD30TE02	24	0.688	0.602	0.520	0.902	0.005	0.896	1	63.7		Rows 3-10
		20	0.594	0.520	0.440	0.649	0.005	0.643	1	34.8		
2004-19	CD30SP04	24	0.688	0.602	0.472	0.629	0.005	0.623	1	26.2		Rows 11-12
2004-20	CD32SP04	20	0.594	0.520	0.394	0.512	0.005	0.506	2	19.7		New Designation
2004-21	CD32EL02	20	0.594	0.520	0.450	0.601	0.005	0.595	1	25.2		Rows 1-8
		20	0.594	0.520	0.394	0.535	0.005	0.529	1	23.5		Rows 9-10 on Pipe Stub
2004-22	ES1ASP01	12	0.375	0.328	0.180	0.305	0.005	0.299	2	20.8		
2004-23	MSD9TE01 to MSD9TE08	8	0.500	0.438	0.348	0.410	0.005	0.404	2	10.3	2010 RFO	
2004-24	MSD9EL05	8	0.500	0.438	0.380	0.432	0.007	0.424	2	6.5	2010 RFO	
2004-25	MSD9EL06	8	0.500	0.438	0.380	0.468	0.005	0.462	1	14.7		
2004-26	MSD9SP06US	8	0.500	0.438	0.348	0.482	0.005	0.476	1	22.3		

NOTES:

- All thickness values are inches.
- Wear/Cycle is approximately inches/18 months. The wear per cycle was calculated per DP0072 using 17.9 equivalent 18 month cycles based on approx. 157,000 operating hours up to 1996 outage, and 12000 ± hrs./cycle. Minimum Wear/Cycle used to calculate T_{pred} and Cycles to T_{min} is 0.005 inches per cycle.
- 2005 T predicted = 2004 T measured - F.S. * (Wear/Cycle), F.S. = Factor of Safety = 1.20.
- Cycles to T_{min} is calculated from: $\frac{(2004 T_{measured} - T_{min})}{F.S. \times \text{Wear/Cycle}}$ (i.e. Cycles from 2004 RFO)
- Tee is fabricated from a 4 inch diameter Sweepolet installed on a 16 inch section of straight pipe.
- 3.5 cycles to T_{min} based on default wear rate. Actual point to point measurements from 1999 to 2004 indicate no wear.

V.Y. PIPING FAC INSPECTION PROGRAM 2004 REFUELING OUTAGE INSPECTION REPORT (RFO24- Spring 2004)
ATTACHMENT 2 SUMMARY OF SMALL BORE PIPING UT INSPECTION RESULTS

SMALL BORE

Small Bore Inspection Number (Note 1)	Description / Location	Sect.	Size (In.)	Sch	T _{nom.} (Inch)	.875T _{nom} (Inch)	T min. (Inch) (Note2)	2004 Min. Measured Thickness (Inch)	Apparent Wear Rate (Inch/cycle)	Cycles to T _{min.} (Note3)	Comments
04-SB01	2"-1SLBPV Pipe @ ½' Weldolet at No.2 Turbine Bypass Valve.		2	80	.218	.191	.089	.120	0.006	4.3	Note 5
04-SB02	2"-1SLBPV Pipe @ 90 deg. SW elbow @ "C" Cross Around	Horizontal	2	80	.218	.191	.089	.155	0.008	6.9	Note 5
		Vertical	2	80	.218	.191	.089	.204	<0.005	19.2	
04-SB03 (No.98, 92-SB02)	2"-1SLBPV Pipe both sides of 90 deg. SW elbow	E-W run	2	80	.218	.191	.089	.197	<0.005	18	Note 5
		N-S run	2	80	.218	.191	.089	.200	<0.005	18.5	
04-SB04 (No.99, 92-SB03)	2"-1SLBPV @ 2x2x2 S.W. Tee	North	2	80	.218	.191	.089	.194	<0.005	17.5	* Replaced, See Note 4, Note 5
		South	2	80	.218	.191	.089	.097	<0.005	1.3 *	
		West	2	80	.218	.191	.089	.201	<0.005	18.7	
04-SB05	2"-1SLBPV @ 90 deg. SW Elbow	E-W run	2	80	.218	.191	.089	.202	<0.005	18.8	Note 5
		N-S run	2	80	.218	.191	.089	.197	<0.005	18.0	
04-SB06 (No.110, 93-SB49)	2 ½" - 1SPL2, HP Turbine Drain	Vertical	2 ½"	40	.203	.178	.094	0.177	<0.005	13.8	Re-Inspect at pipe bend in 2007 RFO after EPU operation.
		Pipe bend Rows 30 to 34	2 ½"	40	.203	.178	.094	0.143	<0.005	8.2	
		Horizontal	2 ½"	40	.203	.178	.094	0.177	<0.005	13.8	

22

V.Y. PIPING FAC INSPECTION PROGRAM 2004 REFUELING OUTAGE INSPECTION REPORT (RFO24- Spring 2004)
ATTACHMENT 2 SUMMARY OF SMALL BORE PIPING UT INSPECTION RESULTS

SMALL BORE - continued

Small Bore Inspection Number (Note 1)	Description / Location	Sect.	Size (In.)	Sch	Tnom. (Inch)	.875T _{nom} (Inch)	T min. (Inch) (Note2)	2004 Min. Measured Thickness (Inch)	Apparent Wear Rate (Inch/cycle)	Cycles to Tmin. (Note3)	Comments
04-SB07 (No.111, 93-SB50)	2 ½" - 1SPL2	Elbow Rows 1 to 6	2 ½"	40	.203	.178	.094	0.169	<0.005	12.5	
		Horizontal Rows 7 to 38	2 ½"	40	.203	.178	.094	0.174	<0.005	13.3	
04-SB08 (No.112, 93-SB51)	2 ½" - 1SPL2	Pipe Bend Rows 1 to 5	2 ½"	40	.203	.178	.094	0.140	<0.005	7.7	Re-inspect at pipe bend in 2007 RFO after EPU operation.
		Horizontal Rows 6 to 17	2 ½"	40	.203	.178	.094	0.173	<0.005	13.2	
04-SB09 04-SB09A (No.113, 93-SB52, No.114, 93-SB53))	2 ½" - 1SPL2	Pipe Bend Rows 1 to 4	2 ½"	40	.203	.178	.094	0.140	<0.005	7.7	Re-inspect at pipe bend in 2007 RFO after EPU operation.
		Horizontal Rows 5 to 23	2 ½"	40	.203	.178	.094	0.160	<0.005	11	
		Elbow Rows 24 to 28	2 ½"	40	.203	.178	.094	0.177	<0.005	13.8	
04-SB10 (No.115, 93-SB54)	2 ½" - 1SPL2, 2 x 2-1/2" Reducer at 36" CAR	Reducer	2 ½" 2"	40	.203 .154	.178 .135	.094 .089	0.191	<0.005	16.2	
04-SB11	½inch piping at FDW Pump warm up line R.O.	D.S. of R.O.	½"	160	.187	.164	.116	0.190	<0.005	12.3	

NOTES:

- Small Bore Database No. and previous inspection identification are shown in parentheses.
- Tmin includes a 0.065 inch corrosion allowance per ANSI B31.1-1967.
- Cycles to Tmin from 2004 refueling outage. SF (safety factor) = 1.2 was used on the apparent wear rate. Small bore wear is generally not trended for the purposes of repeat inspections. Small bore components will generally be replaced if significant thinning is observed.
- South section was replaced with new C.S. pipe see W.O 03-000084-007.
- Engineering Request No. ER 04-0964 was written to replace the entire carbon steel 1SLBPV line with FAC resistant materials.

V.Y. PIPING FAC INSPECTION PROGRAM 2004 REFUELING OUTAGE INSPECTION REPORT (RFO24- Spring 2004)
ATTACHMENT 3: COMPONENTS RECOMMENDED FOR FUTURE MONITORING

LARGE BORE PIPING

Inspection	Component	Calculated Cycles to Tmin	Recommend Re-inspection RFO	Evaluation / Reasons for Recommendation
2004-03	FD01TE05	7.5	2008RFO	Estimated time for component to wear to code minimum thickness is based on the default wear rate of 0.005 inch/cycle. Time calculated based on multiple inspection point to point measurements indicates at least 12.5 cycles to code minimum wall. Recommended inspection at 2008 RFO is based on consideration of flow changes due to power uprate.
2004-06	FD02RD01	10.2	2011RFO	Estimated time for component to wear to code minimum thickness is based on the default wear rate of 0.005 inch/cycle. Time calculated based on multiple inspection point to point measurements indicates at least 50.8 cycles to code minimum wall. Recommended inspection at 2011 RFO is based on consideration of flow changes due to power uprate.
2004-08	FD02TE01	3.5	2007RFO	Estimated time for component to wear to code minimum thickness is based on the default wear rate of 0.005 inch/cycle. Time calculated based on multiple inspection point to point measurements indicates at least 21 cycles to code minimum wall. Recommended inspection at 2007 RFO is based on consideration of flow changes due to power uprate.
2004-09	FD03SP01	10.2	2011RFO	Initial inspection. Estimated time for component to wear to code minimum thickness is based on a conservative wear rate calculation. Recommendation for re-inspection at approx. ½ time to reach Tmin.
2004-10	FD07SP02	6.8	2008RFO	Initial inspection. Estimated time for component to wear to code minimum thickness is based on a conservative wear rate calculation. Recommendation for re-inspection at approx. ½ time to reach Tmin.
2004-13	FD14EL07 @ DS pup piece	5.2	2008RFO	Initial inspection. Estimated time for component to wear to code minimum thickness is based on a conservative wear rate calculation. Recommendation for re-inspection at approx. ½ time to reach Tmin.
2004-23	MSD9TE01 to MSD9TE08	10.3	2010RFO	Initial inspection. Estimated time for component to wear to code minimum thickness is based on a conservative wear rate calculation. Observed thinning was localized to area below connections of small bore lines. Code min wall based on a conservative design pressure of 1250psi. Recommendation for re-inspection at approx. ½ time to reach Tmin.
2004-24	MSD9EL05	6.5	2010RFO	Initial inspection. Estimated time for component to wear to code minimum thickness is based on a conservative wear rate calculation. Observed thinning was localized to area below connections of small bore lines. Code min wall based design pressure of 1250psi considering this line connects directly into the condenser. Recommendation for re-inspection at approx. prior to time to reach Tmin.

74

V.Y. PIPING FAC INSPECTION PROGRAM 2004 REFUELING OUTAGE INSPECTION REPORT (RFO24- Spring 2004)
 ATTACHMENT 3: COMPONENTS RECOMMENDED FOR FUTURE MONITORING

SMALL BORE PIPING

Inspection	Component	Calculated Cycles to Tmin	Recommend Re-Inspection RFO	Evaluation / Reasons for Recommendation												
04-SB01 04-SB02 04-SB03 04-SB04 04-SB05	1/2" & 1"- 1SLBPV	4.3 Min	NONE	Engineering Request ER 04-0964 was written to replace the 1SLBPV line with FAC resistant material. Additional inspections will only be performed on this line, if the piping is not replaced.												
04-SB06, 04-SB08, 04-SB09A	2-1/2"-1 SPL2	8.2 7.7 7.7	2007RFO	<p>The estimated times shown for locations on this line are constructed of bent piping. The calculated times for components to wear to code minimum thickness is based on the default wear rate of 0.005 inch/cycle. Time calculated based on multiple inspection point to point measurements at the piping bends are as follows:</p> <table border="1"> <thead> <tr> <th>Inspection</th> <th>Time to Tmin DEFAULT</th> <th>Time to Tmin point to point</th> </tr> </thead> <tbody> <tr> <td>04-SB06</td> <td>8.2 cycles</td> <td>27.2 cycles</td> </tr> <tr> <td>04-SB08</td> <td>7.7 cycles</td> <td>18.2 cycles</td> </tr> <tr> <td>04-SB09</td> <td>7.7 cycles</td> <td>53.7 cycles</td> </tr> </tbody> </table> <p>Recommended inspection at 2007 RFO is based on consideration of flow changes due to high pressure turbine modifications, power uprate flows, previous wall thinning of this line a Duane Arnold.</p>	Inspection	Time to Tmin DEFAULT	Time to Tmin point to point	04-SB06	8.2 cycles	27.2 cycles	04-SB08	7.7 cycles	18.2 cycles	04-SB09	7.7 cycles	53.7 cycles
Inspection	Time to Tmin DEFAULT	Time to Tmin point to point														
04-SB06	8.2 cycles	27.2 cycles														
04-SB08	7.7 cycles	18.2 cycles														
04-SB09	7.7 cycles	53.7 cycles														

96

V.Y. PIPING FAC INSPECTION PROGRAM 2004 REFUELING OUTAGE INSPECTION REPORT (RFO24- Spring 2004)
 ATTACHMENT 4: CATALOG OF PHOTOS FROM INTERNAL INSPECTION OF 36 INCH DIAMETER CROSS AROUND PIPING

XX in JPEG FILE NUMBER	36 INCH C.A.R. LINE	Description / Notes
01	D	Looking upstream at bottom of 90degree elbow. Note surface tiger striping and previous surface grinding on bottom plates in elbow and in HAZ of weld from pipe to elbow. Some surface roughness on bottom half of horizontal run.
02	D	Same as 01 above rotated 90 degrees. Note small area adjacent to weld to elbow and longitudinal weld in horizontal pipe.
03	D	Looking downstream at right side of horizontal pipe upstream of manway. General surface roughness on pipe and at weld at manway.
04	D	Looking downstream at right side and top of horizontal pipe upstream of manway. General surface roughness on top of pipe and at weld at manway.
05	D	Looking downstream at center of Herzog cone at inlet to MS-1-1D.
06	D	Close-up of welds on Herzog cone at inlet to MS-1-1D.
07	D	Close-up of welds on Herzog cone at inlet to MS-1-1D.
08	D	Close-up of welds on Herzog cone at inlet to MS-1-1D.
09	D	Looking downstream at bottom right side adjacent to weld to MS 1D inlet. Note previous welds overlay and surface grinding.
10	D	Looking downstream at bottom left side in bore of inlet nozzle to MS 1D inlet. Note extent of previous surface corrosion and previous surface grinding.
11	D	General surface condition on bottom of horizontal pipe upstream of manway. Note roughness.
12	D	General surface condition on left side of horizontal pipe upstream and opposite of manway. Note roughness.
13	D	Looking downstream at left side in bore of inlet nozzle to MS-1-1D. Note extent of previous surface corrosion, previous surface grinding, and localized areas of previous attack.
14	D	Looking downstream at left side of pipe and in bore of inlet nozzle to M-1-1D. Note extent of previous surface corrosion, previous surface grinding, and localized areas of previous attack. Also general surface condition of pipe.
15	C	Looking upstream from manway. Note FME in bottom of pipe from HP turbine modifications. Material was vacuumed out of pipe and CR written to document condition.
16	C	Same as 015 above rotated 90 degrees. Note area of surface roughness along left side of pipe.
17	C	Looking upstream from manway. FME in bottom of pipe from HP turbine modifications was removed. Note area of surface roughness and previous surface grinding along left side of pipe and along bottom longitudinal weld in extrados of elbow.
18	C	Looking downstream from manway. Note area of surface roughness and previous surface grinding along right side of pipe and on extrados of mitered elbow at inlet to MS-1-1C.
19	C	Looking upstream at elbow. Note area of surface roughness and previous surface grinding along left side of pipe and left bottom plate of elbow.
20	C	Looking upstream at elbow. Note area of surface roughness and previous surface grinding on right bottom plate of elbow.
21	C	Looking upstream, close-up of bottom of elbow. Note area of surface roughness and previous surface grinding. Crown of longitudinal weld on extrados of elbow and to downstream pipe has no corrosion surface film.
22	C	Looking upstream, close-up of upper right side plate in 90 degree elbow (intrados). Note area of surface tiger striping along weld to turning vane and at weld to horizontal pipe.
23	C	Looking upstream, close-up upper right side of horizontal pipe downstream of weld to 90 degree elbow. Note extent of localized area of surface roughness.
24	C	Looking upstream, close-up upper trailing edge of turning vane and bottom (extrados) of elbow.

V.Y. PIPING FAC INSPECTION PROGRAM 2004 REFUELING OUTAGE INSPECTION REPORT (RFO24- Spring 2004)
 ATTACHMENT 4: CATALOG OF PHOTOS FROM INTERNAL INSPECTION OF 36 INCH DIAMETER CROSS AROUND PIPING

XX in JPEG FILE NUMBER	36 INCH C.A.R. LINE	Description / Notes
25	C	Looking downstream from manway. Note area of surface roughness and previous surface grinding along right side of pipe and welds and on extrados of mitered elbow at inlet to MS-1-1C.
26	C	Close up of extrados of mitered elbow. (right side of horizontal run). Note area of surface roughness below the equator and previous surface grinding along longitudinal weld and circumferential weld on upstream end of mitered elbow.
27	C	Close up of extrados of mitered elbow. (right side of horizontal run). Note area of surface roughness above the equator on extrados of elbow and on bore of inlet nozzle to MS-1-1C.
28	B	General surface condition on bottom of horizontal pipe upstream of manway. Note roughness.
29	B	Looking upstream, close-up of bottom of 90 degree elbow. Note Previous tiger striping and previous surface grinding over entire area of left side bottom plate (extrados) in elbow.
30	B	Looking upstream, close-up of right side of weld at 90 degree elbow to horizontal pipe. Note surface roughness on upper right side plate in elbow (intrados) and on downstream pipe.
31	B	Looking upstream, close-up of bottom of pipe at weld at 90 degree elbow. Note previous area of surface attack immediately upstream of to horizontal pipe. Note surface roughness on bottom surface of pipe.
32	B	Looking upstream, close-up of hole bored in left side of horizontal pipe downstream of 90 degree elbow. Hole is for small bore nozzle used in turbine performance testing. Note general surface condition of pipe.
33	B	Looking upstream, close-up of top left half (intrados) of 90 degree elbow. Note extent of surface tiger striping over entire area of the top left side plate (intrados) in elbow. Also surface roughness on upper surface of turning vane.
34	B	Looking upstream to vertical drop, in intrados of 90 degree elbow (go into top half of elbow). Note local area of surface corrosion on upper left side of intrados adjacent to the longitudinal weld.
35	B	Looking downstream on left side of horizontal pipe just opposite and upstream from manway. Localized area of previous surface corrosion and previous surface grinding along longitudinal weld on left side of pipe.
36	B	Looking downstream on right side of horizontal pipe upstream from manway. Localized area of previous surface corrosion and previous surface grinding along longitudinal weld on right side of pipe.
37	B	Same area described in photo 35 above.
38	B	Looking downstream in horizontal pipe upstream from manway. Localized area of previous surface roughness opposite manway above equator. Note PPE for on large engineer for future inspections (PCs, Safety harness, ropes and oxygen monitor. Knee pads are recommended).
39	B	Looking into 12 inch diameter connection for line 12 ^o -ES-1B. 12 inch piping is chrome-moly. Note fit up miss-match at bottom of 12 inch pipe for future inspections.
40	B	Looking downstream in horizontal pipe opposite from manway. Localized area of previous surface roughness and surface grinding.
41	B	Looking downstream of horizontal pipe bottom surface upstream of inlet to MS-1-1B. Localized area of previous surface roughness and surface grinding at bottom center and along circumferential weld at mitered elbow.
42	B	Looking downstream at right side of horizontal pipe and intrados of mitered elbow at equator of pipe. Note localized area of previous surface corrosion and surface grinding upstream of weld from pipe to elbow.
43	B	Looking downstream at right side of horizontal pipe and intrados of mitered elbow below equator of pipe. Note localized area of surface roughness.
44	A	Looking upstream at right side of horizontal pipe upstream of manway. Note extent of previous internal weld repairs and surface grinding on pipe and upstream elbow.

V.Y. PIPING FAC INSPECTION PROGRAM 2004 REFUELING OUTAGE INSPECTION REPORT (RFO24- Spring 2004)
 ATTACHMENT 4: CATALOG OF PHOTOS FROM INTERNAL INSPECTION OF 36 INCH DIAMETER CROSS AROUND PIPING

XX in JPEG FILE NUMBER	36 INCH C.A.R. LINE	Description / Notes
45	A	Looking upstream at right side of horizontal pipe and 90 degree elbow. Note extent of previous internal weld repairs and surface grinding on pipe. Also note extent of previous surface grinding in elbow at bottom extrados and both top and bottom right side plates.
46	A	Looking upstream into 12 inch diameter connection for line 12"-ES-1A. 12 inch piping is chrome-moly EXCEPT for C.S. pup piece approx. 5 inches long shown between welds in photo. Note fit up miss-match at bottom and left side of 12 inch pipe for future inspections. Also note previous weld repair and surface grinding at left side of 12 inch opening and general surface condition of 36 inch pipe.
47	A	Looking downstream at top left side of entrance to MS-1-1A. Note localized area of previous surface corrosion and surface grinding in bore of nozzle and general condition of circumferential weld.
48	A	Looking downstream at right side of pipe at entrance to MS-1-1A. Note previous weld repair and surface grinding.
49	A	Looking downstream at top of pipe at entrance to MS-1-1A. Note previous surface grinding and general condition of piping upstream of circumferential weld.
50	A	Looking downstream at bottom left side of Herzog cone at inlet to MS-1-1A. Note condition of fillet welds.

- Notes:
1. Pictures are in JPEG format. File names on CD are "RFO24picturexx.JPG" where "xx" is in column 1 above.
 2. In descriptions above, directions for orientation are given looking downstream (i.e. left side of pipe means looking downstream on left side on interior surface).
 3. Reference VY drawings 5920-0150 Sheets 1 & 2 for piping arrangement. And 5920-6841 Sheet 1 of 2 for spool piece details.

82



Entergy

ENN
NUCLEAR
MANAGEMENT
MANUAL

QUALITY RELATED
ADMINISTRATIVE PROCEDURE

INFORMATIONAL USE

ENN-DC-147 Revision 3

Page 15 of 15

ATTACHMENT 9.3

TECHNICAL REVIEW COMMENTS AND RESOLUTION FORM



Entergy

ENN Site Applicability: IP1 IP2 IP3 JAF PNPS VY

Engineering Report

Technical Review Comments and Resolutions Form

Engineering Report
Number:

VY-RPT-04-
00010

Rev.
0

Title: Vermont Yankee Piping Flow Accelerated Corrosion
Inspection Program (PP 7028), 2004 Refueling
Outage Inspection Report (RFO 24 - Spring 2004)

Quality Related: Yes No

Special Notes or Instructions: None

Comment Number	Section/ Page No.	Review Comment	Response/Resolution	Responsible Engineer's Accept Initials
1	5.1/6	Percentages of components	Incorp'd.	JLH
2	Attach. 1	Inspect. No. 2004-09 adjust Tpred.	Incorp'd.	JLH
3	Attach. 1	Notes, 17.9 equivalent cycles	Incorp'd.	JLH
4	Attach. 2	Inspect. No. 04-SB06, adjust Cycles to Tmin.	Incorp'd.	JLH
5	Attach. 2	Inspect. No. 04-SB09, adjust Tmeas.	Incorp'd.	JLH

Reviewed/ Verified By:

T. M. O'Connor

Date: 2-15-05

Site/Department:

VY/MSD

Phone: x3092

VY-RPT-04-00010 REV. 0

79

PM 4E 20 0520

Engineering Report No. VY-RPT-06-00002 Rev. 0

Page 1 of 19



ENTERGY NUCLEAR
Engineering Report Cover Sheet

Engineering Report Title:

VERMONT YANKEE PIPING FLOW ACCELERATED CORROSION
INSPECTION PROGRAM (PP 7028)
2005 REFUELING OUTAGE INSPECTION REPORT
(RFO 25- Fall 2005)

Engineering Report Type:

New Revision Cancelled Superseded

Applicable Site(s)

IP1 IP2 IP3 JAF PNPS VY WPO
ANO1 ANO2 ECH GGNS RBS WF3

DRN No. N/A;

(5) Report Origin: Entergy Vendor
Vendor Document No.: N/A

(6) Quality-Related: Yes No

Prepared by: James C. Fitzpatrick
Responsible Engineer (Print Name/Sign)

Date: 5/8/06

Verified/
Reviewed by: Thomas M. O'Connor
Design Verifier/Reviewer (Print Name/Sign)

Date: 5/9/06

Reviewed by:* N/A
Authorized Nuclear In-service Inspector (ANII)

Date: N/A

Approved by: Scott D. Goodwin
Supervisor (Print Name/Sign)

Date: 5-15-06

*: For ASME Section XI Code Program plans per ENN-DC-120, if required.

EN-DC-147 Rev.0 Engineering Report

No. VY-RPT-06-00002

REVISION SUMMARY

<u>Revision No.</u>	<u>Description of Change</u>	<u>Reason for Change</u>
0	Original Report	N/A

TABLE OF CONTENTS

Section	Description	Page No.
	Engineering Report Cover Sheet (ENN-DC-147 Att.9.1)	1
	REVISION SUMMARY	2
	TABLE OF CONTENTS	3
1.0	EXECUTIVE SUMMARY	4
2.0	SCOPE / PURPOSE	5
3.0	ASSUMPTIONS	5
4.0	2005 REFUELING OUTAGE INSPECTION PLAN	6
5.0	EVALUATION OF INSPECTION RESULTS	7
5.1	Large Bore Piping	7
5.2	Turbine Cross Around Piping	8
5.3	Small Bore Piping	9
5.4	Feedwater Heater Shells	9
6.0	COMPONENTS REQUIRING FUTURE MONITORING	10
7.0	COMPONENTS REQUIRING POSSIBLE REPAIR OR REPLACEMENT	10
8.0	CONCLUSIONS / RECOMMENDATIONS FOR FUTURE FAC INSPECTIONS	11
9.0	REFERENCES	12
ATTACHMENT 1:	SUMMARY OF LARGE BORE PIPING UT INSPECTION RESULTS	13-15
ATTACHMENT 2:	SUMMARY OF SMALL BORE PIPING UT INSPECTION RESULTS	16-17
ATTACHMENT 3:	COMPONENTS RECOMMENDED FOR FUTURE MONITORING	18-19

1.0 EXECUTIVE SUMMARY

External UT measurements were taken on 27 large bore piping components in the Feedwater, Condensate, and Main Steam Systems. External UT inspections were performed on 5 sections of carbon steel small bore piping in the condensate and control rod drive systems. Internal visual inspections of the turbine cross around piping were performed in the A and C 36 inch diameter lines and in the B 30 inch diameter line. The inspections were performed under EMPAC Work Order 04-004983.

Component selection was based on a combination of; previous inspection data, industry events, analyses using the EPRI developed CHECWORKS computer code, and the consequences of component failure. A detailed selection process was used and was documented in reference (4).

The large bore and small bore inspection results were evaluated using a three level screening process defined in plant procedure DP 0072. All components inspected were found to have a wall thickness greater than the code minimum wall thickness. The predicted thickness at the next refueling outage was greater than the code minimum wall thickness for all components. No large bore piping components required repair or replacement during the refueling outage. Remaining service life (RSL) calculations based on the UT inspection data have been factored to account for a 20% extended power uprate commencing in March 2006.

A summary of the large bore piping component screening is contained in Attachment 1. Attachment 2 contains a summary of the small bore piping inspection results.

Section 6.0 discusses the criteria used to screen components as requiring future monitoring. Attachment 3 contains a summary of piping components recommended for future inspections.

No components inspected in RFO 25 required repair or replacement. ER 04-0964 was implemented outside the scope of this program to replace piping previously recommended for replacement in RFO 24, reference(9).

Section 8.0 contains conclusions and recommendations for future FAC Inspections. There were no immediate operability concerns as the result of FAC inspections performed during RFO25.

Components on the SSH and SPE lines scheduled for inspection in RFO25 and were de-scoped due to higher priority LP turbine work in the same location. These locations should be inspected in RFO 26.

2.0 SCOPE / PURPOSE

Each refueling outage, ultrasonic thickness (UT) measurements and/or internal visual inspections are performed on plant piping per the Vermont Yankee Piping Flow Accelerated Corrosion (FAC) Inspection Program, PP 7028, reference (1). For RFO 25, the inspections, scaffolding installation, insulation removal, and surface preparation activities were performed under EMPAC Work Orders 04-004983-000 to 04-004983-010.

This report summarizes the results of the inspections performed during Fall 2005 Refueling Outage (RFO 25).

3.0 ASSUMPTIONS

There are no assumptions.

4.0 2005 REFUELING OUTAGE INSPECTION PLAN

The 2005 refueling outage inspection scope was developed to satisfy the following goals:

- Inspection of large bore components, requiring or recommended for follow up inspections, based on UT data from previous refueling outages.
- Inspection of components identified by the EPRI CHECWORKS computer code as being ranked high for susceptibility to wear and/or having the least time remaining to reach code minimum wall thickness.
- Perform repeat inspections and new inspections on selected large bore components for calibration of the CHECWORKS models.
- To incorporate industry experience into the program through inspection of components at VY that are similar to those that have either failed or showed significant wall thinning at other plants. During the 2005 RFO, inspections were performed on piping at and downstream of flow elements in the condensate system in response to the Mihama event, reference (12).
- Perform an internal visual inspection of two of the four 36" turbine cross around lines exiting the high pressure (HP) turbine. The HP turbine modifications performed in RFO 24 were for power uprate flows. These inspections were to verify the condition on the piping as documented in reference (14), given the new HP turbine was operated for one full cycle off its peak efficiency. Also the last remaining carbon steel 30 inch line was inspected to confirm its condition prior to power uprate flows.
- Inspection of selected small bore components contained in the Small Bore Database which have not had an initial inspection and/or identified through review of industry operation experience (OE).
- Inspection of Large bore piping components subjected to off normal flow conditions, such as components downstream of normally closed valves which connect directly to the condenser. These components are typically identified by the cognizant Systems Engineer, using the turbine performance monitoring system. The feedwater pump recirc lines were inspected during RFO 25.
- Inspect piping components identified as having the largest change in projected wear rate under EPU conditions to obtain current pre-EPU conditions. Component selection was based primarily on the increased velocity. Piping downstream of the Feedwater Reg valve FCV-6-12B was selected for inspection.
- Inspect components based on leaks at VY. Inspections on the Turbine Steam Seal header (SSH) and the Steam Packing Exhauster (SPE) lines to determine the extent of condition for CR-VTY-2004-02985, reference (13).

The planned duration for RFO 25 FAC activities was approximately 10 days. Given the shorter duration consideration was given to optimizing the locations and number of components to be inspected, and also to be consistent with previous outage inspection efforts. The detailed reasoning for component selection is contained in the Inspection Location Worksheets, reference (4). The complete planned scope for RFO 25 is contained in reference (5).

5.0 EVALUATION OF INSPECTION RESULTS

5.1 Large Bore Piping

YFO 27

The planned large bore piping inspection scope for RFO 25 included external UT exams on (37) large bore piping components at sixteen locations on the Feedwater, Condensate, Main Steam, Turbine Steam Seal, and Steam Packing Exhauster Systems. Planned inspections on the turbine Steam Seal header (SSH) and the Steam Packing Exhauster (SPE) lines to determine the extent of condition for CR-VTY-2004-02985 were "de-scoped" from the 2005 RFO due to higher priority LP turbine work in the same location. A total of 27 large bore components were inspected using external UT.

The thickness data were evaluated using a three level screening process as defined in procedure, DP 0072. The UT inspection results for each component were reviewed for anomalies and consistency with piping geometry. Wear rates (wear/cycle) were calculated for each component using methods specified in DP 0072, and are consistent with NSAC-202L, reference (6). The calculated wear rates for piping components which experience flow during normal operation were increased by a factor of 1.25 to account for a 20% extended power update (EPU) commencing in March 2006. The 1.25 factor is to envelope possible increases in wear rates due to the increased EPU flow velocities. The larger of the factored wear rate or a minimum wear rate of 0.005 inches/cycle was used in the trending projections.

Using the calculated wear rates and the 2005 measured thickness, the predicted thickness at the end of the next cycle (2007 Tpred) was calculated using a safety factor of 1.2 on the calculated wear per cycle. Using both the wear rate and 2005 measurement data, the Remaining Service Life (RSL) for each component was calculated. The RSL is the projected number of cycles beyond the Fall 2005 refueling outage (RFO25) for each component to wear down to the code minimum wall thickness.

Components passing the Level 1 screen have 2007 Tpred greater than $.875T_{nom}$ (the manufacturing tolerance of new piping) and require no further evaluation. The Level 2 screen is for components with 2007 Tpred less than $.875T_{nom}$ but greater than T_{min} (the code minimum wall thickness to resist pressure and mechanical loads). These components are acceptable for continued operation but future monitoring may be recommended. The Level 3 screening is for components with 2007 Tpred less than T_{min} . The Level 3 screening is a detailed analytical methodology. It also requires that additional piping components be inspected this outage (sample expansion), and considered for inspection during future refueling outages.

All components inspected were found to have wall thickness greater than code minimum wall thickness. All predicted wall thickness (at the 2007 refueling outage) values were above code minimum wall thickness. Of the 27 large bore piping components inspected, 16 (59%) passed the Level 1 screen, and the remaining 11 (41%) passed the Level 2 screen. A summary of the large bore piping component screening is contained in Attachment 1.

No large bore repairs or replacements were required. Two components which experience continuous flow in the Feedwater system were recommended for future monitoring. These are discussed in Section 6.0 of this report. Additional discussion on monitoring of the carbon steel sections of the Feedwater Pump Recirc. lines, and inspection of components removed from the inspection scope in 2005 are included in Section 6.0.

5.2 Turbine Cross Around Piping

36 Inch Diameter Lines A & C :

Internal visual inspections in two of the four 36" turbine cross around lines exiting the HP turbine were performed. The HP turbine modifications performed in RFO 24 were for power uprate flows. The plant was operated for one full operating cycle at Current Licensed Thermal Power (CLTP), which is off the HP turbine peak efficiency. These inspections were to verify the condition of the piping as documented in Attachment 4 of the 2004 FAC Inspection Report, reference(14). Internal inspection of the 36"A line included the visual inspection of a section of 12 inch diameter carbon steel pipe on line 12-ES-1A stub piece visible from inside the 36"A line.

Comparison of the internal condition of the 36 inch A and C lines with photos contained Attachment 4 of reference (14) showed only one discernable difference. A localized section on the bottom portion of the 36" C line contained a circular area of ferrous oxide centered directly under the 2 inch diameter connection for the turbine bypass valves common 1st seal leakoff line. The oxide was reddish in color, and tightly adhering to the inside surface of the pipe. No localized wall loss was noted in the 36" C piping.

The entire carbon steel Turbine Bypass Valve Chest 1st Seal Leakoff line, 1SLBPV, was replaced with Chrome-Moly material in RFO25, reference(9). Two local sections on this line were replaced with carbon steel in RFO 24. The sources of the corrosion products in the bottom of 36" C line are suspected to be the initial internal surface corrosion products from the partial small bore replacements, which were scoured off the small bore sections and deposited in the bottom of the 36" C line. Two plant trips which occurred during the cycle would result in high flows from the turbine bypass valves seals to the 36" C cross around line.

No areas of active corrosion were identified in either the 36" A or 36"C line.

30 Inch Diameter Line B:

The 30 inch diameter B line is the only remaining original carbon steel line. The other three lines have been completely replaced with Chrome-Moly material (P22) which has been demonstrated to be resistant to FAC damage. A partial internal visual inspection of the north end of the B 30 inch diameter cross around line on the east side of the turbine was performed to confirm the internal condition of the line prior to operation under EPU flows. Only the north end of the line near the manway was inspected due to lack of an open airway for internal ventilation from the south end of the line.

The interior of the line generally appears the same as observed in 1999 and 2002. The extent of areas of red/black oxide identified in previous inspections is essentially the same. Markings on the interior of the pipe to identify the 1995 inspection/repair locations and the 1996 UT locations are still visible. These are evidence that there is no significant wall loss occurring in the north end of the line under current power flows and Moisture Separator (MS) efficiency.

Increased steam flows under EPU conditions may cause a reduction in MS efficiency and result in a decrease in the steam quality in the 30 inch CAR piping. Any significant reduction in steam quality could result in resumption of FAC damage to the carbon steel line. The efficiency of the Moisture Separators can only be confirmed by testing at EPU flows. Unless a test to confirm MS efficiency is performed to determine steam quality it is prudent to perform a complete Internal Inspection of the 30" B line in RFO26. Also reference (8) should be revised to reflect the increase in design pressure from 269psi. to 300psi. for EPU conditions.

5.3 Small Bore Piping

Five sections of small bore piping were scheduled for external UT inspection during the 2005 refueling outage. All inspections were first time inspections. All were selected based on industry Operating Experience (OE) with wall loss downstream of flow orifices, reference (11).

No significant wear was found in the small bore piping inspected. All projected remaining service life (RSL) values are greater than the life of the plant (including a projected 20 year license renewal period). A summary of the small bore piping inspection results is contained in Attachment 2. No recommendations for future inspections were made for small bore piping.

5.4 Feedwater Heater Shells

All four HP feedwater heaters were replaced during RFO 24. All ten feedwater heater shells have been replaced with either chrome-moly or stainless steel materials. There are no planned UT inspections for the feedwater heater shells in the near term.

6.0 COMPONENTS REQUIRING FUTURE MONITORING

Large bore components requiring future monitoring are identified using the predicted thickness at the next refueling outage (2007 $T_{\text{Predicted}}$), the "Screening Level" which the component passed, and the "RSL", the approximate Cycles to T_{min}, shown in Attachment 1. From the wear rates and cycles to T_{min} calculated in Attachment 1, only one component in piping with continuous flow, was identified with less than 10 cycles to T_{min}. Re-inspection was recommended for this component and the adjacent downstream component. See Attachment 3 for a detailed description.

The carbon steel piping component connecting to and adjacent to the condenser on the Reactor Feedwater Pump Recirculation lines have experienced some degree of wall loss due to past flows through normally closed valves. The upstream piping has been replaced with A335 P11 Chrome-Moly piping. During normal operation there is no flow in these lines. No current leakage is indicated since the upstream FCV repairs were performed during RFO24. This piping was inspected to determine if past leakage has caused wear since the last inspections and to insure the condition of the piping for Extend Power Uprate conditions. The Thermal Performance Monitoring (TPM) system will be used to determine if flow is occurring in this pipe during normal operation. The Thermal Performance Monitoring (TPM) system will be used as a trigger to determine if future inspections are required.

The 2005 refueling outage inspection results will be incorporated into the existing CHECWORKS models. The 2005 inspection data along with data from previous inspections will be used to refine the wear rate predictions. The results shown in Attachment 1 and the updated CHECWORKS analyses will be used to determine the inspection scope for future refueling outages.

Planned inspections on the turbine Steam Seal header (SSH) and the Steam Packing Exhauster (SPE) lines to determine the extent of condition for CR-VTY-2004-02985 CA 03 were "de-scoped" from the 2005 RFO due to higher priority LP turbine work in the same location. These inspections should be performed in RFO26.

No small bore components inspected in RFO 25 require future monitoring.

Increased steam flows under EPU conditions may cause a reduction in Moisture Separator efficiency and result in a decrease in the steam quality in the 30 inch CAR piping. Any significant reduction in steam quality could result in resumption of FAC damage to the CS line. Unless a test to confirm MS efficiency is performed to determine steam quality it is prudent to perform a complete internal inspection of the 30" B line in RFO26.

7.0 COMPONENTS REQUIRING POSSIBLE REPAIR OR REPLACEMENT

No specific large bore components or small bore components were identified as requiring repairs or replacements during RFO 25.

8.0 CONCLUSIONS / RECOMMENDATIONS FOR FUTURE FAC INSPECTIONS

There were no immediate operability concerns as the result of FAC inspections performed during RFO25.

Based on results from the RFO 25 inspections, no new immediate or near term repairs or replacements are required. ER 04-0964, reference(9), replaced small bore line 1SLBPV piping which has experienced through wall leaks in the past and eliminates any need for repeat inspections on this line.

Inspection data taken this outage will serve as part of the baseline data prior to operation with the increased flows from power uprate.

Data from repeat inspections of large bore components in the Feedwater System which experience continuous flow shows essentially no wear is occurring under CLTP flow conditions. Measured differences are within the tolerances of the UT equipment (+/- 0.004 inch).

Wear rates calculated from a single (initial) UT inspection using the EPRI recommended methods from reference (2) & (6) in single phase system piping (Condensate and Feedwater) have proven to be conservative when compared to components with multiple inspections.

Components on the SSH and SPE lines scheduled for inspection in RFO25 and were de-scoped due to higher priority LP turbine work in the same location. These locations should be inspected in RFO 26.

A complete internal inspection of the 30" B turbine cross around line should be performed in RFO26.

Reference (8) is a contingency calculation used prior to 1995 pipe repair and moisture separator internal replacement efforts for acceptance criteria for as-found wall loss in the 30 inch diameter carbon steel turbine cross around lines. The calculation should be revised to reflect the increase in design pressure from 269psi. to 300psi. for EPU conditions for the CAR piping.

9.0 REFERENCES

1. V.Y. Program Procedure PP 7028, Piping Flow Accelerated Corrosion (FAC) Inspection Program, Original Issue 5/10/01 with LPC 1 dated 12/06/01.
2. V.Y. Department Procedure, DP 0072, "Structural Evaluation of Thinned Wall Piping Components", Original Issue 5/17/01, with LPC 1 dated 10/02/01.
3. ENN-NDE-9.05, Revision 0, Ultrasonic Thickness Examination
4. V.Y. Piping FAC Inspection Program – 2005 Refueling Outage: Inspection Location Worksheets / Methods and Reasons for Component Selection, revised 3/1/05.
5. ENVY Memo: J.C.Fitzpatrick to S.D.Goodwin, subject: Piping FAC Inspection Scope for the 2005 Refueling Outage (Revision 1a), VYM 2004/007a, dated 5/1/05.
6. EPRI Report, "Recommendations for an Effective Flow-Accelerated Corrosion Program", EPRI NSAC-202L-R2, April 1999.
7. CHECWORKS - Computer Program User Guide, TR 103496, August 1994 by Altos Engineering Applications Inc. for EPRI.
8. VY Calculation No. VYPC 92-004, Rev. 0, "Turbine Cross Around Piping Wall Thinning Evaluation"
9. Engineering Request ER 04 -0964, "Replace Turbine Bypass Valve Chest 1st Seal Leakoff Piping 1SLBPV"
10. VY Design Engineering - Bolton MEMO: J.C. Fitzpatrick to D.Girroi(VY-ISI), VYM 98/91, dated May 8,1998, subject:1998 Refueling Outage Turbine Cross Around Piping Inspections.
11. INPO OE17654, "Potential Trend for Adverse Equipment Conditions Downstream of Orifices" Clinton Power Station, January 16, 2004)
12. INPO OE19368/OE18895: Mihama 3 – PWR, 8/9/2004 Rupture of Condensate line downstream of restriction orifice.
13. CR-VTY-2004-02985, Through wall leaks in the Turbine Steam Seal Header Piping. (Corrective Action: CA-03 for additional inspections)
14. VY-RPT-04-00010, Revision.0 , " Vermont Yankee Piping Flow Accelerated Corrosion Inspection Program (PP 7028) 2004 Refueling Outage Inspection Report (RFO 24)"

V.Y. PIPING FAC INSPECTION PROGRAM 2005 REFUELING OUTAGE INSPECTION REPORT (RFO25- Fall 2005)
 ATTACHMENT 1: SUMMARY OF LARGE BORE PIPING UT INSPECTION RESULTS

LARGE BORE

Inspect. No.	Component ID	DIA (in.)	T _{nom} (in.)	.875T _{nom} (in.)	T _{min} (in.)	2005 Min.T _{meas} (in.)	Wear Rate (in./cycle) Notes 2,3	Factored Wear Rate for EPU Note 4	2007 T _{predicted} Note 5	Passed Screen Level Note 6	(RSL) Note 7	Comments / Future Inspections Recommended	
2005-01	FD14EL03	16	1.219	1.067	0.964	1.169	0.0003	0.005	1.163	1	34.1		
2005-02	FD14SP03US	16	1.219	1.067	0.964	1.052	0.0000	0.005	1.046	2	14.6	Row 1 at counterbore; using default wear rate	
		16	1.219	1.067	0.964	1.205	0.0000	0.005	1.199		40.1	Rows 2-8	
2005-03	FD04RD01	4	0.438	0.383	0.248	0.318	0.0080	*0.0080	0.306	2	*5.7	*Note 8, No flow at normal operation.	
		6	0.562	0.492	0.215	0.436	0.0103	*0.0103	0.426		*23.0		
2005-04	FD04TE01	Run	6	0.562	0.492	0.246	0.553	0.0148	*0.0148	0.535	2	*17.3	
		Branch	6	0.562	0.492	0.246	0.462	0.0215	*0.0215	0.436		*8.2	
		End Cap	6			0.151	0.370	0.0055	*0.0055	0.363			
2005-05	Cond Noz 32A	6	0.562	0.492	0.215	0.348	0.0103	*0.0103	0.336	2	*10.8		
2005-06	FD05RD01	4	0.438	0.383	0.246	0.340	0.0074	*0.0074	0.331	2	*10.6	*Note 8, No flow at normal operation.	
		6	0.562	0.492	0.215	0.448	0.0074	*0.0074	0.439		*26.2		
2005-07	FD05TE01	Run	6	0.562	0.492	0.246	0.461	0.0124	*0.0124	0.446	2	*14.4	
		Branch	6	0.562	0.492	0.246	0.623	0.0060	*0.0060	0.616		*52.4	
		End Cap	6			0.151	0.347	0.0069	*0.0069	0.339			
2005-08	Cond Noz 32B	6	0.562	0.417	0.215	0.417	0.0060	*0.0060	0.410	2	*28.8		
2005-09	FD06RD01	4	0.438	0.383	0.163	0.308	0.0070	*0.0070	0.300	2	*17.3	*Note 8, No flow at normal operation.	
		6	0.562	0.492	0.227	0.419	0.0053	*0.0053	0.413		*30.1		
2005-10	FD06TE01	Run	6	0.562	0.492	0.246	0.684	0.0098	*0.0098	0.672	1	*32.2	
		Branch	6	0.562	0.492	0.246	0.539	0.0050	*0.0050	0.533		*48.8	
		End Cap	6			0.151	0.270	0.0050	*0.0050	0.264			
2005-11	Cond Noz 32C	6	0.562	0.492	0.215	0.352	0.0110	*0.0110	0.338	2	*10.4		

V.Y. PIPING FAC INSPECTION PROGRAM 2005 REFUELING OUTAGE INSPECTION REPORT (RFO25- Fall 2005)
ATTACHMENT 1: SUMMARY OF LARGE BORE PIPING UT INSPECTION RESULTS

Inspect. No.	Component ID	DIA (in.)	T _{nom} (in.)	.875T _{nom} (in.)	T _{min} (in.)	2005 Min. T _{meas} (in.)	Wear Rate (in./cycle) Notes 2,3	Factored Wear Rate for EPU Note 4	2007 T _{predicted} Note 5	Passed Screen Level Note 6	(RSL) Note 7	Comments / Future Inspections Recommended
2005-12	FD08RD03	10	0.844	0.739	0.740	0.794	0.002	0.005	0.788	1	9.0	
		18	1.375	1.203	1.085	1.254	0.002	0.005	1.248		28.2	
2005-13	FD08SP02	18	1.375	1.203	1.085	1.191	0.000	0.005	1.185	2	17.7	Row 1 at counterbore, using default wear rate
		18	1.375	1.203	1.085	1.301	0.000	0.005	1.295		36.0	Rows 2-12
	FD12SP07US	18	1.375	1.203	1.085	1.248	0.004	0.0050	1.242	1	27.2	
2005-14	FD12EL06	18	1.375	1.203	1.085	1.379	0.007	0.0088	1.368	1	27.8	
2005-15	FD12SP08US	18	1.375	1.203	1.085	1.216	0.0084	0.0105	1.203	1	10.4	Row 1 at counterbore
		18	1.375	1.203	1.085	1.278	0.0051	0.0064	1.270		25.1	Rows 2 to 5
2005-16	CD30FE01	20	*0.812	0.711	0.394	0.839	0.0018	0.005	0.833	1	74.2	*Note 9
2005-17	CD30EL11	20	0.594	0.520	0.394	0.689	0.001	0.005	0.683	1	49.2	
2005-18	CD30SP12	20	0.594	0.520	0.394	0.553	0.002	0.005	0.547	1	26.5	
2005-19	CD31FE01	20	*0.812	0.711	0.394	0.764	0.0035	0.005	0.758	1	61.7	*Note 9
2005-20	CD31EL04	20	0.594	0.520	0.394	0.677	0.0083	0.0104	0.665	1	22.7	
2005-21	CD30SP04	20	0.594	0.520	0.394	0.5480	.003	0.005	0.542	1	25.7	
2005-22	CD21RD02	6	0.280	0.245	0.146	0.232	0.0096	0.0120	0.218	2	5.97	Note 10
		14	0.375	0.328	0.276	0.352	0.0029	0.005	0.346		12.7	
2005-23	CD21RD01	6	0.280	0.245	0.146	0.256	0.0051	0.0064	0.248	1	14.3	Note 10
		14	0.375	0.328	0.276	0.353	0.0028	0.005	0.347		12.8	
	MS1DSP12DS	18	0.938	0.820	0.726	0.935	0.0010	0.0013	0.929	1	34.8	
2005-36	MS1DEL07	18	0.938	0.820	0.726	0.974	0.0053	0.0067	0.966	1	30.8	
2005-37	MS1DSP13US	18	0.938	0.820	0.726	0.905	0.004	0.005	0.899	1	29.8	

V.Y. PIPING FAC INSPECTION PROGRAM 2005 REFUELING OUTAGE INSPECTION REPORT (RFO25- Fall 2005)
ATTACHMENT 1: SUMMARY OF LARGE BORE PIPING UT INSPECTION RESULTS

NOTES:

1. All thickness values are inches.
2. Wear/Cycle is approximately inches/18 months. The wear per cycle was calculated per DP0072 using 18.9 equivalent 18 month cycles based on approx. 157,000 operating hours up to 1996 outage, and 12000 \pm hrs./cycle.
3. Minimum Wear/Cycle used to calculate T_{pred} and Cycles to T_{min} is 0.005 inches per cycle.
4. Factored Wear Rate to account for EPU flows = 1.25 x calculated wear rate or 0.005 in/cycle whichever is less larger
5. 2007 T predicted = 2005 T measured - F.S. * (Factored Wear Rate/Cycle), F.S. = Factor of Safety = 1.20.
6. Highest screening level for the entire piping component. For example when multiple areas of a component such as the small end & large end of a piping reducer are evaluated, the highest screening level for either end the component governs.
7. Remaining Service Life = Cycles to T_{min} is calculated from: $\frac{(2005 T \text{ measured} - T_{min})}{F.S. \times \text{Factored Wear Rate / Cycle}}$ (i.e. Cycles from 2005 RFO)
8. During normal operation there is no flow in these lines. No current leakage is indicated since the upstream FCV repairs were performed during RFO24. This piping was inspected to determine if past leakage has caused wear since the last inspections and to insure the condition of the piping for Extend Power Uprate conditions. Wear rates were calculated on a per cycle basis, actual wear rates per cycle may be higher if leakage past the normally closed FCVs occurs. The Thermal Performance Monitoring (TPM) system will be used to determine if flow is occurring in this pipe during normal operation. The Thermal Performance Monitoring (TPM) system will be used as a trigger to determine if future inspections are required.
9. Condensate flow element fabricated from schedule 60 pipe vs. the schedule 40 specification for Condensate piping. Ends are machined to Sch. 40 for fit up to piping. Reference Drawing 5920-5141.
10. Reducers are upstream and downstream of FCV -4 which is the hot well makeup & dump. This line is used only at low feedwater flows, typically during startup. Inspections were performed due to suspected cavitation in or near the control valve. Calculated wear rates based on a single inspection using the EPRI Band Method are conservative.

V.Y. PIPING FAC INSPECTION PROGRAM 2005 REFUELING OUTAGE INSPECTION REPORT (RFO25- Fall 2005)
 ATTACHMENT 2: SUMMARY OF SMALL BORE PIPING UT INSPECTION RESULTS

SMALL BORE

Small Bore Inspection Number (Note 1)	Description / Location	Sect.	Size (in.)	Sch	Tnom. (inch)	.875T _{nom} (inch)	T min. (inch) (Note2)	2005 Min. Measured Thickness (inch)	Apparent Wear Rate (inch/cycle) (Note 3)	Cycles to Tmin. (Note5)	Comments
05-SB01 (119)	1" piping DS of R.O. 64-2 Condensate system TB Heater bay (Small bore Data base Point 119)	DS of RO to V64-15	1	80	.179	.157	0.072	0.150	0.002	32.5	Note 4
		DS V64-15 toward the condenser						0.158 0.180 0.176	0.0014 0.000 0.0002	>50	Note 4
		US of RO to V64-20	1	80	.179	.157	0.091	0.186 0.176 0.178	0.000 0.0002 0.0001	>50	
		DS of V64-20 to V64-22						0.178	0.0001	>50	
		DS of V64-22 toward the ECCS keep fill system						0.177 0.180 0.170	0.0001 0.000 0.0005	>50	
05-SB02 (128)	CRD PUMP Min Flow Line DS of R.O. 3-24A (Smallbore Data Base Point 128)	DS RO to V3-37A	1	160	.250	.218	0.072	0.182	0.0036	25	Original, Sch 160
		DS of V3-37A	1	80	.179	.157	0.072	0.176 0.178	0.0008 0.0003	>50	Installed in 1999
05-SB03 (129)	CRD PUMP Min Flow Line DS of R.O. 3-25A (Smallbore Data Base Point 129)	DS RO to V3-34A	1	160	.250	.218	0.072	0.241	0.0023	>50	Installed in 1999
		DS of V3-34A	1	80	.179	.157	0.072	0.172 0.179	0.0018 0.000	46.2	Installed in 1999
		DS of reducing Tee	1.5	80	0.200	.175	0.074	0.198	0.0005	>50	Installed in 1999
05-SB04 (130)	CRD PUMP Min Flow Line DS of R.O. 3-24B (Smallbore Data Base Point 130)	DS RO to V3-37B	1	160	.250	.218	0.072	0.181	0.0037	25	Original, Sch 160
		DS of V3-37B	1	80	.179	.157	0.072	0.176 0.184	0.0008 0.000	>50	Original, Sch 80

V.Y. PIPING FAC INSPECTION PROGRAM 2005 REFUELING OUTAGE INSPECTION REPORT (RFO25- Fall 2005)
 ATTACHMENT 2: SUMMARY OF SMALL BORE PIPING UT INSPECTION RESULTS

SMALL BORE --continued

Small Bore Inspection Number (Note 1)	Description / Location	Sect.	Size (in.)	Sch	T _{nom.} (inch)	.875T _{nom} (inch)	T _{min.} (inch) (Note2)	2005 Min. Measured Thickness (inch)	Apparent Wear Rate (inch/cycle)	Cycles to T _{min.} (Note3)	Comments
05-SB05 (131)	CRD PUMP Min Flow Line DS of R.O. 3-25B (Smallbore Data Base Point 131)	DS RO to V3-34B	1	160	.250	.218	.072	0.255	0.000	>50	Installed in 1999
		DS of V3-34B	1	80	.179	.157	0.072	0.172 0.178	0.0018 0.0003	46	Installed in 1999
		DS of reducing Tee	1.5	80	0.200	.175	0.074	0.190	0.0005	>50	Installed in 1999

NOTES:

1. Small Bore Database Number is shown in parentheses.
2. T_{min} includes a 0.065 inch corrosion allowance per ANSI B31.1-1967.
3. Apparent wear = T_{nom} - T_{measured}.
4. Apparent Wear Rate includes 1.25 factor to account for EPU flows DS of RO-64-2 only
5. Cycles to T_{min} from 2005 refueling outage. Wear rate = (T_{nom}-T_{measured}) / 18.9 Equivalent 18 month cycles and a SF (safety factor) = 1.2 was used on the apparent wear rate. Small bore wear is generally not trended for the purposes of repeat inspections. Small bore components will generally be replaced if significant thinning is observed.

V.Y. PIPING FAC INSPECTION PROGRAM 2005 REFUELING OUTAGE INSPECTION REPORT (RFO25- Fall 2005)
 ATTACHMENT 3: COMPONENTS RECOMMENDED FOR FUTURE MONITORING

Inspection	Component	Calculated Cycles to T _{min}	Recommend Re-inspection RFO	Evaluation / Reasons for Recommendation
2005-12	FD08RD03	9.0	2010 RFO (RFO28)	<p>Estimated time for component to wear to code minimum thickness is based on a default wear rate of 0.005 inch/cycle. The default wear rate considers increased EPU flows. Actual point to point measurements indicate no wear is occurring under current license power flows. RSL calculated based on multiple inspection point to point measurements and CLTP flows is 22.5 cycles. Given this location has the highest velocity in the feedwater system, recommended inspection at RFO28 (Spring 2010.)</p> <p>Inspect both FD08RD03 and FD08SP02 during RFO28 in the Spring of 2010, based on consideration of flow changes due to power uprate.</p>
2005-03 2005-04 2005-05 2005-06 2005-07 2005-08 2005-09 2005-10 2005-11	FD04RD01 FD04TE01 Cond Nzl 32A FD05RD01 FD05TE01 Cond Nzl 32B FD06RD01 FD06TE01 Cond Nzl 32C	****	Per Thermal performance Monitoring System	<p>These are carbon steel components connecting to and adjacent to the condenser. Upstream piping has been replaced with A335 P11 Chrome-Moly piping. During normal operation there is no flow in these lines. No current leakage is indicated since the upstream FCV repairs were performed during RFO24. This piping was inspected to determine if past leakage has caused wear since the last inspections and to insure the condition of the piping for Extend Power Uprate conditions. Wear rates were calculated on a per cycle basis, actual wear rates per cycle may be higher if leakage past the normally closed FCVs occurs.</p> <p>The Thermal Performance Monitoring (TPM) system will be used to determine if flow is occurring in this pipe during normal operation. The Thermal Performance Monitoring (TPM) system will be used as a trigger to determine if future inspections are required.</p>

V.Y. PIPING FAC INSPECTION PROGRAM 2005 REFUELING OUTAGE INSPECTION REPORT (RFO25- Fall 2005)
 ATTACHMENT 3: COMPONENTS RECOMMENDED FOR FUTURE MONITORING

Inspection	Component	Calculated Cycles to Tmin	Recommend Re-inspection RFO	Evaluation / Reasons for Recommendation
2005-24 2005-25 2005-26 2005-27 2005-28 2005-29 2005-30 2005-31	1SSH3EL05 1SSH3SP06US 1SSH4EL01 1SSH4SP02US 1SSH5EL01 1SSH5SP02US 1SSH6EL06 1SSH6SP08US	* * * * * * * *	* * * * * * * *	* Planned inspections on the turbine Steam Seal header (SSH) and the Steam Packing Exhauster (SPE) lines to determine the extent of condition for CR-VTY-2004-02985 CA 03 were "de-scoped" from the 2005 RFO due to higher priority LP turbine work in the same location. Inspect these locations during RFO26 in Spring 2007.
2005-32 2005-33 2005-34 2005-35	2SPE3EL01 2SPE3SP01US 2SPE5EL01 2SPE5SP01US	* * * *	* * * *	* Planned inspections on the turbine Steam Seal header (SSH) and the Steam Packing Exhauster (SPE) lines to determine the extent of condition for CR-VTY-2004-02985 CA 03 were "de-scoped" from the 2005 RFO due to higher priority LP turbine work in the same location. Inspect these locations during RFO26 in Spring 2007.
2005-40	30" B CAR	N/A	RFO26	Given increased flows and possible reduction in steam quality under EPU conditions, a complete internal inspection of the 30" B turbine cross around line should be performed in RFO26.

CHECWORKS™ FAC Application, Version 1.0G Enhancements

The following enhancements have been incorporated into FAC v1.0G. Please review this list to determine what action, if any, you need to take to make effective use of this new version of the software

1. The user can now enter the hydrazine concentration sampled at the Blowdown of recirculating steam generators as an alternate to the Steam Generator Steam Outlet location. Experience has shown that it is very difficult to obtain an accurate measurement of hydrazine concentration in the steam outlet. To accomplish this, a location selection option "Blowdown" has been added to the "Hydrazine at: SG" drop down window in the PWR Complex Water Treatment data entry form.
2. With Version 1.0F, when the user has entered improper hydrazine concentration values at one or more of the Final Feedwater/Condensate, SG Outlet/Blowdown, or MSR Drain locations and tries to perform an analysis, an error message appears triggered by a hydrazine mass imbalance. This error message only allows the user to abort the analysis so as to correct the input. Version 1.0G has changed the error message, giving the user the additional option of continuing the analysis. In either case the user will then need to correct the hydrazine input concentration values, and rerun the analysis until the imbalance message no longer occurs. See the FAC Version 1.0G User Guide for more details.
3. A new fourth analysis option "NFA→HBD→ARD→COMP" is added to the Wear Rate Analysis Run Definition form. This will allow the user to avoid having to zero out operating conditions in the Component Data form when analyzing multiple power levels and wanting to use the operation conditions from the respective Heat Balance Diagrams. With this new option, the FAC Application will retrieve operating conditions in the following order: first in the Network Flow Analysis results (if available), secondly in the Water Chemistry Analysis results for the lines associated to the Heat Balance Diagram, then the data entered in the wear rate run Advanced Run Definition form, and finally data in the component data form. The other three option labels are also changed to be more intuitive. The revised labels are "COMP→HBD→ARD" (formerly: Ignore NFA Results); NFA→COMP→HBD→ARD" (Formerly: NFA Results 1st Priority); COMP→NFA" (formerly: User Input 1st Priority).
4. The Chemistry Analysis Report now prints input data with 3 digits after the decimal point.
5. The non-applicable data fields (Valve Coefficient, Valve Size, Orifice Size, etc.) in the Operating Data and Component Size/Acceptance pages of the Component Data entry form are now grayed-out and set to 0.

VY Piping FAC Inspection Program PP 7028 - 2004 Refueling Outage

Inspection Location Worksheets / Methods and Reasons for Component Selection

By: JGA 3/17/03

Reviewed JOC 3/21/03

Piping components are selected for inspection during the 2004 refueling outage based on the following groupings and/or criteria.

Large Bore Piping

- LA: Components selected from measured or apparent wear found in previous inspection results.
- LB: Components ranked high for susceptibility from current CHECWORKS evaluation.
- LC: Components identified by industry events/experience via the Nuclear Network or through the EPRI CHUG.
- LD: Components selected to calibrate the CHECWORKS models.
- LE: Components subjected to off normal flow conditions. Primarily isolated lines to the condenser in which leakage is indicated from the turbine performance monitoring system. (through the Systems Engineering Group).
- LF: Engineering judgment / Other
- LG: Piping identified from EMPAC Work Orders (malfunctioning equip., leaking valves, etc.)

Small Bore Piping

- SA: Susceptible piping locations (groups of components) contained in the Small Bore Piping data base which have not received an initial inspection.
- SB: Components selected from measured or apparent wear found in previous inspection results.
- SC: Components identified by industry events/experience via the Nuclear Network or through the EPRI CHUG.
- SD: Components subjected to off normal flow conditions. Primarily isolated lines to the condenser in which leakage is indicated from the turbine performance monitoring system. (through the Systems Engineering Group).
- SE: Engineering Judgment / Other.
- SG: Piping identified from EMPAC Work Orders (malfunctioning equip., leaking valves, etc.)

Feedwater Heater Shells

No feedwater heater shell inspections will be performed during the 2004 RFO. Previous plans were to complete the UT grids on the No.1 & 2 heaters have been made moot by the decision to replace all 4 HP feedwater heaters for EPU. The shells on all four new heaters will be a chrome-moly material (P-11). Informational visual inspections of the open ends of Feedwater, Extraction Steam, Heater Drain, Vents and Moisture Separator piping will be performed as access is available.

VY Piping FAC Inspection Program PP 7028 - 2004 Refueling Outage
 Inspection Location Worksheets / Methods and Reasons for Component Selection

LA: Large Bore Components selected(identified) from previous Inspection Results

From the 1995/1996/1998/1999/2001/2002 Refueling Outage Inspections (Large Bore Piping) these components were identified as requiring future monitoring. The following components have either yet to be inspected as recommended, or the recommended inspection is in a future outage

Inspect. No.	Loc. SK.	Component ID	Notes /Comments / Conclusions
96-13 96-14	001	FD01EL04 FD01SP04	1996 report recommended inclusion of FD01SP04 into 2001 RFO Scope (lower readings at U.S. counterbore). UT inspect elbow and downstream pipe in 2004
99-03 99-04	002	FD02EL01 FD02TE01	1999 Recommendation to inspect tee in 2002. Component is downstream of pump 1B. "B" Pump is used a standby pump, based on usage, inspection was deferred until 2004. UT inspect elbow and downstream tee in 2004
99-25 99-26	008	FD14EL03 FD14SP03	1999 recommendation to inspect pipe at upstream counterbore in 2004. Given that the only low readings were at the pipe counterbore and that 2004 RFO work includes replacement of both No.1 feedwater heaters located under the elbow. Defer re-inspection of the elbow FD14EL03 & pipe FD14SP03 until the 2005 RFO.
01-03 01-04	001	FD01EL01 FD01TE05	2001 recommendation to inspect the tee in 2004. UT inspect elbow and downstream tee in 2004 (1998 RFO results recommended inspection in 2001) Also add inspection of the reducer upstream of the elbow.
02-08 02-09	016	FD18EL01 FD18SP02US	2002 recommendation to inspect the elbow in 2007 based on a single measurement. Re-inspect elbow and downstream pipe in 2007 (3 cycles from 2002).

**VY Piping FAC Inspection Program PP 7028 - 2004 Refueling Outage
Inspection Location Worksheets / Methods and Reasons for Component Selection**

LA: Large Bore Components selected (identified) from previous Inspection Results - continued

Turbine Cross-around Piping:

Previous Internal Visual UT & Repair History:

Line	Mat.	Year Replaced	Internal Visual =V, Internal Thickness =UT, Repairs Performed =R							
			RFO16 S1992	RFO17 F1993	RFO18 S1995	RFO19 F1996	RFO20 S1998	RFO21 F1999	RFO22 S2001	RFO23 F2002
36"-A	GE**	1983		V	V	V	V			
36"-B	GE**	1981	V	V	V	V	V	V		
36"-C	GE**	1981	V	V	V		V			
36"-D	GE**	1983		V	V		V			
30"-A	P-22*	1985	V		V		V			
30"-B	C.S.	Original	V/UT/R	V/UT/R	V/UT/R	V/UT	V	V		V
30"-C	P-22*	1993	V/UT/R							
30"-D	P-22*	1985			V					

** 36" straight pipe sections replaced with GE B50A242E, elbows on the B & C lines are original GE specification D50A67D, elbows on A & D lines are D50A67E (Tnom =0.625 inch).

* 30" A,B,C replaced with A691 CL22 (2-1/4Cr), Fittings A234 WP22. (Tnom. = 0.625 inch)

30" B remains GE B50A242D, fittings and GE D50A67D carbon steel (Tnom = 0.50 inch).

NOTE: Reference Dwg. No. 5920-6841 Sh. 1 of 2 needs to be updated with correct information. This will be performed during the EPU design change effort.

2004 RFO HP turbine work and MS internals/drain line work will have all (4) 36 inch line manways open for access to perform internal visual inspections.

Perform internal visual inspection of all four lines. Priority is A 36" line for access to internals of the 12 inch diameter CS stub piece in extraction steam line. Also if manways and CIV SRVs are removed, perform visual inspection of the 30" C & D lines to confirm condition of P22 replacement materials.

2005 RFO based on increased flows and the possibility of different flow regimes in both the 36 & 30 inch piping, perform a visual inspection. LP turbine work in 2005 RFO may provide opportunity for access to the 30" lines. As a minimum inspect (2) 36 inch lines and the 30" B line.

VY Piping FAC Inspection Program PP 7028 - 2004 Refueling Outage
Inspection Location Worksheets / Methods and Reasons for Component Selection

LB: Large Bore Components Ranked High for Susceptibility from CHECWORKS Evaluation

The current CHECWORKS wear rate calculations contain inspection data up to the 1999 RFO and wear rate predictions are current to the 2001 RFO. The 2001 and 2002 RFO inspection data has been entered into the CHECWORKS database. However, updated wear rate calculations are not complete, and won't be in time to support the schedule date for issuing the inspection scope for the Spring 2004 outage. Based on a review of the 2001 and 2002 RFO inspection data for components on the Feedwater, Condensate, and Heater Drain Systems, the CHECWORKS models still appear to over-predict actual wear. Nothing new or unanticipated was observed in 2002.

Feedwater System

Listed below are components which meet the following criteria:

- a) negative time to T_{min} from the predictive CHECWORKS runs which include inspection data up to the 1999 RFO,
- b) no inspections have been performed on these components or the corresponding components in a parallel train since the 1999 RFO.

Component ID	Location Sketch	Location	Notes
FD07EL03	005	T.B Feed Pump Room	No inspection data for corresponding component FD08EL02 in other train. Inspect this or the other train component in 2004. This component will be inspected in 2004.
FD07TE01 FD07EL11	006	T.B Heater Bay Elevs 228 & 248	Components on other train were inspected in 1998. Results indicate minimal wear. After updating the CHECWORKS model with newer data, assess need for additional inspections in 2005 RFO.
FD07EL12	006	T.B Heater Bay Elev. 248	Feedwater heater replacement to occur in 2004 RFO. Perform internal visual inspection at open end on this component.
FD14EL07	009	RX Steam Tunnel El. 266	Internal visual of elbow performed in 1996 during check valve replacement. no indication of wall loss at that time. Inspect this or the other train component in 2004. (Inspect this component in 2004).
FD08EL02	011	T.B Feed Pump Room	No inspection data for corresponding component FD07EL03 in other train. Inspect this or the other train component in 2004. FD07EL03 will be inspected in 2004.
FD08TE01 FD08EL07	012	T.B Heater Bay Elevs 228 & 248	Intermediate components FD08EL06 & FD08SP06 were inspected in 1998. Results indicate minimal wear. After updating CHECWORKS model with newer data, assess need for inspecting components on the train vs. these.
FD08EL08	012	T.B Heater Bay Elev. 248	Feedwater heater replacement to occur in 2004 RFO. Perform internal visual inspection at open end on this component.
FD15EL08	013	RX Steam Tunnel El. 266	Internal visual of elbow performed in 1996 during check valve replacement. no indication of wall loss at that time. After updating CHECWORKS model with newer data, assess need for inspecting this component in 2005 RFO.

VY Piping FAC Inspection Program PP 7028 - 2004 Refueling Outage
Inspection Location Worksheets / Methods and Reasons for Component Selection

LB: Large Bore Components Ranked High for Susceptibility from CHECWORKS Evaluation - continued

Condensate System

Only one component was identified as having a negative time to T_{min}. This was CD30TE02DS, the downstream side of a 24x24x20 tee on the condensate header in the feed pump room. The CHECWORKS prediction for the downstream side of the tee has a small negative hrs relative to the remainder of the components in the system and relative to the upstream side of the same tee. Other tees on the same header have been previously inspected and show no significant wear. The CHECWORKS model includes UT data up to the 1999 RFO. The inspections on this system performed in 2001 indicate minimal wear. The 2001 inspection data will be input to CHECWORKS to better calibrate the model.

To inspect the components with the highest susceptibility as ranked by CHECWORKS and to obtain a more complete set of inspection data for the Condensate System inspect additional components between the No.3 feedwater heaters and the feedwater pumps. **Inspect CD30TE02 and CD30SP04 in 2004.**

Moisture Separator Drains & Heater Drain System.

No components identified as having negative times to T_{min}. No components were selected for inspection in 2001 or 2002 based on high susceptibility. However future operation under HWC will change dissolved oxygen in system. A separate evaluation has been performed and components were selected for inspection in 2002. See Section LD below.

Extraction Steam System

Three components on this system with negative time to code min. wall. The piping is Chrome-Moly. ES4ATE01 & ES4ATE02, 30inch diameter tees inside the condenser have negative prediction (-3426Hrs.) for time to min wall. The negative times to t_{min} may be conservative based on the modeling techniques used. Refinement of the model of this system is in progress. The negative time to t_{min} is most likely a function of lack of inspection data vs. actual wear. Due to external lagging on this piping and the location inside the condenser, no components are selected for external UT inspection in 2004 based on high susceptibility. However, an opportunity to perform an internal visual inspection of all the Extraction Steam lines inside the condenser during planned LP turbine work in the 2005 RFO may present itself. See Section LF below.

Note the short section of A106 Gr. B straight pipe on line 12"-ES-1A at the connection to the 36 inch A cross around line is not modeled in CHECWORKS. The component material should be included in the next model update.

**VY Piping FAC Inspection Program PP 7028 - 2004 Refueling Outage
Inspection Location Worksheets / Methods and Reasons for Component Selection**

LC: Large Bore Components Identified by Industry Events/Experience.

Review of FAC related Large Bore Operating Experience (OE) and/or piping failures reported since January 2001

Date	Plant - Type	Description & Recommended Actions at VY
4/7/01	Callaway - PWR	Unexpected extent of thinning in feedwater piping (NRC IN 2001-009 & INPO OE12342) Additional components were inspected in the feedwater system in the Drywell during the 2002 RFO in response to this event.
5/9/01	Grand Gulf - BWR	Pin Hole Leak in 4 inch carbon steel elbow in RHR min flow line. System has low use at VY (<2% of time). A review of VY drawings VYI-RHR-Part 14 Sht.1/1 and VYI-RHR Part 15 Sht.1/1 show elbows downstream of restriction orifices. Additional research into this event is warranted. Inspections can be performed with the plant operating. Don't include in the scope of 2004 RFO.
11/20/01	Hamoka 1 - BWR	Rupture of HPCI/RCI 6 inch steam supply line at a section of pipe to RHR Hx sprays. VY is an older design which does not have this configuration.
9/24/02	IP2 - PWR	Pin hole leak on 26 1/2" cross-under piping (HP to MSR) in vicinity of dog bones at expansion joint under location of weld overlay localized wear under/around a previous weld overlay repair. VY has solid piping (no expansion joints. Visual Inspections of CAR piping will be performed in 2004.
1/2/02	Point Lepreau-PHWR	Failure of Extraction Steam Bellows from LP turbine. VY bellows are made from stainless steel. Primary causes of past failures have been cracking of convolutions and vibration failures of tie rods. The bellows were replaced in 1995 and should not be susceptible to FAC damage.
1/15/02 CHUG Meeting	Surry 1-PWR	Leak in 8 inch Condenser drain header for 3 rd /4 th pt. FDW Heater vents. Also thinning in Gland Steam Piping inside the condenser and the 12" Condenser Drain header from MS Drain trap lines. The only large bore drain collector at VY is the 8 inch diameter low point drain header. Inspect sections of this line during the 2004 RFO.
1/15/02 CHUG Meeting	Cooper - BWR	Thinning found in two 20 inch diameter exit nozzles off LP turbine for extraction steam piping. (VY has replaced all LP turbine stub pieces upstream of the expansion bellows with P-11 material. No actions are required at this time.
6/02 CHUG Meeting.	Oconee 1	Wear found in Heater Drain piping downstream of block valve. Ops was using the gate valve to control flow. All valves on VY HD system are control valves. Normal flow downstream of valves is directly into the feedwater heaters. Bypass valve discharge directly into condenser. TPM monitors possible leakage past the Bypass valves.
6/24/02	Prairie Island 1 - PWR	Preliminary notice of possible extraction steam line piping/bellows failure inside condenser. (See 1/2/02 Point Lepreau notice above).
8/29/02	Turkey Point 3 - PWR	Failure of a 6x10 Schedule 40 carbon steel expander in Heater Drain System downstream of a level control valve. Same valve on other train was replaced. However, no inspections were performed on this valve (from INPO Event 250-020829-1, OE 14865, & Info at 1/03 CHUG Meeting). Location is similar to millstone 2 & 3 events in 1991/92. Piping on HD system at VY DS of normal level control valves is constructed from FAC resistant materials or planned for replacement with new Feedwater Heaters. No actions are required for this OE.
10/9/02	Clinton -BWR	Interconnecting piping (4 and 6 inch diameter) between RWCU Heat Exchanger not included in FAC program. Plant assumed they were equipment when in fact they are piping. VY has replaced the original 3 Perflex Hx design with a U-tube Hx. RWCU piping in this area is stainless steel. Therefore not an immediate concern.

**VY Piping FAC Inspection Program PP 7028 - 2004 Refueling Outage
Inspection Location Worksheets / Methods and Reasons for Component Selection**

LD: Large Bore Components Selected to Calibrate CHECWORKS

The CHECWORKS models have been upgraded to include the 96, 98, & 99 RFO inspection data. The 2001 and 2002 inspection data has been loaded however wear rate analyses are not complete at this time. In 2001 components on the higher temperature end of the Condensate System were inspected to calibrate the CHECWORKS models. The inspection data indicate minimal wear and should reinforce the assessment of low wear in the Condensate System. Additional components selected for inspection in 2004 in Section LB above will be used to calibrate the CHECWORKS model.

Prior to the 2002 there was limited inspection data for the Heater Drain system. The current CHECWORKS models (Pass 1 and some Pass 2) indicate low wear rates. During 2002 a number of new inspections were performed to obtain base line data prior to operation under GE Noble Metals HWC. No additional components on the Heater Drain system will be inspected in 2004.

LE: Large Bore Components subjected to off normal flow conditions identified by turbine performance monitoring system (Systems Engineering Group).

The Systems Engineering Production Variance Reports for 2002 & since startup from 2002 (RFO23) do not identify any leaking valves. No other leaking valves or steam traps have been identified (to date) using the Turbine Performance Monitoring (TPM) system. No components will be scheduled for the 2004 RFO based on the TPM reports to date. However, if new data indicates leaking valves then, additions to the outage scope may be required.

LF: Engineering Judgment / Other

Nine ASME Section XI Class 1 Category B-J welds are to be inspected by the FAC program per Code Case N-560 in lieu of a Section XI volumetric weld inspection. The VY ISI Program Interval 4 schedule for inspection of these welds is as follows:

Refueling Outage	Section XI ISI Program Weld ID	Description	FAC Program Components
Spring 2004 (RFO24) Interval 4 Period 1, Outage 1.	FW19-F3B FW19-F3C FW19-F4 FW21-F1	upstream pipe to tee tee to reducer reducer to pipe tee to pipe	"A" Feedwater on Sketch 010 FD19TE01 FD19RD01 FD19SP04 FD21SP01
Fall 2011 (RFO29) Interval 4 Period 3, Outage 6.	FW18-3A FW20-3A FW20-F1 FW20-F1B FW18-F4	upstream pipe to tee tee to reducer reducer to pipe horizontal pipe to pipe tee to pipe	"B" Feedwater on Sketch 016 FD18TE01 FD20RD01 FD20SP01 FD18SP04

**VY Piping FAC Inspection Program PP 7028 - 2004 Refueling Outage
Inspection Location Worksheets / Methods and Reasons for Component Selection**

LF: Engineering Judgment / Other – continued

All Extraction Steam piping is A335-P11, a 1-1/4 chrome material, except for a short carbon steel stub piece in line 12"-ES-1A at the connection to the 36" A cross around line. Internal visual inspection of this stub piece will be performed along with the 36" A cross around line. This extraction steam line (6th point extraction) has the highest quality steam of all extraction lines which indicates a relatively lower wear rate. Based on the 1996 inspection data for the carbon steel section, ES1ASP01 (Inspection 96-07A) showing a small area of wall thickness less than 0.875 x nominal thickness, the expected changes in flow regime due to power uprate, and that this is the only carbon steel section in the ES system, a repeat inspection to confirm actual wall thickness and also to obtain a baseline thickness prior to power uprate should be performed. **Perform external UT inspection of ES1ASP01 in RFO24.**

Extraction Steam piping in the condenser has external lagging which requires significant effort for removal when performing external UT inspections (plus there are significant staging costs). The piping is A335-P11. However an opportunity to perform an internal visual inspection of all the Extraction Steam lines inside the condenser during planned LP turbine work in the 2005 RFO may present itself.

LG: Piping identified from EMPAC Work Orders (malfunctioning equip., leaking valves, etc.)

Word searches of open work orders on EMPAC were performed for the following keywords: trap, leak, valve, replace, repair, erosion, corrosion, steam, FAC, wear, hole, drain, and inspect. No previously unidentified components or piping were identified as requiring monitoring during the Spring 2004 RFO.

VY Piping FAC Inspection Program PP 7028 - 2004 Refueling Outage
Inspection Location Worksheets / Methods and Reasons for Component Selection

Small Bore Piping

SA: Susceptible piping locations (groups of components) contained in the Small Bore Piping data base which have not received an initial inspection.

Locations on the continuous FDW heater vents to the condenser on the No. 3 heaters were inspected in 2002. The continuous vents on the No. 4 heater were installed new in 1995. The start up vents operate less than 2% of operating time. No wear was found in previous inspections on Heater Vent piping from the No.1 & 2 heaters. Given that and the lower pressure in the No. 4, shells a complete inspection of the remainder of the No. 4 heater vent piping can be deferred. The existing small bore data base and the piping susceptibility analysis is under revision. No additional components from Revision 1 of the data base will be inspected.

SB: Components selected from measured or apparent wear found in previous inspection results.

Small Bore Point No. 20. 2-1/2" MSD-6 @ connection to condenser A at Nozzle 33 (Inspection No. 96-SB01 identified a low reading at weld on stub to condenser). Upstream valves are normally closed. TPM system does not indicate any abnormal flow. No inspections will be performed on this line in 2004.

A through wall leak in the turbine bypass valve chest 1st seal leak-off line from the No. 1 bypass valves occurred in 2003. (ER 2003-044) A temporary leak enclosure has been installed (T.M.2003-002 to contain the leak). W.O. 03-0364 was written to inspect/repair/replace/line. The line should be completely replaced with chrome-moly piping. (Dresden has already done this) Given the amount of work already scheduled for the heater bay during the 2004 RFO a complete replacement will be deferred. A local code repair of the piping will be performed to remove the temp Mod during the 2004 RFO. Additional inspections should be performed to insure the integrity of the line. The long term solution (if license renewal is pursued) should include replacement the entire line with chrome-moly material.

System	Description	Inspection No.
2"-1SLBPV	2 inch header off the turbine bypass valve chest first seal leak-off connections. Inspect five locations on this line. Include the 1/2 line at the No. 2 valve. It has the next highest usage from the no.1 valve.	2004 SB01 to SB05
2-1/2" 1SPL2	HP Turbine pocket drains, inspect first two elbows and connecting piping under turbine based on reading from 1993 (inspections 93-SB49 to 93-SB52)	2004 SB06 & SB07

VY Piping FAC Inspection Program PP 7028 - 2004 Refueling Outage
Inspection Location Worksheets / Methods and Reasons for Component Selection

Small Bore Piping

SC: Components identified by industry events/experience via the Nuclear Network or through the EPRI CHUG.

Date	Plant - Type	Description & Recommended Actions at VY
7/23/98	Calvert Cliffs 2 -PWR	Rupture of a moisture separator re-heater (MSR) 2 inch vent line (INPO Event 318-980723-1) No MSRs at VY, therefore no equivalent line at VY.
11/03/98	Hamoka 2 - BWR	Leak due to FAC in turbine driven feed pump casing drain line No turbine driven feed pump at VY, therefore no equivalent line at VY.
4/29/99	Darlington 1 - PHWR	Severed line at steam trap discharge pipe at threaded connection. Equivalent to HHS system at VY. (INPO Event 931-990429-1) Threaded connections typically on condensate side of HHS piping. Lower energy/consequence of leak. Consider during next update of the Small bore data base.
5/07/99	Darlington 4 - PHWR	Leak on HP Feedwater Heater Vent Line downstream of orifice (INPO Event 934-990507-1). At VY inspections have performed DS of orifices on HV lines.
6/14/99	Darlington 2 - PHWR	Leak on steam trap discharge pipe at threaded connection. Equivalent to HHS system at VY. (INPO Event 932-990614-1) Same as above.
10/07/99	Darlington 2 - PHWR	Leak on Feedwater Heater Vent Line downstream of orifice (INPO Event 932-991007-1). At VY inspections have performed DS of orifices on HV lines.
10/1/00	Ocone3 -PWR	From 1/2001 CHUG Meeting. MSR Scavenging steam line Pinhole leak in 1" pipe downstream of flow control valve. No equivalent system at VY.
1/8/01	Oyster Creek - BWR	Rupture of 2 inch line connecting controller/transmitter level column to re-heater drain tank. No MSRs at VY, therefore no equivalent line at VY.
9/1/01	Peach Bottom 3 -BWR	(From 1/14/02 CHUG Meeting), leak on 1 inch Sch. 80 line from in Off Gas Re-combiner pre-heater drain line to condenser. Additional review of AOG steam supply system is required. Consider during next update of the Small bore data base.
6/22/01	Pilgrim - BWR	Leak on 2 inch feedwater heater vent line (OE discussed at 1/02 CHUG Meeting), Equivalent lines at VY have been inspected.
10/22/01	St. Lucie 1 - PWR	(From 1/14/02 CHUG Meeting), Leak on 1 inch Sch. 80 normally isolated drain line remote from process system. TPM used to determine leaks from N.C. valves.
11/28/01	Browns Ferry 3 - BWR	Through - wall leaks in drain lines from extraction stream non-return check valves back to condenser. (Similar lines at VY are chrome-moly and there have been previous inspections performed on these lines. No additional inspections are required.
1/15/02 CHUG Mtg.	Hatch1/2 -BWR	Condenser in leakage due to through wall erosion (external ?) of 1-1/2 inch "slop" drains lines inside the condenser. Lines in each unit were cut and capped similar events at Byron Unit 1 (OE 12609) and Columbia (OE12145). Limerick & Dresden. VY slop drain lines do not show up on VY P&IDs.
1/15/02 CHUG Mtg.	Catawba 2 - PWR	Leak in HP turbine pocket shell drain 1 inch dia. OEM showed pipe as P-11. However, A-106 Gr. B was installed. Inspections will be performed on this line in 2004 to base line condition prior to HP turbine rotor replacement.
1/15/02 CHUG Mtg.	Columbia - BWR	Leak in 2 inch drain line from bleed steam trap to condenser. At VY SB piping DS of steam traps is included in the small bore data base.
1/15/02 CHUG Mtg.	Peach Bottom2 - BWR	Pin Hole leaks in 1" schedule 160 HPCI Steam Supply drains (Plant thought piping was replaced with P-11 , However field conditions showed that is was not. Piping at VY inspected in 1999 (99-SB01 to 99-SB03)

continued

16

**VY Piping FAC Inspection Program PP 7028 - 2004 Refueling Outage
Inspection Location Worksheets / Methods and Reasons for Component Selection**

Small Bore Piping

SC: Components identified by industry events/experience via the Nuclear Network or through the EPRI CHUG – continued.

Date	Plant – Type	Description & Recommended Actions at VY
1/15/02 CHUG Mtg.	Dresden 2 BWR	Thinning found in Bypass valve leak-off line to the 7 th stage extraction steam line. Line is 2" Sch. 80, GE B4A39B. Lowest reading was 0.070" found using Phosphor Plate radiography. Line was replaced with A335 P-11. Same line as recent VY through wall leak, RFO 2004 inspect locally, then long term replacement with A335-P11.
6/02 CHUG Mtg.	ANO1 & ANO 2 PWR	Leaks in Gland seal steam to No.3 bearing 1-1/4 vendor supplied line. Leak in 1" Sch.80 drain from Reheat 2 nd stage drain tank to condenser. Additional review of GE supplied steam seal & drains is required. Consider during next update of the Small bore data base.
6/02 CHUG Mtg.	Brunswick 1 - BWR	Replaced continuous vent lines on #4 feedwater heaters with chrome-moly pipe. (Smart move for long term.) New vent lines on No.1 & 2 FDW heaters at VY will be chrome-moly.
6/02 CHUG Mtg.	Calvert Cliffs 1 PWR	Pin hole leak in 3/4 inch Sch. 80 drain line off MS supply to steam generator feed pump just downstream of orifice. No steam driven feed pumps at VY.
6/02 CHUG Mtg.	Fermi 2 - BWR	Leak in first elbow downstream of AOV in 1 1/2" continuous vent from Turbine Bypass Valve seat drain to condenser. Valve has travel stop which prevents complete closure. Fermi has no steam traps, AOVs are used instead. Piping DS of steam traps on MSD lines are included in the SB program. The only continuous opening to the condenser at VY is the steam leads drains through RO 60-1. This piping has been replaced with chrome-moly piping.
1/03 CHUG Meeting.	JAF -BWR	Through wall leaks in 2" Sch. 80 C.S. lines from 5 th /6 th extraction drain lines immediately downstream of restricting orifices. At VY the only drain lines on the extraction steam piping are upstream of the reverse current valves. There are no restriction orifices at VY. The piping is chrome-moly.
1/03 CHUG Meeting.	Turkey Pt.4 – PWR	Leak in HP turbine bowl drain. 1" sch 80 C.S. pipe. OEM recommended replacement with SS pipe in 1982, did not occur. Equivalent line at VY will be inspected in 2004 to baseline thickness prior to HP turbine rotor replacement.

SD: Components subjected to off normal flow conditions, as indicated from the turbine performance monitoring system (Systems Engineering Group).

No small bore lines have been identified by Systems Engineering on or before 2/27/2003

SE: Engineering judgment

(None at this time.)

SG: Piping identified from EMPAC Work Orders (malfunctioning equip., leaking valves, etc.)

See LG above. The EMPAC search performed in LG above is applicable to both Large and Small components.

- The meeting then split into breakout sessions. Aaron Kelley led a session on BWR issues. The following discussions were noted:

FAC Problem Areas.

- N/A - Hatch has had lots of wear and repairs to their 8th stage extraction (3rd highest), even though the heat balance diagram shows it to be 99% steam. CHROMIUM MOLY @ Vg
- N/A - LaSalle is wondering if there may be problems in their carbon steel turbine nozzles to extraction steam. Riverbend has had to inspect these locations from the turbine side because of the shields. " "
- N/A - Quad Cities has had lots of problems in their expansion bellows.
- - Riverbend replaced the extraction steam check valves using chrome moly. Unfortunately, the internals were carbon steel and they had problems after only two cycles. ● SOUND FROM 400
- ? → - LaSalle had a failure caused by droplet impingement in a heater vent line 17' downstream of the valve.
- ADD 8" MSD 9 - LaSalle is experiencing impingement damage in an 8" common drain header to condenser that collects six to eight 2" and smaller diameter lines. Stainless will help, but they still will need to inspect. INSPECT 8" MSD 9 IN 2004
- N/A - Hope Creek has seen a lot of damage in the drain to condenser of the steam to reactor feed pump turbines.

Water Chemistry.

- → - Riverbend experienced significant increases to iron transport after applying hydrogen injection (medium level of injection). GE did a mini-test. * MONITOR FE
- - Nine Mile Point had unexpected failures on the lower end of the heater drains after applying HWC.
- ? - LaSalle measured oxygen on the heater drains, and then used the data to revise the CHECWORKS model. The data caused to LCFs on the MSR drains, 1st stage reheaters, and 2nd stage reheaters to skyrocket.
- ! - Columbia River has tentatively concluded that noble metals does not effect the fuel. It is too soon to see if hydrogen water chemistry affects the FAC rates.

RPV Bottom Head Drain.

- LaSalle has not inspected the first elbow below the vessel because of its inaccessibility and high radiation dose involved. For this reason, they selected the second 90° elbow which is outside the vessel pedestal. Results were provided on FACNet. Additionally, the sump will maintain water level if there is a break at the first elbow.
- It was noted that it may be possible to inspect the nominally inaccessible areas when there is a 10% disassembly to replace some blades.
- LaSalle and Clinton plan to inspect the accessible portions of the line.
- Columbia River has inspected several locations on the line. No wear was found. Three inspections were also performed on the RWCU near the drywell. No damage was found.
- Exelon (Harold Crockett) volunteered to collate and publish a summary of industry inspections on the line.

ATTACHMENT TO 2004 SCOPING WORKSHOPS (PH 2002)

Inspection Methods.

- LaSalle is performing some pre-outage RTs in selective areas due to final feedwater temperature reduction. This is the second time that some pre-outage work was done in normally high radiation areas. Aaron Kelly can be contacted for more information.
- Riverbend is training their QC inspectors to perform UT.

Power Uprates.

- Nine Mile Point saw little change to wear rates after a 7% uprate.
- Dresden and Quad Cities did a 15% uprate. Some lines saw increases to wear rates of up to 30%. Temperature changes are believed to be responsible.
- Perry did a pre-power uprate analysis on the effects to FAC. They used the results to justify line replacements as part of the planning process.
- LaSalle found no changes to their susceptible-not-modeled rankings as a result of their uprate.

Life Extension.

- General comment was that the NRC has emphasized compliance with NSAC-202L-R2 and brought up main steam susceptibility as part of their approval process.
- At Nine Mile Point, the NRC brought up service water issues.
- Southern Nuclear is taking credit for other programs in response to the NRC questions on valves.

~~In parallel with the BWR session, Jeff Horowitz led the PWR Breakout Session. The session was broken down into three parts:~~

- ~~- A description of the very high levels of iron transport experienced at San Onofre. This presentation included details of the investigation into the phenomenon, a description of the deposits found, several possible explanations for the deposits, and what the effects of the deposit were on plant performance.~~
- ~~- A status report on the EdF hydrazine testing program. Unfortunately, no progress has been made since the last report in June due to a number of problems. The latest problem, inadequate water quality, has been resolved and testing resumed earlier this month. The testing program is expected to take all year to complete. Details of the test program have been presented at previous CHUG meetings.~~
- ~~- There was also a brief discussion of feedwater oxygen and FAC. Several PWRs are now allowing the entry of small amounts of oxygen into the condensate system in hopes of reducing the iron transport. The potential for change to the PWR Water Chemistry Guidelines in this area was discussed.~~

• Tina Gaudreau discussed several EPRI chemistry projects that have FAC implications. The first was the EdF testing for the effects of hydrazine and oxygen on FAC as summarized by Jeff Horowitz in the PWR breakout session. The second project was the next revision to the PWR Secondary Chemistry Guidelines, that will begin this spring. The third project is an investigation into the influence of dissolved iron, electrochemistry, and chemical parameters on



Vermont Yankee Nuclear Power Station
Design Engineering Department - Mechanical/Structural

To S.D. Goodwin Date March 27, 2003
From J.C. Fitzpatrick File # VYM 2003/009
Subject Piping FAC Inspection Scope for the 2004 Refueling Outage

REFERENCES


- (a) PP 7028 Piping Flow Accelerated Corrosion Inspection Program, LPC 1 12/06/01.
- (b) V.Y. Piping F.A.C. Inspection Program - 1996 Refueling Outage Inspection Report, March 23, 1999.
- (c) V.Y. Piping F.A.C. Inspection Program - 1998 Refueling Outage Inspection Report, April 2, 1999.
- (d) V.Y. Piping F.A.C. Inspection Program - 1999 Refueling Outage Inspection Report, February 11, 2000.
- (e) V.Y. Piping F.A.C. Inspection Program - 2001 Refueling Outage Inspection Report, August 11, 2001.
- (f) V.Y. Piping F.A.C. Inspection Program - 2002 Refueling Outage Inspection Report, January 20, 2003.

DISCUSSION

Attached please find the Piping FAC Inspection Scope for the 2004 Refueling Outage. The scope includes locations identified using: previous inspection results, the CHECWORKS models, industry and plant operating experience, input from the Turbine Performance Monitoring System, the CHECWORKS study performed to postulate affects of Hydrogen Water Chemistry operation on FAC wear rates in plant piping, postulated power uprate effects, and engineering judgment.

The planned 2004 RFO inspection scope consists of 26 large bore components at 11 locations, internal inspection of 6 of the 8 lines of the turbine cross around piping, and 11 sections of small bore piping. Given that it's a full year from the start of the outage, any industry or plant events that occur in the interim or new information may necessitate an increase in the planned scope:

I am available to support planning and inspections as necessary. If you have any questions or need additional information please contact me.


James C. Fitzpatrick
VY FAC Program Coordinator

ATTACHMENT: 2004 RFO FAC Inspection Scope (4 Pgs.)

CC D.Girroi (Code Programs Supervisor)
D.King (ISI Program Engineer)
T.M.O'Connor (Design Engineering)
M.LeFrancols (Systems Engineering)

20

ATTACHMENT to VYM 2003/009

VERMONT YANKEE PIPING FAC INSPECTION PROGRAM 2004 INSPECTION SCOPE (3/27/03) Page 1 of 4

LARGE BORE PIPING: External UT Inspections

Point No.	Component ID	Location Sketch	Location	Previous Inspections	Reason / Comments / Notes
2004-01	FD01RD01	001	T.B. FPR. Elev. 232.	2001	2001 recommendation for repeat inspection of FD01TE05.
2004-02	FD01EL01	001	" " "	2001	
2004-03	FD01TE05	001	" " "	2001	
2004-04	FD01EL04	001	T.B. FPR Elev. 241.	1996	1996 recommendation for repeat inspection of FD01SP04.
2004-05	FD01SP04	001	" " "	1996	
2004-06	FD02RD01	002	T.B. FPR. Elev. 232.	1999	1999 recommendation for repeat inspection of FD02TE01.
2004-07	FD02EL01	002	" " "	1999	
2004-08	FD02TE01	002	" " "	1999	
2004-09	FD03SP01	003	T.B. FPR. Elev. 232.	NO	Ranked high by CHECWORKS.
2004-10	FD07SP02DS	005	T.B. FPR. Elev. 232.	NO	Ranked high by CHECWORKS include minimum of 36 inch of vertical run upstream of elbow.
2004-11	FD07EL03	005	" " "	NO	
2004-12	FD14SP08DS	009	Stm Tunnel Elev. 266	NO	Ranked high by CHECWORKS include minimum of 32 inch of vertical run upstream of elbow.
2004-13	FD14EL07	009	" " "	NO	
2004-14	FD19TE01	010	Rx Drywell Elev. 270	1999	Required Inspections per ASME Section XI ISI Program FAC inspections per ASME Code Case N-560.
2004-15	FD19RD01	010	" " "	1999	
2004-16	FD19SP04	010	" " "	1999	
2004-17	FD21SP01	010	" " "	1999	

2

ATTACHMENT to VYM 2003/009

LARGE BORE PIPING: External UT Inspections - continued

Point No.	Component ID	Location Sketch	Location	Previous Inspections	Reason / Comments / Notes
2004-18	CD30TE02	036	T.B. FPR Elev. 243.	NO	Ranked high by CHECWORKS include 12 inch long stub between CD32LE01 & CD32EL02.
2004-19	CD30SP04	036	" " "	NO	
2004-20	CD32EL01	039	" " "	NO	
2004-21	CD32EL02	039	" " "	NO	
2004-22	ES1ASP01	063	T.B. HB Elev. 255.	1998	Highly susceptible to FAC damage. This is the only remaining carbon steel section in Extraction Steam system. Baseline data for power uprate.
2004-23	MSD9TE01 thru MSD9TE08	097	T.B. HB Elev. 249.	NO	Industry Experience with numerous through wall leaks in drain collector headers. Scan as much of header below drains from LCV 38A to 38D and ST-60-2A to 2D as accessible. See Note 3.
2004-24	MSD9EL05	097	T.B. HB Elev. 237.	NO	Industry Experience with numerous through wall leaks in drain collector headers. Inspect a minimum of 16 inch length on MSD9SP06US. See Note 3.
2004-25	MSD9EL06	097	" " "	NO	
2004-26	MSD9SP06US	097	" " "	NO	

LARGE BORE UT NOTES:

1. Coordinate minimum extent of insulation to be removed with J.Fitzpatrick or T.M. O'Connor from DE-M/S.
2. A "No" in the previous inspection column indicates asbestos abatement may be required.
3. Piping is part of the proposed ALT Boundary for Power Uprate AST.

22

T to

ATTACHMENT to VYM 2003/009

VERMONT YANKEE PIPING FAC INSPECTION PROGRAM 2004 INSPECTION SCOPE (3/27/03)

Page 3 of 4

LARGE BORE PIPING: Internal Visual Inspections (with supplemental UT as required)

Inspection Point No.	Description
2004-27	"A" 36 inch diameter Turbine Cross Around line (CAR).
2004-28	"B" 36 inch diameter Turbine Cross Around line (CAR).
2004-29	"C" 36 inch diameter Turbine Cross Around line (CAR).
2004-30	"D" 36 inch diameter Turbine Cross Around line (CAR).
2004-31	"C" 30 inch diameter Turbine Cross Around line (CAR).
2004-32	"D" 30 inch diameter Turbine Cross Around line (CAR).

Note: Internal visual inspections of open ends at all large bore connections to the new High Pressure feedwater heaters will be performed during installation of the new heaters during the 2004 RFO. (This includes Feedwater, Extraction Steam, Moisture Separator Drains, and Heater Drain piping.)


23

Vermont Yankee
Piping F.A.C. Inspection Program
Small Bore Piping
Component Selection Review

Prepared By YAEC Vermont Yankee Project

Revision 0 January 27, 1995

Prepared By:




Date:

2/27/95

James C. Fitzpatrick
Mechanical Engineering Group
Vermont Yankee Project

Reviewed By:



Date:

2/27/95

Thomas M. O'Connor
Mechanical Engineering Group
Vermont Yankee Project

V.Y. Piping F.A.C. Inspection Program - Small Bore Component Selection Review

Introduction / Purpose

The purpose of this paper is to document and to formalize the process used in the selection of small bore piping components to be considered as susceptible to wall thinning due to flow accelerated corrosion (FAC).

Small bore piping locations identified as susceptible to FAC are comprised of either single piping components or groups of components (straight pipes, elbows, reducers, & tees, etc.). The susceptible locations are identified using the Vermont Yankee Piping & Instrumentation Diagrams (P&IDs) and screening criteria listed in this paper.

The locations identified on the P&IDs will be included in a data base of susceptible piping components. These will be considered for inspection under the Vermont Yankee Piping Flow Accelerated Corrosion (FAC) Inspection Program.

Most small bore piping is original plant equipment and has been in service since 1972. The majority of this piping is carbon steel. Given approx. 22 years of service, high wear locations should have made themselves evident. However, some sections of small bore piping have been replaced during equipment replacement and/or repairs.

Inspection data for small bore components prior to 1992 may be available, but there has been no dedicated data base which documents and trends small bore replacements. A detailed search of Maintenance work orders records will be required to obtain this information. Inspections of small bore components performed under the Piping FAC Program began in 1992. A limited number of small bore piping components were inspected during the 1992 refueling outage. An increased number of small bore components were inspected during the 1993 refueling outage. Small bore inspections of the data base locations will continue until all locations are either inspected or judged as not susceptible to FAC damage.

For the Piping FAC Inspection Program, long term tracking of wear in small bore piping will not generally be performed. CHECMATE / CHECWORKS modeling and evaluations will not typically be performed for small bore piping. Given the cost of performing inspections, components and attached piping which exhibit FAC damage will preferably be replaced with FAC resistant materials.

V.Y. Piping F.A.C. Inspection Program - Small Bore Component Selection Review

Small Bore Piping: Susceptible System Selection:

Small bore lines, 2-1/2 inch nominal diameter and smaller are included in the program based on industry and plant experience, possible effects on personnel safety, consequences to plant availability, and possible negative effects to the plant licensing basis.

(Example: a small steam leak in the Reactor Building may adversely effect the fire protection systems and/or electrical equipment in the EQ program).

Criteria for inclusion:

1. Piping diameter 2-1/2" nominal or less. (Note: some 3" segments are included).
2. Design Pressure >275Psi. and/or Design Temperature >200F
3. Piping Material Chrome Content < 5%.
4. Steam Quality < 99%
5. System in use > 2% of Plant Operating Hours (Note: systems in use < 2% of plant operating hours are not automatically excluded).
6. Consequences of leak or failure on personnel safety and plant operation.

Results:

A review of the VY P&ID's using the criteria above, shows portions of the following systems may be susceptible to FAC:

<u>System</u>	<u>Symbol</u>	<u>P&ID's</u>
Auxiliary Steam	AS	G191156, 33600-A217(AOG by Suntac)
Main Steam Drains	MSD	G191156, G191157, G191169, G191174
Extraction Steam	ES	G191156
Condensate	C	G191157
Heater Vents	HV	G191158
Control Rod Drive	CRD	G191170
Reactor Water Cleanup	CUW	G191178
Heating Steam	HS	G191254
Turbine Steam Seal & Leakoff Lines	(various)	5920-224(by GE)

V.Y. Piping F.A.C. Inspection Program - Small Bore Component Selection Review

Small Bore Piping: Identification of Susceptible Piping Components

The following criteria are used to identify Small bore piping components or groups of components susceptible to FAC.

1. The implications of a failure of the line or component on personnel safety, plant availability, and possible negative effects to the plant licensing basis. Priority should be given to sections of piping that cannot be readily isolated.
2. Observed fluid leakage through normally closed valves or blow by in steam traps during operation as indicated in plant work orders and/or the turbine performance monitoring system.
3. Data from previous inspections and continued monitoring of components which have been replaced with either carbon or low alloy steels.
4. Generic Industry Experience Components which are locations in plant piping systems that have experienced failures and/or have been found to exhibit wall thinning due to FAC. Industry Experience Components include but are not limited to:
 - Downstream of flow control valves.
 - Downstream of orifices and/or flow meters.
 - Upstream and downstream of steam traps.
 - Drain and vent connections to large bore piping or components with two-phase flow.
 - Last two changes in direction prior to entering the condenser. (i.e. 90 & 45 degree elbows, reducers, orifices, or globe valves).
 - Events at other plants such as piping failures.
 - Inspection experience from other plant inspection programs, available through the CHECMATE Users Group (CHUG).

V.Y. Piping F.A.C. Inspection Program - Small Bore Component Selection Review

Identification of Small bore components

Not all small bore piping will be included in the program, only the specific small bore locations identified in the Small Bore Data Base. Each location identified has been given a unique point number. The data base is a master list of all small bore locations to be included in the Piping FAC Inspection Program. Locations include the components (valves, steam traps, orifices, etc.) and the adjacent piping and fittings upstream and/or downstream of the components. Additional locations will be included into the database as warranted.

Over time multiple inspections may be performed at the same location (data point). The convention established in 1992 will be used to identify previous inspection data and will be included in the data base.

During each refueling outage the small bore locations inspected will be identified as follows: Each location will be given a unique identifier in the form of:

"YR-SBxx"

where: YR is the year the location is first inspected.
 SB denotes small bore piping (less than 2-1/2" diameter).
 xx a number assigned to the location by the YNSD CE

Example: **93-SB04**

Small Bore Inspection Location Sketches identifying the location in the plant and the components included at each location will be included in the UT inspection report. Details of any grids used, and other data required to identify and/or interpret the inspection data will also be included in each inspection report.

V.Y. Piping F.A.C. Inspection Program - Small Bore Component Selection Review

References

- (a) V.Y. Piping Erosion – Corrosion Inspection Program, Revision 1, dated 2/12/92.
- (b) Draft of EPRI Report NSAC-202L, "Recommendations for an Effective Flow-Accelerated Corrosion Program."

Documentation

Original marked up P&IDs, Isometrics and piping dwgs, used in the review are in the possession of the CE.

Small Bore Component Location Sketches: (Currently located with UT inspection reports in ISI records. The sketches will eventual be included in the Program Manual after more inspections are performed.)

VY Piping FAC Inspection Program: Small Bore Data Base - (attached)

VY PIPING FAC INSPECTION PROGRAM: SMALL BORE DATA BASE

PT.	PREV. INSPECT. No.	SYSTEM	DESCRIPTION	LOCATION	COMMENTS	SIZE	SCH.	T _{nom} inch	T _{min} inch
1	93-SB01	MSD	1" Pipe & Fittings D.S. of valve M-33	Rx. Bldg. Torus Area	MS-33(N.C.)labeled as orifaced valve.	1"	160	.250	.053
2	93-SB02	MSD	1" Pipe & Fittings D.S. of steam trap ST60-3.	Rx. Bldg. Torus Area	Normal flow to condenser is thru ST60-3. (dp=965psi)	1"	160	.250	.053
3	93-SB03	MSD	1" piping D.S. of LCV-2-143	Rx. Bldg. Torus Area	Mn Steam strainer ST60-3 blow down . (dp=965psi)	1"	160	.250	.053
4	93-SB04	MSD	3" & 2½" MSD D. S. of valve MS-79	Rx. Bldg. Torus Area	N.C. valve (dp=965psi)	3" 2½"	160 160	.438 .375	0.141 0.116
5	93-SB05	MSD	3" MSD-4 U.S. of Condenser A.	T. B. - Heater Bay	Industry Experience (IE) point	3"	160 STD	.438 .216	0.141 0.141
6	93-SB06	MSD	1" & 2½" MS-7A D.S. of steam trap, ST-60-2A	T. B. - Heater Bay	(I.E.)	1" 2-1/2"	160 160	.250 .375	.053 .116
7	93-SB07	MSD	1" & 2½" MSD-8A @ LCV-38A.	T. B. - Heater Bay	(I.E.)	1" 2½"	160 160	.250 .375	.053 .116
8		MSD	1" & 2½" MSD-7B D.S. of steam trap, ST-60-2B.	T. B. - Heater Bay	(I.E.)	1" 2-1/2"	160 160	.250 .375	.053 .116
9		MSD	1" & 2½". MSD-8B @ LCV-38B.	T. B. - Heater Bay	(I.E.)	1" 2½"	160 160	.250 .375	.053 .116
10	93-SB09	MSD	1"&2½" MSD-7C D.S. of steam trap ST60-2C.	T. B. - Heater Bay	(I.E.)	1" 2-1/2"	160 160	.250 .375	.053 .116
11	93-SB10	MSD	1" & 2½" MSD-8C @ LCV-38C.	T. B. - Heater Bay	(I.E.)	1" 2½"	160 160	.250 .375	.053 .116
12		MSD	1" & 2½" MSD-7D D.S. of steam trap, ST-60-2D.	T. B. - Heater Bay	(I.E.)	1" 2-1/2"	160 160	.250 .375	.053 .116
13		MSD	1" & 2½" MSD-8D @ LCV-38D.	T. B. - Heater Bay	(I.E.)	1" 2½"	160 160	.250 .375	.053 .116
	93-SB08	MSD	8" MSD-9 Hdr. @ 2½" conn. (See L.B. Sketch 097)	T. B. - Heater Bay	(I.E.)	8"	80	.500	.347
14	93-SB12	MSD	1"&2½" Piping @ valve MS-2A.	T. B. - Heater Bay	(I.E.)	1"	160	.250	.053
15		MSD	1"&2½" Piping @ valve MS-2B.	T. B. - Heater Bay	(I.E.)	1"	160	.250	.053
16	93-SB13	MSD	1"&2½" Piping @ valve MS-2C.	T. B. - Heater Bay	(I.E.)	1" 2½"	160 160	.250 .375	.053 .116
17		MSD	1"&2½" Piping @ valve MS-2D.	T. B. - Heater Bay	(I.E.)	1" 2½"	160 160	.250 .375	.053 .116

VY PIPING FAC INSPECTION PROGRAM: SMALL BORE DATA BASE

PT.	PREV. INSPECT. No.	SYSTEM	DESCRIPTION	LOCATION	COMMENTS	SIZE	SCH.	Tnom inch	T min inch
18	93-SB14	MSD	D.S.of valve MS-4 on 2½" MSD-6.	T. B. - Heater Bay	(I.E.)	2½"	160	.375	.116
19	93-SB15	MSD	2½" MSD-6 @ Fittings U. S. of Condenser A.	T. B. - Heater Bay	(I.E.)	2½"	160	.375	.116
20		MSD	2½" MSD-6. (2 ft. length at Connect to Condenser A	T. B. - Heater Bay	(I.E.)	2½"	160	.375	.116
21	93-SB16	MSD	1" MSD U.S. & D.S.of valve MS-5A. ,	T. B. - Heater Bay	(I.E.)	1"	160	.250	.053
22	93-SB55	MSD	1" MSD U.S. & D.S.of valve MS-5B.	T. B. - Heater Bay	(I.E.)	1"	160	.250	.053
23	93-SB17	MSD	1" MSD U.S. & D.S.of valve MS-5C.	T. B. - Heater Bay	(I.E.)	1"	160	.250	.053
24	93-SB56	MSD	1" MSD U.S. & D.S.of valve MS-5D.	T. B. - Heater Bay	(I.E.)	1"	160	.250	.053
25	93-SB18	MSD	2" MSD hdr. under 5A & 5C valves.	T. B. - Heater Bay	(I.E.)	2"	160	.344	.096
26	93-SB19	MSD	2" pipe & fittings D.S. of valves MS-5A to 5D..	T. B. - Heater Bay	(I.E.)	2"	160	.344	.096
27		MSD	2" pipe & fittings D.S. of valves MS-5A to 5D. at Connect to Condenser. A	T. B. - Heater Bay	(I.E.)	2"	160	.344	.096
28	92-SB10/11	MSD	2" pipe & fittings D.S. of valve MS-12 up to tee conn.	T. B. - Heater Bay	Leak @ MS-12 valve in 1992 Replaced in 1992	2"	80	.218	.096
29	92-SB13 to 92-SB15	MSD	1" pipe & fittings U.S. & D.S. of R.O. 60-1 up to tee conn.	T. B. - Heater Bay	Replaced in 1992.	1"	80	.179	.053
30	92-SB12	MSD	2" piping D.S of tee conn. D.S. of R.O.60-1.	T. B. - Heater Bay	Leak @MS-12 valve in 1992	2"	80	.218	.096
31		MSD (HPCI)	1" pipe & fittings D.S. of valve HPCI FCV -43	RX. - HPCI Room.	Replaced in 1990, w/ A335-P11	1"	80	.179	.053
32		MSD (RCIC)	2" pipe & fittings D.S. of valve RCIC FCV-35	RX. - RCIC Room	Replaced in 1990, w/ A335-P11	2"	80	.218	.096
33		MSD (HPCI/RCIC)	2" pipe & fittings U.S. of connect. to Condenser B.	T.B. - Heater Bay	Replaced in 1990, w/ A335-P11	2"	80	.218	.096

VY PIPING FAC INSPECTION PROGRAM: SMALL BORE DATA BASE

PT.	PREV. INSPECT. No.	SYSTEM	DESCRIPTION	LOCATION	COMMENTS	SIZE	SCH.	Tnom inch	T min inch
34	93-SB20	HV	1"-HV-1A, pipe & fittings U.S. of connect. to Cond. B.	T. B. - Heater Bay	Industry Experience Point	1"	80	.179	.011
35	93-SB21	HV	1"HV -1A, pipe & fittings D.S. of R.O.-1A	T. B. - Heater Bay	Industry Experience Point	1"	80	.179	.011
36	93-SB22	HV	1"HV-1A, pipe & fittings @ valve HV-1A	T. B. - Heater Bay	Industry Experience Point	1"	80	.179	.011
37		HV	1"-HV-1B. pipe & fittings U.S. of connect. to Cond. B	T. B. - Heater Bay	Industry Experience Point	1"	80	.179	.011
38		HV	1"- HV-1B, pipe & fittings D.S. of R.O.-1B	T. B. - Heater Bay	Industry Experience Point	1"	80	.179	.011
39		HV	1"-HV-1B, pipe & fittings @ valve HV-1B	T. B. - Heater Bay	Industry Experience Point	1"	80	.179	.011
40		HV	1"-HV-2A, pipe & fittings @ valve HV- 4B	T. B. - Heater Bay	Industry Experience Point	1"	80	.179	.007
41		HV	1"-HV-2A, pipe & fittings @ R.O.-2A.	T. B. - Heater Bay	Industry Experience Point	1"	80	.179	.007
42		HV	1"-HV-2A, pipe & fittings @ Condenser A.	T. B. - Heater Bay	Industry Experience Point	1"	80	.179	.007
43	93-SB23	HV	1"-HV-2B, pipe & fittings @ valve HV- 4B	T. B. - Heater Bay	Industry Experience Point	1"	80	.179	.007
44	93-SB24	HV	1"-HV-2B, pipe & fittings @ R.O.-2B.	T. B. - Heater Bay	Industry Experience Point	1"	80	.179	.007
45	93-SB25	HV	1"-HV-2B, pipe & fittings @	T. B. - Heater Bay	Industry Experience Point	1"	80	.179	.007
46		HV	1½"-HV-3A, pipe & fittings @ valve HV- 7A	T. B. - Heater Bay	Industry Experience Point	1½"	80	.200	.007
47		HV	1½"-HV-3A, pipe & fittings @ Condenser A.	T. B. - Heater Bay	Industry Experience Point	1½"	80	.200	.007
48		HV	2"-HV-9A, pipe & fittings.@ R.O.-3A.	T. B. - Heater Bay	Industry Experience Point	2"	80	.218	.008
49		HV	2"-HV-9A, pipe & fittings D.S. of valve HV- 15A	T. B. - Heater Bay	(I.E)	2"	80	.218	.008
50		HV	2"-HV-9A, pipe & fittings.@ Condenser A.	T. B. - Heater Bay	(I.E)	2"	80	.218	.008
51		HV	1½"-HV-3B, pipe & fittings @ valve HV- 7B	T. B. - Heater Bay	(I.E)	1½"	80	.200	.007
52		HV	1½"-HV-3B, pipe & fittings @ Condenser A.	T. B. - Heater Bay	(I.E)	1½"	80	.200	.007

VY PIPING FAC INSPECTION PROGRAM: SMALL BORE DATA BASE

PT.	PREV. INSPECT. No.	SYSTEM	DESCRIPTION	LOCATION	COMMENTS	SIZE	SCH.	T _{nom} inch	T _{min} inch
53		HV	2"-HV-9B, pipe & fittings @ R.O.-3B.	T. B. - Heater Bay	(I.E)	2"	80	.218	.008
54		HV	2"-HV-9B, pipe & fittings D.S. of valve HV- 15B	T. B. - Heater Bay	(I.E)	2"	80	.218	.008
55		HV	2"-HV-9B, pipe & fittings @ Condenser A.	T. B. - Heater Bay	(I.E)	2"	80	.218	.008
56		HV	2½"-HV-4A, pipe & fittings U.S. of connect. to Cond. B.	T. B. - Heater Bay	Industry Experience Point	1"	80	.179	.011
57		HV	2½"-HV -4A, pipe & fittings D.S. of R.O.-4A	T. B. - Heater Bay	Industry Experience Point	1"	80	.179	.011
58		HV	2½"-HV-4A, pipe & fittings @ valve HV-9A	T. B. - Heater Bay	Industry Experience Point	1"	80	.179	.011
59		HV	2½"-HV-4B. pipe & fittings U.S. of connect. to Cond. B	T. B. - Heater Bay	Industry Experience Point	1"	80	.179	.011
60		HV	2½"- HV-4B, pipe & fittings D.S. of R.O.-4B	T. B. - Heater Bay	Industry Experience Point	1"	80	.179	.011
61		HV	2½"-HV-4B, pipe & fittings @ valve HV-9B	T. B. - Heater Bay	Industry Experience Point	1"	80	.179	.011
62		ES	2"-ES-12A piping US & DS of LCV-2A near Condenser A	T. B. - Heater Bay	Industry Experience Point	2"	80	.218	.012
63		ES	2"-ES-10A piping US & DS of LCV-3A near Condenser A	T. B. - Heater Bay	Industry Experience Point	2"	80	.218	.012
64	93-SB26	ES	2"-ES-12B piping US & DS of LCV-2B near Condenser B.	T. B. - Heater Bay	Industry Experience Point	2"	80	.218	.012
65	93-SB27	ES	2"-ES-10B piping US &DS of LCV-3B near Condenser B	T. B. - Heater Bay	Industry Experience Point	2"	80	.218	.012
66	93-SB28	AS	1" piping US &DS of valve LCV-101-39	T.B. - SJA E Room.	Industry Experience Point	1"	160	.250	.053
67	93-SB29	AS	1" & 2" piping US &DS of steam trap ST 62-1.	T.B. - SJA E Room.	Industry Experience Point	1" 2"	160 160	.250 .344	.053 .096
68	93-SB30	AS	2"-MSD-465 pipe & fittings @ connect. to Condenser B	T.B. - Heater Bay	Industry Experience Point	2"	160	.344	.096
69		AS	2"-MSD-465 pipe & fittings DS of valve V-62-2	T.B. - SJA E Room.	Industry Experience Point	1"	160	.250	.053
70		AS	1" piping US &DS of valve LCV-101-40	T.B. - SJA E Room.	Industry Experience Point	1"	160	.250	.053

VY PIPING FAC INSPECTION PROGRAM: SMALL BORE DATA BASE

PT.	PREV. INSPECT. No.	SYSTEM	DESCRIPTION	LOCATION	COMMENTS	SIZE	SCH.	Tnom inch	T min inch
71		AS	1" & 1½" piping US & DS of steam trap ST 62-2.	T.B. - SJAE Room.	Industry Experience Point	1" 2"	160 160	.250 .344	.053 .096
72		AS	1½" -MSD-464 pipe & fittings @ connect. to Condenser B	T.B. - Heater Bay	Industry Experience Point	2"	160	.344	.096
73		AS(AOG)	2" piping of DS of valve OG PRV -834A	T.B. - Heater Bay El.248.	Industry Experience Point	1"	160	.250	.053
74		AS(AOG)	¾" piping US & DS of steam trap MS-113-1A.	T.B. - Heater Bay El.248.	Industry Experience Point	1" 2"	160 160	.250 .344	.053 .096
75		AS(AOG)	¾" piping US & DS of steam trap MS115-1A	T.B. - Heater Bay El.248.	Industry Experience Point	2"	160	.344	.096
76		AS(AOG)	¾"MS-189-D3 AS drain from OG @ connect. to 3"-MSD-4.	T.B. - Heater Bay El 233'-4"	Industry Experience Point	2"	160	.344	.096
77		AS(AOG)	¾"HCN-188-H1 AS drain from OG @ conn. to 3"-MSD-4.	T.B. - Heater Bay El 233'-4"	I. E. Point, Replaced prior to 1990	2"	160	.344	.096
78	93-SB31	SSL	1½" & 3" Header for 1SLMSV off Turbine Stop Valves	T.B. - Heater Bay.	Industry Experience Point	1½" 3"	80 40	.200 .216	.077 .141
79	93-SB32	SSL	1½"-1SLMSV - Stop Valve A	T.B. - Heater Bay	Industry Experience Point	1½"	80	.200	.077
80	93-SB33	SSL	1½"-1SLMSV - Stop Valve B	T.B. - Heater Bay	Industry Experience Point	1½"	80	.200	.077
81	93-SB34	SSL	1½"-1SLMSV - Stop Valve C	T.B. - Heater Bay	Industry Experience Point	1½"	80	.200	.077
82	93-SB35	SSL	1½"-1SLMSV - Stop Valve D	T.B. - Heater Bay	Industry Experience Point	1½"	80	.200	.077
83	93-SB36	SSL	1½" Header for 1SCVL off Turbine Control Valves	T.B. - Heater Bay		1½"	80	.200	.067
83	93-SB38	SSL	½"-1SCVL - Control Valve A.	T.B. - Heater Bay		½"	80	.147	.033
85	93-SB39/40	SSL	½"-1SCVL - Control Valve B.	T.B. - Heater Bay		½"	80	.147	.033
86	93-SB41/42	SSL	½"-1SCVL - Control Valve C.	T.B. - Heater Bay		½"	80	.147	.033
87	93-SB37	SSL	½"-1SCVL - Control Valve D.	T.B. - Heater Bay		½"	80	.147	.033
88	93-SB43	SSL	1" & 3" Header for 2SLMSV off Turbine Stop Valves A & B	T.B. - Heater Bay		2-1/2" 1"	40 80	.203 .179	.116 .053
89	93-SB44	SSL	1" & 3" Header for 2SLMSV off Turbine Stop Valve C	T.B. - Heater Bay		3" 1"	40 80	.216 .179	.141 .053
90	93-SB45	SSL	1" - 2SLMSV off Turbine Stop Valve D	T.B. - Heater Bay		3" 1"	40 80	.216 .179	.141 .053
91	93-SB58	SSL	2½" - Header for 2SCVL off Turbine Control Valves	T.B. - Heater Bay		1"	80	.179	.053
92	93-SB61	SSL	1" - 2SCVL off Control Valve A	T.B. - Heater Bay		2½"	40	.203	.116
93	93-SB60	SSL	1" - 2SCVL off Control Valve B	T.B. - Heater Bay		1"	80	.179	.053

VY PIPING FAC INSPECTION PROGRAM: SMALL BORE DATA BASE

PT.	PREV. INSPECT. No.	SYSTEM	DESCRIPTION	LOCATION	COMMENTS	SIZE	SCH.	Tnom inch	T min inch
94	93-SB59	SSL	1" - 2SCVL off Control Valve C	T.B. - Heater Bay		1"	80	.179	.053
95	93-SB57	SSL	1" - 2SCVL off Control Valve D	T.B. - Heater Bay		1"	80	.179	.053
96	92-(SB-info only)	SSL	Turbine Bypass Valve Chest 1st Seal Leakoff 1/2"-1SLBPV	T.B. - Heater Bay	1/2' pipes of f BPV chest	1/2"	80	.147	.034
97	92-SB01	SSL	TBV Chest 1st Seal Leakoff 2"-1SLBPV	T.B. - Heater Bay		2"	80	.218	.099
98	92-SB02	SSL	TBV Chest 1st Seal Leakoff 2"-1SLBPV	T.B. - Heater Bay		2"	80	.218	.099
99	92-SB03	SSL	TBV Chest 1st Seal Leakoff 2"-1SLBPV	T.B. - Heater Bay		2"	80	.218	.099
100	92-SB04	SSL	TBV Chest 1st Seal Leakoff 2"-1SLBPV	T.B. - Heater Bay		2"	80	.218	.099
101	92-SB05	SSL	TBV Chest 1st Seal Leakoff 2"-1SLBPV	T.B. - Heater Bay		2"	80	.218	.099
102	92-SB06	SSL	TBV Chest 1st Seal Leakoff 2"-1SLBPV	T.B. - Heater Bay	Not Inspected in 1992	2"	80	.218	.099
103	92-SB07	SSL	TBV Chest 1st Seal Leakoff 2"-1SLBPV	T.B. - Heater Bay		2"	80	.218	.099
104	92-SB08	SSL	TBV Chest 1st Seal Leakoff 2"-1SLBPV	T.B. - Heater Bay		2"	80	.218	.099
105	92-SB 09	SSL	TBV Chest 1st Seal Leakoff 2"-1SLBPV	T.B. - Heater Bay	Vertical section replaced in 1992.	2"	80	.218	.099
106	92-SB 10	SSL	TBV Chest 1st Seal Leakoff 2"-1SLBPV	T.B. - Heater Bay	Location of 1992 leak, replaced in 1992.	2"	80	.218	.099
107	93-SB46	SSL	TBV Chest 2nd Seal Leakoff 2½" - 2SLBPV	T.B. - Heater Bay	Continuation of 1992 inspections	2½"	40	.203	.116
108	93-SB47	SSL	TBV Chest 2nd Seal Leakoff 2½" - 2SLBPV	T.B. - Heater Bay	" "	2½"	40	.203	.116
109	93-SB48A 93-SB48B	SSL	TBV Chest 2nd Seal Leakoff 2½" - 2SLBPV	T.B. - Heater Bay	" "	2½"	40	.203	.116
110	93-SB49	SSL	2½" - 1SPL2 H.P. Turbine Pocket Drain	T.B. - Heater Bay	Significant Wear @ Duane Arnold	2½"	40	.203	.023
111	93-SB50	SSL	2½" - 1SPL2 H.P. Turbine Pocket Drain	T.B. - Heater Bay	" "	2½"	40	.203	.023
112	93-SB51	SSL	2½" - 1SPL2 H.P Turbine Pocket Drain	T.B. - Heater Bay	" "	2½"	40	.203	.023

VY PIPING FAC INSPECTION PROGRAM: SMALL BORE DATA BASE

PT.	PREV. INSPECT. No.	SYSTEM	DESCRIPTION	LOCATION	COMMENTS	SIZE	SCH.	T nom inch	T min inch
113	93-SB52	SSL	2½" - 1SPL2 H.P. Turbine Pocket Drain	T.B. - Heater Bay	" "	2½"	40	.203	.023
114	93-SB53	SSL	2½" - 1SPL2 H.P. Turbine Pocket 90 deg elbow	T.B. - Heater Bay	" "	2½"	40	.203	.023
115	93-SB54	SSL	1SPL2 2½" x 2" reducer at 36" CAR pipe.	T.B. - Heater Bay	" "	2½" 2"	40 40	.203 .154	.023 .019
116		C	1½" & 2½" piping US & DS of LCV 1A-3	T.B. - Heater Bay	(I.E)	1½" 2½"	80 80	.200 .276	.038 .057

NOTES:

I.E. Denotes Industry Experience Point

Vermont Yankee
Piping F.A.C. Inspection Program
Small Bore Piping
Component Selection Review

Prepared By Vermont Yankee Design Engineering, Mechanical/Structural Group

Revision 1, December 6, 1999


Prepared By:



Date: 12/6/99

Joseph Fortier
Mechanical/Structural Group
Vermont Yankee Design Engineering

Reviewed By:



Date: 12/6/99

James C. Fitzpatrick
Mechanical/Structural Group
Vermont Yankee Design Engineering

V.Y. Piping F.A.C. Inspection Program - Small Bore Component Selection Review

Introduction / Purpose

The purpose of this paper is to document and to formalize the process used in the selection of small bore piping components to be considered as susceptible to wall thinning due to flow accelerated corrosion (FAC).

Small bore piping locations identified as susceptible to FAC are comprised of either single piping components or groups of components (straight pipes, elbows, reducers, & tees, etc.). The susceptible locations are identified using the Vermont Yankee Piping & Instrumentation Diagrams (P&IDs) and screening criteria listed in this paper.

The locations identified on the P&IDs will be included in a data base of susceptible piping components. These will be considered for inspection under the Vermont Yankee Piping Flow Accelerated Corrosion (FAC) Inspection Program.

Most small bore piping is original plant equipment and has been in service since 1972. The majority of this piping is carbon steel. Given approx. 27 years of service, high wear locations should have made themselves evident. However, some sections of small bore piping have been replaced during equipment replacement and/or repairs.

Inspection data for small bore components prior to 1992 may be available, but there has been no dedicated data base which documents and trends small bore replacements. A detailed search of Maintenance work orders records will be required to obtain this information. Inspections of small bore components performed under the Piping FAC Program began in 1992. Since then approximately 83% of the small bore lines identified as susceptible to FAC have been inspected. Some have multiple inspections. Small bore inspections of the data base locations will continue until all locations are either inspected or judged as not susceptible to FAC damage.

For the Piping FAC Inspection Program, long term tracking of wear in small bore piping will not generally be performed. CHECWORKS modeling and evaluations will not typically be performed for small bore piping. Given the cost of performing inspections, components and attached piping which exhibit FAC damage will preferably be replaced with FAC resistant materials.

V.Y. Piping F.A.C. Inspection Program - Small Bore Component Selection Review

Small Bore Piping: Susceptible System Selection:

Small bore lines, 2-1/2 inch nominal diameter and smaller are included in the program based on industry and plant experience, possible effects on personnel safety, consequences to plant availability, and possible negative effects to the plant licensing basis.

(Example: a small steam leak in the Reactor Building may adversely effect the fire protection systems and/or electrical equipment in the EQ program).

Criteria for inclusion:

1. Piping diameter 2-1/2" nominal or less. (Note: some 3" segments are included).
2. Design Pressure > 275Psi. and/or Design Temperature > 200°F
3. Piping Material Chrome Content < 5%.
4. Steam Quality < 99%
5. System in use > 2% of Plant Operating Hours (Note: systems in use < 2% of plant operating hours are not automatically excluded).
6. Consequences of leak or failure on personnel safety and plant operation.

Results:

A review of the VY P&ID's using the criteria above, shows portions of the following systems may be susceptible to FAC:

<u>System</u>	<u>Symbol</u>	<u>P&ID's</u>
Auxiliary Steam	AS	G191156, 33600-A217(AOG by Suntac)
Main Steam Drains	MSD	G191156, G191157, G191169, G191174
Extraction Steam	ES	G191156
Condensate	C	G191157
Heater Vents	HV	G191158
Control Rod Drive	CRD	G191170
Reactor Water Cleanup	CUW	G191178
Heating Steam	HS	G191254
Turbine Steam Seal & Leakoff Lines	(various)	5920-224(by GE)

V.Y. Piping F.A.C. Inspection Program - Small Bore Component Selection Review

Small Bore Piping: Identification of Susceptible Piping Components

The following criteria are used to identify Small bore piping components or groups of components susceptible to FAC.

1. The implications of a failure of the line or component on personnel safety, plant availability, and possible negative effects to the plant licensing basis. Priority should be given to sections of piping that cannot be readily isolated.
2. Observed fluid leakage through normally closed valves or blow by in steam traps during operation as indicated in plant work orders and/or the turbine performance monitoring system.
3. Data from previous inspections and continued monitoring of components which have been replaced with either carbon or low alloy steels.
4. Generic Industry Experience (IE) Components which are locations in plant piping systems that have experienced failures and/or have been found to exhibit wall thinning due to FAC. Industry Experience Components include but are not limited to:
 - Downstream of flow control valves.
 - Downstream of orifices and/or flow meters.
 - Upstream and downstream of steam traps.
 - Drain and vent connections to large bore piping or components with two-phase flow.
 - Last two changes in direction prior to entering the condenser. (i.e. 90 & 45 degree elbows, reducers, orifices, or globe valves).
 - Events at other plants such as piping failures.
 - Inspection experience from other plant inspection programs, available through the CHECWORKS Users Group (CHUG).

V.Y. Piping F.A.C. Inspection Program - Small Bore Component Selection Review

Identification of Small bore components

Not all small bore piping will be inspected under the program, only the specific small bore locations identified in the Small Bore Data Base. Each location identified has been given a unique point number. The data base is a master list of all small bore locations to be included in the Piping FAC Inspection Program. Locations include the components (valves, steam traps, orifices, etc.) and the adjacent piping and fittings upstream and/or downstream of the components. Additional locations will be included into the database as warranted.

Over time multiple inspections may be performed at the same location (data point). The convention established in 1992 will be used to identify previous inspection data and will be included in the data base.

During each refueling outage the small bore locations inspected will be identified as follows: Each location will be given a unique identifier in the form of:

"YR-SBxx"

- where:
- YR** - is the year the location is inspected.
 - SB** - denotes small bore piping (less than 2-1/2" diameter).
 - xx** - a number assigned to the location by the FAC Program Coordinator

Example: **93-SB04**

Small Bore Inspection Location Sketches identifying the location in the plant and the components inspected at each location will be included in the UT inspection report. Details of any grids used, and other data required to identify and/or interpret the inspection data will also be included in each inspection report.

V.Y. Piping F.A.C. Inspection Program - Small Bore Component Selection Review

References

- (a) V.Y. Piping Flow Accelerated Corrosion Inspection Program, Revision 2, dated 3/7/95.
- (b) EPRI Report NSAC-202L-R2, "Recommendations for an Effective Flow-Accelerated Corrosion Program."

Documentation

Original marked up P&IDs, Isometrics and piping dwgs, used in the review are in the possession of the FAC Program Coordinator.

Small Bore Component Location Sketches: are located with the UT inspection reports permanently stored with the ISI records.

VY Piping FAC Inspection Program: Small Bore Data Base - (attached pages 7 to 15)

Drawing List:

1. G191167, Flow Diagram – Nuclear Boiler, Revision 62
2. G191156, Flow Diagram – Main, Extraction and Auxiliary Steam Systems, Revision 29
3. G191169 Sheets 1 & 2, High Pressure Coolant Injection System, Revisions 40 & 36
4. G191174 Sheets 1 & 2, Reactor Core Isolation Cooling System, Revision 36 & 23
5. G191158, Flow Diagram – Heater Drain and Vent system, Revision 23
6. 33600-A217, Flow Diagram – Turbine Building Area, AOG, Revision 17
7. 5920-224, Diagram of Steam Seal Piping, Revision 9

VY PIPING FAC INSPECTION PROGRAM - SMALL BORE INSPECTION LOCATIONS
 Revision 1, 12/6/1999

PT.	PREV. INSPECT. No.	SYSTEM	DESCRIPTION	LOCATION	DRAWINGS	COMMENTS	SIZE	SCH.	Tnom inch	T min inch
1	93-SB01	MSD	1" Pipe & Fittings D.S. of valve M-33	Rx. Bldg. Torus Area	G191167	MS-33(N.C.)labeled as orifaced valve.	1"	160	.250	.053
2	93-SB02 95-SB01	MSD	1" Pipe & Fittings D.S. of steam trap ST60-3.	Rx. Bldg. Torus Area	G191167	Normal flow to condenser is thru ST60-3. (dp=965psi)	1"	160	.250	.053
3	93-SB03	MSD	1" piping D.S. of LCV-2-143	Rx. Bldg. Torus Area	G191167	Mn Steam strainer ST60-3 blow down . (dp=965psi)	1"	160	.250	.053
4	93-SB04	MSD	3" & 2½" MSD D. S. of valve MS-79 (3"-MSD-4)	Rx. Bldg. Torus Area	G191167	N.C. valve (dp=965psi)	3" 2½"	160 160	.438 .375	0.141 0.116
5	93-SB05	MSD	3" MSD-4 U.S. of Condenser A. Nozzle 67	T. B. - Heater Bay	G191156	IE	3"	160 STD	.438 .216	0.141 0.141
6	93-SB06	MSD	1" & 2½" MSD-7A D.S. of steam trap, ST-60-2A	T. B. - Heater Bay	G191156	IE	1" 2-1/2"	160 160	.250 .375	.053 .116
7	93-SB07	MSD	1" & 2½" MSD-8A @ LCV-38A.	T. B. - Heater Bay	G191156	IE	1" 2½"	160 160	.250 .375	.053 .116
8	95-SB03	MSD	1" & 2½" MSD-7B D.S. of steam trap, ST-60-2B.	T. B. - Heater Bay	G191156	IE	1" 2-1/2"	160 160	.250 .375	.053 .116
9	95-SB04	MSD	1" & 2½". MSD-8B @ LCV-38B.	T. B. - Heater Bay	G191156	IE	1" 2½"	160 160	.250 .375	.053 .116
10	93-SB09	MSD	1"&2½" MSD-7C D.S. of steam trap ST60-2C.	T. B. - Heater Bay	G191156	IE	1" 2-1/2"	160 160	.250 .375	.053 .116
11	93-SB10 95-SB02	MSD	1" & 2½" MSD-8C @ LCV-38C.	T. B. - Heater Bay	G191156	IE	1" 2½"	160 160	.250 .375	.053 .116
12	95-SB05	MSD	1" & 2½" MSD-7D D.S. of steam trap, ST-60-2D.	T. B. - Heater Bay	G191156	IE	1" 2-1/2"	160 160	.250 .375	.053 .116
13	95-SB-06	MSD	1" & 2½" MSD-8D @ LCV-38D.	T. B. - Heater Bay	G191156	IE	1" 2½"	160 160	.250 .375	.053 .116
	93-SB08	MSD	8" MSD-9 Hdr. @ 2½" conn. (See L.B. Sketch 097)	T. B. - Heater Bay	G191156	(IE) Portions of LB component inspected with SB pipe.	8"	80	.500	.347

VY PIPING FAC INSPECTION PROGRAM - SMALL BORE INSPECTION LOCATIONS

Revision 1, 12/6/1999

PT.	PREV. INSPECT. No.	SYSTEM	DESCRIPTION	LOCATION	DRAWINGS	COMMENTS	SIZE	SCH.	T nom inch	T min inch
14	93-SB12	MSD	1"&2½" Piping @ valve MS-2A.	T. B. - Heater Bay	G191156	IE	1"	160	.250	.053
15	95-SB-07	MSD	1"&2½" Piping @ valve MS-2B.	T. B. - Heater Bay	G191156	IE	1"	160	.250	.053
16	93-SB13	MSD	1"&2½" Piping @ valve MS-2C.	T. B. - Heater Bay	G191156	IE	1" 2½"	160 160	.250 .375	.053 .116
17	95-SB08	MSD	1"&2½" Piping @ valve MS-2D.	T. B. - Heater Bay	G191156	IE	1" 2½"	160 160	.250 .375	.053 .116
18	93-SB14	MSD	D.S.of valve MS-4 on 2½" MSD-6.	T. B. - Heater Bay	G191156	IE	2½"	160	.375	.116
19	93-SB15	MSD	2½" MSD-6 @ Fittings U. S. of Condenser A.	T. B. - Heater Bay	G191156	IE	2½"	160	.375	.116
20	95-SB09 96-SB01	MSD	2½" MSD-6. (2 ft. length at Connect. to Conden. A -Noz.33	T. B. - Heater Bay	G191156	IE	2½"	160	.375	.116
21	93-SB16	MSD	1" MSD U.S. & D.S.of valve MS-5A. ,	T. B. - Heater Bay	G191156	IE	1"	160	.250	.053
22	93-SB55	MSD	1" MSD U.S. & D.S.of valve MS-5B.	T. B. - Heater Bay	G191156	IE	1"	160	.250	.053
23	93-SB17	MSD	1" MSD U.S. & D.S.of valve MS-5C.	T. B. - Heater Bay	G191156	IE	1"	160	.250	.053
24	93-SB56	MSD	1" MSD U.S. & D.S.of valve MS-5D.	T. B. - Heater Bay	G191156	IE	1"	160	.250	.053
25	93-SB18	MSD	2" MSD hdr. Under 5A & 5C valves.	T. B. - Heater Bay	G191156	IE	2"	160	.344	.096
26	93-SB19	MSD	2" pipe & fittings D.S. of valves MS-5A to 5D..	T. B. - Heater Bay	G191156	IE	2"	160	.344	.096
27	95-SB10	MSD	2" pipe & fittings D.S. of valves MS-5A to 5D. at Connect to Condenser. A Noz.34	T. B. - Heater Bay	G191156	IE	2"	160	.344	.096
28	92-SB10 92-SB11 95-SB38	MSD	2" pipe & fittings D.S. of valve MS-12 up to tee conn.	T. B. - Heater Bay	G191156	Leak @ MS-12 valve in 1992 Replaced in 1992	2"	80	.218	.096

VY PIPING FAC INSPECTION PROGRAM - SMALL BORE INSPECTION LOCATIONS
 Revision 1, 12/6/1999

PT.	PREV. INSPECT. No.	SYSTEM	DESCRIPTION	LOCATION	DRAWINGS	COMMENTS	SIZE	SCH.	Tnom inch	T min inch
29	92-SB13 to 92-SB15 95-SB11	MSD	1" pipe & fittings U.S. & D.S. of R.O. 60-1 up to tee conn.	T. B. - Heater Bay	G191156	Replaced in 1992.	1"	80	.179	.053
30A	92-SB12 95-SB12	MSD	2" piping D.S of tee conn. D.S. of R.O.60-1.	T. B. - Heater Bay	G191156	Leak @MS-12 valve in 1992 Replaced in 96 W/ A335 P11	2"	80	.218	.096
30B	95-SB12	MSD	2" piping D.S of tee conn. D.S. of R.O. 60-1. at condenser	T. B. - Heater Bay	G191156	Replaced in 96 W/ A335 P11				
31	96-SB03	MSD (HPCI)	1" pipe & fittings D.S. of valve HPCI FCV - 43	RX. - HPCI Room.	G191169 VYI-HPCI/RCIC-DRAIN	Replaced in 1990, w/ A335-P11	1"	80	.179	.053
32	96-SB04	MSD (RCIC)	1" pipe & fittings D.S. of valve RCIC FCV-35	RX. - RCIC Room	G191174 VYI-HPCI/RCIC-DRAIN	Replaced in 1990, w/ A335-P11	2"	80	.218	.096
33		MSD (HPCI/RCIC)	2" pipe & fittings U.S. of connect. to Condenser B.	T.B. - Heater Bay	G191156 VYI-HPCI/RCIC-DRAIN	Replaced in 1990, w/ A335-P11	2"	80	.218	.096
34	93-SB20	HV	1"-HV-1A, pipe & fittings U.S. of connect. to Cond. B.	T. B. - Heater Bay	G191158	Industry Experience Point	1"	80	.179	.011
35	93-SB21	HV	1" HV -1A, pipe & fittings D.S. of R.O.-1A	T. B. - Heater Bay	G191158	Industry Experience Point	1"	80	.179	.011
36	93-SB22	HV	1" HV-1A, pipe & fittings @ valve HV-1A	T. B. - Heater Bay	G191158	Industry Experience Point	1"	80	.179	.011
37	95-SB17	HV	1"-HV-1B. pipe & fittings U.S. of connect. to Cond. B	T. B. - Heater Bay	G191158	Industry Experience Point	1"	80	.179	.011
38	95-SB16	HV	1"- HV-1B, pipe & fittings D.S. of R.O.-1B	T. B. - Heater Bay	G191158	Industry Experience Point	1"	80	.179	.011
39	95-SB18	HV	1"-HV-1B, pipe & fittings @ valve HV-1B	T. B. - Heater Bay	G191158	Industry Experience Point	1"	80	.179	.011
40	95-SB19 98-SB01	HV	1"-HV-2A, pipe & fittings @ valve HV-4A	T. B. - Heater Bay	G191158	Industry Experience Point	1"	80	.179	.007

VY PIPING FAC INSPECTION PROGRAM - SMALL BORE INSPECTION LOCATIONS

Revision 1, 12/6/1999

PT.	PREV. INSPECT. No.	SYSTEM	DESCRIPTION	LOCATION	DRAWINGS	COMMENTS	SIZE	SCH.	Tnom inch	T min inch
41	95-SB20 98-SB02	HV	1"-HV-2A, pipe & fittings @ R.O.-2A.	T. B. - Heater Bay	G191158	Industry Experience Point	1"	80	.179	.007
42	95-SB21 98-SB03	HV	1"-HV-2A, pipe & fittings @ Condenser A.	T. B. - Heater Bay	G191158	Industry Experience Point	1"	80	.179	.007
43	93-SB23	HV	1"-HV-2B, pipe & fittings @ valve HV-4B	T. B. - Heater Bay	G191158	Industry Experience Point	1"	80	.179	.007
44	93-SB24	HV	1"-HV-2B, pipe & fittings @ R.O.-2B.	T. B. - Heater Bay	G191158	Industry Experience Point	1"	80	.179	.007
45	93-SB25	HV	1"-HV-2B, pipe & fittings @ condenser A	T. B. - Heater Bay	G191158	Industry Experience Point	1"	80	.179	.007
46		HV	1½"-HV-3A, pipe & fittings @ valve HV-7A	T. B. - Heater Bay	G191158	Industry Experience Point	1½"	80	.200	.007
47	95-SB22	HV	1½"-HV-3A, pipe & fittings @ Condenser A. Nozzle 23	T. B. - Heater Bay	G191158	Industry Experience Point	1½"	80	.200	.007
48		HV	2"-HV-9A, pipe & fittings. @ R.O.-3A.	T. B. - Heater Bay	G191158	Industry Experience Point	2"	80	.218	.008
49		HV	2"-HV-9A, pipe & fittings D.S. of valve HV- 15A	T. B. - Heater Bay	G191158	IE	2"	80	.218	.008
50		HV	2"-HV-9A, pipe & fittings. @ Condenser A.	T. B. - Heater Bay	G191158	IE	2"	80	.218	.008
51		HV	1½"-HV-3B, pipe & fittings @ valve HV-7B	T. B. - Heater Bay	G191158	IE	1½"	80	.200	.007
52	95-SB23	HV	1½"-HV-3B, pipe & fittings @ Condenser A.	T. B. - Heater Bay	G191158	IE	1½"	80	.200	.007
53		HV	2"-HV-9B, pipe & fittings. @ R.O.-3B.	T. B. - Heater Bay	G191158	IE	2"	80	.218	.008
54		HV	2"-HV-9B, pipe & fittings D.S. of valve HV- 15B	T. B. - Heater Bay	G191158	IE	2"	80	.218	.008

VY PIPING FAC INSPECTION PROGRAM - SMALL BORE INSPECTION LOCATIONS

Revision 1, 12/6/1999

PT.	PREV. INSPECT. No.	SYSTEM	DESCRIPTION	LOCATION	DRAWINGS	COMMENTS	SIZE	SCH.	Tnom inch	T min inch
55		HV	2"-HV-9B, pipe & fittings. @ Condenser A.	T. B. - Heater Bay	G191158	IE	2"	80	.218	.008
56		HV	2½"-HV-4A, pipe & fittings U.S. of connect. to Cond. B.	T. B. - Heater Bay	G191158	Industry Experience Point	1"	80	.179	.011
57		HV	2½"-HV-4A, pipe & fittings D.S. of R.O.-4A	T. B. - Heater Bay	G191158	Industry Experience Point	1"	80	.179	.011
58		HV	2½"-HV-4A, pipe & fittings @ valve HV-9A	T. B. - Heater Bay	G191158	Industry Experience Point	1"	80	.179	.011
59		HV	2½"-HV-4B. pipe & fittings U.S. of connect. to Cond. B	T. B. - Heater Bay	G191158	Industry Experience Point	1"	80	.179	.011
60		HV	2½"-HV-4B, pipe & fittings D.S. of R.O.-4B	T. B. - Heater Bay	G191158	Industry Experience Point	1"	80	.179	.011
61		HV	2½"-HV-4B, pipe & fittings @ valve HV-9B	T. B. - Heater Bay	G191158	Industry Experience Point	1"	80	.179	.011
62	95-SB24 98-SB08	ES	2"-ES-12A piping US & DS of LCV-2A near Condenser A	T. B. - Heater Bay	G191156	Industry Experience Point	2"	80	.218	.012
63	95-SB25	ES	2"-ES-10A piping US & DS of LCV-3A near Condenser A	T. B. - Heater Bay	G191156	Industry Experience Point	2"	80	.218	.012
64	93-SB26	ES	2"-ES-12B piping US & DS of LCV-2B near Condenser B.	T. B. - Heater Bay	G191156	Industry Experience Point	2"	80	.218	.012
65	93-SB27 98-SB09	ES	2"-ES-10B piping US & DS of LCV-3B near Condenser B	T. B. - Heater Bay	G191156	Industry Experience Point	2"	80	.218	.012
66	93-SB28	AS	1" piping US & DS of valve LCV-101-39	T.B. - SJAЕ Room.	G191156	Industry Experience Point	1"	160	.250	.053
67	93-SB29 98-SB04	AS	1" & 2" piping US & DS of steam trap ST 62-1.	T.B. - SJAЕ Room.	G191156	Industry Experience Point	1" 2"	160 160	.250 .344	.053 .096

VY PIPING FAC INSPECTION PROGRAM - SMALL BORE INSPECTION LOCATIONS
Revision 1, 12/6/1999

PT.	PREV. INSPECT. No.	SYSTEM	DESCRIPTION	LOCATION	DRAWINGS	COMMENTS	SIZE	SCH.	Tnom inch	T min inch
68	93-SB30 98-SB03	AS	2"-MSD-465 pipe & fittings @ connect. to Condenser B Nozzle 68	T.B. - Heater Bay	G191156	Industry Experience Point	2"	160	.344	.096
69	95-SB26	AS	2"-MSD-465 pipe & fittings DS of valve V-62-2	T.B. - SJAE Room.	G191156	Industry Experience Point	1"	160	.250	.053
70	95-SB27	AS	1" piping US & DS of valve LCV-101-40	T.B. - SJAE Room.	G191156	Industry Experience Point	1"	160	.250	.053
71	95-SB28 98-SB06	AS	1" & 1½" piping US & DS of steam trap ST 62-2.	T.B. - SJAE Room.	G191156	Industry Experience Point	1" 2"	160 160	.250 .344	.053 .096
72	95-SB29 98-SB07	AS	1½"-MSD-464 pipe & fittings @ connect. to Condenser B Nozzle 69	T.B. - Heater Bay	G191156	Industry Experience Point	2"	160	.344	.096
73	95-SB30	AS(AOG)	2" piping of DS of valve OG PRV -834A	T.B. - Heater Bay El.248.	33600-A217	Industry Experience Point	1"	160	.250	.053
74	95-SB31	AS(AOG)	¾" piping US & DS of steam trap MS-113-1A.	T.B. - Heater Bay El.248.	33600-A217	Industry Experience Point	1" 2"	160 160	.250 .344	.053 .096
75	95-SB32	AS(AOG)	¾" piping US & DS of steam trap MS115-1A	T.B. - Heater Bay El.248.	33600-A217	Industry Experience Point	2"	160	.344	.096
76	95-SB33	AS(AOG)	¾"MS-189-D3 AS drain from OG @ conn. to 3"-MSD-4.	T.B. - Heater Bay El 233'-4".	33600-A217	Industry Experience Point	2"	160	.344	.096
77	95-SB34	AS(AOG)	¾"HCN-188-H1 AS drain from OG @ conn. to 3"-MSD-4.	T.B. - Heater Bay El 233'-4"	33600-A217	I. E. Point, Replaced prior to 1990	2"	160	.344	.096
78	93-SB31	SSL	1½" & 3" Header for 1SLMSV off Turbine Stop Valves	T.B. - Heater Bay.	5920-224	Industry Experience Point	1½" 3"	80 40	.200 .216	.077 .141
79	93-SB32	SSL	1½"-1SLMSV - Stop Valve A	T.B. - Heater Bay	5920-224	Industry Experience Point	1½"	80	.200	.077
80	93-SB33	SSL	1½"-1SLMSV - Stop Valve B	T.B. - Heater Bay	5920-224	Industry Experience Point	1½"	80	.200	.077
81	93-SB34	SSL	1½"-1SLMSV - Stop Valve C	T.B. - Heater Bay	5920-224	Industry Experience Point	1½"	80	.200	.077

VY PIPING FAC INSPECTION PROGRAM SMALL BORE INSPECTION LOCATIONS

Revision 1, 12/6/1999

PT.	PREV. INSPECT. No.	SYSTEM	DESCRIPTION	LOCATION	DRAWINGS	COMMENTS	SIZE	SCH.	T nom inch	T min inch
82	93-SB35	SSL	1½"-1SLMSV - Stop Valve D	T.B. - Heater Bay	5920-224	Industry Experience Point	1½"	80	.200	.077
83	93-SB36	SSL	1½" Header for 1SCVL off Turbine Control Valves	T.B. - Heater Bay	5920-224		1½"	80	.200	.067
84	93-SB38	SSL	½"-1SCVL - Control Valve A.	T.B. - Heater Bay	5920-224		½"	80	.147	.033
85	93-SB39/40	SSL	½"-1SCVL - Control Valve B.	T.B. - Heater Bay	5920-224		½"	80	.147	.033
86	93-SB41/42	SSL	½"-1SCVL - Control Valve C.	T.B. - Heater Bay	5920-224		½"	80	.147	.033
87	93-SB37	SSL	½"-1SCVL - Control Valve D.	T.B. - Heater Bay	5920-224		½"	80	.147	.033
88	93-SB43	SSL	1" & 3" Header for 2SLMSV off Turbine Stop Valves A & B	T.B. - Heater Bay	5920-224		2-1/2" 1"	40 80	.203 .179	.116 .053
89	93-SB44	SSL	1" & 3" Header for 2SLMSV off Turbine Stop Valve C	T.B. - Heater Bay	5920-224		3" 1"	40 80	.216 .179	.141 .053
90	93-SB45	SSL	1" - 2SLMSV off Turbine Stop Valve D	T.B. - Heater Bay	5920-224		3" 1"	40 80	.216 .179	.141 .053
91	93-SB58	SSL	2½" - Header for 2SCVL off Turbine Control Valves	T.B. - Heater Bay	5920-224		1"	80	.179	.053
92	93-SB61	SSL	1" - 2SCVL off Control Valve A	T.B. - Heater Bay	5920-224		2½"	40	.203	.116
93	93-SB60	SSL	1" - 2SCVL off Control Valve B	T.B. - Heater Bay	5920-224		1"	80	.179	.053
94	93-SB59	SSL	1" - 2SCVL off Control Valve C	T.B. - Heater Bay	5920-224		1"	80	.179	.053
95	93-SB57	SSL	1" - 2SCVL off Control Valve D	T.B. - Heater Bay	5920-224		1"	80	.179	.053
96	92-(SB-info only)	SSL	Turbine Bypass Valve Chest 1st Seal Leakoff 1/2"-1SLBPV	T.B. - Heater Bay	5920-224		1/2"	80	.147	.034
97	92-SB01	SSL	TBV Chest 1st Seal Leakoff 2"-1SLBPV	T.B. - Heater Bay	5920-224		2"	80	.218	.099
98	92-SB02	SSL	TBV Chest 1st Seal Leakoff 2"-1SLBPV	T.B. - Heater Bay	5920-224		2"	80	.218	.099

VY PIPING FAC INSPECTION PROGRAM - SMALL BORE INSPECTION LOCATIONS
Revision 1, 12/6/1999

PT.	PREV. INSPECT. No.	SYSTEM	DESCRIPTION	LOCATION	DRAWINGS	COMMENTS	SIZE	SCH.	T _{nom} inch	T _{min} inch
99	92-SB03	SSL	TBV Chest 1st Seal Leakoff 2"-1SLBPV	T.B. - Heater Bay	5920-224		2"	80	.218	.099
100	92-SB04	SSL	TBV Chest 1st Seal Leakoff 2"-1SLBPV	T.B. - Heater Bay	5920-224		2"	80	.218	.099
101	92-SB05	SSL	TBV Chest 1st Seal Leakoff 2"-1SLBPV	T.B. - Heater Bay	5920-224		2"	80	.218	.099
102		SSL	TBV Chest 1st Seal Leakoff 2"-1SLBPV	T.B. - Heater Bay	5920-224	Not Inspected in 1992	2"	80	.218	.099
103	92-SB07	SSL	TBV Chest 1st Seal Leakoff 2"-1SLBPV	T.B. - Heater Bay	5920-224		2"	80	.218	.099
104	92-SB08	SSL	TBV Chest 1st Seal Leakoff 2"-1SLBPV	T.B. - Heater Bay	5920-224		2"	80	.218	.099
105	92-SB09	SSL	TBV Chest 1st Seal Leakoff 2"-1SLBPV	T.B. - Heater Bay	5920-224	Vertical section replaced in 1992.	2"	80	.218	.099
106	92-SB10	SSL	TBV Chest 1st Seal Leakoff 2"-1SLBPV	T.B. - Heater Bay	5920-224	Loc. of 1992 leak, replaced in 1992.	2"	80	.218	.099
107	93-SB46	SSL	TBV Chest 2nd Seal Leakoff 2½" - 2SLBPV	T.B. - Heater Bay	5920-224	Continuation of 1992 inspections	2½"	40	.203	.116
108	93-SB47 95-SB35	SSL	TBV Chest 2nd Seal Leakoff 2½" - 2SLBPV	T.B. - Heater Bay	5920-224	" "	2½"	40	.203	.116
109	93-SB48A 93-SB48B 95-SB36A 95-SB36B	SSL	TBV Chest 2nd Seal Leakoff 2½" - 2SLBPV	T.B. - Heater Bay	5920-224	" "	2½"	40	.203	.116
110	93-SB49	SSL	2½" - 1SPL2 H.P. Turbine Pocket Drain	T.B. - Heater Bay	5920-224	Significant Wear @ Duane Arnold	2½"	40	.203	.023
111	93-SB50	SSL	2½" - 1SPL2 H.P. Turbine Pocket Drain	T.B. - Heater Bay	5920-224	" "	2½"	40	.203	.023
112	93-SB51	SSL	2½" - 1SPL2 H.P. Turbine Pocket Drain	T.B. - Heater Bay	5920-224	" "	2½"	40	.203	.023
113	93-SB52	SSL	2½" - 1SPL2 H.P. Turbine Pocket Drain	T.B. - Heater Bay	5920-224	" "	2½"	40	.203	.023
114	93-SB53	SSL	2½" - 1SPL2 H.P. Turbine Pocket 90 deg elbow	T.B. - Heater Bay	5920-224	" "	2½"	40	.203	.023
115	93-SB54	SSL	1SPL2 2½" x 2" reducer at 36° CAR pipe.	T.B. - Heater Bay	5920-224	" "	2½" 2"	40 40	.203 .154	.023 .019

VY PIPING FAC INSPECTION PROGRAM - SMALL BORE INSPECTION LOCATIONS
 Revision 1, 12/6/1999

PT.	PREV. INSPECT. No.	SYSTEM	DESCRIPTION	LOCATION	DRAWINGS	COMMENTS	SIZE	SCH.	Tnom inch	T min inch
116	95-SB37	C	1½" & 2½" piping US & DS of LCV 1A-3	T.B. - Heater Bay	G191157 Sht.1	IE	1½" 2½"	80 80	.200 .276	.038 .057
117		MSD	Steam Seal Regulator to Steam Seal Piping low point drain		G191156 5920-224	IE	1"			
118		HV	4"-HV-8A @ Condenser A No.4 continuous vent.	T.B. - Heater Bay	G191158	IE				
119		C	1" Piping D.S of R.O. 64-2	T.B. - Heater Bay	G191157 Sht.1	IE				
120		ES	3"-ES-8A D.S.of LCV-4A	T.B. - Heater Bay	G191156	IE				
121		ES	3"-ES-8B D.S.of LCV-4B	T.B. - Heater Bay	G191156	IE				
122	99-SB01	MSD	1" piping US & DS valve HPCI-LCV-53	Rx. Bldg. HPCI Rm.	G191169 Sht.1 VYI-HPCI- Pt.3A St.2/2	(I.E.) Dreseden 3 LER 3/96	1"	160	.250	.053
123	99-SB02	MSD	1" piping US & DS of Steam Trap ST-3	Rx. Bldg. HPCI Rm.	G191169 Sht.1 VYI-HPCI- Pt.3A St.2/2	(I.E.) Dreseden 3 LER 3/96	1"	160	.250	.053
124	99-SB03	MSD	1" piping US & DS valve HPCI-FCV-42	Rx. Bldg. HPCI Rm.	G191169 Sht.1 VYI-HPCI- Pt.3A St.2/2	(I.E.) Dreseden 3 LER 3/96	1"	160	.250	.053
125	99-SB04	MSD	1" piping US & DS valve RCIC LCV-32	Rx. Bldg. RCIC Rm.	G191174 Sht.1 VYI-RCIC-Pt.3A Shts.1/2 & 2/2	(I.E.) Dreseden 3 LER 3/96	1"	160	.250	.053
126	99-SB05	MSD	1" piping US & DS of Steam Trap ST-6	Rx. Bldg. RCIC Rm.	G191174 Sht.1 VYI-RCIC-Pt.3A Shts.1/2 & 2/2	(I.E.) Dreseden 3 LER 3/96	1"	160	.250	.053
127	99-SB06	MSD	1" piping US & DS valve RCIC FCV-34	Rx. Bldg. RCIC Rm.	G191174 Sht.1 VYI-RCIC-Pt.3A Shts.1/2 & 2/2	(I.E.) Dreseden 3 LER 3/96	1"	160	.250	.053