

Tennessee Valley Authority, 1101 Market Street, LP 5A, Chattanooga, Tennessee 37402-2801

June 23, 2008

10 CFR 52.79

U.S. Nuclear Regulatory Commission ATTN: Document Control Desk Washington, D.C. 20555

washington, D.C. 2033.

In the Matter of

Docket No. 52-014 and 52-015

Tennessee Valley Authority)

BELLEFONTE COMBINED LICENSE APPLICATION – RESPONSE TO REQUEST FOR ADDITIONAL INFORMATION – CONTROL ROOM HABITABILITY

Reference:

Letter from Ravindra G. Joshi (NRC) to Andrea L. Sterdis (TVA), Request for Additional Information Letter No. 012 Related to SRP Section 06.04 for the Bellefonte Units 3 and 4 Combined License Application, dated May 12, 2008.

This letter provides the Tennessee Valley Authority's (TVA) response to the Nuclear Regulatory Commission's (NRC) request for additional information (RAI) items included in the reference letter. The items address the control room habitability evaluation.

The enclosure provides response to the RAI and identifies changes that will be made in a future revision of the BLN application.

If you should have any questions, please contact Phillip Ray at 1101 market Street, LP5A, Chattanooga, Tennessee 37402-2801, by telephone at (423) 751-7030, or via email at pmray@tva.gov.

I declare under penalty of perjury that the foregoing is true and correct.

Executed on this 230 day of June, 2008

Andrea L. Sterdis

Manager, New Nuclear Licensing and Industry Affairs

Enclosure

cc: See Page 2

A102 DOSS NEO

Document Control Desk

Page 2

June 23, 2008

cc: (Enclosures)

- J. P. Berger, EDF
- E. Cummins, Westinghouse
- S. P. Frantz, Morgan Lewis
- MW. Gettler, FP&L
- R.C. Grumbir, NuStart
- P. S. Hastings, NuStart
- P. Hinnenkamp, Entergy
- R.G. Joshi, NRC/HQ
- M C. Kray, NuStart
- D. Lindgren, Westinghouse
- G. D. Miller, PG&N
- M.C. Nolan, Duke Energy
- N. T. Simms, Duke Energy
- G. A. Zinke, NuStart

cc: (w/o Enclosure)

- B. C. Anderson, NRC/HQ
- M.M.Comar,NRC/HQ
- B. Hughes, NRC/HQ
- R. H. Kitchen, PGN
- M.C Kray, NuStart
- A. Monroe, SCE&G
- C. R. Pierce, SNC
- R. Reister, DOE/PM
- L. Reyes, NRC/RII
- T. Simms, NRC/HQ
- J. M. Sebrosky, NRC/HQ

Enclosure TVA letter dated June 23, 2008 RAI Responses

Responses to NRC Request for Additional Information letter No. 012 dated May 12, 2008 (2 pages)

Subject: Control Room Habitability Evaluation

RAI Number

Date of TVA Response

06.04-01

This letter – see following pages

Attachments / Enclosures

Pages Included

None

Enclosure TVA letter dated June 23, 2008 RAI Responses

NRC Letter Dated: May 12, 2008

NRC Review of Final Safety Analysis Report

NRC RAI NUMBER: 06.04-01

The Bellefonte COL FSAR Table 2.3-321, "Control Room Atmospheric Dispersion Factors for Accident Dose Analysis," provides, among other release points, a release point called "Steam Vent." This term for a release point is not used in the AP1000 DCD, Rev. 16, Table 15A-6, which is the corresponding table in the AP1000 DCD for use in design basis radiological consequences analyses. Please describe which AP1000 DCD Table 15A-6 design reference release point is equivalent to the Bellefonte FSAR Table 2.3-321 release point termed "Steam Vent," and which associated design basis accident analyses use those control room atmospheric dispersion factors. In addition, make the terminology in Bellefonte Table 2.3-321 consistent with that of DCD Table 15A-6.

BLN RAI ID: 0350

BLN RESPONSE:

The heading for the "Steam Vent" columns in Table 2.3-321 and Table 2.0-202 will be revised to match the corresponding DCD Table 15A-6 identified release point of "Steam Line Break Releases." The steam line break release points and associated design basis accident analyses are as described in DCD Chapter 15, Subsection 15.1.5.

This response is PLANT-SPECIFIC.

ASSOCIATED BLN COL APPLICATION REVISIONS:

1. COLA Part 2, FSAR Chapter 2, Section 2.0, Table 2.0-202, column headings (two) will be revised from:

"Steam Vent"

To read:

"Steam Line Break Releases"

2. COLA Part 2, FSAR Chapter 2, Section 2.3, Table 2.3-321, column headings (two) will be revised from:

"Steam Vent"

To read:

"Steam Line Break Releases"

ATTACHMENTS/ENCLOSURES:

None