

Tom Tynan
Vice President - Vogtle

**Southern Nuclear
Operating Company, Inc.**
7821 River Road
Waynesboro, Georgia 30830

Tel 706.826.3151
Fax 706.826.3321

June 25, 2008



Docket Nos.: 50-424
50-425

NL-08-0994

U. S. Nuclear Regulatory Commission
ATTN: Document Control Desk
Washington, D. C. 20555-0001

Vogtle Electric Generating Plant, Unit 2
Supplemental Information Supporting Acceptance Review of
Emergency Technical Specification (TS) Revision Request
Regarding TS 3.6.6, "Containment Spray and Cooling Systems"

Ladies and Gentlemen:

On June 24, 2008, Southern Nuclear Operating Company (SNC) submitted a letter (NL-08-0987) requesting a proposed emergency amendment to Vogtle Electric Generating Plant (VEGP) Unit 2 Technical Specifications (TS) for a one-time change to the Limiting Condition for Operation (LCO) 3.6.6, "Containment Spray and Cooling Systems," Action A.

During the acceptance review of the June 24, 2008 submittal, SNC was requested to provide further clarification in regard to the nature of the risk insights contained section 5.0, "Risk Assessment," of Enclosure 1. The risk insights were provided for additional information only to support a deterministic discussion. The SNC submittal is not a risk informed submittal.

SNC was also requested to include the following two NRC commitments as a supplement to the June 24, 2008 submittal.

- Both trains of the emergency core cooling system (ECCS), both trains of the containment cooling system (CCS), the remaining train of the containment spray (CS) system, and attendant equipment will remain operable during the proposed 7 day Completion Time.
- If any train of ECCS, CCS, or the remaining train of CS becomes inoperable or requires maintenance during the proposed 7 day Completion Time, TS LCO 3.0.3 will be entered.

Mr. T. E. Tynan states he is a Vice President of Southern Nuclear Operating Company, is authorized to execute this oath on behalf of Southern Nuclear Operating Company and to the best of his knowledge and belief, the facts set forth in this letter are true.

The NRC commitments contained in this letter are provided in the enclosed table. If you have any questions, please advise.

Respectfully submitted,

SOUTHERN NUCLEAR OPERATING COMPANY



T. E. Tynan
Vice President – Vogtle

Sworn to and subscribed before me this 25 day of June, 2008.

Notary Public

Notary Public, Burke County, Georgia
My commission expires: My Commission Expires January 13, 2012

TET/DRG/

Enclosure: List of Regulatory Commitments

cc: Southern Nuclear Operating Company
Mr. J. T. Gasser, Executive Vice President
Mr. D. H. Jones, Vice President – Engineering
Mr. L. M. Stinson, Vice President – Fleet Operations Support
RType: CVC7000

U. S. Nuclear Regulatory Commission
Mr. L. A. Reyes, Regional Administrator
Mr. R. A. Jervey, NRR Project Manager – Vogtle
Mr. G. J. McCoy, Senior Resident Inspector – Vogtle

State of Georgia
Mr. N. Holcomb, Commissioner – Department of Natural Resources

**Vogtle Electric Generating Plant, Unit 2
Supplemental Information Supporting Acceptance Review of
Emergency Technical Specification (TS) Revision Request
Regarding TS 3.6.6, "Containment Spray and Cooling Systems"**

Enclosure

List of Regulatory Commitments

List of Regulatory Commitments

The following table identifies those actions committed by Southern Nuclear Operating Company in this document for Vogtle Electric Generating Plant. Any other statements in this submittal are provided for information purposes and are not considered to be regulatory commitments.

Commitment	Due Date/Event
Both trains of the emergency core cooling system (ECCS), both trains of the containment cooling system (CCS), the remaining train of the containment spray (CS) system, and attendant equipment will remain operable during the proposed TS LCO 3.6.6 Action A, 7 day Completion Time.	During TS LCO 3.6.6 Action A, 7 day completion time.
If any train of ECCS, CCS, or the remaining train of CS becomes inoperable or requires maintenance during the proposed TS LCO 3.6.6 Action A, 7 day Completion Time, TS LCO 3.0.3 will be entered.	During TS LCO 3.6.6 Action A, 7 day completion time.