PMBelCOL PEmails

From: Tanya Simms
Sent: Thursday, June 26, 2008 12:38 PM
To: 'Bob Hirmanpour'; 'Ray, Phillip M'; 'erg-xl@cox.net'
Cc: PMBelCOL PEmails
Subject: RAI 365

Hello Bob,

The staff has reviewed the suggested information in the FSER action item in DCD Tier 1 2.5.2-8 item 1 ITAAC.
The staff has determined that they do not find the ITAAC in DCD Tier 1 2.5.2-8 item 1 acceptable in its current form to satisfy the COL action item. One proposed resolution is to add a sub-bullet to Table 2.5.2-8 item 1 to call out specifically that the "as-built I&C design configuration" conforms with schematics.

If you feel a phone call is needed to clarify this information, Friday, June 27 at 9:00a or 11:00a are available.

Thank you,
Tanya

Hearing Identifier: Bellefonte_COL_Public_EX
Email Number: 343

Mail Envelope Properties (C4A4C9A16294FB4CBA5A36312D05FFAC0A9B348F87)

Subject: RAI 365
Sent Date: 6/26/2008 12:37:43 PM
Received Date: 6/26/2008 12:37:46 PM
From: Tanya Simms

Created By: Tanya.Simms@nrc.gov

Recipients:
"PMBelCOL PEmails" <PMBelCOL.PEmails@nrc.gov>
Tracking Status: None
"'Bob Hirmanpour'" <bobhirman@live.com>
Tracking Status: None
"'Ray, Phillip M'" <pmray@tva.gov>
Tracking Status: None
"'erg-xl@cox.net'" <erg-xl@cox.net>
Tracking Status: None

Post Office: HQCLSTR02.nrc.gov

Files	**Size**	**Date & Time**
MESSAGE	616	6/26/2008 12:37:46 PM

Options
Priority: Standard
Return Notification: No
Reply Requested: No
Sensitivity: Normal
Expiration Date:
Recipients Received: