

Dominion Nuclear Connecticut, Inc.
5000 Dominion Boulevard, Glen Allen, Virginia 23060
Web Address: www.dom.com



June 26, 2008

U. S. Nuclear Regulatory Commission
Attention: Document Control Desk
Washington, DC 20555-0001

Serial No. 08-0050C
NL&OS/GAW R1
Docket Nos. 50-336
50-423
License Nos. DPR-65
NPF-49

DOMINION NUCLEAR CONNECTICUT, INC.
MILLSTONE POWER STATION UNITS 2 AND 3
SUPPLEMENTAL INFORMATION
REGARDING CONTROL ROOM HABITABILITY (TAC NOS. MD6115 AND MD6116)

On July 13, 2007, Dominion Nuclear Connecticut, Inc. (DNC) submitted a request for an amendment to the Technical Specifications (TSs) for Millstone Power Station Units 2 and 3 (MPS2 and MPS3) (Serial No. 07-0440). The proposed amendment would revise TS requirements related to control room envelope habitability consistent with the intent of NRC-approved Technical Specification Task Force (TSTF) Standard Technical Specification Change Traveler, TSTF-448, "Control Room Habitability," Revision 3. The NRC sent DNC requests for additional information (RAIs) in letters dated November 21, 2007 and January 28, 2008. DNC responded to the RAIs in letters dated December 7, 2007 (Serial No. 07-0790), March 5, 2008 (Serial No. 08-0050), March 25, 2008 (Serial No. 08-0050A) and June 9, 2008 (Serial No. 08-0050B).

As discussed in a conference call between NRC staff and DNC on June 17, 2008, DNC is providing additional clarification for its June 9, 2008 response to Question 3 in the attachment to this letter. Question 3 was included in the NRC RAI dated January 28, 2008. Specifically, NEI 99-03, Revision 1 is not relied upon in claiming any exceptions to the ASTM E741 test method.

Should you have any further questions in regard to this submittal, please contact Mr. Geoffery A. Wertz at (804) 273-3572.

Sincerely,

Gerald Bischof
Vice President – Nuclear Engineering


COMMONWEALTH OF VIRGINIA)
)
COUNTY OF HENRICO)

The foregoing document was acknowledged before me, in and for the County and Commonwealth aforesaid, today by Gerald T. Bischof, who is Vice President – Nuclear Engineering of Dominion Nuclear Connecticut, Inc. He has affirmed before me that he is duly authorized to execute and file the foregoing document in behalf of that company, and that the statements in the document are true to the best of his knowledge and belief.

Acknowledged before me this 26TH day of June, 2008.

My Commission Expires: May 31, 2010

Notary Public



Serial No. 08-0050C

Docket No. 50-336

50-423

Control Room Habitability Supplemental Information

Page 2 of 2

Attachments: (1)

Control Room Habitability (TAC Nos. MD6115 and MD6116) - Supplemental Information

Commitments made in this letter: None

cc: U.S. Nuclear Regulatory Commission
Region I
475 Allendale Road
King of Prussia, PA 19406-1415

Mr. J. D. Hughey
Project Manager
U.S. Nuclear Regulatory Commission
One White Flint North, Mail Stop 08 B3
11555 Rockville Pike
Rockville, MD 20852-2738

NRC Senior Resident Inspector
Millstone Power Station

Director
Bureau of Air Management
Monitoring and Radiation Division
CT Department of Environmental Protection
79 Elm St.
Hartford, CT 06106-5127

ATTACHMENT

CONTROL ROOM HABITABILITY (TAC NOS. MD6115 AND MD6116)
SUPPLEMENTAL INFORMATION

MILLSTONE POWER STATION UNITS 2 AND 3
DOMINION NUCLEAR CONNECTICUT, INC.

CONTROL ROOM HABITABILITY
SUPPLEMENTAL INFORMATION

This supplement further clarifies the intent of DNC's application of the ASTM E741 testing methodology to nuclear power plant control room envelope integrity. Specifically, as discussed in a conference call between NRC staff and DNC on June 16, 2008, DNC is providing an amended response to Question 3. Question 3 was included in the NRC request for additional information dated January 28, 2008.

NRC Question

DNC references NEI 99-03, Revision 1, Appendix EE, in Attachment 1, Page 7 of 11 under 'Exceptions.'

The NRC staff has not reviewed NEI 99-03, Revision 1. Therefore, exceptions used in Appendix EE of NEI 99-03, Revision 1, have not been reviewed by the NRC staff. Please identify alternate plant-specific ASTM E741 exceptions and provide a detailed explanation justifying the acceptability of these exceptions.

DNC Response

The ASTM E741 test method was not written specifically for use in nuclear power plant control room envelope tests. Exceptions referenced in DNC's submittal on July 13, 2007 (Serial No. 07-0440) are limited to those exceptions necessary to meet the intent of the ASTM E741 methodology when applying it to nuclear power plant control room envelope testing. These exceptions are typically taken by test vendors and documented in test reports, as is the case for MPS3.

When CRE testing is performed at MPS2 without the use of a vendor, DNC will document the steps taken to appropriately apply the ASTM E741 test methodology in the surveillance.

NEI 99-03, Revision 1 is not relied upon in claiming any exceptions to the ASTM E741 test method.