

**Vogtle Electric Generating Plant Units 1 and 2
License Amendment Request to Revise Technical Specification (TS)
Sections 5.5.9, "Steam Generator (SG) Program" and TS 5.6.10,
"Steam Generator Tube Inspection Report" for Interim Alternate Repair Criterion**

Enclosure 11

List of Regulatory Commitments

List of Regulatory Commitments

The following table identifies those actions committed by Southern Nuclear Operating Company in this document for Vogtle Electric Generating Plant. Any other statements in this submittal are provided for information purposes and are not considered to be regulatory commitments.

Commitment	Due Date/Event
For integrity assessments, the ratio of 2.5 will be used in the completion of both the condition monitoring (CM) and operational assessment (OA) upon implementation of the IARC. For example, for the CM assessment, the component of leakage from the lower 4 inches for the most limiting steam generator during the prior cycle of operation will be multiplied by a factor of 2.5 and added to the total leakage from any other source and compared to the allowable accident analysis leakage assumption. For the OA, the difference in leakage from the allowable limit during the limiting design basis accident minus the leakage from the other sources will be divided by 2.5 and compared to the observed leakage. An administrative limit will be established to not exceed the calculated value.	Completion of CM and OA