ATTACHMENT B

INSPECTION SCOPE

ATTACHMENT B.1

Hot Leg Bobbin Coil Inspection Scope

SG - A Bobbin Program as Tested from Hot Leg

Byron B1R15 CAE 7720

E 6069 Tested Full Length from Hot Leg with .560 Probe

O 561 Tested F10 - TEH with .540 Probe

X 2 Tested 09C - TEH with .540 Probe

▫ 1 Plugged Tube



Westinghouse Electric Company LLC - ST Max 04/04/2008 16:07:11

SG - B Bobbin Program as Tested from Hot Leg

Byron B1R15 CAE 7720

E 6069 Tested Full Length from Hot Leg with .560 Probe

O 560 Tested F10 - TEH with .540 Probe

X 3 Tested 09C - TEH with .540 Probe

▫ 1 Plugged Tube



Westinghouse Electric Company LLC - ST Max 04/04/2008 16:15:52

SG - C Bobbin Program as Tested from Hot Leg

Byron B1R15 CAE 7720

E 6069 Tested Full Length from Hot Leg with .560 Probe

O 562 Tested F10 - TEH with .540 Probe

X 1 Tested 09C - TEH with .540 Probe

▫ 1 Plugged Tube



Westinghouse Electric Company LLC - ST Max 04/04/2008 16:16:50

SG - D Bobbin Program as Tested from Hot Leg

Byron B1R15 CAE 7720

E 6065 Tested Full Length from Hot Leg with .560 Probe

O 559 Tested F10 - TEH with .540 Probe

X 3 Tested 09C - TEH with .540 Probe

W 1 Tested 08C - TEH with .540 Probe

□ 5 Plugged Tube



Westinghouse Electric Company LLC - ST Max 04/04/2008 16:18:03

Attachment B.2

Cold Leg Bobbin Coil Inspection Scope

SG - A Bobbin Program As Tested from Cold Leg

Byron B1R15 CAE 7720

0 563 Tested F10 - TEC with .560 Probe

1 Plugged Tube



Westinghouse Electric Company LLC - ST Max 04/04/2008 16:20:07

SG - B Bobbin Program As Tested from Cold Leg

Byron B1R15 CAE 7720



SG - C Bobbin Program As Tested from Cold Leg

Byron B1R15 CAE 7720

0 563 Tested F10 - TEC with .560 Probe

1 Plugged Tube



Westinghouse Electric Company LLC - ST Max 04/04/2008 16:23:22

SG - D Bobbin Program As Tested from Cold Leg

Byron B1R15 CAE 7720

0 563 Tested F10 - TEC with .560 Probe

5 Plugged Tube



Westinghouse Electric Company LLC - ST Max 04/04/2008 16:24:08