



10 CFR 51.92

Tennessee Valley Authority, Post Office Box 2000, Spring City, Tennessee 37381-2000

July 2, 2008

U.S. Nuclear Regulatory Commission  
ATTN: Document Control Desk  
Mail Stop: OWFN P1-35  
Washington, D.C. 20555-0001

Gentlemen:

In the Matter of )  
Tennessee Valley Authority )

Docket No. 50-391

**WATTS BAR NUCLEAR PLANT (WBN) - UNIT 2 - FINAL SUPPLEMENTAL ENVIRONMENTAL IMPACT STATEMENT - REQUEST FOR ADDITIONAL INFORMATION (TAC MD8203)**

- References:
1. NRC letter dated June 3, 2008, "Watts Bar Nuclear Plant, Unit 2 - Request for Supplemental Information for Review of Supplemental Environmental Statement (TAC MD8203)"
  2. TVA letter dated February 15, 2008, "Watts Bar Nuclear Plant (WBN) - Unit 2 - Final Supplemental Environmental Impact Statement for the Completion and Operation of Unit 2"
  3. TVA letter dated June 16, 2008, "Watts Bar Nuclear Plant (WBN) - Unit 2 - Regulatory Framework for the Completion of Construction and Licensing Activities for Unit 2 - Revision 1 (TAC. No. MD6311)"

This letter responds to an NRC request for additional information (RAI) (Reference 1) regarding TVA's Final Supplemental Environmental Impact Statement for the Completion and Operation of Unit 2 (FSEIS). TVA's FSEIS was submitted on February 15, 2008 (Reference 2). Additional information, in accordance with 10 CFR 51.92, is provided to support NRC in updating NUREG-0498, "Final Environmental Statement Related to the Operation of Watts Bar Nuclear Plant, Units 1 and 2," for the operation of WBN Units 1 and 2.

The FSEIS supplements TVA's original 1972 "Final Environmental Statement, Watts Bar Nuclear Plant Units 1 and 2" (1972 FES) and updates subsequent related documents identified below. In December 1978, NRC issued a "Final Environmental Statement Related to the Operation of Watts Bar Nuclear Plant Units 1 and 2, NUREG-0498" (1978 NRC FES-OL). This environmental review dealt with the impacts of operation of WBN Units 1 and 2.

COOL  
NRR

In 1993, TVA conducted a review of the TVA and NRC documents to determine whether an additional environmental review was needed to inform decision makers about whether to complete both units and concluded that neither plant design nor environmental considerations had changed in a manner that materially altered the environmental impact analysis set forth in its 1972 FES. In 1994, NRC requested TVA provide updated environmental information in accordance with 10 CFR 51.92 to determine if it was necessary to issue a supplement to the 1978 NRC FES-OL. TVA provided additional analyses and information in support of NRC's "Final Environmental Statement Related to the Operation of Watts Bar Nuclear Plant, Units 1 and 2, NUREG-0498 Supplement 1," for the operation of WBN Units 1 and 2, which was issued in April 1995. The NRC concluded that there were no significant changes in the environmental impacts since the 1978 NRC FES-OL from changes in plant design, proposed methods of operation, or changes in the environment. Following an independent review of NRC's analyses and a new analysis of the need for additional power, TVA adopted NRC's 1995 FES in July 1995.

Another major review of WBN environmental impacts was completed for TVA's Environmental Assessment (EA) for the Watts Bar Supplemental Condenser Cooling Water Project in 1998. This system and the EA are discussed in detail in Enclosure 1.


The FSEIS was completed in June 2007 to inform decision makers and the public about the potential for environmental impacts associated with the completion of WBN Unit 2 and operation concurrent with WBN Unit 1. As part of the FSEIS review process, TVA posted the draft FSEIS, published a notice of availability in the Federal Register, issued a press release for an open house that was held near the plant, and accepted public comments on the draft. Comments were responded to directly or by revising applicable sections of the FSEIS.

Enclosure 1 lists the NRC requests and provides TVA's responses. Enclosure 2 provides the listing of open actions required for licensing made in Enclosure 1.

In light of previous discussions with NRC concerning the FSEIS and the RAI to which this letter is responding, TVA has decided that a document similar to the Regulatory Framework (Reference 3) previously submitted could assist the NRC in using the FSEIS as an aide to review/revise NUREG-0498. This review matrix is included as Enclosure 3. It provides a reference of portions of NUREG-0498 to applicable portions of TVA's FSEIS or other applicable documents.

If you have any questions, please contact me at (423) 365-2351.

Sincerely,

  
Masoud Bajestani  
Watts Bar Unit 2 Vice President

Enclosures  
cc: See page 3

U.S. Nuclear Regulatory Commission  
Page 3  
July 2, 2008

cc (Enclosures):

Lakshminarasimh Raghavan  
U.S. Nuclear Regulatory Commission  
MS 08H4A  
One White Flint North  
11555 Rockville Pike  
Rockville, Maryland 20852-2738

Patrick D. Milano, Senior Project Manager, Watts Bar Special Projects Branch  
U.S. Nuclear Regulatory Commission  
One White Flint North  
11555 Rockville Pike  
Rockville, Maryland 20852-2738

Loren R. Plisco, Deputy Regional Administrator for Construction  
U. S. Nuclear Regulatory Commission  
Region II  
Sam Nunn Atlanta Federal Center, Suite 23T85  
61 Forsyth Street, SW,  
Atlanta, Georgia 30303-8931

U. S. Nuclear Regulatory Commission  
Region II  
Sam Nunn Atlanta Federal Center  
61 Forsyth Street, SW, Suite 23T85  
Atlanta, Georgia 30303-8931

NRC Resident Inspector Unit 2  
Watts Bar Nuclear Plant  
1260 Nuclear Plant Road  
Spring City, Tennessee 37381

## Enclosure 1

### Response to Request for Additional Information

#### **NRC request 1:**

*Provide a description of the plant cooling water modes that will be used once WBN Unit 2 begins operation, including a discussion of the differences from modes described in previous environmental reviews completed by the NRC, as required by 10 CFR 51.53(b). TVA's response should describe any changes and analyses as required by 10 CFR 51.45(b) and (c), and should include information of the impact on fish and shellfish resources as should be shown in a copy of the Clean Water Act 316(b) determination.*

#### **TVA response:**

The Condenser Circulating Water (CCW) system for Watts Bar, a closed loop system, uses hyperbolic natural draft cooling towers to reject waste heat from the steam cycle. The CCW system provides approximately 410,000 gallons per minute (gpm) of cooling water to each of the WBN Unit 1 and Unit 2 condensers for the main steam turbines. Four pumps for each unit operate in parallel and circulate water from the cooling tower cold water basin, through the condenser, and back to the heat exchanger section of the cooling tower. Each pump has a capacity of 102,500 gpm. Previous environmental reviews completed by NRC only reviewed the CCW system.

The Supplemental Condenser Cooling Water (SCCW) system draws water by gravity flow from the intake structure immediately upstream of the Watts Bar Dam. Depending on lake level, approximately 115,000 to 135,000 gpm is used to supplement the cooling capacity of the existing cooling towers. This water mixes with and lowers the temperature of the CCW from the cooling towers. The SCCW flow passes through the WBN Unit 2 cooling tower basin and mixes with the WBN Unit 1 CCW flow through a gated opening (flume crosstie) added to the wall separating the Unit 1 and Unit 2 CCW intake channels. After passing through the condenser and cooling tower, the CCW flow ends up in the basin beneath the Unit 1 cooling tower. The SCCW system includes a separate discharge weir to deliver heated water back to the Tennessee River (see attached SCCW simplified drawing). The amount of flow returned to the river via the SCCW discharge conduit is roughly the same as that delivered to the plant by the SCCW intake conduit.

Since the SCCW system is operated by gravity flow, the amount of water entering and exiting the system depends on the elevation of the water surface behind Watts Bar Dam. The SCCW system became operational in 1999 and currently serves WBN Unit 1. As part of the completion of construction of WBN Unit 2, TVA plans to distribute the existing SCCW flow to both WBN Unit 1 and Unit 2. This would not change the total volume of water delivered and removed by the SCCW system.

TVA evaluated the effects of the SCCW system in a 1998 Environmental Assessment (EA). The EA evaluated 2 alternatives: (1) no action and (2) the proposed construction and operation of the SCCW. Operational impacts addressed in the EA included impacts to water quality, endangered and threatened species, and aquatic ecology. TVA circulated the EA to the Tennessee

## Enclosure 1

### Response to Request for Additional Information

Department of Environment and Conservation, the Tennessee Historical Commission, the U. S. Fish and Wildlife Service, and the U. S. Army Corps of Engineers. Based on the EA, TVA concluded that the construction and operation of the SCCW system would not be a major federal action significantly affecting the quality of the environment. Accordingly, an environmental impact statement was not required. A copy of the EA is attached for information.

As the volume of water delivered to Watts Bar by the SCCW system would not change for dual-unit operation, recently completed fish impingement studies are applicable to two-unit operation. Attached is the 316(b) monitoring program report, "Fish Impingement at Watts Bar Nuclear Plant Supplemental Condenser Cooling Water Intake Structure During 2005 Through 2007." The report presents impingement data collected by TVA from the SCCW intake screens during 2005-2007, with comparisons to historical data collected during 1974-1975 and 1999-2000. The report concluded "... the WBN SCCW intake is not adversely impacting the fish community in the vicinity of WBN."


#### **NRC request 2:**

*Provide an analysis of alternatives available for preventing or mitigating adverse environmental effects of severe accidents for WBN Unit 2. The analysis should be consistent in scope and content with severe accident mitigation alternative analyses provided in support of recent license renewal applications, and should consider risks from both internal and external events. The analysis should demonstrate that differences between WBN Units 1 and 2, and the effects of multi-unit operations are adequately addressed, and should be supported by completion of a probabilistic safety assessment reflecting the impact of simultaneous operation of both WBN units. TVA's response should clearly demonstrate the applicability of any information submitted to WBN Unit 2.*

#### **TVA response:**

TVA will use the current RISKMAN model to complete the WBN Unit 2 severe accident management alternative (SAMA) analysis. The single-unit model, with shared systems reflective of dual-unit operation and with dual-unit initiators, will be evaluated to determine the design alternatives to be further evaluated for cost benefit determination.


TVA will provide a WBN Unit 2 SAMA analysis consistent in scope and content with the SAMA analyses provided in support of recent license renewal applications. The WBN Unit 2 SAMA analysis will consider risks from both internal and external events. TVA will submit the WBN Unit 2 SAMA analysis by January 30, 2009.



**SUPPLEMENTAL  
CCW  
SIMPLIFIED DWG.**

**DRAWING FOR INFORMATION ONLY  
(NOT TO SCALE)**

**WATTS BAR NUCLEAR PLANT  
SUPPLEMENTAL  
CONDENSER COOLING WATER PROJECT**



**Environmental Assessment  
August 1998**

**LAST COPY: DO NOT REMOVE**

Index No: 444

Title: Watts Bar Nuclear Plant  
Supplemental Condenser Cooling Water  
Project EA - August 1998

August 26, 1998

Richard T. Purcell, ADM 1V-WBN

FINDING OF NO SIGNIFICANT IMPACT (FONSI)—ENVIRONMENTAL ASSESSMENT (EA)  
WATTS BAR NUCLEAR PLANT (WBN) SUPPLEMENTAL CONDENSER COOLING WATER  
(SCCW) SYSTEM

An EA (attached) was prepared concerning a proposal by TVA Nuclear to supplement the cooling capacity for WBN. The purpose of this system is to increase power generation at the plant which is constrained by cooling tower performance. The proposed SCCW system would use cooling water drawn from Watts Bar Lake at the Watts Bar Fossil Plant condenser cooling water intake structure. Approximately 135,000 gallons per minute of water would be routed through existing piping to the vicinity of the fossil plant at which point a new supply line would carry the water by gravity to the WBN unit 2 cooling tower basin for the purpose of further cooling water exiting the unit 1 cooling tower which supplies the unit 1 main steam condenser. A like flow of heated water would be discharged through an overflow weir from the unit 1 cooling tower basin by gravity through new piping to the existing fossil plant discharge channel and into the Tennessee River. Construction required for the system would occur entirely on TVA lands.

The EA evaluated 2 alternatives: (1) no action and (2) the proposed construction and operation of the SCCW. Other alternatives not addressed in detail due to technical or economic infeasibility were use of a diffuser at the fossil plant discharge, combined use unit 1 and 2 cooling towers, and further modification of the unit 1 cooling tower to improve performance. In addition to being economically infeasible, the use of a diffuser would cause extensive disturbance to the river bottom from excavation necessary to provide a bed for the diffuser.

The EA addressed potential environmental impacts of constructing the SCCW including impacts to air quality, wetlands and floodplains, endangered and threatened species, wildlife, and cultural and archeological resources. Best management practices required under WBN's Storm Water Pollution Prevention Plan and under a Tennessee General NPDES Permit for Storm Water Discharges Associated with Construction Activity would minimize erosion during construction. Discharge of hydrostatic test water will also be permitted under the General NPDES permit limiting impacts to water quality. Fugitive emission of particulate during construction would be minimized through use of reasonable precautions as required under Tennessee's air pollution regulations. The Aquatic Resource Alteration Permits required from the State of Tennessee for pipeline crossings of wet weather conveyances would mitigate impacts to aquatic resources. Upon review of TVA's assessment of historic properties, Tennessee's State Historic Preservation Officer (SHPO) in the Tennessee Historical Commission, and the Advisory Council on Historic Preservation confirmed that historic properties will not be adversely affected by this project.

Operational impacts addressed in the EA included impacts to water quality, endangered and threatened species, and aquatic ecology. A potential impact to native mussels, including endangered or threatened species, was identified in the immediate vicinity of the heated water discharge to the Tennessee River. To avoid these impacts, native mussels within an area 150 feet square would be relocated prior to system operation. The U.S. Fish and Wildlife Service

confirmed that the project would not adversely affect these native mussel species. Computer modeling and past fossil plant thermal discharge field studies indicated that the State of Tennessee thermal water quality criteria would be met at the end of a 1000 foot mixing zone when using a 24 hour averaging period. A zone of passage for fish below the buoyant heated discharge plume in the unaffected lower portion of the water column would further minimize thermal impacts. A modification to WBN's State of Tennessee NPDES permit would be required for operation of the system. This permit would be expected to contain several conditions to monitor compliance with thermal water quality criteria and to confirm that aquatic biological impacts would be negligible.

TVA concluded, based on computer modeling of the thermal discharge, that use of a diffuser for the SCCW discharge offers no environmental advantages. River temperature measurements made during operation of the Watts Bar Fossil Plant thermal discharge (which is now decommissioned) support the SCCW model results. It is TVA staff opinion that the potential disruptive impact on the benthic community caused by construction of a diffuser would far exceed the impact resulting from use of the existing fossil plant discharge and that the full water column mixing created by a diffuser would expose the river bottom to warmer water than the discharge structure proposed by TVA. Also, the cost to construct and operate a diffuser would make the project economically infeasible. This economic analysis is presented in the EA at section 2.3.3.

TVA circulated the EA to the Tennessee Department of Environment and Conservation (TDEC), the Tennessee Historical Commission, the U.S. Fish and Wildlife Service (USFWS), and the U.S. Army Corps of Engineers, Nashville District. The correspondence to and from these agencies are contained in section 9.0 of the EA. In a letter dated April 27, 1998 from TWRA to TDEC's Division of Water Pollution Control, two issues were raised, that in its view, remained unresolved. The two issues were related to the construction of a diffuser and monitoring of impacts to water quality and aquatic life. Subsequent to receipt of this letter, TVA made the following additional project commitments for monitoring which are listed in the EA at section 3.11:


- Conduct seasonal monitoring of the instream river temperatures within the mixing zone of the discharge during the first year of SCCW operation and compare the results with model projections, and
- Conduct a fisheries monitoring program in the vicinity of the WBN SCCW facilities during the first year of SCCW operation to study a limited number of crucial fish species to verify selected impact projections outlined in this EA.

Following further discussions with TDEC and TWRA, TVA received a letter from TDEC dated August 20 that granted conditional site approval for the project as proposed by TVA without a diffuser. In lieu of a diffuser, TDEC has required TVA to modify the existing discharge structure, if feasible, to maximize surface flow. This letter is contained in section 9.0 of the EA. TDEC's site approval is based on the following conditions:

Richard T. Purcell  
Page 3  
August 26, 1998

1. TVA will develop a mussel relocation plan in cooperation with TWRA.
2. TVA will modify the existing discharge structure to direct flow off the river bottom and/or to dissipate the flow energy.
3. TVA will perform instream temperature monitoring at two locations: on the river bottom near the discharge at the perimeter of the mussel relocation zone, and in a vertical array in the water column at the end of the mixing zone. Additionally, if feasible, TVA will monitor river flow direction near but upstream of the discharge.
4. TVA will provide mussel habitat enhancement as defined in a proposal to be provided by TVA and reviewed by TWRA.
5. TVA will monitor the discharge as established as part of the NPDES permit and will include continuous flow and temperature, and chemical and biological sampling.

Based on the EA, the commitments contained in the EA and the requirements in environmental permits required for the project, we conclude that TVA's proposed construction and operation of the WBN SCCW would not be a major federal action significantly affecting the quality of the environment. Accordingly, an environmental impact statement is not required.



Jon M. Loney, Manager  
Environmental Management  
WT 8C-K

GLA  
Attachment

cc: S. N. Bender, ET 12A-K  
E. S. Christenbury, ET 10A-K  
Erskine Hickman, MOB 2U-WBN  
K. J. Jackson, WT 11A-K  
C. R. McIntosh, ADM 1V-WBN  
J. K. Watts, LP 5D-C  
R. J. Williams, CTR 2C-M  
Files, EM, WT 8C-K

Prepared by Greg Askew (EM)

# **WBN Supplemental Condenser Cooling Water Project**

## **Environmental Assessment**

### **Executive Summary**

#### **Project statement**

This project would construct and operate a Supplemental Condenser Cooling Water (SCCW) system for the Watts Bar Nuclear Plant. The system would connect existing water intake and discharge piping originally operated as a part of the Watts Bar Fossil Plant to the cooling towers at the Nuclear Plant. This system would increase power production by the Watts Bar Nuclear Plant by reducing main turbine condenser temperature.

The gravity flow SCCW system would operate continuously except during times of chemical water treatment for the Nuclear Plant. Operation of the existing cooling tower was optimized previously at 105% of design capacity, however, warm weather power losses continue due to undersizing of cooling tower capacity to support maximum main turbine generator power and condenser cooling capacity. Without installation of the SCCW system, no increase in generation would be realized.

#### **Commitments**

1. Use of construction Best Management Practices
2. One-time relocation of native mussels
3. Addition of flow diverting provisions to discharge structure
4. Support experiment or test plan for enhancement of mussel habitat
5. Discharge monitoring
6. River monitoring

#### **Conclusions**

This assessment was prepared by an interdisciplinary environmental review team of the Tennessee Valley Authority. The team reviewed in depth the construction and operation of this proposed system relative to environmental requirements and guidelines. Specifically, the thermal discharge analysis demonstrates system operation within mixing zone required limits of 30.5 °C (86.9 °F) maximum discharge temperature, 3 °C (5.4 °F) maximum delta temperature, and  $\pm 2$  °C ( $\pm 3.6$  °F) rate of rise. With the appropriate implementation of the above commitments, no significant adverse environmental impacts have been identified by the team.

## Table of Contents

<b>Executive Summary</b>	<b>2</b>
<b>1.0 PURPOSE OF AND NEED FOR ACTION</b>	<b>5</b>
1.1 Improved Plant Performance	5
1.2 Description of Supplemental CCW System	6
1.3 Public Involvement	6
1.4 Federal and State Permits and Licenses Required	8
1.5 Other Environmental Reviews or Documentation	9
<b>2.0 ALTERNATIVES</b>	<b>10</b>
2.1 The Proposed Action	10
2.1.1 WBF Intake and existing pipeline	11
2.1.2 New supply pipeline	11
2.1.3 New discharge pipeline	11
2.1.4 WBF discharge structure	11
2.2 No Action	12
2.3 Other Actions and Project Variations not Considered in Detail	12
2.3.1 Modification of the existing tower	12
2.3.2 Using both towers for Unit 1 operation	12
2.3.3 Variances to Proposed Action	13
2.4 Comparison of Alternatives	13
2.4.1 Comparison of Construction Impacts	15
2.4.2 Comparison of Operational Impacts	15
<b>3.0 ENVIRONMENTAL IMPACTS</b>	<b>17</b>
3.1 Air Resources	17
3.1.1 Existing Conditions for WBN - NAAQS Attainment	17
3.1.2 Construction Impacts - Fugitive Dust and Vehicle Emissions	17
3.1.3 Operational Impacts	18
3.2 Water Quality	18
3.2.1 Existing Conditions	18
3.2.2 Construction Impacts	22
3.2.3 Operational Impacts	22
3.3 Aquatic Ecology	27
3.3.1 Existing Conditions	27
3.3.2 Construction Impacts	33
3.3.3 Operational Impacts	34
3.3.4 Chemical Impacts	39
3.4 Terrestrial Ecology	40
3.4.1 Existing Conditions	40
3.4.2 Construction Impacts	41

3.4.3 Operational Impacts	42
3.5 Endangered and Threatened Species	42
3.5.1 Existing Conditions	42
3.5.2 Construction Effects	43
3.5.3 Operational Effects	44
3.6 Solid and Hazardous Wastes	44
3.7 Wetlands and Floodplains	44
3.7.1 Field Inspection and Notes	44
3.7.2 Construction Impacts	45
3.7.3 Operational Impacts	45
3.8 Cultural and Archaeological Resources	48
3.8.1 Existing Conditions	48
3.8.2 Construction Impacts	48
3.8.3 Operational Impacts	48
3.9 Socioeconomic Resources	48
3.9.1 Existing Conditions	48
3.9.2 Environmental Justice	48
3.9.3 Impacts	49
3.10 Issues Not Requiring Detailed Analysis	49
3.10.1 Traffic	49
3.10.2 Land Use Conversion	49
3.10.3 Noise	49
3.11 Commitments	50
<b>4.0 LIST OF PREPARERS</b>	<b>51</b>
<b>5.0 LIST OF AGENCIES AND PERSONS CONTACTED</b>	<b>52</b>
<b>7.0 GLOSSARY</b>	<b>57</b>
<b>8.0 ENCLOSURES</b>	<b>58</b>
<b>9.0 ATTACHMENTS</b>	<b>58</b>


# 1.0 PURPOSE OF AND NEED FOR ACTION

## 1.1 Improved Plant Performance

The Condenser Circulating Water (CCW) system for Watts Bar Nuclear Plant (WBN) uses natural draft cooling towers to reject waste heat from the steam cycle. The capability of the towers to cool the CCW is significantly affected by site meteorological conditions. As the ambient temperatures become higher, the tower cooled water temperature also increases. This warmer water from the towers results in a decrease in the net megawatt output of WBN due to an increase in the condenser backpressure above the optimum design. If the temperature of the water to the main condenser could be reduced, the efficiency and output of WBN could be improved. Therefore, it was decided to investigate the feasibility of supplementing tower performance by routing cooler water from upstream of the Watts Bar Dam (WBH) to WBN. This water would mix with and lower the temperature of the water from the towers.

The use of water from WBH to supplement the present CCW would result in approximately 63,400 megawatt hours (MWh) increased output from WBN annually. This corresponds to a net revenue gain of approximately \$1,600,000 in fiscal year 1999. This increased capacity would occur predominately in the warm weather months of May through August when the cooling tower cooled water is warmest. Figure 1-1 shows the increase in MWh for each month of an average year. This increase would result from a combination of factors, primarily reduced condenser backpressure with a resultant increase in turbine-generator output. Other less significant contributors would be avoided impacts and costs from reduced operation of some equipment ( i.e. turning off of extra pumps) and extension of effective life of other items ( e.g. condensate polisher resin beds).

Figure 1-1 Seasonal variation of energy gain under typical weather conditions



## **1.2 Description of Supplemental CCW System**


The proposed project would provide between 115,000 and 135,000 gallons per minute (gpm) from Watts Bar Reservoir to WBN, depending on the pool elevation, to supplement the cooling capacity of the existing cooling tower. The supplemental flow would normally be continuous during WBN operation. Existing structures supply circulating water for the WBF from the Watts Bar Reservoir. The proposed project would use some of the existing WBF components to take advantage of the gravity flow and eliminate the need for new pumps. This project would use the existing intake structure at WBH, and most of the existing large-diameter pipe from the WBH to WBF to supply supplemental cooling water to the WBN CCW system. New pipe between WBF and WBN cooling towers would be installed. The discharge structure at WBF would also be integrated into the project. See Figure 1-2 for the general location of the project components.

## **1.3 Public Involvement**

TVA determined that the appropriate public involvement for the draft EA was to request comment from involved State of Tennessee and Federal agencies. Neither the environmental or socioeconomic effects of the project are expected to be of public concern. The project construction occurs only on TVA property, and no significant off-site environmental impacts are projected.

Applications for new or modified environmental permits may result in public notices and public meetings at a later time.

# Watts Bar Site



WATTS BAR SUPPLEMENTAL  
CCW PROJECT

FIGURE 1-2

#### 1.4 Federal and State Permits and Licenses Required

All required Federal, State, and local regulatory non-radiological environmental permits and approvals were obtained for construction and operation of both WBN and WBF. These include various State permits or licenses for air, water, demolition landfill, underground storage tanks, and hazardous waste generation. Environmental regulatory agencies conduct periodic inspections to verify that these facilities are in compliance with their permits and applicable requirements. In addition, TVA conducts periodic internal audits to provide further assurance of compliance with applicable environmental regulations and TVA environmental policy. Table 1-1 lists the status of existing environmental permits for both WBN and WBF.

**Table 1-1 Watts Bar Facilities Existing Permits**

Source Description	Permit Number	Renewal Date	Expiration Date
WBN Paint Shop -- Air	048011P	07/01/2006	09/01/2006
WBN Sandblast Shop -- Air	048010P	07/01/2006	09/01/2006
WBN Cooling Tower 1 -- Air	019953P	None	None
WBN Cooling Tower 2 -- Air	019954P	None	None
WBN Lube Oil Vapor Extractor 1 -- Air	042726P	07/01/99	09/01/99
WBN Lube Oil Vapor Extractor 2 -- Air	042725P	07/01/99	09/01/99
WBN Auxiliary Boilers -- Air	043216F	07/01/2000	09/01/2000
WBN Hazardous Waste Generator (Fees)	TN2640030035	02/01/98	03/01/98
WBN Landfill (Fees)	721030025	09/30/98	10/17/98
WBN DG Underground Storage Tanks (Fees)	0-610035	01/31/98	03/31/98
WBN General NPDES Storm Water	TNR001343	12/26/2001	12/31/2001
WBN General Construction Storm Water	TNR102716	Per Project	None
WBN NPDES	TN0020168	03/29/98	09/29/98
WBF NPDES	TN00005461	3/31/97	8/1/2000

WBN's existing National Pollution Discharge Elimination System (NPDES) permit authorizes the discharge of process wastewater resulting from the generation of electric power by nuclear fission and associated operations, including steam generator blowdown, cooling tower blowdown, sanitary wastewater, intake screen and strainer backwash, metal cleaning wastewater, miscellaneous flows, and storm water runoff from specific outfalls. WBN will request an expedited special NPDES permit modification from the State of Tennessee in order to begin construction on the SCCW project with subsequent discharge of cooling water through WBF's Outfall 003. As shown in the above table, WBN's permit expiration date of 9/29/98 is approaching, and the WBN permit renewal will include references to the modified special permit which will add Outfall 003 at WBF. In turn, the WBF NPDES permit will be revised to eliminate Outfall 003.

In addition to changes in the NPDES permits, it would be necessary for TVA to obtain other state environmental permits for the construction phase of this project. Prior to constructing the new supplemental cooling water discharge and supply pipelines, an erosion control plan would be developed as a part of obtaining and implementing a Tennessee General NPDES Permit for Storm Water Discharges Associated with Construction Activity. An Aquatic Resource Alteration Permit (ARAP) for Utility Line Crossings would be required for pipeline crossings of wet weather conveyances and streams. A Notice of Intent to be covered under the General NPDES Permit for Discharges of Hydrostatic Test Water for testing of the WBF intake and existing pipeline as well as the newly constructed pipelines would also need to be submitted as appropriate.

The proposed project would not involve any jurisdictional wetlands. However, stream crossings may require Corps of Engineers Section 404 permits and ARAP permits. In addition, concurrence would be needed from USFWS and SHPO.

If work needs to be performed on the discharge structure itself, then Corps of Engineers and ARAP permits may be needed for work performed on stream banks or on the discharge structure in water.

No nuclear licensing issues were identified by the team as an impact by the SCCW project. A nuclear safety analysis will be completed as part of the project engineering design change to verify this preliminary conclusion.

The WBN Final Safety Analysis Report (FSAR) section 10.4.5 does commit to meeting all applicable water thermal criteria by dissipating the waste heat directly to the atmosphere by means of a natural draft cooling tower. With the implementation of this project, a portion of the waste heat (up to 20%) would be dissipated in the river. However, as demonstrated by the analysis of this assessment, applicable thermal criteria would still be met. In addition, this project would include provisions to maintain compliance with chemical criteria by control discharges to the same level as those presently in the blowdown leaving the cooling towers. This plan will be revised as appropriate when the SCCW project is implemented.

### **1.5 Other Environmental Reviews or Documentation**

The construction and operational impacts of WBN were assessed by both TVA and NRC in separate EISs (TVA, 1972 and NRC, 1978). Prior to plant startup and receipt of an operating license, and following an extended construction period, TVA prepared a review of its EIS to identify any new issues (TVA, 1995). No substantial new issues were identified by this review. Subsequently, NRC decided to prepare a supplement to their 1978 EIS. The Notice of Availability of the Final Supplemental Statement was published on May 1, 1995 (Federal Register, 1995a). TVA decided to adopt the NRC Final Supplemental EIS, and published its Notice of Adoption on July 10, 1995 and Record of Decision on August 23, 1995 (Federal Register, 1995b and 1995c).

These EISs analyze the operation of the WBN CCW system including the cooling towers. The cooling tower chemical treatment, blowdown concentrations, and thermal effects of the blowdown stream discharge were analyzed.

In 1996, recovery of boiler slag at the Watts Bar Fossil Plant for commercial sale was proposed. The environmental effects of this project were presented in an environmental assessment (TVA, 1996). The proposed route of the pipeline for the WBN SCCW project would pass near and through portions of the WBF site impacted by boiler slag recovery operations identified in that environmental assessment.


## 2.0 ALTERNATIVES

WBN has the capacity to generate more electrical power than is presently produced, particularly in the warmer weather months. This inherent capability can be realized if the average cold water temperature of the CCW system can be decreased, which in turn, will reduce turbine backpressure and improve turbine steam energy conversion into electrical output without increasing input energy. Various alternatives were evaluated for achieving the increased output as well as the No Action option.

### 2.1 The Proposed Action

The proposed action involves providing water from Watts Bar Reservoir to the CCW system at WBN to supplement the performance of the existing cooling tower. The arrangement of the project is schematically shown on Figure 2-1.

Figure 2-1. Conceptual flow diagram of SCCW system.



### **2.1.1 WBF Intake and existing pipeline**

Water from the reservoir flows through an intake screen house that is adjacent to the west upstream side of WBH. The water enters the screen house through six intake sluice gates with bottoms at elevation 710, and traveling water screens. The gates tend to act as water skimmers since normal summer headwater is at elevation 740.5. The water flows approximately 3,200 feet to the fossil plant through two 78 inch diameter concrete pipes. One pipe serves units A & B, and the other serves units C & D. The piping then enters 5-foot 9-inch square concrete box culverts which serve the condensers. Portions of these components would be used in the project after some minor refurbishment.

### **2.1.2 New supply pipeline**

A new 90-inch diameter reinforced concrete pipe would be tied into two existing 78-inch pipes at approximately 200 feet north of the WBF switchyard. This pipe would be routed around the east side of the WBF to the back side of the of the WBN Unit 2 cooling tower basin. The pipe would run along the side of the existing ash ponds and the coal yard on the fossil plant site. After leaving the WBF property, the pipe would be routed across the northeast portion of the WBN site to a new inlet structure at the Unit 2 tower. The pipe would be primarily above ground to minimize excavation and placement of backfill. A motor operated valve would be located in the pipeline prior to entering the cooling tower basin. The valve would be required to stop the flow to the tower basin whenever cooling tower blowdown is suspended during periodic chemical treatment of the CCW.

The supplemental CCW would be conveyed through the Unit 2 tower basin to the Unit 1 tower discharge flume. Here it would mix with the warmer water from the Unit 1 tower prior to being pumped to the inlet of the Unit 1 main condenser.

### **2.1.3 New discharge pipeline**

To maintain the level and volume of the CCW system and to take advantage of the cooling effect, warm water must be discharged at the same flow rate as the supplemental supply. To accomplish this, an overflow weir structure would be provided on the side of the Unit 1 cooling tower basin. A 78-inch diameter reinforced concrete pipe would convey the discharge flow by gravity from the tower to the existing WBF discharge canal. This pipe would be routed along the side of the new supply pipe from the WBN tower to the vicinity of the WBF discharge. A motor operated valve would be located in the pipeline near the supply line valve. The valve would be required to stop the flow from the tower basin whenever cooling tower blowdown is suspended during periodic chemical treatment of the CCW.

In addition, a partial 42-inch crosstie pipeline with a control valve would be provided to divert up to 40% of the supplemental flow from the supply pipeline to the new WBN discharge line. This would be used in cooler months to reduce the amount of heat and lower the temperature of water discharged through the WBF discharge structure. This crosstie would also provide capability of a gradual change in discharge temperature during periods of system startup and shutdown.

### **2.1.4 WBF discharge structure**

Water from WBF is discharged to the Tennessee River approximately 1.1 miles upstream of the nuclear plant intake through a discharge structure that consists of an open discharge canal, an overflow weir drop structure, and a below water discharge tunnel. This discharge tunnel is a rectangular culvert seven feet wide by 10 feet high at the discharge point. The elevation of the top of the culvert outlet is 675 feet, which coincides with the normal minimum pool elevation of Chickamauga Reservoir. At winter reservoir elevations, the culvert acts as an open channel discharge. At higher reservoir elevations, the top of the culvert opening is submerged to a maximum depth of 8 feet.

This existing structure would be used as the discharge for the warm water from the WBN Unit 1 tower basin. To reduce the potential of the heated discharge flow from impacting the river bottom in the vicinity of the discharge structure, a flow directing ramp or incline may be added to the discharge structure to direct the flow toward the surface as it enters the river. This would consist of prefabricating a diverter and placing it on the existing discharge

structure apron or slab. This diverter would be installed if evaluations indicate a reduction of bottom impact will be achieved.

## **2.2 No Action**

For the purpose of this assessment, the No Action alternative is continuation of the present operation of the WBN CCW system and not implementing the proposed project. Under the No Action option, the potential capacity of WBN would remain under utilized and no increased revenue would be generated. The extra capacity potentially available to the TVA power system would have to be provided from another source, possibly future new construction.

Any new project would have to address the specific environmental impacts unique to such a facility and its location. Depending on the type of generating facility equipment there might be no need for heated water discharge. However, there might be significant issues with air quality or water withdrawal impacts. Considering that the proposed project would comply with thermal water quality criteria and have no significant environmental impact, it is possible that the net effect of future new construction could be of greater environmental impact.

## **2.3 Other Actions and Project Variations not Considered in Detail**

Other actions to lower the average CCW cold water temperature were considered. These included such options as:

- modification of the cooling tower,
- using both the Unit 1 and 2 cooling towers for Unit 1 operation,
- and adding a diffuser at the WBF discharge structure.

These options are discussed in sections 2.3.1 - 2.3.3.

### **2.3.1 Modification of the existing tower**

Recent tests indicate the existing cooling tower is performing at about 105% of the design capacity. Since operation of the tower is already optimized and due to physical configuration of a natural draft tower, additional changes to enhance performance are not economically viable.

### **2.3.2 Using both towers for Unit 1 operation**

A feasibility study prepared in August, 1996, showed that cross-tie of the Unit 1 and Unit 2 cooling towers for Unit 1 operation provided no increase in plant output. The use of both cooling towers did not provide sufficient increase in plant output for recovery of capital and/or operating costs.

Using the towers in parallel would result in less water flow through the tower than the design conditions. Due to the physical and thermodynamic mechanisms associated with the performance of natural draft towers, a corresponding decrease in air flow results. This loss of air flow would offset the lower heat load on the tower with a resultant decrease in performance. The net effect would be no change of the combined tower cold water temperature. Using the towers in series would require not only capital expenditures for modifications but also operation of the Unit 2 CCW pumps with an increase in plant electrical load. Series operation would result in a lower final cold water temperature with an expected increase in plant output of 8 to 10 MW. However, this would be offset by the 9 megawatts required by the four CCW pumps.

### 32.3.3 Variances to Proposed Action

#### Adding a diffuser at the WBF discharge

The addition of a diffuser at the WBF discharge structure significantly increases the required capital investment to the point that the rate of return on investment would not be acceptable. The economic analysis for projects at TVA Nuclear facilities is based on an evaluation of the cost versus increased revenue and avoided operational and maintenance costs to determine the payback period and internal rate of return. To successfully compete for capital resources within TVA, a project typically must show a positive net present value (NPV), a 35% internal rate of return (IRR) using a 15% discount rate, and a payback in 3 years or less. The construction of a new diffuser was estimated to increase the capital cost of the proposed project by approximately 30% (\$2 million) with no increase in the revenue. This increase would primarily result from the excavation and anchorage in the river channel necessary for a diffuser large enough to handle the 330 cfs discharge (Note this is 3 to 4 times the capacity of the existing WBN diffuser system). The incremental annual maintenance cost is estimated at \$10,000. These increases in cost would extend the payback period more than 2 years to 9 years and reduce the IRR 4% to 26%. Based on this, TVA would not financially consider the proposed action with the added capital cost of a diffuser and no further action was pursued. This decision was further substantiated by thermal plume modeling which demonstrated the project as proposed complies with all thermal water quality criteria limits.

Installation of a diffuser to replace the existing WBF discharge would allow more rapid dissipation of the thermal effluent. However, due to the unique location of the Watts Bar Fossil (WBF) discharge, within one mile downstream of Watts Bar Dam, disruption of the benthic habitat in the vicinity of the discharge during installation of the diffuser would cause much greater impact to the resident mussel community than the limited impact area resulting from discharges at the current facility. These impacts include extensive disturbance to bottom life during construction. This would result from the excavation of the river bottom to provide a bed for the diffuser and associated anchorage. The excavated area would be far more extensive than the bottom area which the CORMIX model computed as being impacted by the thermal plume of the proposed project. In addition to the direct impact to the bottom life residing in the area of excavation, there would also be a potential impact downstream due the silt created from dredging and blasting. As described in Sections 3.2 and 3.3, potential adverse impacts to resident biota resulting from thermal discharges at the existing WBF outlet are very localized. Fish will have ready avenues to avoid the high temperatures in the immediate vicinity of the discharge and freshwater mussels will be moved from the impact zone.

#### Elimination of Crosstie Line


Another option was eliminating the crosstie capability from the scope of the proposed project (See section 2.1.3 for description). This was eliminated from consideration due to problems in compliance with thermal discharge temperature limits during winter operation.

### 2.4 Comparison of Alternatives

Two alternatives are considered in this EA:

- **Proposed Action** — the SCCW system would be installed and operated to supply supplemental cooling water from Watts Bar Reservoir via the existing Watts Bar Fossil (WBF) intake and piping, and then through a new supply pipe installed from WBF to the WBN Unit 2 cooling tower basin. A new discharge pipe would be installed from the Unit 1 cooling tower basin to the existing WBF CCW discharge structure. (See Section 2.1 for a detailed description of design and operation.)
- **No action** — no SCCW system would be installed and no increase in generation capacity would be realized. Figure 2-2 shows the equivalent capacity that will continue to be lost from the No Action option on a monthly basis.

Figure 2-2 Monthly variation of power production capacity with/without proposed action.



### 2.4.1 Comparison of Construction Impacts

Only the proposed action would have environmental impacts from construction. These impacts, as evaluated in Section 3, would be both temporary and minor. These impacts include noise, fugitive dust, vehicle air emissions, soil erosion, vegetation alteration and loss, and wildlife disturbance. No unusual controls or measures would be required to mitigate these impacts. Routine measures such as best management practices (BMPs) for construction would provide adequate environmental controls for this project.

### 2.4.2 Comparison of Operational Impacts

The operational impacts of both alternatives include water intake entrainment and impingement of aquatic life, thermal discharges effects, and chemical discharge effects. Of course, for the No Action alternative, the impacts are simply a continuation of existing impacts. For the Proposed Action, the impacts are new.

*Thermal Discharge*—The proposed action would increase the annual thermal discharge (energy rejection) to the river, compared to the existing cooling tower blowdown, by a factor of 10. In July, the energy rejected to the river would be 13.7 times greater. However, the discharge flow rate and temperature, and the resulting river mixed water temperature, temperature change, and rate of temperature change in the river are the important factors in evaluating aquatic environmental impacts. Table 2-1 gives a summary of comparable river temperature data based on modeling results for the two alternatives. Both alternatives were evaluated at the end of their respective 1000 foot mixing zones. As shown in the Table, the two alternatives would have similar temperature effects. The primary differences are the maximum 24 hr temperature rise and rate of temperature rise which would be considerably higher for the proposed action.

**Table 2-1. Comparison of Modeled Temperatures at the Discharge and at the End of 1000 Foot Mixing Zone for No Action and the Proposed Action (modeled from 1976 to 1993).**

Parameter	Units	Alternative			
		Present WBN Diffuser		Proposed Action (SCCW)	
<b>Conditions at Each Discharge Point</b>					
Maximum 1 hr Discharge Temperature	°F	96	July	95.9	July
Average 1 hr Discharge Temperature	°F	85.7	July	85.7	July
Maximum 24 hr Discharge Temperature	°F	91.1	July	91	July
Average 24 hr Discharge Temperature	°F	85.7	July	85.7	July
<b>Conditions at the End of 1000 Foot Mixing Zone</b>					
Maximum 24 hr Temperature	°F	82.5	July	83.5	July
Average 24 hr Temperature	°F	76.5	August	77.7	August
Maximum 24 hr Temperature Rise	°F	0.5	April	5.3	May
Average 24 hr Temperature Rise	°F	0.1	April	2.7	May
Maximum Rate of Temperature Change	°F/hr	1.5	February	3.5	May

As discussed in Section 3 (3.3.3.3 and 3.3.3.4), there are potential impacts of the proposed action to fish, bottom life, and mussels in the immediate vicinity of the proposed thermal discharge. Limited mortality of several fish species is projected near the proposed discharge due to elevated water temperature. However, no significant adverse effects are projected on these fish communities. Sauger and white bass congregate in the WBH tailwater, near the point of the proposed thermal discharge, prior to spawning. No significant impacts on spawning are projected to result from the proposed thermal discharge. Potential adverse impacts were projected to occur to mussels, including one endangered species, in the vicinity of the proposed thermal discharge. However, TVA proposes to relocate native mussels from a 2,100 m<sup>2</sup> area near the discharge which would minimize these potential impacts. As a result, the proposed action would cause only minor new impacts to fish and mussels. The existing WBN thermal discharge would continue to operate essentially unchanged (No Action), and would continue to have minimal, if any, impact on aquatic life.

Measured river temperatures comparable to the modeled results would have been helpful as a further comparison of the effect of the existing system. The WBN NPDES permit requires that field surveys be performed to verify the mixing zone dimensions and model results within one year of commercial operation. TVA performed one survey in April, 1997 and one in July, 1997. However, the weather in 1997 did not provide the extremes of conditions needed for comparison with the model results for the proposed system.

*Entrainment and Impingement* — The WBF intake structure at Watts Bar Dam (WBH) would resume operation, but at a reduced flow (about 50 percent of the former WBF flow). Entrainment and impingement were quantified for the WBF intake during 316(b) studies in 1974 - 1975. It is projected that entrainment impacts would be half the impacts predicted in the 316(b) studies for past operation of the WBF (see 3.3.3.1). Impingement impacts would be no greater than those indicated in the previous study (see 3.3.3.2). The existing WBN water intakes would continue to operate unchanged, thus not altering these entrainment and impingement impacts. As a result, the entrainment and impingement impacts of the proposed project are not expected to be significant.

*Chemical Discharges*—The present operation of the cooling tower concentrates river water chemical constituents (primarily dissolved solids) by a factor of approximately 2 in the blowdown. The proposed supplemental cooling water flow would dilute the discharge of the proposed system to a maximum concentration factor of 1.4, with an average projected to be about 1.2. The present discharge has no known adverse effects from the chemical discharge and the proposed SCCW discharge would provide an additional margin of safety due to the reduced concentration. Implementation of the proposed project would not increase or change the use of chemicals presently approved in the WBN NPDES permit.

### 3.0 ENVIRONMENTAL IMPACTS

Resources that could potentially be affected by the proposed action were identified by TVA technical staff. Appropriate regulatory issues included:

- air quality,
- water quality,
- threatened and endangered species,
- disposal of solid and hazardous waste,
- wetlands and floodplains,
- and cultural and archaeological resources.

The potential for effects to socioeconomic resources, traffic, land use conversion, and noise, are discussed in sections 3.7 and 3.10. Because of the obvious potential for thermal impacts to water quality due to the very nature of the proposed action, that issue was accordingly examined in detail (see Sections 3.2 and 3.3).

In this chapter, the existing situation with respect to the potentially affected resources is described, followed by a discussion of the potential for impacts from both construction and operation of the proposed SCCW project.

#### 3.1 Air Resources

##### 3.1.1 Existing Conditions for WBN - NAAQS Attainment

Rhea County, Tennessee and surrounding areas are currently classified as attainment (or unclassified) for all National Ambient Air Quality Standards (NAAQS), and as such, air quality conditions are considered to be good in this region. The NAAQS for ozone (O<sub>3</sub>) and particulate matter (PM) have recently been revised. The O<sub>3</sub> NAAQS were lowered and new NAAQS were set for fine particulate matter (PM<sub>2.5</sub>)—PM with an aerodynamic diameter less than or equal to a nominal 2.5 micrometers. Attainment designations have not yet been revised to reflect the new NAAQS.

##### 3.1.2 Construction Impacts - Fugitive Dust and Vehicle Emissions

PM emissions, chiefly fugitive dust, would be generated during the construction of the water supply and discharge pipelines for this project. Emissions during such construction are associated with land clearing and ground excavation activities. These PM emissions would be temporary and could be expected to vary from day to day, depending on the level of activity, the specific operations, and the weather conditions. The pipelines would be installed primarily above ground to minimize excavation and placement of backfill. TVA would adhere to State air regulations (TDAPC Chapter 1200-3-8) requiring reasonable precautions (for example, applying water sprays on dirt roads) as needed to reduce fugitive dust emissions. Considering the limited nature of this project, TVA expects that fugitive dust emissions would be minor and would not result in any significant impacts to the environment.

Some minor and transitory air quality impacts would result if open burning of natural waste materials (untreated wood, trees, tree trimmings, and brush) were conducted. State regulations (TDAPC Chapter 1200-3-4) place restrictions on the timing and location (with regards to nearby residences, hospitals, roads, etc.) for any open burning. TVA would adhere to these regulations to insure that any open burning does not significantly impact the environment.

Pollution from fossil-fuel combustion in construction equipment and increased traffic during construction would also cause some minor and temporary impact on of air quality in the vicinity of the project. Combustion emissions consist of PM, sulfur dioxide (SO<sub>2</sub>), carbon monoxide (CO), nitrogen oxides (NO<sub>x</sub>), and hydrocarbons (HC). NO<sub>x</sub> and HC emissions participate in photochemical reactions in the atmosphere to form O<sub>3</sub>. As noted previously, the pipelines would be installed primarily near ground level to minimize excavation and placement of backfill. This approach would reduce the combustion-related emissions due to operation of construction equipment. Consequently,

TVA expects that these relatively minor combustion-related emissions would not result in any significant impacts to the environment.

### **3.1.3 Operational Impacts**

There are no operational impacts on air resources.

## **3.2 Water Quality**

### **3.2.1 Existing Conditions**

#### **Groundwater**

Geologic conditions at the inactive Watts Bar Fossil Plant site are generally considered to be the same as those at the WBN site. Information on Groundwater in the 1972 WBN EIS (TVA 1972) and the 1995 Supplemental Environmental Review (TVA 1995) were used to prepare the following description.

The Watts Bar Fossil Plant site is underlain by unconsolidated terrace and alluvial deposits consisting of gravel, sand, and clay. These surficial deposits average approximately 12.2 meters (40 feet) in thickness and are generally poorly water-bearing. The hydraulic conductivity of the terrace deposits is estimated to be 14.6 meters per day (48 feet/day) and porosity is estimated at 0.15. The average depth to groundwater in the surficial deposits is approximately 5.2 meters (17 feet) indicating an average saturated thickness of 7.0 meters (23 feet).

The Conasauga Formation, which is of Middle Cambrian age, forms the bedrock foundation at the site. This bedrock formation is composed of several hundred feet of interbedded limestones and shales. The general strike of the Conasauga is N30W, and the overall dip is to the southeast. The formation is poorly water-bearing with groundwater occurring in small fractures and bedding planes.

Groundwater system recharge at the site occurs from infiltration of local precipitation, which averages around 127 cm per year (50 inches per year) and from lateral underflow from the area north of the plant site. Approximately 20 to 25 cm (8 to 10 inches) of this precipitation enters groundwater storage. In this region, groundwater levels normally reach peak elevation in February and March and are at minimum levels in late summer and early fall. The depth to the water table is generally less than 6.1 meters (20 feet) throughout the site. All groundwater originating at the site ultimately discharges to the Tennessee River in upper Chickamauga Reservoir.

#### **Surface Water**

Water quality in the Tennessee River near the Watts Bar Fossil Plant is well documented by data collected during preparation of the WBN Environmental Impact Statements (NRC 1995, TVA 1972, TVA 1995). The quality of the water is generally good. It is slightly hard with hardness values generally less than 100 mg/L.

Surface water on the plant site is limited to local runoff and to waste treatment and holding ponds which have permitted discharges to the Tennessee River. Water may also continue to enter the ash pond from Watts Bar Reservoir. This water currently is conveyed to the Fossil Plant by two existing 78 inch concrete pipes to be used in proposed project. The discharge from this pond is permitted under NPDES.

#### **WBN Chemical Impacts**

Presently, WBN chemically treats the raw cooling and essential raw cooling water systems to control corrosion and biological fouling. The discharge of these systems provides makeup water to the CCW system. The CCW does not receive any direct injection of any of the chemical treatments. Only the residual remaining after passing through the raw water cooling systems is discharged into the CCW and is not counted on for any protective benefit in the CCW. These treatments are presently monitored with the combined cooling tower blowdown prior to discharging through the diffusers.

The NPDES permit regulates all liquid discharges of chemicals at the WBN Plant. To accomplish this task, the following chemicals are used in the manner described:

A copolymer dispersant is injected on a year-round continuous basis to keep settleable solids in suspension and thereby reduce accumulations of silt and rust. The release of the copolymer is anticipated to be no more than 0.2 milligram per liter (0.2 ppm) as active product.

Tetrapotassium pyrophosphate is injected on a year-round continuous basis to sequester iron from existing corrosion products in raw-water piping and ancillary components. The release of pyrophosphate at the diffuser discharge is not expected to exceed 0.2 milligrams per liter (0.2 ppm) as total phosphorus.

Zinc sulfate is injected on a year-round continuous basis to reduce corrosion rates of carbon-steel piping and components. The release of zinc sulfate is anticipated to be maintained at 0.2 milligram per liter (0.2 ppm) zinc.

Tolytriazole, a corrosion inhibitor, is injected periodically into the raw-water systems to reduce corrosion rates. Most of the heat exchangers cooled by the raw water systems are constructed with copper or copper-alloy tubes. The primary point of chemical injection is at the intake pumping station (about once every 2 weeks) when the river temperature is above 60° F.

Dodecylguanidine hydrochloride (DGH) and didecyltrimethyl ammonium chloride (Quat), non-oxidizing biocides, are injected periodically to eradicate clams and mussels and prevent MIC.

1-bromo-3-chloro-5,5-dimethylhydantoin (BCDMH), an oxidizing biocide used to reduce MIC and control Asiatic clams and Zebra mussels, is injected at the intake pumping station approximately four hours each day throughout the year. Samples of river water are collected periodically during clam-spawning season to monitor the concentration of Asiatic clam larvae entering the plant. Twice a year, BCDMH is injected continuously for at least three weeks after the peak clam-dissemination periods (unless a non-oxidizing biocide is used).

The pyrophosphate, zinc sulfate, and copolymer is injected into the raw-water systems using flow controllers located in the intake pumping station. The BCDMH is also injected at the intake pumping station. The primary point of chemical injection for tolytriazole and DGH is the intake pumping station; however, other locations may be used as permitted.

Further details of the chemical usage are provided in the present NPDES discharge permit and will not change due to the proposed SCCW project.

Some of these treatments introduce chemicals into the CCW which are undesirable to be discharged to the river. These treatments include:

- Tolytriazole, a corrosion treatment
- Nonoxidizing molluscicide treatment

Blowdown from the cooling towers is suspended during these treatments until the residual of the adverse chemicals decreases to environmentally acceptable levels for discharge to the river as committed to and regulated under National Pollutant Discharge Elimination System (NPDES) Permit TN0020168 for WBN. The concentrations in the present WBN discharge to the river are within permit limits. The present NPDES discharge permit for WBN has a maximum daily limitation of 0.10 mg/l for total residual chlorine in the diffuser discharge, Outfall 101.

#### **Oxygenation of Watts Bar Hydro Releases**

The Watts Bar Fossil Plant site is located within reach of the Tennessee River which, periodically, has been impacted by low dissolved oxygen in the releases from Watts Bar Dam. In 1996, TVA installed a line diffuser system in Watts Bar Reservoir to meet a target dissolved oxygen concentration (DO) of 4.0 mg/L in the hydro plant release (turbine discharge). The system consists of four line diffusers with a total length of 24,000 feet arranged in the forebay along the old riverbed ( See figure 3.2.1). Releases from Chickamauga Dam rarely contain low dissolved oxygen levels and there are no current plans to install an aeration system to address the occasional periods when releases from that dam drop to below 4 mg/L.



The system has the capacity to dispense 900 standard cubic feet per minute (scfm) or 50 tons/day of oxygen from a 15,000-gallon bulk liquid oxygen storage facility located near the east end of Watts Bar Dam. The oxygen diffuser system is operated on an "as needed" basis based on DO concentrations measured in the turbine discharge. Analysis of data collected from 1961 through 1993 indicates that DO concentrations in the WBH release can drop below 4.0 mg/L between the months of May and August, with the greatest likelihood occurring in June and July. Therefore, DO concentrations are monitored on a continuous basis between the months of May and August. Due to the shallower depth of the right side (facing downstream) of Watts Bar forebay, releases from WBH Units 1 and 2 typically have DO concentrations about 0.5 mg/L higher than releases from the other units. Preferential use of Units 1 and 2 provides some measure of relief during the low release DO season (June to August) and reduces liquid oxygen usage.

### **3.2.2 Construction Impacts**

Construction activities would result in exposed soils that could cause temporary increases in erosion and sediment runoff if not properly managed. Any stockpiled soil piles on the site would need to be avoided or moved. In addition, appropriate design and construction best management practices (BMPs) would be needed to minimize erosion and sediment runoff. Proper use of BMPs as appropriate would minimize the magnitude and duration of the impacts due to construction activity.

### **3.2.3 Operational Impacts**

#### **Wastewater Impacts**

Potential water quality impacts associated with the withdrawal and subsequent discharge of water from Watts Bar Reservoir include chemicals or wastes added to the water and reduced hypolimnetic dissolved oxygen concentrations in Watts Bar and Chickamauga Reservoirs.

Modifications and revisions would need to be made for both WBN and WBF NPDES permits. Potential aquatic impacts associated with WBN current chemical treatments are addressed in Section 3.3, Aquatic Ecology. During periods of chemical treatment of the CCW system, normal SCCW discharge would be suspended as necessary, until the residual treatment chemicals are within discharge permit limits.

TVA presently uses an O<sub>2</sub> diffuser system to meet a target DO level of 4.0 mg/l in the WBH turbine discharge as stipulated in the Reservoir Release Improvement (RRI) program. Installation of the SCCW project is not anticipated to adversely impact the DO level in the River.

The O<sub>2</sub> diffuser system has been designed with sufficient capacity to adequately oxygenate the flow through the 5 hydro units. The SCCW flow (~ 330 cfs) is a small fraction of the hydro discharge (< 1.0% of 5 hydro units). The added flow out of the Reservoir for the SCCW would not be sufficient to significantly impact the oxygen content of the water discharged through the hydro units. In fact the constant SCCW flow could even enhance the DO level due to the continuous movement of water through the reservoir and reducing the residence time in the forebay upstream of the dam.

The top of the turbine intake is at elevation 711.2 and the bottom is at elevation 663.75. The intake for the SCCW has a bottom elevation of 710.0, one foot below the turbine intake, and the top at about elevation 730. The differences in elevation is another reason the SCCW is not anticipated to adversely affect the DO provisions of the oxygenation system. The oxygenation system is designed so that the injected O<sub>2</sub> is absorbed in the lower 30 feet of the reservoir or below elevation 700 which is below the SCCW intake. Therefore the SCCW flow will not short circuit the oxygenated water from the turbine intakes. Stratification and the flow pattern in the forebay upstream of the dam further reduces the impact of the water withdrawn for the SCCW on the results obtained from the oxygenation system.

The impact of the SCCW discharge on the DO in the river is anticipated to be insignificant. The stratification and flow pattern upstream of WBH naturally results in a higher DO level on the west side of the reservoir where the SCCW intake is located. While the SCCW is withdrawn from a cooler subsurface layer of the forebay, the supply is from side of the reservoir and in the reservoir strata where the higher DO level naturally occurs. The discharge will have passed through the cooling tower prior to release to the river and should be saturated with oxygen as it falls through the tower. These conditions in combination with the SCCW withdrawal being small relative compared to minimum daily flows in the river result in insignificant impact. The potential impact of the additional waste heat on DO concentrations in Chickamauga Reservoir is also expected to be insignificant due to the SCCW withdrawal being small relative to minimum daily flows in the river.

The discharge flow of the proposed project would be approximately half of that discharged during operation of WBF. Since the discharge would go through the existing concrete tunnel, the velocity of the flow into the river for the proposed project would be half of that during WBF operation. Due to the reduced velocity, there would be no erosion expected to the banks of the Tennessee River.

### **Thermal effects**

A significant consideration of the proposed project would be the thermal impact of the heated effluent on the Tennessee River. The project was analyzed to determine compliance with water quality criteria for thermal discharge. Model results indicate that instream thermal criteria (1. maximum instream temperature of 86.9°F, 2. maximum rise of 5.4°F, and 3. maximum rate of change  $\pm 3.6^\circ\text{F/hr}$ ) can be met under normal operation of the supplemental CCW system, provided the bypass line is operated during months of December, February through April, and on an as-needed basis during November and January.

The thermal effects of WBN operation with the proposed SCCW system were modeled as described in Enclosure 1. Computer simulations of WBN operation were performed using recorded meteorology and dam releases for the period from January 1, 1976 through October 15, 1993. The ambient river temperature (WBH discharge temperature) was computed as a daily average. WBN intake temperature (ERCW and RCW systems) was computed on an hourly basis, as was the rate of change of downstream river temperature. The WBN discharge temperature (diffuser discharge and discharge through WBF structure) and downstream temperature were computed as 24-hour running averages. The maximum and monthly average computed values of ambient river temperature, WBN intake temperature, WBN discharge temperature, downstream river temperature, and instream temperature rise and rate of change of downstream temperature for the simulation period are shown in Table 3.2-1 for the existing WBN discharge and in Table 3.2-2 for the SCCW system. These results indicate the combined effects of the discharge from the WBF structure and the existing WBN diffusers. The instream temperature rise shown is the difference between the river temperature at the downstream end of the diffuser mixing zone and the temperature of the WBH discharge.

Sudden variations in the operation of the this project have the potential to impact the time rate of change of temperature in the river ( $\Delta T/\text{hr}$ ). Abrupt start or stop of the discharge flow, sudden changes in heat rejected to the CCW, and rapid initiation or stop of releases through the WBH were evaluated for any unfavorable effects. Fluctuations in heat load during normal startup, normal shutdown or load changes during operation, would not cause problems with the rate of rise due the gradual nature of the changes.

Normal startup or shutdown of the WBN unit would result in a gradual change in heat load as the reactor comes up in power or is shutdown. During startup, the discharge would initially be about the same temperature as the river and increase as the unit came up in power. This would occur over several hours to stay within feedwater chemistry and turbine startup limitations. During normal shutdown, the heat rejected to the CCW gradually reduces as the unit decreases in power over several hours. This results in a corresponding decrease in the heat load of the discharge flow. Sensitivity analyses on varying power levels at WBN from low loads to full power, indicate only a small variation in the final instream mixed temperature. Since TVA base loads nuclear units, WBN should rarely see significant load changes. In addition, normal startup and shutdown of the SCCW would occur when there is river flow equivalent to one WBH unit operating. All of this demonstrates that  $\Delta T/\text{hr}$  limits would continue to be met during normal startup and shutdown of WBN.

Since the WBH units are used as peaking load capacity, their remote dispatching will result in frequent variations in the river flow past the WBF discharge. The analyses run to model the thermal impact of the project ( Enclosure 1) included the actual flow variations through WBH which occurred during the period of January 1, 1976 through October 15, 1993. No problems with rate of rise were identified in these analyses with WBN at steady operation. Based on these results, it is concluded that  $\Delta T/hr$  limits will be met during fluctuations in flow releases through WBH. When the project is brought online, these modeling results would be verified at various times during the first year of operation. The scope and specific components of this monitoring would be determined by TVA in coordination with the Tennessee Department of Environment and Conservation.

Due to limits placed on the rate of temperature change for the main steam system and the main turbine and for feedwater chemistry control, abrupt startup and corresponding heat rejection to the CCW does not occur at WBN. The only mechanism to abruptly increase the heat load discharged to the river would be by initiation of the SCCW with the unit at power or closure of the bypass. The analysis indicates this is only a problem when the WBN unit is operating at power and with a simultaneous river flow of less than one WBH unit. This would be averted through procedural control to only allow SCCW flow changes when there is at least one WBH unit in operation and to require opening of the bypass as part of the SCCW startup or shutdown. Therefore, noncompliance with the  $\Delta T/hr$  limits would not occur due to a sudden increase in heat load. Unexpected shutdown due to a load shed, turbine trip or reactor trip are the events which would result in potential abrupt loss of heat load to the CCW. During these events, the reactor power level decreases almost immediately to about 6% of full power with residual heat continuing to decrease to approximately 1% within an hour. However, the impact of this dramatic decrease in heat input to the CCW is not immediately reflected in a drop in the temperature of the discharge to the river. The immense mass of heated water in the CCW ( approximately 7.5 million gallons ) acts as a thermal capacitor extending the duration required to drop the discharge temperature after the unit trip. Since cooler SCCW continues to flow into the CCW after unit trip, the discharge temperature would gradually decrease and eventually approach that of the SCCW supply. The most significant decrease occurs during the first hour after the unit trip when the heat input is so dramatically decreased. If this abrupt loss of the unit were to occur simultaneously with the maximum downstream river temperature rise in Table 3.2-2, a maximum drop of the discharge temperature of 15.5 °F would result during May. Should this extremely infrequent event occur, then, for a single hour, the rate of rise in the river could approximately - 4.5 °F in May and - 4.1 °F in June slightly exceeding the  $\pm 3.6$  °F/hr limit.

Operation of the supplemental CCW system would result in increased intake temperatures for the WBN RCW and ERCW systems. Based on historical data and normal WBH operations, there is little likelihood that the intake temperatures would reach or exceed the intake temperature safety limit of 85 °F (29.4°C). However, if the intake temperature should approach this limit, the intake temperature can be reduced by increasing discharge from WBH, operation of the bypass system, or by shutting down the supplemental CCW system. Should the WBH discharge temperature approach the WBN intake limit, initiation of WBN shut-down protocols would be required.

Based on the model results in Enclosure 1 and the above evaluations, operation of the proposed SCCW system would meet the instream thermal discharge criteria limits. While TVA is confident that the SCCW project would comply with thermal discharge criteria limits and no significant environmental impact would occur, a program would be implemented to monitor the instream temperature at various times during the first year of operation. Measurements will be taken to ascertain the instream mixed temperature approximately 1000 feet downstream of the WBF discharge structure and at the river bottom near the perimeter of the mussel relocation zone. This program will verify the resultant conclusions of the Environmental Assessment including thermal discharge temperature criteria are met with a 1000 ft mixing zone and 24 hr averaging time and adequacy of the mussel relocation zone to ensure the minimization of impact to bottom life. The program would also be designed to confirm the adequacy of using CORMIX3 to model the thermal plume for the SCCW discharge to the Tennessee River. The scope and specific components of this monitoring work would be determined by TVA in coordination with the Tennessee Department of Environment and Conservation.

In addition, based on previous evaluations of the simultaneous operation of WBN and Sequoyah Nuclear Plant (SQN), operation of the WBN SCCW system should have no significant effect on river temperatures in the vicinity of SQN.

**Table 3.2-1 Computed Temperatures Based On 1976-1993 Meteorology and Dam Releases  
24 hour averaging, 1230 MWe generation, without supplemental cooling water**

		Intake	River Temperature				Discharge Temperature				Total heat (BTU/hr)
		Temperature 24-Hr Avg (F)	ambient 24-Hr Avg (F)	downstream 24-Hr Avg (F)	rise 24-Hr Avg (F)	rate Hourly (F/hr)	WBN diffuser 1-Hr Avg (F)	24-Hr Avg (F)	SCCW 1-Hr Avg (F)	24-Hr Avg (F)	
January	Max	51.7	51.7	51.7	0.4	1.2	79.2	78	0	0	2.18E+08
	Avg	42	42	42.1	0.1	N/A	62.8	62.8	0	0	1.01E+08
February	Max	51	51	51.1	0.4	1.5	82.2	79.3	0	0	2.72E+08
	Avg	41.9	41.9	41.9	0.1	N/A	65.1	65.1	0	0	1.13E+08
March	Max	56.1	56.1	56.1	0.4	1.4	85.7	81.9	0	0	1.83E+08
	Avg	47.7	47.7	47.7	0.1	N/A	69.4	69.3	0	0	1.06E+08
April	Max	65.1	65.1	65.2	0.5	1.4	86.8	83.2	0	0	1.64E+08
	Avg	56.7	56.7	56.7	0.1	N/A	73.8	73.7	0	0	8.32E+07
May	Max	71.9	71.9	71.9	0.4	1.4	90.1	87.2	0	0	1.30E+08
	Avg	64.5	64.5	64.5	0.1	N/A	78.8	78.7	0	0	7.13E+07
June	Max	78.8	78.8	78.8	0.2	1.1	92.7	89.4	0	0	1.30E+08
	Avg	70.7	70.7	70.7	0	N/A	83.4	83.3	0	0	6.55E+07
July	Max	82.5	82.5	82.5	0.2	1.1	96	91.1	0	0	1.19E+08
	Avg	74.9	74.9	74.9	0	N/A	85.7	85.7	0	0	5.71E+07
August	Max	81.7	81.7	81.9	0.1	0.7	94.4	89.5	0	0	8.26E+07
	Avg	76.5	76.5	76.5	0	N/A	85	85	0	0	4.43E+07
September	Max	81.1	81.1	81.1	0.2	0.6	91.7	88.1	0	0	8.78E+07
	Avg	75	75	75.1	0	N/A	81.4	81.5	0	0	3.40E+07
October	Max	76.7	76.7	76.7	0.1	0.5	89	86.2	0	0	9.45E+07
	Avg	68	68	68.2	0	N/A	74.2	74.3	0	0	3.04E+07
November	Max	67.9	67.9	68.1	0.2	1	84.6	82.7	0	0	1.37E+08
	Avg	58.8	58.8	59	0	N/A	69.5	69.7	0	0	5.18E+07
December	Max	59.2	59.2	59.5	0.3	1.1	84.1	80.9	0	0	1.80E+08
	Avg	48.7	48.7	48.9	0	N/A	64.9	64.9	0	0	7.83E+07

**Table 3.2-2 Computed Temperatures Based On 1976-1993 Meteorology and Dam Releases**  
**24 hour averaging, 1230 MWe generation, with supplemental cooling water**  
**3 CCW pumps, Jan -Feb; Bypass flow Nov - Apr**

		Intake Temperature	River Temperature				Discharge Temperature				Total heat (BTU/hr)
		24-Hr Avg (F)	ambient 24-Hr Avg (F)	downstream 24-Hr Avg (F)	rise 24-Hr Avg (F)	rate Hourly (F/hr)	WBN diffuser 1-Hr Avg (F)	WBN diffuser 24-Hr Avg (F)	SCCW 1-Hr Avg (F)	SCCW 24-Hr Avg (F)	
January	Max	52.8	51.7	52.7	3.8	1.4	77.2	77.1	64.6	64.9	1.31E+09
	Avg	43.5	42	43.7	1.6	N/A	60.7	60.8	52.5	52.5	6.83E+08
February	Max	52.8	51	52.7	3.8	1.7	80.3	77.4	65	63.6	1.39E+09
	Avg	43.7	41.9	43.7	2	N/A	63.1	63.1	53.7	53.7	7.71E+08
March	Max	59.1	56.1	58.5	4	1.5	85.7	81.8	72.4	70.2	1.37E+09
	Avg	49.6	47.7	49.6	2	N/A	69.4	69.3	59.8	59.7	7.92E+08
April	Max	66.4	65.1	66.3	3.2	1.4	86.8	83.1	75.8	74	1.25E+09
	Avg	58.2	56.7	58.3	1.7	N/A	73.8	73.7	66.3	66.2	7.11E+08
May	Max	75.2	71.9	74.4	5.3	3.5	90.1	87.2	90	87.2	1.84E+09
	Avg	67.1	64.5	67.1	2.7	N/A	78.8	78.7	78.7	78.6	1.02E+09
June	Max	80.2	78.8	80	4.2	1.6	92.6	89.4	92.6	89.4	1.69E+09
	Avg	72.8	70.7	72.8	2.1	N/A	83.4	83.3	83.4	83.3	9.17E+08
July	Max	83.7	82.5	83.5	3.4	1.6	95.9	91	95.9	91	1.55E+09
	Avg	76.5	74.9	76.5	1.6	N/A	85.7	85.7	85.7	85.7	7.81E+08
August	Max	82.9	81.7	82.8	2.4	1.3	94.3	89.4	94.2	89.4	1.15E+09
	Avg	77.7	76.5	77.7	1.2	N/A	85	85	85	85	6.10E+08
September	Max	82.3	81.1	82	2.4	1	91.7	88.1	91.6	88.1	1.03E+09
	Avg	76.1	75	76.2	1.1	N/A	81.4	81.5	81.4	81.5	4.63E+08
October	Max	78.3	76.7	78	3.1	1.1	89	86.2	89	86.2	1.31E+09
	Avg	69.3	68	69.4	1.3	N/A	74.2	74.3	74.2	74.3	4.25E+08
November	Max	69.4	67.9	69.7	3.1	1.2	84.6	82.7	76.8	78.9	1.08E+09
	Avg	59.9	58.8	60.2	1.2	N/A	69.5	69.6	64.8	65	4.26E+08
December	Max	60.6	59.2	60.7	3.7	1.5	84.1	80.9	71.4	69.3	1.23E+09
	Avg	50.1	48.7	50.3	1.5	N/A	64.9	64.9	57.7	57.8	5.90E+08

Definition of column headings for tables 3.2.1 and 3.2.2:

**Intake Temperature** - Intake temperature for the RCW and ERCW systems (°F), determined by adding the instream temperature rise due to the SCCW discharge to the ambient river temperature.

**River Temperature**

- ambient - Ambient river temperature (WBH discharge temperature) (°F)
- downstream - River temperature at downstream end of WBN diffuser mixing zone (°F)
- rise - Instream DT at downstream end of WBN diffuser mixing zone (F°)
- rate - Rate of change of river temperature at downstream end of WBN diffuser mixing zone (F°/hr)

**Discharge Temperature**

- WBN Diffuser - Temperature of discharge through WBN diffuser (°F)
- SCCW - Temperature of discharge through SCCW surface discharge (°F)

**Total Heat** - Combined heat discharge to river from WBN diffuser and SCCW discharge (BTU/hr)

**Chemical Impacts**

The chemical characteristics of the discharge are dependent upon the concentration level of dissolved solids in the CCW system. This is a function of the evaporative losses from the towers and the combined rate of makeup plus SCCW flows of river water. With maximum evaporative losses of 15,000 gpm and a minimum total flow into the towers of 85,000 gpm, the maximum concentration of dissolved solids would be approximately 1.4 times that in the river. A normal range of 1.1 to 1.2 concentrations would result from operation of this system.

Implementation of the SCCW will not increase or change the use of chemicals. Corrosion control chemicals are not used specifically for the CCW system which the SCCW supplies. These chemicals are only used in the once-through

auxiliary cooling systems, ERCW and RCW. Also biocide chemicals for mollusk control are presently only used in the ERCW and RCW systems. Since the CCW system does not receive direct injection of these chemicals, there would be no change to the present use of such chemicals. While the total poundage of the chemicals released to the river would remain unchanged, the implementation of the proposed project would result in a decrease in the average ppm of continuously injected chemicals in the diffuser discharge. This is due to the decrease in concentration levels in the CCW resulting from the input of the SCCW flow mass.

As discussed in Section 3.2.1, cooling tower blowdown is temporarily suspended during certain periodic chemical treatments. The discharge of the SCCW system would also be suspended during these same times to prevent the introduction of these chemicals to the river.

An algicide treatment may be specifically used in the CCW in the future and is approved in the present NPDES permit for WBN. This chemical would be injected as short duration dose shock treatment. SCCW supply would be suspended during the CCW treatment so that the amount of chemical is dependent of the fixed volume of the CCW system which is unchanged. Therefore, the proposed project would not require any increase use of this chemicals.

Also as discussed in Section 3.2.1, there is discharge of residuals from continuous corrosion control chemical treatments. The higher makeup rate due to the SCCW would result in further dilution and lower concentrations of the residual in the discharge to the river through the present WBN discharge point and the proposed WBF discharge.

As pointed out in Section 3.2.1, the present NPDES discharge permit for WBN has a maximum daily limitation of 0.10 mg/l for total residual chlorine in the diffuser discharge, Outfall 101. While not a permit limitation, the rationale used in approving the permit limit was based on a water quality requirement that the maximum in-stream concentration not exceed 0.019 mg/l as an instantaneous maximum and 0.011 mg/l as a weekly average. Operation of the proposed SCCW will ensure continued compliance with the in-stream concentration limits.

Actual measurements of the residual chlorine concentrations in the WBN discharge since the plant went into operation indicate the highest daily maximum has been 0.088 mg/l and the highest daily average has been 0.037 mg/l. The majority of the time the residuals were at or below the measurable level of 0.025 mg/l. This is an indication of the low residual in the CCW system and reflects the chlorine demand of the CCW system and the scrubbing effect of the water passing through the cooling tower. With the proposed project the chlorinated makeup streams, ERCW and RCW, will be total mixed with the SCCW as it passes through the CCW system. The affect of the mixing of the SCCW, ERCW and RCW will be to decrease the residual chlorine in the CCW to below measurable levels. This will result due to the significant chlorine demand of the large volume of raw river water for the SCCW. Accordingly, the SCCW discharge as well as the present blowdown will contain lower residual concentrations.

Using a mass balance evaluation with a discharge flow of 270 cfs (135,000 gpm) and a conservative concentration of 0.025 mg/l in the proposed SCCW discharge, a minimum stream flow of 85 cfs would be required to meet the 0.019 mg/l instantaneous maximum in-stream concentration. A minimum stream flow of 343 cfs would be required to meet the 0.011 mg/l weekly average. A conservative estimate of leakage alone through WBH is about 250 cfs which is almost three times the minimum to meet the instantaneous maximum in-stream concentration limit. Operation of a single WBH unit at minimum capacity (approximately 4000 cfs) for 2 hours in any day would be more than adequate to meet the minimum stream flow of 343 cfs for the instream weekly average. It is concluded that there will be no adverse impact on the river from chlorine due to the operation of the SCCW.

### **3.3 Aquatic Ecology**

#### **3.3.1 Existing Conditions**

##### **Fish Community, Sport/Commercial Fishery**

Aquatic communities in the inflow, transition, and forebay zones of all Tennessee River reservoirs, and several major embayments, are sampled routinely as part of the TVA Vital Signs Monitoring Program to assist in monitoring

reservoir environmental quality. One part of this program uses electrofishing and experimental gill netting results to calculate Reservoir Fish Assemblage Index (RFAI) scores as an expression of fish community quality. RFAI results are available from the forebay area of Watts Bar Reservoir (TRM 531) in the vicinity of the WBF intake; upper Chickamauga Reservoir (TRM 529) in the vicinity of the WBN and WBF plant discharges; and below these plant discharges at the Chickamauga Reservoir transition zone (TRM 490).

RFAI sampling results (Table 3.3.1) indicate similar communities at all three locations. A total of 38 fish species was collected from the Watts Bar forebay and the Chickamauga transition site, with 42 species recorded during sampling in the vicinity of the WBN and WBF discharges (Chickamauga inflow). No consistent change in fish community status at these locations appears to have occurred since the program was initiated in 1990 (Scott, 1992 and Dycus, 1995). Annual variations within each site are minimal. Average RFAI scores from each site compare favorably with average scores from similar areas in other mainstream Tennessee River reservoirs (Table 3.3.2).

Reservoir-wide creel surveys have been conducted periodically on Chickamauga and Watts Bar reservoirs by Tennessee Wildlife Resources Agency (TWRA). Black basses (*Micropterus* sp.) have been the most sought after sport fish in both reservoirs in recent years, accounting for 34 to 41 percent of the overall fishing effort during 1993 through 1995 (O'Bara, 1994; 1995; 1996). Crappie (*Pomoxis* sp.) drew 14 to 22 percent of the fishing effort during these years, striped bass 4 to 14 percent, sauger made up 3 to 6 percent, and catfish 1 to 11 percent. Sport Fishing Index (SFI) scores for largemouth bass and sauger indicate Watts Bar and Chickamauga rated in the top ten out of 35 reservoirs in the Tennessee and Cumberland River basins regarding quality of the fisheries for each of these species (TVA unpublished data). The channel catfish fishery in these two reservoirs ranked in the top 15.

Recreational fishing data in the Watts Bar tailwater (TRM 523.2 to TRM 529.9) also were collected during both preoperational and operational monitoring for WBN using access point angler creel surveys (Baxter et al. 1997). Preoperational creel results were limited to catch rate estimates, average weight of each species, and percent composition of the catch. During WBN operational monitoring (April 1996 through March 1997), harvest, catch, and effort data were collected to characterize the fishery in the vicinity of the WBN and WBF discharges.

Baxter et al. (1997) concluded that the operation of WBN had no impact on the Watts Bar tailwater fishery during the initial year of operation. Operational creel results indicated a majority of fishing in the area below Watts Bar Dam (71%) was done from the bank, with 49 % of this pressure being exerted along the bank adjacent to the WBF and WBN plants. Anglers expended an estimated 277,284 hours of effort during the initial year of operation with an average daily effort of 597 hours on weekdays and 1209 hours on weekend days indicating this is a heavily used tailwater for fishing. Monthly angling effort varied somewhat throughout the year with highest effort during March, May, June, and July (Figure 3.3.1).

Catfish were the main species sought by anglers in the Watts Bar Dam tailwater area during operational monitoring (Table 3.3.3). Sauger, white bass, black basses, and striped bass also were important to the fishery. Catfish angling effort was highest during summer months, with sauger dominating the fall and winter fishery (Baxter et al. 1997). Angling effort for white bass and crappie was highest during winter and spring months, and striped bass fishing occurred mainly during fall and winter months.

Creel results including all anglers reveal that bluegill, white bass, catfish, yellow bass, sauger, crappie, and black bass were caught in the Watts Bar tailwater more frequently than any other species (Figure 3.3.2). A majority of the sauger, white bass, and striped bass are caught along the side of the tailwater adjacent to the WBF and WBN plants as these species of fish orient to the current coming through the generators located in this side of Watts Bar Dam. Catfish also congregate along the current during summer months. During non-generation periods, individuals of all these species tend to roam the tailwater area and are not as concentrated.

Commercial fishing in the vicinity of WBF and WBN is not possible due to current velocities in the area making netting virtually impossible. Commercial netting is not permitted in Watts Bar Reservoir. Therefore, potential impact of the WBN SCCW project on commercial fishing is not an issue.

Table 3.3.1. Species of Fish Collected during TVA Vital Signs Monitoring between 1991 and 1996 from Watts Bar Reservoir Forebay (TRM 531), Chickamauga Reservoir Inflow (TRM 529), and Chickamauga Reservoir Transition (TRM 490).

Scientific Name	Common Name	TRM 531	TRM 529	TRM 490
<i>Ichthyomyzon castaneus</i> *	Chestnut lamprey			X
<i>Lepisosteus oculatus</i>	Spotted gar	X		X
<i>Lepisosteus osseus</i>	Longnose gar	X	X	
<i>Alosa chrysochloris</i>	Skipjack herring	X	X	X
<i>Dorosoma cepedianum</i>	Gizzard shad	X	X	X
<i>Dorosoma petenense</i>	Threadfin shad	X	X	X
<i>Hiodon tergisus</i>	Mooneye	X	X	
<i>Camptostoma anomalum</i>	Central stoneroller		X	X
<i>Cyprinella spiloptera</i>	Spotfin shiner	X	X	X
<i>Cyprinella whipplei</i>	Steelcolor shiner	X	X	
<i>Cyprinus carpio</i>	Common carp	X	X	X
<i>Notemigonus crysoleucas</i>	Golden shiner	X	X	X
<i>Notropis atherinoides</i>	Emerald shiner	X	X	X
<i>Notropis chrysocephalus</i> *	Striped shiner		X	
<i>Pimephales notatus</i>	Bluntnose minnow	X	X	X
<i>Pimephales vigilax</i>	Bullhead minnow	X		X
<i>Carpiodes carpio</i>	River carpsucker			X
<i>Carpiodes cyprinus</i>	Quillback		X	
<i>Hypentelium nigricans</i>	Northern hog sucker	X	X	
<i>Ictiobus bubalus</i>	Smallmouth buffalo	X	X	X
<i>Minytrema melanops</i>	Spotted sucker	X	X	X
<i>Moxostoma duquesnei</i>	Black redhorse		X	
<i>Moxostoma erythrurum</i>	Golden redhorse		X	
<i>Ictalurus furcatus</i>	Blue catfish	X	X	X
<i>Ictalurus punctatus</i>	Channel catfish	X	X	X
<i>Pylodictis olivaris</i>	Flathead catfish	X	X	X
<i>Labidesthes sicculus</i>	Brook silverside	X	X	X
<i>Morone chrysops</i>	White bass	X	X	X
<i>Morone mississippiensis</i>	Yellow bass	X	X	X
<i>Morone saxatilis</i>	Striped bass	X	X	X
<i>Lepomis auritus</i>	Redbreast sunfish	X	X	X
<i>Lepomis cyanellus</i>	Green sunfish	X	X	X
<i>Lepomis gulosus</i>	Warmouth	X	X	X
<i>Lepomis macrochirus</i>	Bluegill	X	X	X
<i>Lepomis megalotis</i>	Longear sunfish		X	X
<i>Lepomis microlophus</i>	Redear sunfish	X	X	X
<i>Micropterus dolomieu</i>	Smallmouth bass	X	X	X
<i>Micropterus punctulatus</i>	Spotted bass	X	X	X
<i>Micropterus salmoides</i>	Largemouth bass	X	X	X
<i>Pomoxis annularis</i>	White crappie	X	X	X
<i>Pomoxis nigromaculatus</i>	Black crappie	X	X	X
<i>Perca flavescens</i>	Yellow perch	X	X	X
<i>Percina caprodes</i>	Logperch	X	X	X
<i>Stizostedion canadense</i>	Sauger	X	X	X
<i>Stizostedion vitreum</i>	Walleye	X	X	X
<i>Aplodinotus grunniens</i>	Freshwater drum	X	X	X
	TOTAL	38	42	38

\* Species either not full-time residents of reservoirs or usually not captured with these gear types.

**Table 3.3.2. Reservoir Fish Assemblage Index Scores (higher scores indicate better quality) from the vicinity of WBF intake (TRM 531), in the vicinity of WBN/WBF discharges (TRM 529), and below the WBN/WBF outlets (TRM 490).**

Year	TRM 531	TRM 529	TRM 490
1990	42	50	45
1991	42	48	45
1992	35	42	41
1993	39	56	51
1994	43	52	43
1995		44	50
1996	41	38	44
Average	40	47	46
Mainstream Reservoir Averages (1991-1995)	41	42	41
	(forebay zones)	(inflow zones)	(transition zones)

**Table 3.3.3 Estimated effort for major species sought after by fishermen in the Watts Bar tailwater fishery, April 1996 through March 1997.**

Directed Species Group	Percent Effort	Estimated Effort (hours)	Estimated Trips
Any Species	32	88,731	19,587
Catfish	22	61,002	13,801
Sauger	13	36,045	7,853
White Bass	12	33,274	6,681
Striped Bass	6	16,637	4,413
Black Basses	6	16,637	2,955
Sunfish	5	13,864	2,818
Crappie	4	11,091	2,509

### Bottom Life

The aquatic insects, snails, and other animals which live in and on the river bottom in the Watts Bar tailwater were sampled most recently in 1996 as part of the operational monitoring program for WBN (Baxter, et al. 1997). A total of 86 different taxa (identified to orders, families, genera, or species) was found at the five sampling sites in the tailwater (between TRM 521.0 and 528.5). The most abundant species at the two stations near the WBF discharge was the planarian *Dugesia tirgrina* (28 percent of the average site total), followed by the Asiatic clam, *Corbicula fluminea*, (24 percent), and the amphipod *Gammarus minus* (18 percent). These three species, accompanied by the next three most abundant taxa (a trichopeteran, *Cyrmellus fraternus*; Chironomidae; and Tubificidae) accounted for 91 percent of the total number of animals encountered at these sites.

### Freshwater Mussels

The State of Tennessee has designated the first 10 miles of the Tennessee River downstream from Watts Bar Dam (TRM 529.9 - 520.0) a mollusk sanctuary. The taking of aquatic mollusks and the degradation and/or destruction of aquatic habitat is prohibited in this reach of the river.

As part of the monitoring program for the WBN Project and for other purposes, TVA aquatic biologists have conducted several examinations of freshwater mussels in the Tennessee River downstream from Watts Bar Dam. Three of these studies include sites within the two-mile reach just downstream from the dam. Starting in 1983, TVA staff have been routinely monitoring the status of mussel stocks in three "mussel beds" near WBN, including a mile-long bed along the left (descending) shore of the river opposite this project site (between River Miles 528.0 and 529.0). In 1990, TVA mussel divers searched several sites between WBN and the dam which would have been

affected by construction of a (then) proposed new lock and a possible new bridge (between River Miles 527.9 - and 529.4). In 1997, as part of this project, TVA divers searched for mussels just offshore from the WBF discharge (at River Mile 529.2).

Pertinent results from these studies are presented in Tables 3.3.4 and 3.3.5. As indicated in Table 3.3.4, live representatives of 13 native mussel species were found just offshore from the WBF discharge. The most abundant species found near this discharge was the elephantear, *Elliptio crassidens* (57 percent of the total), while three other species (pink heelsplitter, *Potamilus alatus*; pimpleback, *Quadrula pustulosa*; and Ohio pigtoe, *Pleurobema cordatum*) each accounted for at least five percent of the total. Mussels were relatively scarce throughout this area (on average, one animal per three square meters) and appeared to be rather evenly distributed.

Results from other pertinent mussel surveys (Table 3.3.5), indicate that a total of 25 native species have been found in recent years within this two-mile river reach; however, several species have been encountered only in the well-studied mussel bed along the left shore. When the sample size is large enough (at least 50 mussels), the elephantear is nearly always the most abundant species (23 - 81 percent of the total). Other abundant species typically include the Ohio pigtoe, pimpleback, and purple wartyback, *Cyclonaias tuberculata*, usually in that order. The available abundance estimates (presented in Table 3.3.5) indicate that mussels are relatively scarce along the right shore both upstream and downstream from the WBF discharge (about one animal per two square meters) and appear to be less abundant along the left shore near the lock and dam (one per 10 square meters). The single set of abundance estimates made along the left shore downstream from the dam indicates that mussels are more abundant there (an average of 1.2 mussels per square meter); however, those results include considerable variation, perhaps because some of the sites are within the known bed and others are outside of it.

A recent summary of native mussel information from the Watts Bar Dam tailwater (TVA and NRC 1995) indicates that the surviving animals are remnants of the much more diverse mussel community which existed in this part of the river before the dams were built. Nearly all of the individual mussels are large and, apparently, quite old. Very few of the species show any evidence of recent recruitment.

**Table 3.3.4. Freshwater mussels encountered during diver-conducted searches of transects located just off shore from the Watts Bar Fossil Plant discharge (Tennessee River Mile 529.2), May 27, 1997.**

<b>Species</b>	<b>Near Shore</b>	<b>~ 20 Meters off shore</b>	<b>~ 30 Meters off shore</b>	<b>Totals</b>
<i>Elliptio crassidens</i>	27	16	19	62
<i>Potamilus alatus</i>	7	4	1	12
<i>Quadrula pustulosa</i>	4	4	2	10
<i>Pleurobema cordatum</i>		1	6	7
<i>Anodonta grandis</i>	2	1		3
<i>Cyclonaias tuberculata</i>		1	2	3
<i>Quadrula metanevra</i>			3	3
<i>Ellipsaria lineolata</i>		2		2
<i>Leptodea fragilis</i>	2			2
<i>Lampsilis abrupta</i> ©			1	1
<i>Lampsilis ovata</i>		1		1
<i>Ligumia recta</i>			1	1
<i>Obliquaria reflexa</i>	1			1
<b>Total Specimens</b>	43	30	35	108
<b>Species Included</b>	6	8	6	13
<b>Search Area (m<sup>2</sup>)</b>	100	100	110	310
<b>Number/m<sup>2</sup></b>	0.43	0.30	0.32	0.35

© - federal endangered species

Table 3.3.5. Results of other recent mussel surveys within two river miles downstream from Watts Bar Dam, Tennessee River Miles (TRM) 529.9 to 527.9.

Species	TRM 529.4 R* (1990)	TRM 529.4 L (1990)	TRM 527.9- 528.6R (1990)	TRM 527.9- 528.6L (1990)	TRM 528.2- 529.0L (1996)	TRM 528.2- 529.0L (1983- 1994)
<i>Elliptio crassidens</i>	21	2	32	204	268	2921
<i>Pleurobema cordatum</i>	17		4	34	47	530
<i>Quadrula pustulosa</i>	1	4	52	4	20	241
<i>Cyclonaias tuberculata</i>	4		8	5	13	142
<i>Potamilus alatus</i>	1		6	1	4	50
<i>Ellipsaria lineolata</i>			3		9	43
<i>Amblema plicata</i>	2	4	3	1	3	39
<i>Lampsilis abrupta</i> ☉	2			1	1	26
<i>Anodonta grandis</i>		1	2		1	20
<i>Ligumia recta</i>			1		1	18
<i>Quadrula metanevra</i>	1				1	18
<i>Actinonaias ligamentina</i>						8
<i>Lampsilis ovata</i>						8
<i>Leptodea fragilis</i>			3	2	1	8
<i>Megalonaias nervosa</i>						7
<i>Obliquaria reflexa</i>	4	1	20			7
<i>Tritogonia verrucosa</i>		2	4		1	7
<i>Elliptio dilatata</i>			1	1		6
<i>Pleurobema oviforme</i>						6
<i>Anodonta suborbiculata</i>						1
<i>Cyprogenia stegaria</i> ☉						1
<i>Fusconaia maculata</i>						1
<i>Lasmigona complanata</i>						1
<i>Pleurobema plenum</i> ☉						1
<i>Ptychobranhus fasciolaris</i>						1
<i>Lasmigona costata</i>					1	
<b>Total Specimens</b>	53	14	139	253	371	4111
<b>Species Included</b>	9	6	13	9	14	25
<b>Sample Area (m<sup>2</sup>)</b>	100	100	250	200	nd	nd
<b>Number/m<sup>2</sup></b>	0.53	0.14	0.56	1.26	--	--

\* - L = along Left (descending) shore; R = along Right shore

☉ - federal endangered species

nd - not determined (survey conducted using time intervals, not area)

### 3.3.2 Construction Impacts

Aquatic species would not be affected by construction associated with this project as construction activities will not occur in the water or along the shoreline. Use of appropriate erosion control BMPs during construction would prevent sedimentation effects on fish, mussels, and other benthic organisms.

### **3.3.3 Operational Impacts**

#### **3.3.3.1 Fisheries - Entrainment**

The proposed use of the WBF intake to supply water for WBN would involve half of the water volume used when WBF was in service. A 316(b) entrainment study (TVA 1976) conducted biweekly during the period March 24 through July 28, 1975, estimated hydraulic entrainment by WBF to range from 0 to 1.53 percent of reservoir flow. Estimated entrainment of total fish larvae ranged from 0.11 to 0.86 percent of the total population transported through Watts Bar Dam generators during the period sampled. Total larval fish entrainment during the entire sampling period was estimated to be 0.24 percent of the transported population. The low (0.24%) estimated entrainment of larval fish resulted in a conclusion of no significant adverse impact on the fisheries resource of Watts Bar Reservoir from the WBF intake. The proposed SCCW project would result in loss of fish eggs and larvae through entrainment at half (0.12% estimated entrainment) previous levels.

#### **3.3.3.2 Fisheries - Impingement**

As part of 316(b) monitoring at TVA fossil plants, fish impinged on the WBF intake traveling screens were collected during weekly 24-hour counts from August 1974 through July 1975. During the 29 samples, a total of 2,507 fish was impinged. Twenty-two species were represented, with threadfin shad comprising 59 percent of the total. Other dominant species in impingement samples were freshwater drum (13%) and bluegill (12%). Expanding numbers from 29 samples to a total of 273 days during the period sampled, an estimated 21,787 fish were impinged during August 1974 through July 1975 (Table 3.3.6). SCCW operation would require half of the intake volumes of WBF; however only half of the intake screens would be in use. Therefore, the intake velocity and resultant fish impingement of the SCCW would be similar to that occurring during the previous WBF operational monitoring.

**Table 3.3.6 – Annual Fish Impingement Projection**

	Aug. 1974	Sept. 1974	Oct. 1974	Nov. 1974	Dec. 1974	Jan. 1975	Feb. 1975	Mar. 1975	Apr. 1975	May 1975	June 1975	July 1975	Total
Days sampled	4	4	4	3	3	3	3	3	2	4	4	5	42
Days/month	31	30	31	30	31	31	28	31	30	31	30	31	365
Threadfin Shad	620	1,658	178	90	413	951	1,017	3,710	3,210	1,387	83	831	12,784
Gizzard Shad	8	23	8	0	124	21	19	52	45	54	135	50	539
Skipjack Herring	23	23	295	150	382	62	56	620	315	8	0	31	1,695
Mooneye	0	0	0	0	0	0	19	10	30	0	8	0	52
Emerald Shiner	0	0	0	0	0	0	0	0	15	62	0	6	87
Steelcolor Shiner	0	0	8	0	10	10	0	0	0	0	0	0	26
Bullhead Minnow	0	8	0	0	0	0	0	0	0	0	0	0	9
Smallmouth	0	0	0	0	0	0	0	10	0	0	0	0	9
Blue Cat	0	30	0	10	10	0	0	10	0	8	0	0	70
Channel Catfish	0	68	39	10	0	21	9	21	90	39	0	19	295
Flathead Catfish	8	15	0	0	0	0	0	0	0	0	0	0	26
White Bass	0	0	0	80	52	0	0	0	150	0	0	118	365
Yellow Bass	0	8	0	0	0	0	0	0	0	0	0	0	9
Striped bass	0	0	0	0	0	0	0	10	0	0	0	19	35
Redbreast SF	0	0	0	0	0	0	0	0	0	0	0	0	9
Bluegill	271	953	155	120	21	10	0	21	180	155	150	329	2,642
Smallmouth Bass	16	23	0	0	0	0	0	0	0	0	0	0	43
Spotted Bass	0	0	0	0	0	0	0	0	0	0	0	43	61
White Crappie	0	68	23	0	10	31	0	10	90	16	0	6	226
Black Crappie	0	0	0	0	0	0	0	0	0	0	0	6	9
Logperch	0	0	0	0	0	0	0	0	0	16	0	6	26
Freshwater Drum	380	188	101	30	62	62	308	351	615	178	308	279	2,772
	1,325	3,060	806	490	1,085	1,168	1,428	4,826	4,740	1,922	683	1,748	21,787

### 3.3.3.3 Fisheries - Thermal Impacts

The main thermal-related fishery impacts anticipated from the WBN operational change include: 1) concentration of fish and fishermen in the vicinity of the WBF discharge, 2) potential for fish kills in the immediate vicinity of the WBF discharge, and 3) potential for impacts on reproduction or growth of important sport and prey fish species.

Heated effluents can concentrate fishing effort and fish on a reservoir, especially during winter months (McNurney and Dreier, 1981), thus increasing the potential for adverse impacts. Concentrating fishermen together with large aggregations of a particular species of fish can result in overharvest and a subsequent decline of that fishery. However, recent information on sport fishing and sport fish communities in the vicinity of WBN (Baxter et. al. 1997) and Sequoyah Nuclear Plant (SQN) (Wrenn et al. 1989 and Kay and Buchanan 1995) revealed limited concentration of fishermen or fish in plant discharge areas. No adverse impacts were documented on fishermen effort or success, or sport fish communities as a result of heated water effluents from these plants.

Plant operational changes can result in rapid shifts in environmental conditions such as water temperatures, which can adversely impact fish populations. Under "worst case" conditions described during April for WBN SCCW system operation (see Section 3.2.3 and Enclosure 1), water temperatures at the end of the mixing zone (305 meters or 1000 feet downstream of the WBF discharge) will increase a maximum of only 2.3°C (4.1°F) above ambient water temperatures. Except in extreme instances (rapid changes in water temperature greater than 10°C or 18°F), thermal impacts to resident fish species are minimized if timely relief from the condition is available. Only at temperatures near the upper lethal limit for a particular species will a limited exposure to higher temperatures at the end of the mixing zone of the WBN SCCW potentially have adverse impacts. Even under these circumstances, Neill and Magnuson (1974) reported that yellow perch (*Perca flavescens*), a cool-water relative to sauger, make short-term feeding forays (2 to 3 hours) into water heated up to 3°C above their upper lethal temperature with no adverse effects.

The greatest potential for adverse impact due to operational changes under the WBN SCCW project involves water temperatures in the immediate vicinity of the WBF discharge. Section 3.2.3 details how the immediate area of the SCCW discharge will be influenced during startup and shutdown of the SCCW system. No adverse impacts to fish are anticipated during normal operation, at startup, or at shutdown due to the gradual nature of the discharge temperature changes under these conditions. When an unexpected WBN shutdown occurs (i.e. load shed, turbine trip, or reactor trip) there potentially could be an abrupt loss of heat load to the CCW, resulting in a maximum drop of the temperature at the point of discharge of 9.1°C (15.5°F) after one hour, with a maximum instream rate of change of -2.5°C/hr (-4.5°F/hr). Since these worst-case conditions occur during May and June, when ambient water temperatures are around 20-25°C, this level of water temperature decrease will not cause mortality of even the most cold water sensitive fish species, threadfin shad. If the abrupt temperature decline were to occur during times when the ambient temperatures were near the lower lethal limit of threadfin shad (10°C, Griffith 1978), threadfin in the immediate vicinity of the discharge could experience mortality. Water temperature decreases due to unexpected WBN shutdown during winter months could result in declines of up to 3.3°C (6°F) at the point of discharge after one hour. Under these conditions, limited mortality of threadfin shad could occur. This is due to the warm discharge providing a refuge from the colder ambient water thereby preventing the seasonal mortality that normally occurs for this cold sensitive species. No other fish species is anticipated to experience mortality under operation of WBN with the SCCW.

The hydrology of the discharge (see Enclosure 1) is such that lethal temperatures involve the entire water column for only a few meters horizontally. Water temperatures will dissipate rapidly until the  $\Delta T$  at a distance of 30.5 meters (100 feet) from the outlet is reduced to 5.6°C (10°F), which is sub-lethal to even the most thermally intolerant species, except near their lethal temperature limits. The current  $\Delta T$  limit of <3°C (5.4°F) at the end of the mixing zone will be attained within 46 meters (150 feet) of the discharge. This should allow fish residing in the vicinity of the discharge to avoid the maximum  $\Delta T$  and prevent, or minimize fish mortality at unexpected WBN shutdown.

The potential for impacts on reproduction or growth vary with individual species, and a review of these possible impacts requires the use of representative species. Fish species to be addressed individually include sauger,

threadfin shad, catfish, white bass, and striped bass. Sauger is an important cool-water sport fish species with a relatively low maximum thermal tolerance (Koenst and Smith, 1976). Threadfin shad is a major forage species in the reservoir that experiences severe stress below 10°C and near total mortality below 4°C (Griffith, 1978; Lewis and Heidinger, 1979; Irwin and Bettoli, 1995). White bass is an important warm-water sport fish in the Watts Bar tailwater area. Striped bass is an introduced "trophy" species, that, like sauger, is sensitive to high temperatures. Catfish, which constitute a majority of the fishery in the tailwater area during summer months, are relatively tolerant species.

### Sauger

Sauger populations in Tennessee River reservoirs historically have experienced considerable fluctuations in density (Hackney and Holbrook, 1978). An extreme sauger population decline in Chickamauga Reservoir during the mid to late-1980s was documented by Hevel (1988), Hickman et al. (1989), Hickman et al. (1990), and Hevel and Hickman (1991). Yeager (1990), St. John (1990), Brown (1990), and Pegg et al. (1996) also noted the decline of sauger in other Tennessee River reservoirs and searched for causes. Water velocities and water temperatures during the April spawning period are generally cited as important factors in sauger spawning success and ultimately year-class strength (Yeager, 1990; Yeager and Shaio, 1992; Hickman and Buchanan, 1996). Brooks (1993) also reported that optimal water temperatures (7-10°C) during spawning and incubation coupled with high water levels promoted fry and fingerling survival in the Illinois River.

The potential for the proposed WBN SCCW project to impact sauger spawning success is limited to disruption of the normal migration of adults to the spawning area. Watts Bar Dam blocks sauger during the annual spawning migration resulting in a congregation of sauger in the Watts Bar tailwater area during winter months. Typically, as individuals approach spawning readiness (late March-early April), they move downstream to the most suitable spawning site available. Sauger in Chickamauga Reservoir spawn approximately eight miles downstream of Watts Bar Dam. The major concern for sauger with WBN SCCW operational changes is if spawners were delayed or diverted from moving to the spawning area. Hevel and Hickman (1991) and Kay and Buchanan (1995) reported no concentration or diversion of sauger to the warm water near the SQN diffusers during the fall-winter period when sauger migrate past that plant. The increased water temperature at the WBN SCCW discharge is also not anticipated to alter adult sauger migration patterns.

Another potential concern is the concentration of adults during WBN operation in the immediate vicinity of the WBF discharge during the winter period when they are staging at Watts Bar Dam. This could result in an increase in fishermen catch of migrating sauger which might lead to overharvest of spawners. This is considered unlikely as this condition has not occurred in similar situations at SQN or WBN on Chickamauga Reservoir (Kay and Buchanan 1995 and Baxter et. al. 1997) or at Bull Run Steam Plant on Melton Hill Reservoir (Schneider et. al. 1977). Sauger do not concentrate in the Watts Bar tailwater area during summer months when discharge temperatures are high enough to adversely impact growth. Therefore, the WBN SCCW project is not anticipated to have negative impacts on sauger growth.

### White Bass

As with sauger, white bass apparently declined in abundance and fishermen catches during the mid-1980s. By 1992, the white bass population had improved (Buchanan 1994) as year-class strength, numbers harvested, and harvest rate in Chickamauga Reservoir had increased to levels higher than those reported for 1986. Competition with an expanding population of yellow bass was suggested as the major factor limiting the white bass population in Chickamauga Reservoir. White bass, like sauger, concentrate during the late winter and spring below Watts Bar Dam and would be exposed to potential impacts of the WBN SCCW project. White bass have three primary spawning sites in Chickamauga Reservoir. The closest of these to the WBN area is eight miles downstream at Hunter Shoals. As with sauger, no alteration of white bass spawning migration patterns is anticipated as a result of the WBN SCCW project. Some concentration of white bass staging below Watts Bar Dam may occur in the immediate vicinity of the WBF discharge during WBN operational periods. If this occurs, fishermen catch could increase, slightly enhancing the potential for overharvest of spawners. However, as with sauger, there is no indication of this happening under similar circumstances (Kay and Buchanan 1995 and Buchanan 1994).

The maximum growth potential for white bass occurs from 27-28.5°C (Magnuson et al. 1990). During the time frame when white bass inhabit the tailwater area, the maximum water temperature in the vicinity of the WBF discharge will be 28°C. Therefore, no adverse impacts on white bass growth are anticipated.

### Threadfin Shad

Numbers of juvenile threadfin shad in Chickamauga Reservoir cove rotenone samples have fluctuated considerably between 1970 and 1995 (Jenkins, 1996). Peak mean density of 22,913 young-of-the-year (YOY) threadfin per hectare was found in 1985, with the lowest mean density, 53 fish per hectare, occurring in 1978. Threadfin shad are very sensitive to cold water temperatures (severe stress below 10°C and near total mortality below 4°C) and severity of low winter water temperatures often is the determining factor in survival and reproductive success the following year (Griffith, 1978; Lewis and Heidinger, 1979). During very cold years, adult densities often are reduced to a point where significant recruitment does not occur the following year. Low density estimates of YOY threadfin in Chickamauga Reservoir were preceded by especially cold winters (Jenkins, 1996).

Lewis and Heidinger (1979) reported that threadfin shad were attracted to the heated effluent of a power plant during winter. A potential exists for the creation of a winter thermal refuge for threadfin shad in the vicinity of the WBF discharge. This artificial refuge could increase the number of spawners the following spring enhancing the potential for a large threadfin shad year class. However, if long non-operational periods occur during winter at WBN, water temperatures would decline, potentially resulting in large mortality of attracted threadfin shad. It must be kept in mind that these fish would have died due to ambient conditions unless they were in the vicinity of a natural refuge such as a spring outlet. Threadfin shad are tolerant of water temperatures in excess of 32°C, limiting the impact of maximum water temperatures. However, rapid increases in water temperature (>10°C) in the immediate vicinity of the discharge could cause limited threadfin shad mortality.

### Catfish

Catfish support a majority of the angling effort during summer months in the inflow area of Chickamauga Reservoir. During an extended drought in the mid-1980s, catfish in Chickamauga Reservoir were reported to decline in abundance. Peck and Buchanan (1995) initiated an investigation in 1988 to determine the quality of the catfish population in the reservoir. They found the number of catfish harvested by sport fishermen in Chickamauga Reservoir remained relatively stable from 1988 through 1993, and gill netting catch rates from inflow, transition, and forebay zones of the reservoir during 1989 through 1993 suggested a generally increasing population. The inflow area in the vicinity of WBN and WBF consistently had higher gill netting catch rates than other areas of the reservoir. Length distributions of catfish (blue, channel, and flathead) collected by Tennessee Tech University (TTU) personnel during August 1997 (Chris O'Bara, personal communication) indicate healthy populations of each species with numerous year classes represented in each population.

Catfish spawn in cavities formed by crevices in rock, cave-like depressions in the bank, hollow logs, or debris such as discarded automobile tires. Adequate spawning habitat does not exist in the immediate vicinity of the WBF discharge, and therefore the WBN SCCW changes are not anticipated to influence catfish spawning success. Catfish are very tolerant to high temperatures with upper thermal tolerance limits from 32 to 37.8°C (Eaton et al. 1995, Allen and Strawn 1968) and preferred or maximum growth temperatures of 30 to 33.5°C (Andrews and Stickney 1972, Eaton et al. 1995). The "worst case" maximum water temperature at the end of the WBF mixing zone is projected to be 30°C, and the maximum discharge temperature in the immediate vicinity of the WBF outlet pipe is projected at 34.7°C. No adverse impacts on catfish survival or growth are anticipated.

## Striped Bass

Striped bass were initially stocked into Chickamauga Reservoir by TWRA in 1974 (Anders Myhr, personal communication). This, and subsequent striped bass introductions, resulted in the establishment of a "trophy" fishery in the Watts Bar tailwater in the vicinity of the WBF and WBN plants. Stripers accounted for 2,955 fishing trips and 16,637 estimated hours (6% of total fishing effort) in the tailwater in 1996-1997 (Baxter et al. 1997).

Striped bass are an introduced species and spawning requirements are seldom met in Tennessee River impoundments and populations are generally maintained by supplemental stocking. Striped bass eggs are semi-buoyant and current velocities must be sufficient to keep the fertilized eggs in the water column until hatching. These conditions are met below Watts Bar Dam only during extremely wet springs when water has to be released through the spillway gates during the striped bass spawn (generally in April). Therefore, WBN SCCW system operation will not impact striped bass spawning.

Striped bass growth potential is best from 20 to 24°C (Coutant 1975). It is anticipated that striped bass will congregate in the warmer discharge water during winter months, and avoid the discharge during summer when the water temperatures are above the preferred temperature range. Currently, striped bass do not congregate in the vicinity of the WBF discharge (Anders Myhr, personal communication). Therefore, it is not anticipated that striped bass will be exposed to rapid temperature increases occurring during plant start-up. However, if some striped bass are in the immediate area of the discharge during initiation of WBN generation using the SCCW system, some limited mortality could occur. As with sauger and white bass, if striped bass congregate in the winter in the immediate vicinity of the WBF discharge during WBN operation, increases in fishermen harvest are probable.

TVA would conduct a fisheries monitoring program in the vicinity of WBN SCCW facilities during the first year of SCCW operation to verify selected impact projections outlined in this EA regarding sauger and striped bass. Additional aspects to be addressed in the monitoring program include minimal demonstration of impacts resulting from impingement and entrainment, along with fish community monitoring aspects.

## Bottom Life

Bottom-dwelling species, including freshwater mussels, in the immediate vicinity of the WBF discharge could be adversely affected by the elevated temperature of the water being released here from WBN. As indicated in Section 2.1, the temperature of the discharge water (prior to mixing) would be as high as 96°F, approximately 10 degrees warmer than the warmest observed temperature in this part of the river. Information presented in Enclosure 1 (especially Figure 4), however, indicates this heated water would rise to the surface very quickly. Animals present in the relatively small amount of bottom habitat that would be exposed to water temperatures above ambient levels (an area just offshore from the point of discharge measuring approximately 150 x 150 ft., approximately 22,500 sq. ft. (2,100 m<sup>2</sup>)) would either not be able to survive there or would experience different growing conditions than elsewhere in the Watts Bar tailwater. Many insects and other resident species that would be adversely affected by warmer water temperatures could swim or drift out of the impact area. Resident freshwater mussels, however, would not be able to avoid the heated water on their own and could be adversely affected. If this alternative is adopted, TVA would minimize the potential impacts on native mussel species by relocating as many resident mussels as possible out of the 2,100 m<sup>2</sup> (22,500 sq. ft.) area where the thermal impacts would affect the river bottom. Divers would collect these animals and place them in suitable mussel habitat elsewhere in the Watts Bar mollusk sanctuary. The operational temperature monitoring described in section 3.2.3 would demonstrate that the selected area for relocation as predicted by the CORMIX model was adequate to ensure the minimization of impact to bottom life or suggest that additional actions might be necessary to protect mussel resources near the discharge. All of these activities would be conducted in coordination with the Tennessee Wildlife Resources Agency.

### **3.3.4 Chemical Impacts**

NPDES permits control the discharge of chemicals from WBN and WBF (See Section 1.4). In support of past chemical treatments of condenser cooling water, TVA conducted toxicity assessments of the molluscicide, Clamtrol, alone and in combination with other chemical additives at WBN. TVA concluded that significant effects on aquatic

life would not occur due to the amounts of chemicals used, the frequency of use, and the rapid dilution in the Tennessee River (TVA 1995a; U.S. NRC 1995). Monthly whole effluent toxicity (WET) tests were conducted on WBN discharges over a year-long period when chemicals were being used by the plant. Test results did not identify toxicity in undiluted Outfall 101 effluent (diffuser discharge) based on the responses of daphnids (*Ceriodaphnia dubia*) and fathead minnows (*Pimephales promelas*). Both species are standard NPDES toxicity biomonitoring organisms. Additional targeted studies indicated that daphnids are much more sensitive to active ingredients of Clamtrol than a fish or two species of juvenile freshwater mussels (TVA and NRC 1994). Based on 96-hour survival data, daphnids were nine times more sensitive than fathead minnows. When silt was present in the mussel tests (a natural condition in the river), daphnids were fifteen times more sensitive to the molluscicide than the most sensitive mussel tested. TVA also concluded that NPDES WET testing would identify any potentials for aquatic life impairments, should they occur.

On August 20, 1996, TVA requested concurrence from the Tennessee Department of Environment and Conservation (TDEC), Division of Water Pollution Control, to make minor modifications to the biocide and corrosion control chemical treatment programs at WBN. This request included the substitution of the non-oxidizing biocide (molluscicide) H-130M (didecyldimethylammonium chloride or DDMAC) for a similar biocide, Clamtrol (dodecylguanidine hydrochloride and n-alkyl dimethyl benzyl ammonium chloride or DGH and quat) which has been used at WBN. On September 6, 1996, TDEC approved the requested modification at a discharge concentration <0.05 mg/L DDMAC, as long as the discharge was to the Tennessee River.

The substitution of the molluscicide H-130M for Clamtrol should not pose a problem, based on extensive testing of H-130M alone and with other chemical additives used at TVA's Sequoyah Nuclear Plant (TVA 1995b and 1995c). Greatest toxicity of H-130M was measured in a 9-day juvenile mussel aqueous exposure test without silt. However, toxicity demonstrated in the "silt-free" test ( $LC_{50} = 47.1 \mu\text{g/L}$ ) was completely eliminated (zero mortality at  $300 \mu\text{g/L}$ ) by the addition of silt into the test chambers (detoxification factor >6.4). Next greatest toxicity of H-130M was measured in a 7-day larval fish test ( $IC_{25} = 104.2 \mu\text{g/L}$ ). This concentration is approximately two times the projected (permitted)  $50 \mu\text{g/L}$  discharge concentration before mixing. The molluscicide was not toxic to daphnids (*Ceriodaphnia dubia*) in aqueous tests or to sediment dwelling organisms (scuds, midges, juvenile mussels) in whole-sediment tests at the permitted discharge concentration of  $50 \mu\text{g/L}$ . In approving the chemical treatment modifications at WBN, the State of Tennessee concluded that discharges of the molluscicide into the Tennessee River at  $<50 \mu\text{g/L}$  should pose no problem for instream water quality (TDEC 1996).

Based on these results, TVA concludes that the chemical treatment program for supplemental cooling water at WBN would not constitute an adverse environmental impact. The NPDES permit for WBN requires periodic WET testing using daphnids and fathead minnows as test organisms. Future testing and compliance of the WBN and WBF condenser cooling water discharges with NPDES WET and chemical limits would ensure protection of aquatic life in the Tennessee River from chemical additions.

### 3.4 Terrestrial Ecology

#### 3.4.1 Existing Conditions

Watts Bar Nuclear Plant and the Watts Bar Fossil Plant are located immediately downstream of the Watts Bar Dam on the Tennessee River at Tennessee River Mile (TRM) 530. The proposed project would be located between the Watts Bar Fossil Plant at TRM 529 and the cooling towers of the Watts Bar Nuclear Plant. Land uses in the local area around the plant sites include agriculture, forestry, and residential uses. The TVA Watts Bar Dam reservation is primarily lawn and upland forest of mixed oaks, hickories, tulip tree and pines.

Much of the property within the Watts Bar Nuclear and Watts Bar Fossil plant sites has been used for power generation sites or for other uses associated with the construction of these generating facilities. Prominent recent land uses have included building sites, parking areas (paved and graveled), lawn maintenance, construction lay-down areas, spoil areas, and storage areas. Several buildings and parking areas have been removed and allowed to revert to fallow conditions.

Because of extensive site disturbance, much of the area along the proposed route is currently open or covered with shrubby vegetation. Approximately 45 percent of the proposed route crosses lawn areas. About 30 percent is in moist, deciduous forests, chiefly hackberry, red maple, green ash, black willow and other early successional species. Another 10 percent is shrub/scrub areas of lespedeza, sumac, blackberry, privet, ironweed, Virginia pine and various grasses. Approximately 5 percent has wetland vegetation of cattails, cardinal flower, marsh mallow and soft rush. The remainder of the route consists of roads, roadsides, cleared areas and other idle land.

The proposed project site has been disturbed extensively by previous construction activities and operations of the Watts Bar Nuclear and Watts Bar Fossil Plants. At its northern end, the proposed pipeline route would cross a fenced area (primarily lawn) adjacent to the Watts Bar Fossil Plant. As it proceeds south, the route runs along the edge or crosses portions of the existing slag disposal area for the Watts Bar Fossil Plant. After leaving the slag disposal area, the route crosses an open area adjacent to roadways. The route then crosses a narrow wooded area along a natural drainage northeast of the cooling towers. The route in the vicinity of the cooling towers would be over open land that is currently covered with sparse grassy vegetation.

Along with natural drainage, the slag disposal areas receive water from the Fossil plant and from slag washing operations. The slag disposal area in general exhibits some wetland functions. A small wetland area supporting hydrophytic vegetation is present in the natural drainage immediately northeast of the cooling towers. Additional discussion of wetlands is provided in section 3.7. Vegetation in the slag disposal area consists of some typical wetland species such as cattail and wool grass along with more upland species such as Virginia pine and sumac.

Common terrestrial mammal species in the project vicinity include white-tailed deer, raccoons, opossums, gray squirrels, and groundhogs, and a variety of shrews and mice commonly found in early successional habitats. Local birds include American robin, European starling, mockingbird, Canada goose, morning dove, killdeer, and a variety of songbirds and neotropical migrants. Amphibians and reptiles include those species often found in wetland habitats, such as spring peepers, northern cricket frogs, gray treefrogs, and midland water snake.

The Yellow Creek Wildlife Management Area (WMA) is located approximately 1 mile west of Watts Bar Nuclear Plant. It is designated primarily for the benefit of migrant and wintering waterfowl. An area designated by the Tennessee Wildlife Resources Agency as the Yellow Creek Key Endangered Species Habitat (KESH) is adjacent to the WMA and is managed for osprey. Chickamauga Shoreline TVA Habitat Protection Area is located on the east bank beginning at TRM 528. It provides habitat for bald eagles and osprey, and provides riparian buffer for the adjacent State Mussel Sanctuary. Chickamauga Reservoir State Mussel Sanctuary is located in the section of the Tennessee River between TRM 520 and TRM 529.9. TVA Natural Heritage records indicate a heronry (a roosting or breeding area for herons) located approximately one mile northeast of the Watts Bar Fossil Plant. In 1990 approximately 20 pairs of great blue herons nested at this site. However, the number of nests at the site had fallen to 4 in 1993. Another heronry was located approximately one half mile southwest of the Nuclear Plant, near the Yellow Creek KESH. However, this heronry has been inactive since 1988.

### **3.4.2 Construction Impacts**

During construction, a corridor 50 feet wide (approximate average) and 4,000 feet long (approximately 4.5 acres) would be disturbed. This disturbance would be from clearing, earth moving (excavation and fill) and from movement of associated construction equipment. Plans call for minimum maintenance of a 30-foot wide right-of-way along the pipeline route primarily to prevent growth of trees. Right-of-way maintenance would be similar to that performed on transmission line rights-of-way. That is, periodic mowing or spraying of herbicides would be used to prevent growth of trees or other woody vegetation along the pipeline.

During construction, existing vegetation along the pipeline right-of-way would be altered (removed, then allowed to return as grass or low brush). Total area affected by the right-of-way would be about 4.5 acres. The net effect on vegetation would be that vegetation within the pipeline right-of-way would be altered from its current condition (brush, shrubs and some trees) to an early successional (fallow-like) condition maintained by periodic mowing or herbicide treatments.

Mobile resident wildlife species would be temporarily displaced directly by the onsite disturbance and indirectly by noise and the presence of workers and equipment during construction. Some non-mobile species or species of low mobility could be lost within the work zone. Construction of the proposed pipeline would result in the conversion of some forested habitats to early successional habitats. Any adverse direct impacts to terrestrial wildlife would occur on a localized basis. Because no rare, threatened, or endangered species occur on site, indirect and cumulative impacts to terrestrial wildlife are expected to be minor and regionally insignificant.

### 3.4.3 Operational Impacts

Noise and other operational nuisances to wildlife species are expected to be minimal. Operational noise is not expected to contribute to current ambient noise levels. Noise should have no impact on nearby heronries due to the distance of the heronries from the site.

The proposed pipeline would be embedded in the soil roughly to the centerline with the remaining covered by a mounded overburden approximately 12 inches deep on top of pipe. One road crossing of the above-ground section of the pipeline would be required (see Figure 1.2). This road crossing would be at a point where the pipeline is routed below grade. Drainage culverts would be placed under the pipeline in areas where drain water could accumulate.

The ground level segment of the proposed pipeline could create a minor barrier similar to a fence to some non-avian fauna. Some more mobile species such as deer, raccoons, groundhogs and opossums would be able to cross the pipeline at road crossings, along the buried portions, or simply climb over the mounded overburden placed on the ground level pipe. Smaller mammals, reptiles and amphibians would be able to cross under the pipeline via the drainage culverts.

Direct or indirect effects to the nearby Yellow Creek WMA and KESH, the TVA habitat protection area, or heronries are expected to be negligible.

## 3.5 Endangered and Threatened Species

### 3.5.1 Existing Conditions

As part of recent environmental review activities for the Watts Bar Nuclear Plant, TVA and the Nuclear Regulatory Commission (NRC) compiled information on the endangered and threatened species which are known to exist in the general vicinity of Watts Bar Dam (TVA and NRC 1995). Seven federally listed species were identified; two species are terrestrial (bald eagle, *Haliaeetus leucocephalus*; and gray bat, *Myotis grisescens*) and the other five are aquatic (snail darter, *Percina tanasi*; fanshell, *Cyprogenia stegaria*; dromedary pearly mussel, *Dromus dromas*; pink mucket, *Lampsilis abrupta*; and rough pigtoe, *Pleurobema plenum*). The bald eagle and snail darter are now listed as federal threatened species but the gray bat and all four mussel species are listed as endangered. Two state listed wildlife species were also identified. The osprey (*Pandion haliaetus*) and grasshopper sparrow (*Ammodramus savannarum*) are listed as threatened and in need of management in Tennessee, respectively. No state or Federal protected plant species are known from the Watts Bar Reservation. Available information indicates that regional populations of the bald eagle and snail darter are increasing, while the regional population of the gray bat appears to be relatively stable. In the Tennessee River downstream from Watts Bar Dam, all four mussel species are represented only by relatively few, old individuals. As indicated in Section 3.3 (Aquatic Life), these and most other native mussel species apparently have not reproduced successfully in this part of the river for many years (TVA and NRC 1995).

Bald eagles and gray bats have been observed in the general vicinity of Watts Bar and Chickamauga Reservoirs but are not closely associated with the Watts Bar Dam tailwater. In recent years, the wintering bald eagle population in the Watts Bar-Chickamauga Reservoir area has increased to about 30 birds and a pair of these eagles built, then

abandoned a nest in this area in 1994 (Tennessee Wildlife Resources Agency unpublished data). Gray bats probably forage for flying insects over upper Chickamauga Reservoir and are known to roost in caves between 6 and 30 km (4 to 20 miles) from Watts Bar Dam (USFWS 1982). Snail darters are known to occur in Sewee Creek (which enters the river approximately eight km [five miles] downstream from Watts Bar Dam) and in the river near that creek mouth. Other snail darter populations occur in direct tributaries of the Tennessee River between Huntsville, Alabama, and Knoxville, Tennessee (USFWS 1984).

Results of recent mussel surveys near this project site (Section 3.3 and Tables 3.3.4 and 3.3.5) indicate that three of the four endangered mussel species (all but the dromedary pearly mussel) have been found in the two-mile reach just downstream from Watts Bar Dam. A single specimen of the fanshell was found at TRM 528.8 in the mussel bed along the left (descending) shoreline during 1983. Similarly, one specimen of the rough pigtoe was found at TRM 528.9 in the same left-shore mussel bed during the 1985 survey. No additional specimens of either species have been found in this reach during subsequent years and only two other specimens of each species have been found at other sites in the Watts Bar tailwater (all four at TRM 520.6). Reproducing populations of the fanshell persist in the Green and Licking Rivers in Kentucky, and in the Clinch River, Tennessee and Virginia (USFWS 1991). The rough pigtoe persists in the Green and Barren Rivers in Kentucky, the Cumberland River in central Tennessee, and in the Clinch River, Tennessee and Virginia (USFWS 1984). The rough pigtoe was placed on the list of federal endangered species in 1976 (USFWS 1984) but the fanshell was not added to that list until 1990 (USFWS 1991).

A few specimens of the pink mucket, *Lampsilis abrupta*, have been found during each extensive mussel survey conducted in the Watts Bar tailwater. In the two-mile reach just downstream from the dam, a single pink mucket was found just offshore from the WBF discharge during the 1997 survey (Tables 3.3.4), two were found along the right (descending) shore not far upstream from the WBF discharge in 1990 (Table 3.3.5), and several have been found during recent years in the mussel bed along the left (descending) shore (Table 3.3.5). In terms of relative abundance, the pink mucket consistently accounts for 0.3 to 0.7 percent of well-sampled mussel communities in this tailwater (TVA and NRC 1995). Besides the Watts Bar tailwater, the pink mucket is known to exist at scattered locations from the Kanawha River in West Virginia, west to the Osage and Meramec Rivers in Missouri, south to the Black River in Arkansas, and east to the Tennessee and Cumberland Rivers in Tennessee. The most upstream site in the Tennessee River watershed where this species has been found is the Clinch River in northeast Tennessee (USFWS 1985).

So far as is known, each of these endangered mussel species has similar feeding and reproductive requirements. Adult members of these species live imbedded in cobble or gravel river bottoms where water currents prevent excessive silt accumulations. Native mussels feed by filtering small food particles (detritus, algae, etc.) out of the water. Reproduction involves a stage when the larvae (glochidia) must become temporary parasites on certain fish species in order to complete their development. The required "fish hosts" are unknown for most of these species; however, the pink mucket is reported to parasitize sauger (*Stizostedion canadense*) and freshwater drum (*Aplodinotus grunniens*) (USFWS 1985). Members of these mussel species may live for 40 years or more.

Watts Bar reservoir has one of the largest breeding populations of osprey in the southeast. Yellow Creek, located one mile west of the project area, is designated as "Key Endangered Species Habitat" (KESH) by the Tennessee Wildlife Resources Agency and is managed for breeding populations of osprey. Osprey are likely to forage along the shoreline of Watts Bar adjacent to the project area.

TVA Regional Natural Heritage files indicate no records of grasshopper sparrows at the Watts Bar Nuclear site. However, early successional habitat favored by this species exists in the general vicinity. Therefore, it is likely that this species can be found near the project site.

### 3.5.2 Construction Effects

No endangered or threatened species would be affected by construction associated with this project. Bald eagles, gray bats and osprey would continue to occasionally forage over the site and would not be affected by this work. None of the construction activity would occur in the water or along the shoreline. Use of appropriate erosion control BMP during the construction activity would prevent sedimentation effects on endangered mussels in the river.

Because construction of the pipeline is restricted to the Nuclear and Fossil Plant sites, little impact to state listed terrestrial species of wildlife is expected.

### **3.5.3 Operational Effects**

The bald eagle, gray bat, and snail darter would not be adversely affected by the operation of this water system. Eagles and gray bats would continue to occasionally forage over the site and would not be affected by the discharge. Snail darters in the river near the mouth of Sewee Creek would be unaffected by the minor increase in water temperature. State listed species of wildlife are not likely to be affected by operation of the pipeline.

Specimens of the pink mucket and, potentially, other endangered mussel species present in the immediate vicinity of the WBF discharge could be adversely affected by the elevated temperature of the discharge water. As indicated in Section 2.1, the temperature of the discharge (prior to mixing) would be approximately 96°F, approximately 10 degrees warmer than the warmest observed temperature in this part of the river. Information presented in Enclosure 1 (especially Figure 4), however, indicates this heated water would rise to the surface very quickly. Endangered mussels present in the relatively small amount of bottom habitat that would be exposed to water temperatures above ambient levels (an area just offshore from the discharge measuring approximately 150 x 150 ft., approximately 22,500 sq. ft. (2,100 m<sup>2</sup>)) would either not be able to survive there or would experience different growing conditions than elsewhere in the Watts Bar tailwater. If this alternative is adopted, TVA would minimize the potential for impacts to endangered mussel species by relocating as many resident mussels as possible out of the 2,100 m<sup>2</sup> area where the thermal impacts would affect the river bottom. Divers would collect these animals and place them in suitable mussel habitat elsewhere in the Watts Bar mollusk sanctuary. This activity would be conducted in compliance with Section 7 of the Endangered Species Act through coordination with the U. S. Fish and Wildlife Service, and the Tennessee Wildlife Resources Agency. As indicated in a letter dated May 26, 1998, the U.S. Fish and Wildlife Service has concurred that completion of the mussel relocation effort prior to the use of this discharge point would result in no adverse effect on endangered or threatened species. The short-term operational monitoring of temperatures in the mixing zone (described in section 3.2.3) would verify the adequacy of the CORMIX model results used to predict and select the relocation area or suggest that additional measures might be necessary to ensure protection of endangered mussels near the discharge. Completion of the mussel relocation effort prior to the use of this discharge point would result in no adverse effect on endangered or threatened species.

### **3.6 Solid and Hazardous Wastes**

No hazardous wastes will be generated by the construction processes planned for this project.

Little if any solid waste will be generated which should be in the form of inert materials such as construction rubble. Any solid wastes generated would be disposed of in accordance with TVA procedures, consistent with State of Tennessee rules governing solid waste disposal.

Soils would be returned to their original locations or reused along the pipeline following disturbance during excavation, pipe installation, and backfill (around or over the pipe) and are therefore not a solid waste.

### **3.7 Wetlands and Floodplains**

#### **3.7.1 Field Inspection and Notes**

A review of National Wetland Inventory (NWI) maps show no wetlands exist in the proposed project site. A field survey performed on September 3, 1997 indicated an emergent wetland (Site 1) approximately 2 hectares in size has developed within the abandoned ash disposal site south of the old steam plant. A summary of the field notes is provided as Table 3.7.1. The hydrology of this wetland is influenced primarily by process wastewater emerging from the fossil plant. To a lesser degree, it receives drainage from a wooded area northwest of the steam plant and

settling ponds south of the plant. Vegetation in this wetland area consists of sycamore, black willow, sweetgum, American hornbeam, box-elder, yellow poplar, green ash, willow oak, marsh-mallow, swamp smartweed, wool-grass, cattail, flatsedge, soft rush, and unidentified species of sedges. The soil survey for Rhea County (1948) maps Atkins soil series, a hydric soil, in this drainage. Because this area is part of a waste treatment system, it is not considered a water of the United States and is not a wetland falling under the jurisdiction of the Clean Water Act (i.e., it is not a jurisdictional wetland).

The proposed supply line would cross through or along the edge of a ravine (15 to 20 feet deep) adjacent to the cooling towers (Site 2). This ravine is one of the least disturbed areas along the route. The soil survey indicates the presence of hydric soils north of this crossing, but construction has effectively drained this area. Although hydric soils were observed within the ravine and sufficient hydrology does exist, the plant community is dominated by upland species, and this area is not considered a jurisdictional wetland. A site description based on field inspection is provided as Table 3.7.2.

### **3.7.2 Construction Impacts**

The proposed pipeline route would follow the edge of the slag disposal area containing Site 1. During construction, a corridor approximately 50 feet wide (average) would be disturbed in a portion of the wetland area, and existing vegetation would be removed within the right of way. Drainage patterns could be altered somewhat. However, measures that allow continued free surface water drainage under the proposed pipeline would minimize the impact to non-jurisdictional wetlands. Thus, overall hydrology of the wetland area would not be affected significantly.

The proposed supply line would cross through or along the edge of a ravine (15 to 20 feet deep) adjacent to the cooling towers (Site 2). If the undisturbed portion of the ravine is crossed, the pipeline would be located above grade and would be supported by pilings or other support structure which would minimize the impact. Here, surface water flow patterns would not be affected. However, vegetation (primarily woody) would be removed along the right of way. These effects would be localized and insignificant.

### **3.7.3 Operational Impacts**

According to preliminary design, 60 to 80% of the proposed pipeline would generally be embedded in the soil approximately to the centerline, with the remaining cross section of the pipeline extending above grade and covered with soil. Drainage culverts or other measures would be placed in areas where water accumulates to prevent ponding behind the pipeline and to prevent alteration of surface water flow patterns. It is likely that some of the impacted wetland areas would revert to wetland, as hydrology influences the development of wetland plant species. Because of periodic right-of-way maintenance, these areas would likely revert to herbaceous and/or shrub/scrub wetland areas.

Table 3.7.1 - Site Field Notes, Wetland Site 1

**SOILS:**

<u>Depth</u>	<u>Matrix</u>	<u>Mottles</u>	<u>Texture</u>
0 - 3"	10YR4/3		Silt Loam
3 - 7"	10YR5/2		Sandy Loam
7 - 10	10YR5/1	7.5YR4/4	Sandy Loam

**VEGETATION:**

<u>Common</u>	<u>Latin</u>	<u>Stratum</u>	<u>Indicator*</u>
Sycamore	<i>Platanus occidentalis</i>	Tree	FACW-
Black Willow	<i>Salix nigra</i>	Tree/Shrub	OBL
Sweetgum	<i>Liquidambar styraciflua</i>	Tree/Shrub	FAC+
Am. Hornbeam	<i>Carpinus caroliniana</i>	Tree	FAC
Box-Elder	<i>Acer negundo</i>	Tree	FACW
Yellow Poplar	<i>Liriodendron tulipifera</i>	Tree	FAC
Green Ash	<i>Fraxinus pennsylvanica</i>	Tree	FACW
Willow Oak	<i>Quercus phellos</i>	Tree	FACW-
Marsh-Mallow	<i>Althaea officinalis</i>	Shrub	NI
Swamp Smartweed	<i>Polygonum hydropiperoides</i>	Herb	OBL
Wool-Grass	<i>Scirpus cyperinus</i>	Herb	OBL
Cattail	<i>Typha latifolia</i>	Herb	OBL
Flatsedge	<i>Cyperus spp.</i>	Herb	FACW & OBL
Soft Rush	<i>Juncus effusus</i>	Herb	FACW+
Sedge	<i>Carex spp</i>	Herb	FACW or OBL

**ADDITIONAL REMARKS:**

Water stained leaves  
 Oxidized root coatings  
 Depth of standing water in places >12 inches  
 Atkins soil series is mapped and is hydric.

Table 3.7.2. Site Field Notes Wetland Site 2

**SOILS:**

<u>Depth</u>	<u>Matrix</u>	<u>Mottles</u>	<u>Texture</u>
0 - 10"			Cobbly river sediments
<b>Some areas:</b>			
0 - 4"	10YR4/1		Sandy loam
4 - 10"	10YR5/1		Sandy Loam

**VEGETATION:**

<u>Common</u>	<u>Latin</u>	<u>Stratum</u>	<u>Indicator*</u>
Red Maple	<i>Acer rubrum</i>	Tree	FAC
Black Willow	<i>Salix nigra</i>	Tree/Shrub	OBL
Sweetgum	<i>Liquidambar styraciflua</i>	Tree/Shrub	FAC+
Am. Hornbeam	<i>Carpinus caroliniana</i>	Tree	FAC
Yellow Poplar	<i>Liriodendron tulipifera</i>	Tree	FAC
Alder, Common	<i>Alnus serrulata</i>	Tree	NI
American Beech	<i>Fagus grandifolia</i>	Tree	FACU
Hackberry	<i>Celtis occidentalis</i>	Tree	FACU
Dogwood	<i>Cornus florida</i>	Tree	FACU
Amer. Holly	<i>Ilex opaca</i>	Shrub	FAC-
Privet	<i>Ligustrum sinense</i>	Shrub	FAC
Nettle	<i>Urtica spp.</i>	Herb	FAC

**ADDITIONAL REMARKS:**

Oxidized root coatings  
 Depth of standing water in places >10 inches

**\*PLANT INDICATOR STATUS CATEGORIES FOR TABLE 3.7.1 AND 3.7.2 FIELD NOTES**

<b>Indicator Category</b>	<b>Indicator Symbol*</b>	<b>Definition</b>
Obligate wetland plants	OBL	Plants that occur almost always (estimated probability >99%) in wetlands
Facultative wetland plants	FACW	Plants that occur usually (estimated probability >67-99%) in wetlands, but also occur (estimated probability 1%-33%) in non-wetlands
Facultative plants	FAC	Plants with a similar likelihood (estimated probability 33% - 67%) of occurring in both wetlands and non-wetlands
Facultative upland plants	FACU	Plants that occur in sometimes (estimated probability 1% - <33%) in wetlands, but occur more often (estimated probability >67% - 99%) in non-wetlands
Obligate upland plants	UPL	Plants that occur rarely (estimated probability <1%) in wetlands
Not Indicated	NI	

\*Categories were originally developed and defined by the U.S. Fish and Wildlife Service National Wetlands Inventory and subsequently modified by the National Plant List Panel. The three facultative categories are subdivided by (+) and (-) modifiers. Soil nomenclature follows U.S. Department of Agriculture - Soil Conservation Service 1975 and Munsell Color 1975.

### **3.8 Cultural and Archaeological Resources**

#### **3.8.1 Existing Conditions**

The Watts Bar Fossil Plant is eligible for listing in the National Register of Historic Places (NR); it was the first fossil plant built by TVA. Construction started in 1940, and generation began in 1942. The nearby Watts Bar Dam, Hydroelectric Plant and Lock date from the early 1940s and are also eligible for the NR.

Archaeological sites 40RH1 and 40RH5-7 are within the Watts Bar Fossil and Nuclear Plant Reservations. Archaeological resources present within the reservations were first identified by Clarence B. Moore in 1915 when he reported the locations of the Viniard Landing Group of aboriginal mounds (three clusters of mounds: cluster 1, mounds- A, B and C; cluster 2, mounds -D, E and F; and cluster 3, mounds-G and H) and the Luty Place Mound. The 1936 archaeological reconnaissance of Chickamauga Reservoir included part of the reservations. This survey identified RH1 and RH5 (possibly Moore's Keyforver Place, and Kimbrough Place) and located seven of Moore's eight Viniard Landing Mounds (designating them RH7 units 9 through 15). The Luty Place Mound was also relocated and designated RH6. To mitigate adverse construction impacts of the Watts Bar Nuclear Plant, in 1971 the University of Tennessee-Knoxville conducted investigations at the mound complex associated with 40RH6 and at 40RH7. In 1972 the University of Tennessee-Chattanooga conducted archaeological investigations at the habitation site portion of 40RH6.

#### **3.8.2 Construction Impacts**

The Watts Bar Fossil Plant would be visually impacted by the pipeline but the impact would not be adverse. The nearby Watts Bar Dam would not be impacted by the proposed project.

Given prior terrain alterations along the proposed pipeline route, there would not be any construction impacts to any archaeological site.

TVA has completed consultation with the Tennessee State Historic Preservation Officer, pursuant to Section 106 of the National Historic Preservation Act, 36 CFR Part 800, regarding the above findings on proposed project impacts on significant cultural resources.

#### **3.8.3 Operational Impacts**

There are no operational impacts to cultural and archaeological resources.

### **3.9 Socioeconomic Resources**

The proposed project has an estimated capital cost of approximately \$6.8 million. This estimate includes design and construction costs including all labor and materials. Approximately one-half of the estimated cost is labor with the other one-half being materials. The duration of the construction phase of the project would be about 10 months. Peak construction employment is estimated to be 50 workers.

#### **3.9.1 Existing Conditions**

For construction purposes, the area labor market serving WBN is defined to include Knox and Hamilton counties (Knoxville and Chattanooga) and the counties in the valley and along Interstate Highway 75 between the two. In 1994, total employment in this area was about 565,000, with total annual earnings of about \$14.8 billion.

#### **3.9.2 Environmental Justice**

This project's construction impacts would be confined to the TVA reservations of the Watts Bar Fossil Plant and Watts Bar Nuclear Plant. The nearest residence is over 1 mile from the proposed project. No potential for impacts to minority or low income persons were identified.

### **3.9.3 Impacts**

The area labor market can easily provide the necessary labor for the proposed project. Because of the short duration of the project and the proximity to both Chattanooga and Knoxville, most persons employed by the project can be expected to commute daily. As a result no impacts to the local housing market or community infrastructure are anticipated. Although beneficial, this project would be a very small addition to the area payroll.

Most materials for this project (primarily reinforced concrete pipe and valves) would not likely be procured locally. Materials such as lumber and crushed limestone could be procured locally and would have some small beneficial effect on the local economy.

Heated water discharged to the WBH tailwaters during project operation are not expected to significantly alter the sport fishery (see Section 3.3). Therefore, any subsistence fishing that may occur in the vicinity of the project should not be impacted.

### **3.10 Issues Not Requiring Detailed Analysis**

The following issues did not require a detailed analysis nor mitigation to determine that potential impacts were insignificant:

#### **3.10.1 Traffic**

Although some truck traffic would occur to supply materials to the project, no impacts are anticipated since an excellent road network serves the site vicinity.

#### **3.10.2 Land Use Conversion**

The entire project would be located on portions of the two power plant sites which are allocated for industrial use. No important or uncommon terrestrial habitat would be disturbed or converted.

#### **3.10.3 Noise**

The construction phase of the project would temporarily create typical noise levels from heavy construction equipment. No residential or other sensitive human receptor is located within 1 mile of the project. No Federally listed threatened or endangered species inhabit the proposed site. Due to noise, some temporary relocation of common wildlife in the vicinity of the project could occur during construction. No operational noise above ambient levels is anticipated. General Health and Safety Practices will determine worker hearing protection required during the construction of this project.

### 3.11 Commitments

A summary of all specific commitments made by this EA are listed below:

1. Use of construction Best Management Practices (BMPs) to limit erosion and reasonable precautions to minimize fugitive dust
2. A one-time relocation of native mussels in the immediate vicinity of the new thermal discharge prior to initial operation of the SCCW system
3. Addition of provisions at the discharge structure apron (concrete slab) to direct the warmer discharge water to the surface and minimize impact on the river bottom
4. Support experiment or test plan for enhancement of mussel habitat to improve conditions conducive to species-specific juvenile mussel recruitment
5. Discharge monitoring to include:
  - Flow
  - Temperature
  - Chemical and biological sampling
6. River monitoring to include:
  - Seasonal vertical instream river temperature monitoring at end of mixing zone during the first year of SCCW operation with comparison of the results with model projections to verify top to bottom mixing of thermal plume
  - River bottom temperature monitoring to verify high temperature impact is limited to zone predicted by TVA thermal plume modeling
  - River bottom flow direction monitoring (if feasible) to verify no adverse heated flow upstream to adjacent mussel beds
  - Conduct a fisheries monitoring program in the vicinity of WBN SCCW facilities during the first year of SCCW operation to verify selected impact projections outlined in this EA

#### 4.0 LIST OF PREPARERS

<u>Preparers</u>	<u>Title</u>	<u>TVA Office and / or Department</u>
Askew, Gregory L., P.E.	Senior Specialist	Environmental Management, Environmental Research and Services, Resource Group
Bartlow, Judith P.	Natural Areas Specialist	Land Management, Resource Group
Buchanan, Johnny	Senior Aquatic Biologist	Water Management, Resource Group
Collins, J. Leo	Botanist	Land Management, Resource Group
Harper, Walter L.	Mechanical Engineer	Water Management, Resource Group
Henry, T. Hill	Terrestrial Zoologist	Land Management, Resource Group
Hickman, Gary	Senior Fisheries Ecologist	Water Management, Resource Group
Higgins, John M.	Senior Environmental Engineer	Water Management, Resource Group
Jenkinson, Dr. John J.	Senior Malacologist	Water Management, Resource Group
McIntosh, C. Randall, P.E.	Manager of Projects	WBN, Site Vice President's Staff
Pilarski, Kim	Wetlands Specialist	Land Management, Resource Group
Printz, Lindy	Environmental Specialist	Fossil Environmental Affairs Staff
Reeves, Mark E., P.E.	Lead Mechanical Engineer	Synterprise Group
Wade, Donald C.	Senior Toxicologist	Water Management, Resource Group
Williamson, James	Environmental Scientist	Land Management, Resource Group

## **5.0 LIST OF AGENCIES AND PERSONS CONTACTED**

Tennessee Wildlife Resources Agency, Anders Myhr, District III Fisheries Biologist.

Discussed the potential for construction and thermal impacts as a result of the proposed WBN CCW project on all aspects of the tailwater sport fishery below Watts Bar Dam.

Tennessee Wildlife Resources Agency, David McKinney, contacted by Gary Hickman

US Department of Interior, Fish and Wildlife Service, various meetings and teleconferences

Tennessee Wildlife Resources Agency, meeting and various teleconferences

Tennessee Department of Environment and Conservation, Division of Water Pollution Control, various meetings and teleconferences

United States Environmental Protection Agency, various meetings and teleconferences with Regional office in Atlanta, GA

## 6.0 REFERENCES

- Allen, K. O. and K. Strawn. 1968. Heat tolerance of channel catfish (*Ictalurus punctatus*). Proc. Annual Conference Southeast Association of Game and Fish Commissioners 21:399-410.
- Andrews, J. W. and R. R. Stickney. 1972. Interactions of feeding rates and environmental temperature on growth, food conversion, and body composition of channel catfish. Transactions of the American Fisheries Society 101: 94-99.
- Baxter, D. S., J. P. Buchanan, G. D. Hickman, J. J. Jenkinson, J. D. Milligan, C. J. O'Bara. 1997. Aquatic environmental conditions in the vicinity of Watts Bar Nuclear Plant during the first year of operation, 1996. Tennessee Valley Authority, Chattanooga, Tennessee. 167 pp.
- Brown, K. A. 1990. Age and growth characteristics of a spawning population of sauger (*Stizostedion canadense*) in the Fort Loudoun tailwaters, Tennessee. Master's Thesis. Tennessee Technological University, Cookeville, TN. 90 pp.
- Buchanan, J. P. 1994. Chickamauga white bass study 1990-1992, final project report. Tennessee Valley Authority, Chattanooga, Tennessee. 21 pp.
- Coutant, C. C. 1975. Striped bass, temperature, and dissolved oxygen: A speculative hypothesis for environmental risk. Transactions of the American Fisheries Society 11:31-61.
- Dycus, D. L. 1995. Aquatic ecological health determinations for TVA reservoirs--1994: an informal summary of 1994 vital signs monitoring results and ecological health determination methods. Tennessee Valley Authority, Water Management, Chattanooga, TN.
- Eaton, J. G., J. H. McCormick, B. E. Goodno, D. G. O'Brien, H. G. Stefany, M. Hondzo, and R. M. Scheller. A field information-based system for estimating fish temperature tolerances. Fisheries 20(4): 10-18.
- Federal Register, 1995a. Nuclear Regulatory Commission, "Supplemental Environmental Statement; Availability." V60, n83, 21225-21226, May 1, 1995.
- Federal Register, 1995b. Tennessee Valley Authority, "Adoption of Final Environmental Impact Statement." V60, n131, 35577-35579, July 10, 1995.
- Federal Register, 1995c. Tennessee Valley Authority, "Operation of Watts Bar Nuclear Plant Unit 1; Issuance of Record of Decision." V60, n131, 35577-35579, August 23, 1995.
- Griffith, J. S. 1978. Effects of low temperatures on the behavior and survival of threadfin shad, *Dorosoma petenense*. Transactions of American Fisheries Society. 107(1): 63-70.
- Hackney, P. A. and J. A. Holbrook II. 1978. Sauger, walleye, and yellow perch in the United States. In R. L. Kendall, editor. Selected coolwater fishes of North America. American Fisheries Society Special Publication Number 11, Washington, D. C. p. 74-81
- Hevel, K. W. 1988. Survey of the population dynamics of sauger (*Stizostedion canadense*) in Chickamauga Reservoir, Tennessee - 1986 and 1987. Tennessee Valley Authority, Water Resources, Environmental Compliance, Chattanooga, TN. 44 pp.
- Hevel K. W. and G. D. Hickman. 1992. Fish community assessment of selected Chickamauga Reservoir embayments. Tennessee Valley Authority, Water Resources, Chattanooga, TN. 20 pp.

- Hevel, K. W. and G. D. Hickman. 1991. Population survey of sauger in Chickamauga Reservoir. Tennessee Valley Authority, Water Resources, Environmental Compliance, Chattanooga, TN. 13 pp.
- Hickman, G. D. and J. P. Buchanan. 1996. Chickamauga Reservoir sauger investigation 1993-1995 final project report. Tennessee Valley Authority, Water Management, Chattanooga, TN 17 pp.
- Hickman, G. D., K. W. Hevel, and E. M. Scott. 1989. Density, movement patterns, and spawning characteristics of sauger (*Stizostedion canadense*) in Chickamauga Reservoir, Tennessee - 1988. Tennessee Valley Authority, Water Resources, Environmental Compliance, Chattanooga, TN. 53 pp.
- Hickman, G. D., K. W. Hevel, and E. M. Scott. 1990. Population survey of sauger (*Stizostedion canadense*) in Chickamauga Reservoir, Tennessee - 1989. Tennessee Valley Authority, Water Resources, Environmental Compliance, Chattanooga, TN. 27 pp.
- Irwin, E. R. and P. W. Bettoli. 1995. Introduced clupeids in a southern reservoir: more evidence for system-specific reproductive styles. *Environmental Biology of Fishes* 42:151-159.
- Jenkins, G. D. 1996. Chickamauga Reservoir 1995 fisheries monitoring cove rotenone results. Tennessee Valley Authority, Water Management, Chattanooga, TN 52 pp.
- Kay, L. K. and J. P. Buchanan. 1995. Effects of thermal effluent from Sequoyah Nuclear Plant on fish population in Chickamauga Reservoir. Tennessee Valley Authority, Water Resources, Environmental Compliance, Chattanooga, TN. 16 pp.
- Lewis, W. M. and R. C. Heidinger. 1979. Potentials of warmwater discharge in fish management. *Farm Pond Harvest - Summer*. pp. 17-18.
- Magnuson, J. J., J. D. Meisner, and D. K. Hill. 1990. Potential changes in the thermal habitat of Great Lakes fish after global climate warming. *Transactions of American Fisheries Society* 119: 254-264.
- McNurney, J. M. and H. Dreier. 1981. Lake Sangchris Illinois USA Creel Survey 1973-1975. *Illinois Natural History Survey Bulletin* 32(4): 594-614.
- Mobley, M.H. 1997. "TVA Reservoir Aeration Diffuser System," Technical Paper 97-3, Presented at Waterpower '97, Atlanta, Georgia, August 5-8, 1997.
- Neill, W. H. and J. J. Magnuson. 1974. Distributional ecology and behavioral thermoregulation of fishes in relation to heated effluent from a power plant at Lake Monona, Wisconsin. *Transactions of the American Fisheries Society* 103(4): 663-710.
- Nuclear Regulatory Commission, 1978. *Final Environmental Statement, Watts Bar Nuclear Plant Unit Nos. 1 and 2*, NUREG-0498, December, 1978.
- O'Bara, C. J. 1994. TWRA creel survey - 1993. Tennessee Wildlife Resources Agency, Nashville, TN. 94-29: 350 pp.
- O'Bara, C. J. 1995. TWRA creel survey - 1994. Tennessee Wildlife Resources Agency, Nashville, TN. 95-29: 317 pp.
- O'Bara, C. J. 1996. 1995 TWRA creel survey. Tennessee Wildlife Resources Agency, Nashville, TN. 96-29: 282 pp.
- Peck, G. E. and J. P. Buchanan. 1995. Status of the channel catfish population in Chickamauga Reservoir. Tennessee Valley Authority, Water Management, Chattanooga, TN. 13 pp.

- Pegg, M. A., J. B. Layzer, and P. W. Bettoli. 1996. Angler exploitation of anchor-tagged saugers in the lower Tennessee River. *North American Journal of Fisheries Management* 16:218-222.
- Schneider, R. W., W. K. Wilson, and B. L. Evenhuis. 1977. Migration of sauger past a thermal discharge in Melton Hill Reservoir. *Proceedings, Annual Conference SE Association of Fish and Wildlife Reservoir Agencies*. 31:538-545.
- Scott, E. M., Jr. 1992. TVA reservoir monitoring program--fish community results - 1991. Tennessee Valley Authority, Water Resources, Chattanooga, TN. 93 pp.
- Shiao, M.C., Proctor, W.D., Hoover, J.H., and Hadjerioua, B., 1997 "Release Dissolved Oxygen Improvement at Watts Bar Dam," Tennessee Valley Authority, Resource Group, Engineering Services, Engineering Laboratory Report No. WR97-1-14-109, Norris, Tennessee.
- St. John, R. T. 1990. Sauger (*Stizostedion canadense*) abundance and spawning movements in the Fort Loudoun tailwaters, Tennessee. Master's Thesis. Tennessee Technological University, Cookeville, TN. 92 pp.
- Tennessee Department of Environment and Conservation (TDEC). 1996. Letter from Thomas E. Roehm, Manager, Industrial Facilities Section, Division of Water Pollution Control, to Odis E. Hickman, Jr., Radwaste/Environmental Control Superintendent, Watts Bar Nuclear Plant, September 6, 1996.
- Tennessee Valley Authority and Nuclear Regulatory Commission. 1994. Watts Bar Nuclear Plant Biological Assessment. Tennessee Valley Authority and Nuclear Regulatory Commission, Chattanooga, TN and Washington, DC, 43 pages.
- Tennessee Valley Authority, 1972. *Final Environmental Statement for Watts Bar Nuclear Plant, Units 1 and 2*, Report No. TVA-OHES-EIS-9.
- Tennessee Valley Authority, 1995. *Supplemental Environmental Review, Final, Operation of Watts Bar Nuclear Plant*, June 1995.
- Tennessee Valley Authority, 1996. *Final Environmental Assessment, Watts Bar Fossil Plant Slag Marketing*, June 1996.
- Tennessee Valley Authority. 1976. Estimates of Entrainment of Fish Eggs and Larvae by Watts Bar Steam Plant, 1975, and assessment of the Impact on the Fisheries, Resource of Watts Bar Reservoir.
- Tennessee Valley Authority. 1995a. Supplemental Environmental Review, Final, Operation of Watts Bar Nuclear Plant. June 1995. 85 pp.
- Tennessee Valley Authority. 1995b. Toxicity biomonitoring using *Pimephales promelas* (fathead minnows), *Ceriodaphnia dubia* (daphnids), and *Selenastrum capricornutum* (algae), Calgon simulated effluent and molluscicide bioassay (Phase I). TVA Water Management, Resource Group. February 8-28, 1995.
- Tennessee Valley Authority. 1995c. Toxicity assessment using *Utterbackia (Anodonta) imbecillis* (freshwater mussel), *Hyalella azteca* (amphipod), and *Chironomus tentans* (midge), Calgon simulated effluent and molluscicide sediment toxicity assessment (Phases II and III). TVA Water Management, Resource Group. June 13-July 21, 1995.
- U.S. Fish and Wildlife Service. 1982. Gray Bat Recovery Plan. Wildlife Service, Washington, DC.
- U.S. Fish and Wildlife Service. 1984a. Endangered and Threatened Wildlife and Plants; Final rule reclassifying the snail darter (*Percina tanasi*) from an endangered species to a threatened species and rescinding critical habitat designation. *Federal Register*, 49(130):27510-27514. Resource of Watts Bar Reservoir.

- U.S. Fish and Wildlife Service. 1984b. Rough Pigtoe Pearly Mussel Recovery Plan. Wildlife Service, Atlanta, Georgia, 51 pages
- U.S. Fish and Wildlife Service. 1985. Recovery Plan for the Pink Mucket Pearly Mussel. Wildlife Service, Atlanta, Georgia, 47 pages.
- U.S. Fish and Wildlife Service. 1991. Fanshell [*Cyprogenia stegaria* (= *irrorata*)] Recovery Plan. U.S. Fish and Wildlife Service, Atlanta, Georgia, 37 pages.
- U.S. Nuclear Regulatory Commission. 1995. Final Environmental Statement related to the operation of Watts Bar Nuclear Plant, Units 1 and 2. URREG-0498, Supplement No. 1. Docket Nos. 50-390 and 50-391. Tennessee Valley Authority. U.S. NRC Office of Nuclear Reactor Regulation. April 1995.
- Wrenn, W. B., N. M. Woomer, P. Ostrowski Jr., W. L. Harper, and E. B. Robertson. 1989. A predictive section 316(a) demonstration for an alternative winter thermal discharge limit for Sequoyah Nuclear Plant, Chickamauga Reservoir, Tennessee. Tennessee Valley Authority, Water Management, Environmental Compliance, Chattanooga, TN. 87 pp.
- Yeager, B. and M. Shiao. 1992. Recommendation and implementation of special seasonal flow releases to enhance sauger spawning in Watts Bar tailwater. Tennessee Valley Authority, Water Resources, Chattanooga, TN. 57 pp.
- Yeager, B. L. 1990. Biological responses to flow and dissolved oxygen in TVA tailwaters. In S. Campbell, editor, Proceedings of the tailwater ecology workshop: tailwaters - a regulated stream's most valuable resource. U.S. Bureau of Reclamation, Austin, TX Document R-91-15: 35-59.

## 7.0 GLOSSARY

**ARAP** - Aquatic Resource Alteration Permit

**CCW** - Condenser Cooling Water used in tube shell heat exchangers to condense turbine steam

**cfs** - cubic feet per second

**daphnids** - Aquatic invertebrate organisms (water fleas) that include the toxicity test species *ceriodaphnia dubia*

**DO** - dissolved oxygen

**EA** - environmental assessment; a written environmental analysis which is prepared pursuant to the National Environmental Policy Act to determine whether a federal action would significantly affect the environment and thus require preparation of a more detailed environmental impact statement.

**gpm** - gallons per minute

**Hydro** - a term used to identify a type of generating station in which the primary generation equipment is driven by water power.

**IC25** - The 25 percent inhibition concentration, or the concentration of a substance (or whole effluent sample) that causes a 25 percent reduction in the measured response during a sub-chronic toxicity test. For Whole Effluent Toxicity (WET) evaluations, the measured responses are survival and growth in a 7-day larval fathead minnow (*Pimephales promelas*) test and survival and reproduction in a 3-brood daphnid (*Ceriodaphnia dubia*) test.

**jurisdictional wetlands** - wetland areas that fall under the jurisdiction of the U.S. Army Corps of Engineers pursuant to the Clean Water Act.

**KESH** - Key Endangered Species Habitat

**L** - liter, a metric measure of volume

**LC50** - The concentration of a substance (or whole effluent sample) that causes mortality to half the test organisms in an acute toxicity test. An acute exposure for aquatic life is normally 48 hours, but may be as long as 96 hours.

**mg** - milligram, one-thousandth of a gram

**MWH** - megawatt hours, a unit of measurement of electrical energy equal to one million watt hours.

**NAAQS** - National Ambient Air Quality Standards

**NPDES** - National Pollutant Discharge Elimination System

**NRC** - Nuclear Regulatory Commission

**riparian** - shoreline

**SCCW** - Supplemental Condenser Cooling Water

**TRM** - Tennessee River Mile

**Turbine** - a machine that generates mechanical power from flowing water (hydrostation turbine) or flowing steam (steam turbine).

**USFWS** - United States Fish and Wildlife Service

**WBF** - Watts Bar Fossil plant

**WBH** - Watts Bar Hydro plant

**WBN** - Watts Bar Nuclear plant

**WET** - Whole Effluent Toxicity

**WMA** - Wildlife Management Area

## **8.0 ENCLOSURES**

1. WBN SCCW Thermal Plume Modeling (Separate Enclosure)
2. Effect of Watts Bar Nuclear Plant and Watts Bar Steam Plant Discharges on Chickamauga Lake Water Temperatures (Separate Enclosure)
3. Discharge Temperature Limit Evaluation for Watts Bar Nuclear Plant (Separate Enclosure)

## **9.0 ATTACHMENTS**

Chronological listing of correspondence by author:

1. J. Bennett Graham, Senior Archaeologist, Land Management, to Dr. Joe Garrison, Environmental Review Coordinator, Tennessee Historical Commission dated November 17, 1997.
2. Herbert L. Harper, Executive Director and Deputy State Historic Preservation Officer, to J. Bennett Graham, Cultural Resources Program, Division Land and Economic Resources, "TVA Watts Bar/108 inch Water Pipeline, Unincorporated, Rhea County," dated November 25, 1997.
3. J. Bennett Graham, Senior Archaeologist, Land Management, to Martha Catlin, Eastern Office of Review, Advisory Council on Historic Preservation, dated December 17, 1997.
4. Lee A. Barclay, Field Supervisor, US Department of Interior, Fish and Wildlife Service, to Greg Askew, Environmental Management, TVA, "Watts Bar Nuclear Power Supplemental Condenser Cooling Water Project," dated December 22, 1997.
5. Herbert L. Harper, Executive Director and Deputy State Historic Preservation Officer, to Jon M. Loney, Environmental Management, TVA, "TVA, Watts Bar NP/Condenser Cooling, Unincorporated, Roane County," dated December 29, 1997.
6. Aubrey D. McKinney, Chief, Environmental Services Division, TWRA, to Jon M. Loney, Environmental Management, TVA, "Draft environmental Assessment for the Watts Bar Nuclear Plant Supplemental Condenser Cooling Water Project," dated January 14, 1998.
7. J. Bennett Graham, Senior Archaeologist, Land Management, to Jon M. Loney, Environmental Management, TVA, "Watts Bar Nuclear Plant - 108 inch Auxiliary Cooling Water Pipeline From Watts Bar Fossil Plant - Section 106 Compliance," dated March 12, 1998.

8. Jon M. Loney, Environmental Management, TVA, to Aubrey D. McKinney, Chief, Environmental Services Division, TWRA, "Environmental Assessment (EA) for the Watts Bar Nuclear Plant (WBN) Supplemental Condenser Cooling Water (SCCW) Project," dated March 26, 1998.
9. Aubrey D. McKinney, Chief, Environmental Services Division, TWRA, to Paul E. Davis, Director, Division of Water Pollution Control, Tennessee Department of Environment and Conservation, "Watts Bar Nuclear (WBN) Plant Supplemental Condenser Cooling Water (SCCW) Project," dated April 27, 1998.
10. Jon M. Loney, Environmental Management, TVA, to Lee A. Barclay, Field Supervisor, US Department of Interior, Fish and Wildlife Service, dated May 7, 1998.
11. Odis E. Hickman, Jr., Radwaste/Environmental Superintendent, Watts Bar Nuclear Plant, Tennessee Valley Authority, to Phillip L. Stewart, Manager, Chattanooga Field Office, Division of Water Pollution Control, Tennessee Department of Environment and Conservation, "Watts Bar Nuclear Plant (WBN) -Supplemental Condenser Cooling Water Project Draft Engineering Report", dated May 11, 1998.
12. Lee A. Barclay, Field Supervisor, US Department of Interior, Fish and Wildlife Service, to Jon M. Loney, Environmental Management, TVA, "FWS #98-236," dated May 26, 1998.
13. C. Randall McIntosh, Manager of Projects, Watts Bar Nuclear Plant, Tennessee Valley Authority, to Phillip L. Stewart, Manager, Chattanooga Field Office, Division of Water Pollution Control, Tennessee Department of Environment and Conservation, "Watts Bar Nuclear Plant (WBN) - Proposed Supplemental Condenser Cooling Water (SCCW) Project - Validation of the Cormix Model," dated June 4, 1998.
14. C. Randall McIntosh, Manager of Projects, Watts Bar Nuclear Plant, Tennessee Valley Authority, to Phillip L. Stewart, Manager, Chattanooga Field Office, Division of Water Pollution Control, Tennessee Department of Environment and Conservation, "Watts Bar Nuclear Plant (WBN) - Supplemental Condenser Cooling Water (SCCW) Project - Revised Draft Environmental Assessment," dated June 19, 1998.
15. Phillip L. Stewart, Manager, Chattanooga Field Office, Division of Water Pollution Control, Tennessee Department of Environment and Conservation, to Odis E. Hickman, Jr., Radwaste / Environmental Superintendent, Watts Bar Nuclear Plant, Tennessee Valley Authority, "Conditional Site Approval for New Outfall Construction, Proposed Supplemental Condenser Cooling Water Project, NPDES Permit No. TN0020168, Tennessee River and Yellow Creek, Rhea County," dated August 20, 1998.

November 17, 1997

Dr. Joe Garrison  
Environmental Review Coordinator  
Tennessee Historical Commission  
Clover Bottom Mansion  
2941 Lebanon Pike  
Nashville, Tennessee 37243-0442

Dear Dr. Garrison:

TVA is proposing to construct a 108-inch water pipeline from the deactivated Watts Bar Fossil Plant to the Watts Bar Nuclear Plant (proposed route is on enclosed map). The purpose of this proposed project is to route water from the condenser cooling water (CCW) system of the former Watts Bar Fossil Plant to the CCW system of the Watts Bar Nuclear Plant. This system is expected to increase the nuclear plant's efficiency and generation by up to 50 MW. The pipeline will be constructed on a grade built up of slag from the old fossil plant for the entire route. As you can note on the enclosed map, the pipe would run along the toe of the contour in back of the former fossil plant. It is our opinion that the old Watts Bar Fossil Plant is eligible for the National Register of Historic Places. While the pipeline will have an impact on this eligible structure, given all the ancillary facilities constructed in this area over the years, we do not think that the impact will be adverse.

While the entire route of the proposed pipeline has been extensively altered in the past, it crosses the recorded location of archaeological site 40RH1 and may cross an outer edge of 40RH6. However, slag was deposited over this area of the route in the 1950's and 60's and the pipe will be placed either on the slag or in the top 24 inches. We do not think that construction of this waterline will have an effect on any archaeological site.

By this letter we are seeking staff determinations regarding our above findings. If questions arise, I can be reached at (423) 632-1583.

Sincerely,

J. Bennett Graham  
Senior Archaeologist

JBG:BB  
Enclosure  
cc: Files, LM, FOR 1A-N



**TENNESSEE HISTORICAL COMMISSION**  
DEPARTMENT OF ENVIRONMENT AND CONSERVATION  
2941 LEBANON ROAD  
NASHVILLE, TN 37243-0442  
(615) 532-1550

November 25, 1997

Mr. J. Bennett Graham  
Cultural Resources Program  
Div. Land & Economic Res.  
Norris, Tennessee 37828

RE: TVA. WATTS BAR/108 INCH WATER PIPELINE, UNINCORPORATED, RHEA COUNTY

Dear Mr. Graham:

Pursuant to your request, this office has reviewed documentation concerning the above-referenced undertaking. This is a requirement of Section 106 of the National Historic Preservation Act for compliance by the participating federal agency or applicant for federal assistance. Procedures for implementing Section 106 of the Act are codified at 36 CFR 800 (51 FR 31115, September 2, 1986).

Considering available information, we find that the project as currently proposed will not adversely affect any property that is eligible for listing in the National Register of Historic Places. Therefore, this office has no objection to the implementation of this project. You should now inform the Advisory Council on Historic Preservation of this no adverse effect determination. Please enclose a copy of this determination in your notification to the Council as delineated at 36 CFR Part 800. **Until you have received a final comment on this project from the Council, you have not completed the Section 106 review process.** Please direct questions and comments to Joe Garrison (615)532-1559. We appreciate your cooperation.

Sincerely,

Herbert L. Harper  
Executive Director and  
Deputy State Historic  
Preservation Officer

HLH/jyg

December 17, 1997

Ms. Martha Catlin  
Eastern Office of Review  
Advisory Council on Historic Preservation  
Old Post Office Building, Suite 803  
1100 Pennsylvania Avenue, NW  
Washington, DC 20004

Dear Ms. Catlin:

The Tennessee Valley Authority (TVA) proposes to construct a supplementary cooling water pipeline at the Watts Bar Nuclear Power Plant in Rhea County, Tennessee. The proposed pipeline would be constructed over two archaeological sites and in the vicinity of the Watts Bar coal-fired power plant, a property eligible for inclusion in the National Register of Historic Places. The Tennessee State Historic Preservation Officer (SHPO) concurs with TVA that the proposed undertaking will not adversely affect any of these properties. Project documentation is enclosed for your review pursuant to Section 800.5(d) of the Advisory Council's regulations.

If you have any questions regarding this request, please call me at (423) 632-1583.

Sincerely,

J. Bennett Graham  
Senior Archaeologist  
Land Management

DEO:BB

Enclosures

cc: Dr. Joe Garrison  
Tennessee Historical Commission  
Clover Bottom Mansion  
2941 Lebanon Pike  
Nashville, Tennessee 37243-0442

Files, LM, FOR 1A-N



# United States Department of the Interior

## FISH AND WILDLIFE SERVICE

446 Neal Street  
Cookeville, Tennessee 38501

December 22, 1997

Mr. Greg Askew  
Tennessee Valley Authority  
400 West Summit Hill Drive  
Knoxville, Tennessee 37902-1499

Re: Watts Bar Nuclear Power Supplemental Condenser Cooling Water Project

Dear Mr. Askew:

Thank you for your letter and enclosures of December 11, 1997, regarding the subject project. The Fish and Wildlife Service (Service) has reviewed the four documents which you submitted. The Service was also represented at a meeting held on December 18 to discuss this project.

The draft environmental assessment (December 5, 1997) appears to be comprehensive in nature. The meeting held on December 18 allowed a thorough discussion of the project, anticipated chemical and thermal impacts, and planned efforts to minimize adverse impacts to aquatic resources, including species federally listed as endangered.

It is our understanding that the proposed project will result in the addition of a new thermal discharge at the TVA Watts Bar Fossil plant. Based on thermal modeling done by TVA, the dispersion zones of the fossil plant discharge and the nuclear plant discharge will not overlap. Mussels would be relocated from an area approximately 150' x 150' in the immediate vicinity of the new discharge. At least one mussel species federally listed as endangered (*Lampsilis abrupta*) could be included in the relocation effort.

Some concern was expressed about the change from hourly temperature averaging to daily (24-hour) averaging. What maximum temperatures would result based on some intermediate averaging periods (i.e., 2 hr, 5 hr)? Please keep us informed of your evaluation of this, and other, issues as you proceed through the permitting process.

We appreciate the opportunity to review documents on the subject project and provide comments. We also appreciate the time and effort involved to have an open and informative meeting on this project. Should you have any questions, please contact Allen Robison of my staff at 931/528-6481.

Sincerely,

  
for Lee A. Barclay, Ph.D.  
Field Supervisor



**TENNESSEE HISTORICAL COMMISSION**  
DEPARTMENT OF ENVIRONMENT AND CONSERVATION  
2941 LEBANON ROAD  
NASHVILLE, TN 37243-0442  
(615) 532-1550

December 29, 1997

Mr. Jon M. Loney  
Environmental Management  
400 West Summit Hill Drive  
Knoxville, Tennessee 37902-1499

RE: TVA. WATTS BAR NP/CONDENSER COOLING, UNINCORPORATED, ROANE COUNTY

Dear Mr. Loney:

Pursuant to your request, this office has reviewed documentation concerning the above-referenced undertaking received Friday, December 19, 1997. This is a requirement of Section 106 of the National Historic Preservation Act for compliance by the participating federal agency or applicant for federal assistance. Procedures for implementing Section 106 of the Act are codified at 36 CFR 800 (51 FR 31115, September 2, 1986).

Considering available information, we find that the project as currently proposed will not adversely affect any property that is eligible for listing in the National Register of Historic Places. Therefore, this office has no objection to the implementation of this project. You should now inform the Advisory Council on Historic Preservation of this no adverse effect determination. Please enclose a copy of this determination in your notification to the Council as delineated at 36 CFR Part 800. **Until you have received a final comment on this project from the Council, you have not completed the Section 106 review process.** Please direct questions and comments to Joe Garrison (615)532-1559. We appreciate your cooperation.

Sincerely,

Herbert L. Harper  
Executive Director and  
Deputy State Historic  
Preservation Officer

HLH/jyg

3311

6.0



TENNESSEE WILDLIFE RESOURCES AGENCY

ELLINGTON AGRICULTURAL CENTER  
P. O. BOX 40747  
NASHVILLE, TENNESSEE 37204

January 14, 1998

Mr. Jon M. Loney, Manager  
Environmental Management  
Tennessee Valley Authority  
400 West Summit Hill Drive  
Knoxville, TN 37902-1499

re: Draft Environmental Assessment for the Watts Bar Nuclear  
Plant Supplemental Condenser Cooling Water Project

Dear Mr. Loney:

The Tennessee Wildlife Resources Agency is in the process of reviewing the above Draft Environmental Assessment. We should complete this review in the near future and will provide comments and recommendations to you on or before February 9, 1998. Please contact me at 615/781-6643 if there are additional data which should be brought to our attention.

Sincerely,

*Aubrey D. McKinney*  
Aubrey D. McKinney, Chief  
Environmental Services Division

ADM/bjs

RECEIVED	
JAN 20 1998	
Doc. No. 3395	
<input checked="" type="checkbox"/>	PLS
<input type="checkbox"/>	ALL
<input type="checkbox"/>	ASH
2 GA	

The State of Tennessee

AN EQUAL OPPORTUNITY EMPLOYER



# TENNESSEE WILDLIFE RESOURCES AGENCY

ELLINGTON AGRICULTURAL CENTER  
P. O. BOX 40747  
NASHVILLE, TENNESSEE 37204

January 28, 1998

Mr. Jon M. Loney, Manager  
Environmental Management  
Tennessee Valley Authority  
400 West Summit Hill Drive  
Knoxville, TN 37902-1499

re: Draft Environmental Assessment for the Watts Bar Nuclear Plant (WBN)  
Supplemental Condenser Cooling Water (SCCW) Project

Dear Mr. Loney:

The Tennessee Wildlife Resources Agency has completed initial review of the above referenced document and supporting materials, and offers the following comments and recommendations.

1. Utilization of a diffuser at Watts Bar Fossil facility (WBF) to accommodate thermal releases associated to proposed SCCW project is dismissed as economically unacceptable DEA (2.3.3 p.12); the document, however, does not provide an economic analysis of this issue. Please provide those data routinely used in cost effectiveness determinations including diffuser cost and maintenance over the life of the project as compared to the increase in both capacity and revenue from WBN over the same period. Likewise, dismissal of a diffuser option appears to conflict with the statement at DEA (2 p. 12) that in the absence of the SCCW project new, presumably diffuser equipped, facility construction would be required.
2. Over the years, the Tennessee Valley Authority (TVA) has utilized provisions in the 316(a) process to consider significant increase in both the annual thermal discharge and deviation from state and federal thermal standards at both Watts Bar Nuclear and Sequoyah Nuclear. Given the maximum potential thermal release capacity of these projects, what are the upper bounds of such increases that TVA might seek in future proposals? This analysis should include defining the circumstances of thermal releases considered by TVA to have potentially

The State of Tennessee

AN EQUAL OPPORTUNITY EMPLOYER

adverse impact on water quality and fish and aquatic life. We suggest that neither U.S. Environmental Protection Agency (EPA) nor Tennessee Department of Environment and Conservation (TDEC) continue with the incremental alterations, modification, or variances until such time as the ultimate boundaries or future requests are more clearly defined.

3. As a result of the complexity and variability of flow and water quality conditions in tailwater situations, environmental impact projections are, at best, highly speculative; documentation of actual impact under operational conditions requires extensive, well designed monitoring, such as TVA's vital signs monitoring program, the reservoir release improvement monitoring, and discharge specific operational monitoring programs. We are concerned that TVA may divest itself of both the capability and the commitment for such state of the art monitoring and research programs in preparation for national deregulation of the power industry. Absolute confidence in TVA's commitment to continued excellence in field sciences of aquatic ecology and water quality is essential to consideration of projects with speculative impacts such as the SCCW proposal. As part of this process, TVA should prepare a comprehensive, integrated summary of monitoring and research commitments for both Watts Bar and Sequoyah nuclear operations, and Watts Bar and Chickamauga Reservoirs in consultation with Tennessee, the U.S. Environmental Protection Agency, and the U.S. Fish and Wildlife Service (USFWS) for incorporation by reference into the appropriate NPDES permits or through other formal agreements.
4. The DEA (3.2.3 p. 19) does not specify how implementation of the SCCW would alter or increase the use of chemicals for corrosion control or biofouling. Please provide an estimation of the increased use of such chemicals. Likewise, we suggest that NPDES modification for all chemical release outfalls include periodic WET evaluation using the 9-day juvenile mussel test with silt and whole sediment test with appropriate organisms in addition to present toxicity testing requirements.
5. The DEA (3.2.3 p. 20) does not address the potential impacts of providing additional release from Watts Bar Hydroelectric facility (WBH) to meet the thermal intake requirements at WBN. The potential impact, particularly of sustained late summer, early fall releases from Norris Reservoir should be fully discussed, including an evaluation of the anticipated frequency, duration, and circumstances requiring prolonged releases from Norris Reservoir.

6. The DEA analysis (3.33 p. 30) relies upon 316(b) entrainment and impingement studies which were conducted in 1975, more than two decades ago. Are there recent data indicating that entrainment and impingement impacts in 1998 would be reasonably similar to those observed in 1975? In the absence of such corroborating information, TVA should propose limited sampling as necessary to provide for comparative evaluation of the 1975 studies and current conditions.
7. We concur with the description of the mussel community in the Watts Bar tailwater sanctuary as a remnant of the diverse assemblage of mussels existing prior to the impoundment. The reasons for the inability of the remaining mussels to reproduce are not understood. We suggest that mitigation for the proposed SCCW project include a substantial research effort to identify the reasons this mussel community is unable to reproduce. Likewise, the ability of juvenile mussels, obtained through culture techniques, to survive and grow in the WBH tailwaters should be evaluated.
8. A continuing concern in the Tennessee River system is expansion of zebra mussels and their potential adverse impact on native species of fish and aquatic life. Please provide an evaluation of the potential response of zebra mussels to conditions resulting from the proposed SCCW project as proposed and with a new diffuser at WBF.

Until such time as these outstanding issues are resolved, we cannot recommend the WBN/SCCW project to either TDEC, the USFWS or EPA; we look forward to working with all parties to address these concerns.

If you have questions or need additional information, please contact me at 615/781-6643.

Sincerely,

  
Aubrey D. McKinney, Chief  
Environmental Services Division

ADM/bjs

cc: Philip Stewart - TDEC/WPC, Chattanooga  
Anders Myhr - TWRA, Region III  
David Young - TWRA, Region III


March 12, 1998

Jon M. Loney, WT 8C-K

**WATTS BAR NUCLEAR PLANT - 108 INCH AUXILLARY COOLING WATER  
PIPELINE FROM WATTS BAR FOSSIL PLANT - SECTION 106 COMPLIANCE**

The attached letters evidence TVA's compliance with Section 106 of the National Historic Preservation Act for the above referenced project. Under the regulations of the Advisory Council on Historic Preservation at 36 CFR Part 800.5(d)(1) when TVA finds the effect of an undertaking on a historic property (Watts Bar Fossil Plant and two archaeological sites) is not adverse, TVA will obtain the SHPO's concurrence (November 19, 1997 and November 25, 1997 letters) and notify and submit to the Council summary documentation (December 17, 1997 letter). Under Part 800.5(d)(2) of the Council's regulations, if the Council does not object to the finding within 30 days of receipt of notice, TVA is not required to take any further steps in the Section 106 process. No objection to our finding has been received from the Council more than 75 days after the notice was sent.

If you have any questions about this compliance documentation, please give me a call at 632-1583.



J. Bennett Graham  
Senior Archaeologist  
Land Management  
NRB 2C-N

DEO:BB  
Attachments  
cc: Files, LM, FOR 1A-N

RECEIVED	
MAR 13 1998	
3824	
1	
2	2
3	3

Pray



Tennessee Valley Authority, 400 West Summit Hill Drive, Knoxville, Tennessee 37902-1499

March 26, 1998

Aubrey D. McKinney, Chief  
Environmental Services Division  
Tennessee Wildlife Resources Agency  
Ellington Agricultural Center  
P.O. Box 40747  
Nashville, Tennessee 37402

**ENVIRONMENTAL ASSESSMENT (EA) FOR THE WATTS BAR NUCLEAR  
PLANT (WBN) SUPPLEMENTAL CONDENSER COOLING WATER (SCCW)  
PROJECT**

Dear Mr. McKinney:

We appreciate the detailed comments given in your letter dated January 28, 1998. TVA staff reviewed these comments and prepared responses which are enclosed. The format consists of a restatement of each of your comments followed by TVA's response.

In summary, TVA believes that the proposed WBN SCCW project will have only minor localized effects, and that our environmental assessment, including the proposed mitigation, supports this conclusion. Please call me at 423-632-3012 if you would like to discuss our comments.

Sincerely,

A handwritten signature in black ink that reads "Jon Loney". The signature is written in a cursive style with a large, looping initial "J".

Jon Loney, Manager  
Environmental Management

Enclosure

**TWRA Comment 1.** Utilization of a diffuser at Watts Bar Fossil facility (WBF) to accommodate thermal releases associated to proposed SCCW project is dismissed as economically unacceptable DEA (2.3.3 p.12); the document, however, does not provide an economic analysis of this issue. Please provide those data routinely used in cost effectiveness determinations including diffuser cost and maintenance over the life of the project as compared to the increase in both capacity and revenue from WBN over the same period. Likewise, dismissal of a diffuser option appears to conflict with the statement at DEA (2 p.12) that in the absence of the SCCW project new, presumably diffuser equipped, facility construction would be required.

**TVA Response:** The economic analysis for projects at TVA Nuclear facilities is based on an evaluation of the cost versus increased revenue and avoided operational and maintenance costs to determine the payback period and internal rate of return. To successfully compete for capital resources within TVA, a project typically must show a positive net present value (NPV), a 35% internal rate of return (IRR) using a 15% discount rate, and a payback in 3 years or less. The construction of a new diffuser was estimated to increase the capital cost of the proposed project by approximately 30% (\$2 million) with no increase in the revenue. This increase would primarily result from the excavation and anchorage in the river channel necessary for a diffuser large enough to handle the 330 cfs discharge (Note this is 3 to 4 times the capacity of the existing WBN diffuser system). The incremental annual maintenance cost is estimated at \$10,000. These increases in cost would extend the payback period more than 2 years to 9 years and reduce the IRR 4% to 26%. Based on this TVA would not financially consider the proposed action with the added capital cost of a diffuser and no further action was pursued. This decision was further substantiated by thermal plume modeling which demonstrated the project as proposed complies with all thermal water quality criteria limits.

Installation of a diffuser to replace the existing WBF discharge would allow more rapid dissipation of the thermal effluent. However, due to the unique location of the Watts Bar Fossil (WBF) discharge, within one mile downstream of Watts Bar Dam, disruption of the benthic habitat in the vicinity of the discharge during installation of the diffuser would cause much greater impact to the resident mussel community than the limited impact area resulting from discharges at the current facility. While all impacts have not been extensively investigated and quantified, obvious affects include extensive disturbance to bottom life during construction. This would result from the excavation of the river bottom to provide a bed for the diffuser and associated anchorage. The excavated area would be far more extensive than the bottom area which the CORMIX model computed as being impacted by the thermal plume of the proposed project. In addition to the

direct impact to the bottom life residing in the area of excavation, there would also be a potential impact downstream due the silt created from dredging and blasting. As described in the EA, potential adverse impacts to resident biota resulting from thermal discharges at the existing WBF outlet are very localized. Fish will have ready avenues to avoid the high temperatures in the immediate vicinity of the discharge and freshwater mussels will be moved from the impact zone.

The statement in DEA paragraph 2.2, No Action, regarding need for another source to provide the capacity available from the proposed project was not intended to restrict future construction options. Elimination of the diffuser was specifically applicable to the economics of this proposed project and therefore not in conflict with future projects. Any new project would have to address the specific environmental impacts unique to such a facility and its location. Depending on the type of generating facility equipment there might be no need for heated water discharge and consideration of a diffuser. However, there might be significant issues with air quality or water withdrawal impacts. Considering that the proposed project is projected to comply with thermal water quality criteria and have no significant environmental impact, this was intended to point out the possibility that the net effect of future construction could be of greater environmental impact.

**TWRA Comment 2.** Over the years, the Tennessee Valley Authority (TVA) has utilized provisions in the 316(a) process to consider significant increase in both the annual thermal discharge and deviation from state and federal thermal standards at both Watts Bar Nuclear and Sequoyah Nuclear. Given the maximum potential thermal release capacity of these projects, what are the upper bounds of such increases that TVA might seek in future proposals? This analysis should include defining the circumstances of thermal releases considered by TVA to have potentially adverse impact on water quality and fish and aquatic life. We suggest that neither U.S. Environmental Protection Agency (EPA) nor Tennessee Department of Environment and Conservation (TDEC) continue with the incremental alterations, modification, or variances until such time as the ultimate boundaries or future requests are more clearly defined.

**TVA Response:** Beyond the current proposal, TVA has no plans to increase thermal discharges to Chickamauga Reservoir. Because both Sequoyah and Watts Bar Nuclear Plants use cooling towers, the majority of necessary thermal releases are now rejected to the atmosphere.

TVA believes that its permitted thermal releases have only localized effects. This belief is evidenced by the limited mixing zone lengths necessary to meet State of Tennessee thermal water quality criteria which protect water quality, and by monitoring results that have failed to identify adverse

impacts. Thus, TVA does not believe that its thermal releases have reservoir-scale effects. As a result, TVA sees no regulatory need nor practical benefit of analyzing reservoir behavior in response to hypothetical thermal releases. For the present proposal, TVA's environmental assessment evaluated the cumulative behavior and impact of the existing WBN thermal release and the proposed release.

**TWRA Comment 3.** As a result of the complexity and variability of flow and water quality conditions in tailwater situations, environmental impact projections are, at best, highly speculative; documentation of actual impact under operational conditions requires extensive, well designed monitoring, such as TVA's vital signs monitoring program, the reservoir release improvement monitoring, and discharge specific operational monitoring programs. We are concerned that TVA may divest itself of both the capability and the commitment for such state of the art monitoring and research programs in preparation for national deregulation of the power industry. Absolute confidence in TVA's commitment to continued excellence in field sciences of aquatic ecology and water quality is essential to consideration of projects with speculative impacts such as the SCCW proposal. As part of this process, TVA should prepare a comprehensive, integrated summary of monitoring and research commitments for both Watts Bar and Sequoyah nuclear operations, and Watts Bar and Chickamauga Reservoirs in consultation with Tennessee, the U.S. Environmental Protection Agency, and the U.S. Fish and Wildlife Service (USFWS) for incorporation by reference into the appropriate NPDES permits or through other formal agreements.

**TVA Response:** Environmental impact projections resulting from operation of WBN using the SCCW system are speculative, yet, as indicated in the EA, they are based on results of the best available modeling tool (CORMIX). The EA documents a reasonable and accepted engineering approach to predicting the behavior and characteristics of the proposed thermal discharge. There is uncertainty to such methods, but because of conservative assumptions, TVA believes the estimates of temperature changes and the extent of the discharge plume were appropriately characterized. This characterization was taken in combination with extensive knowledge of resident biological communities in the Watts Bar Reservoir forebay and Watts Bar Dam tailwater ecosystems. This knowledge is supplemented with large historical databases from these two areas as a result of previous compliance monitoring, site assessments, and a detailed "vital signs" monitoring program. As Mr. McKinney suggested, a monitoring program could be devised to determine if projections were correct, however, it is TVA's contention that the potential for unforeseen impacts is limited, and the additional expense is not merited.

Comment 3, clarified through subsequent discussions with Mr. McKinney,

goes on to request continuous, or at least intermittent commitments to monitor biological impacts of both Watts Bar and Sequoyah nuclear operations on Watts Bar and Chickamauga Reservoir aquatic communities. While this request may have some merit with regard to operational monitoring for the two nuclear plants, TVA considers this request outside the scope of the WBN SCCW project.

Monitoring activities currently in place on Watts Bar and Chickamauga Reservoirs include those done under the Vital Signs Monitoring program, funded by Federal appropriations, and compliance operational monitoring in the vicinity of Watts Bar Nuclear Plant. Vital Signs Monitoring activities include water quality and biological community (fish and benthic macroinvertebrate) aspects. Reservoirs are sampled biennially, except Chickamauga, where fish community sampling was done during "unscheduled" years through funding provided by Watts Bar and Sequoyah Nuclear Plants to provide information relative to existing compliance issues or variance requests. Operational Monitoring at Watts Bar Nuclear Plant was done during 1996 and 1997, the initial two years of operation, as part of Clean Water Act compliance, however, TVA will recommend discontinuing this effort as no adverse impacts have been identified. Only the Vital Signs monitoring funded by Federal appropriations is projected for either of these reservoirs, or in the vicinity of either Watts Bar or Sequoyah Nuclear plants in the future.

**TWRA Comment 4.** The DEA (3.2.3 p.19) does not specify how implementation of the SCCW would alter or increase the use of chemicals for corrosion control or biofouling. Please provide an estimation of the increased use of such chemicals. Likewise, we suggest that NPDES modification for all chemical release outfalls include periodic WET evaluation using the 9-day juvenile mussel test with silt and whole sediment test with appropriate organisms in addition to present toxicity testing requirements.

**TVA Response:** Implementation of the SCCW will not increase or change the use of chemicals. No corrosion control chemicals are used specifically for the CCW system which the SCCW supplies. These chemicals are only used in the once-through auxiliary cooling systems, ERCW and RCW. Only the residual remaining after passing through these systems would be discharged into the CCW and is not counted on for any protective benefit in the CCW. Also biocide chemicals for mollusk control are presently only used in the ERCW and RCW systems. Since the CCW system does not receive direct injection of these chemicals, there would be no change to the present use of such chemicals. While the total poundage of the chemicals released to the river would remain unchanged, the implementation of the proposed project would result in a decrease in the average ppm of

continuously injected chemicals in the diffuser discharge. This due to the decrease in concentration levels in the CCW resulting from the input of the SCCW flow mass.

An algaecide treatment may be specifically used in the CCW. This chemical would be injected as short duration dose shock treatment. SCCW supply would be suspended during the CCW treatment so that the amount of chemical is dependent of the fixed volume of the CCW system which is unchanged. Therefore the proposed project would not require any increase use of this chemical.

As explained in the DEA, whenever the introduction of chemical controls results in residuals in the CCW in excess of permissible discharge levels, blowdown is withheld until acceptable residuals are attained. The discharge of the SCCW will be operated in this manner.

A description of the chemical usage in the raw water systems, ERCW and RCW, is as follows:

- A copolymer dispersant will be injected on a year-round basis to keep settleable solids in suspension and thereby reduce accumulations of silt and rust. The release of the copolymer is anticipated to be no more than 0.2 milligram per liter (0.2 ppm) as active product.
- Tetrapotassium pyrophosphate will be injected on a year-round continuous basis to sequester iron from existing corrosion products in raw-water piping and ancillary components. The release of pyrophosphate at the diffuser discharge is not expected to exceed 0.2 milligrams per liter (0.2 ppm) as total phosphorus.
- Zinc sulfate will be injected on a year-round continuous basis to reduce corrosion rates of carbon-steel piping and components. The release of zinc sulfate is anticipated to be maintained at 0.2 milligram per liter (0.2 ppm) zinc.
- Butyl benzotriazole (Copper-Trol™), a corrosion inhibitor, will be injected periodically into the raw-water systems to reduce copper corrosion rates. Most of the heat exchangers cooled by the raw water systems are constructed with copper or copper-alloy tubes.

The total poundage of the chemicals and the maximum concentration levels of releases to the river would remain unchanged for the proposed project. Also the average ppm of continuously injected chemicals would decrease in the WBN diffuser discharge.

TVA Comments to TWRA Comments Given in Mr. Aubrey D. McKinney's  
Letter Dated January 28, 1998

---

With respect to WET evaluation using the 9-day juvenile mussel test with silt and whole sediment test with appropriate organisms, TVA believes that this subject was adequately covered in the SCCW EA and in previous WBN documents.

**TWRA Comment 5.** The DEA (3.2.3 p.20) does not address the potential impacts of providing additional release from Watts Bar Hydroelectric facility (WBH) to meet the thermal intake requirements at WBN. The potential impact, particularly of sustained late summer, early fall releases from Norris Reservoir should be fully discussed, including an evaluation of the anticipated frequency, duration, and circumstances requiring prolonged releases from Norris Reservoir.

**TVA Response:** There are no anticipated or planned additional releases from either Watts Bar or Norris Reservoirs needed to meet the intake temperature requirements at WBN. The paragraph in the EA (3.23.3, page 20) which mentions possible increased WBH discharges was intended only to indicate that there are actions which could be taken to reduce the WBN intake temperature in the statistically unlikely event that the limit is approached.

The WBN intake temperature limit of 85° F was not reached or exceeded at any time during the 18 years of simulated operation of the SCCW system. The maximum predicted WBN intake temperature was 83.7° F. This was based on recorded dam releases, reservoir elevations, and meteorological data from January 1, 1976 through October 15, 1993. The meteorological data should be conservative (higher air temperatures) because the data were measured at the Chattanooga airport, which is an urban area. No credit was taken for thermal stratification in the river, so actual WBN intake temperatures should be lower than predicted.

**TWRA Comment 6.** The DEA analysis (3.33 p.30) relies upon 316(b) entrainment and impingement studies which were conducted in 1975, more than two decades ago. Are there recent data indicating that entrainment and impingement impacts in 1996 would be reasonably similar to those observed in 1975? In the absence of such corroborating information, TVA should propose limited sampling as necessary to provide for comparative evaluation of the 1975 studies and current conditions.

**TVA Response:** The requested sampling would allow determination if fish populations (both larval and adult) in the vicinity of the WBF intake are similar now to those present in 1975. While there have been some changes in factors influencing water quality of Watts Bar Reservoir since the 1975 impingement and entrainment studies, Vital Signs Monitoring results from 1990 to 1997 indicate a relatively stable fish community in the forebay environment. Although reductions in adverse influences, mainly in the

TVA Comments to TWRA Comments Given in Mr. Aubrey D. McKinney's  
Letter Dated January 28, 1998

upper reservoir areas, may have impacted resident fish between 1975 to 1990, the potential for major shifts in forebay fish community quality appears remote.

New aeration activities in the forebay may influence distribution patterns of some fish (e.g. striped bass) that require cool, oxygenated water. During times of the year when aeration is required to maintain dissolved oxygen levels in the tailwater (late summer and early fall), increased impingement by the WBF intake of striped bass drawn to the aerated area above the dam could occur if the aeration system failed. Individuals would be forced into warmer, oxygenated levels where they may become stressed due to their low tolerance to high water temperatures and become susceptible to impingement. However, operation of the SCCW would not be the causative agent. Aeration is not necessary during the spawning period in the Watts Bar forebay, and therefore entrainment should not be influenced over that experienced in the early 1970s (except for only half of the flow required during WBF operation will be needed for the WBN SCCW project).

**TWRA Comment 7.** We concur with the description of the mussel community in the Watts Bar tailwater sanctuary as a remnant of the diverse assemblage of mussels existing prior to the impoundment. The reasons for the inability of the remaining mussels to reproduce are not understood. We suggest that mitigation for the proposed SCCW project include a substantial research effort to identify the reasons this mussel community is unable to reproduce. Likewise, the ability of juvenile mussels, obtained through culture techniques, to survive and grow in the WBH tailwaters should be evaluated.

**TVA Response:** As indicated in the draft environmental assessment, this renewed use of the Watts Bar Fossil Plant discharge would have a detectable effect only on a very small part of the available gravel and cobble mussel habitat in the Tennessee River downstream from Watts Bar Dam. Completion of this project would expose an area of bottom habitat measuring less than 150 x 150 ft. to temperature conditions which would be higher than normal for this part of the Watts Bar Dam tailwater. TVA has proposed to relocate the few native mussels which exist in the thermal impact area to other suitable mussel habitat in the Watts Bar tailwater. That relocation appears to be adequate mitigation for the potential adverse effects this discharge could have on native mussels in the river.

TVA biologists are well aware of the status of native mussel stocks downstream from Watts Bar Dam and the other mainstream dams on the Tennessee River. On several occasions (e.g., in the 1990 Reservoir Operations Review EIS, and in the 1986 Watts Bar Pre-operational Monitoring Report), TVA has acknowledged that the dams are probably

TVA Comments to TWRA Comments Given in Mr. Aubrey D. McKinney's  
Letter Dated January 28, 1998

---

related to the lack of mussel recruitment in these tailwaters. While TVA staff agree that the specific causes of this lack of recruitment are unknown, the presence of some reproducing mussel stocks in specific locations downstream from a few Tennessee River dams seems to offer tantalizing clues which might be used to solve this mystery. Unfortunately, neither TVA nor any other federal, state, or non-governmental agency has given this project the emphasis some believe it deserves. In spite of this lack of any other attention to this recovery project, TVA does not see any logic in attempts to link the general issue of mussel recovery to a minor project which happens to have been proposed for the Watts Bar Dam tailwater.

**TWRA Comment 8.** A continuing concern in the Tennessee River system is expansion of zebra mussels and their potential adverse impact on native species of fish and aquatic life. Please provide an evaluation of the potential response of zebra mussels to conditions resulting from the proposed SCCW project as proposed and with a new diffuser at WBF.

**TVA Response:** TVA monitoring activities indicate that zebra mussels presently occur in both Watts Bar Reservoir and in the Watts Bar tailwater. During 1997, sampling in the river downstream from Watts Bar Dam has documented that zebra mussel larvae reached a peak of approximately 800 per cubic meter in the water, and zebra mussel adults were present at approximately 50 per square meter on many hard substrates. Research being conducted in the Great Lakes and elsewhere indicates that zebra mussels can tolerate water temperatures down to near freezing; however, temperatures above 90 degrees Fahrenheit inhibit reproduction and, above about 93 degrees, zebra mussel survival.

The proposed SCCW project (without or with a diffuser) would have only very localized impacts on zebra mussels in Watts Bar Reservoir or the tailwater. Zebra mussels would be unlikely to survive in the 90+ degree water within the discharge structures or on the small area of river substrate which would be bathed with this heated flow. Adult zebra mussels living on the river bottom within the remainder of the mixing zone would be virtually unaffected by the heated water because the warm water would quickly rise to the surface and be completely mixed with ambient temperature water before coming back into contact with the river bottom. Downstream from the mixing zone, zebra mussels would be virtually unaffected by the 0.1 or 0.2 degree increase in temperature caused by the SCCW discharge.



# TENNESSEE WILDLIFE RESOURCES AGENCY

ELLINGTON AGRICULTURAL CENTER  
P. O. BOX 40747  
NASHVILLE, TENNESSEE 37204

April 27, 1998

Mr. Paul E. Davis, Director  
Division of Water Pollution Control  
Tennessee Department of Environment & Conservation  
6th Floor, L&C Annex  
401 Church Street  
Nashville, TN 37243-1534

re: Watts Bar Nuclear (WBN) Plant  
Supplemental Condenser Cooling Water (SCCW) Project

Dear Mr. Davis:

Please find attached a copy of the Tennessee Valley Authority's (TVA) March 26, 1998 response to Tennessee Wildlife Resources Agency (TWRA) correspondence of January 28, 1998 regarding TVA's SCCW project. Considering the dismissive nature of TVA's response to TWRA concerns and recommendations, we must recommend that a National Pollutant Discharge Elimination System (NPDES) permit not be issued to accommodate the SCCW project until such time these issues are effectively resolved.

The rationale adopted by TVA for this project incorporates significant unresolved contradictions:

- Diffuser Issues:** The volume of the proposed SCCW discharge is approximately five times larger than the existing WBN diffuser release. Permitting the SCCW release through the existing Watts Bar Fossil (WBF) culvert may impact the Division's ability to require utilization of appropriate diffuser technology elsewhere in the Tennessee River Valley in the future. We find nothing in the SCCW project to distinguish it from other requests for thermal releases of this magnitude which would, in all likelihood, require utilization of diffuser technology. We are likewise concerned about permitting a non-diffuser equipped thermal release based on modeling results which are strongly counter intuitive.

<b>RECEIVED</b>	
APR 30 1998	
Doc. No. 4068	
<u>1</u> JML	<u>1</u> MLI
<u>1</u> Files	<u>3</u> AHL/CRW
	<u>2</u> GFA
Environmental Management	

The State of Tennessee

AN EQUAL OPPORTUNITY EMPLOYER

A portion of TVA's rationale for not equipping this release with a diffuser is the potential, temporary adverse impact on the benthic community, including freshwater mussels. TVA acknowledges that the demise of the Watts Bar tailwaters mussel community is directly related to the Watts Bar Hydroelectric (WBH) facility and further acknowledges that the SCCW project unites WBH/WBF/WBN into single entity. Allowing TVA to use concern for adverse impact to the benthic community as rationale for a non-diffuser equipped thermal release while concurrently disclaiming responsibility for conservation of the same community is (see, TVA response 7), at best, inconsistent with the intent of the NPDES process.

One of the originally proposed benefits of the WBN project was elimination of adverse environmental impact from the WBF facility. It would appear that reestablishing a non-diffuser equipped thermal release from WBF partially negates that identified benefit and likewise is counter to the intent of the anti-backsliding provisions of the Clean Water Act.

2. **Monitoring Issues:** The purpose of the SCCW project is to increase power production at WBN with a subsequent increase in profit for TVA. TVA, however, is willing to commit to related aquatic resource impact monitoring only to the extent that national tax payor funds are made available through appropriated dollars from the U.S. Congress (see, TVA response 3). Monitoring the environmental impact of TVA hydro, fossil, and/or nuclear power projects should be a TVA power responsibility, incorporated in the appropriate permits or certifications, unrelated to non-power funding.


With regard to reliance on 316 (a) data now more than 20 years old, TVA's position is that evaluating the current validity of those data may result in information requiring further consideration of aquatic resource impacts related to the WBN facility in general and the SCCW project in particular. Impact assessment based on reliable information gathered by the discharger is an important component of the NPDES permit process and should not be discarded for the SCCW project.

Through the combined impacts of the Watts Bar Hydroelectric facility and the Watts Bar Nuclear facility, TVA essentially controls the quality of one of Tennessee's premier aquatic resources. The rationale TVA puts forward to support the SCCW project, if adopted, assures that project elements remain distinct, thus diminishing TVA's responsibility for the cumulative impacts of the WBH/WBF/WBN complex. TWRA wishes to re-emphasize our original comments 3 and 6 of January 28, 1998; we consider the issue of an appropriate monitoring commitment to be incorporated into an NPDES permit for WBN/SCCW to be wholly unresolved.

Our concerns with regard to discharge release impacts, utilization of diffuser technology, model verification, updating 316(a) data, and conservation of freshwater mussels are unresolved. Likewise, our concerns over potential adverse impacts on the behavior, survival and recruitment of sauger, catfish, striped bass, and freshwater mussels are unresolved

Your time and attention in this matter is greatly appreciated.

Sincerely,



Aubrey D. McKinney, Chief  
Environmental Services Division

ADM/bjs

cc: EPA - Region IV, Atlanta, GA  
Jon Loney - TVA

May 7, 1998

Dr. Lee A. Barclay, Supervisor  
U.S. Fish and Wildlife Service  
446 Neal Street  
Cookeville, Tennessee 38501

Dear Dr. Barclay:

Enclosed is a copy of the near-final Tennessee Valley Authority Environmental Assessment (EA) concerning the proposed Supplemental Condenser Cooling Water Project at the Watts Bar Nuclear Plant, Tennessee River Mile 528. This version of the EA (final except for the insertion of the enclosures and attachments) contains relatively few changes from the draft provided to your office in December, 1997. As you may remember, that draft was used as the basis for a discussion with you, your staff, and Tennessee Department of Environment and Conservation staff on December 18, 1997.

The EA indicates that seven species federal endangered or threatened species are known to occur in the vicinity of Watts Bar Nuclear Plant. In the EA, we conclude that three of these species (the bald eagle, gray bat, and snail darter) would not be affected by the proposed action. With regard to the four endangered mussel species (pink mucket, fanshell, dromedary pearlymussel, and rough pigtoe), only the pink mucket has been found in recent years within the portion of the Tennessee River that would be affected by the project. As indicated in the EA, TVA proposes to relocate endangered and other mussels out of the 150 x 150 ft. thermal impact area offshore from the discharge point to other suitable habitats within the State of Tennessee Watts Bar mollusk sanctuary. Our conclusion in the EA is that completion of the mussel relocation effort prior to the use of the discharge would not result in an adverse effect on the pink mucket or any other endangered mussel species.

We believe the information about federal endangered and threatened species presented in the EA, and our determinations that this project either will not have any effect, or will not have any adverse effect on these species fulfills our obligations under the Endangered Species Act. Please review the endangered species material in the EA and, if appropriate, indicate your concurrence with our determinations in a response to this letter.

Dr. Lee A. Barclay  
Page 2  
May 7, 1998

Thank you, again, for hosting the December 1997 meeting and for your continuing interest in this project. If you have any questions about this request, please contact TVA staff members Charles P. Nicholson (423/632-3582) or John J. Jenkinson (423/751-6903).

Sincerely,

**Original Signed By**  
Greg Askew

for

- Jon M. Loney, Manager  
Environmental Management

CPN  
CPN:BL  
Enclosure

cc: Gregory L. Askew, WT 8C-K  
C. Randall McIntosh, ADM 1V-WBN  
John J. Jenkinson, CST 17B-C  
Files, EM, WT 8C-K

Prepared by Charles P. Nicholson and John J. Jenkinson

WBN cooling - FWS ltr



Tennessee Valley Authority, Post Office Box 2000, Spring City, Tennessee 37381-2000

May 11, 1998

Mr. Philip L. Stewart, Manager  
Tennessee Department of Environment & Conservation  
Division of Water Pollution Control  
Chattanooga Field Office  
Suite 550, 540 McCallie Avenue  
Chattanooga, Tennessee 37402-2013

Dear Mr. Stewart:

WATTS BAR NUCLEAR PLANT (WBN) - SUPPLEMENTAL CONDENSER COOLING  
WATER PROJECT DRAFT ENGINEERING REPORT

Enclosed is a copy of the subject draft engineering report and draft design drawings for the Supplemental Condenser Cooling Water project. This environmental report includes the need for the proposed project, the operational impacts, the routing of the SCCW pipelines, the discharge flow calculations, and the materials list.

The enclosed information is being provided for your early review and comment. We are not requesting a permit modification at this time. We will submit our request and three copies of the engineering report and preliminary plans in subsequent correspondence, once all environmental reviews have been completed and a final decision has been made.

If you have any questions regarding this engineering report, please contact Robert W. Bond at (423) 697-4108 in Chattanooga or me at (423) 365-3325 at Watts Bar Nuclear Plant.

Sincerely,

A handwritten signature in cursive script that reads "Odis E. Hickman, Jr." followed by a period.

Odis E. Hickman, Jr.  
Radwaste/Environmental Superintendent

Enclosure

→ K Mal



# United States Department of the Interior

## FISH AND WILDLIFE SERVICE

446 Neal Street  
Cookeville, Tennessee 38501

May 26, 1998

Mr. Jon M. Loney  
Manager, Environmental Management  
Tennessee Valley Authority  
400 West Summit Hill Drive  
Knoxville, Tennessee 37902-1499

Attention: Mr. Charles P. Nicholson

Re: FWS #98-236

<b>RECEIVED</b>	
MAY 27 1998	
Doc. No. _____	
___ JML	___ MLI
___ Files	___ AHL
___	___ MDM
___	___ DWW
Environmental Management	

Dear Mr. Loney:

Thank you for your letter and enclosure of May 7, 1998, transmitting an environmental assessment for the proposed Supplemental Condenser Cooling Water Project at the Watts Bar Nuclear Plant in Rhea County, Tennessee. The Fish and Wildlife Service (Service) has reviewed the document and offers the following comments.

The Service concurs that the proposed action will not affect the endangered gray bat, or the threatened bald eagle and snail darter. We further concur that the project is not likely to adversely affect the endangered pink mucket pearly mussel, fanshell, dromedary pearly mussel, or the rough pigtoe. In view of this, we believe that the requirements of Section 7 of the Endangered Species Act are fulfilled. Obligations under Section 7 must be reconsidered, however, if: (1) new information reveals that the proposed action may affect listed species in a manner or to an extent not previously considered, (2) the proposed action is subsequently modified to include activities which were not considered during this consultation, or (3) new species are listed or critical habitat designated that might be affected by the action.

Thank you for the opportunity to comment on this action. If you have any questions, please contact Jim Widlak of my staff at 931/528-6481, ext. 202.

Sincerely,

*Douglas B. Barclay*  
 Lee A. Barclay, Ph.D.  
 Field Supervisor

Watts Bar Nuclear Plant  
 Environmental Services  
 May 28 1998

ACTION	NOTE
IP, Site Operations Plant Manager	
Business & Work Perf	
Consent, Competition	
Engg. & Materials	
Human Resources	
Site Support	
Access Resolution	
Life	
Clear Assurance	
Processing	



Tennessee Valley Authority, Post Office Box 2000, Spring City, Tennessee 37381

June 4, 1998

Mr. Philip L. Stewart, Manager  
Chattanooga Field Office  
Division of Water Pollution Control  
Suite 550, 540 McCallie Avenue  
Chattanooga, Tennessee 37402

Dear Mr. Stewart:

**WATTS BAR NUCLEAR PLANT (WBN) - PROPOSED SUPPLEMENTAL  
CONDENSER COOLING WATER (SCCW) PROJECT - VALIDATION OF THE  
CORMIX MODEL**

During telecons with the Tennessee Department of Environment & Conservation (TDEC), uncertainty regarding the accuracy with which CORMIX3 models the discharge of the SCCW to the Tennessee River was expressed. TVA has identified actual temperature measurements of river conditions from a 1974 field survey with heated discharge into the river from an operating Watts Bar Fossil Plant (WBF). As a result of the TDEC concerns, TVA decided to validate CORMIX3 by modeling WBF operation and discharge and comparing the predicted temperatures to the actual field measured survey results.

Temperature surveys were conducted in the vicinity of the WBF discharge on March 14 and 15, 1974, with the plant in operation. The results of the survey are presented in a TVA Division of Water Control Planning Report No. 9-1105, "Watts Bar Steam Plant Water Temperature Surveys." Two CORMIX model runs were made to simulate the thermal plume configuration with river and plant discharge conditions existing at the time of the field survey. Results of these runs were compared to the field measurements to determine consistency between them. The details of this comparison effort

Mr. Philip L. Stewart

Page 2

June 4, 1998

are presented in the paper, "Comparison of CORMIX Results with Field Measurements During Watts Bar Fossil Plant Operation." It is our opinion that the correlation seen between the CORMIX model and the field data validates the appropriateness of using CORMIX to model the SCCW discharge. Accordingly, TVA believes CORMIX is adequate to predict the thermal effects to the river from SCCW operation and conservatively assess the resultant environmental impact.

A copy of this paper and a reprint of the original survey are enclosed. We trust this will help to alleviate any concern you might have regarding the adequacy of CORMIX modeling of SCCW operation. Hopefully, this will give you further confidence in the validity of the results presented in the Environmental Assessment for the SCCW project.

If you have any questions please feel free to contact me at (423) 365-3843.

Sincerely,



C. Randall McIntosh  
Manager of Projects  
Watts Bar Nuclear Plant

Enclosures

cc (Enclosures):

Mr. Bruce Evans  
Division of Water Pollution Control  
Tennessee Department of Environment & Conversation  
6<sup>th</sup> Floor, L&C Annex  
401 Church Street  
Nashville, Tennessee 37243-1534

Aubrey D. McKinney, Chief  
Environmental Services Division  
Tennessee Wildlife Resources Agency  
Ellington Agricultural Center  
P.O. Box 40747  
Nashville, Tennessee 37402



Tennessee Valley Authority, Post Office Box 2000, Spring City, Tennessee 37381

June 19, 1998

Mr. Philip L. Stewart, Manager  
Chattanooga Field Office  
Division of Water Pollution Control  
Suite 550, 540 McCallie Avenue  
Chattanooga, Tennessee 37402

Dear Mr. Stewart:

**WATTS BAR NUCLEAR PLANT (WBN) - SUPPLEMENTAL CONDENSER  
COOLING WATER (SCCW) PROJECT - REVISED DRAFT  
ENVIRONMENTAL ASSESSMENT**

This letter transmits a revision of the draft Environmental Assessment (DEA). Since submittal of the initial DEA in December 1997, Tennessee Department of Environment & Conservation (TDEC) and Tennessee Wildlife Resources Agency (TWRA) personnel have raised issues in letters, meetings, and teleconferences with TVA. The DEA has been revised to provide clarification and additional information to address these issues.

The primary areas of update are as follows:

- Chemical Impacts - Sections 3.2.1 and 3.2.3 have been revised to provide more detail on the present chemical treatments for the raw water systems at WBN and why the SCCW will not affect existing treatments or result in an adverse impact from chemical discharge to the river.
- Dissolved Oxygen (DO) Impact - Sections 3.2.1 and 3.2.3 have been revised to provide information on the present oxygenation provisions at Watts Bar Hydro and why the SCCW will not adversely impact DO in the river.
- Erosion - Section 3.2.3 has been revised to explain why SCCW operation is not expected to cause any erosion to the banks of the river.
- Temperature Monitoring - Sections 3.2.3, 3.3.3.3, 3.5.3, and 3.11 have been revised to add a program to conduct seasonal monitoring of the instream river temperature during the first year of SCCW operation. The measured data will be compared to the predicted CORMIX model results.
- Fish Monitoring - Section 3.3.3 has been revised to add a program to study a limited number of crucial fish species during the first year of operation to verify there is no unexpected impact.

Mr. Philip L. Stewart

Page 2

June 19, 1998

Enclosed is the revised DEA for TDEC's information and use. So that all important issues can be fully discussed, TVA would like to schedule an interagency meeting with TEDC and others. TVA proposes the meeting be held the week of June 29 at Watts Bar Nuclear Plant. Please notify me as soon as possible of your availability to attend the proposed meeting.

If you have any questions please feel free to contact me at (423) 365-3843.

Sincerely,



C. Randall McIntosh  
Manager of Projects  
Watts Bar Nuclear Plant

Enclosures

cc (Enclosures):

Mr. Bruce Evans  
Division of Water Pollution Control  
Tennessee Department of Environment & Conversation  
6<sup>th</sup> Floor, L&C Annex  
401 Church Street  
Nashville, Tennessee 37243-1534

Aubrey D. McKinney, Chief  
Environmental Services Division  
Tennessee Wildlife Resources Agency  
Ellington Agricultural Center  
P.O. Box 40747  
Nashville, Tennessee 37402



ENVIRONMENTAL ASSISTANCE CENTER  
TENNESSEE DEPARTMENT OF ENVIRONMENT AND CONSERVATION  
540 McCALLIE AVE., SUITE 550  
CHATTANOOGA, TENNESSEE 37402-  
PHONE (423) 634-5745 STATEWIDE 1-888-891-8332 FAX (423) 634-6389

August 20, 1998

Mr. O. Erskin Hickman, Jr., Superintendent - Radwaste/Environmental Control  
Tennessee Valley Authority  
Watts Bar Nuclear Plant  
P. O. Box 2000, MOB2U  
Spring City, TN 37381

Re: Conditional Site Approval for New Outfall Construction  
Proposed Supplemental Condenser Cooling Water Project  
NPDES Permit No. TN0020168  
Tennessee River and Yellow Creek, Rhea County

Dear Mr. Hickman:

This letter is in response to the site approval request for the above referenced project. The project is described in TVA's draft Engineering Report and Construction Plans dated May 11, 1998 and supported by TVA's revised draft Environmental Assessment dated June 19, 1998. Supplemental information submitted by Mr. Randall McIntosh on July 31, 1998, described the proposed instream monitoring program. This correspondence also addresses information exchanged during the July 24, 1998 meeting in Nashville between representatives of the Division of Water Pollution Control and TVA.

**Project Summary**

TVA proposes to use the existing water inlet and bank side discharge structures at Watts Bar Fossil Plant to supply and discharge supplemental condenser cooling water (SCCW) to the nuclear plant cooling tower and main condenser. TVA understands that the Division would not consider allowing a side discharge for wastewater flows comparable to the planned project, at this or any other location, except that the proposed project would use an existing discharge structure which modeling has shown can be operated with minimal impact. The predicted result of the SCCW use is an increase in condenser performance, which will translate into approximately 64,000 megawatt hours additional annual energy output. By using the existing structures and inlet piping to the fossil plant,

Mr. Hickman  
TVA - Watts Bar Nuclear Plant  
August 20, 1998  
Page 2

TVA has designed a gravity feed system for both the intake and the discharge of the SCCW. New piping and connections will be necessary from the river water intake at the fossil plant to the No. 2 cooling tower basin, and from the No. 1 cooling tower basin overflow to the fossil plant discharge structure. A bypass line from the inlet piping to the discharge piping may be used in the winter months to reduce the possibility of instream temperature rises greater than 5.4° F.

The existing fossil plant discharge structure is a channel with an overflow weir drop structure directing flow to a side bank discharge tunnel. The discharge will be either under (maximum of eight feet) or even with the water surface depending on river stage and season. TVA used the CORMIX 3 model, an EPA endorsed model used for side bank discharges, to predict the mixing zone for the heated discharge. This model predicted that the heated discharge will descend to the river bottom immediately adjacent to the outfall structure and will rebound to the surface within a 150' x 150' impact zone. When using 24 hour averaging, TVA's model predicts that sufficient mixing will occur within 1000 feet downstream from the outfall to meet thermal water quality criteria.

### **Division Concerns**

Please note that thermal water quality criteria are established for one hour averages only. In addition, it should be pointed out that compliance with the thermal water quality criteria does not necessarily guarantee compliance with narrative water quality criteria (i.e., no harm to aquatic life).

The entire reach of the Tennessee River for ten miles downstream from the Watts Bar Dam has been designated as a mussel sanctuary by the Tennessee Wildlife Resources Agency (TWRA). The Division is concerned about the location of the fossil plant discharge structure in relation to endangered mussel beds supporting habitat for four endangered species of mussel in this river section. One such bed is located within the area of direct discharge impact. The Division believes that the side bank discharge as proposed would not be as protective of the remaining mussel beds as other types of discharge structures; e.g., multiport diffuser. If permitted, the additional risk would need to be offset in some fashion.

### **Conditional Site Approval**

The Division reviewed the SCCW project in accordance with the Department's rules for control of construction and operation of wastewater treatment and discharge facilities. We also reviewed and discussed all of the TVA supplied information concerning this project, including the special circumstances involved in the use of the side bank discharge. As a result of our review, and in consideration of the feasibility to mitigate the loss of

critical aquatic habitat and the increased risk to remaining habitat, we hereby grant site approval for this project contingent on TVA's acceptance and compliance with the following conditions:

1. Some of the threatened and endangered mussels of concern are located within the predicted impact area. The Division and TVA both have concerns about the survival of the relocated mussel population. To provide an appropriate margin of safety for this irreplaceable natural resource, the Division requests that a mussel relocation plan be developed which is acceptable to both David McKinney of TWRA and John Jenkinson of TVA prior to the commencement of project operation.
2. The Division believes that a properly designed and constructed diffuser outfall would add a safety factor to the protection of the endangered mussels and the maintenance of river water quality. However, since TVA must use the existing fossil plant discharge structure, physical controls must be added to maximize surface discharge and minimize bottom discharge impact. For example, a flow directing/energy dissipation structure may be designed and placed at the end of the discharge outfall tunnel to direct the majority of the discharge flow to the river surface, instead of allowing it to plunge directly toward the river bottom. Final engineering plans and drawings must show the proposed structure modifications.
3. The outfall structure design must insure that the predicted impact zone is not exceeded. Permanent, continuous river bottom temperature monitoring must be established on all sides of the impact zone. Since TVA proposed four temperature monitors in the July 31, 1998 document, the Division would prefer that the monitors be stationed for maximum delineation of the perimeter of the potential hot water plume. The worst ambient river conditions for thermal plume mixing will occur during the summer months (warm river temperature) and low or no river flow through Watts Bar Dam. Therefore, it is suggested that two temperature monitors be stationed equidistant along the impact zone perimeter parallel to river flow and perpendicular to discharge flow. The two remaining temperature monitors may be stationed as proposed; one upstream and one downstream of the discharge. Each temperature monitor should be located in the center of the impact zone perimeters perpendicular to river flow.

The vertical temperature study presented in the revised draft environmental assessment and the July 31, 1998 TVA proposed monitoring program must also be implemented within the first year of SCCW discharge.

To more adequately characterize discharge impact under varying river conditions and dam operation, the Division proposes that TVA determine river

bottom flow direction. A permanent, continuous monitoring station must be established, if feasible. This monitoring station should be set up in the general proximity and upstream of the discharge structure and the predicted impact zone.

4. As part of this project, TVA shall provide measures to enhance the available habitat for the mussel population in this stretch of the river. The Division is of the opinion that habitat improvement may be partially accomplished through improving conditions conducive to species-specific juvenile mussel recruitment. We propose to include in the Watts Bar Nuclear Plant NPDES permit a requirement that TVA must submit a habitat enhancement proposal for review and approval by TWRA and the Division within six months of commencement of the SCCW project operation. This proposal should include structural and/or administrative controls which have shown either experimental or proven benefits to mussel habitat enhancement.
5. Monitoring criteria for this outfall will be established as part of the NPDES permit. These criteria will include at a minimum continuous flow and temperature measurement, as well as chemical and biological sampling. Provisions for collecting these measurements and samples must be implemented during construction of the project. General river monitoring, such as fisheries monitoring, will also be included in the permit.

This conditional site approval should be used for planning purposes only. It does not grant approval to construct or discharge from the proposed outfall. TVA should not construe this conditional site approval to represent a certainty that an NPDES permit will be issued for this proposed discharge as contemplated by the TVA documents thus far reviewed by the Division. Opportunity for public participation must be made during the permit application process. However, if additional information regarding adverse water quality and habitat impacts does not emerge during the draft permit and public participation steps, it is likely that an NPDES permit can be issued for this discharge.

#### **Further Steps for Final Project Approval**

As stated during the July 24, 1998 meeting, the Division would like to include this project as part of the current Watts Bar Nuclear Plant permit renewal application. Therefore, the next step for TVA is to submit a permit modification request associated with the SCCW project to the Chattanooga Environmental Assistance Center for review and permit inclusion. The modification request should provide a general conceptual approach for the conditions outlined above. A final copy of the Environmental Assessment and two final copies of the Engineering Report and Plans should be included in this request package for


Mr. Hickman  
TVA - Watts Bar Nuclear Plant  
August 20, 1998  
Page 5

review and appropriate fee assessment. The final Engineering Report and Plans should include the instrumentation for continuous monitoring parameters specified in the NPDES permit. After review and acceptance, the Engineering Report and Plans will be stamped approved by the Division. One copy of the Engineering Report and Plans will be returned to TVA to be maintained at the construction site.

Additionally, it should be noted that the Division has not yet received the previously requested revised and/or amended NPDES application forms, along with a comprehensive flow diagram. Copies of this information may also be sent to our Permit Section in Nashville to expedite matters.

The Division appreciates TVA's willingness to work towards an environmentally acceptable project. If you have any questions regarding the above site approval or project conditions, please call me or Cynthia Anderson at (423)634-5712.

Sincerely,



Philip L. Stewart, P.E.  
Manager  
Division of Water Pollution Control


pls\cma\permit\tva\wbn\sccwlet

✓ cc: Randall McIntosh, Senior Project Manager, TVA - Watts Bar Nuclear Plant  
cc: DWPC, Nashville, Director's Office, c/o Paul Davis, P.E.  
cc: DWPC, Nashville, Permit Section, c/o Saya Qualls, P.E.  
cc: TWRA, Nashville, c/o David McKinney

**TENNESSEE VALLEY AUTHORITY**

**WATTS BAR NUCLEAR PLANT  
NPDES PERMIT NO. TN0020168  
316(b) MONITORING PROGRAM**

**FISH IMPINGEMENT AT WATTS BAR NUCLEAR  
PLANT SUPPLEMENTAL CONDENSER  
COOLING WATER INTAKE STRUCTURE  
DURING 2005 THROUGH 2007**



**ENVIRONMENTAL STEWARDSHIP AND POLICY**

**2007**

## TABLE OF CONTENTS

List of Tables .....	i
List of Figures .....	ii
List of Acronyms .....	ii
Introduction .....	1
Plant Description .....	1
Supplemental Condenser Cooling Water System Description .....	1
Methods .....	2
Moribund/Dead Fish .....	2
Data Analysis .....	3
Results and Discussion .....	3
Summary and Conclusions .....	5
References .....	6

## LIST OF TABLES

Table 1. List of Fish Species by Family, Scientific, and Common Name Including Numbers Collected in Impingement Samples During 2005-2007 at TVA's Watts Bar Nuclear Plant. ....	7
Table 2. Estimated Annual Numbers, Biomass and Percent Composition of Fish Impinged by Species at Watts Bar Nuclear Plant During 2005-2007. ....	8
Table 3. Numbers of Fish Impinged at Watts Bar Nuclear Plant by Month and Percent of Annual Total During Year-One, Year-Two, and for both Years Combined. ....	9
Table 4. Total Numbers of Fish Estimated Impinged by Year at Watts Bar Nuclear Plant and Numbers Following Application of Equivalent Adult and Production Foregone Models. ....	10
Table 5. Percent Composition (By Number and After EA and PF Models Applied) of Major Species of Fish Impinged at TVA's Watts Bar Nuclear Plant During 1974-1975 and 2005-2007.....	10

## LIST OF FIGURES

- Figure 1. Aerial photograph of Watts Bar Nuclear Plant, displaying the SCCW intake structure upstream of Watts Bar Dam and the downstream SCCW discharge into Chickamauga Reservoir. .... 11
- Figure 2. Comparison of estimated weekly fish impingement at TVA's Watts Bar Nuclear Plant during historical and recent monitoring periods. Data from 1974-1975 was collected from Watts Bar Fossil Plant. .... 12

## LIST OF ACRONYMS

CCW	Condenser Cooling Water
CWA	Clean Water Act
EA	Equivalent Adult
EPA	Environmental Protection Agency
EPRI	Formerly the Electric Power Research Institute
MW	Megawatts
NPDES	National Pollutant discharge Elimination System
PF	Production Foregone
RFAI	Reservoir Fisheries Assemblage Index
SCCW	Supplemental Condenser Cooling Water
TRK	Tennessee River Kilometer
TRM	Tennessee River Mile
TVA	Tennessee Valley Authority
WBF	Watts Bar Fossil Plant
WBH	Watts Bar Hydroelectric Plant
WBN	Watts Bar Nuclear Plant

## **Introduction**

Watts Bar Nuclear Plant (WBN) is located on the west bank of Chickamauga Reservoir at Tennessee River Kilometer (TRK) 849.7 (Tennessee River Mile [TRM] 528) and is situated approximately 3.2 km (2 miles) downstream of Watts Bar Hydroelectric Plant (WBH) and 1.6 km (1 m) downstream of the decommissioned Watts Bar Fossil Plant (WBF).

WBN withdraws supplemental condenser cooling water (SCCW) from the Tennessee River and is subject to compliance with the Tennessee Water Quality Act and the federal Clean Water Act (CWA). Section 316(b) of the CWA requires the location, design, construction, and capacity of cooling water intake structures to reflect the best technology available for minimizing adverse impacts. Impingement mortality is a component of 316(b) and is defined as the condition in which fish and/or shellfish are trapped or impinged against an intake screen. The WBN SCCW system, designed to augment the performance of the cooling water system for WBN, became operational July 19, 1999. The SCCW withdraws cooling water from the forebay of Watts Bar Reservoir and operates under the National Pollutant Discharge Elimination System (NPDES) Permit for WBN. The SCCW intake structure formerly provided condenser cooling water (CCW) for the operation of WBF, but currently provides about 50% less flow for the WBN SCCW operation.

This report presents impingement data collected by the Tennessee Valley Authority (TVA) from the WBN SCCW intake screens during 2005-2007, with comparisons to historical data collected during 1974-1975 for WBF and 1999-2000 after the WBN SCCW initially began operation.

## **Plant Description**

WBN began commercial operation on May 27, 1996. This one-unit nuclear generating plant is designed for an electrical output of about 1270 megawatts (MW).

The plant is operated in closed cycle cooling mode, using one of the two cooling towers for heat dissipation. Makeup water and other water supply requirements are obtained from the intake channel and pumping station at TRK 849.7 (TRM 528).

### **Supplemental Condenser Cooling Water System Description**

The WBN SCCW is designed to provide between 7.3 and 8.5 m<sup>3</sup>/s (115,000 and 135,000 gallons per minute), depending on the pool elevation in from Watts Bar Reservoir. The CCW system for WBN uses natural draft cooling towers to reject waste heat from the steam cycle. The capability of the towers to cool the CCW is significantly affected by site meteorological conditions. As the ambient temperatures become higher, the temperature of the water from the cooling tower increases. This warmer water from the towers results in a decrease in the net MW output of WBN due to an increase in the condenser back-pressure above the optimum design. Reducing the temperature of the water that flows to the main condenser improves efficiency and output. This increased capacity occurs predominately in the warm weather months of May through August when the temperatures are warmest.

Water for the SCCW enters through the WBF intake screen house on Watts Bar Reservoir that is adjacent to the west upstream side of WBH. The water enters the old WBF screen house through three functioning intake sluice gates with traveling water screens. The water flows approximately 975 m (3,200 ft) to WBF through two 198 cm

(78 in) diameter concrete pipes. A new 229 cm (90 in) diameter reinforced concrete pipe was tied into the existing pipes approximately 61 m (200 ft) north of the WBF switchyard to take the water to WBN. This pipe runs along the east side of WBF, skirting the side of the existing ash ponds and the coal yard on the fossil plant site. After leaving the WBF property, the pipe traverses the northeast portion of the WBN site to a new inlet structure at the Unit 2 tower. The SCCW is conveyed through the Unit 2 tower basin to the Unit 1 tower discharge flume. Here it mixes with the warmer water from the Unit 1 tower prior to its being pumped to the inlet of the WBN Unit 1 main condenser.

Water from the SCCW system is discharged through the old WBF discharge structure located on the Tennessee River approximately 1.8 km (1.1 m) upstream of the nuclear plant intake. It consists of an open discharge canal, an overflow weir drop structure, and a subsurface discharge tunnel and is currently authorized under the WBN NPDES permit as Outfall 113.

## **Methods**

Weekly impingement monitoring began on August 16, 2005, and samples were collected through August 7, 2007. To simplify comparisons in this report, data from August 16, 2005, through August 9, 2006, will be referred to as Year-One, and from August 16, 2006, through August 7, 2007, as Year-Two. To collect each sample, intake screens were rotated and washed on a prearranged schedule by the plant Assistant Unit Operator to remove all fish and debris. After 24 hours, screens were again rotated and washed with a TVA Aquatic Monitoring and Management crew on site. Fish and debris were collected from the sluice pipe with dip nets where the monitoring crew removed and processed the sample. Fish were sorted from debris, identified, separated into 25 mm (1 in) length classes, enumerated, and weighed. Data were recorded by one member of the crew and checked and verified (signed) by the other for quality control. Quality Assurance/Quality Control procedures for impingement sampling (TVA 2004) were followed to ensure samples were comparable with historical impingement mortality data.

Historical impingement sampling was initially conducted for WBF at this intake by TVA during August 1974 through April 1975 (TVA 1976). During the 10-month sampling period, samples were collected weekly and consisted of thirty-three 24-hr samples.

Following completion of the WBN SCCW project, impingement monitoring was conducted from August 31, 1999, through September 29, 1999, and between March 7, 2000, and April 26, 2000 (Baxter et al., 2001). Impingement samples were collected on five days during each of these two periods. These periods were selected to correspond with peak impingement observed during historical monitoring for WBF.

### **Moribund/Dead Fish**

The majority of fish collected from a 24-hour screen wash were usually dead when processed. Incidental numbers of fish which appeared to have been dead for more than 24 hours (i.e., exhibiting pale gills, cloudy eyes, fungus, or partial decomposition) were not included in the sample. Also, during winter, threadfin shad occasionally suffer die-offs or stress from cold-shock and are often impinged after death or in a moribund state (Griffith and Tomljanovich 1975, Griffith 1978). If these die-off incidents were observed, they were documented to specify that either all, or a portion of impinged threadfin shad

collected during the sample period were due to cold-shock and may not have been impinged otherwise. Any fish collected alive were returned to the reservoir after processing.

### **Data Analysis**

Impingement data from weekly 24-hr samples were extrapolated for each week to provide estimates of total fish impinged by week and an estimate for each year of this study. In rare situations when less than a 24-hr sample was possible, data were normalized to 24 hours. Historical data were collected weekly during 1974-1975 at WBF and weekly estimates were extrapolated accordingly. Impingement data collected during September 1999 and March through April 2000 at WBN was also extrapolated to obtain estimates of annual totals. These annual estimates did not represent a continuous year of monitoring, therefore comparisons of the 1974-1975 and current impingement data were used for analysis.

To facilitate the implementation of and compliance with the Environmental Protection Agency's (EPA) regulations for Section 316(b) of the CWA prior to its suspension by the EPA, fish lost to impingement were evaluated by extrapolating the losses to equivalent reductions of adult fish, or of biomass production available to predators in the case of forage species. EPRI (formerly the Electric Power Research Institute) has identified two models for extrapolating losses of fish eggs, larvae, and juveniles at intake structures to numbers or production of older fish (Barnhouse 2004). The Equivalent Adult (EA) model quantifies entrainment and impingement losses in terms of the number of fish that would have survived to a given future age. The Production Foregone (PF) model is applied to forage fish species to quantify the loss from entrainment and impingement in terms of potential forage available for consumption by predators. These models require site-specific data on the distribution and abundance of fish populations vulnerable to entrainment and impingement. TVA in turn used these models to determine the "biological liability" of the SCCW intake structure.

### **Results and Discussion**

Numbers of fish collected by year and by species are presented in Table 1. During Year-One, 770,217 fish were collected and 30,202 fish were collected during Year-Two. Threadfin shad comprised 99% of the total number of fish impinged. The number of species collected was 23 species during Year-One and 16 species during Year-Two, respectively.

Estimated total numbers impinged, extrapolated from weekly samples, was 5,391,526 during Year-One and 211,414 during Year-Two (Table 2). The rate of impingement was highest during January through March during Year-One (Table 3 and Figure 2). Similarly, Year-Two impingement rates were highest during these months, as well as in August (Table 3). Estimated impingement during Year-One was 25.5 times greater than Year-Two, which was due to impingement of 28 times more threadfin shad during Year-One (Table 2).

The historical annual impingement estimate was much lower than that observed in the current study (Table 4). Although shad were the dominant species collected in historical samples, they comprised a smaller percentage overall in the historical sample's composition, compared to the current study. Impingement sampling at WBF during 1974-1975, resulted in the collection of 2,130 fish comprised of 59% threadfin shad, 12%

bluegill, 13% freshwater drum, and 8% skipjack herring (Table 5). The estimated total annual impingement (extrapolated) was 16,421 fish with 40% impinged during March and April, and September. Forty-four percent of annual impingement occurred during these two periods.

After the WBN SCCW became operational in 1999, additional impingement monitoring was conducted to verify if impingement losses remained minimal. Sampling peak impingement periods (September, March, and April) found during the 1999-2000 study were similar to impingement patterns documented during the 1974-1975 WBF impingement study (Baxter et al., 2001).

Threadfin and/or gizzard shad typically comprise over 90% of fish impinged on cooling-water intake screens of thermal power stations in the Southeastern United States (EPRI, 2005). They also comprise an average of 35-56% of total fish biomass where they occur (Jenkins 1967). Threadfin shad have a high fecundity rate, move in large schools, and are intolerant to cold temperatures, often resulting in high mortality rates in the winter. These traits are probably major contributing factors to the high impingement rates observed at WBN since peak impingement during Year-One and Year-Two occurred during January through March (Table 3). A recent study by Fost (2006) indicated that cold-stressed threadfin and gizzard shad can be classified as either impaired or moribund. Impaired shad could recover if environmental conditions improved and would therefore not die if not impinged. Moribund fish on the other hand, are assumed to not be able to recover and die regardless of impingement. However, TVA did not have temperature data near the SCCW intake; therefore accurate correlations between peak impingement and water temperatures cannot be made. TVA installed permanent temperature monitors during October 2007 in the forebay of Watts Bar Reservoir, so these data will be available if future impingement studies are conducted.

Application of the EA and PF models to the total numbers estimated impinged resulted in the reduced numbers (Table 4) of fish which would have been expected to survive to either harvestable (EA) size/age or to provide forage (PF). This reduced number is considered the "biological liability" resulting from the WBN SCCW impingement. A comparison of historic and current percent of species composition by number and biological liability of fish impinged is shown in Table 4. The numbers of fish representing WBN's biological liability for Year-One and Year-Two were 125,878 and 5,584, respectively, and the number estimated for 1974-1975 was almost identical to Year-Two (Table 5).

Resident fish communities have been sampled upstream in the forebay of Watts Bar Reservoir (TRK 854.6 [TRM 531]) and downstream in the tailwater below WBH (TRK 851.3 [TRM 529]) since 1993 as part of TVA's Vital Signs monitoring program. Resulting data were analyzed using a multi-metric Reservoir Fisheries Assemblage Index (RFAI) (Hickman and Brown 2002) to rate the overall health and condition of the fish community at these sampling locations. Fish communities at both sites upstream and downstream from WBN have averaged a rating of "Good" during 1993-2006, indicating that neither WBN or the WBN SCCW is adversely impacting the resident fish community (Baxter and Simmons 2007).

## **Summary and Conclusions**

Estimated fish impingement at WBN SCCW during 2005-2007 was much higher than estimated from samples collected during 1975-1975. Threadfin shad have been the dominant species impinged during all sampling periods and comprised 99% of the fish impinged during the current study. Peak impingement periods were during late winter and may be related to cold-shock, which would have made shad more vulnerable to impingement.

RFAI scores for sites just upstream and downstream of WBN have averaged a rating of "Good" during 1993-2006, indicating that the WBN SCCW intake is not adversely impacting the fish community in the vicinity of WBN.

## References

- Barnthouse, L. W. 2004. Extrapolating Impingement and Entrainment Losses to Equivalent Adults and Production Foregone. EPRI Report 1008471, July 2004.
- Baxter, D.S., K. D. Gardner, and G.D. Hickman. 2001. Watts Bar Nuclear Plant Supplemental Condenser Cooling Water System Fish Monitoring Program. Tennessee Valley Authority, Knoxville, Tennessee. 40 pp.
- Baxter, D. S. and J. W. Simmons. 2007. Biological Monitoring of the Tennessee River Near Watts Bar Nuclear Plant Discharge, 2006. Tennessee Valley Authority, Aquatic Monitoring and Management, Knoxville, Tennessee. 36pp.
- EPRI. 2005. Large-Scale Natural Mortality Events in Clupeid Fishes: A Literature Review. Palo Alto, CA. EPRI Report.
- Fost, B. A. 2006. Physiological & Behavioral Indicators of Shad Susceptibility to Impingement at Water Intakes. M. S. Thesis, University of Tennessee, Knoxville. 45pp.
- Griffith, J. S. and D. A. Tomljanovich. 1975. Susceptibility of threadfin shad to impingement. Proceedings of the 29<sup>th</sup> Annual Conference of the Southeastern Association of Game and Fish Commissioners. 223-234.
- Griffith, J. S. 1978. Effects of low temperature on the survival and behavior of threadfin shad, *Dorosoma petenense*. Transactions of the American Fisheries Society. 107(1): 63-70.
- Hickman, G. and Brown, M. L. 2002. Proposed methods and endpoints for defining and assessing adverse environmental impact (AEI) on fish communities/populations in the Tennessee River reservoirs. In Defining and Assessing Adverse Environmental Impact Symposium 2001. *TheScientificWorldJOURNAL* 2(S1), 204-218.
- Jenkins, R. M. 1967. The influence of some environmental factors on standing crop and harvest of fishes in U. S. reservoirs. Pages 298-321 in Reservoir fishery resources symposium. Southern Div. Am. Fish. Soc., University of Georgia, Athens.
- Tennessee Valley Authority. 1976. Impingement by Watts Bar Steam Plant, 1975, and assessment of the impact on the fisheries resource of Watts Bar Reservoir. Fisheries and Waterfowl Resources Branch, Division of Forestry, Fisheries, and Wildlife Development, Norris, TN 10 pp.
- Tennessee Valley Authority. 2004. Impingement Counts. Quality Assurance Procedure No. RSO&E-BR-23.11, Rev 1. TVA River Systems Operation and Environment, Aquatic Monitoring and Management Knoxville TN. 11 pp.

**Table 1. List of Fish Species by Family, Scientific, and Common Name Including Numbers Collected in Impingement Samples During 2005-2007 at TVA's Watts Bar Nuclear Plant.**

Family	Scientific Name	Common Name	Total Number Impinged	
			Year-One	Year-Two
<b>Clupeidae</b>	<i>Dorosoma cepedianum</i>	Gizzard shad	1,086	2,957
	<i>Alosa chrysochloris</i>	Skipjack herring	1	1
	<i>Dorosoma petenense</i>	Threadfin shad	768,777	27,164
<b>Cyprinidae</b>	<i>Pimephales notatus</i>	Bluntnose minnow	0	2
	<i>Pimephales vigilax</i>	Bullhead minnow	1	7
	<i>Cyprinella spiloptera</i>	Spotfin shiner	0	1
<b>Ictaluridae</b>	<i>Ictalurus furcatus</i>	Blue catfish	4	0
	<i>Ictalurus punctatus</i>	Channel catfish	12	3
	<i>Pylodictis olivaris</i>	Flathead catfish	0	1
<b>Atherinidae</b>	<i>Labidesthes sicculus</i>	Brook silverside	2	1
<b>Moronidae</b>	<i>Morone saxatilis</i>	Striped bass	1	0
	<i>Morone chrysops</i>	White bass	2	1
	<i>Morone mississippiensis</i>	Yellow bass	18	10
<b>Centrarchidae</b>	<i>Lepomis macrochirus</i>	Bluegill	229	48
	<i>Lepomis gulosus</i>	Warmouth	1	0
	<i>Lepomis megalotis</i>	Longear sunfish	5	0
	<i>Lepomis auritus</i>	Redbreast sunfish	5	0
	<i>Lepomis microlophus</i>	Redear sunfish	6	0
	<i>Micropterus punctulatus</i>	Spotted bass	2	0
	<i>Micropterus salmoides</i>	Largemouth bass	17	1
	<i>Pomoxis annularis</i>	White crappie	3	2
	<i>Pomoxis nigromaculatus</i>	Black crappie	11	0
<b>Percidae</b>	<i>Percina aurantiaca</i>	Tangerine darter	1	0
	<i>Percina caprodes</i>	Logperch	14	1
	<i>Perca flavescens</i>	Yellow perch	2	0
<b>Sciaenidae</b>	<i>Aplodinotus grunniens</i>	Freshwater drum	18	2
<b>Total number of fish</b>			<b>770,218</b>	<b>30,202</b>
<b>Total number of species</b>			<b>23</b>	<b>16</b>

**Table 2. Estimated Annual Numbers, Biomass and Percent Composition of Fish Impinged by Species at Watts Bar Nuclear Plant During 2005-2007.**

Species	Estimated Number			Estimated Biomass (g)			Percent Composition by Number
	Year-One	Year-Two	Average	Year-One	Year-Two	Average	
Threadfin shad	5,381,439	190,148	2,785,794	9,810,374	266,280	5,038,327	99
Gizzard shad	7,602	20,699	14,151	359,296	70,245	214,771	T
Bluegill	1,603	336	970	40,138	8,953	24,546	T
Yellow bass	126	70	98	4,445	1,064	2,755	T
Freshwater drum	126	14	70	10,381	483	5,432	T
Largemouth bass	119	7	63	43,302	35	21,669	T
Channel catfish	84	21	53	987	266	627	T
Logperch	98	7	53	1,491	84	788	T
Black crappie	77	0	39	23,352	0	11,676	T
Bullhead minnow	7	49	28	14	70	42	T
Redear sunfish	42	0	21	8,512	0	4,256	T
Longear sunfish	35	0	18	4,858	0	2,429	T
Redbreast sunfish	35	0	18	2,555	0	1,278	T
White crappie	21	14	18	1,295	35	665	T
Blue catfish	28	0	14	3,472	0	1,736	T
Brook silverside	14	7	11	56	21	39	T
White bass	14	7	11	3,654	1,393	2,524	T
Bluntnose minnow	0	14	7	0	21	11	T
Skipjack herring	7	7	7	1,281	2,590	1,936	T
Spotted bass	14	0	7	84	0	42	T
Yellow perch	14	0	7	1,183	0	592	T
Flathead catfish	0	7	4	0	1,344	672	T
Spotfin shiner	0	7	4	0	21	11	T
Striped bass	7	0	4	35	0	18	T
Tangerine darter	7	0	4	98	0	49	T
Warmouth	7	0	4	1,127	0	564	T
<b>Totals</b>	<b>5,391,526</b>	<b>211,414</b>	<b>2,801,470</b>	<b>10,321,990</b>	<b>352,905</b>	<b>5,337,448</b>	

T = Trace < one percent

**Table 3. Numbers of Fish Impinged at Watts Bar Nuclear Plant by Month and Percent of Annual Total During Year-One, Year-Two, and for both Years Combined.**

Month	Total Number of Fish Impinged Year-One	Percent of Annual Total	Total Number of Fish Impinged Year-Two	Percent of Annual Total	Years-One and Two Combined	Percent of Two-Year Total
Jan	95,727	12	1,460	5	97,187	12
Feb	573,722	74	19,442	64	593,164	74
Mar	98,149	13	5,990	20	104,139	13
Apr	799	0	27	0	826	0
May	560	0	23	0	583	0
Jun	4	0	4	0	8	0
Jul	482	0	187	1	669	0
Aug	160	0	2,993	10	3,153	0
Sep	344	0	18	0	362	0
Oct	135	0	0	0	135	0
Nov	72	0	27	0	99	0
Dec	63	0	31	0	94	0
<b>Total</b>	<b>770,217</b>		<b>30,202</b>		<b>800,419</b>	

**Table 4. Total Numbers of Fish Estimated Impinged by Year at Watts Bar Nuclear Plant and Numbers Following Application of Equivalent Adult and Production Foregone Models.**

	1974-1975	2005-2006	2006-2007
<b>Extrapolated Annual Number Impinged</b>	17,675	5,391,526	211,414
<b>Number for after EA &amp; PF Reduction</b>	5,648	125,878	5,584

**Table 5. Percent Composition (By Number and After EA and PF Models Applied) of Major Species of Fish Impinged at TVA's Watts Bar Nuclear Plant During 1974-1975 and 2005-2007.**

<b>Species Composition</b>	<b>1974-1975</b>		<b>2005-2006</b>		<b>2006-2007</b>	
	<b>% by Number</b>	<b>% after PA and EF</b>	<b>% by Number</b>	<b>% after PA and EF</b>	<b>% by Number</b>	<b>% after PA and EF</b>
Threadfin shad	59	33	99.9	99.9	98.6	97.0
Gizzard shad	2	1	0.1	0.1	0.8	0.8
Bluegill	12	27	-	-	-	1.3
Freshwater drum	13	15	-	-	-	-
Skipjack herring	8	4	-	-	-	-
White bass	2	9	-	-	-	-
White crappie	1	3	-	-	-	-
Channel catfish	1	2	-	-	-	-
<b>Total</b>	<b>98</b>	<b>94</b>	<b>100</b>	<b>100</b>	<b>99</b>	<b>99</b>

Dash denotes not a major species during that year.



**Figure 1. Aerial photograph of Watts Bar Nuclear Plant, displaying the SCCW intake structure upstream of Watts Bar Dam and the downstream SCCW discharge into Chickamauga Reservoir.**




Figure 2. Comparison of estimated weekly fish impingement at TVA's Watts Bar Nuclear Plant during historical and recent monitoring periods. Data from 1974-1975 was collected from Watts Bar Fossil Plant.

Enclosure 2

Listing of Open Actions Required for Licensing

1. TVA will provide a WBN Unit 2 SAMA analysis consistent in scope and content with the SAMA analyses provided in support of recent license renewal applications. The WBN Unit 2 SAMA analysis will consider risks from both internal and external events. TVA will submit the WBN Unit 2 SAMA analysis by January 30, 2009.

# ENCLOSURE 3

## FINAL ENVIRONMENTAL STATEMENT RELATED TO THE OPERATION OF WATTS BAR NUCLEAR PLANT, UNITS 1 AND 2 (NUREG-0498, SUPPLEMENT 1 - 04/1995) REVIEW MATRIX

1995 NRC FES SECTION	TITLE	*	ADDITIONAL INFORMATION
1 . 0 . 0	Introduction	U	Update was provided in 1.2 (Background) of the TVA FSEIS (June 2007).
1 . 1 . 0	History	U	Update was provided in 1.2 (Background) of the TVA FSEIS (June 2007). Figure 1-2 (Unit 2 Site Plan) shows the location of all buildings and facilities currently on site and the location of proposed new buildings. Although the exact location of the new facilities is not firm, the area to be disturbed is not expected to change.
1 . 2 . 0	Environmental Approvals and Consultations	U	Update was provided in 1.5 (Environmental Permits and Approvals) of the TVA FSEIS (June 2007). The operation of WBN Unit 2 may require that some of these permits be amended and additional approvals obtained.
1 . 3 . 0	References	U	References were updated in 6.1 (Literature Cited) of the TVA FSEIS (June 2007).
2 . 0 . 0	The Site	NA	Section header
2 . 1 . 0	Regional Demography	U	Update was provided in 3.8.1 (Population) of the TVA SEIS (June 2007).
2 . 1 . 1	Population Changes	U	Population changes were updated to the 2005 estimates in 3.8.1 (Population) of the TVA FSEIS (June 2007).
2 . 1 . 2	Changes in Regional Socioeconomic Characteristics	U	Update was provided in 3.8.2 (Employment and Income), 3.8.3 (Low-Income and Minority Populations), 3.8.4 (Housing and Community Services), 3.8.5 (Schools), 3.8.6 (Land Use), 3.8.7 (Local Government Revenues), and 3.8.8 (Cumulative Effects) of the TVA FSEIS (June 2007).
2 . 2 . 0	Water Use	O	No change has been made in basic plant water use since NUREG-0498, Supplement 1 (April 1995).  The Supplemental Condenser Cooling Water (SCCW) system was placed in service in 1999 (Watts Bar Nuclear Plant SCCW Project EA, August 1998).  SCCW water use for 2-unit operation is discussed in 2.2 of the TVA FSEIS (June 2007). Additionally, see response to NRC Request 1 of Enclosure 1 of TVA letter to NRC, "Watts Bar Nuclear Plant (WBN) - Unit 2 - Final Supplemental Environmental Impact Statement - Request For Additional Information (TAC MD8203)" dated July 2, 2008.

1995 NRC FES SECTION	TITLE	*	ADDITIONAL INFORMATION
2 . 2 . 1	Regional Water Use	<b>U</b>	TVA's Reservoir Operations Study Final Programmatic EIS (ROS PEIS) (May 2004) updated regional water use. This document is incorporated, by reference, into 1.3 (Other Pertinent Environmental Reviews and Tiering) of the TVA FSEIS (June 2007).  4.5 of the ROS PEIS covers water supply availability, delivery cost, and water quality. 5.5 covers the potential affects of the alternatives on water supply issues. 6.2.3 addresses cumulative impacts on the water supply from all TVA activities in the Tennessee River watershed. Conclusion is that water supply is ok under any alternative that could have been chosen.
2 . 2 . 2	Surface Water Hydrology	<b>NC</b>	No changes have been made since NUREG-0498, Supplement 1 (April 1995).
2 . 2 . 3	Water Quality	<b>U</b>	Update was provided in 3.1 (Water Quality) of the TVA FSEIS (June 2007).  TVA's Reservoir Operations Study Final Programmatic EIS (ROS PEIS) (May 2004) provided additional information about water quality in the Tennessee River at Watts Bar Nuclear Plant. This document is incorporated, by reference, into 1.3 (Other Pertinent Environmental Reviews and Tiering) of the TVA FSEIS (June 2007).
2 . 3 . 0	Meteorology	<b>U</b>	Update was provided in 3.11 (Climatology and Meteorology) of the TVA FSEIS (June 2007).
2 . 3 . 1	Regional Climate	<b>U</b>	Update was provided in 3.11 (Climatology and Meteorology) of the TVA FSEIS (June 2007).
2 . 3 . 2	Severe Weather	<b>U</b>	Update was provided in 3.11 (Climatology and Meteorology) of the TVA FSEIS (June 2007).
2 . 3 . 3	Local Meteorological Conditions	<b>U</b>	Update was provided in 3.11 (Climatology and Meteorology) of the TVA FSEIS (June 2007).
2 . 3 . 4	Atmospheric Dispersion	<b>U</b>	Update was provided in 3.11 (Climatology and Meteorology) and 3.13 (Radiological Effects) of the TVA FSEIS (June 2007).
2 . 4 . 0	Ecology	<b>NA</b>	Section header
2 . 4 . 1	Terrestrial Ecology	<b>U</b>	Update for terrestrial ecology was provided in 3.3.1 (Plants) and 3.3.2 (Wildlife) of the TVA FSEIS (June 2007). Update for T&E terrestrial species is provided in 3.4.2 (Plants) and 3.4.3 (Wildlife). No new transmission lines are planned. The area of potential affect was limited to the existing site which is illustrated in Figure 1-2 (Unit 2 Site Plan).
2 . 4 . 2	Aquatic Ecology	<b>U</b>	Updates were provided in 3.2 (Aquatic Ecology) and 3.4.1 (Threatened and Endangered Species / Aquatic Animals) of the TVA SEIS (June 2007).
2 . 5 . 0	Background Radiological Characteristics	<b>O</b>	The latest radiological background data can be found in the 2007 Annual Radiological Environmental Monitoring Report (ADAMS Accession Numbers ML081430028, 29, and 30).
2 . 6 . 0	Historical and Archeological Sites	<b>U</b>	Update was provided in 3.7 (Cultural Resources) of the TVA FSEIS (June 2007).

1995 NRC FES SECTION	TITLE	*	ADDITIONAL INFORMATION
2 . 7 . 0	Geology and Seismology	U	<p>Seismology was updated in 3.10 (Seismic Effects) of the TVA SEIS (June 2007). Since no major new construction is proposed for completion of Watts Bar Nuclear Plant Unit 2, geology was not addressed further in the TVA FSEIS (June 2007).</p> <p>Table submitted with TVA letter dated June 16, 2008, "Watts Bar Nuclear Plant (WBN) - Unit 2 - Regulatory Framework for the Completion of Construction and Licensing for Unit 2 - Revision 1 (TAC NO. MD6311)" noted that Seismology was "Approved for both units in SER." Applicable SER portion was 2.5.2.</p>
2 . 8 . 0	References	U	References were updated in 6.1 (Literature Cited) of the TVA FSEIS (June 2007).
3 . 0 . 0	The Plant	NA	Section header
3 . 1 . 0	Plant Water Use	O	<p>Update was provided in 2.2.1 (Plant Water Use) of the TVA FSEIS (June 2007). This discusses the addition of the Supplemental Condenser Cooling Water (SCCW) system in 1999 (Watts Bar Nuclear Plant SCCW Project EA, August 1998). Additionally, see response to NRC Request 1 of Enclosure 1 of TVA letter to NRC, "Watts Bar Nuclear Plant (WBN) - Unit 2 - Final Supplemental Environmental Impact Statement - Request For Additional Information (TAC MD8203)" dated July 2, 2008.</p> <p>DOE's FEIS for Production of Tritium in a Commercial Light Water Reactor, March 1999 (Tritium EIS) also updated plant water use. TVA adopted this document in May 2000. NRC approved production of tritium at Watts Bar Unit 1 via amendment 40 (ADAMS accession number ML022540925). Production of tritium is not part of the construction completion and licensing of WBN Unit 2.</p>
3 . 2 . 0	Heat Dissipation Systems	O	<p>Update was provided in 2.2.2 (Heat Dissipation System) of the TVA FSEIS (June 2007). This includes a description of the Condenser Cooling Water (CCW) system and the Supplemental Condenser Cooling Water (SCCW) system. Figure 2-1 (Components of Watts Bar Nuclear Plant Heat Dissipation System) shows the components of the WBNP heat dissipation system. Figure 2-2 (Schematic of Current Configuration of Watts Bar Nuclear Plant Supplemental Condenser Cooling Water System) provides a schematic of the SCCW system.</p> <p>The SCCW system was the subject of the Watts Bar Nuclear Plant SCCW Project EA (August 1998) in which the system is described in detail. Additionally, see response to NRC Request 1 of Enclosure 1 of TVA letter to NRC, "Watts Bar Nuclear Plant (WBN) - Unit 2 - Final Supplemental Environmental Impact Statement - Request For Additional Information (TAC MD8203)" dated July 2, 2008.</p>
3 . 3 . 0	Radioactive Waste Treatment System	U	Update was provided in 3.14 (Radioactive Waste) of the TVA FSEIS (June 2007).
3 . 4 . 0	Chemical, Sanitary, and Other Waste Treatment	U	Update was provided in 3.14 (Radioactive Waste) of the TVA FSEIS (June 2007).

1995 NRC FES SECTION	TITLE	*	ADDITIONAL INFORMATION
3 . 5 . 0	Power Transmission System	U	Update was provided in 2.3 (Other Activities) of the TVA FSEIS (June 2007). No new transmission lines are proposed. 2.3 discusses the potential need for a new on-site power supply line. Categorical Exclusion Checklist (CEC) 18271, Watts Bar Nuclear Plant 500-kV Switchyard Startup Unit 2 - Project No. Z0172 - Work Order 62189 was initiated April 28, 2008, to address this on-site power line.
3 . 6 . 0	References	U	References were updated in 6.1 (Literature Cited) of the TVA FSEIS (June 2007).
4 . 0 . 0	Environmental Effects of Site Preparation and Transmission Facilities Construction	NA	Section header
4 . 1 . 0	References	U	References were updated in 6.1 (Literature Cited) of the TVA FSEIS (June 2007).
5 . 0 . 0	Environmental Impact of Watts Bar Nuclear Plant and Transmission Facilities Operations	NA	Section header
5 . 1 . 0	Impacts on Land Use	NC	No new major construction activities would be required to complete Unit 2. The affected area is within the current Vehicle Barrier System [See Figure 1-2 (Unit 2 Site Plan) of the TVA FSEIS (June 2007)]. Paragraph 4 (following the list of bulleted items) in 2.1 (Proposed Action) of the TVA FSEIS (June 2007) discusses the geographic scope of the project.
5 . 2 . 0	Impacts on Water Use	NA	Section header
5 . 2 . 1	Thermal Discharges	O	<p>Hydrothermal impacts of 2-unit operation with the SCCW are updated in 3.1.1 (Surface Water - Hydrothermal Effects) of the TVA FSEIS (June 2007). As explained in this section, one of the modeling assumptions used in the FSEIS's "Updated Hydrothermal Analysis" (page 37) was that the SCCW system would operate essentially as currently designed, with no increase in the volume of water delivered and removed by the SCCW system. Additionally, see response to NRC Request 1 of Enclosure 1 of TVA letter to NRC, "Watts Bar Nuclear Plant (WBN) - Unit 2 - Final Supplemental Environmental Impact Statement - Request For Additional Information (TAC MD8203)" dated July 2, 2008.</p> <p>The updated model also accounted for reservoir system operation changes implemented by TVA in May 2004, as part of TVA's Reservoir Operations Study Final Programmatic EIS (ROS PEIS) (May 2004). Appendix A (Summary of Previous Hydrothermal Impact Studies) of the TVA FSEIS is a summary of previous hydrothermal impact studies, including one dated July 1999, that was conducted to study the thermal discharge affects of the SCCW system.</p>

1995 NRC  
FES SECTION

TITLE

\*

ADDITIONAL INFORMATION

1995 NRC FES SECTION	TITLE	*	ADDITIONAL INFORMATION
5 . 2 . 2	Operational Chemical Wastes	U	<p>Update was provided in 3.1.2 (Surface Water - Chemical Additives to Raw Water) of the TVA FSEIS (June 2007).</p> <p>This update notes "The referenced earlier environmental reviews analyzed potential impacts to surface water and water quality. A primary area of concern for surface water and water quality relates to the chemicals added to treat raw water. These earlier analyses continue to adequately depict the kinds of chemicals used at the plant and associated environmental impacts.</p> <p>Proposed chemical additives and their respective toxicological data are presented to the state for approval prior to plant use in the facility's Biocide and Corrosion Treatment Plan (B/CTP) required by the WBN Unit NPDES permit. ..."</p> <p>For NPDES Permit, refer to ADAMS accession number ML063560378.</p>
5 . 2 . 3	Sanitary Wastes	U	<p>TVA issued a Finding of No Significant Action for the Watts Bar to Spring City Sewer Pipeline Project in August 2005 [See Table 1-1 (Environmental Reviews and Documents Pertinent to Watts Bar Nuclear Plant Unit 2) of the TVA FSEIS (June 2007)]. The sewer line, which is currently being installed, will support both Units 1 and 2.</p>
5 . 2 . 4	NPDES Permit	U	<p>The NPDES permit is discussed in 2.2.2 (Changes in Plant Design and Operational System Since 1995; see page 26), throughout 3.1.1 (Surface Water - Hydrothermal Effects), and in 3.1.2 (Surface Water - Chemical Additives to Raw Water) of the TVA FSEIS (June 2007).</p> <p>Table 3-1 (NPDES Temperature Limits for WBN Outfalls to the Tennessee River) provides current NPDES Temperature limits for WBN outfalls to the Tennessee River.</p> <p>For NPDES Permit, refer to ADAMS accession number ML063560378.</p>
5 . 2 . 5	Effects on Water Users Through Changes in Water Quality	U	<p>Near-field and far-field hydrothermal affects of 2-unit operation with the SCCW in operation are discussed in 3.1.1 (Surface Water - Hydrothermal Effects; see page 45) of the TVA FSEIS (June 2007). The FSEIS concludes that these are no significant impacts in these areas.</p> <p>Additionally, see response to NRC Request 1 of Enclosure 1 of TVA letter to NRC, "Watts Bar Nuclear Plant (WBN) - Unit 2 - Final Supplemental Environmental Impact Statement - Request For Additional Information (TAC MD8203)" dated July 2, 2008.</p> <p>Low river flow is discussed in 3.1.1 (page 44).</p>
5 . 2 . 6	Effects on Surface Water Supply	U	<p>Water supply is addressed in several places in the TVA FSEIS (June 2007). In Chapter 3 (page 33, under the heading "Cumulative Effects") TVA notes that the cumulative effects of constructing and operating Units 1 and 2 were considered in previous environmental reviews. TVA's Reservoir Operations Study Final Programmatic EIS (ROS PEIS) (May 2004) addressed cumulative effects on water supply in the Tennessee River from the operation of TVA's power plants. Response 20 (Water Impacts) in Appendix D (Response to Comments) of the TVA FSEIS (June 2007) addresses consumptive use of water. This response points to other relevant sections of the document. Response 22 (TDEC, Division of Water Supply) addresses groundwater supply.</p>

1995 NRC FES SECTION	TITLE	*	ADDITIONAL INFORMATION
5 . 2 . 7	Effects on Groundwater	U	Update was provided in 3.1.3 (Groundwater) of the TVA FSEIS (June 2007). Also see Response 22 (TDEC, Division of Water Supply) of Appendix D (Response to Comments).
5 . 2 . 8	River Recreational Use	NC	Since no major changes affecting the river temperature, flows, or navigability are proposed for the completion of Unit 2; river recreational use was not addressed in the TVA FSEIS (June 2007).
5 . 3 . 0	Impacts on Terrestrial Environment	NA	Section Heading
5 . 3 . 1	Impacts on Terrestrial Animal Species	U	Update was provided in 3.3.2 (Wildlife) of the TVA FSEIS (June 2007).
5 . 3 . 2	Impacts on Terrestrial Plant Species	U	Update was provided in 3.3.1 (Plants) of the TVA FSEIS (June 2007).
5 . 3 . 3	Impacts on Threatened and Endangered Terrestrial Species	U	Update was provided in 3.4.2 (Plants) and 3.4.3 (Wildlife) of the TVA FSEIS (June 2007).
5 . 4 . 0	Impacts on Aquatic Environment	U	Updates provided in 3.2 (Aquatic Ecology) and 3.4.1 (Threatened and Endangered Species / Aquatic Animals) of the TVA FSEIS (June 2007).
5 . 4 . 1	Entrainment and Impingement of Aquatic Biota	U	Updates provided in 3.2 (Aquatic Ecology - under subheaders "Plankton" and "Aquatic Communities") and 3.4.1 (Threatened and Endangered Species / Aquatic Animals - last paragraph) of the TVA FSEIS (June 2007). Topics are further discussed in Response 25 (DOI) of Appendix D (Response to Comments).  Additionally, see response to NRC Request 1 of Enclosure 1 of TVA letter to NRC, "Watts Bar Nuclear Plant (WBN) - Unit 2 - Final Supplemental Environmental Impact Statement - Request For Additional Information (TAC MD8203)" dated July 2, 2008.
5 . 4 . 2	Thermal Effects	O	Changes to the heat dissipation system are discussed in 2.2.2 (Heat Dissipation System) of the TVA FSEIS (June 2007). Thermal Effects analysis was updated in 3.1.1 (Surface Water – Hydrothermal Effects). Appendix A (Summary of Previous Hydrothermal Impact Studies) provides a summary of previous hydrothermal impact studies, including one prepared to address the SCCW (July 1999). Additionally, see response to NRC Request 1 of Enclosure 1 of TVA letter to NRC, "Watts Bar Nuclear Plant (WBN) - Unit 2 - Final Supplemental Environmental Impact Statement - Request For Additional Information (TAC MD8203)" dated July 2, 2008.

1995 NRC FES SECTION	TITLE	*	ADDITIONAL INFORMATION
5 . 4 . 3	Chemical Effects	U	<p>Update was provided in 3.1.2 (Surface Water - Chemical Additives to Raw Water) of the TVA FSEIS (June 2007).</p> <p>This update notes "The referenced earlier environmental reviews analyzed potential impacts to surface water and water quality. A primary area of concern for surface water and water quality relates to the chemicals added to treat raw water. These earlier analyses continue to adequately depict the kinds of chemicals used at the plant and associated environmental impacts.</p> <p>Proposed chemical additives and their respective toxicological data are presented to the state for approval prior to plant use in the facility's Biocide and Corrosion Treatment Plan (B/CTP) required by the WBN Unit NPDES permit. ..."</p> <p>For NPDES Permit, refer to ADAMS accession number ML063560378.</p>
5 . 4 . 4	Impacts on Threatened and Endangered Aquatic Species	U	Update was provided in 3.4.1 (Threatened and Endangered Species - Aquatic Animals) and Response 25 of Appendix of the TVA FSEIS (June 2007).
5 . 4 . 5	Nuisance Aquatic Organisms	U	Update was provided in 3.2 (Aquatic Ecology - subheader "Invasive and Noninvasive Aquatic Plants") of the TVA FSEIS (June 2007).
5 . 5 . 0	Radiological Impacts	U	Update was provided in 3.13 (Radiological Effects - Paragraph 1) of the TVA FSEIS (June 2007).
5 . 5 . 1	Changes to the Plant	U	Update was provided in 3.14 (Radioactive Waste) of the TVA FSEIS (June 2007).
5 . 5 . 2	Summary of Radioactive Effluents and Potential Exposures of Humans	U	Update was provided in 3.13 (Radiological Effects) of the TVA FSEIS (June 2007), including discussion of liquid and gaseous effluents.
5 . 5 . 3	Radiological Impact on Animals	NC	No change since NUREG-0498, Supplement 1 (April 1995).
5 . 5 . 4	Storage and Transportation of Radioactive Material	U	Update was provided in 3.14 (Radioactive Waste) of the TVA FSEIS (June 2007).
5 . 5 . 5	Health Effects of Radiation Doses From Effluents	U	Update was provided in 3.13 (Radiological Effects) of the TVA FSEIS (June 2007), including discussion of liquid and gaseous effluents.
5 . 5 . 6	Impacts of the Uranium Fuel Cycle	U	<p>Fuel use update was provided in 3.15 (Spent Fuel Storage) of the TVA FSEIS (June 2007). TVA has incorporated, by reference, the Department of Energy's FEIS for the Production of Tritium in a Commercial Light Water Reactor (March 1999). TVA adopted this document in May 2000.</p> <p>NRC approved production of tritium at Watts Bar Unit 1 via amendment 40 (ADAMS accession number ML022540925). Production of tritium is not part of the construction completion and licensing of WBN Unit 2.</p>
5 . 6 . 0	Non-Radiological Human Health Impacts	NA	Section heading

**1995 NRC  
FES SECTION**

FES SECTION	TITLE	*	ADDITIONAL INFORMATION
5 . 6 . 1	Electromagnetic Fields and Shock Hazards From Transmission Lines	<b>U</b>	<p>1.4 (Scoping and Draft SEIS Review) of the TVA FSEIS (June 2007) noted that no changes in or additions to transmission lines are planned as a result of completing Unit 2.</p> <p>Potential effects of the new on-site power line will be addressed in Categorical Exclusion Checklist (CEC) 18271, Watts Bar Nuclear Plant 500-kV Switchyard Startup Unit 2 - Project No. 20172 - Work Order 62189 initiated April 28, 2008.</p>
5 . 6 . 2	Airborne Pathogenic Microorganisms	<b>NC</b>	No change since NUREG-0498, Supplement 1 (April 1995).
5 . 6 . 3	Noise Levels	<b>NC</b>	No change since NUREG-0498, Supplement 1 (April 1995).
5 . 6 . 4	Air Quality	<b>U</b>	<p>1.4.1 (Scoping and Draft SEIS Review) of the TVA FSEIS (June 2007) noted that air quality was found to have been adequately addressed in previous environmental reviews.</p> <p>Updates for Unit 1 were provided in 3.1 of the Watts Bar Nuclear Plant SCCW EA (August 1998). The EA concluded there are no operational impacts on air resources.</p> <p>It was also addressed in the DOE's FEIS for Production of Tritium in a Commercial Light Water Reactor, March 1999 (Tritium EIS). TVA adopted this document in May 2000.</p> <p>NRC approved production of tritium at Watts Bar Unit 1 via amendment 40 (ADAMS accession number ML022540925). Production of tritium is not part of the construction completion and licensing of WBN Unit 2.</p>
5 . 7 . 0	Socioeconomic Impacts	<b>U</b>	Update was provided in 3.8 (Socioeconomic, Environmental Justice, and Land Use) of the TVA FSEIS (June 2007).
5 . 8 . 0	Environmental Justice	<b>U</b>	Update was provided in 3.8.3 (Low-income and Minority Populations) of the TVA FSEIS (June 2007).
5 . 9 . 0	References	<b>U</b>	References were updated in 6.1 (Literature Cited) of the TVA FSEIS (June 2007).
6 . 0 . 0	Environmental Monitoring Program	<b>NA</b>	Section heading
6 . 1 . 0	Preoperational Monitoring Program	<b>NA</b>	Unit 1 has been operational since 1995.
6 . 1 . 1	Preoperational Onsite Meteorological Program	<b>NA</b>	Unit 1 has been operational since 1995.
6 . 1 . 2	Preoperational Water Quality Studies	<b>NA</b>	Unit 1 has been operational since 1995.
6 . 1 . 3	Preoperational Groundwater Studies	<b>NA</b>	Unit 1 has been operational since 1995.

1995 NRC FES SECTION	TITLE	*	ADDITIONAL INFORMATION
6 . 1 . 4	Preoperational Aquatic Biological Monitoring	NA	Unit 1 has been operational since 1995.
6 . 1 . 5	Preoperational Terrestrial Monitoring	NA	Unit 1 has been operational since 1995.
6 . 1 . 6	Preoperational Radiological Monitoring	NA	Unit 1 has been operational since 1995.
6 . 2 . 0	Operational Monitoring Program	NA	Section heading
6 . 2 . 1	Operational Onsite Meteorological Program	U	Update was provided in 3.11 (Climatology and Meteorology) of the TVA FSEIS (June 2007).
6 . 2 . 2	Operational Water Quality Studies	U	Water quality monitoring under the current NPDES permit for Unit 1 operation is updated in 3.1.1 (Surface Water – Hydrothermal Effects - under discussion of the outfalls) and 3.1.2 (Surface Water – Chemical Additives to Raw Water) of the TVA FSEIS (June 2007).  For NPDES Permit, refer to ADAMS accession number ML063560378.
6 . 2 . 3	Operational Groundwater Studies	U	Water quality monitoring under the current NPDES permit for Unit 1 operation is updated in 3.1.3 (Groundwater) of the TVA FSEIS (June 2007).  For NPDES Permit, refer to ADAMS accession number ML063560378.
6 . 2 . 4	Operational Chemical Effluents Monitoring	U	Update was provided in 3.1.2 (Surface Water - Chemical Additives to Raw Water) of the TVA FSEIS (June 2007).  This update notes "The referenced earlier environmental reviews analyzed potential impacts to surface water and water quality. A primary area of concern for surface water and water quality relates to the chemicals added to treat raw water. These earlier analyses continue to adequately depict the kinds of chemicals used at the plant and associated environmental impacts.  Proposed chemical additives and their respective toxicological data are presented to the state for approval prior to plant use in the facility's Biocide and Corrosion Treatment Plan (B/CTP) required by the WBN Unit NPDES permit. ..."  For NPDES Permit, refer to ADAMS accession number ML063560378.

1995 NRC  
FES SECTION

TITLE

\*

ADDITIONAL INFORMATION

1995 NRC FES SECTION	TITLE	*	ADDITIONAL INFORMATION
6 . 2 . 5	Operational Aquatic Biological Monitoring	O	<p>The monitoring referenced in 6.2.5 of the NUREG was completed, and a final report was submitted to the State of Tennessee in 2001 ("Watts Bar Nuclear Plant Supplemental Condenser Cooling Water System Fish Monitoring Program"). The report stated "Overall, it was concluded that the WBN SCCW system operation, including both water intake and thermal discharge has had no impact to aquatic life in the forebay of Watts Bar Reservoir and the upper two-thirds of Chickamauga Reservoir."</p> <p>TVA currently conducts annual aquatic biological monitoring under its Vital Signs Monitoring Program described in 3.2 (Aquatic Ecology - subheading Aquatic Communities) of the TVA FSEIS (2007). Additional updates were provided in 3.1.1 (Surface Water – Hydrothermal Effects - subsection "Far-Field Effects") and 3.1.2 (Surface Water – Chemical Additives to Raw Water) of the TVA FSEIS (June 2007). NPDES permit monitoring requirements are discussed in 3.1 (Water Quality).</p> <p>For NPDES Permit, refer to ADAMS accession number ML063560378.</p> <p>The most recent biological monitoring report was published May 2008 ("Biological Monitoring of the Tennessee River Near Watts Bar Nuclear Plant Discharge 2007"). The Results and Discussion portion of the report (pages 4 and 5) state:</p> <ul style="list-style-type: none"> <li>- "... Watts Bar Reservoir forebay RFAI data collected between 1993 and 2007 reflect little change in the overall ecological health of the fish communities at this site ..."</li> <li>- "... These data indicate that a healthy benthic macroinvertebrate community exists in the downstream vicinity of WBN and that the plant is not adversely impacting this fauna. ..."</li> <li>- "... Watts Bar Reservoir forebay RBI data collected between 1994 and 2007 reflect little change in the overall ecological health of the benthic macroinvertebrate community at this site. ..."</li> </ul>
6 . 2 . 6	Operational Terrestrial Monitoring	NC	No changes have been made since NUREG-0498, Supplement 1 (April 1995).
6 . 2 . 7	Operational Radiological Monitoring	O	Changes made to the program since 1995 are referenced in the latest/current ODCM (revision 21 dated January 15, 2008).
6 . 3 . 0	References	U	References were updated in 6.1 (Literature Cited) of the TVA FSEIS (June 2007).
7 . 0 . 0	Accident Analysis	NA	SAMA to be updated per response to NRC Request 2 of Enclosure 1 of TVA letter to NRC, "Watts Bar Nuclear Plant (WBN) - Unit 2 - Final Supplemental Environmental Impact Statement - Request For Additional Information (TAC MD8203)" dated July 2, 2008
7 . 1 . 0	Realistic Accident Analysis	O	SAMA to be updated per response to NRC Request 2 of Enclosure 1 of TVA letter to NRC, "Watts Bar Nuclear Plant (WBN) - Unit 2 - Final Supplemental Environmental Impact Statement - Request For Additional Information (TAC MD8203)" dated July 2, 2008
7 . 2 . 0	Severe Accident Mitigation Design Alternatives (SAMDA)	O	SAMA to be updated per response to NRC Request 2 of Enclosure 1 of TVA letter to NRC, "Watts Bar Nuclear Plant (WBN) - Unit 2 - Final Supplemental Environmental Impact Statement - Request For Additional Information (TAC MD8203)" dated July 2, 2008

1995 NRC FES SECTION	TITLE	*	ADDITIONAL INFORMATION
7.2 . 1	Introduction	O	SAMA to be updated per response to NRC Request 2 of Enclosure 1 of TVA letter to NRC, "Watts Bar Nuclear Plant (WBN) - Unit 2 - Final Supplemental Environmental Impact Statement - Request For Additional Information (TAC MD8203)" dated July 2, 2008
7.2 . 2	Estimate of Risk for Watts Bar Nuclear Plant	O	SAMA to be updated per response to NRC Request 2 of Enclosure 1 of TVA letter to NRC, "Watts Bar Nuclear Plant (WBN) - Unit 2 - Final Supplemental Environmental Impact Statement - Request For Additional Information (TAC MD8203)" dated July 2, 2008
7.2 . 3	Potential Design Improvements	O	SAMA to be updated per response to NRC Request 2 of Enclosure 1 of TVA letter to NRC, "Watts Bar Nuclear Plant (WBN) - Unit 2 - Final Supplemental Environmental Impact Statement - Request For Additional Information (TAC MD8203)" dated July 2, 2008
7.2 . 4	Risk Reduction Potential of Design Improvements	O	SAMA to be updated per response to NRC Request 2 of Enclosure 1 of TVA letter to NRC, "Watts Bar Nuclear Plant (WBN) - Unit 2 - Final Supplemental Environmental Impact Statement - Request For Additional Information (TAC MD8203)" dated July 2, 2008
7.2 . 5	Cost Impacts of Candidate Design Improvements	O	SAMA to be updated per response to NRC Request 2 of Enclosure 1 of TVA letter to NRC, "Watts Bar Nuclear Plant (WBN) - Unit 2 - Final Supplemental Environmental Impact Statement - Request For Additional Information (TAC MD8203)" dated July 2, 2008
7.2 . 6	Cost-Benefit Comparison	O	SAMA to be updated per response to NRC Request 2 of Enclosure 1 of TVA letter to NRC, "Watts Bar Nuclear Plant (WBN) - Unit 2 - Final Supplemental Environmental Impact Statement - Request For Additional Information (TAC MD8203)" dated July 2, 2008
7.2 . 7	Conclusions	O	SAMA to be updated per response to NRC Request 2 of Enclosure 1 of TVA letter to NRC, "Watts Bar Nuclear Plant (WBN) - Unit 2 - Final Supplemental Environmental Impact Statement - Request For Additional Information (TAC MD8203)" dated July 2, 2008
7.3 . 0	References	U	SAMA to be updated per response to NRC Request 2 of Enclosure 1 of TVA letter to NRC, "Watts Bar Nuclear Plant (WBN) - Unit 2 - Final Supplemental Environmental Impact Statement - Request For Additional Information (TAC MD8203)" dated July 2, 2008
8.0 . 0	Consequences of Proposed Actions	NA	Chapter heading
8.1 . 0	Unavoidable Adverse Environmental Effects	NC	No change since NUREG-0498, Supplement 1 (April 1995).
8.2 . 0	Short-term Uses and Long-term Productivity	NC	No change since NUREG-0498, Supplement 1 (April 1995).
8.3 . 0	Irreversible and Irretrievable Commitments of Resource	NC	No change since NUREG-0498, Supplement 1 (April 1995).
8.4 . 0	Decommissioning	U	Update was provided in 3.17 (Decommissioning) of the TVA FSEIS (June 2007).

1995 NRC  
FES SECTION

TITLE

\*

ADDITIONAL INFORMATION

8 . 5 . 0

References

U

References were updated in 6.1 (Literature Cited) of the TVA FSEIS (June 2007).

---

**STATUS CODE DEFINITIONS**

**O (OPEN):** NUREG-0498, Supplement 1 may require revision to incorporate updated information provided in TVA documents.

**NA (NOT APPLICABLE):** Justification as to why a subsection is not applicable is provided in the ADDITIONAL INFORMATION column.

**NC (NOT CHANGED):** No changes have been made in this area.

**U (UPDATED):** Although minor updates have been provided in TVA documents, NUREG-0498, Supplement 1 should not require revision.