

98

**From:** William Ruland  
**To:** Bloomer, Tamara  
**Date:** 10/29/2007 7:38:27 AM  
**Subject:** Fwd: FYI - Jaczko briefing request

We provided the below information to Commissioner Jaczko.

Bill

>>> Warren Lyon 10/28/2007 8:28 PM >>>

>>> Warren Lyon 10/28/2007 8:26 PM >>>

Westinghouse identified (b) (6) power recovery installations and 16 power uprate installations in a proprietary report a year or so ago. Of these, (b) (6) power recoverys are not in operation - (b) (6) due to UFM error, and (b) (6) of the uprates are not in operation - 2 because we denied the uprate request and one because we were going to deny the request - all for reasons the licensees did not dispute.

>>> Thomas Hipschman 10/26/2007 12:47 PM >>>

Warren,

Are any plants using the WEC UFM? If so, how many, and how many have had MURs?

Also, FYI, Commissioner Jaczko has requested a briefing via the EDO's office on this issue and the WEC letter.

Thanks,

Tom

Thomas Hipschman  
Policy Advisor for Reactors  
Office of Commissioner Jaczko  
301-415-1832  
[trh@nrc.gov](mailto:trh@nrc.gov)

**CC:** Lyon, Warren

N-5