



Jeffrey B. Archie
Vice President, Nuclear Operations
803.345.4214

July 7, 2008

Document Control Desk
U. S. Nuclear Regulatory Commission
Washington, DC 20555

Dear Sir / Madam:


Subject: VIRGIL C. SUMMER NUCLEAR STATION
DOCKET NO. 50/395
OPERATING LICENSE NO. NPF-12
SPECIAL REPORT (SPR) 2008-002

South Carolina Electric & Gas Company (SCE&G) is submitting this report pursuant to the requirements of Technical Specification 3.3.3.1.b. This report addresses the inoperability of the Main Steam Line radiation monitor RM-G19A for greater than 72 hours. During the inoperable period of 138 hours and 15 minutes, V. C. Summer Nuclear Station implemented a preplanned alternate method of monitoring in accordance with the requirements of Action 30 of the Technical Specification.

RM-G19A was declared inoperable June 23, 2008 due to a Universal Digital Ratemeter (UDR) failure. The UDR was replaced, and the radiation monitor was returned to operable status on June 29, 2008.

Should you have any questions, please call Mr. Bruce Thompson at (803) 931-5052 at your convenience.

Very truly yours,



Jeffrey B. Archie

JHW/JBA/sr

c: K. B. Marsh
S. A. Byrne
N. S. Carns
J. H. Hamilton
R. J. White
L. A. Reyes
R. E. Martin

NRC Resident Inspector
K. M. Sutton
INPO Records Center
NSRC
RTS (CR-08-02782)
File (818.08)
PRSF (RC-08-0086)

JEB
NR