

Request for Additional Information No. 38, Revision 0

7/16/2008

U. S. EPR Standard Design Certification
AREVA NP Inc.
Docket No. 52-020

SRP Section: 17.5 - Quality Assurance Program Description - Design Certification, Early Site
Permit and New License Applicants
Application Section: 17.5 and 1.9
CQVP Branch

QUESTIONS

17.5-1

Section 17.5 of the EPR design certification FSAR references AREVA Topical Report ANP-10266A which was reviewed and approved by the staff on April 26, 2007. As documented in the staff's safety evaluation report, SRP 17.5 was in a draft format and did not contain a commitment to Regulatory Guide 1.37, Revision 1, at the time of the AREVA topical report approval. The final version of SRP 17.5 includes a commitment to Regulatory Guide 1.37, Revision 1. ANP-10266A includes a commitment to Regulatory Guide 1.37, Revision 0. Additionally, Table 1.9-2 of Section 1.9 of the EPR FSAR states conformance to Regulatory Guide 1.37, Revision 1 for the applicable EPR FSAR sections, except for section 17.5.

AREVA needs to revise Table 1.9-2 of Section 1.9 of the FSAR and AREVA Topical Report ANP-10266A to show conformance and commitment to Regulatory Guide 1.37, Revision 1.