NOTE:
FLAGS FOR SYSTEM BOUNDARIES WERE NOT MARKED ON DRAIN HEADERS DUE TO LARGE NUMBER AND LACK OF SPACE

INSIDE CONTAINMENT VESSEL UNIT #1 | OUTSIDE CONTAINMENT VESSEL | OUTSIDE CONTAINMENT VESSEL | INSIDE CONTAINMENT VESSEL UNIT #2

FAN COIL UNIT #13 | FAN COIL UNIT #24

REAC HEAD VENT TO ATM DRAIN | DECONTAMINATION PIT | MANIPULATOR CRANE RAILS | REACTOR HEAD VENT TO ATM DRAIN

FAN FL. EL. 755'-0"

MAINSTEAM RELIEF HDR. DRNS. 11 SG SEE NF-39339-5 | TO TURB. BLDG. SUMP SEE B-9 THIS DWG. | 1½"-WL-383

½" FROM REACTOR COOLANT DRAIN FILTER LR-39249 | ½" FROM REACTOR COOLANT DRAIN FILTER LR-39258 | CAPPED FOR FUTURE

¾" FROM SEAL WATER FILTER LR-XH-1-39 | ½" FROM NON AERATED DRAIN FILTER LR-39249

¾" FROM REACTOR COOLANT FILTER LR-XH-1-39 | ¾" FROM REACTOR COOLANT FILTER LR-XH-1001-5

¾" FROM LET DOWN FILTER LR-XH-1001-5 | ¾" FROM LET DOWN FILTER LR-XH-1-39

¾" FROM SEAL WATER FILTER LR-XH-1001-5 | CAPPED FOR FUTURE | 2" C.O.

¾" FROM SPENT FUEL SKIMMER FILTER & STRAINER LR-XH-1-29

OPER. FL. EL. 735'-0"

MAINSTEAM RELIEF HDR. DRNS. 22 SG SEE NF-39339-5 | TO TURBINE BLDG. SUMP UNIT 2 | 21 SG DRNS C-9 THIS DWG. | 11 SG DRNS A-3 THIS DWG. | 12 SG DRNS C-3 THIS DWG.

2WL-57-30 | 2WL-57-28 | 2WL-81

4-WL-365 | NEW FUEL FL. EL. 738'-7" | 2" FROM LEAK DETECTION SEE DWG. NF-39338-1

CONTINUED ON THIS DWG.

FAN COIL COND COLLECTING TK (TYP.)

FLR. EL. 733'-9" | FAN COIL COND. COLLECTING TK (TYP.) AT R.C. PUMP #11 | AT R.C. PUMP #12

FROM LEAK DETECTION SEE DWG NF-39338-1

PIPE CHASE FL. EL. 726'-6"

MEZZ. FL. EL. 720'-0"

MAIN STEAM RELIEF HDR. DRNS. 21 SG SEE DWG. LR-39339-5 | TO TURBINE BLDG. SUMP SEE B-9 THIS DWG. | 1½"-2WL-80 | 2WL-57-29 | FL. EL. 723'-9" | 2WL-57-27

2" FROM CATION BED DEMIN. LR-XH-1-39 | 2" FROM SEAL WATER HT EXCH LR-XH-1-39 | 2" FROM LETDOWN HT EXCH. LR-XH-1-39 | 2" FROM DEBORATING DEMINERALIZER LR-XH-1-39 | 2" FROM EVAP FEED ION EXCHS LR-X-1-40 | 2" FROM DEBORATING DEMIN. LR-XH-1001-5

2" FROM MIXED BED DEMIN. LR-XH-1001-5 | ¾" TUBING FROM VALVE 2VC-38-4 LR-XH-1001-5 | 2" FROM SEAL WATER HT. EXCH. LR-XH-1001-5 | 2" FROM CATION BED DEMIN. LR-XH-1001-5 | ¾" TUBING CAPPED

2" FROM EVAPOR. COND DEMIN. #11 & 21 LR-XH-1-40 | 2" FROM SPENT FUEL PIT DEMIN. LR-XH-1-29

2" FROM WASTE GAS COMPRESSOR LR-XH-1-124 | 2" FROM RESIN DISPOSAL SUMP "B" THIS DWG. AT LOC. H-3

REFUELING CANAL DRAIN SAMPLE | EL. 713'-2" FAN COIL UNITS 1-WL-84 | DECONTAMINATION PIT | REACTOR HD LAYDOWN

TO TURB. BLDG. SUMP SEE B-9 THIS DWG. | 2" FROM SEAL WATER HT EXCH LR-XH-1-39 | 2" FROM LETDOWN HT EXCH. LR-XH-1-39 | 2" FROM DEBORATING DEMINERALIZER LR-XH-1-39 | 2" FROM EVAP FEED ION EXCHS LR-X-1-40 | 2" FROM DEBORATING DEMIN. LR-XH-1001-5

2" FROM MIXED BED DEMIN. LR-XH-1001-5 | ¾" TUBING FROM VALVE 2VC-38-4 LR-XH-1001-5 | 2" FROM SEAL WATER HT. EXCH. LR-XH-1001-5 | 2" FROM CATION BED DEMIN. LR-XH-1001-5 | ¾" TUBING CAPPED

2" FROM EVAPOR. COND DEMIN. #11 & 21 LR-XH-1-40 | 2" FROM SPENT FUEL PIT DEMIN. LR-XH-1-29

2" FROM WASTE GAS COMPRESSOR LR-XH-1-124 | 2" FROM RESIN DISPOSAL SUMP "B" THIS DWG. AT LOC. H-3

REFUELING CANAL DRAIN | FAN COIL UNITS | DECONTAMINATION PIT | REACTOR HD LAYDOWN

TO TU 48677 THIS DWG.

TO TU48177 | TO TU48176 | TO RC DR TK PUMPS LR-XH-1-123 | FROM RC. DRAIN TK LR-XH-1-123 | OPEN SIGHT DRAIN | FLOOR EL. 697'-6"

ANNULUS SUMP PUMP | BACK-UP PUMP CONT. | HI LEVEL | FLOOR EL. 697'-6"

4" OVERFLOW FROM MAKE UP TANK 11 & 12 SEE LR-39242 | 4" OVERFLOW FROM "21" REFUELING WATER STORAGE TANK UNIT "2" SEE LR-39237

FROM GAS DECAY TANK COND. OR PUMP SEE LR-XH-1-124 | TO SPENT RESIN TANK LR-39236 | 1" LINE FROM GAS DECAY TANKS LR-XH-1-124

FROM RC DRAIN TANK PUMP SEE LR-XH-1-123 | TO RC DRAIN TANK PUMP SEE LR-XH-1-123

SEE DWG NF-39678 2½-WL-365 | GR. FL. EL. 695'-0"

WASTE DISPOSAL FILTER *121 (IN FILTER ROOM) DRAIN TO AERATED WASTE VIA FLOOR DRAIN

CONTAINMENT ISOLATION VALVES SV-33632 | CAP OFF EXISTING LINE TO HEADER | TO UNIT #2 SUMP "A" HD1 | TO FILTER ROOM EXHAUST DUCT LR-39600

*11 SUMP "A" FILTER | *2: SUMP "A" FILTER | SHIELD WALL | SPOOL REMOVED CAP AT EL 8' ABANDON IN PLACE

SPOOL REMOVED CAPPED & ABANDONED | 3" EXCESS LET DOWN HT. EXCH. SHELL OUTLET (LR-39245)

SUMP TANK #121 AERATED SYST. SEE ORD. & DWG. NF-XH-1-67 | OLD. 600 GAL (III/3) WSPWDATST | NEW 300 GAL (III/3) WDAPST2 | NON-AERATED SUMP TANK PUMP #121 ITEM: WDAPST2 ORD. & DWG. NF-XH-1-156 | NON-AERATED SUMP TANK PUMP #121 ITEM: WDAPST2 ORD. & DWG. NF-3755

2" DRAIN FROM C.C. SURGE TK "11" | 3" OVERFLOW FROM "11" REFUELING WTR STORAGE TK UNIT "1" SEE LR-39237 | 2" DRAIN FROM C.C. SURGE TANK #21 | DRAIN TO AERATED WASTE VIA FLOOR DRAIN

2" C.V.C.S. HOLD UP TANK CUBICAL DRAINS | FROM C.V.C.S. HOLDUP TANKS LR-XH-1-40

R.H.R. PIT BOUNDARY | CONTAINMENT SUMP "A" (III/3) | CONTAINMENT SUMP "B" | REACTOR CAVITY SUMP "C" | CHEM. ADDITIVE TANK | CHEMICAL DRAIN TANK WDATCD1 (III/3)

TO AERATED WASTE VIA FLOOR DR. | TO NON-AERATED FILTER FOR CONTINUATION SEE DWG. LR-39249 | TO ADT COLLECTION TANKS - SEE DWG. LR-39236 | REPLACE EXISTING PUMPS WITH HIGHER CAPACITY PUMPS NEW CAPACITY EACH PUMP 35 PM @ 60 TDH TO AERATED DRAIN MONITOR TANKS FOR CONTINUATION SEE DWG. LR-39249

*121 AUX. BLDG. DUPLEX SUMP PUMP | *11 SUMP PUMP (III/1) | SUMP PUMP (III/1) | *12 SUMP PUMP (III/1)

2-WL-550-2" VENT TO AUX. BLDG. SPECIAL VENT FOR CONT. SEE LR-39600 | CONT. ON LR-39253 @ LOC. H-1

RESIDUAL PIT SUMPS UNIT #1 | RESIDUAL PIT SUMPS UNIT # 2

2" DRAIN FROM RHR PUMP DISCH. FOR CONT. SEE NF-XH-1001-8 | #22 SUMP PUMP (III/1) | #21 SUMP PUMP (III/1)

TO AERATED SUMP TK *121 VIA FLOOR DRAIN SYSTEM SEE THIS DWG. @ LOC D-9 | *121 RESIN DISPOSAL BLDG. SUMP "B" PUMPS DISCHARGE STRAINER | TRUCK AREA FLOOR DRAINS | RESIN DISPOSAL BLDG. SUMP "B"

LOW LEVEL RADWASTE ENCLOSURE SUMP

CAT I DENOTES CATEGORY I VENTILATION ZONE

CONT'D FROM DWG. LR-39253 LOC @ H-6

ALL PIPING TO BE QA TYPE III UNLESS OTHERWISE NOTED
DENOTES LIMITS OF Q A TYPES
I, IIB, III DENOTES THE Q A TYPES
DENOTES FLOOR DRAIN & EQUIPMENT DRAIN SYSTEM
DENOTES WASTE DISPOSAL SYSTEM SHOWN ON DWG NO. XH-1-123

LEGEND (CONT.)
V-DENOTES VENT
D-DENOTES DRAIN
P-DENOTES PURGE CONN.

(00) DENOTES CONTAINMENT PENETRATION NUMBER
(P1) DENOTES WESTINGHOUSE INSTR. NUMBER
(001) DENOTES PS&E INSTR. NUMBER
INSTR. MARKED W FURNISHED BY WESTINGHOUSE ALL OTHERS FURNISHED BY PURCHASER. REFER TO DWG. NF-39214 FOR LEGEND.
(III/3) DENOTES EQUIPMENT Q.A. TYPE/DESIGN CLASS

LR-SYSTEMS
WD - WASTE DISPOSAL
VC - CHEMICAL AND VOLUME CONTROL
CC - COMPONENT COOLING
SM - PLANT SAMPLE SYSTEM
RH - RESIDUAL HEAT REMOVAL

LR - LEGEND
IN SCOPE FOR LR PER 10 CFR 54.4(a)(1)
IN SCOPE FOR LR PER 10 CFR 54.4(a)(3)
OUT OF SCOPE
XX DENOTES SYSTEM BOUNDARY BREAK

REVISIONS

0
DRAWN BY: JLB
DATE: 6-20-07
PREPARED BY: RAB
DATE: 6-20-07
REVIEWED BY: SRM
DATE: 6-22-07

1
REVISED LINK DWG FROM LR TO NF, HIGHLIGHTED INSTRUMENT PRESSURE BOUNDARIES, HIGHLIGHTED IN SCOPE CNTM ISOL VLVS 31438 & 31439, REMOVED HIGHLIGHTS FROM OUT OF SCOPE PIPING, REVISED BOUNDARY FLAG, ENLARGED BOUNDARY FLAGS, HIGHLIGHTED (6X2) CONTINUATION LINE, REVISED LR - SYSTEM LEGEND, HIGHLIGHTED VLV ACTUATOR FOR CV-31521 & CV-31839, REMOVED HIGHLIGHTS (NOT IN SCOPE) ANNULUS SUMP PUMPS, CNTM SUMP A PUMPS, & RHR SUMP PUMPS, & ASSOCIATED LEVEL ALARMS TOOK OUT OF SCOPE, AUX. BLDG SUMP PUMPS & ASSOCIATED PIPING & LEVEL ALARMS.
DRAWN BY: JLB
DATE: 12-7-07
PREPARED BY: WJI
DATE: 12-7-07
REVIEWED BY: SRM
DATE: 12-11-07

2
REVISED (6X2) BOUNDARY TO INCLUDE WASTE HOLD-UP TK VENTLINE AND OVERFLOW.
DRAWN BY: JLB
DATE: 1-29-08
PREPARED BY: WJO
DATE: 1-29-08
REVIEWED BY: SRM
DATE: 2-1-08

REFERENCE NF-39248 REV. 77

This map / document is a tool to assist employees in the performance of their jobs. Your personal safety is provided for by using safety practices, procedures and equipment as described in safety training programs, manuals and SPAFs.

DWN | DATE | CHECKED | PROJECT NO. | APP'D & CERT. | FILMED

SIGNIFICANT NO. 8630 | 7500 7200 | ½ | 4410 | 1 | 8424
GROUP 1 2 3 4 5 CL 6

LICENSE RENEWAL BOUNDARY DWG
FLOW DIAGRAM UNIT 1 & 2
AUX & REACTOR BUILDING
FLOOR & EQUIPMENT DRAIN SYSTEMS

NORTHERN STATES POWER COMPANY
Xcel Energy
PRAIRIE ISLAND NUCLEAR GENERATING PLANT
RED WING, MINNESOTA

SCALE N/A | REV 2
LR-39248

D-057

$$USERNAME$$
$$$$SYSTIME$$$$