July 29, 2008

LICENSEE: Entergy Nuclear Operations, Inc.

FACILITY: Indian Point Nuclear Generating Unit Nos. 2 and 3

SUBJECT: SUMMARY OF TELEPHONE CONFERENCE CALL HELD ON JUNE 24, 2008, BETWEEN THE U.S. NUCLEAR REGULATORY COMMISSION AND ENTERGY NUCLEAR OPERATIONS, INC., RELATED TO THE INDIAN POINT NUCLEAR GENERATING UNIT NOS. 2 AND 3, LICENSE RENEWAL APPLICATION—BALANCE OF PLANT

The U.S. Nuclear Regulatory Commission (NRC or the staff) and representatives of Entergy Nuclear Operations Inc. (Entergy) held a telephone conference call on June 24, 2008, to obtain clarification on Entergy's recent annual update concerning the Indian Point Nuclear Generating Unit Nos. 2 and 3 (IP2 and IP3), license renewal application (LRA). By letter dated June 11, 2008, Entergy submitted an annual update to LRA. The staff reviewed the information contained therein, and requested additional information/clarification on a few items.

Enclosure 1 provides a listing of the participants, and Enclosure 2 contains the items discussed with the applicant, including a brief description of their resolutions.

The applicant had an opportunity to comment on this summary.

\RA

Kimberly Green, Safety Project Manager
Projects Branch 2
Division of License Renewal
Office of Nuclear Reactor Regulation

Docket Nos. 50-247 and 50-286

Enclosure:
As stated

cc w/encl: See next page

July 29, 2008

LICENSEE: Entergy Nuclear Operations, Inc.

FACILITY: Indian Point Nuclear Generating Unit Nos. 2 and 3

SUBJECT: SUMMARY OF TELEPHONE CONFERENCE CALL HELD ON JUNE 24, 2008, BETWEEN THE U.S. NUCLEAR REGULATORY COMMISSION AND ENTERGY NUCLEAR OPERATIONS, INC., RELATED TO THE INDIAN POINT NUCLEAR GENERATING UNIT NOS. 2 AND 3, LICENSE RENEWAL APPLICATION—BALANCE OF PLANT

The U.S. Nuclear Regulatory Commission (NRC or the staff) and representatives of Entergy Nuclear Operations Inc. (Entergy) held a telephone conference call on June 24, 2008, to obtain clarification on Entergy's recent annual update concerning the Indian Point Nuclear Generating Unit Nos. 2 and 3 (IP2 and IP3), license renewal application (LRA). By letter dated June 11, 2008, Entergy submitted an annual update to LRA. The staff reviewed the information contained therein, and requested additional information/clarification on a few items.

Enclosure 1 provides a listing of the participants, and Enclosure 2 contains the items discussed with the applicant, including a brief description of their resolutions.

The applicant had an opportunity to comment on this summary.

\RA

Kimberly Green, Safety Project Manager
Projects Branch 2
Division of License Renewal
Office of Nuclear Reactor Regulation

Docket Nos. 50-247 and 50-286

Enclosure:
As stated

cc w/encl: See next page
DISTRIBUTION: See next page

ADAMS Accession No.: ML082050276

OFFICE	LA:DLR	PM:RPB2:DLR	BC:RPB2:DLR
NAME	SFigueroa	KGreen	RFranovich (JRowley for)
DATE	07/24/08	07/25/08	07/29/08

OFFICIAL RECORD COPY

TELEPHONE CONFERENCE CALL
INDIAN POINT NUCLEAR GENERATING UNIT NOS. 2 AND 3
LICENSE RENEWAL APPLICATION

LIST OF PARTICIPANTS
JUNE 24, 2008

PARTICIPANTS	AFFILIATIONS
Kim Green	U.S. Nuclear Regulatory Commission (NRC)
Stan Gardocki	NRC
Mike Stroud	Entergy Nuclear Operations, Inc. (Entergy)
Don Fronabarger	Entergy
Ted Ivy	Entergy
John Curry	Entergy
Charlie Caputo	Entergy
Charlie Jackson	Entergy

ENCLOSURE 1

INDIAN POINT NUCLEAR GENERATING UNIT NOS. 2 AND 3
LICENSE RENEWAL APPLICATION
ANNUAL UPDATE – BALANCE OF PLANT
JUNE 24, 2008

Station Air System:

The applicant eliminated the station air compressor housing as a component type subject to an aging management review (AMR), but did not provide any reason for the elimination. The staff inquired about this elimination. Entergy stated that station air penetrates containment, so originally it placed the entire station air system in scope for 10 CFR 54.4(a)(2). However, later Entergy found a seismic anchor just outside of containment; therefore, the compressor does not need to be in scope.

Expansion Joints:

Expansion joints for IP3 have been added as a component type subject to an AMR in the condensate suction pump system. Similar expansion joints exist for IP2. The staff requested clarification on whether the expansion joints for IP2 should be subject to an AMR with material type "elastomer" exposed to an internal environment of treated water. Entergy clarified that the IP2 expansion joints are within the scope of license renewal and subject to an AMR, and are evaluated with the condensate system.

Letter to Entergy Nuclear Operations, Inc. from K. Green, dated July 29, 2008

DISTRIBUTION:

SUBJECT: SUMMARY OF TELEPHONE CONFERENCE CALL HELD ON JUNE 24, 2008, BETWEEN THE U.S. NUCLEAR REGULATORY COMMISSION AND ENTERGY NUCLEAR OPERATIONS, INC., RELATED TO THE INDIAN POINT NUCLEAR GENERATING UNIT NOS. 2 AND 3, LICENSE RENEWAL APPLICATION—BALANCE OF PLANT

HARD COPY:
DLR RF

E-MAIL:
PUBLIC
RidsNrrDlr
RidsNrrDlrRpb1
RidsNrrDlrRpb2
RidsNrrDlrRer1
RidsNrrDlrRer2
RidsNrrDlrRerb
RidsNrrDlrRpob
RidsNrrDciCvib
RidsNrrDciCpnb
RidsNrrDraAfpb
RidsNrrDraAplb
RidsNrrDeEmcb
RidsNrrDeEeeb
RidsNrrDssSrxb
RidsNrrDssSbpb
RidsNrrDssScvb
RidsOgcMailCenter

RFranovich	EDacus, OCA
BPham	GMeyer, RI
KGreen	MMcLaughlin, RI
JBoska	NMcNamara, RI
RAuluck	DScrenci, RI OPA
KChang	NSheehan, RI OPA
MKowal	PCataldo, RI
STurk, OGC	CHott, RI
LSubin, OGC	DJackson, RI
BMizuno, OGC	BWelling, RI
SBurnell, OPA	ECobey, RI
DMcIntyre, OPA	MCox, RI
TMensah, OEDO	RConte, RI

Indian Point Nuclear Generating
Unit Nos. 2 and 3

cc:

Senior Vice President
Entergy Nuclear Operations, Inc.
P.O. Box 31995
Jackson, MS 39286-1995

Vice President Oversight
Entergy Nuclear Operations, Inc.
P.O. Box 31995
Jackson, MS 39286-1995

Senior Manager, Nuclear Safety & Licensing
Entergy Nuclear Operations, Inc.
P.O. Box 31995
Jackson, MS 39286-1995

Senior Vice President and COO
Entergy Nuclear Operations, Inc.
440 Hamilton Avenue
White Plains, NY 10601

Assistant General Counsel
Entergy Nuclear Operations, Inc.
440 Hamilton Avenue
White Plains, NY 10601

Manager, Licensing
Entergy Nuclear Operations, Inc.
Indian Point Energy Center
450 Broadway, GSB
P.O. Box 249
Buchanan, NY 10511-0249

Mr. Paul D. Tonko
President and CEO
New York State Energy, Research, and Development Authority
17 Columbia Circle
Albany, NY 12203-6399

Mr. John P. Spath
New York State Energy, Research, and Development Authority
17 Columbia Circle
Albany, NY 12203-6399

Mr. Paul Eddy
New York State Department of Public Service
3 Empire State Plaza
Albany, NY 12223-1350

Regional Administrator, Region I
U.S. Nuclear Regulatory Commission
475 Allendale Road
King of Prussia, PA 19406

Senior Resident Inspector's Office
Indian Point 2 and 3
U.S. Nuclear Regulatory Commission
P.O. Box 59
Buchanan, NY 10511

Mr. Charles Donaldson, Esquire
Assistant Attorney General
New York Department of Law
120 Broadway
New York, NY 10271

Mr. Raymond L. Albanese
Four County Coordinator
200 Bradhurst Avenue
Unit 4 Westchester County
Hawthorne, NY 10532

Mayor, Village of Buchanan
236 Tate Avenue
Buchanan, NY 10511

Mr. William DiProfio
PWR SRC Consultant
48 Bear Hill Road
Newton, NH 03858

Mr. Garry Randolph
PWR SRC Consultant
1750 Ben Franklin Drive, 7E
Sarasota, FL 34236

cc:

Mr. William T. Russell
PWR SRC Consultant
400 Plantation Lane
Stevensville, MD 21666-3232

Mr. Jim Riccio
Greenpeace
702 H Street, NW
Suite 300
Washington, DC 20001

Mr. Phillip Musegaas
Riverkeeper, Inc.
828 South Broadway
Tarrytown, NY 10591

Mr. Mark Jacobs
IPSEC
46 Highland Drive
Garrison, NY 10524

Mr. R. M. Waters
Technical Specialist Licensing
450 Broadway
P.O. Box 0249
Buchanan, NY 10511-0249

Mr. Sherwood Martinelli
351 Dyckman Street
Peekskill, NY 10566

Ms. Susan Shapiro, Esq.
21 Perlman Drive
Spring Valley, NY 10977

Mr. John Sipos
Assistant Attorney General
New York State Department of Law
Environmental Protection Bureau
The Capitol
Albany, NY 12224

Robert Snook
Assistant Attorney General
Office of the Attorney General
State of Connecticut
55 Elm Street
P.O. Box 120
Hartford, CT 06141-0120

Ms. Kathryn M. Sutton, Esq.
Morgan, Lewis & Bockius, LLP
1111 Pennsylvania Avenue, NW
Washington, DC 20004

Mr. Paul M. Bessette, Esq.
Morgan, Lewis & Bockius, LLP
1111 Pennsylvania Avenue, NW
Washington, DC 20004

Mr. Martin J. O'Neill, Esq.
Morgan, Lewis & Bockius, LLP
1111 Pennsylvania Avenue, NW
Washington, DC 20004

The Honorable Nita Lowey
222 Mamaroneck Avenue, Suite 310
White Plains, NY 10605

Ms. Joan Leary Matthews
Senior Counsel for Special Projects
Office of General Counsel
NYS Department of Environmental
Conservation
625 Broadway
Albany, NY 12233-5500