

3.6 CONTAINMENT SYSTEMS

3.6.9 Shield Building Ventilation System (SBVS)

LCO 3.6.9 Two SBVS trains shall be OPERABLE.

APPLICABILITY: MODES 1, 2, 3, and 4.

ACTIONS

CONDITION	REQUIRED ACTION	COMPLETION TIME
A. One SBVS train inoperable.	A.1 Restore SBVS train to OPERABLE status.	7 days
B. Required Action and associated Completion Time not met.	B.1 Be in MODE 3.	6 hours
	<u>AND</u> B.2 Be in MODE 5.	36 hours

SURVEILLANCE REQUIREMENTS

SURVEILLANCE	FREQUENCY
SR 3.6.9.1 Operate each SBVS train for ≥ 15 minutes with heaters operating.	31 days

ACTIONS (continued)

CONDITION	REQUIRED ACTION	COMPLETION TIME
C. Required Action and associated Completion Time not met.	C.1 Be in MODE 3.	6 hours
	<u>AND</u> C.2 Be in MODE 5.	36 hours

SURVEILLANCE REQUIREMENTS

SURVEILLANCE	FREQUENCY
SR 3.7.12.1 Operate each ABSVS train for ≥ 15 minutes with the heaters operating.	31 days
SR 3.7.12.2 Perform required ABSVS filter testing in accordance with the Ventilation Filter Testing Program (VFIP).	In accordance with the VFIP
SR 3.7.12.3 Verify each ABSVS train can produce a negative pressure within 6 minutes after initiation.	92 days
SR 3.7.12.4 Verify each ABSVS train actuates on an actual or simulated actuation signal.	24 months

ACTIONS (continued)

CONDITION	REQUIRED ACTION	COMPLETION TIME
C. Both SFPSVS trains inoperable.	C.1 Suspend movement of irradiated fuel assemblies in the spent fuel pool enclosure.	Immediately

SURVEILLANCE REQUIREMENTS

SURVEILLANCE	FREQUENCY
SR 3.7.13.1 Operate each SFPSVS train for \geq 15 minutes with the heaters operating.	31 days
SR 3.7.13.2 Perform required SFPSVS filter testing in accordance with the Ventilation Filter Testing Program (VFIP).	In accordance with the VFIP
SR 3.7.13.3 Verify each SFPSVS train actuates on an actual or simulated actuation signal.	24 months
SR 3.7.13.4 Verify the SFPSVS fan in each train delivers 4680 to 5720 cfm.	24 months on a STAGGERED TEST BASIS

5.5 Programs and Manuals (continued)

5.5.9 Ventilation Filter Testing Program (VFIP)

A program shall be established to implement the following required testing of the Control Room Special Ventilation System (CRSVS), Auxiliary Building Special Ventilation System (ABSVS), Shield Building Ventilation System (SBVS), and the Spent Fuel Pool Special and Inservice Purge Ventilation System (SFPSIPVS) at least once each 24 months.

Demonstrate for the ABSVS, SBVS, CRSVS, and SFPSIPVS systems that:

- a. An inplace DOP test of the high efficiency particulate air (HEPA) filters shows a penetration and system bypass $< 0.05\%$ (for DOP, particles having a mean diameter of 0.7 microns);
- b. A halogenated hydrocarbon test of the inplace charcoal adsorber shows a penetration and system bypass $< 0.05\%$;
- c. A laboratory test of a sample of the charcoal adsorber, when obtained as described in Regulatory Guide 1.52, Revision 2, shows the methyl iodide penetration less than: 1) 15% penetration for ABSVS, 2) 15% penetration for SBVS, 3) 7.5% penetration for the SFPSIPVS, and 4) 2.5% penetration for the CRSVS when tested in accordance with ASTM D3803-1989 at a temperature of 30°C and 95% relative humidity (RH);
- d. The pressure drop across the combined HEPA filters and the charcoal adsorbers is less than 6 inches of water at the system flowrate $\pm 10\%$; and
- e. A laboratory test of a sample of the charcoal adsorber shall have filter test face velocities greater than or equal to the following values for each system: 1) 54 fpm for the CRSVS, 2) 72 fpm for the ABSVS, 3) 47 fpm for the SBVS, and 4) 47 fpm for the SFPSIPVS.