BellefonteRAIsPEm Resource

From: Tanya Simms
Sent: Monday, July 28, 2008 8:30 AM
To: BellefonteRAIsPEm Resource
Subject: Request for Additional Information Letter No. 089 Related To SRP Section 07.05 for the Bellefonte Units 3 and 4 Combined License Application
Attachments: BEL-RAI-LTR-089.doc

Hearing Identifier: Bellefonte_COL_RAI_Public
Email Number: 68

Mail Envelope Properties (C4A4C9A16294FB4CBA5A36312D05FFAC0A9C71ED52)

Subject: Request for Additional Information Letter No. 089 Related To SRP Section 07.05 for the Bellefonte Units 3 and 4 Combined License Application
Sent Date: 7/28/2008 8:29:55 AM
Received Date: 7/28/2008 8:29:56 AM
From: Tanya Simms

Created By: Tanya.Simms@nrc.gov

Recipients:
"BellefonteRAIsPEm Resource" <BellefonteRAIsPEm.Resource@nrc.gov>
Tracking Status: None

Post Office: HQCLSTR02.nrc.gov

Files	**Size**	**Date & Time**
MESSAGE	3	7/28/2008 8:29:56 AM
BEL-RAI-LTR-089.doc	50682	

Options
Priority: Standard
Return Notification: No
Reply Requested: Yes
Sensitivity: Normal
Expiration Date:
Recipients Received:

July 28, 2008

Ms. Andrea L. Sterdis
Manager, Nuclear Licensing & Industry Affairs
Nuclear Generation Development & Construction
Tennessee Valley Authority
1101 Market Street
Chattanooga, Tennessee 37402-2801

SUBJECT: REQUEST FOR ADDITIONAL INFORMATION LETTER NO. 089 RELATED TO SRP SECTION 07.05 FOR THE BELLEFONTE UNITS 3 AND 4 COMBINED LICENSE APPLICATION

Dear Ms. Sterdis:

By letter dated October 30, 2007, as supplemented by letters dated November 2, 2007, January 8, 2008 and January 14, 2008, Tennessee Valley Authority (TVA) submitted its application to the U. S. Nuclear Regulatory Commission (NRC) for a combined license (COL) for two AP1000 advance passive pressurized water reactors pursuant to 10 CFR Part 52. The NRC staff is performing a detailed review of this application to enable the staff to reach a conclusion on the safety of the proposed application.

The NRC staff has identified that additional information is needed to continue portions of the review. The staff's request for additional information (RAI) is contained in the enclosure to this letter.

To support the review schedule, you are requested to respond within 45 days of the date of this letter. If changes are needed to the final safety analysis report, the staff requests that the RAI response include the proposed wording changes.

If you have any questions or comments concerning this matter, you may contact me at 301-415-1387 or you may contact Joesph Sebrosky, the lead project manager for the Bellefonte combined license at 301-415-1132.

Sincerely,

/**RA**/

Tanya Simms, Project Manager
AP1000 Projects Branch 1
Division of New Reactor Licensing
Office of New Reactors

Docket Nos. 52-014
52-015

Enclosure:
Request for Additional Information

CC: see next page

If you have any questions or comments concerning this matter, you may contact me at 301-415-1387 or you may contact Joesph Sebrosky, the lead project manager for the Bellefonte combined license at 301-415-1132.

Sincerely,

/**RA**/

Tanya Simms, Project Manager
AP1000 Projects Branch 1
Division of New Reactor Licensing
Office of New Reactors

Docket Nos. 52-014
52-015
ERAI Tracking No. 537

Enclosure:
Request for Additional Information

Distribution:

Public	TJackson	BHughes
RidsNroDnrlNwe1	SCoffin	MComar
RidsNroLAKGoldstein	TSimms	AHodgdon
RidsOgcMailCenter	BAnderson	RJoshi
RidsAcrsAcnwMailCenter	JSebrosky	PMoulding
RidsRgn2MailCenter	RidsNroDnrlNwe2	WRoggenbrodt

NRO-002

OFFICE	ICE1/BC	NWE1/PM	OGC	NWE1/L-PM
NAME	TJackson *	TSimms*	PMoulding*	JSebrosky*
DATE	7/07/08	7/07/08	7/12/08	7/28/08

*Approval captured electronically in the electronic RAI system.

OFFICIAL RECORD COPY

Request for Additional Information No. 537 Revision 0
Bellefonte Units 3 and 4
Tennessee Valley Authority
Docket No. 52-014 and 52-015
SRP Section: 07.05 - Information Systems Important to Safety
Application Section: Chap 7.5

QUESTION from Instrumentation, Controls and Electrical Engineering 1 (ICE1)

07.05-1

Table 7.5-1, "Post-Accident Monitoring System," (Sheets 3 and 12 of 12) and Table 7.5-8, "Summary of Type E Variables," of AP1000 Design Control Document (DCD), Revision 16, contain variables to monitor the meteorological parameters and environs radiation and radioactivity. These variables are defined as "site specific" in the DCD. Please identify where the combined license application addresses these site-specific variables, consistent with Regulatory Guide 1.97, Rev. 3, or explain what alternative approach the applicant is proposing.