

TENNESSEE VALLEY AUTHORITY

CHATTANOOGA, TENNESSEE 37401
400 Chestnut Street Tower II

July 2, 1981

Mr. James P. O'Reilly, Director
Office of Inspection and Enforcement
U.S. Nuclear Regulatory Commission
Region II - Suite 3100
101 Marietta Street
Atlanta, Georgia 30303



Dear Mr. O'Reilly:

OFFICE OF INSPECTION AND ENFORCEMENT BULLETIN 79-03A - RII:JPO 50-327,
-328, -390, -391, -438, -439, -566, AND -567 - SEQUOYAH, WATTS EAR,
BELLEFONTE, AND YELLOW CREEK NUCLEAR PLANTS

The subject bulletin dated April 4, 1980, required a response for all PWR licensees and permit holders. Our initial response was submitted August 5, 1980. Enclosed is an updated response for Sequoyah, Watts Bar, Bellefonte, and Yellow Creek Nuclear Plants. We expect to submit further information on Watts Bar by September 1, 1981.

If you have any questions, please get in touch with D. L. Lambert at FTS 857-2587.

Very truly yours,

TENNESSEE VALLEY AUTHORITY

L. M. Mills, Manager
Nuclear Regulation and Safety

Enclosure

cc: Division of Reactor Construction
Inspection (Enclosure)
Office of Inspection and Enforcement
U.S. Nuclear Regulatory Commission
Washington, DC 20555

*TEII
S
1/1*

8107240427 810702
PDR ADOCK 05000327
PDR

ENCLOSURE

SEQUOYAH, WATTS BAR, BELLEFONTE, AND YELLOW CREEK NUCLEAR PLANTS
RESPONSE TO IE BULLETIN 79-03A

Sequoyah, Bellefonte, and Yellow Creek Nuclear Plants

SA-312 and A-312, type 300 series fusion welded pipe is not used or planned for use in safety-related systems subject to design stresses greater than 85 percent of the code allowable stresses.

Watts Bar Nuclear Plant

SA-312 and A-312, type 300 series fusion welded pipe is not used or planned for use in safety-related Balance of Plant systems subject to design stresses greater than 85 percent of code allowable stresses.

Westinghouse has identified piping associated with the Containment Spray pumps at Watts Bar that may be subject to stresses greater than 85 percent of the code allowable stresses. Westinghouse is evaluating this potential problem.