

TENNESSEE VALLEY AUTHORITY

CHATTANOOGA TENNESSEE 37401
400 Chestnut Street Tower II

August 11 1981

AG: 21

Mr. James P. O'Reilly, Director
Office of Inspection and Enforcement
U.S. Nuclear Regulatory Commission
Region II - Suite 3100
101 Marietta Street
Atlanta, Georgia 30303



Dear Mr. O'Reilly:

WATTS BAR NUCLEAR PLANT UNITS 1 AND 2 - IMPROPER MATERIALS USED IN
AUXILIARY BOARD ROOM AIR CONDITIONING SYSTEM - NCR 2597R - REVISED
FINAL REPORT, SUPPLEMENT 1

The subject deficiency was initially reported to NRC-OIE Inspector R. W. Wright on September 15, 1980, in accordance with 10 CFR 50.55(e). A final report was submitted on October 14, 1980. That report stated that TVA would replace all type M copper tubing with type K copper tubing. Subsequent to that report, TVA reevaluated this deficiency and plans to take alternate corrective actions. Enclosed is our revised final report, supplement 1. We plan to submit our next report by September 4, 1981. This matter was discussed with Inspector R. V. Crlenjak on August 6, 1981.

If you have any questions, please get in touch with D. L. Lambert at
PTS 857-2581.

Very truly yours,

TENNESSEE VALLEY AUTHORITY

A handwritten signature in cursive script that reads "L. M. Mills".

L. M. Mills, Manager
Nuclear Regulation and Safety

Enclosure

cc: Mr. Victor Stello, Director (Enclosure)
Office of Inspection and Enforcement
U.S. Nuclear Regulatory Commission
Washington, DC 20555

IE 27
S/11

ENCLOSURE

WATTS BAR NUCLEAR PLANT UNITS 1 AND 2
IMPROPER MATERIALS USED IN AUXILIARY BOARD ROOM AIR CONDITIONING SYSTEM
NCR 2597R
10 CFR 50.55(e)
REVISED FINAL REPORT, SUPPLEMENT 1

Description of Deficiency

The Auxiliary Board Room Air Conditioning System was assembled onsite by TVA using copper tubing of a type not specified for that application. M type copper was used in place of K type copper tubing. ASTM B88 M type copper tubing may not be acceptable for use in this system because the minimum design pressure of 350 psi is in excess of the allowable working stress of 327 psi for type M tubing.

Interim Progress

The quality assurance program controlling work on this system has been revised to include a mandatory materials verification hold point at the point of fabrication and/or installation to prevent any reoccurrence of this problem. TVA now plans to verify, through a sampling program, that the installed type M copper tubing is adequate for use in the Auxiliary Board Room Air Conditioning System. Further details on the specific tests to be conducted will be included in our next report.